


ORIGINAL



**Florida  
Power**  
CORPORATION

**JAMES A. MCGEE**  
SENIOR COUNSEL

January 4, 1999

Ms. Blanca S. Bayó, Director  
Division of Records and Reporting  
Florida Public Service Commission  
2540 Shumard Oak Boulevard  
Tallahassee, Florida 32399-0850

Dear Ms. Bayó:

Pursuant to Commission Rule 25-6.438, F.A.C., enclosed for filing are an original and fifteen copies of Florida Power Corporation's Non-Firm Electric Service Report as of December 1998.

Please acknowledge your receipt of the above filing on the enclosed copy of this letter and return to the undersigned. Thank you for your assistance in this matter.

Very truly yours,

James A. McGee

- ACK \_\_\_\_\_
- AFA   1
- APP \_\_\_\_\_
- CAF \_\_\_\_\_
- CMU \_\_\_\_\_
- CTR \_\_\_\_\_
- EAG \_\_\_\_\_
- LEG   1
- LIN \_\_\_\_\_
- OPC \_\_\_\_\_
- RCH \_\_\_\_\_
- SEC   1
- WAS \_\_\_\_\_
- OTH \_\_\_\_\_

JAM/kma  
Enclosure

LO-2: 10-1-99 66

GENERAL OFFICE

DOCUMENT NUMBER-DATE

00102 JAN-5 99

FPSC-RECORDS/REPORTING

ORIGINAL

**FLORIDA POWER  
CORPORATION  
NON-FIRM  
ELECTRIC SERVICE  
REPORT  
DECEMBER 1998**

<b>TYPES OF SERVICE</b>	<b>DECEMBER 1998 AMOUNT OF NON-FIRM SERVICE ON SYSTEM (MWs)</b>	<b>MAXIMUM LEVEL OF COST-EFFECTIVE NON-FIRM LOAD (MW)</b>
Load Management	898	1,229
Interruptible	288	324
Curtailed	18	20
Standby Generation	20	20
Total MWs	1,224	1,593

**Notes:**

1. All values at meter
2. All values assumed to be coincident with the winter system peak