

# AUSLEY & McMULLEN

ATTORNEYS AND COUNSELORS AT LAW

227 SOUTH CALHOUN STREET  
P.O. BOX 391 (ZIP 32302)  
TALLAHASSEE, FLORIDA 32301  
(850) 224-9115 FAX (850) 222-7560

July 9, 1999

HAND DELIVERED

RECEIVED-FPSC  
JUL -9 PM 2:50  
RECORDS AND REPORTING

Ms. Blanca S. Bayo, Director  
Division of Records and Reporting  
Florida Public Service Commission  
2540 Shumard Oak Boulevard  
Tallahassee, Florida 32399-0850

Re: Fuel and Purchased Power Cost Recovery Clause with Generating Performance Incentive Factor; FPSC Docket No. 990001-EI


Dear Ms. Bayo:


Enclosed for filing in the above docket on behalf of Tampa Electric Company are the original and ten (10) copies of supplemental Prepared Direct Testimony and Exhibit (CTAH-1) of Chonta T. A. Haynes regarding Generating Performance Incentive Factor (GPIF) for the period April 1998 - September 1998. This testimony and exhibit were inadvertently omitted from the company's April 1, 1999 filing.

Please acknowledge receipt and filing of the above by stamping the duplicate copy of this letter and returning same to this writer.

Thank you for your assistance in connection with this matter.

Sincerely,

  
James D. Beasley

RECEIVED & FILED  
  
FPSC-BUREAU OF RECORDS

FA a  
PP \_\_\_\_\_  
CAF \_\_\_\_\_  
CMU \_\_\_\_\_  
CTR \_\_\_\_\_  
EAG Bolmann  
LEG 3rag  
MAS \_\_\_\_\_  
OPC \_\_\_\_\_  
RAR \_\_\_\_\_  
SEC 1  
WAW \_\_\_\_\_  
OTH \_\_\_\_\_

JDB/pp  
Enclosures

cc: All Parties of Record (w/enc.)

DOCUMENT NUMBER-DATE

08194 JUL-99

FPSC-RECORDS/REPORTING

CERTIFICATE OF SERVICE

I HEREBY CERTIFY that a true copy of the foregoing Testimony and Exhibit (CTAH-1),  
filed on behalf of Tampa Electric Company, has been furnished by U. S. Mail or hand delivery (\*)  
on this 9<sup>th</sup> day of July, 1999 to the following:

Ms. Leslie J. Paugh\*  
Staff Counsel  
Division of Legal Services  
Florida Public Service Commission  
2540 Shumard Oak Boulevard  
Tallahassee, FL 32399-0863

Mr. John W. McWhirter  
McWhirter, Reeves, McGlothlin,  
Davidson & Bakas  
Post Office Box 3350  
Tampa, FL 33601

Mr. James A. McGee  
Senior Counsel  
Florida Power Corporation  
Post Office Box 14042  
St. Petersburg, FL 33733

Mr. Matthew M. Childs  
Steel Hector & Davis  
Suite 601  
215 South Monroe Street  
Tallahassee, FL 32301

Mr. Joseph A. McGlothlin  
Ms. Vicki Gordon Kaufman  
McWhirter, Reeves, McGlothlin,  
Davidson, Rief & Bakas  
117 S. Gadsden Street  
Tallahassee, FL 32301

Ms. Suzanne Brownless  
Suzanne Brownless P.A.  
1311-B Paul Russell Road #201  
Tallahassee, FL 32301

Mr. Jack Shreve  
Office of Public Counsel  
Room 812  
111 West Madison Street  
Tallahassee, FL 32399-1400

Mr. Jeffrey A. Stone  
Beggs & Lane  
Post Office Box 12950  
Pensacola, FL 32576

Mr. Kenneth A. Hoffman  
Rutledge, Ecenia, Underwood,  
Purnell & Hoffman  
Post Office Box 551  
Tallahassee, FL 32302-0551

Mr. Norman H. Horton, Jr.  
Mr. Floyd R. Self  
Messer, Caparello & Self, P.A.  
Post Office Box 1876  
Tallahassee, FL 32302-1876

  
ATTORNEY

(TRUE-UP)

1                   BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

2                                   PREPARED DIRECT TESTIMONY

3   OF

4   CHONTA T.A. HAYNES

5  
6 Q. Will you please state your name, business address, and  
7 employer?

8  
9 A. My name is Chonta T.A. Haynes and my business address is  
10 Post Office Box 111, Tampa, Florida 33601. I am employed  
11 by Tampa Electric Company.

12  
13 Q. Please furnish us with a brief outline of your educational  
14 background and business experience.

15  
16 -A. I am an Electrical Engineering graduate of Georgia  
17 Institute of Technology and the University of Miami (FL).  
18 My bachelors degree was obtained in 1983 from Georgia Tech  
19 and I received my masters degree in 1991 from U of M. My  
20 career spans 15 years with various engineering positions in  
21 the utility and automotive industries. I am currently  
22 employed by Tampa Electric Company as a Senior Engineer in  
23 the Operation Services group.

1 Q. What are your current responsibilities?

2

3 A. I am responsible for unit performance analysis and  
4 reporting of generation statistics.

5

6 Q. What is the purpose of your testimony?

7

8 A. My testimony presents the actual performance results from  
9 unit equivalent availability and station heat rate used to  
10 determine the Generating Performance Incentive Factor  
11 (GPIF) for the period April 1998 through September 1998.  
12 I will also compare these results to the targets  
13 established prior to the beginning of the period.

14

15 Q. Have you prepared an exhibit with the results for this six  
16 month period?

17

18 A. Yes. The exhibit entitled "Tampa Electric Company, April  
19 1998 - September 1998, Generating Performance Incentive  
20 Factor Results" consists of 28 pages and is filed with this  
21 testimony (Have identified as Exhibit CTAH-1).

22

23 Q. Have you calculated the results of Tampa Electric Company  
24 for its performance under the GPIF during this period?

25

1 A. Yes, I have. This is shown on page 4 of my exhibit. Based  
2 upon -.986 GPIF points, the result is a penalty amount of  
3 \$229,924 for the period.  
4  
5 Q. Please proceed with your review of the actual results for  
6 the April 1998 - September 1998 period.  
7  
8 A. On page 3 of my exhibit, the actual average common equity  
9 for the period is shown on line 8 as \$1,162,139,343. This  
10 produces the maximum penalty or reward figure of \$2,331,887  
11 as shown on line 15, page 3.  
12  
13 Q. Will you explain how you arrived at the actual equivalent  
14 availability results for the six units included within the  
15 GPIF?  
16  
17 A. Yes, I will. Operating data on each of our units is filed  
18 monthly with the Florida Public Service Commission on the  
19 Actual Unit Performance data form. Additionally, outage  
20 information is reported to the Commission on a monthly  
21 basis. A summary of this data for the six months provides  
22 the basis for the GPIF.  
23  
24  
25

1 Q. Are the equivalent availability results shown on page 6,  
2 column 2, directly applicable to the GPIF table?

3  
4 A. Not exactly. Adjustments to equivalent availability may be  
5 required as noted in section 4.3.3 of the GPIF Manual. The  
6 actual equivalent availability including the required  
7 adjustment is shown on page 6 of my exhibit. The necessary  
8 adjustments as prescribed in the GPIF Manual are further  
9 defined by a letter dated October 23, 1981, from Mr. J.H.  
10 Hoffsis of the Commission's Staff. The adjustments for  
11 each unit are as follows:

12  
13 Gannon Unit No. 5

14 On this unit, no planned outage hours were originally  
15 scheduled to fall within the Summer 1998 period and none in  
16 fact occurred. Consequently, the actual equivalent  
17 availability requires no adjustment as shown on page 7 of  
18 my exhibit.

19  
20 Gannon Unit No. 6

21 On this unit, 336 planned outage hours were originally  
22 scheduled to fall within the Summer 1998 period. Due to a  
23 revision of the outage schedule, this work was accomplished  
24 prior to the beginning of the period, and no planned outage  
25 hours fell within the period. Consequently, the actual

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

equivalent availability of 82.0% is adjusted to 75.8%, as shown on page 8 of my exhibit.

Big Bend Unit 1

On this unit 336 planned outage hours were originally scheduled to fall within the Summer 1998 period. Due to a revision of the outage schedule, this outage occurred after the Summer period, and no planned outage hours fell within the period. Consequently, the actual equivalent availability of 85.5% is adjusted to 79.0% as shown on page 9 of my exhibit.

Big Bend Unit No. 2

On this unit no planned outage hours were originally scheduled to fall within the Summer 1998 period. Due to a revision of the outage schedule, this outage was moved forward and 913.2 planned outage hours fell within the period. Consequently, the actual equivalent availability of 67.8% is adjusted to 85.6% as shown on page 10 of my exhibit.

Big Bend Unit No. 3

On this unit 791 planned outage hours were originally scheduled to fall within the Summer 1998 period. Due to a reprioritization of work, the outage was shortened and

1 393.8 planned outage hours fell within the period.  
2 Consequently, the actual equivalent availability of 71.4%  
3 is adjusted to 64.3% as shown on page 11 of my exhibit.  
4

5 Big Bend Unit No. 4

6 On this unit no planned outage hours were scheduled to fall  
7 within the Summer 1998 period, and none in fact occurred.  
8 Consequently, the actual equivalent availability of 89.2%  
9 requires no adjustment as shown on page 12 of my exhibit.  
10

11 Q. How did you arrive at the applicable equivalent  
12 availability points for each unit?  
13

14 A. The final adjusted equivalent availabilities for each unit  
15 are shown on page 6, column 4, of my exhibit. This number  
16 is entered into the respective Generating Performance  
17 Incentive Point (GPIP) Table for each particular unit on  
18 pages 21 through 26. Page 4 of my exhibit summarizes the  
19 equivalent availability points to be awarded or penalized.  
20

21 Q. Would you please explain the heat rate results relative to  
22 the GPIF?  
23

24 A. The actual heat rate and adjusted actual heat rate for the  
25 Gannon units and Big Bend Station are shown on page 6 of my



1 exhibit. The adjustment was developed based on the  
2 guidelines of section 4.3.16 of the GPIF Manual. This  
3 procedure is further defined by a letter dated October 23,  
4 1981, from Mr. J.H. Hoffsis of the FPSC Staff. The final  
5 adjusted actual heat rates are also shown on page 5 of my  
6 exhibit. This heat rate number is entered into the  
7 respective GPIF table for the particular unit, shown on  
8 pages 21 through 26. Page 4 of my exhibit summarizes the  
9 weighted heat rate and equivalent availability points to be  
10 awarded.

11

12 Q. Were any additional adjustments to heat rate required?

13

14 A. In order to assure compatibility of data, Big Bend Unit 3  
15 heat rates have been calculated in the standard fashion,  
16 without scrubber power. This methodology has been reviewed  
17 and approved by the PSC staff, to be employed until there  
18 is sufficient operational history with the scrubber to meet  
19 target preparation guidelines.

20

21 Q. Does this assure that the Big Bend 3 heat rate for the  
22 period is appropriate for comparison to its target and  
23 meets GPIF criteria?

24

25 A. Yes.

1 Q. What is the overall GPIF for Tampa Electric Company during  
2 this six month period?

3

4 A. This is shown on page 28 of my exhibit. Essentially, the  
5 weighting factors shown on page 4, column 3, plus the  
6 equivalent availability points and the heat rate points  
7 shown on page 4, column 4, are substituted within the  
8 equation. This resultant value,  $-.986$ , is then entered  
9 into the GPIF table on page 2. Using linear interpolation,  
10 a penalty amount of \$229,924 is calculated.

11

12 Q. Does this conclude your testimony?

13

14 A. Yes, it does.

15

16

17

18

19

20

21

22

23

24

25

TAMPA ELECTRIC COMPANY  
APRIL 1998 - SEPTEMBER 1998  
GENERATING PERFORMANCE INCENTIVE FACTOR  
RESULTS  
TABLE OF CONTENTS

<u>SCHEDULE</u>	<u>PAGE</u>
GPIF REWARD / PENALTY TABLE ACTUAL	2
GPIF CALCULATIONS OF MAXIMUM ALLOWED INCENTIVE DOLLARS	3
CALCULATIONS OF SYSTEM ACTUAL GPIF POINTS	4
GPIF UNIT PERFORMANCE SUMMARY, EQUIVALENT AVAILABILITY	5
GPIF UNIT PERFORMANCE SUMMARY, AVERAGE NET OPERATING HEAT RATE	5
GPIF UNIT PERFORMANCE DATA	6
GPIF ( EAF & HEAT RATE ) ADJUSTMENT COMPUTATIONS	7 - 18
PLANNED OUTAGE SCHEDULE - ACTUAL	19
CRITICAL PATH DIAGRAM	20
GENERATING PERFORMANCE INCENTIVE POINTS TABLES (ACTUAL)	21 - 26
COMPARISON OF GPIF TARGET VS ACTUAL PERFORMANCE	27
GENERATING PERFORMANCE INCENTIVE POINTS CALCULATIONS	28

**TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE  
REWARD / PENALTY TABLE - ACTUAL  
APRIL 1998 - SEPTEMBER 1998**

GENERATING PERFORMANCE INCENTIVE POINTS (GPIP)	FUEL SAVINGS / (LOSS) (\$000)	GENERATING PERFORMANCE INCENTIVE FACTOR (\$000)
+10	6,630.7	2,331.9
+9	5,967.6	2,098.7
+8	5,304.6	1,865.5
+7	4,641.5	1,632.3
+6	3,978.4	1,399.1
+5	3,315.4	1,165.9
+4	2,652.3	932.8
+3	1,989.2	699.6
+2	1,326.1	466.4
+1	663.1	233.2
0	0	0.0
-1	(972.8)	(233.2)
-2	(1,945.5)	(466.4)
-3	(2,918.3)	(699.6)
-4	(3,891.0)	(932.8)
-5	(4,863.8)	(1,165.9)
-6	(5,836.6)	(1,399.1)
-7	(6,809.3)	(1,632.3)
-8	(7,782.1)	(1,865.5)
-9	(8,754.8)	(2,098.7)
-10	(9,727.6)	(2,331.9)

	<div style="border: 1px solid black; padding: 5px; display: inline-block;"> <b>GPIP Points -0.986</b> </div>	<div style="border: 1px solid black; padding: 5px; display: inline-block;"> <b>REWARD DOLLARS (\$229,924)</b> </div>	
--	--	--	--

**TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE FACTOR  
CALCULATION OF MAXIMUM ALLOWED INCENTIVE DOLLARS  
ACTUAL  
APRIL 1998 - SEPTEMBER 1998**

Line 1	Beginning of period balance of common equity end of month common equity:	\$1,145,671,810
Line 2	Month of April 1998	\$1,131,405,751
Line 3	Month of May 1998	\$1,148,822,283
Line 4	Month of June 1998	\$1,168,109,175
Line 5	Month of July 1998	\$1,162,731,120
Line 6	Month of August 1998	\$1,182,491,844
Line 7	Month of September 1998	\$1,195,743,419
Line 8	(summation of line 1 through line 7 divided by 7)	\$1,162,139,343
Line 9	25 Basis points	0.0025
Line 10	Revenue expansion factor	61.3738%
Line 11	Maximum allowed incentive Dollars (Line 8 times line 9 divided by line 10 times 0.5)	\$2,366,929
Line 12	Jurisdictional Sales	8549852 MWH
Line 13	Total Sales	8678332 MWH
Line 14	Jurisdictional Separation Factor (Line 12 divided by line 13)	98.52%
Line 15	Maximum Allowed Jurisdictional Incentive Dollars (Line 11 times line 14)	\$2,331,887

**TAMPA ELECTRIC COMPANY  
CALCULATION OF SYSTEM GPIF POINTS  
APRIL 1998 - SEPTEMBER 1998  
ACTUAL**

<u>PLANT/UNIT</u>	<u>6 MO ADJ ACTUAL PERFORMANCE</u>	<u>WEIGHTING FACTOR %</u>	<u>UNIT POINTS</u>	<u>WEIGHTED UNIT POINTS</u>
GANNON 5	84.2% EAF	5.22%	-0.938	-0.049
GANNON 6	75.8% EAF	5.06%	-10.000	-0.506
BIG BEND 1	79.0% EAF	10.92%	2.188	0.239
BIG BEND 2	85.6% EAF	9.38%	-1.490	-0.140
BIG BEND 3	64.3% EAF	13.19%	-6.274	-0.828
BIG BEND 4	89.2% EAF	3.15%	-8.310	-0.262
GANNON 5	10321 ANOHR	7.58%	0.000	0.000
GANNON 6	10643 ANOHR	10.09%	-1.262	-0.127
BIG BEND 1	10117 ANOHR	11.15%	2.577	0.287
BIG BEND 2	9970 ANOHR	7.96%	7.059	0.562
BIG BEND 3	9899 ANOHR	9.38%	-1.723	-0.162
BIG BEND 4	9885 ANOHR	6.92%	0.000	0.000
				-0.986

GPIF REWARD

(\$229,924)

TAMPA ELECTRIC COMPANY  
GPIF TARGET AND RANGE SUMMARY

APRIL 1998 - SEPTEMBER 1998

EQUIVALENT AVAILABILITY

<u>PLANT/UNIT</u>	<u>WEIGHTING FACTOR (%)</u>	<u>EAF TARGET (%)</u>	<u>EAF MAX. (%)</u>	<u>RANGE MIN. (%)</u>	<u>MAX. FUEL SAVINGS (\$000)</u>	<u>MAX. FUEL LOSS (\$000)</u>	<u>EAF ADJUSTED ACTUAL %</u>	<u>ACTUAL FUEL SAVINGS/LOSS (\$000)</u>
GANNON 5	5.22%	84.8	87.9	78.9	346.2	(660.8)	84.2%	(62.0)
GANNON 6	5.06%	81.1	83.8	75.9	335.4	(823.9)	75.8%	(823.9)
BIG BEND 1	10.92%	78.3	81.5	72.0	724.0	(1,391.9)	79.0%	304.6
BIG BEND 2	9.38%	86.4	89.1	81.0	622.0	(1,212.2)	85.6%	(180.6)
BIG BEND 3	13.19%	68.8	72.3	61.7	874.4	(1,694.8)	64.3%	(1,063.4)
BIG BEND 4	3.15%	91.9	93.5	88.7	208.9	(424.2)	89.2%	(352.5)
GPIF SYSTEM	46.92%				3,110.9	(6,207.8)		

AVERAGE NET OPERATING HEAT RATE  
FOR  
GPIF COAL GENERATING UNITS

<u>PLANT/UNIT</u>	<u>WEIGHTING FACTOR (%)</u>	<u>ANOHR Btu/kwh</u>	<u>TARGET NOF</u>	<u>ANOHR TARGET RANGE</u>		<u>MAX. FUEL SAVINGS (\$000)</u>	<u>MAX. FUEL LOSS (\$000)</u>	<u>ACTUAL ADJUSTED ANOHR</u>	<u>ACTUAL FUEL SAVINGS/LOSS (\$000)</u>
				<u>MIN.</u>	<u>MAX.</u>				
GANNON 5	7.58%	10377	89.0	9899	10855	502.6	(502.6)	10321	0.0
GANNON 6	10.09%	10527	91.3	10127	10927	669.3	(669.3)	10643	(84.4)
BIG BEND 1	11.15%	10267	83.6	9901	10633	739.0	(739.0)	10117	190.5
BIG BEND 2	7.96%	10225	83.1	9895	10555	527.8	(527.8)	9970	372.6
BIG BEND 3	9.38%	9778	94.5	9436	10120	621.7	(621.7)	9899	(107.1)
BIG BEND 4	6.92%	9831	96.6	9643	10019	459.4	(459.4)	9885	0.0
GPIF SYSTEM	53.08%					3,519.8	(3,519.8)		

**TAMPA ELECTRIC COMPANY  
ACTUAL UNIT PERFORMANCE DATA  
APRIL 1998 - SEPTEMBER 1998**

<u>PLANT / UNIT</u>	<u>ACTUAL EAF %</u>	<u>ADJUSTMENTS (1) EAF %</u>	<u>EAF ADJUSTED ACTUAL %</u>
GANNON 5	84.2	0.0	84.2
GANNON 6	82.0	-6.2	75.8
BIG BEND 1	85.5	-6.5	79.0
BIG BEND 2	67.8	17.8	85.6
BIG BEND 3	71.4	-7.1	64.3
BIG BEND 4	89.2	0.0	89.2

<u>PLANT / UNIT</u>	<u>ACTUAL ANOHR Btu/kwh</u>	<u>ADJUSTMENTS (2) TO ANOHR Btu/kwh</u>	<u>ANOHR ADJUSTED ACTUAL Btu/kwh</u>
GANNON 5	10475	-154	10321
GANNON 6	10540	103	10643
BIG BEND 1	10225	-108	10117
BIG BEND 2	10101	-131	9970
BIG BEND 3	10228	-329	9899
BIG BEND 4	10074	-189	9885

(1) Documentation of adjustments to Actual EAF on pages 7 - 12

(2) Documentation of adjustments to Actual ANOHR on pages 13 - 18



TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
GANNON UNIT NO. 5  
APRIL 1998 - SEPTEMBER 1998

WEIGHTING FACTOR = 5.22%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4391.0	4391.0	4391.0
E.A.F.	84.8	84.2	84.2
P.O.H.	0.0	0.0	0.0
F.O.H. + E.F.O.H	555.0	499.7	499.7
M.O.H. + E.M.O.H	111.0	191.6	191.6
P.O.F.	0.0	0.0	0.0
E.F.O.F.	12.6	11.4	11.4
E.M.O.F.	2.5	4.4	4.4

-0.938 E. A. POINTS

ADJUSTMENTS TO E.A.F.

$$\frac{P.H. - TGT\ POH}{P.H. - ACT\ POH} \times (FOH + EFOH + MOH + EMOH) = \text{ADJUSTED EUOH}$$

$$\frac{4391 - 0}{4391 - 0} \times (210.7 + 289.0 + 41.3 + 150.3) = 691.3$$

$$\frac{0 + 691}{4391} \times 100 = 15.8$$

$$100.0 - 15.8 = 84.2$$

- PH = PERIOD HOURS
- EAF = EQUIVALENT AVAILABILITY FACTOR
- POH = PLANNED OUTAGE HOURS
- FOH = FORCED OUTAGE HOURS
- MOH = MAINTENANCE OUTAGE HOURS
- POF = PLANNED OUTAGE FACTOR
- EFOF = EQUIVALENT FORCED OUTAGE FACTOR
- EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
GANNON UNIT NO. 6  
APRIL 1998 - SEPTEMBER 1998

WEIGHTING FACTOR = 5.06%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4391.0	4391.0	4391.0
E.A.F.	81.1	82.0	75.8
P.O.H.	336.0	0.0	336.0
F.O.H. + E.F.O.H	292.0	451.2	416.7
M.O.H. + E.M.O.H	203.0	337.7	311.9
P.O.F.	7.7	0.0	7.7
E.F.O.F.	6.6	10.3	9.5
E.M.O.F.	4.6	7.7	7.1

-10.000 E. A. POINTS

ADJUSTMENTS TO E.A.F.

$$\frac{P.H. - TGT POH}{P.H. - ACT POH} \times ( FOH + EFOH + MOH + EMOH ) = \text{ADJUSTED EUOH}$$

$$\frac{4391 - 336}{4391 - 0} \times ( 22.2 + 429.0 + 195.1 + 142.6 ) = 728.5$$

$$\frac{336 + 729}{4391} \times 100 = 24.2$$

$$100.0 - 24.2 = 75.8$$

- PH = PERIOD HOURS
- EA.F = EQUIVALENT AVAILABILITY FACTOR
- POH = PLANNED OUTAGE HOURS
- FOH = FORCED OUTAGE HOURS
- MOH = MAINTENANCE OUTAGE HOURS
- EUOH = EQUIVALENT UNPLANNED OUTAGE HOURS
- POF = PLANNED OUTAGE FACTOR
- EFOF = EQUIVALENT FORCED OUTAGE FACTOR
- EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR
- EUOF = EQUIVALENT UNPLANNED OUTAGE FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
BIG BEND UNIT NO. 1  
APRIL 1998 - SEPTEMBER 1998

WEIGHTING FACTOR = 10.92%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4391.0	4391.0	4391.0
E.A.F.	78.3	85.5	79.0
P.O.H.	336.0	0.0	336.0
F.O.H. + E.F.O.H	413.0	468.8	432.9
M.O.H. + E.M.O.H	202.0	165.9	153.2
P.O.F.	7.7	0.0	7.7
E.F.O.F.	9.4	10.7	9.9
E.M.O.F.	4.6	3.8	3.5

2.188 E. A. POINTS

ADJUSTMENTS TO E.A.F.

$$\frac{\text{P.H.} - \text{TGT POH}}{\text{P.H.} - \text{ACT POH}} \times (\text{FOH} + \text{EFOH} + \text{MOH} + \text{EMOH}) = \text{ADJUSTED EUOH}$$

$$\frac{4391 - 336}{4391 - 0} \times (327.2 + 141.6 + 65.5 + 100.4) = 586.1$$

$$\frac{336 + 586}{4391} \times 100 = 21.0$$

$$100.0 - 21.0 = 79.0$$

PH = PERIOD HOURS  
EAF = EQUIVALENT AVAILABILITY FACTOR  
POH = PLANNED OUTAGE HOURS  
FOH = FORCED OUTAGE HOURS  
MOH = MAINTENANCE OUTAGE HOURS  
EUOH = EQUIVALENT UNPLANNED OUTAGE HOURS  
POF = PLANNED OUTAGE FACTOR  
EFOF = EQUIVALENT FORCED OUTAGE FACTOR  
EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR  
EUOF = EQUIVALENT UNPLANNED OUTAGE FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
BIG BEND UNIT NO. 2  
APRIL 1998 - SEPTEMBER 1998

WEIGHTING FACTOR = 9.38%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4391.0	4391.0	4391.0
E.A.F.	86.4	67.8	85.6
P.O.H.	0.0	913.2	0.0
F.O.H. + E.F.O.H	401.0	352.5	445.1
M.O.H. + E.M.O.H	195.0	148.4	187.4
P.O.F.	0.0	20.8	0.0
E.F.O.F.	9.1	8.0	10.1
E.M.O.F.	4.4	3.4	4.3

-1.490 E. A. POINTS

ADJUSTMENTS TO E.A.F.

$$\frac{\text{P.H.} - \text{TGT POH}}{\text{P.H.} - \text{ACT POH}} \times (\text{FOH} + \text{EFOH} + \text{MOH} + \text{EMOH}) = \text{ADJUSTED EUOH}$$

$$\frac{4391 - 0}{4391 - 913} \times (231.6 + 120.9 + 35.3 + 113.1) = 632.4$$

$$\frac{0 + 632}{4391} \times 100 = 14.4$$

$$100.0 - 14.4 = 85.6$$

PH = PERIOD HOURS  
EAF = EQUIVALENT AVAILABILITY FACTOR  
POH = PLANNED OUTAGE HOURS  
FOH = FORCED OUTAGE HOURS  
MOH = MAINTENANCE OUTAGE HOURS  
EUOH = EQUIVALENT UNPLANNED OUTAGE HOURS  
POF = PLANNED OUTAGE FACTOR  
EFOF = EQUIVALENT FORCED OUTAGE FACTOR  
EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR  
EUOF = EQUIVALENT UNPLANNED OUTAGE FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
BIG BEND UNIT NO. 3  
APRIL 1998 - SEPTEMBER 1998

WEIGHTING FACTOR = 13.19%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4391.0	4391.0	4391.0
E.A.F.	68.8	71.4	64.3
P.O.H.	791.0	393.8	791.0
F.O.H. + E.F.O.H	431.0	700.2	630.6
M.O.H. + E.M.O.H	150.0	159.9	144.0
P.O.F.	18.0	9.0	18.0
E.F.O.F.	9.8	15.9	14.4
E.M.O.F.	3.4	3.6	3.3

-6.274 E. A. POINTS

ADJUSTMENTS TO E.A.F.

$$\frac{\text{P.H.} - \text{TGT POH}}{\text{P.H.} - \text{ACT POH}} \times (\text{FOH} + \text{EFOH} + \text{MOH} + \text{EMOH}) = \text{ADJUSTED EUOH}$$

$$\frac{4391 - 791}{4391 - 394} \times (504.4 + 195.8 + 0.0 + 159.9) = 774.6$$

$$\frac{791 + 775}{4391} \times 100 = 35.7$$

$$100.0 - 35.7 = 64.3$$

- PH = PERIOD HOURS
- EAF = EQUIVALENT AVAILABILITY FACTOR
- POH = PLANNED OUTAGE HOURS
- FOH = FORCED OUTAGE HOURS
- MOH = MAINTENANCE OUTAGE HOURS
- EUOH = EQUIVALENT UNPLANNED OUTAGE HOURS
- POF = PLANNED OUTAGE FACTOR
- EFOF = EQUIVALENT FORCED OUTAGE FACTOR
- EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR
- EUOF = EQUIVALENT UNPLANNED OUTAGE FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
BIG BEND UNIT NO. 4  
APRIL 1998 - SEPTEMBER 1998

WEIGHTING FACTOR = 3.15%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4391.0	4391.0	4391.0
E.A.F.	91.9	89.2	89.2
P.O.H.	0.0	0.0	0.0
F.O.H. + E.F.O.H	213.0	253.7	253.7
M.O.H. + E.M.O.H	141.0	218.3	218.3
P.O.F.	0.0	0.0	0.0
E.F.O.F.	4.9	5.8	5.8
E.M.O.F.	3.2	5.0	5.0

-8.310 E. A. POINTS

ADJUSTMENTS TO E.A.F.

$$\frac{P.H. - TGT POH}{P.H. - ACT POH} \times (FOH + EFOH + MOH + EMOH) = \text{ADJUSTED EUOH}$$

$$\frac{4391 - 0}{4391 - 0} \times (145.9 + 107.8 + 44.4 + 173.9) = 472.0$$

$$\frac{0 + 472}{4391} \times 100 = 10.8$$

$$100.0 - 10.8 = 89.2$$

- PH = PERIOD HOURS
- EA.F = EQUIVALENT AVAILABILITY FACTOR
- POH = PLANNED OUTAGE HOURS
- FOH = FORCED OUTAGE HOURS
- MOH = MAINTENANCE OUTAGE HOURS
- EUOH = EQUIVALENT UNPLANNED OUTAGE HOURS
- POF = PLANNED OUTAGE FACTOR
- EFOF = EQUIVALENT FORCED OUTAGE FACTOR
- EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR
- EUOF = EQUIVALENT UNPLANNED OUTAGE FACTOR

TAMPA ELECTRIC COMPANY  
 ADJUSTMENTS TO HEAT RATE  
 GANNON UNIT NO. 5  
 HEAT RATE DATA  
 APRIL 1998 - SEPTEMBER 1998

WEIGHTING FACTOR = 7.58%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	10377	10475
STA. NET GEN. (GWH)	682.3	734.1
OPER. Btu (10 <sup>9</sup> btu)	7079.988	7689.155
NET OUTPUT FACTOR	89.0	79.2

0.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

CURRENT EQUATION NOF(-15.6845) + 11773.1 = ANOHR

$$79.2 \quad (-15.6845) + 11773.1 = \quad 10531$$

$$10475 \quad - \quad 10531 \quad = \quad -56$$

$$10377 \quad + \quad -56 \quad = \quad 10321$$

ANOHR = AVERAGE NET OPERATING HEAT RATE  
 NOF = NET OPERATING FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO HEAT RATE  
GANNON UNIT NO. 6  
HEAT RATE DATA  
APRIL 1998 - SEPTEMBER 1998

WEIGHTING FACTOR = 10.09%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	10527	10540
STA. NET GEN. (GWH)	1151.3	1143.6
OPER. Btu (10 <sup>9</sup> btu)	12120.697	12054.383
NET OUTPUT FACTOR	91.3	76.5

-1.262 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

$$\begin{aligned} \text{CURRENT EQUATION } \text{NOF}(7.0159) + 9886.9 &= \text{ANOHR} \\ 76.5 (7.0159) + 9886.9 &= 10424 \\ 10540 - 10424 &= 116 \\ 10527 + 116 &= 10643 \end{aligned}$$

ANOHR = AVERAGE NET OPERATING HEAT RATE  
NOF = NET OPERATING FACTOR



TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO HEAT RATE  
BIG BEND UNIT NO. 1  
HEAT RATE DATA  
APRIL 1998 - SEPTEMBER 1998

WEIGHTING FACTOR = 11.15%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	10267	10225
STA. NET GEN. (GWH)	1355.3	1333.2
OPER. Btu (10 <sup>9</sup> btu)	13915.115	13632.341
NET OUTPUT FACTOR	83.6	79.2

2.577 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

CURRENT EQUATION  $NOF(-24.5419) + 12319.0 = ANOHR$

79.2 (-24.5419) + 12319.0 = 10375

10225 - 10375 = -150

10267 + -150 = 10117

ANOHR = AVERAGE NET OPERATING HEAT RATE  
NOF = NET OPERATING FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO HEAT RATE  
BIG BEND UNIT NO. 2  
HEAT RATE DATA  
APRIL 1998 - SEPTEMBER 1998

WEIGHTING FACTOR = 7.96%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	10225	10101
STA. NET GEN. (GWH)	1074.5	1059.1
OPER. Btu (10 <sup>9</sup> btu)	10986.729	10698.317
NET OUTPUT FACTOR	83.1	79.3

7.059 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

CURRENT EQUATION NOF(-29.1068) + 12664.0 = ANOHR

79.3	(-29.1068)	+	12664.0	=	10356
10101	-		10356	=	-255
10225	+		-255	=	9970

ANOHR = AVERAGE NET OPERATING HEAT RATE  
NOF = NET OPERATING FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO HEAT RATE  
BIG BEND UNIT NO. 3  
HEAT RATE DATA  
APRIL 1998 - SEPTEMBER 1998

WEIGHTING FACTOR = 9.38%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	9778	10228
STA. NET GEN. (GWH)	1607.4	1184.3
OPER. Btu (10 <sup>9</sup> btu)	15717.682	12113.369
NET OUTPUT FACTOR	94.5	79.2

-1.723 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

$$\begin{aligned} \text{CURRENT EQUATION } \text{NOF}(-21.5491) + 11814.6 &= \text{ANOHR} \\ 79.2(-21.5491) + 11814.6 &= 10107 \\ 10228 - 10107 &= 121 \\ 9778 + 121 &= 9899 \end{aligned}$$

ANOHR = AVERAGE NET OPERATING HEAT RATE  
NOF = NET OPERATING FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO HEAT RATE  
BIG BEND UNIT NO. 4  
HEAT RATE DATA  
APRIL 1998 - SEPTEMBER 1998

WEIGHTING FACTOR = 6.92%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	9831	10074
STA. NET GEN. (GWH)	1753.2	1577.4
OPER. Btu (10 <sup>9</sup> btu)	17235.118	15890.953
NET OUTPUT FACTOR	96.6	85.0

0.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

$$\begin{array}{rcll} \text{CURRENT EQUATION} & \text{NOF}(-28.6185) + 12450.9 & = & \text{ANOHR} \\ 85.0 & (-28.6185) + 12450.9 & = & 10020 \\ 10074 & - & 10020 & = & 54 \\ 9831 & + & 54 & = & 9885 \end{array}$$

ANOHR = AVERAGE NET OPERATING HEAT RATE  
NOF = NET OPERATING FACTOR


TAMPA ELECTRIC COMPANY  
GPIF PLANNED OUTAGE SCHEDULE - ACTUAL  
APRIL 1998 - SEPTEMBER 1998

<u>STATION/UNIT</u>	<u>PLANNED OUTAGE DATES</u>	<u>OUTAGE REASON</u>
*BIG BEND 2	MAR 21 - MAY 08	PRIMARY RHTR BFPT INSPECTION PPTR TRANS. RECTIFIER CLASSIFIERS / MILL ENDS HOT GAS DUCT
** BIG BEND 3	MAY 09 - MAY 25	WIND BOX REPAIRS

Milestone or Critical Path Charts of actual schedule are included on page 20.

\* Start / End dates outside of GPIF period.

\*\* Outage is less than 4 weeks in duration and a CPM was not included for this unit.



TAMPA ELECTRIC COMPANY  
 BIG BEND UNIT NUMBER 2  
 PLANNED OUTAGE 1998  
 ACTUAL CPM  
 03/18/99

TAMPA ELECTRIC COMPANY  
 GENERATING PERFORMANCE INCENTIVE POINTS TABLE

APRIL 1998 - SEPTEMBER 1998

GANNON 5

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	346.2	87.9	+10	502.6	9899
+9	311.6	87.6	+9	452.3	9939
+8	277.0	87.3	+8	402.1	9980
+7	242.3	87.0	+7	351.8	10020
+6	207.7	86.7	+6	301.6	10060
+5	173.1	86.4	+5	251.3	10101
+4	138.5	86.0	+4	201.0	10141
+3	103.9	85.7	+3	150.8	10181
+2	69.2	85.4	+2	100.5	10221
+1	34.6	85.1	+1	50.3	10262
0	0.0	84.8	0	0.0	10302
-1	(66.1)	84.2	-1	(50.3)	10377
-2	(132.2)	83.6	-2	(100.5)	10452
-3	(198.2)	83.0	-3	(150.8)	10492
-4	(264.3)	82.4	-4	(201.0)	10533
-5	(330.4)	81.9	-5	(251.3)	10573
-6	(396.5)	81.3	-6	(301.6)	10613
-7	(462.6)	80.7	-7	(351.8)	10654
-8	(528.6)	80.1	-8	(402.1)	10694
-9	(594.7)	79.5	-9	(452.3)	10734
-10	(660.8)	78.9	-10	(502.6)	10774
					10815
					10855

EAF POINTS  
-0.938

Adjusted EAF  
84.2%

AHR POINTS  
0.000

Adjusted Actual ANOHR  
10321

Weighting Factor =

5.22%

Weighting Factor =

7.58%

TAMPA ELECTRIC COMPANY  
 GENERATING PERFORMANCE INCENTIVE POINTS TABLE

APRIL 1998 - SEPTEMBER 1998

GANNON 6

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	346.2	83.8	+10	669.3	10127
+9	311.6	83.5	+9	602.4	10160
+8	277.0	83.3	+8	535.4	10192
+7	242.3	83.0	+7	468.5	10225
+6	207.7	82.7	+6	401.6	10257
+5	173.1	82.5	+5	334.7	10290
+4	138.5	82.2	+4	267.7	10322
+3	103.9	81.9	+3	200.8	10355
+2	69.2	81.6	+2	133.9	10387
+1	34.6	81.4	+1	66.9	10420
0	0.0	81.1	0	0.0	10452
-1	(66.1)	80.6	-1	0.0	10527
-2	(132.2)	80.1	-2	0.0	10602
-3	(198.2)	79.5	-3	66.9	10635
-4	(264.3)	79.0	-4	(133.9)	10667
-5	(330.4)	78.5	-5	(200.8)	10700
-6	(396.5)	78.0	-6	(267.7)	10732
-7	(462.6)	77.5	-7	(334.7)	10765
-8	(528.6)	76.9	-8	(401.6)	10797
-9	(594.7)	76.4	-9	(468.5)	10830
-10	(660.8)	75.9	-10	(535.4)	10862
				(602.4)	10895
				(669.3)	10927

EAFF POINTS  
-10.000

Adjusted EAF  
75.8

AHR POINTS  
-1.262

Adjusted Actual ANOHR  
10643

Weighting Factor = 5.06%

Weighting Factor = 10.09%



TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE  
APRIL 1998 - SEPTEMBER 1998  
BIG BEND 1

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	724.0	81.5	+10	739.0	9901
+9	651.6	81.2	+9	665.1	9930
+8	579.2	80.9	+8	591.2	9959
+7	506.8	80.5	+7	517.3	9988
+6	434.4	80.2	+6	443.4	10017
+5	362.0	79.9	+5	369.5	10047
+4	289.6	79.6	+4	295.6	10076
+3	217.2	79.3	+3	221.7	10105
+2	144.8	78.9	+2	147.8	10134
+1	72.4	78.6	+1	73.9	10163
0	0.0	78.3	0	0.0	10192
-1	139.2	77.7	-1	(73.9)	10267
-2	278.4	77.0	-2	(147.8)	10342
-3	417.6	76.4	-3	(221.7)	10371
-4	556.8	75.8	-4	(295.6)	10400
-5	696.0	75.2	-5	(369.5)	10429
-6	835.1	74.5	-6	(443.4)	10458
-7	974.3	73.9	-7	(517.3)	10488
-8	1,113.5	73.3	-8	(591.2)	10517
-9	1,252.7	72.6	-9	(665.1)	10546
-10	1,391.9	72.0	-10	(739.0)	10575

← EAF POINTS 2.188

Adjusted EAF 79.0 →

← AHR POINTS 2.577

Adjusted Actual ANOHR 10117 →

Weighting Factor = 10.92%

Weighting Factor = 11.15%

TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE  
APRIL 1998 - SEPTEMBER 1998  
BIG BEND 2

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	622.0	89.1	+10	527.8	9895
+9	559.8	88.8	+9	475.0	9921
+8	497.6	88.6	+8	422.2	9946
+7	435.4	88.3	+7	369.5	9972
+6	373.2	88.0	+6	316.7	9997
+5	311.0	87.8	+5	263.9	10023
+4	248.8	87.5	+4	211.1	10048
+3	186.6	87.2	+3	158.3	10074
+2	124.4	86.9	+2	105.6	10099
+1	62.2	86.7	+1	52.8	10125
0	0.0	86.4	0	0.0	10150
-1	(121.2)	85.9	-1	0.0	10225
-2	(242.4)	85.3	-2	(52.8)	10300
-3	(363.7)	84.8	-3	(105.6)	10326
-4	(484.9)	84.2	-4	(158.3)	10351
-5	(606.1)	83.7	-5	(211.1)	10377
-6	(727.3)	83.2	-6	(263.9)	10402
-7	(848.5)	82.6	-7	(316.7)	10428
-8	(969.8)	82.1	-8	(369.5)	10453
-9	(1,091.0)	81.5	-9	(422.2)	10479
-10	(1,212.2)	81.0	-10	(475.0)	10504
				(527.8)	10530
					10555

<div style="border: 1px solid black; padding: 2px; display: inline-block;">                     EAF POINTS -1.490                 </div>	<div style="border: 1px solid black; padding: 2px; display: inline-block;">                     Adjusted EAF 85.6                 </div>	<div style="border: 1px solid black; padding: 2px; display: inline-block;">                     AHR POINTS 7.059                 </div>	<div style="border: 1px solid black; padding: 2px; display: inline-block;">                     Adjusted Actual ANOHR 9970                 </div>
--	--	---	---

Weighting Factor =	9.38%	Weighting Factor =	7.96%
--------------------	-------	--------------------	-------

TAMPA ELECTRIC COMPANY  
 GENERATING PERFORMANCE INCENTIVE POINTS TABLE

APRIL 1998 - SEPTEMBER 1998

BIG BEND 3

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	874.4	72.3	+10	621.7	9436
+9	787.0	72.0	+9	559.5	9463
+8	699.5	71.6	+8	497.4	9489
+7	612.1	71.3	+7	435.2	9516
+6	524.6	70.9	+6	373.0	9543
+5	437.2	70.5	+5	310.9	9570
+4	349.8	70.2	+4	248.7	9596
+3	262.3	69.9	+3	186.5	9623
+2	174.9	69.5	+2	124.3	9650
+1	87.4	69.2	+1	62.2	9676
0	0.0	68.8	0	0.0	9703
-1	169.5	68.1	-1	0.0	9778
-2	339.0	67.4	-2	62.2	9853
-3	508.4	66.7	-3	(124.3)	9880
-4	677.9	66.0	-4	(186.5)	9906
-5	847.4	65.3	-5	(248.7)	9933
-6	1,016.9	64.5	-6	(310.9)	9960
-7	1,186.4	63.8	-7	(373.0)	9987
-8	1,355.8	63.1	-8	(435.2)	10013
-9	1,525.3	62.4	-9	(497.4)	10040
-10	1,694.8	61.7	-10	(559.5)	10067
				(621.7)	10093
					10120

← EAF POINTS 6.274

Adjusted EAF 64.3 →

AHR POINTS -1.723 ←

Adjusted Actual ANOHR 9899 →

Weighting Factor = 13.19%

Weighting Factor = 9.38%

TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE

APRIL 1998 - SEPTEMBER 1998

BIG BEND 4

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	208.9	93.5	+10	459.4	9643
+9	188.0	93.3	+9	413.5	9654
+8	167.1	93.2	+8	367.5	9666
+7	146.2	93.0	+7	321.6	9677
+6	125.3	92.9	+6	275.6	9688
+5	104.5	92.7	+5	229.7	9700
+4	83.6	92.5	+4	183.8	9711
+3	62.7	92.4	+3	137.8	9722
+2	41.8	92.2	+2	91.9	9733
+1	20.9	92.1	+1	45.9	9745
0	0.0	91.9	0	0.0	9756
-1	42.4	91.6	-1	(45.9)	9917
-2	84.8	91.3	-2	(91.9)	9929
-3	127.3	90.9	-3	(137.8)	9940
-4	169.7	90.6	-4	(183.8)	9951
-5	212.1	90.3	-5	(229.7)	9963
-6	254.5	90.0	-6	(275.6)	9974
-7	296.9	89.7	-7	(321.6)	9985
-8	339.4	89.3	-8	(367.5)	9996
-9	381.8	89.0	-9	(413.5)	10008
-10	424.2	88.7	-10	(459.4)	10019

EAF POINTS  
-8.310

Adjusted EAF  
89.2

AHR POINTS  
0.000

Adjusted Actual ANOHR  
9885

Weighting Factor =

3.15%

Weighting Factor =

6.92%

TAMPA ELECTRIC COMPANY  
COMPARISON OF GPIF TARGETS VS. PRIOR PERIOD ACTUAL PERFORMANCE  
APRIL 1998 - SEPTEMBER 1998

AVAILABILITY

<u>PLANT/UNIT</u>	<u>TARGET WEIGHTING FACTOR</u>	<u>NORMALIZED WEIGHTING FACTOR</u>	<u>TARGET PERIOD APR 98 - SEP 98</u>			<u>ACTUAL PERFORMANCE APR 98 - SEP 98</u>		
			<u>POF</u>	<u>EUOF</u>	<u>EUOR</u>	<u>POF</u>	<u>EUOF</u>	<u>EUOR</u>
BIG BEND 1	10.92%	23.3	7.7	14.0	15.2	0.0	14.5	14.5
BIG BEND 2	9.38%	20.0	0.0	13.6	13.6	20.8	11.4	14.4
BIG BEND 3	13.19%	28.1	18.0	13.2	16.1	9.0	19.6	21.5
BIG BEND 4	3.15%	6.7	0.0	8.1	8.1	0.0	10.7	10.7
GANNON 5	5.22%	11.1	0.0	15.2	15.2	0.0	15.7	15.7
GANNON 6	5.06%	10.8	7.7	11.3	12.2	0.0	18.0	18.0
	46.92%	100.0						
GPIF SYSTEM WEIGHTED AVERAGE			7.7	13.1	14.3	6.7	15.6	16.7
GPIF SYSTEM WEIGHTED EQUIVALENT AVAILABILITY				79.2			77.7	
			5 PERIOD AVERAGE			5 PERIOD AVERAGE		
			POF	EUOF	EUOR	EAF		
			6.9	13.4	14.4	79.7		

AVERAGE NET OPERATING HEAT RATE (Btu/kwh)

<u>PLANT/UNIT</u>	<u>TARGET WEIGHTING FACTOR</u>	<u>NORMALIZED WEIGHTING FACTOR</u>	<u>HEAT RATE TARGET</u>	<u>ACTUAL HEAT RATE APR 98 - SEP 98</u>
GANNON 5	7.58%	14.3	10377	10475
GANNON 6	10.09%	19.0	10527	10540
BIG BEND 1	11.15%	21.0	10267	10225
BIG BEND 2	7.96%	15.0	10225	10101
BIG BEND 3	9.38%	17.7	9778	10228
BIG BEND 4	6.92%	13.0	9831	10074
	53.08%	100.0		
GPIF SYSTEM WEIGHTED AVERAGE HEAT RATE (Btu/kwh)			10183	10283

**TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS CALCULATION  
APRIL 1998 - SEPTEMBER 1998**

Points are calculated according to the formula:

$$\text{GPIP} = \sum_{i=1}^n [ (a_i) (\text{EAP}_i) + (e_i) (\text{AHRP}_i) ]$$

Where:

$i=1,n$

$a$  = Unit equivalent availability weighting factor

EAP = Unit equivalent availability points

$e$  = Station average heat rate weighting factor

AHRP = Station average heat rate points

Weighting factors and point values are listed in separate tables.

GPIP =	5.22% *	(GN 5 EAP)	+	5.06% *	(GN 6 EAP)	+	10.92% *	(BB 1 EAP)
	9.38% *	(BB 2 EAP)	+	13.19% *	(BB 3 EAP)	+	3.15% *	(BB 4 EAP)
	7.58% *	(GN 5 AHRP)	+	10.09% *	(GN 6 AHRP)	+	11.15% *	(BB 1 AHRP)
	7.96% *	(BB 2 AHRP)	+	9.38% *	(BB 3 AHRP)	+	6.92% *	(BB 4 AHRP)

GPIP =	5.22% *	-0.938	+	5.06% *	-10.000	+	10.92% *	2.188
	9.38% *	-1.490	+	13.19% *	-6.274	+	3.15% *	-8.310
	7.58% *	0.000	+	10.09% *	-1.262	+	11.15% *	2.577
	7.96% *	7.059	+	9.38% *	-1.723	+	6.92% *	0.000

GPIP =	-0.049	+	-0.506	+	0.239	+	-0.140
	-0.828	+	-0.262	+	0.000	+	-0.127
	0.287	+	0.562	+	-0.162	+	0.000

GPIP = -0.986 POINTS

REWARD/PENALTY dollar amounts of the Generating Performance Incentive Factor (GPIF) are determined directly from the table for the corresponding Generating Performance Points (GPIP) - see page 2.

GPIP = (\$229,924)