

ORIGINAL

CLASS B
WATER AND/OR WASTEWATER UTILITIES

**FINANCIAL, RATE
AND ENGINEERING
MINIMUM FILING
REQUIREMENTS**

OF

Company: Indiantown Company, Inc.

Exact Legal Name of Utility

VOLUME IIIa



FOR THE

Test Year Ended: June 30, 1999

**Indiantown Company, Inc.
Additional Engineering Information
Index**

ORIGINAL

**Volume IIIa
Schedule**

- A** **Chemicals used for water and sewer treatment by type, dollar amounts, quantities purchased, unit prices, and dosage rates**

- B** **Copy of the most recent Chemical Analysis**

- C** **Copies of Water and Wastewater Operating Reports for the test year and the preceding year**

**Volume IIIb
Schedule**

- D** **Copy of the most recent Water Plant Sanitary Survey & Wastewater Inspection Report**

- E** **Copy of Health Department & DER Construction/Operating Permits for Water & Wastewater**

- F** **Copies of Violation Notices, Consent Orders, Letters of Notice or Warning Notices for the previous five years, including Utility response**

- G** **List of all field employees, responsibilities and duties, certificates held, and an explanation of each employee's salary allocation method to expense accounts**

- H** **Serial Numbers and description of all vehicles owned by the Utility, original cost, person vehicle is assigned to, and the method of allocation to the Utility**


- I** **List of customer complaints during the test year and Utility response**

- J** **Information required for investment in public interest**

**DOCUMENT NUMBER-DATE
15728 DEC 27 88
FPSC-RECORDS/REPORTING**



Indiantown Company, Inc.
List of Chemicals Used, Unit Cost, and Dosage Rates



Water Department


<u>Date</u>	<u>Cost</u>	<u>Lbs. Chlorine</u>	<u>Chlorine Tabs</u>	<u>Unit Cost</u>
July, 1998	\$ 1,143.73	4,000	pk of 1000	\$.29/tab
August, 1998	450.00	2,000		.22/lb.
September, 1998	954.48	4,000	pk of tabs	.24/tab
November, 1998	900.00	4,000		.23/lb.
December, 1998	900.00	4,000		.23/lb.
January, 1999	450.00	2,000		.23/lb.
February, 1999	494.45	2,000		.25/lb.
March, 1999	900.00	4,000		.23/lb.
April, 1999	900.00	4,000		.23/lb.
May, 1999	485.89	2,000		.24/lb.
June, 1999	900.00	4,000		.23/lb.
Total	<u>\$ 8,478.55</u>	<u>36,000</u>		

Normal dosage rate - 100 lbs./day

Sewer Department

<u>Date</u>	<u>Cost</u>	<u>Lbs. Chlorine</u>	<u>Flowmate Degreaser</u>	<u>Unit Cost</u>
July, 1998	\$ 900.00	1,500		\$.60/lb.
August, 1998	270.00	450		.60/lb.
August, 1998	275.44		5 gal.	55/gal.
September, 1998	720.00	1,200		.60/lb.
November, 1998	540.00	900		.60/lb.
December, 1998	720.00	1,200		.60/lb.
January, 1999	270.00	450		.60/lb.
February, 1999	990.00	1,650		.60/lb.
March, 1999	450.00	750		.60/lb.
April, 1999	540.00	900		.60/lb.
May, 1999	270.00	450		.60/lb.
June, 1999	450.00	750		.60/lb.
Total	<u>\$ 6,395.44</u>	<u>10,200</u>		

Normal dosage rate - 40 lbs./day



Most Recent Water Chemical Analysis

HARBOR BRANCH ENVIRONMENTAL LABORATORY

5600 US 1 North, Fort Pierce, FL 34946
561-465-2400, Ext. 285

FDEP QAP 870174

October 27, 1999



Jim Hewitt
Indiantown Company, Inc.
15851 S.W. Farms Rd.
Indiantown, FL 34956

Client : Indiantown Company, Inc.
Project [Reference] : 3 Year Compliance [9006660]
Date Received : October 05, 1999

Analytical results presented in this report have been reviewed for compliance with the laboratory quality assurance plan and applicable quality control criteria. The quality control parameters evaluated have met all method and compliance criteria unless otherwise noted on a Quality Control Summary Page immediately following this cover sheet.

FDOH (HRS) Drinking Water Certification Number: 96230, 83486, 82500, 85512, 84526

FDOH (HRS) Environmental Certification Number: E96080, E83509, E82417, E85370, E84418

FDEP CompQAP Approval Number: 870174

NOTE: This report is not to be copied, except in full, without the express written consent of the Harbor Branch Environmental Laboratory.

If you have any questions regarding this report, or if we can be of further assistance, please feel free to call (561) 465-2400 ext. 285 and ask to speak with a Client Services Representative.

Don Hash
Project Manager

Copy

Florida
34946
96080

Orlando Area
Deltona, FL 32725
FDOH #83486 / E83509

Jacksonville Area
Fernandina Beach, FL 32034
FDOH #82500 / E82417

Fort Myers Area
Lehigh Acres, FL 33936
FDOH #85512 / E85370

West Central Florida
Spring Hill, FL 34607
FDOH #84526 / E84418

HARBOR BRANCH ENVIRONMENTAL LABORATORY5600 US 1 North, Fort Pierce, FL 34946
561-465-2400, Ext. 285

FDEP QAP 870174


PESTICIDE & PCB CHEMICAL ANALYSIS
 62-550.310 (2) (c)
 (PWS029)

Project Indiantown Company, Inc.
Sample Location Point of Entry
Sample Number 9006660001
Sampling Date 10/05/99 07:50
Preservative Sodium Thiosulfate
Date Received 10/05/99 11:45
Workorder 3 Year Compliance

ID	Parameter [MCL]	Result	Method	MDL	Date	Lab ID
2005	Endrin[2]	ND	ug/L	EPA 508	0.0061	10/07/99 96230
2010	Lindane[.2]	ND	ug/L	EPA 508	0.0041	10/07/99 96230
2015	Methoxychlor [40]	ND	ug/L	EPA 508	0.0041	10/07/99 96230
2020	Toxaphene [3]	ND	ug/L	EPA 508	1.2	10/07/99 96230
2031	Dalapon [200]	ND	ug/L	EPA 515.1	2.6	10/07/99 96230
2032	Diquat [20]	ND	ug/L	EPA 549.1	2.6	10/11/99 96230
2033	Endothall [100]	ND	ug/L	EPA 548.1	2.8	10/11/99 96230
2034	Glyphosate [700]	ND	ug/L	EPA 547	3.3	10/18/99 96230
2035	Di(2-ethylhexyl)adipate [400]	ND	ug/L	EPA 525	0.82	10/11/99 96230
2036	Oxamyl (Vydate) [200]	ND	ug/L	EPA 531.1	0.25	10/25/99 96230
2037	Simazine [4]	ND	ug/L	EPA 507	0.19	10/07/99 96230
2039	Di(2-ethylhexyl)phthalate [6]	ND	ug/L	EPA 525	1.4	10/11/99 96230
2040	Picloram [500]	ND	ug/L	EPA 515.1	0.26	10/07/99 96230
2041	Dinoseb [7]	ND	ug/L	EPA 515.1	0.58	10/07/99 96230
2042	Hexachlorocyclopentadiene [50]	ND	ug/L	EPA 508	0.071	10/07/99 96230
2046	Carbofuran [40]	ND	ug/L	EPA 531.1	0.31	10/25/99 96230
2050	Atrazine [3]	ND	ug/L	EPA 507	0.18	10/07/99 96230
2051	Alachlor [2]	ND	ug/L	EPA 507	0.37	10/07/99 96230
2065	Heptachlor [4]	ND	ug/L	EPA 508	0.0051	10/07/99 96230
2067	Heptachlor epoxide [.2]	ND	ug/L	EPA 508	0.0041	10/07/99 96230
2105	2,4-D [70]	ND	ug/L	EPA 515.1	0.53	10/07/99 96230
2110	2,4,5-TP (Silvex) [50]	ND	ug/L	EPA 515.1	0.41	10/07/99 96230
2274	Hexachlorobenzene [1]	ND	ug/L	EPA 508	0.019	10/07/99 96230
2306	Benzo(a)pyrene [.2]	ND	ug/L	EPA 525	0.072	10/11/99 96230
2326	Pentachlorophenol [1]	ND	ug/L	EPA 515.1	0.34	10/07/99 96230
2383	PCB [.5]	ND	ug/L	EPA 508	0.22	10/07/99 96230
2931	Dibromochloropropane [.2]	ND	ug/L	EPA 504.1	0.0022	10/11/99 96230
2946	Ethylene dibromide [.02]	ND	ug/L	EPA 504.1	0.0024	10/11/99 96230
2959	Chlordane [2]	ND	ug/L	EPA 508	0.012	10/07/99 96230

 Southeast Florida
 Fort Pierce, FL 34946
 FDOH #96230 / E96080

 Orlando Area
 Deltona, FL 32725
 FDOH #83486 / E83509

 Jacksonville Area
 Fernandina Beach, FL 32034
 FDOH #82500 / E82417

 Fort Myers Area
 Lehigh Acres, FL 33936
 FDOH #85512 / E85370

 West Central Florida
 Spring Hill, FL 34607
 FDOH #84526 / E84418

HARBOR BRANCH ENVIRONMENTAL LABORATORY


5600 US 1 North, Fort Pierce, FL 34946
561-465-2400, Ext. 285

FDEP QAP 870174

November 01, 1999



Jim Hewitt
Indiantown Company, Inc.
15851 S.W. Farms Rd.
Indiantown, FL 34956



Client : Indiantown Company, Inc.
Project [Reference] : Tri-Annual Compliance [9006796]
Date Received : October 13, 1999

Analytical results presented in this report have been reviewed for compliance with the laboratory quality assurance plan and applicable quality control criteria. The quality control parameters evaluated have met all method and compliance criteria unless otherwise noted on a Quality Control Summary Page immediately following this cover sheet.

FDOH (HRS) Drinking Water Certification Number: 96230, 83486, 82500, 85512, 84526

FDOH (HRS) Environmental Certification Number: E96080, E83509, E82417, E85370, E84418

FDEP CompQAP Approval Number: 870174

NOTE: This report is not to be copied, except in full, without the express written consent of the Harbor Branch Environmental Laboratory.

If you have any questions regarding this report, or if we can be of further assistance, please feel free to call (561) 465-2400 ext. 285 and ask to speak with a Client Services Representative.

Don Hash
Project Manager

HARBOR BRANCH ENVIRONMENTAL LABORATORY

5600 US 1 North, Fort Pierce, FL 34946
561-465-2400, Ext. 285

FDEP QAP 870174




SECONDARY CHEMICAL ANALYSIS 62-550.320 (PWS031)

Project Indiantown Company, Inc.
Sample Location Point of Entry
Sample Number 9006796001
Sampling Date 10/13/99 08:00
Preservative Nitric Acid or None
Date Received 10/13/99 12:15

Workorder Tri-Annual Compliance

ID	Parameter [MCL]	Result		Method	MDL	Date	Lab ID
1002	Aluminum[.2]	ND	mg/L	EPA 200.7	0.0030	10/29/99	96230
1017	Chloride[250]	34	mg/L	EPA 300.0	5.0	10/20/99	96230
1022	Copper[1]	ND	mg/L	EPA 200.7	0.0014	10/29/99	96230
1025	Fluoride.[2]	0.19	mg/L	EPA 300.0	0.011	10/14/99	96230
1028	Iron[.3]	ND	mg/L	EPA 200.7	0.025	10/29/99	96230
1032	Manganese[.05]	ND	mg/L	EPA 200.7	0.0038	10/29/99	96230
1050	Silver[.1]	ND	mg/L	EPA 200.7	0.0010	10/29/99	96230
1055	Sulfate[250]	4.7	mg/L	EPA 300.0	1.4	10/20/99	96230
1095	Zinc[5]	0.020	mg/L	EPA 200.7	0.010	10/29/99	96230
1905	Color[15]	ND	CU	SM2120 B	5.0	10/14/99	96230
1920	Odor[3]	5.1	T.O.N.	SM2150 B	1.0	10/13/99	96230
1925	pH [6-8.5] []	7.8	SU	EPA 150.1	0.20	10/19/99	96230
1930	Total Dissolved Solids[500]	410	mg/L	SM2540 C	10	10/15/99	96230
2905	Foaming Agents[.5]	0.036	mg/L	SM5540 C	0.019	10/14/99	96230



Southeast Florida
Fort Pierce, FL 34946
FDOH #96230 / E96080

Orlando Area
Deltona, FL 32725
FDOH #83486 / E83509

Jacksonville Area
Fernandina Beach, FL 32034
FDOH #82500 / E82417

Fort Myers Area
Lehigh Acres, FL 33936
FDOH #85512 / E85370

West Central Florida
Spring Hill, FL 34607
FDOH #84526 / E84418

HARBOR BRANCH ENVIRONMENTAL LABORATORY

5600 US 1 North, Fort Pierce, FL 34946
561-465-2400, Ext. 285

FDEP QAP 870174



RADIOCHEMICAL ANALYSIS
62-550.310(5)
(PWS033)

Workorder Tri-Annual Compliance

Project Indiantown Company, Inc.
Sample Location Point of Entry
Sample Number 9006796001
Sampling Date 10/13/99 08:00
Preservative Nitric Acid
Date Received 10/13/99 12:15

ID	Name	Result (pCi/L)	Method	Error	Date	Lab ID
4000	Gross Alpha	1.9 pCi/L	EPA 900.0	+/- 0.9	10/29/99	84252



Southeast Florida
Fort Pierce, FL 34946
FDOH #96230 / E96080

Orlando Area
Deltona, FL 32725
FDOH #83486 / E83509

Jacksonville Area
Fernandina Beach, FL 32034
FDOH #82500 / E82417

Fort Myers Area
Lehigh Acres, FL 33936
FDOH #85512 / E85370

West Central Florida
Spring Hill, FL 34607
FDOH #84526 / E84418

HARBOR BRANCH ENVIRONMENTAL LABORATORY

5600 US 1 North, Fort Pierce, FL 34946

561-465-2400, Ext. 285

FDEP QAP 870174



VOLATILE ORGANIC ANALYSIS


62-550.310 (2) (b)

(PWS028)

Project *Indiantown Company, Inc.*
Sample Location *Point of Entry*
Sample Number *9006796001*
Sampling Date *10/13/99 08:00*
Preservative *1:1 Hydrochloric Acid*
Date Received *10/13/99 12:15*

Workorder *Tri-Annual Compliance*

ID	Parameter [MCL]	Result	Method	MDL	Date	Lab ID
2378	1,2,4-Trichlorobenzene [70]	ND	ug/L	EPA 524.2	0.37	10/16/99 96230
2380	cis-1,2-Dichloroethylene [70]	ND	ug/L	EPA 524.2	0.23	10/16/99 96230
2955	Total Xylenes [10000]	ND	ug/L	EPA 524.2	0.30	10/16/99 96230
2964	Dichloromethane [5]	ND	ug/L	EPA 524.2	0.49	10/16/99 96230
2968	o-Dichlorobenzene [600]	ND	ug/L	EPA 524.2	0.35	10/16/99 96230
2969	para-Dichlorobenzene [75]	ND	ug/L	EPA 524.2	0.28	10/16/99 96230
2976	Vinyl chloride [1]	ND	ug/L	EPA 524.2	0.33	10/16/99 96230
2977	1,1-Dichloroethylene [7]	ND	ug/L	EPA 524.2	0.21	10/16/99 96230
2979	trans-1,2-Dichloroethylene [100]	ND	ug/L	EPA 524.2	0.18	10/16/99 96230
2980	1,2-Dichloroethane [3]	ND	ug/L	EPA 524.2	0.45	10/16/99 96230
2981	1,1,1-Trichloroethane [200]	ND	ug/L	EPA 524.2	0.25	10/16/99 96230
2982	Carbon tetrachloride [3]	0.34	ug/L	EPA 524.2	0.28	10/16/99 96230
2983	1,2-Dichloropropane [5]	ND	ug/L	EPA 524.2	0.23	10/16/99 96230
2984	Trichloroethylene [3]	ND	ug/L	EPA 524.2	0.21	10/16/99 96230
2985	1,1,2-Trichloroethane [5]	ND	ug/L	EPA 524.2	0.23	10/16/99 96230
2987	Tetrachloroethylene [3]	ND	ug/L	EPA 524.2	0.26	10/16/99 96230
2989	Monochlorobenzene [100]	ND	ug/L	EPA 524.2	0.23	10/16/99 96230
2990	Benzene [1]	ND	ug/L	EPA 524.2	0.090	10/16/99 96230
2991	Toluene [1000]	ND	ug/L	EPA 524.2	0.18	10/16/99 96230
2992	Ethylbenzene [700]	ND	ug/L	EPA 524.2	0.19	10/16/99 96230
2996	Styrene [100]	ND	ug/L	EPA 524.2	0.24	10/16/99 96230



Southeast Florida
Fort Pierce, FL 34946
FDOH #96230 / E96080

Orlando Area
Deltona, FL 32725
FDOH #83486 / E83509

Jacksonville Area
Fernandina Beach, FL 32034
FDOH #82500 / E82417

Fort Myers Area
Lehigh Acres, FL 33936
FDOH #85512 / E85370

West Central Florida
Spring Hill, FL 34607
FDOH #84526 / E84418

8

HARBOR BRANCH ENVIRONMENTAL LABORATORY

5600 US 1 North, Fort Pierce, FL 34946
561-465-2400, Ext. 285

FDEP QAP 870174




INORGANICS ANALYSIS 62-550.310 (1) (PWS030)

Project Indiantown Company, Inc.
Sample Location Point of Entry
Sample Number 9006796001
Sampling Date 10/13/99 08:00
Preservative Nitric Acid, Sodium Hydroxide or None
Date Received 10/13/99 12:15

Workorder Tri-Annual Compliance

ID	Parameter [MCL]	Result	Method	MDL	Date	Lab ID
1005	Arsenic[.05]	ND	mg/L	EPA 200.7	0.0032	10/29/99 96230
1010	Barium[2]	0.025	mg/L	EPA 200.7	0.0018	10/29/99 96230
1015	Cadmium[.005]	ND	mg/L	EPA 200.7	0.00070	10/29/99 96230
1020	Chromium[.1]	ND	mg/L	EPA 200.7	0.0018	10/29/99 96230
1024	Cyanide[.2]	ND	mg/L	SM4500CN E	0.0040	10/22/99 96230
1025	Fluoride[4]	0.19	mg/L	EPA 300.0	0.011	10/14/99 96230
1035	Mercury[.002]	ND	mg/L	EPA 245.1	0.000060	10/25/99 96230
1036	Nickel[.1]	ND	mg/L	EPA 200.7	0.0020	10/29/99 96230
1040	Nitrate as N[10]	0.058	mg/L	EPA 300.0	0.0030	10/14/99 96230
1041	Nitrite as N[1]	ND	mg/L	EPA 300.0	0.0022	10/14/99 96230
1045	Selenium[.05]	ND	mg/L	EPA 200.9	0.0022	10/27/99 96230
1052	Sodium[160]	12	mg/L	EPA 200.7	0.50	10/29/99 96230
1074	Antimony[.006]	ND	mg/L	EPA 200.9	0.0042	10/26/99 96230
1075	Beryllium[.004]	ND	mg/L	EPA 200.7	0.0010	10/29/99 96230
1085	Thallium[.002]	ND	mg/L	EPA 200.9	0.0010	10/25/99 96230



Southeast Florida
Fort Pierce, FL 34946
FDOH #96230 / E96080

Orlando Area
Deltona, FL 32725
FDOH #83486 / E83509

Jacksonville Area
Fernandina Beach, FL 32034
FDOH #82500 / E82417

Fort Myers Area
Lehigh Acres, FL 33936
FDOH #85512 / E85370

West Central Florida
Spring Hill, FL 34607
FDOH #84526 / E84418

HARBOR BRANCH ENVIRONMENTAL LABORATORY

5600 US 1 North, Fort Pierce, FL 34946
561-465-2400, Ext. 285

FDEP QAP 870174

November 10, 1999



Jim Hewitt
Indiantown Company, Inc.
15851 S.W. Farms Rd.
Indiantown, FL 34956

Client : Indiantown Company, Inc.
Project [Reference] : Odor Re-sample [9007245]
Date Received : November 09, 1999

Analytical results presented in this report have been reviewed for compliance with the laboratory quality assurance plan and applicable quality control criteria. The quality control parameters evaluated have met all method and compliance criteria unless otherwise noted on a Quality Control Summary Page immediately following this cover sheet.

FDOH (HRS) Drinking Water Certification Number: 96230, 83486, 82500, 85512, 84526


FDOH (HRS) Environmental Certification Number: E96080, E83509, E82417, E85370, E84418

FDEP CompQAP Approval Number: 870174

NOTE: This report is not to be copied, except in full, without the express written consent of the Harbor Branch Environmental Laboratory.

If you have any questions regarding this report, or if we can be of further assistance, please feel free to call (561) 465-2400 ext. 285 and ask to speak with a Client Services Representative.

Don Hash
Project Manager



HARBOR BRANCH ENVIRONMENTAL LABORATORY

5600 US 1 North, Fort Pierce, FL 34946
561-465-2400, Ext. 285

FDEP QAP 870174




SECONDARY CHEMICAL ANALYSIS
62-550.320
(PWS031)

Project Indiantown Company, Inc.
Sample Location Point of Entry
Sample Number 9007245001
Sampling Date 11/09/99 09:05
Preservative Nitric Acid or None
Date Received 11/09/99 11:45

Workorder Odor Re-sample

ID	Parameter [MCL]	Result	Method	MDL	Date	Lab ID
1920	Odor [3]	1.6	T.O.N.	SM2150 B	1.0	11/09/99 96230



Southeast Florida
Fort Pierce, FL 34946
FDOH #96230 / E96080

Orlando Area
Deltona, FL 32725
FDOH #83486 / E83509

Jacksonville Area
Fernandina Beach, FL 32034
FDOH #82500 / E82417

Fort Myers Area
Lehigh Acres, FL 33936
FDOH #85512 / E85370

West Central Florida
Spring Hill, FL 34607
FDOH #84526 / E84418

HARBOR BRANCH ENVIRONMENTAL LABORATORY


5600 US 1 North, Fort Pierce, FL 34946
561-465-2400, Ext. 285

FDEP QAP 870174

September 09, 1999



Dean Smiley
Indiantown Company, Inc.
P.O. Box 397
Indiantown, FL 34956



Client : Indiantown Company, Inc.
Project [Reference] : Tri-Annual Pest/PCBs [9005312]
Date Received : July 26, 1999

Analytical results presented in this report have been reviewed for compliance with the laboratory quality assurance plan and applicable quality control criteria. The quality control parameters evaluated have met all method and compliance criteria unless otherwise noted on a Quality Control Summary Page immediately following this cover sheet.

FDOH (HRS) Drinking Water Certification Number: 96230, 83486, 82500, 85512, 84526

FDOH (HRS) Environmental Certification Number: E96080, E83509, E82417, E85370, E84418

FDEP CompQAP Approval Number: 870174

NOTE: This report is not to be copied, except in full, without the express written consent of the Harbor Branch Environmental Laboratory.

If you have any questions regarding this report, or if we can be of further assistance, please feel free to call (561) 465-2400 ext. 285 and ask to speak with a Client Services Representative.

Don Hash
Project Manager

Southeast Florida
Fort Pierce, FL 34946
FDOH #96230 / E96080

Orlando Area
Deftona, FL 32725
FDOH #83486 / E83509

Jacksonville Area
Fernandina Beach, FL 32034
FDOH #82500 / E82417

Fort Myers Area
Lehigh Acres, FL 33936
FDOH #85512 / E85370

West Central Florida
Spring Hill, FL 34607
FDOH #84526 / E84418

PESTICIDE & PCB CHEMICAL ANALYSIS
62-550.310(2)(c)
(PWS029)

Project Indiantown Company, Inc.
Sample Location Point of Entry
Sample Number 9005312001
Sampling Date 07/26/99 11:48
Preservative Sodium Thiosulfate
Date Received 07/26/99 14:30

Workorder Tri-Annual Pest/PCBs

ID	Parameter [MCL]	Result	Method	MDL	Date	Lab ID
2005	Endrin[2]	ND	ug/L	EPA 508	0.0062	07/30/99 96230
2010	Lindane[.2]	ND	ug/L	EPA 508	0.0041	07/30/99 96230
2015	Methoxychlor[40]	ND	ug/L	EPA 508	0.0041	07/30/99 96230
2020	Toxaphene[3]	ND	ug/L	EPA 508	1.2	07/30/99 96230
2031	Dalapon[200]	ND	ug/L	EPA 515.1	2.6	08/06/99 96230
2032	Diquat[20]	ND	ug/L	EPA 549.1	2.6	07/30/99 96230
2033	Endothal[100]	ND	ug/L	EPA 548.1	2.8	07/30/99 96230
2034	Glyphosate[700]	ND	ug/L	EPA 547	3.3	08/04/99 96230
2035	Di(2-ethylhexyl)adipate[400]	ND	ug/L	EPA 525	0.82	07/26/99 96230
2036	Oxamyl (Vydate)[200]	ND	ug/L	EPA 531.1	0.25	07/29/99 96230
2039	Di(2-ethylhexyl)phthalate[6]	ND	ug/L	EPA 525	1.4	07/26/99 96230
2040	Picloram[500]	ND	ug/L	EPA 515.1	0.26	08/06/99 96230
2041	Dinoseb[7]	ND	ug/L	EPA 515.1	0.58	08/06/99 96230
2042	Hexachlorocyclopentadiene[50]	ND	ug/L	EPA 508	0.072	07/30/99 96230
2046	Carbofuran[40]	ND	ug/L	EPA 531.1	0.31	07/29/99 96230
2065	Heptachlor[.4]	ND	ug/L	EPA 508	0.0051	07/30/99 96230
2067	Heptachlor epoxide[.2]	ND	ug/L	EPA 508	0.0041	07/30/99 96230
2105	2,4-D[70]	ND	ug/L	EPA 515.1	0.53	08/06/99 96230
2110	2,4,5-TP (Silvex)[50]	ND	ug/L	EPA 515.1	0.41	08/06/99 96230
2274	Hexachlorobenzene[1]	ND	ug/L	EPA 508	0.020	07/30/99 96230
2306	Benzo(a)pyrene[.2]	ND	ug/L	EPA 525	0.072	07/26/99 96230
2326	Pentachlorophenol[1]	ND	ug/L	EPA 515.1	0.34	08/06/99 96230
2383	PCB[.5]	ND	ug/L	EPA 508	0.22	07/30/99 96230
2931	Dibromochloropropane[.2]	ND	ug/L	EPA 504.1	0.0022	08/16/99 96230
2946	Ethylene dibromide[.02]	ND	ug/L	EPA 504.1	0.0024	08/16/99 96230
2959	Chlordane[2]	ND	ug/L	EPA 508	0.012	07/30/99 96230

Most Recent Wastewater Chemical Analysis

SHORT ENVIRONMENTAL LABORATORIES, INC.

10405 US 27 South
Sebring, Florida 33870

(800) 833-4022 HRS# 85344 & E85458, FDEP QAP# 880516 (941) 655-4022

For: Indiantown Company Inc.
P.O. Box 397
Indiantown, FL 33456-0397
Attn: Dean Smiley

10/13/1999
Page 1 of 1

Laboratory Number: 111251

Project: ICI
Location: WWTP
Sample ID: Digestor
Sampled By: D Smiley on 09/28/1999 @ 1505
Received: 09/28/1999 @ 1645

REPORT OF ANALYSIS


LABORATORY DATA

Parameter	Result	Units	Method	Analyst	Date/Time of Analysis	MDL
Total Solids	1.18	%	EPA 160.3	J. Cosgrave	10/01/1999 @ 1154	N/A
pH	6.59	S.U.	EPA 150.1	J. Cosgrave	09/28/1999 @ 1700	N/A
Total Nitrogen	5.86	%	Calc.	A. Mitchell	10/11/1999 @ 1707	
Total Kjeldahl Nitrogen (N)	5.86	%	EPA 351.2	J. Gwaltney	10/01/1999 @ 1453	
Nitrate Nitrogen (NO _x -N)	0.02 _u	%	EPA 353.2	J. Gwaltney	10/05/1999 @ 1123	
Potassium (K)	0.67	%	EPA 7610	D. Morton	10/08/1999 @ 0906	
Total Phosphorus	2.42	%	EPA 365.2	D. Martin	10/05/1999 @ 1355	
Arsenic	3.4	mg/kg	EPA 7061	D. Morton	10/06/1999 @ 1600	
Cadmium	3.4 _u	mg/kg	EPA 7130	D. Morton	10/05/1999 @ 1510	
Copper	380.	mg/kg	EPA 7210	D. Morton	10/01/1999 @ 1759	
Lead	48.	mg/kg	EPA 7420	D. Morton	10/05/1999 @ 1338	
Mercury	1.0	mg/kg	EPA 7471	D. Morton	10/04/1999 @ 0905	
Molybdenum	6.4	mg/kg	EPA 7481	D. Morton	10/07/1999 @ 1558	
Nickel	24.	mg/kg	EPA 7520	D. Morton	10/05/1999 @ 1420	
Selenium	8.5 _u	mg/kg	EPA 7740	D. Murto	10/01/1999 @ 1315	
Zinc	302.	mg/kg	EPA 7950	D. Morton	10/05/1999 @ 1630	

Analysis on a dry basis

u = Parameter was analyzed for but not detected

Respectfully Submitted,



Angela F. Mitchell
Project Manager

SHORT ENVIRONMENTAL LABORATORIES, INC.

10405 US 27 South
Sebring, Florida 33870

(800) 833-4022 HRS# 85344 & E85458, FDEP QAP# 880516 (941) 655-4022

For: Indiantown Company Inc.
P.O. Box 397
Indiantown, FL 33456-0397
Attn: Dean Smiley

10/13/1999
Page 1 of 1

Laboratory Number: 111251

Project: ICI
Location: WWTP
Sample ID: Digester
Sampled By: D Smiley on 09/28/1999 @ 1505
Received: 09/28/1999 @ 1645

REPORT OF ANALYSIS

LABORATORY DATA

Parameter	Result	Units	Method	Analyst	Date/Time of Analysis	MDL
Total Solids	1.18	%	EPA 160.3	J. Cosgrave	10/01/1999 @ 1154	N/A
pH	6.59	S.U.	EPA 150.1	J. Cosgrave	09/28/1999 @ 1700	N/A
Total Nitrogen	5.86	%	Calc.	A. Mitchell	10/11/1999 @ 1707	
Total Kjeldahl Nitrogen (N)	5.86	%	EPA 351.2	J. Gwaltney	10/01/1999 @ 1453	
Nitrate Nitrogen (NO _x -N)	0.02 _u	%	EPA 353.2	J. Gwaltney	10/05/1999 @ 1123	
Potassium (K)	0.67	%	EPA 7610	D. Morton	10/08/1999 @ 0906	
Total Phosphorus	2.42	%	EPA 365.2	D. Martin	10/05/1999 @ 1355	
Arsenic	3.4	mg/kg	EPA 7061	D. Morton	10/06/1999 @ 1600	
Cadmium	3.4 _u	mg/kg	EPA 7130	D. Morton	10/05/1999 @ 1510	
Copper	380.	mg/kg	EPA 7210	D. Morton	10/01/1999 @ 1759	
Lead	48.	mg/kg	EPA 7420	D. Morton	10/05/1999 @ 1338	
Mercury	1.0	mg/kg	EPA 7471	D. Morton	10/04/1999 @ 0905	
Molybdenum	6.4	mg/kg	EPA 7481	D. Morton	10/07/1999 @ 1558	
Nickel	24.	mg/kg	EPA 7520	D. Morton	10/05/1999 @ 1420	
Selenium	8.5 _u	mg/kg	EPA 7740	D. Murto	10/01/1999 @ 1315	
Zinc	302.	mg/kg	EPA 7950	D. Morton	10/05/1999 @ 1630	

Analysis on a dry basis

u = Parameter was analyzed for but not detected

Respectfully Submitted,



Angela F. Mitchell
Project Manager

SHORT ENVIRONMENTAL LABORATORIES, INC.

10405 US 27 South
Sebring, Florida 33870


(800) 833-4022 HRS# 85344 & E85458, FDEP QAP# 880516 (941) 655-4022

For: Indiantown Company Inc.
P.O. Box 397
Indiantown, FL 33456-0397
Attn: Dean Smiley

06/22/1999
Page 1 of 2

Laboratory Number: 103656

Project: ICI
Location: WWTP
Sample ID: Digestor
Sampled By: D Smiley on 05/18/1999 @ 1300
Received: 05/18/1999 @ 1700



REPORT OF ANALYSIS

LABORATORY DATA

Parameter	Result	Units	Method	Analyst	Date/Time of Analysis	MDL
Total Solids	1.70	%	EPA 160.3	W. Smith	05/25/1999 @ 0900	
Total Non-Volatile Solids	0.53	%	EPA 160.4	W. Smith	05/25/1999 @ 0900	
Total Volatile Solids	1.17	%	Calc.	W. Smith	05/25/1999 @ 0900	
pH	7.72	S.U.	EPA 150.1	J. Gwaltney	05/19/1999 @ 1310	
Total Nitrogen	9.13	%	Calc.	B. Cummings	06/22/1999 @ 1258	
Total Kjeldahl Nitrogen (N)	9.13	%	EPA 351.2	J. Gwaltney	06/01/1999 @ 1005	
Nitrate Nitrogen (NO _x -N)	0.01u	%	EPA 353.2	J. Gwaltney	05/28/1999 @ 1138	
Potassium (K)	0.36	%	EPA 7610	D. Morton	06/17/1999 @ 1810	
Total Phosphorus	2.61	%	EPA 365.2	D. Martin	05/20/1999 @ 0926	
Arsenic	1.9	mg/kg	EPA 7061	D. Morton	06/14/1999 @ 1656	
Cadmium	2.3u	mg/kg	EPA 7130	D. Morton	06/16/1999 @ 1300	
Copper	470.	mg/kg	EPA 7210	D. Morton	06/17/1999 @ 1400	
Lead	24.u	mg/kg	EPA 7420	D. Morton	06/16/1999 @ 1600	
Mercury	1.2	mg/kg	EPA 7471	D. Morton	05/19/1999 @ 1525	
Molybdenum	7.5	mg/kg	EPA 7481	D. Murto	06/16/1999 @ 1152	
Nickel	25.8	mg/kg	EPA 7520	D. Morton	06/15/1999 @ 1105	
Selenium	5.9u	mg/kg	EPA 7740	D. Murto	06/18/1999 @ 1106	
Zinc	648.	mg/kg	EPA 7950	D. Morton	06/15/1999 @ 1518	

Results on a dry basis.

u = Parameter was analyzed for but not detected

Respectfully Submitted,

Bruce Cummings
Laboratory Director

SHORT ENVIRONMENTAL LABORATORIES, INC.

10405 US 27 South
Sebring, Florida 33870


(800) 833-4022 HRS# 85344 & E85458, FDEP QAP# 880516 (941) 655-4022

For: Indiantown Company Inc.
P.O. Box 397
Indiantown, FL 33456-0397
Attn: Dean Smiley

06/22/1999
Page 1 of 2

Laboratory Number: 103656

Project: ICI
Location: WWTP
Sample ID: Digester
Sampled By: D Smiley on 05/18/1999 @ 1300
Received: 05/18/1999 @ 1700



REPORT OF ANALYSIS

LABORATORY DATA

Parameter	Result	Units	Method	Analyst	Date/Time of Analysis	MDL
Total Solids	1.70	%	EPA 160.3	W. Smith	05/25/1999 @ 0900	
Total Non-Volatile Solids	0.53	%	EPA 160.4	W. Smith	05/25/1999 @ 0900	
Total Volatile Solids	1.17	%	Calc.	W. Smith	05/25/1999 @ 0900	
pH	7.72	S.U.	EPA 150.1	J. Gwaltney	05/19/1999 @ 1310	
Total Nitrogen	9.13	%	Calc.	B. Cummings	06/22/1999 @ 1258	
Total Kjeldahl Nitrogen (N)	9.13	%	EPA 351.2	J. Gwaltney	06/01/1999 @ 1005	
Nitrate Nitrogen (NO ₃ -N)	0.01u	%	EPA 353.2	J. Gwaltney	05/28/1999 @ 1138	
Potassium (K)	0.36	%	EPA 7610	D. Morton	06/17/1999 @ 1810	
Total Phosphorus	2.61	%	EPA 365.2	D. Martin	05/20/1999 @ 0926	
Arsenic	1.9	mg/kg	EPA 7061	D. Morton	06/14/1999 @ 1656	
Cadmium	2.3u	mg/kg	EPA 7130	D. Morton	06/16/1999 @ 1300	
Copper	470.	mg/kg	EPA 7210	D. Morton	06/17/1999 @ 1400	
Lead	24.u	mg/kg	EPA 7420	D. Morton	06/16/1999 @ 1600	
Mercury	1.2	mg/kg	EPA 7471	D. Morton	05/19/1999 @ 1525	
Molybdenum	7.5	mg/kg	EPA 7481	D. Murto	06/16/1999 @ 1152	
Nickel	25.8	mg/kg	EPA 7520	D. Morton	06/15/1999 @ 1105	
Selenium	5.9u	mg/kg	EPA 7740	D. Murto	06/18/1999 @ 1106	
Zinc	648.	mg/kg	EPA 7950	D. Morton	06/15/1999 @ 1518	

Results on a dry basis.

u = Parameter was analyzed for but not detected

Respectfully Submitted,

A handwritten signature in cursive script, appearing to read "Bruce Cummings".

Bruce Cummings
Laboratory Director

SHORT ENVIRONMENTAL LABORATORIES, INC.

10405 US 27 South
Sebring, Florida 33870


(800) 833-4022 HRS# 85344 & E85458, FDEP QAP# 880516 (941) 655-4022

For: Indiantown Company Inc.
P.O. Box 397
Indiantown, FL 33456-0397
Attn: Dean Smiley

06/22/1999
Page 2 of 2

Laboratory Number: 103657

Project: ICI
Location: WWTP
Sample ID: Digester influent
Sampled By: D Smiley on 05/18/1999 @ 1300
Received: 05/18/1999 @ 1700



REPORT OF ANALYSIS

LABORATORY DATA

Parameter	Result	Units	Method	Analyst	Date/Time of Analysis	MDL
Total Solids	0.89	%	EPA 160.3	W. Smith	05/25/1999 @ 0900	
Total Non-Volatile Solids	0.29	%	EPA 160.4	W. Smith	05/25/1999 @ 0900	
Total Volatile Solids	0.60	%	Calc.	W. Smith	05/25/1999 @ 0900	

Respectfully Submitted,

A handwritten signature in black ink, appearing to read "Bruce Cummings".

Bruce Cummings
Laboratory Director


SHORT ENVIRONMENTAL LABORATORIES, INC.

10405 US 27 South
Sebring, Florida 33870

(800) 833-4022 HRS# 85344 & E85458, FDEP QAP# 880516 (941) 655-4022

For: Indiantown Company Inc.
P.O. Box 397
Indiantown, FL 33456-0397
Attn: Dean Smiley

06/22/1999
Page 2 of 2



Laboratory Number: 103657

Project: ICI
Location: WWTP
Sample ID: Digestor influent
Sampled By: D Smiley on 05/18/1999 @ 1300
Received: 05/18/1999 @ 1700

REPORT OF ANALYSIS

LABORATORY DATA

Parameter	Result	Units	Method	Analyst	Date/Time of Analysis	MDL
Total Solids	0.89	%	EPA 160.3	W. Smith	05/25/1999 @ 0900	
Total Non-Volatile Solids	0.29	%	EPA 160.4	W. Smith	05/25/1999 @ 0900	
Total Volatile Solids	0.60	%	Calc.	W. Smith	05/25/1999 @ 0900	

Respectfully Submitted,

A handwritten signature in cursive script, appearing to read "Bruce Cummings".

Bruce Cummings
Laboratory Director

SHORT ENVIRONMENTAL LABORATORIES
 10405 US 27 S
 SEBRING, FL 33870
 (941) 655-4022 (800) 833-4022

R E C E I V E D
 JUN 25 1999

CHAIN OF CUSTODY
 and
 TRANSMITTAL FORM

1C0

LABORATORY ANALYSES

SAMPLE'S NAME (PLEASE PRINT)		PROJECT NAME						LABORATORY ANALYSES							
DEAN SMITHEY		INDIANTOWN COMPANY, INC #380						pH							
SAMPLE'S SIGNATURE		PROJECT LOCATION						AS/S/M							
<i>[Signature]</i>		WWTP						Cd/S							
FIELD ID#	SAMPLE ID	DATE	TIME	SAMP TYPE	GRAB	LABORATORY ID#	# OF CONT	Mo/S/GF	Se/S/GF	%P	%SOL	%TKN	%NO _x	%K	%SOL(V)
								Ni/S	Zn/S <th>%N</th> <td></td> <td></td> <td></td> <td></td> <td></td>	%N					
A	DIGESTOR	5/18/99	1300	LSS	X	103656	1	X	X	X	X	X			
V.I.	DIGESTOR INFLUENT	5/18/99	1300	LSS	X	103657	1					X			
	<i>[Signature]</i>														

21

NUTRIENT CONTAINERS PRESERVED
 SAMPLES ICED TO 4C

YES NO
 YES NO

SAMPLE QTY:	RELINQUISHED BY:	ACCEPTED BY:	DATE:	TIME:
2	<i>[Signature]</i>	Jeffrey Finna	5-18-99	1530
2	Jeffrey Finna	<i>[Signature]</i>	5-18-99	1700

9120

RECLAIMED WATER OF EFFLUENT ANALYSIS REPORT

Part I - Instructions

- 1) All applicable items must be completed in full. Note that if parts of this application do not apply, those parts of the form need not be executed.
- 2) All information is to be typed or printed in ink.
- 3) This form shall be submitted to the appropriate District Office in accordance with the schedule in the permit.
- 4) Analyses shall be performed using appropriate methods and shall be capable of achieving minimum detection limits less than or equal to the maximum contaminant levels shown.
- 5) The following instructions apply to Parts III through VIII of this form.
- 6) Column (a) - List the parameters that are to be analyzed.
- 7) Column (b) - List the STORET Code for these parameters.
- 8) Column (c) - Record the results of the analysis. If the result was below the minimum detection limit, indicate by showing a less than sign preceding the detection limit for the analytical method used (i.e. <0.01).
- 9) Column (d) - List the primary or secondary drinking water standard from Chapter 62-550, F.A.C.
- 10) Column (e) - Indicate the analytical method used. Record the number from Figure 1 in Chapter 62-601, F.A.C., or from other sources.
- 11) Column (f) - Enter the date on which the analysis was run (MM/DD/YR).
- 12) (g) - If the result shown in Column (c) is greater than the standard shown in Column (d) - enter an asterisk (*) in Column (g).

Part II - General Information

1) Facility Name: Indiantown Company, Inc.

Address: P.O. Box 397

City: Indiantown, FL

Zip: 33456-0397

Telephone Number(including area code): (561) 597-2121

2) Owner or Authorized Representative

Name: Dean Smiley

Title: Lead Operator

Address: P.O. Box 397

City: Indiantown, FL

Zip: 33456-0397

Telephone Number: (561) 597-2121

3) Method of Discharge: Percolation Ponds

4) Report Period: 01/01/99 To: 12/31/99
(Begin Date) (End Date)

5) Name of Laboratory conducting the analysis: SHORT ENVIRONMENTAL LABORATORIES, INC.
Address: 10405 U.S. Highway 27 South
City: Sebring, Florida 33870
Telephone Number: 941-655-4022

6) The facilities DEP identification number (WAFR or GMS ID#): F10029939

7) DEP test site identification number (for the sampling location) EFF-6

8) Description of the monitoring point Plant effluent

9) Date on which the sample was taken (MM/DD/YR) 03/16-17/99

Time of day at which the sample was taken: 24hr composite. VOC's & TTHM's collected on 03/17/99 @ 1430

10) Date of extraction for the organic chemical analysis performed in Part VI (MM/DD/YR)

Part III - Inorganic Analysis

(a) Parameter Name	(b) STORET Code	(c) Analysis Result(mg/L)	(d) Standard (mg/L)	(e) Analytical Method	(f) Analysis Date	(g) Above Standard
Arsenic	900208	0.005 u	0.05	EPA 206.3	04/23/99	
Barium	900209	0.02 u	2.0	EPA 208.1	03/31/99	
Cadmium	900210	0.002 u	0.005	EPA 213.2	05/03/99	
Chromium	900211	0.005 u	0.1	EPA 218.2	04/23/99	
Fluoride	000951	0.17	4.0	EPA 340.2	04/01/99	
Lead	900212	0.001 u	0.015	EPA 239.2	04/13/99	
Mercury	900213	0.001 u	0.002	EPA 245.2	04/05/99	
Nitrate (as N)	071850	9.55	10.	EPA 353.2	04/05/99	
Selenium	900214	0.005 u	0.05	EPA 270.2	04/08/99	
Silver	900215	0.001 u	0.1	EPA 272.2	04/28/99	
Sodium	000929	74.	160.	EPA 273.1	03/30/99	

Part IV - Volatile Organic Analysis

(a) Parameter Name	(b) STORET Code	(c) Analysis Result(ug/L)	(d) Standard (ug/L)	(e) Analytical Method	(f) Analysis Date	(g) Above Standard
Ethylene dibromide	900222	0.01 u	0.02	EPA 504	04/07/99	
Para-dichlorobenzene	—	3.25	75.	EPA 502.2	03/24/99	
Vinyl chloride	039175	0.04 u	1.	EPA 502.2	03/24/99	
1,1-dichloroethene	034496	0.07 u	7.	EPA 502.2	03/24/99	
1,2-dichloroethane	034531	0.03 u	3.	EPA 502.2	03/24/99	
1,1,1-trichloroethane	034506	0.03 u	200.	EPA 502.2	03/24/99	
Carbon tetrachloride	032102	0.01 u	3.	EPA 502.2	03/24/99	
Trichloroethene	-	0.01 u	3.	EPA 502.2	03/24/99	
Tetrachloroethene	-	0.04 u	3.	EPA 502.2	03/24/99	
Benzene	034030	0.01 u	1.	EPA 502.2	03/24/99	

Part V - Trihalomethane Analysis

(a) Parameter Name	(b) STORET Code	(c) Analysis Result(mg/L)	(d) Standard (mg/L)	(e) Analytical Method	(f) Analysis Date	(g) Above Standard
Total THM	082080	0.0040	0.10	EPA 502.2	03/24/99	

u = Parameter was analyzed for but not detected.

Part VI - Organic Chemical Analysis

(a) Parameter Name	(b) STORET Code	(c) Analysis Result(ug/L)	(d) Standard (ug/L)	(e) Analytical Method	(f) Analysis Date	(g) Above Standard
Endrin	039390	0.015 u	2.	EPA 508	04/14/99	
Lindane	039782	0.015 u	0.2	EPA 508	04/14/99	
Methoxychlor	039480	0.050 u	40.	EPA 508	04/14/99	
Toxaphene	039400	0.2 u	3.	EPA 508	04/14/99	
2,4-D	039730	0.2 u	70.	EPA 515.1	04/10/99	
2,4,5-TP (Silvex)	039760	0.1 u	50.	EPA 515.1	04/10/99	

Part VII - Radiological Analysis

(a) Parameter Name	(b) STORET Code	(c) Analysis Result(pCi/L)	(d) Standard (pCi/L)	(e) Analytical Method	(f) Analysis Date	(g) Above Standard
Gross alpha excl. radon and uranium	001519	1.8+/-1.3	15.	SM7110B	04/01/99	
Radium-226 and Radium-228 combined	011503		5			

Part VIII - Secondary Chemical Analysis

(a) Parameter Name	(b) STORET Code	(c) Analysis Result(mg/L)	(d) Standard (mg/L)	(e) Analytical Method	(f) Analysis Date	(g) Above Standard
Chloride	000940	97.	250.	EPA 325.3	04/05/99	
Copper	900218	0.02	1.	EPA 220.1	04/02/99	
Iron	900219	0.05	0.3	EPA 236.1	03/31/99	
Manganese	900220	0.02	0.05	EPA 243.1	03/31/99	
Sulfate	000945	23.	250.	EPA 375.4	03/22/99	
Zinc	900221	0.039	5	EPA 289.1	04/09/99	
pH (units)	000403	7.38	6.5 - 8.5	EPA 150.1	03/17/99	
TDS	070300	557.	500	EPA 160.1	03/22/99	*
Foaming Agents	900217	0.21	0.5	EPA 425.1	03/17/99	


u = Parameter was analyzed for but not detected.

DEP Form 62-620.910(15)
Effective July 1, 1991

Part IX - Certification

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that these are significant penalties for submitting false information, including the possibility of fine and imprisonment.

Date: 5/26/99



Signature of Lead Operator

Phone: (561) 597-2121

Dean S. Smiley, Jr. A/6805
Name (please type) and Certification Number

Indiantown Company, Inc.

P.O. Box 397

Indiantown, FL 33456-0397

SHORT ENVIRONMENTAL LABORATORIES, INC.

10405 US 27 South
Sebring, Florida 33870

(800) 833-4022 HRS# 85344 & E85458, FDEP QAP# 880516 (941) 655-4022

For: Indiantown Company Inc.
P.O. Box 397
Indiantown, FL 33456-0397
Attn: Dean Smiley

05/03/1999
Page 1 of 5

Laboratory Number: 100784

Project: Indiantown
Location: WWTP
Sample ID: Plant effluent
Sampled By: R. Greene on 03/16/1999 @ 1340
Received: 03/17/1999 @ 1700

REPORT OF ANALYSIS

FIELD DATA

Temperature 24.8 deg. C
pH 7.38 S.U.
Conductivity 983. umho/cm
Dissolved Oxygen 6.2 mg/L

LABORATORY DATA

Parameter	Result	Units	Method	Analyst	Date/Time of Analysis	MDL
Color	27.	Pt-Co unit	EPA 110.2	D. Morton	03/18/1999 @ 1715	1.
Odor	3.	T.D.N.	SM 2150	D. Morton	03/18/1999 @ 1715	N/A
Total Dissolved Solids	557.	mg/L	EPA 160.1	D. Morton	03/22/1999 @ 1310	10.
Foaming Agents (MBAS)	0.21	mg/L	EPA 425.1	D. Martin	03/17/1999 @ 1700	0.02
Chloride	97.	mg/L	EPA 325.3	W. Smith	04/05/1999 @ 1200	0.5
Cyanide	0.027	mg/L	EPA 335.3	J. Gwaltney	03/30/1999 @ 1200	0.005
Fluoride	0.17	mg/L	EPA 340.2	W. Smith	04/01/1999 @ 0914	0.05
Sulfate	23.	mg/L	EPA 375.4	D. Martin	03/22/1999 @ 1000	1.
Nitrite Nitrogen (NO2-N)	0.75	mg/L	EPA 354.1	J. Gwaltney	03/18/1999 @ 1330	0.01
Nitrate Nitrogen (NO3-N)	9.55	mg/L	Calc.	B. Cummings	05/03/1999 @ 1025	0.02
Nitrate + Nitrite N (NO2+NO3)	10.3	mg/L	EPA 353.2	J. Gwaltney	04/05/1999 @ 1026	0.02
Aluminum	0.06	mg/L	EPA 202.1	D. Morton	03/31/1999 @ 1054	0.05
Antimony	0.003u	mg/L	EPA 204.2	D. Morton	04/09/1999 @ 0939	0.003
Arsenic	0.005u	mg/L	EPA 206.3	D. Morton	04/23/1999 @ 1730	0.005

u = Parameter was analyzed for but not detected

Respectfully Submitted,



Bruce Cummings
Laboratory Director

SHORT ENVIRONMENTAL LABORATORIES, INC.

10405 US 27 South
Sebring, Florida 33870

(800) 833-4022 HRS# 85344 & E85458, FDEP QAP# 880516 (941) 655-4022

For: Indiantown Company Inc.
P.O. Box 397
Indiantown, FL 33456-0397
Attn: Dean Smiley

05/03/1999
Page 2 of 5

Laboratory Number: 100784

Project: Indiantown
Location: WWTP
Sample ID: Plant effluent
Sampled By: R. Greene on 03/16/1999 @ 1340
Received: 03/17/1999 @ 1700

REPORT OF ANALYSIS

LABORATORY DATA

Parameter	Result	Units	Method	Analyst	Date/Time of Analysis	MDL
Barium	0.02u	mg/L	EPA 208.1	D. Morton	03/31/1999 @ 1300	0.02
Beryllium	0.001u	mg/L	EPA 210.2	D. Morton	04/29/1999 @ 1615	0.001
Cadmium	0.0002u	mg/L	EPA 213.2	D. Morton	05/03/1999 @ 0945	0.0002
Chromium	0.005u	mg/L	EPA 218.2	D. Morton	04/23/1999 @ 1040	0.005
Copper	0.02	mg/L	EPA 220.1	D. Morton	04/02/1999 @ 0926	0.01
Iron	0.05	mg/L	EPA 236.1	D. Morton	03/31/1999 @ 1425	0.02
Lead	0.001u	mg/L	EPA 239.2	D. Morton	04/13/1999 @ 1030	0.001
Manganese	0.02	mg/L	EPA 243.1	D. Morton	03/31/1999 @ 1720	0.01
Mercury	0.001u	mg/L	EPA 245.1	D. Morton	04/05/1999 @ 1436	0.001
Nickel	0.02	mg/L	EPA 249.1	D. Morton	04/09/1999 @ 1512	0.01
Selenium	0.005u	mg/L	EPA 270.2	D. Morton	04/08/1999 @ 1045	0.005
Silver	0.001u	mg/L	EPA 272.2	D. Morton	04/28/1999 @ 1047	0.001
Sodium	74.	mg/L	EPA 273.1	D. Morton	03/30/1999 @ 1510	1.0
Thallium	0.002u	mg/L	EPA 279.2	D. Morton	04/29/1999 @ 0957	0.002
Zinc	0.039	mg/L	EPA 289.1	D. Morton	04/09/1999 @ 1554	0.002
1,2,4-Trichlorobenzene	0.02u	ug/L	EPA 502.2	E84098	03/24/1999 @ 0000	0.02
cis-1,2-Dichloroethylene	0.01u	ug/L	EPA 502.2	E84098	03/24/1999 @ 0000	0.01
Xylenes (total)	0.02u	ug/L	EPA 502.2	E84098	03/24/1999 @ 0000	0.02
Dichloromethane	0.02u	ug/L	EPA 502.2	E84098	03/24/1999 @ 0000	0.02
o-Dichlorobenzene	0.05u	ug/L	EPA 502.2	E84098	03/24/1999 @ 0000	0.05

u = Parameter was analyzed for but not detected

Respectfully Submitted,



Bruce Cummings
Laboratory Director

SHORT ENVIRONMENTAL LABORATORIES, INC.

10405 US 27 South
Sebring, Florida 33870

(800) 833-4022 HRS# 85344 & E85458, FDEP QAP# 880516 (941) 655-4022

For: Indiantown Company Inc.
P.O. Box 397
Indiantown, FL 33456-0397
Attn: Dean Smiley

05/03/1999
Page 3 of 5

Laboratory Number: 100784

Project: Indiantown
Location: WWTP
Sample ID: Plant effluent
Sampled By: R. Greene on 03/16/1999 @ 1340
Received: 03/17/1999 @ 1700

REPORT OF ANALYSIS

LABORATORY DATA

Parameter	Result	Units	Method	Analyst	Date/Time of Analysis	MDL
para-Dichlorobenzene	3.25	ug/L	EPA 502.2	E84098	03/24/1999 @ 0000	0.01
Vinyl Chloride	0.04u	ug/L	EPA 502.2	E84098	03/24/1999 @ 0000	0.04
1,1-Dichloroethylene	0.07u	ug/L	EPA 502.2	E84098	03/24/1999 @ 0000	0.07
trans-1,2-Dichloroethylene	0.06u	ug/L	EPA 502.2	E84098	03/24/1999 @ 0000	0.06
1,2-Dichloroethane	0.03u	ug/L	EPA 502.2	E84098	03/24/1999 @ 0000	0.03
1,1,1-Trichloroethane	0.03u	ug/L	EPA 502.2	E84098	03/24/1999 @ 0000	0.03
Carbon Tetrachloride	0.01u	ug/L	EPA 502.2	E84098	03/24/1999 @ 0000	0.01
1,2-Dichloropropane	0.01u	ug/L	EPA 502.2	E84098	03/24/1999 @ 0000	0.01
Trichloroethylene	0.01u	ug/L	EPA 502.2	E84098	03/24/1999 @ 0000	0.01
1,1,2-Trichloroethane	0.03u	ug/L	EPA 502.2	E84098	03/24/1999 @ 0000	0.03
Tetrachloroethylene	0.04u	ug/L	EPA 502.2	E84098	03/24/1999 @ 0000	0.04
Monochlorobenzene	0.01u	ug/L	EPA 502.2	E84098	03/24/1999 @ 0000	0.01
Benzene	0.01u	ug/L	EPA 502.2	E84098	03/24/1999 @ 0000	0.01
Toluene	2.21	ug/L	EPA 502.2	E84098	03/24/1999 @ 0000	0.01
Ethylbenzene	0.01u	ug/L	EPA 502.2	E84098	03/24/1999 @ 0000	0.01
Styrene	0.01u	ug/L	EPA 502.2	E84098	03/24/1999 @ 0000	0.01
Dibromochloropropane	0.01u	ug/L	EPA 504	E84098	04/07/1999 @ 0000	0.01
Ethylene Dibromide	0.01u	ug/L	EPA 504	E84098	04/07/1999 @ 0000	0.01
Simazine	0.10u	ug/L	EPA 507	E84098	04/13/1999 @ 0000	0.10
Atrazine	0.10u	ug/L	EPA 507	E84098	04/13/1999 @ 0000	0.10

u = Parameter was analyzed for but not detected

Respectfully Submitted,



Bruce Cummings
Laboratory Director

SHORT ENVIRONMENTAL LABORATORIES, INC.

10405 US 27 South

Sebring, Florida 33870

(800) 833-4022 HRS# 85344 & E85458, FDEP QAP# 880516 (941) 655-4022

For: Indiantown Company Inc.
P.O. Box 397
Indiantown, FL 33456-0397
Attn: Dean Smiley

05/03/1999
Page 4 of 5

Laboratory Number: 100784

Project: Indiantown
Location: WWTP
Sample ID: Plant effluent
Sampled By: R. Greene on 03/16/1999 @ 1340
Received: 03/17/1999 @ 1700

REPORT OF ANALYSIS

LABORATORY DATA

Parameter	Result	Units	Method	Analyst	Date/Time of Analysis	MDL
Alachlor	0.40u	ug/L	EPA 507	E84098	04/13/1999 @ 0000	0.40
Endrin	0.015u	ug/L	EPA 508	E84098	04/14/1999 @ 0000	0.015
Lindane	0.015u	ug/L	EPA 508	E84098	04/14/1999 @ 0000	0.015
Methoxychlor	0.050u	ug/L	EPA 508	E84098	04/14/1999 @ 0000	0.050
Toxaphene	0.2u	ug/L	EPA 508	E84098	04/14/1999 @ 0000	0.2
Heptachlor	0.010u	ug/L	EPA 508	E84098	04/14/1999 @ 0000	0.010
Heptachlor Epoxide	0.020u	ug/L	EPA 508	E84098	04/14/1999 @ 0000	0.020
Hexachlorobenzene	0.010u	ug/L	EPA 508	E84098	04/14/1999 @ 0000	0.010
PCB	0.5u	ug/L	EPA 508	E84098	04/14/1999 @ 0000	0.5
Chlordane	0.02u	ug/L	EPA 508	E84098	04/14/1999 @ 0000	0.02
Dalapon	1.0u	ug/L	EPA 515.1	E84098	04/10/1999 @ 0000	1.0
Picloram	0.1u	ug/L	EPA 515.1	E84098	04/10/1999 @ 0000	0.1
Dinoseb	0.2u	ug/L	EPA 515.1	E84098	04/10/1999 @ 0000	0.2
2,4-D	0.2u	ug/L	EPA 515.1	E84098	04/10/1999 @ 0000	0.2
2,4,5-TP	0.1u	ug/L	EPA 515.1	E84098	04/10/1999 @ 0000	0.1
Pentachlorophenol	0.1u	ug/L	EPA 515.1	E84098	04/10/1999 @ 0000	0.1
Di(2-ethylhexyl)adipate	0.5u	ug/L	EPA 525.1	E84098	04/16/1999 @ 0000	0.5
Di(2-ethylhexyl)phthalate	1.0u	ug/L	EPA 525.1	E84098	04/16/1999 @ 0000	1.0
Hexachlorocyclopentadiene	0.1u	ug/L	EPA 525.1	E84098	04/16/1999 @ 0000	0.1
Benzo(A)pyrene	0.1u	ug/L	EPA 525.1	E84098	04/16/1999 @ 0000	0.1

u = Parameter was analyzed for but not detected

Respectfully Submitted,



Bruce Cummings
Laboratory Director

SHORT ENVIRONMENTAL LABORATORIES, INC.

10405 US 27 South
Sebring, Florida 33870

(800) 833-4022 HRS# 85344 & E85458, FDEP QAP# 880516 (941) 655-4022

For: Indiantown Company Inc.
P.O. Box 397
Indiantown, FL 33456-0397
Attn: Dean Smiley

05/03/1999
Page 5 of 5

Laboratory Number: 100784

Project: Indiantown
Location: WWTP
Sample ID: Plant effluent
Sampled By: R. Greene on 03/16/1999 @ 1340
Received: 03/17/1999 @ 1700

REPORT OF ANALYSIS

LABORATORY DATA

Parameter	Result	Units	Method	Analyst	Date/Time of Analysis	MDL
Oxanyl (Vydate)	2.0u	ug/L	EPA 531	E84098	04/01/1999 @ 0000	2.0
Carbofuran	1.5u	ug/L	EPA 531	E84098	04/01/1999 @ 0000	1.5
Glyphosate	6.0u	ug/L	EPA 547	E84098	04/02/1999 @ 0000	6.0
Endothall	5.0u	ug/L	EPA 548	E84098	04/01/1990 @ 0000	5.0
Diquat	0.4u	ug/L	EPA 549	E84098	03/29/1999 @ 0000	0.4
Total THMs	0.0040	mg/L	EPA 502.2	E84098	03/24/1999 @ 0000	0.0001
Gross Alpha	1.8	pCi/L	SM 7110 B	84147	04/01/1999 @ 0000	+/-1.3

u = Parameter was analyzed for but not detected

Respectfully Submitted,



Bruce Cummings
Laboratory Director

CHAIN OF CUSTODY

and

TRANSMITTAL FORM

LABORATORY DW 351

I	S	G	R	V	P	U	L	I	N	T	O
N	E	R	A	O	F	N	N	N	O	H	T
O	C	O	D	C	S	R	R	R	X	M	H
R	O	S			T	E	E	E	N		E
G	N	S	226			G	G	G	O		R
A	D	A	228		P				O		
N	A	A			C	G	G	G	2		
I	R				B	R	R	R			
C	Y					I	II	III			

SAMPLER'S NAME (PLEASE PRINT)	PROJECT NAME <i>Indian town Company</i>
SAMPLER'S SIGNATURE <i>[Signature]</i>	PROJECT LOCATION <i>WWTP</i>
	SAMPLE TYPE: DRINKING WATER

FACILITY ID#	SAMPLE ID	DATE	TIME	ENTRY	DIST	WELL	LAB ID	# OF CONT									
317C1-13	PLANT Effluent	3/17	1430	COMP 24hr			100784	13	X	X	X	X	X	X	X	X	X

COMMENTS: *sampler started at 1340 on 3/16/99* *VOC*

# OF SAMPLES	CONTAINERS RELINQUISHED BY:	ACCEPTED BY:	DATE	TIME
1	<i>[Signature]</i>	<i>[Signature]</i>	3/17/99	1700
	SAMPLES RELINQUISHED BY:	ACCEPTED BY:	DATE	TIME
	<i>[Signature]</i>	<i>[Signature]</i>		
	SAMPLES RELINQUISHED BY:	ACCEPTED BY:	DATE	TIME

*5 Vials - SS & THW
Gal Glass
2 50 S
2 - 1/2 Gal
1/2 G #1
1L - N
1L
1L Zn Acetate*

8422




**SHORT
ENVIRONMENTAL
LABORATORIES, INC.**

(800) 833-4022
(941) 655-4022
FAX (941) 655-5820
HRS# 85344 & E85458
QAP# 880516

E-mail - shortlab@strato.net

February 25, 1999



Mr. Dean Smiley
Indiantown Company, Inc.
P.O. Box 397
Indiantown, Florida 34956

Dear Dean:

As per our phone conversation on February 24, 1999 listed below are the prices on the 62.550 annual wastewater analyses we discussed. We will use our composite sampler, do all the required field work, lab analyses, and report it in the format required by FDEP.

Primary Inorganics	\$ 225.00
Secondary Inorganics	140.00
VOC	85.00
Pesticides/PCB	600.00
Gross Alpha *	50.00

	\$ 1,100.00
Field Time	100.00

	\$ 1,200.00
* If needed Ra 226 is -	\$ 90.00
If needed Ra 228 is -	125.00

I look forward to supplying quotes for your additional wastewater, ground water and drinking water requirements. If you have any further questions please call Bruce Cummings and me at 1-800-833-4022.


Sincerely,

Richard E. Greene
Field Manager

REG/bac

HARBOR BRANCH ENVIRONMENTAL LABORATORY

5600 US 1 North, Fort Pierce, FL 34946
561-465-2400, Ext. 285



Client: Indiantown Company, Inc.
Workorder ID Annual Compliance Well
Laboratory ID 8009797001
Sample ID Compliance Well

Sampled 12/10/98 10:30
Received 12/10/98 12:20
Reported 01/06/99 18:12

Matrix Environmental Water

Herbicides EPA 515.1

Parameter	Prep Date	Analyzed	Result	DL	Units
2,4-D	12/21/98	12/28/98 MM	ND	0.53	ug/L
2,4,5-TP	12/21/98	12/28/98 MM	ND	0.41	ug/L
Dalapon	12/21/98	12/28/98 MM	ND	2.6	ug/L
Dinoseb	12/21/98	12/28/98 MM	ND	0.58	ug/L
Pentachlorophenol	12/21/98	12/28/98 MM	ND	0.34	ug/L
Picloram	12/21/98	12/28/98 MM	ND	0.26	ug/L

Surrogate	Result	% Recovery	Limits
2,4-Dichlorophenylacetic acid	16 ug/L	80 %	(70-130)

Southeast Florida
Fort Pierce, FL 34946
FDOH #96230 / E96080

Orlando Area
Deftona, FL 32725
FDOH #83486 / E83509

Jacksonville Area
Fernandina Beach, FL 32034
FDOH #82500 / E82417


Fort Myers Area
Lehigh Acres, FL 33936
FDOH #85512 / E85370

West Central Florida
Spring Hill, FL 34607
FDOH #84526 / E84418

HARBOR BRANCH ENVIRONMENTAL LABORATORY

5600 US 1 North, Fort Pierce, FL 34946
561-465-2400, Ext. 285

FDEP QAP 870174



Client: Indiantown Company, Inc.
Workorder ID Annual Compliance Well
Laboratory ID 8009797001
Matrix Environmental Water

Sample ID Compliance Well

Pesticides Analysis EPA 608

Parameter	Prep Date	Analyzed	Result	DL	Units
Aldrin	12/11/98	12/19/98 SXS	ND	0.051	ug/L
alpha-BHC	12/11/98	12/19/98 SXS	ND	0.051	ug/L
beta-BHC	12/11/98	12/19/98 SXS	ND	0.051	ug/L
delta-BHC	12/11/98	12/19/98 SXS	ND	0.051	ug/L
gamma-BHC (Lindane)	12/11/98	12/19/98 SXS	ND	0.051	ug/L
Chlordane	12/11/98	12/19/98 SXS	ND	0.051	ug/L
4,4'-DDD	12/11/98	12/19/98 SXS	ND	0.051	ug/L
4,4'-DDE	12/11/98	12/19/98 SXS	ND	0.051	ug/L
4,4'-DDT	12/11/98	12/19/98 SXS	ND	0.051	ug/L
Dieldrin	12/11/98	12/19/98 SXS	ND	0.051	ug/L
Endosulfan I	12/11/98	12/19/98 SXS	ND	0.051	ug/L
Endosulfan II	12/11/98	12/19/98 SXS	ND	0.051	ug/L
Endosulfan sulfate	12/11/98	12/19/98 SXS	ND	0.051	ug/L
Endrin	12/11/98	12/19/98 SXS	ND	0.051	ug/L
Endrin aldehyde	12/11/98	12/19/98 SXS	ND	0.051	ug/L
Heptachlor	12/11/98	12/19/98 SXS	ND	0.051	ug/L
Heptachlor epoxide	12/11/98	12/19/98 SXS	ND	0.051	ug/L
Toxaphene	12/11/98	12/19/98 SXS	ND	1.0	ug/L
Aroclor-1016	12/11/98	12/19/98 SXS	ND	0.51	ug/L
Aroclor-1221	12/11/98	12/19/98 SXS	ND	0.51	ug/L
Aroclor-1232	12/11/98	12/19/98 SXS	ND	0.51	ug/L
Aroclor-1242	12/11/98	12/19/98 SXS	ND	0.51	ug/L
Aroclor-1248	12/11/98	12/19/98 SXS	ND	0.51	ug/L
Aroclor-1254	12/11/98	12/19/98 SXS	ND	0.51	ug/L
Aroclor-1260	12/11/98	12/19/98 SXS	ND	0.51	ug/L
Methoxychlor	12/11/98	12/19/98 SXS	ND	0.20	ug/L

Surrogate	Result	% Recovery	Limits
Decachlorobiphenyl	.065 ug/L	16 %	(20-136)
Tetrachlorometaxylene	.11 ug/L	28 %	(20-136)

Southeast Florida
Fort Pierce, FL 34946
FDOH #96230 / E96080

Orlando Area
Deltona, FL 32725
FDOH #83486 / E83509

Jacksonville Area
Fernandina Beach, FL 32034
FDOH #82500 / E82417


Fort Myers Area
Lehigh Acres, FL 33936
FDOH #85512 / E85370

West Central Florida
Spring Hill, FL 34607
FDOH #84526 / E84418

HARBOR BRANCH ENVIRONMENTAL LABORATORY

5600 US 1 North, Fort Pierce, FL 34946

561-465-2400, Ext. 285



Client: Indiantown Company, Inc.
Workorder ID: Annual Compliance Well
Laboratory ID: 8009797001
Matrix: Environmental Water

Page 4

Sample ID: Compliance Well

Semivolatile Analysis EPA 625

Parameter	Prep Date	Analyzed	Result	DL	Units
Phenol	12/17/98	12/22/98	ND	10	ug/L
2-Chlorophenol	12/17/98	12/22/98	ND	10	ug/L
2-Nitrophenol	12/17/98	12/22/98	ND	10	ug/L
2,4-Dimethylphenol	12/17/98	12/22/98	ND	10	ug/L
2,4-Dichlorophenol	12/17/98	12/22/98	ND	10	ug/L
4-Chloro-3-methylphenol	12/17/98	12/22/98	ND	10	ug/L
2,4,6-Trichlorophenol	12/17/98	12/22/98	ND	10	ug/L
2,4-Dinitrophenol	12/17/98	12/22/98	ND	25	ug/L
4-Nitrophenol	12/17/98	12/22/98	ND	25	ug/L
2-Methyl-4,6-dinitrophenol	12/17/98	12/22/98	ND	25	ug/L
Pentachlorophenol	12/17/98	12/22/98	ND	10	ug/L

Surrogate	Result	% Recovery	Limits
Terphenyl-d14	20 ug/L	40 %	(33-141)
2,4,6-Tribromophenol	31 ug/L	40 %	(10-123)
1,2-Dichlorobenzene-d4	26 ug/L	52 %	(16-110)
2-Fluorobiphenyl	30 ug/L	59 %	(43-116)
2-Fluorophenol	28 ug/L	37 %	(21-110)
Nitrobenzene-d5	29 ug/L	57 %	(35-114)
Phenol-d5	30 ug/L	40 %	(10-110)
2-Chlorophenol-d4	33 ug/L	43 %	(33-110)

Southeast Florida
Fort Pierce, FL 34946
FDOH #96230 / E96080

Orlando Area
Deltona, FL 32725
FDOH #83486 / E83509


Jacksonville Area
Fernandina Beach, FL 32034
FDOH #82500 / E82417

Fort Myers Area
Lehigh Acres, FL 33936
FDOH #85512 / E85370

West Central Florida
Spring Hill, FL 34607
FDOH #84526 / E84418

HARBOR BRANCH ENVIRONMENTAL LABORATORY

5600 US 1 North, Fort Pierce, FL 34946
561-465-2400, Ext. 285



Client: Indiantown Company, Inc.
Workorder ID Annual Compliance Well
Laboratory ID 8009797001
Matrix Environmental Water

Page 5

Sample ID Compliance Well

Trace Metals

Parameter	Method	Prep Date	Analyzed	Result	DL	Units
Antimony	SW-846 6010	12/18/98	12/21/98 DM	ND	0.0050	mg/L
Arsenic	SW-846 6010	12/18/98	12/21/98 DM	ND	0.0050	mg/L
Barium	SW-846 6010	12/18/98	12/21/98 DM	0.015	0.010	mg/L
Beryllium	SW-846 6010	12/18/98	12/21/98 DM	ND	0.0010	mg/L
Cadmium	SW-846 6010	12/18/98	12/21/98 DM	ND	0.0010	mg/L
Chromium	SW-846 6010	12/18/98	12/21/98 DM	ND	0.0020	mg/L
Copper	SW-846 6010	12/18/98	12/21/98 DM	ND	0.0020	mg/L
Lead	SW-846 6010	12/18/98	12/21/98 DM	0.0040	0.0030	mg/L
Manganese	SW-846 6010	12/18/98	12/21/98 DM	ND	0.010	mg/L
Nickel	SW-846 6010	12/18/98	12/21/98 DM	ND	0.0050	mg/L
Selenium	SW-846 6010	12/18/98	12/21/98 DM	ND	0.0050	mg/L
Sodium	SW-846 6010	12/18/98	12/21/98 DM	25	1.0	mg/L
Thallium	SW-846 6010	12/18/98	12/21/98 DM	ND	0.017	mg/L
Zinc	SW-846 6010	12/18/98	12/21/98 DM	ND	0.10	mg/L
Mercury	SW-846 7470	12/21/98	12/22/98 DM	ND	0.00050	mg/L

Southeast Florida
Fort Pierce, FL 34946
FDOH #96230 / E96080

Orlando Area
Deltona, FL 32725
FDOH #83486 / E83509

Jacksonville Area
Fernandina Beach, FL 32034
FDOH #82500 / E82417


Fort Myers Area
Lehigh Acres, FL 33936
FDOH #85512 / E85370

West Central Florida
Spring Hill, FL 34607
FDOH #84526 / E84418

HARBOR BRANCH ENVIRONMENTAL LABORATORY

5600 US 1 North, Fort Pierce, FL 34946

561-465-2400, Ext. 285



Client: Indiantown Company, Inc.
 Workorder ID Annual Compliance Well
 Laboratory ID 8009797001
 Matrix Environmental Water

Sample ID Compliance Well

Volatiles Analysis EPA 624

Parameter	Prep Date	Analyzed	Result	DL	Units
Acrolein	N/A	12/22/98 WR	ND	15	ug/L
Acrylonitrile	N/A	12/22/98 WR	ND	5.0	ug/L
Benzene	N/A	12/22/98 WR	ND	1.0	ug/L
Bromodichloromethane	N/A	12/22/98 WR	ND	2.0	ug/L
Bromoform	N/A	12/22/98 WR	ND	2.0	ug/L
Bromomethane	N/A	12/22/98 WR	ND	1.0	ug/L
Carbon tetrachloride	N/A	12/22/98 WR	ND	1.0	ug/L
Chlorobenzene	N/A	12/22/98 WR	ND	1.0	ug/L
Chloroethane	N/A	12/22/98 WR	ND	1.0	ug/L
Chloroform	N/A	12/22/98 WR	ND	1.0	ug/L
Chloromethane	N/A	12/22/98 WR	ND	1.0	ug/L
Dibromochloromethane	N/A	12/22/98 WR	ND	2.0	ug/L
2-Chloroethylvinyl ether	N/A	12/22/98 WR	ND	1.0	ug/L
1,1-Dichloroethane	N/A	12/22/98 WR	ND	1.0	ug/L
1,2-Dichloroethane	N/A	12/22/98 WR	ND	1.0	ug/L
1,1-Dichloroethene	N/A	12/22/98 WR	ND	1.0	ug/L
trans-1,2-Dichloroethene	N/A	12/22/98 WR	ND	1.0	ug/L
Methylene chloride	N/A	12/22/98 WR	ND	5.0	ug/L
1,2-Dichloropropane	N/A	12/22/98 WR	ND	1.0	ug/L
cis-1,3-Dichloropropene	N/A	12/22/98 WR	ND	2.0	ug/L
trans-1,3-Dichloropropene	N/A	12/22/98 WR	ND	2.0	ug/L
Ethylbenzene	N/A	12/22/98 WR	ND	1.0	ug/L
Tetrachloroethene	N/A	12/22/98 WR	ND	1.0	ug/L
1,1,2,2-Tetrachloroethane	N/A	12/22/98 WR	ND	5.0	ug/L
Toluene	N/A	12/22/98 WR	ND	1.0	ug/L
1,1,1-Trichloroethane	N/A	12/22/98 WR	ND	2.0	ug/L
1,1,2-Trichloroethane	N/A	12/22/98 WR	ND	2.0	ug/L
Trichloroethene	N/A	12/22/98 WR	ND	2.0	ug/L
Vinyl chloride	N/A	12/22/98 WR	ND	1.0	ug/L

Surrogate	Result	% Recovery	Limits
1,2-Dichloroethane-d4	52 ug/L	105 %	(75-135)

Southeast Florida
 Fort Pierce, FL 34946
 FDOH #96230 / E96080

Orlando Area
 Deltona, FL 32725
 FDOH #83486 / E83509


Jacksonville Area
 Fernandina Beach, FL 32034
 FDOH #82500 / E82417

Fort Myers Area
 Lehigh Acres, FL 33936
 FDOH #85512 / E85370

West Central Florida
 Spring Hill, FL 34607
 FDOH #84526 / E84418

HARBOR BRANCH ENVIRONMENTAL LABORATORY

5600 US 1 North, Fort Pierce, FL 34946
561-465-2400, Ext. 285



Client: Indiantown Company, Inc.
Workorder ID Annual Compliance Well
Laboratory ID 8009797001
Matrix Environmental Water

Sample ID **Compliance Well**

Surrogate	Result	% Recovery	Limits
Toluene-d8	46 ug/L	92 %	(64-142)
4-Bromofluorobenzene	49 ug/L	98 %	(79-112)

Southeast Florida
Fort Pierce, FL 34946
FDOH #96230 / E96080

Orlando Area
Deltona, FL 32725
FDOH #83486 / E83509


Jacksonville Area
Fernandina Beach, FL 32034
FDOH #82500 / E82417

Fort Myers Area
Lehigh Acres, FL 33936
FDOH #85512 / E85370

West Central Florida
Spring Hill, FL 34607
FDOH #84526 / E84418

HARBOR BRANCH ENVIRONMENTAL LABORATORY

5600 US 1 North, Fort Pierce, FL 34946
561-465-2400, Ext. 285



Client: Indiantown Company, Inc.
Workorder ID Annual Compliance Well
Laboratory ID 8009797001
Matrix Environmental Water

Sample ID **Compliance Well**

Wet Chemistry Analysis

Sulfate	EPA 300.0	N/A	12/15/98	KM	15	2.5	mg/L
Fluoride	EPA 300.0	N/A	12/10/98	16:26 RS	0.37	0.22	mg/L
Nitrite as N	EPA 300.0	N/A	12/10/98	16:26 RS	ND	0.044	mg/L
Nitrate as N	EPA 300.0	N/A	12/10/98	16:26 RS	0.24	0.060	mg/L
Cyanide	EPA 335.2	12/14/98	12/14/98	GE	0.013	0.010	mg/L
Surfactants as LAS, Mol.wt.340	EPA 425.1	12/10/98	12/15/98	CMM	0.17	0.040	mg/L

Southeast Florida
Fort Pierce, FL 34946
FDOH #96230 / E96080

Orlando Area
Deltona, FL 32725
FDOH #83486 / E83509

Jacksonville Area
Fernandina Beach, FL 32034
FDOH #82500 / E82417

Fort Myers Area
Lehigh Acres, FL 33936
FDOH #85512 / E85370

West Central Florida
Spring Hill, FL 34607
FDOH #84526 / E84418

FDOH # 86230/E88080
5800 U.S. 1 North
Fort Pierce, FL 34948

HARBOR BRANCH ENVIRONMENTAL LABORATORY

Phone: (561) 465-2400, Ext. 285 Fax: (561) 467-1584

Chain-of-Custody

USE BALL POINT PEN ONLY

FDOH # 82500/E82417
5390 First Coast Hwy., Suite 1
Fernandina Beach, FL 32034

Company: Indian Town Company

Method of Shipment: _____

Standard Turn Around Time

FDOH # 83486/E83508
255 Enterprise Road, Suite 1
Deltona, FL 32725

Address: PO Box 397

Cooler #'s _____

Rush in _____ Business Days

FDOH # 85512/E85370
307 Coolidge Avenue
Lehigh Acres, FL 33938

Indian Town FL 34956

Date _____ Time _____

For Lab Use Only			
Temperature Checked	Custody Seals Intact	pH Checked	HPN # <u>8009797</u>
Y <input checked="" type="checkbox"/>	O <input checked="" type="checkbox"/> N	O <input checked="" type="checkbox"/> N	

FDOH # 84256/E84418
2514 Osceola Blvd.
Spring Hill, FL 34607

Client Contact: D. Smiley

Project Name: Annual Compliance Work

Sampled By: D. Smiley

Purchase Order #: _____

PRESERVATIVE										Preservation Key	
NOV	NOV	NOV	NOV	NOV	NOV	NOV	NOV	NOV	NOV	N - Hydrochloric Acid	P - Phosphoric Acid
ANALYSES REQUESTED										N - Nitric Acid	ST - Sodium Thiosulfate
										S - Sulfuric Acid <td>U - Unpreserved</td>	U - Unpreserved
										SH - Sodium Hydroxide <td></td>	
Metals	Cyanide	Nitrate, Nitrite, Sulfate, Fluoride	608, 515, 607	624 VOC's	MBA's	COMMENTS					
✓						I 001 (ACW 12/10 1030 G GW 1 <u>Compliance Work</u> ACW 12/10 1030 G GW 1 " ACW 12/10 1030 G GW 1 " ACW 12/10 1030 G GW 3 " ACW 12/10 1030 G GW 3 " ACW 12/10 1030 G GW "					
	✓										
		✓									
			✓								
				✓							
					✓						

* Sample Type: G-Grab C-Composite O-Other ** Matrix: S-Solid SL-Sludge DW-Drinking Water GW-Ground Water SW-Surface Water WW-Wastewater

RELINQUISHED BY	RELINQUISHED BY	RELINQUISHED BY
DATE/TIME	DATE/TIME	DATE/TIME
RECEIVED BY	RECEIVED BY	RECEIVED FOR HBEL CUSTODY BY <u>B. North</u>
DATE/TIME	DATE/TIME	DATE/TIME <u>12-10-98 1220</u>

Distribution: WHITE with REPORT; YELLOW for FILE; PINK to CLIENT; GOLD for RECEIVING; GREEN for SAMPLER

PAGE ____ of ____



Florida Department of Environmental Regulation

Twin Towers Office Bldg. • 2600 Blair Stone Road • Tallahassee, Florida 32399-2400

DER Form #	17-601.900(4)
Form Title	Reclaimed Water or Effluent Analysis Report
Effective Date	July 1, 1991
DER Application No.	(Filed in by DER)

Reclaimed Water or Effluent Analysis Report

Part I - Instructions

- (1) All applicable items must be completed in full. Note that if parts of this application do not apply, those parts of the form need not be executed.
- (2) All information is to be typed or printed in ink.
- (3) This form shall be submitted to the appropriate District Office in accordance with the schedule in the permit.
- (4) Analyses shall be performed using appropriate methods and shall be capable of achieving minimum detection limits less than or equal to the maximum contaminant levels shown.
- (5) The following instructions apply to Parts III through VIII of this form.
- (6) Column (a) - List the parameters that are to be analyzed.
- (7) Column (b) - List the STORET Code for these parameters.
- (8) Column (c) - Record the results of the analysis. If the result was below the minimum detection limit, indicate by showing a less than sign preceding the detection limit for the analytical method used (i.e. < 0.01).
- (9) Column (d) - List the primary or secondary drinking water standard from Chapter 17-550, F.A.C.
- (10) Column (e) - Indicate the analytical method used. Record the number from Figure 1 in Chapter 17-601, F.A.C., or from other sources.
- (11) Column (f) - Enter the date on which the analysis was run (MM/DD/YR).
- (12) Column (g) - If the result shown in Column (c) is greater than the standard shown in Column (d) - enter an asterisk (*) in Column (g).

Part II - General Information

(1) Facility Name TADRIANTOWN WASTEWATER TREATMENT PLANT
 Address P.O. Box 397 / 14843 SW 168 TH AVE
 City TADRIANTOWN, FLA. Zip 34956
 Telephone Number (561) 597-3496

(2) Owner or Authorized Representative
 Name JAMES G. HEWITT / DEAN S. SMILEY, JR.
 Title SUPV. / ASST. SUPV.
 Address P.O. Box 397
 City TADRIANTOWN State FLA Zip 34956
 Telephone (561) 597-3496

(3) Method of Discharge EVAP. / POND. PONDS / IRRIGATION

(4) Report Period: 1 / 01 / 98 To 12 / 31 / 98
 (Beginning Date) (End Date)

(5) Name of Laboratory conducting the analysis: HARBOR BRANCH ENVIRONMENTAL LABORATORY
 Address 5600 US 2 NORTH
 City FT. PIERCE State FLA Zip 34956
 Telephone Number (561) 465-2400

(6) The facilities DER identification number (also known as the GMS identification number) 5143P03291

(7) DER test site identification number (for the sampling location) N/A

(8) Description of the monitoring point COMPLIANCE WELL

(9) Date on which the sample was taken (MM/DD/YR) 12/10/98

Time of day at which the sample was taken 10:30 a.m. p.m.

(10) Date of extraction for the organic chemical analysis performed in Part VI (MM/DD/YR) 1/1

Part III - Inorganic Analysis

(a) Parameter Name	(b) STORET Code	(c) Analysis Result (mg/L)	(d) Standard (mg/L)	(e) Analytical Method	(f) Analysis Date	(g) Above Standard
Arsenic	900208		0.05		/ /	
Barium	900209		1.0		/ /	
Cadmium	900210		0.010		/ /	
Chromium	900211		0.05		/ /	
Fluoride	000951		4.0		/ /	
Lead	900212		0.05		/ /	
Mercury	900213		0.002		/ /	
Nitrate (as N)	071850		10		/ /	
Selenium	900214		0.01		/ /	
Silver	900215		0.05		/ /	
Sodium	000929		160		/ /	

Part IV - Volatile Organic Analysis

(a) Parameter Name	(b) STORET Code	(c) Analysis Result (ug/L)	(d) Standard (ug/L)	(e) Analytical Method	(f) Analysis Date	(g) Above Standard
Ethylene dibromide	900222		0.02		/ /	
Para-dichlorobenzene	-		75		/ /	
Vinyl chloride	039175		1		/ /	
1,1-dichloroethane	034496		7		/ /	
1,2-dichloroethane	034531		3		/ /	

Part IV - Volatile Organic Analysis (continued)

(a) Parameter Name	(b) STORET Code	(c) Analysis Result (ug/L)	(d) Standard (ug/L)	(e) Analytical Method	(f) Analysis Date	(g) Above Standard
1,1,1-trichloroethane	034506		200		/ /	
Carbon tetrachloride	032102		3		/ /	
Trichloroethene	—		3		/ /	
Tetrachloroethene	—		3		/ /	
Benzene	034030		1		/ /	

Part V - Trihalomethane Analysis

(a) Parameter Name	(b) STORET Code	(c) Analysis Result (ug/L)	(d) Standard (ug/L)	(e) Analytical Method	(f) Analysis Date	(g) Above Standard
Total THM	082080		100		/ /	

Part VI - Organic Chemical Analysis

(a) Parameter Name	(b) STORET Code	(c) Analysis Result (ug/L)	(d) Standard (ug/L)	(e) Analytical Method	(f) Analysis Date	(g) Above Standard
Endrin	039390		0.02		/ /	
Lindane	039782		4		/ /	
Methoxychlor	039480		100		/ /	
Toxaphene	039400		5		/ /	
2,4-D	039730		100		/ /	
2,4,5-TP (Silvex)	039760		10		/ /	

Part VII - Radiological Analysis

(a) Parameter Name	(b) STORET Code	(c) Analysis Result (pCi/L)	(d) Standard (pCi/L)	(e) Analytical Method	(f) Analysis Date	(g) Above Standard
Gross alpha excl. radon and uranium	001519		15		/ /	
Radium-226 and Radium-228 combined	011503		5		/ /	

Part VIII - Secondary Chemical Analysis

(a) Parameter Name	(b) STORET Code	(c) Analysis Result (mg/L)	(d) Standard (mg/L)	(e) Analytical Method	(f) Analysis Date	(g) Above Standard
Chloride	000940		250		/ /	
Copper	900218		1		/ /	
Iron	900219		0.3		/ /	
Manganese	900220		0.05		/ /	

Part VIII - Secondary Chemical Analysis (continued)

(a) Parameter Name	(b) STORET Code	(c) Analysis Result (mg/L)	(d) Standard (mg/L)	(e) Analytical Method	(f) Analysis Date	(g) Above Standard
Sulfate	000945		250		/ /	
Zinc	900221		5		/ /	
pH (units)	000403		6.5 - 8.5		/ /	
TDS	070300		500		/ /	
Foaming Agents	900217		0.5		/ /	

Part IX - Certification

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that these are significant penalties for submitting false information, including the possibility of fine and imprisonment.

Date: _____

Phone: (_____) _____

Signature of Lead Operator

Name (please type) Certification Number

Address

Harbor Branch Oceanographic Institution, Inc.
Harbor Branch Environmental Laboratory
5600 U.S. 1, North
Fort Pierce, Florida 34946



FACSIMILE

DATE: Feb 3, 1999	
TO: DEAN SMILEY	
FAX NO: 561-597-5027	TELEPHONE:
Internet: hash@hbhel.com	
FROM: Don Hash	
FACSIMILE: (561) 467-1584	TELEPHONE: (561) 465-2400, ext. 285
FOLLOWS IS THE REUSE REPORTING FORM WITH DATA.	
NOT REQUESTED ON THE CHAIN TO RUN ARE SILVER, IRON, PH, TDS, CHLORIDE, RADS, EDB, AND 1,4 (PARA)DICHLOROBENZENE. ALL THESE DATA SLOTS ARE EMPTY EXCEPT I COULD GATHER THE SILVER AND IRON DATA FROM THE METALS RUN. OTHERS WOULD NEED TO BE COLLECTED, IF THAT IS EVEN NECESSARY.	
THOUGHT YOU SHOULD KNOW.	
IF THIS FORM WITH DATA IS OK, LET US KNOW AND I WILL SEND ALONG HARD COPY.	

5 PAGES INCLUDING COVER



Reclaimed Water or Effluent Analysis Report

Part I - Instructions

- (1) All applicable items must be completed in full. Note that if parts of this application do not apply, those parts of the form need not be executed.
- (2) All information is to be typed or printed in ink.
- (3) This form shall be submitted to the appropriate District Office in accordance with the schedule in the permit.
- (4) Analyses shall be performed using appropriate methods and shall be capable of achieving minimum detection limit is less than or equal to the maximum contaminant levels shown.
- (5) The following instructions apply to Parts III through VIII of this form.
- (6) Column (a) - List the parameters that are to be analyzed.
- (7) Column (b) - List the STORET Code for these parameters.
- (8) Column (c) - Record the results of the analysis. If the result was below the minimum detection limit, indicate by showing a less than sign preceding the detection limit for the analytical method used (i.e. < 0.01).
- (9) Column (d) - List the primary or secondary drinking water standard from Chapter 17-550, F.A.C.
- (10) Column (e) - Indicate the analytical method used. Record the number from Figure 1 in Chapter 17-601, F.A.C., or from other sources.
- (11) Column (f) - Enter the date on which the analysis was run (MM-DD-YR).
- (12) Column (g) - If the result shown in Column (c) is greater than the standard shown in Column (d) - enter an asterisk (*) in Column (g).

Part II - General Information

(1) Facility Name: Indianmound Company, Inc.

Address: POB 397

City: Indianmound

Zip: 34957

Telephone Number: 361-397-3496

(2) Owner or Authorized Representative

Name: _____

Title: _____

Address: _____

City: _____

State: _____

Zip: _____

Telephone Number: _____

(3) Method of Discharge: _____

(4) Report Period

To: _____

(Begin Date)

(End Date)

(5) Name of Laboratory conducting the analysis: Harbor Branch Environmental Laboratory

Address: 5600 U.S. 1 North

City: Ft. Pierce

State: FL

Zip: 34946

Telephone Number: 561-465-2400

(6) The facilities DER identification number (also known as the GMS identification number)

(7) DER test site identification number (for the sampling location)

(8) Description of the monitoring point

(9) Date on which the sample was taken (MM/DD/YR)

Time of day at which the sample was taken:

10:30

a.m.

p.m.

(10) Date of extraction for the organic chemical analysis performed in Part VI (MM/DD/YR) 5/5/2011 6:08:12 PM

Part III - Inorganic Analysis

(a) Parameter Name	(b) STORET Code	(c) Analysis Result (mg/L)	(d) Standard (mg/L)	(e) Analytical Method	(f) Analysis Date	(g) Above Standard
Arsenic	900208	<0.005	0.05	SW846-6010	12/21/98	
Barium	900209	0.015	2.0	SW846-6010	12/21/98	
Cadmium	900210	<0.001	0.005	SW846-6010	12/21/98	
Chromium	900211	<0.002	0.1	SW846-6010	12/21/98	
Fluoride	000951	0.37	4.0	EPA 3000	12/16/98	
Lead	900212	0.004	0.015	SW846-6010	12/21/98	
Mercury	900213	<0.0005	0.002	SW846-7470	12/21/98	
Nitrate (as N)	071850	0.24	10	EPA 3000	12/16/98	
Selenium	900214	<0.005	0.05	SW846-6010	12/21/98	
Silver	900215	<0.001	0.1	SW846-6010	12/21/98	
Sodium	000929	25	160	SW846-6010	12/21/98	

Part IV - Volatile Organic Analysis

(a) Parameter Name	(b) STORET Code	(c) Analysis Result (mg/L)	(d) Standard (mg/L)	(e) Analytical Method	(f) Analysis Date	(g) Above Standard
Ethylene dibromide	900222		0.00002	SW846-8011		
Para-dichlorobenzene	---		0.075	EPA 624		
Vinyl chloride	039175	<0.001	0.001	EPA 624	12/22/98	
1,1-dichloroethane	034496	<0.001	Unregulated	EPA 624	12/22/98	
1,2-dichloroethane	034531	<0.001	0.003	EPA 624	12/22/98	

Part IV- Volatile Organic Analysis (continued)

(a) Parameter Name	(b) STORET Code	(c) Analysis Result (mg/L)	(d) Standard (mg/L)	(e) Analytical Method	(f) Analysis Date	(g) Above Standard
1,1,1-trichloroethane	034506	<0.002	0.2	EPA 624	12/22/98	
Carbon tetrachloride	032102	<0.001	0.005	EPA 624	12/22/98	
Trichloroethene	--	<0.002	0.005	EPA 624	12/22/98	
Tetrachloroethene	--	<0.001	0.003	EPA 624	12/22/98	
Benzene	034030	<0.001	0.001	EPA 624	12/22/98	

Part V- Trihalomethane Analysis

(a) Parameter Name	(b) STORET Code	(c) Analysis Result (mg/L)	(d) Standard (mg/L)	(e) Analytical Method	(f) Analysis Date	(g) Above Standard
Total THM	082080	<0.0051	0.1	EPA 624	12/22/98	

Part VI- Organic Chemical Analysis

(a) Parameter Name	(b) STORET Code	(c) Analysis Result (mg/L)	(d) Standard (mg/L)	(e) Analytical Method	(f) Analysis Date	(g) Above Standard
Endrin	059390	<0.000051	0.002	EPA 608	12/22/98	
Lindane	039782	<0.000051	0.0002	EPA 608	12/22/98	
Methoxychlor	039480	<0.00020	0.04	EPA 608	12/22/98	
Toxaphene	039400	<0.0010	0.005	EPA 618	12/22/98	
2,4-D	039730	<0.00053	0.07	EPA 515	12/22/98	
2,4,5-TP (Silvex)	039760	<0.00041	0.05	EPA 515	12/22/98	

Part VII- Radiological Analysis

(a) Parameter Name	(b) STORET Code	(c) Analysis Result (pCi/L)	(d) Standard (pCi/L)	(e) Analytical Method	(f) Analysis Date	(g) Above Standard
Gross alpha excl. radon and uranium	001519		5	EPA 9010		
Radium-226 and Radium-228 combined	011503		5	EPA 903 (Ra-05)		

Part VIII- Secondary Chemical Analysis

(a) Parameter Name	(b) STORET Code	(c) Analysis Result (mg/L)	(d) Standard (mg/L)	(e) Analytical Method	(f) Analysis Date	(g) Above Standard
Chloride	000940		250	EPA 3000		
Copper	900218	<0.002	1	SW846-6010	12/22/98	
Iron	900219	0.37	0.3	SW846-6010	12/22/98	
Manganese	900220	<0.010	0.05	SW846-6010	12/22/98	

Part VIII- Secondary Chemical Analysis (continued)

(a) Parameter Name	(b) STORET Code	(c) Analysis Result (mg/L)	(d) Standard (mg/L)	(e) Analysis Method	(f) Analysis Date	(g) Analysis Station
Sulfate	000945	15	250	EPA 300.1	12/15/98	
Zinc	900221	<0.10	5	SW 846-9010	12/15/98	
pH (units)	000403		6.5-8.5	EPA 150.3		
TDS	070300		500	EPA 150.1		
Foaming Agents	900217	0.17	0.5	EPA 425.1	12/15/98	

Part IX - Certification

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and the attachments and that the information is true and accurate and that I believe the individuals immediately responsible for obtaining the information believe that the information is true and accurate and that there are no significant reasons for submitting false information, including the possibility of false imprisonment.


Date:

Phone:

Signature of Lead Analyst

Name (please type) and Certification Number

Address:



Water Operating Reports

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: _____

Treatment Plant Name: _____

Reporting Month/Year: JULY, 1997

DEP Form No. 1
 Permit Title: Monthly Operating Report for Public Water Systems that Use Ground Water and/or Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 18, 1988
 DEP Application No.: _____
 Filed in by DEP: _____

- Refer to Chapter 62-699, F.A.C., for plant staffing requirements. Class A plants must be staffed by a certified operator 24 hours per day for some days per week; Class B plants must be staffed by a certified operator seven days per week; Class C plants must be staffed/visited by a certified operator seven days per week or at least six days per week depending on the type and capacity of treatment at the plant; and Class D plants must be visited/checked by a certified operator and/or water system representative at least five days per week. The one day per week that a Class C plant may not be staffed/visited should, if possible, be a day when the plant is not in operation; and the two days per week that a Class D plant may not be visited/checked should, if possible, be days when the plant is not in operation and should be non-consecutive days if the plant is in operation six or seven days per week.

I. GENERAL WATER SYSTEM AND WATER TREATMENT PLANT INFORMATION

Water System Name and PWS Identification Number, System Owner, System Type, Service Connections to System, and Population Served by System

• System Name: Indiantown Water Company PWS Identification No.: 4430667
 • System Owner Name: Indiantown Company, Inc. Telephone No.: 561-597-2121
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956

• System Type: community; non-transient non-community; non-community; consecutive

• Number of Service Connections at End of Reporting Month: _____

• Total Population Served by System at End of Reporting Month: _____

Water Treatment Plant Name, Permitted Capacity of Plant, Plant Category and Class, and Plant Operators

• Treatment Plant Name: Indiantown Water Company Telephone No.: 561-597-2122
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956

• Permitted Maximum Day Capacity of Plant: 1,296,000 gpd

• Plant Category and Class per Rule 62-699.310(3), F.A.C.: 4-C

• Lead/Chief Plant Operator:

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
James Hewitt	3821	B	5

• Other Certified Plant Operators (attach additional sheets if necessary):

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
Dean Smiley	5715	B	2
Higino Rodriguez	8378	C	5
Earl Maine	4644	D	5

and for Consecutive Public Water Systems that Treat Their Water

Form No. 92-441.21024
 Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 18, 1994
 DEP Application No.:
 (Filled in by DEP)

System PWS Identification Number: _____
 Treatment Plant Name: _____
 Reporting Month/Year: July, 1997

II. SUMMARY OF DAILY WATER TREATMENT DATA FOR REPORTING MONTH

- Reporting Month/Year: July, 1997
- Type of Residual Disinfectant Maintained in Distribution System Served by Plant: free chlorine; combined chlorine (chloramine); chlorine dioxide
- Summary of Daily Water Treatment Data for Reporting Month:

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
1	17	642,000	2.4	0.8			
2	17	607,000	2.9	0.2			
3	17	671,000	2.5	0.8			
4	16	656,000	2.0	0.4			
5	16	640,000	2.0	0.5			
6	15	639,000	2.0	0.3			
7	16	640,000	2.2	0.5			
8	16	637,000	2.0	0.8			
9	16	667,000	1.9	0.7	6	0.6	
10	16	547,000	2.3	0.5			
11	14	571,000	2.0	1.0			
12	15	518,000	2.2	0.4			
13	16	550,000	1.0	1.0			
14	15	532,000	1.1	0.3			
15	15	511,000	1.9	1.1			
16	16	555,000	2.0	0.6			
17	14	562,000	2.2	0.8			
18	15	514,000	2.4	0.1			
19	15	499,000	2.9	0.3			
20	14	474,000	2.7	0.4			
21	15	543,000	2.0	0.5			
22	13	497,000	2.2	0.8			
23	15	503,000	2.0	0.6			
24	15	516,000	2.0	0.8			
25	15	558,000	2.5	0.6			
26	14	471,000	2.1	0.7			
27	16	511,000	2.3	0.8			
28	15	570,000	2.7	0.4			
29	14	527,000	2.0	0.3			

53

Monthly Operation Report for Public Water Systems that Use Ground Water
 and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: _____
 Treatment Plant Name: _____
 Reporting Month/Year: July, 1997

DEP Form No.: **62-555.310(3)**
 Form Title: **Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water**
 Effective Date: **December 19, 1994**
 DEP Application No.: _____
 (Filled in by DEP)

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L) ^a	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L) ^b	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L) ^c	
30	16	512,000	2.6	0.3			
31	15	529,000	2.7	0.5			
Total	XXXXXXX	17,369,000	XXXXXXXXXX	XXXXXXXXXX		XXXXXXXXXXXXXXXXXX	XXXXXXX
Avg.	XXXXXXX	560,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXXX
Max.	XXXXXXX	671,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXXX

^a If at any time the residual disinfectant concentration at the entry to the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

^b If at any time the residual disinfectant concentration in the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose and/or flush appropriate portions of the distribution system until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

III. SUMMARY OF USE, AT WATER TREATMENT PLANT, OF POLYMER CONTAINING ACRYLAMIDE, POLYMER CONTAINING EPICHLOROHYDRIN, AND/OR IRON AND MANGANESE SEQUESTANT (complete this part only for the reporting month of December each year)

• Is any polymer containing the monomer acrylamide used at the treatment plant? _____ If yes, the polymer dose and the acrylamide level in the polymer are as follows:

Polymer Dose - _____ ppm ^a	Acrylamide Level - _____ % ^b
---------------------------------------	---

^a The acrylamide level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for acrylamide exceeds 0.05% dosed at 1 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

• Is any polymer containing the monomer epichlorohydrin used at the treatment plant? _____ If yes, the polymer dose and the epichlorohydrin level in the polymer are as follows:

Polymer Dose - _____ ppm ^a	Epichlorohydrin Level - _____ % ^b
---------------------------------------	--

^a The epichlorohydrin level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for epichlorohydrin exceeds 0.01% dosed at 20 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

54

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: _____
 Treatment Plant Name: _____
 Reporting Month/Year: July, 1997

DEP Form No.:	62-555.910(3)
Form Title:	Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
Effective Date:	December 19, 1994
DEP Application No.:	_____
(Filed in by DEP)	

• is any iron and manganese sequestrant used at the treatment plant? _____ If yes, the type of sequestrant, sequestrant dose, etc., are as follows:

Type of Sequestrant (polyphosphate or sodium silicate): _____
Sequestrant Dose (mg/L of phosphate as PO ₄ or mg/L of silicate as SiO ₂): _____
If sodium silicate is used, the amount of added plus naturally occurring silicate = _____ mg/L as SiO ₂ .

If polyphosphate is used, the total phosphate applied shall not exceed 10 mg/L as PO₄ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.; and if sodium silicate is used, the amount of silicate added shall be limited to 20 mg/L as SiO₂ per "Recommended Standards for Water Works."
The amount of added plus naturally occurring silicate shall not exceed 60 mg/L as SiO₂ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.

IV. STATEMENT BY LEAD/CHIEF WATER TREATMENT PLANT OPERATOR

I, the undersigned lead/chief operator of Indiantown Water Co., certify that, to the best of my knowledge and belief, the information provided in this report is true and accurate.

Also, I certify that the following additional operations records applicable to this plant were prepared each day a certified operator staffed or visited the plant during the reporting month indicated on this report and that these records will be maintained available for review at the plant site for not less than five years:

- records of amounts of chemicals used and chemical feed rates;
- process performance records for coagulation/flocculation (e.g., source water temperature, pH, turbidity, color, and alkalinity and process effluent pH and alkalinity in addition to chemical feed rates);
- process performance records for sedimentation (e.g., process effluent turbidity and sludge volume produced);
- process performance records for filtration (e.g., process effluent turbidity and color, number of filters in service, filtration rates, unit filter run volumes, head losses, length of filter runs, frequency of backwash, amount of backwash water used, duration of backwash, and backwash rates);
- process performance records for lime-soda ash softening (e.g., source water and process effluent hardness in addition to records for coagulation/flocculation, sedimentation, and filtration);
- process performance records for ion exchange softening (e.g., feed and bypass flows, blend rate, and salt and brine used);
- process performance records for reverse osmosis (e.g., feed, product, and brine flows; feed pressure, temperature, pH, conductivity, and turbidity; product pH and conductivity; and brine pH and conductivity); and
- process performance records for electrodialysis (e.g., polarity, feed temperature and total dissolved solids, product conductivity and total dissolved solids, dilute flow rate, brine make-up, pressures, and volts/amps).

James Hewitt 8/13/97
 Signature and Date

James Hewitt B.O. 3821
 Name and Certificate Number (please type or print)

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: _____

Reporting Month/Year: August 1997

SDP Form No. 1
 Form Title: Annual Reporting Form for Public Water Systems
 Effective Date: December 18, 1996
 SDP Application No.: _____
 Filed in by SDP: _____

Refer to Chapter 62-699, F.A.C., for plant staffing requirements. Class A plants must be staffed by a certified operator 24 hours per day for seven days per week; Class B plants must be staffed by a certified operator seven days per week; Class C plants must be staffed/visited by a certified operator seven days per week or at least six days per week depending on the type and capacity of treatment at the plant; and Class D plants must be visited/checked by a certified operator and/or water system representative at least five days per week. The one day per week that a Class C plant may not be staffed/visited should, if possible, be a day when the plant is not in operation; and the two days per week that a Class D plant may not be visited/checked should, if possible, be days when the plant is not in operation and should be non-consecutive days if the plant is in operation six or seven days per week.

I. GENERAL WATER SYSTEM AND WATER TREATMENT PLANT INFORMATION

Water System Name and PWS Identification Number, System Owner, System Type, Service Connections to System, and Population Served by System

● System
 Name: Indiantown Water Company PWS Identification No.: 4430667

● System Owner
 Name: Indiantown Company, Inc. Telephone No.: 561-597-2121
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL Zip Code: 34956

● System Type: community; non-transient non-community; non-community; consecutive

● Number of Service Connections at End of Reporting Month: 1710

● Total Population Served by System at End of Reporting Month: _____

Water Treatment Plant Name, Permitted Capacity of Plant, Plant Category and Class, and Plant Operators

● Treatment Plant
 Name: Indiantown Water Company Telephone No.: 561-597-2121
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL Zip Code: 34956

● Permitted Maximum Day Capacity of Plant: 1,200,000 gpd

● Plant Category and Class per Rule 62-699.310(3), F.A.C.: 4-C

● Lead/Chief Plant Operator:

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
James Hewitt	3821	B	5

● Other Certified Plant Operators (attach additional sheets if necessary):

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
Dean Smiley	5715	B	2
Higinio Rodriguez	8378	C	5
Earl Maine	4644	D	5

56

Treatment Plant Name: _____
 Reporting Month/Year: August, 1997

Treat Their Water
 Effective Date: December 19, 1995
 DEP Application No.: _____
 (Filed in by DEP)

II. SUMMARY OF DAILY WATER TREATMENT DATA FOR REPORTING MONTH

- Reporting Month/Year: August, 1997
- Type of Residual Disinfectant Maintained in Distribution System Served by Plant: free chlorine; combined chlorine (chloramine); chlorine dioxide
- Summary of Daily Water Treatment Data for Reporting Month:

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
1	15	315,000	2.0	0.8			
2	14	347,000	2.0	0.8			
3	16	389,000	2.0	0.8			
4	15	428,000	1.6	1.0			
5	18	405,000	3.5	0.2			
6	18	414,000	2.5	1.2			
7	13	389,000	2.0	0.4			
8	14	388,000	2.0	0.3			
9	15	388,000	1.9	0.5			
10	14	379,000	1.5	0.4			
11	15	404,000	2.0	0.8	6	0.6	
12	16	401,000	1.5	0.8			
13	15	407,000	1.5	0.6			
14	16	420,000	2.0	0.8			
15	19	440,000	3.5	1.1			
16	16	431,000	3.0	1.0			
17	15	389,000	1.3	1.2			
18	16	439,000	0.9	1.0			
19	13	395,000	1.0	1.2			
20	14	450,000	1.1	1.0			
21	13	488,000	1.0	0.2			
22	13	417,000	0.5	0.6			
23	11	322,000	1.0	0.2			
24	16	421,000	1.1	0.5			
25	18	483,000	1.2	0.5			
26	13	391,000	1.0	0.4			
27	15	422,000	1.5	0.8			
28	13	440,000	2.0	0.3			
29	15	467,000	1.0	0.6			

Monthly operation report for public water systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: _____

Treatment Plant Name: _____

Reporting Month/Year: August, 1997

DEP Form No.: **62-555-910(3)**
 Form Title: **Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water**
 Effective Date: **December 19, 1994**
 DEP Application No.: _____
 (Filled in by DEP)

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
30	19	440,000	2.5	0.7			
31	16	468,000	2.0	0.6			
Total	XXXXXXX	12,773,000	XXXXXXXXXX	XXXXXXXXXX		XXXXXXXXXXXXXXXXXX	XXXXXXX
Avg.	XXXXXXX	412,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXX
Max.	XXXXXXX	483,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXX

* If at any time the residual disinfectant concentration at the entry to the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

† If at any time the residual disinfectant concentration in the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose and/or flush appropriate portions of the distribution system until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

III. SUMMARY OF USE, AT WATER TREATMENT PLANT, OF POLYMER CONTAINING ACRYLAMIDE, POLYMER CONTAINING EPICHLOROHYDRIN, AND/OR IRON AND MANGANESE SEQUESTRANT (complete this part only for the reporting month of December each year)

• Is any polymer containing the monomer acrylamide used at the treatment plant? _____ If yes, the polymer dose and the acrylamide level in the polymer are as follows:

Polymer Dose - _____ ppm* Acrylamide Level - _____ %*

* The acrylamide level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for acrylamide exceeds 0.05% dosed at 1 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

• Is any polymer containing the monomer epichlorohydrin used at the treatment plant? _____ If yes, the polymer dose and the epichlorohydrin level in the polymer are as follows:

Polymer Dose - _____ ppm* Epichlorohydrin Level - _____ %*

* The epichlorohydrin level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for epichlorohydrin exceeds 0.01% dosed at 20 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

58

Monthly Operation Report for Public Water Systems that Use Ground Water
and for Consecutive Public Water Systems that Treat Their Water
 System PWS Identification Number: _____
 Treatment Plant Name: _____
 Reporting Month/Year: August 1997

DEP Form No.: 62-555.910(3)
 Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 19, 1994
 DEP Application No.: _____
 (Filed in by DEP)

• Is any iron and manganese sequestrant used at the treatment plant? _____ If yes, the type of sequestrant, sequestrant dose, etc., are as follows:

Type of Sequestrant (polyphosphate or sodium silicate): _____
Sequestrant Dose (mg/L of phosphate as PO ₄ or mg/L of silicate as SiO ₂): _____
If sodium silicate is used, the amount of added plus naturally occurring silicate = _____ mg/L as SiO ₂ . ¹

¹ If polyphosphate is used, the total phosphate applied shall not exceed 10 mg/L as PO₄ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.; and if sodium silicate is used, the amount of silicate added shall be limited to 20 mg/L as SiO₂ per "Recommended Standards for Water Works."
¹ The amount of added plus naturally occurring silicate shall not exceed 60 mg/L as SiO₂ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.

IV. STATEMENT BY LEAD/CHIEF WATER TREATMENT PLANT OPERATOR

I, the undersigned lead/chief operator of Judithtown Water Co., certify that, to the best of my knowledge and belief, the information provided in this report is true and accurate.

Also, I certify that the following additional operations records applicable to this plant were prepared each day a certified operator staffed or visited the plant during the reporting month indicated on this report and that these records will be maintained available for review at the plant site for not less than five years:

- records of amounts of chemicals used and chemical feed rates;
- process performance records for coagulation/flocculation (e.g., source water temperature, pH, turbidity, color, and alkalinity and process effluent pH and alkalinity in addition to chemical feed rates);
- process performance records for sedimentation (e.g., process effluent turbidity and sludge volume produced);
- process performance records for filtration (e.g., process effluent turbidity and color, number of filters in service, filtration rates, unit filter run volumes, head losses, length of filter runs, frequency of backwash, amount of backwash water used, duration of backwash, and backwash rates);
- process performance records for lime-soda ash softening (e.g., source water and process effluent hardness in addition to records for coagulation/flocculation, sedimentation, and filtration);
- process performance records for ion exchange softening (e.g., feed and bypass flows, blend rate, and salt and brine used);
- process performance records for reverse osmosis (e.g., feed, product, and brine flows; feed pressure, temperature, pH, conductivity, and turbidity; product pH and conductivity; and brine pH and conductivity); and
- process performance records for electro dialysis (e.g., polarity, feed temperature and total dissolved solids, product conductivity and total dissolved solids, dilute flow rate, brine make-up, pressures, and volts/amperes).

James Hewitt 9/15/97
 Signature and Date

JAMES HEWITT B.O. 3821
 Name and Certificate Number (please type or print)

The Company cannot find a copy of the September, 1997, Operating Report and believes the original may have been sent to DEP without a copy being made.

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667
 Treatment Plant Name: Indian Town Water Co
 Reporting Month/Year: October, 1997

DEP Form No. 1
 Form Title: **Monthly Operation Report for Public Water Systems that Use Ground Water and/or Consecutive Public Water Systems that Treat Their Water**
 Effective Date: December 18, 1996
 DEP Application No.: _____
 Filed in by DEP: _____

- Refer to Chapter 62-699, F.A.C., for plant staffing requirements. Class A plants must be staffed by a certified operator 24 hours per day for some days per week; Class B plants must be staffed by a certified operator seven days per week; Class C plants must be staffed/visited by a certified operator seven days per week or at least six days per week depending on the type and capacity of treatment at the plant; and Class D plants must be visited/checked by a certified operator and/or water system representative at least five days per week. The one day per week that a Class C plant may not be staffed/visited should, if possible, be a day when the plant is not in operation; and the two days per week that a Class D plant may not be visited/checked should, if possible, be days when the plant is not in operation and should be non-consecutive days if the plant is in operation six or seven days per week.

I. GENERAL WATER SYSTEM AND WATER TREATMENT PLANT INFORMATION

Water System Name and PWS Identification Number, System Owner, System Type, Service Connections to System, and Population Served by System

- System Name: Indiantown Water Company PWS Identification No.: 4430667
- System Owner Name: Indiantown Company, Inc. Telephone No.: 561-597-2121
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956
- System Type: community; non-transient non-community; non-community; consecutive
- Number of Service Connections at End of Reporting Month: 1690
- Total Population Served by System at End of Reporting Month: 5070

Water Treatment Plant Name, Permitted Capacity of Plant, Plant Category and Class, and Plant Operators

- Treatment Plant Name: Indiantown Water Company Telephone No.: 561-597-2122
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956
- Permitted Maximum Day Capacity of Plant: 1,296,000 gpd
- Plant Category and Class per Rule 62-699.310(3), F.A.C.: 4-C
- Lead/Chief Plant Operator:

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
James Hewitt	3821	B	5

- Other Certified Plant Operators (attach additional sheets if necessary):

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
Dean Smiley	5715	B	2
Rigino Rodriguez	8378	C	5
Earl Maine	4644	D	5

4430667
 Treatment Plant Name: Fredericktown Water Co
 Reporting Month/Year: October, 1997

Consent to Publish Water System Information
 Issued Under Order
 December 18, 1995
 Effective Date: _____
 DEP Application No.: _____
 Filed in by DEP

II. SUMMARY OF DAILY WATER TREATMENT DATA FOR REPORTING MONTH

- Reporting Month/Year: October, 1997
- Type of Residual Disinfectant Maintained in Distribution System Served by Plant: free chlorine; combined chlorine (chloramine); chlorine dioxide
- Summary of Daily Water Treatment Data for Reporting Month:

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
1	16	553,000	2.6	1.5			
2	15	542,000	3.0	1.3			
3	17	633,000	1.5	1.1			
4	15	542,000	1.1	0.3			
5	16	405,000	1.4	0.2			
6	18	686,000	1.7	1.0			
7	16	587,000	3.0	0.4			
8	20	625,000	2.5	1.1			
9	16	577,000	2.3	0.6			
10	14	550,000	2.5	1.0			
11	15	478,000	2.0	1.0			
12	17	576,000	3.0	0.9			
13	17	641,000	2.0	0.3			
14	19	611,000	3.5	0.4			
15	17	612,000	1.9	0.6			
16	16	631,000	1.8	0.3			
17	17	603,000	1.7	0.7			
18	17	655,000	1.2	0.4			
19	16	778,000	2.5	0.9			
20	19	677,000	2.7	0.6			
21	15	615,000	1.6	1.1			
22	17	658,000	1.9	0.5	6	0.8	
23	18	616,000	3.0	0.6			
24	15	632,000	2.0	0.4			
25	17	621,000	2.5	0.7			
26	17	679,000	2.0	0.6			
27	18	723,000	2.0	0.9			
28	16	596,000	2.0	0.4			
29	17	628,000	2.0	0.7			

62

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
30	17	636,000	1.9	0.4			
31	17	635,000	2.3	0.8			
Total	XXXXXXX	19,001,000	XXXXXXXXXX	XXXXXXXXXX	6	XXXXXXXXXXXXXXXXXX	XXXXXXX
Avg.	XXXXXXX	589,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXXX
Max.	XXXXXXX	778,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXXX

* If at any time the residual disinfectant concentration at the entry to the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

† If at any time the residual disinfectant concentration in the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose and/or flush appropriate portions of the distribution system until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

III. SUMMARY OF USE, AT WATER TREATMENT PLANT, OF POLYMER CONTAINING ACRYLAMIDE, POLYMER CONTAINING EPICHLOROHYDRIN, AND/OR IRON AND MANGANESE SEQUESTRANT (complete this part only for the reporting month of December each year)

• Is any polymer containing the monomer acrylamide used at the treatment plant? _____ If yes, the polymer dose and the acrylamide level in the polymer are as follows:

Polymer Dose - _____ ppm* Acrylamide Level - _____ %*

The acrylamide level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for acrylamide exceeds 0.05% dosed at 1 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

• Is any polymer containing the monomer epichlorohydrin used at the treatment plant? _____ If yes, the polymer dose and the epichlorohydrin level in the polymer are as follows:

Polymer Dose - _____ ppm* Epichlorohydrin Level - _____ %*

The epichlorohydrin level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for epichlorohydrin exceeds 0.01% dosed at 20 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

Treatment Plant Name: Jardinetown Water Co
Reporting Month/Year: October 1997

Effective Date: December 19, 1994
DEP Application No.: _____
(Filled in by DEP)

• Is any iron and manganese sequestrant used at the treatment plant? _____ If yes, the type of sequestrant, sequestrant dose, etc., are as follows:

Type of Sequestrant (polyphosphate or sodium silicate): _____
Sequestrant Dose (mg/L of phosphate as PO_4 or mg/L of silicate as SiO_2): _____
If sodium silicate is used, the amount of added plus naturally occurring silicate = _____ mg/L as SiO_2 . ¹

¹ If polyphosphate is used, the total phosphate applied shall not exceed 10 mg/L as PO_4 per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.; and if sodium silicate is used, the amount of silicate added shall be limited to 20 mg/L as SiO_2 , per "Recommended Standards for Water Works."
¹ The amount of added plus naturally occurring silicate shall not exceed 60 mg/L as SiO_2 , per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.

IV. STATEMENT BY LEAD/CHIEF WATER TREATMENT PLANT OPERATOR

I, the undersigned lead/chief operator of Jardinetown Water Co., certify that, to the best of my knowledge and belief, the information provided in this report is true and accurate.

Also, I certify that the following additional operations records applicable to this plant were prepared each day a certified operator staffed or visited the plant during the reporting month indicated on this report and that these records will be maintained available for review at the plant site for not less than five years:

- records of amounts of chemicals used and chemical feed rates;
- process performance records for coagulation/flocculation (e.g., source water temperature, pH, turbidity, color, and alkalinity and process effluent pH and alkalinity in addition to chemical feed rates);
- process performance records for sedimentation (e.g., process effluent turbidity and sludge volume produced);
- process performance records for filtration (e.g., process effluent turbidity and color, number of filters in service, filtration rates, unit filter run volumes, head losses, length of filter runs, frequency of backwash, amount of backwash water used, duration of backwash, and backwash rates);
- process performance records for lime-soda ash softening (e.g., source water and process effluent hardness in addition to records for coagulation/flocculation, sedimentation, and filtration);
- process performance records for ion exchange softening (e.g., feed and bypass flows, blend rate, and salt and brine used);
- process performance records for reverse osmosis (e.g., feed, product, and brine flows; feed pressure, temperature, pH, conductivity, and turbidity; product pH and conductivity; and brine pH and conductivity); and
- process performance records for electro dialysis (e.g., polarity, feed temperature and total dissolved solids, product conductivity and total dissolved solids, dilute flow rate, brine makeup, pressures, and volts/amps).

James Hewitt 11/12/97
Signature and Date

James Hewitt B.O. 3821
Name and Certificate Number (please type or print)

64

Monthly operation report for public water systems that use ground water
 and for consecutive public water systems that treat their water
 System PWS Identification Number: 4430667
 Treatment Plant Name: Indiantown Co., Inc.
 Reporting Month/Year: November, 1997

DEP Form No.: 62-699.310(3)
 Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 18, 1995
 DEP Application No.: _____
 Filed in by DEP: _____

- Refer to Chapter 62-699, F.A.C., for plant staffing requirements. Class A plants must be staffed by a certified operator 24 hours per day for seven days per week; Class B plants must be staffed by a certified operator seven days per week; Class C plants must be staffed/visited by a certified operator seven days per week or at least six days per week depending on the type and capacity of treatment at the plant; and Class D plants must be visited/checked by a certified operator and/or water system representative at least five days per week. The one day per week that a Class C plant may not be staffed/visited should, if possible, be a day when the plant is not in operation; and the two days per week that a Class D plant may not be visited/checked should, if possible, be days when the plant is not in operation and should be non-consecutive days if the plant is in operation six or seven days per week.

I. GENERAL WATER SYSTEM AND WATER TREATMENT PLANT INFORMATION

Water System Name and PWS Identification Number, System Owner, System Type, Service Connections to System, and Population Served by System

- System Name: Indiantown Water Company PWS Identification No.: 4430667
- System Owner Name: Indiantown Company, Inc. Telephone No.: 561-597-2121
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956
- System Type: community; non-transient non-community; non-community; consecutive
- Number of Service Connections at End of Reporting Month: 1690
- Total Population Served by System at End of Reporting Month: 5070

Water Treatment Plant Name, Permitted Capacity of Plant, Plant Category and Class, and Plant Operators

- Treatment Plant Name: Indiantown Water Company Telephone No.: 561-597-2122
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956
- Permitted Maximum Day Capacity of Plant: 1,296,000 gpd.
- Plant Category and Class per Rule 62-699.310(3), F.A.C.: 4-C
- Lead/Chief Plant Operator:

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
James Hewitt	3821	B	5

Other Certified Plant Operators (attach additional sheets if necessary):

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
Dean Smiley	5715	B	2
Higino Rodriguez	8378	C	5
Earl Maine	4644	D	5

65

**Monthly Operation Report for Public Water Systems that Use Ground Water
and for Consecutive Public Water Systems that Treat Their Water**

System PWS Identification Number: 4430667
 Treatment Plant Name: INDIAN TOWN WATER CO
 Reporting Month/Year: NOVEMBER, 1997

DEP Form No.: 82-DEP-2.12021
 Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 18, 1994
 DEP Application No.: _____
 (Filed in by DEP)

II. SUMMARY OF DAILY WATER TREATMENT DATA FOR REPORTING MONTH

- Reporting Month/Year: NOVEMBER, 1997
- Type of Residual Disinfectant Maintained in Distribution System Served by Plant: free chlorine; combined chlorine (chloramine); chlorine dioxide
- Summary of Daily Water Treatment Data for Reporting Month:

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
1	15	535,000	1.6	0.4			
2	17	612,000	1.5	0.9			
3	15	559,000	1.5	0.4			
4	17	545,000	1.6	0.6			
5	13	555,000	1.4	0.2			
6	14	505,000	1.5	0.3			
7	17	586,000	1.4	0.3			
8	15	542,000	1.9	0.5			
9	15	557,000	2.4	0.2			
10	18	630,000	2.5	0.2			
11	16	563,000	1.1	0.2			
12	16	545,000	1.0	0.2			
13	17	574,000	1.6	0.2			
14	16	514,000	3.0	0.4			
15	14	481,000	1.5	0.4			
16	15	542,000	1.5	0.4			
17	15	574,000	1.5	0.4			
18	16	592,000	1.5	0.3			
19	16	592,000	1.7	0.6	6	0.6	
20	16	553,000	1.0	0.6			
21	17	643,000	1.4	0.6			
22	16	569,000	1.0	0.4			
23	15	558,000	1.5	0.3			
24	17	611,000	2.6	1.0			
25	16	527,000	1.6	0.4			
26	15	574,000	1.6	1.0			
27	17	589,000	1.3	0.3			
28	17	605,000	1.5	1.0			
29	18	778,000	2.1	0.5			

66

Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667
 Treatment Plant Name: Indianapolis Water Co.
 Reporting Month/Year: November, 1997

DEP Form No.: 62-555.310(3)
 Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 13, 1994
 DEP Application No.: _____
 (Filled in by DEP)

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
30	14	763,000	1.3	0.9			
31							
Total	XXXXXXX	17,376,000	XXXXXXXXXXXX	XXXXXXXXXXXX		XXXXXXXXXXXXXXXX	XXXXXXX
Avg.	XXXXXXX	579,000	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXX	XXXXXXX
Max.	XXXXXXX	778,000	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXX	XXXXXXX

* If at any time the residual disinfectant concentration at the entry to the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

† If at any time the residual disinfectant concentration in the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose and/or flush appropriate portions of the distribution system until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

III. SUMMARY OF USE, AT WATER TREATMENT PLANT, OF POLYMER CONTAINING ACRYLAMIDE, POLYMER CONTAINING EPICHLOROHYDRIN, AND/OR IRON AND MANGANESE SEQUESTANT (complete this part only for the reporting month of December each year)

• Is any polymer containing the monomer acrylamide used at the treatment plant? _____ If yes, the polymer dose and the acrylamide level in the polymer are as follows:

Polymer Dose - _____ ppm*	Acrylamide Level - _____ %*
---------------------------	-----------------------------

* The acrylamide level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for acrylamide exceeds 0.05% dosed at 1 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

• Is any polymer containing the monomer epichlorohydrin used at the treatment plant? _____ If yes, the polymer dose and the epichlorohydrin level in the polymer are as follows:

Polymer Dose - _____ ppm*	Epichlorohydrin Level - _____ %*
---------------------------	----------------------------------

* The epichlorohydrin level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for epichlorohydrin exceeds 0.01% dosed at 20 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

67

Monthly Operation Report for Public Water Systems that Use Ground Water
and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667
Treatment Plant Name: Indian Town Water Co.
Reporting Month/Year: November 1997

DEP Form No.:	62-555.910(3)
Form Title:	Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
Effective Date:	December 19, 1994
DEP Application No.:	(Filled in by DEP)

• Is any iron and manganese sequestrant used at the treatment plant? _____ If yes, the type of sequestrant, sequestrant dose, etc., are as follows:

Type of Sequestrant (polyphosphate or sodium silicate): _____
Sequestrant Dose (mg/L of phosphate as PO_4 or mg/L of silicate as SiO_2): _____
If sodium silicate is used, the amount of added plus naturally occurring silicate - _____ mg/L as SiO_2 .

* If polyphosphate is used, the total phosphate applied shall not exceed 10 mg/L as PO_4 per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.; and if sodium silicate is used, the amount of silicate added shall be limited to 20 mg/L as SiO_2 per "Recommended Standards for Water Works."

† The amount of added plus naturally occurring silicate shall not exceed 60 mg/L as SiO_2 per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.

IV. STATEMENT BY LEAD/CHIEF WATER TREATMENT PLANT OPERATOR

I, the undersigned lead/chief operator of Indian Town Water Co., certify that, to the best of my knowledge and belief, the information provided in this report is true and accurate.

Also, I certify that the following additional operations records applicable to this plant were prepared each day a certified operator staffed or visited the plant during the reporting month indicated on this report and that these records will be maintained available for review at the plant site for not less than five years:

- records of amounts of chemicals used and chemical feed rates;
- process performance records for coagulation/flocculation (e.g., source water temperature, pH, turbidity, color, and alkalinity and process effluent pH and alkalinity in addition to chemical feed rates);
- process performance records for sedimentation (e.g., process effluent turbidity and sludge volume produced);
- process performance records for filtration (e.g., process effluent turbidity and color, number of filters in service, filtration rates, unit filter run volumes, head losses, length of filter runs, frequency of backwash, amount of backwash water used, duration of backwash, and backwash rates);
- process performance records for lime-soda ash softening (e.g., source water and process effluent hardness in addition to records for coagulation/flocculation, sedimentation, and filtration);
- process performance records for ion exchange softening (e.g., feed and bypass flows, blend rate, and salt and brine used);
- process performance records for reverse osmosis (e.g., feed, product, and brine flows; feed pressure, temperature, pH, conductivity, and turbidity; product pH and conductivity; and brine pH and conductivity); and
- process performance records for electrodialysis (e.g., polarity, feed temperature and total dissolved solids, product conductivity and total dissolved solids, dilute flow rate, brine make-up, pressures, and volts/amps).

James Hewitt 12/14/97
Signature and Date

James Hewitt B.O. 3821
Name and Certificate Number (please type or print)

68

Monthly operation report for public water systems that use ground water
and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667
Treatment Plant Name: Indiantown Water Co.
Reporting Month/Year: December, 1997

DEP Form No.: **62-699.310(3)**
Form Title: **Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water**
Effective Date: December 18, 1997
DEP Application No.: _____
Filed in by DEP: _____

- Refer to Chapter 62-699, F.A.C., for plant staffing requirements. Class A plants must be staffed by a certified operator 24 hours per day for seven days per week; Class B plants must be staffed by a certified operator seven days per week; Class C plants must be staffed/visited by a certified operator seven days per week or at least six days per week depending on the type and capacity of treatment at the plant; and Class D plants must be visited/checked by a certified operator and/or water system representative at least five days per week. The one day per week that a Class C plant may not be staffed/visited should, if possible, be a day when the plant is not in operation; and the two days per week that a Class D plant may not be visited/checked should, if possible, be days when the plant is not in operation and should be non-consecutive days if the plant is in operation six or seven days per week.

I. GENERAL WATER SYSTEM AND WATER TREATMENT PLANT INFORMATION

Water System Name and PWS Identification Number, System Owner, System Type, Service Connections to System, and Population Served by System

• **System**
Name: Indiantown Water Company PWS Identification No.: 4430667

• **System Owner**
Name: Indiantown Company, Inc. Telephone No.: 561-597-2121
Address: 15851 S.W. Farms Rd./P.O. Box 397
City: Indiantown State: FL. Zip Code: 34956

• System Type: community; non-transient non-community; non-community; consecutive

• Number of Service Connections at End of Reporting Month: 1701
• Total Population Served by System at End of Reporting Month: 5953

Water Treatment Plant Name, Permitted Capacity of Plant, Plant Category and Class, and Plant Operators

• **Treatment Plant**
Name: Indiantown Water Company Telephone No.: 561-597-2122
Address: 15851 S.W. Farms Rd./P.O. Box 397
City: Indiantown State: FL. Zip Code: 34956

• Permitted Maximum Day Capacity of Plant: 1,296,000 gpd
• Plant Category and Class per Rule 62-699.310(3), F.A.C.: 4-C

• Lead/Chief Plant Operator:

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
James Hewitt	3821	B	5

• Other Certified Plant Operators (attach additional sheets if necessary):

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
Dean Smiley	5715	B	2
Rigino Rodriguez	8378	C	5
Earl Maine	4644	D	5

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667
 Treatment Plant Name: Indiantown Water Co.
 Reporting Month/Year: December, 1997

DEP Form No.: 82-585.91028
 Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 18, 1995
 DEP Application No.: _____
 (Filed in by DEP)

II. SUMMARY OF DAILY WATER TREATMENT DATA FOR REPORTING MONTH

- Reporting Month/Year: December, 1997
- Type of Residual Disinfectant Maintained in Distribution System Served by Plant: free chlorine; combined chlorine (chloramine); chlorine dioxide
- Summary of Daily Water Treatment Data for Reporting Month:

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
1	16	639,000	1.0	0.3			
2	14	530,000	1.1	0.4			
3	14	528,000	1.0	0.4			
4	16	535,000	1.5	0.4			
5	15	506,000	1.5	0.4			
6	11	482,000	1.3	0.6			
7	16	502,000	1.4	0.2			
8	15	576,000	1.9	0.3			
9	16	539,000	1.5	0.2			
10	19	566,000	3.0	0.5			
11	18	563,000	3.5	0.4			
12	15	529,000	3.0	1.0			
13	14	498,000	1.6	0.6			
14	13	471,000	1.5	0.6			
15	15	534,000	2.0	0.7			
16	14	498,000	2.6	2.0			
17	13	514,000	2.5	1.0	6	0.9	
18	13	517,000	1.8	1.0			
19	15	535,000	1.3	1.0			
20	13	507,000	1.0	1.0			
21	15	547,000	1.0	1.0			
22	15	596,000	1.4	1.0			
23	15	611,000	2.0	0.7			
24	14	660,000	1.0	1.1			
25	15	613,000	1.1	0.5			
26	15	552,000	1.5	1.0			
27	15	531,000	1.5	0.2			
28	12	491,000	1.1	0.3			
29	15	544,000	1.0	0.2			

70

Monthly Operation Report for Public Water Systems that Use Ground Water

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667
Treatment Plant Name: INDIANTOWN WATER CO.
Reporting Month/Year: December 1997

DEP Form No.:
Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
Effective Date: December 19, 1994
DEP Application No.:
(Filed in by DEP)

• Is any iron and manganese sequestrant used at the treatment plant? yes If yes, the type of sequestrant, sequestrant dose, etc., are as follows: 1/2 year

Type of Sequestrant (polyphosphate or sodium silicate): polyphosphate
Sequestrant Dose (mg/L of phosphate as PO₄ or mg/L of silicate as SiO₂): 2 mg/L
If sodium silicate is used, the amount of added plus naturally occurring silicate = mg/L as SiO₂.

* If polyphosphate is used, the total phosphate applied shall not exceed 10 mg/L as PO₄ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.; and if sodium silicate is used, the amount of silicate added shall be limited to 20 mg/L as SiO₂ per "Recommended Standards for Water Works."
* The amount of added plus naturally occurring silicate shall not exceed 60 mg/L as SiO₂ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.

IV. STATEMENT BY LEAD/CHIEF WATER TREATMENT PLANT OPERATOR

I, the undersigned lead/chief operator of INDIANTOWN WATER CO., certify that, to the best of my knowledge and belief, the information provided in this report is true and accurate.

Also, I certify that the following additional operations records applicable to this plant were prepared each day a certified operator staffed or visited the plant during the reporting month indicated on this report and that these records will be maintained available for review at the plant site for not less than five years:

- records of amounts of chemicals used and chemical feed rates;
- process performance records for coagulation/flocculation (e.g., source water temperature, pH, turbidity, color, and alkalinity and process effluent pH and alkalinity in addition to chemical feed rates);
- process performance records for sedimentation (e.g., process effluent turbidity and sludge volume produced);
- process performance records for filtration (e.g., process effluent turbidity and color, number of filters in service, filtration rates, unit filter run volumes, head losses, length of filter runs, frequency of backwash, amount of backwash water used, duration of backwash, and backwash rates);
- process performance records for lime-soda ash softening (e.g., source water and process effluent hardness in addition to records for coagulation/flocculation, sedimentation, and filtration);
- process performance records for ion exchange softening (e.g., feed and bypass flows, blend rate, and salt and brine used);
- process performance records for reverse osmosis (e.g., feed, product, and brine flows; feed pressure, temperature, pH, conductivity, and turbidity; product pH and conductivity; and brine pH and conductivity); and
- process performance records for electrodialysis (e.g., polarity, feed temperature and total dissolved solids, product conductivity and total dissolved solids, dilute flow rate, brine make-up, pressures, and volts/amperes).

James Hewitt 1/13/98
Signature and Date

JAMES HEWITT B.O. 3821
Name and Certificate Number (please type or print)

community operation reports for public water systems that use ground water
and for consecutive public water systems that treat their water

System PWS Identification Number: 4430667
Treatment Plant Name: Indiantown Water Company
Reporting Month/Year: JANUARY 1978

DEP Form No.: 62-699.2 (1978)
Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
Effective Date: December 18, 1978
DEP Application No.: _____ (Print in by DEP)

Refer to Chapter 62-699, F.A.C., for plant staffing requirements. Class A plants must be staffed by a certified operator 24 hours per day for seven days per week; Class B plants must be staffed by a certified operator seven days per week; Class C plants must be staffed/visited by a certified operator seven days per week or at least six days per week depending on the type and capacity of treatment at the plant; and Class D plants must be visited/checked by a certified operator and/or water system representative at least five days per week. The one day per week that a Class C plant may not be staffed/visited should, if possible, be a day when the plant is not in operation; and the two days per week that a Class D plant may not be visited/checked should, if possible, be days when the plant is not in operation and should be non-consecutive days if the plant is in operation six or seven days per week.

I. GENERAL WATER SYSTEM AND WATER TREATMENT PLANT INFORMATION

Water System Name and PWS Identification Number, System Owner, System Type, Service Connections to System, and Population Served by System

• System Name: Indiantown Water Company PWS Identification No.: 4430667
• System Owner Name: Indiantown Company, Inc. Telephone No.: 561-597-2121
Address: 15851 S.W. Farms Rd./P.O. Box 397
City: Indiantown State: FL. Zip Code: 34956
• System Type: community; non-transient non-community; non-community; consecutive
• Number of Service Connections at End of Reporting Month: 1705
• Total Population Served by System at End of Reporting Month: 5967

Water Treatment Plant Name, Permitted Capacity of Plant, Plant Category and Class, and Plant Operators

• Treatment Plant Name: Indiantown Water Company Telephone No.: 561-597-2122
Address: 15851 S.W. Farms Rd./P.O. Box 397
City: Indiantown State: FL. Zip Code: 34956
• Permitted Maximum Day Capacity of Plant: 1,296,000 gpd
• Plant Category and Class per Rule 62-699.310(3), F.A.C.: 4-C
• Lead/Chief Plant Operator:

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
James Hewitt	3821	B	5

• Other Certified Plant Operators (attach additional sheets if necessary):

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
Dean Smiley	5715	B	2
Rigino Rodriguez	8378	C	5
Earl Maine	4644	D	5

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: JANUARY, 1998

USE Form No. 62-111.2.1002
 Form Title: Monthly Operating Report for Public Water Systems that Use Ground Water and/or Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 18, 1994
 DEP Application No.: _____
 Filed in by DEP

II. SUMMARY OF DAILY WATER TREATMENT DATA FOR REPORTING MONTH

• Reporting Month/Year: JANUARY, 1998

• Type of Residual Disinfectant Maintained in Distribution System Served by Plant: free chlorine; combined chlorine (chloramine); chlorine dioxide

• Summary of Daily Water Treatment Data for Reporting Month:

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
1	14	518,000	1.9	1.0			
2	14	523,000	2.0	0.2			
3	16	550,000	1.8	0.3			
4	13	555,000	1.4	2.5			
5	16	625,000	1.5	0.6			
6	15	568,000	1.6	0.6			
7	15	542,000	1.6	0.2			
8	14	526,000	2.5	1.0			
9	13	484,000	3.0	0.7			
10	15	494,000	1.7	2.9			
11	14	498,000	1.9	0.3			
12	14	586,000	2.0	1.1			
13	15	523,000	2.0	1.0			
14	14	530,000	2.2	1.4			
15	15	511,000	1.8	1.0			
16	13	461,000	1.0	1.0	6	0.9	
17	13	459,000	1.0	1.0			
18	15	538,000	1.0	1.0			
19	16	584,000	2.0	1.1			
20	15	553,000	3.0	0.6			
21	15	574,000	1.0	1.0			
22	14	548,000	2.5	0.2			
23	13	517,000	2.0	1.0			
24	14	454,000	1.6	0.4			
25	13	522,000	1.9	0.6			
26	14	547,000	1.5	1.0			
27	14	478,000	1.8	0.2			
28	13	499,000	1.9	0.8			
29	13	502,000	1.8	0.3			

Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water

DEP Form No.: **62-555.910(3)**
 Form Title: **Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water**
 Effective Date: **December 19, 1994**
 DEP Application No.: _____ (Filled in by DEP)

System PWS Identification Number: **4430667**
 Treatment Plant Name: **Indiantown Water Company**
 Reporting Month/Year: **JANUARY, 1998**

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
30	16	530,000	1.4	1.0			
31	12	521,000	1.9	2.2			
Total	XXXXXX	16,320,000	XXXXXXXXXX	XXXXXXXXXX		XXXXXXXXXXXXXXXXXX	XXXXXX
Avg.	XXXXXX	526,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXX
Max.	XXXXXX	625,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXX

* If at any time the residual disinfectant concentration at the entry to the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

† If at any time the residual disinfectant concentration in the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose and/or flush appropriate portions of the distribution system until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

III. SUMMARY OF USE, AT WATER TREATMENT PLANT, OF POLYMER CONTAINING ACRYLAMIDE, POLYMER CONTAINING EPICHLOROHYDRIN, AND/OR IRON AND MANGANESE SEQUESTRANT (complete this part only for the reporting month of December each year)

• Is any polymer containing the monomer acrylamide used at the treatment plant? _____ If yes, the polymer dose and the acrylamide level in the polymer are as follows:

Polymer Dose = _____ ppm* Acrylamide Level = _____ %*

* The acrylamide level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for acrylamide exceeds 0.05% dosed at 1 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

• Is any polymer containing the monomer epichlorohydrin used at the treatment plant? _____ If yes, the polymer dose and the epichlorohydrin level in the polymer are as follows:

Polymer Dose = _____ ppm* Epichlorohydrin Level = _____ %*

* The epichlorohydrin level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for epichlorohydrin exceeds 0.01% dosed at 20 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

Monthly Operation Report for Public Water Systems that Use Ground Water
 and for Consecutive Public Water Systems that Treat Their Water
 Item PWS Identification Number: 4430667
 Treatment Plant Name: Indiantown Water Company
 Reporting Month/Year: JANUARY, 1997

DEP Form No.: 62-555.910(3)
 Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 19, 1994
 DEP Application No.: _____
 (Filed in by DEP)

• Is any iron and manganese sequestrant used at the treatment plant? _____ If yes, the type of sequestrant, sequestrant dose, etc., are as follows:

Type of Sequestrant (polyphosphate or sodium silicate): _____
Sequestrant Dose (mg/L of phosphate as PO_4 or mg/L of silicate as SiO_2): _____
If sodium silicate is used, the amount of added plus naturally occurring silicate - _____ mg/L as SiO_2 , ¹

¹ If polyphosphate is used, the total phosphate applied shall not exceed 10 mg/L as PO_4 , per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.; and if sodium silicate is used, the amount of silicate added shall be limited to 20 mg/L as SiO_2 , per "Recommended Standards for Water Works."

¹ The amount of added plus naturally occurring silicate shall not exceed 60 mg/L as SiO_2 , per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.

IV. STATEMENT BY LEAD/CHIEF WATER TREATMENT PLANT OPERATOR

I, the undersigned lead/chief operator of _____, certify that, to the best of my knowledge and belief, the information provided in this report is true and accurate.

Also, I certify that the following additional operations records applicable to this plant were prepared each day a certified operator staffed or visited the plant during the reporting month indicated on this report and that these records will be maintained available for review at the plant site for not less than five years:

- records of amounts of chemicals used and chemical feed rates;
- process performance records for coagulation/flocculation (e.g., source water temperature, pH, turbidity, color, and alkalinity and process effluent pH and alkalinity in addition to chemical feed rates);
- process performance records for sedimentation (e.g., process effluent turbidity and sludge volume produced);
- process performance records for filtration (e.g., process effluent turbidity and color, number of filters in service, filtration rates, unit filter run volumes, head losses, length of filter runs, frequency of backwash, amount of backwash water used, duration of backwash, and backwash rates);
- process performance records for lime-soda ash softening (e.g., source water and process effluent hardness in addition to records for coagulation/flocculation, sedimentation, and filtration);
- process performance records for ion exchange softening (e.g., feed and bypass flows, blend rate, and salt and brine used);
- process performance records for reverse osmosis (e.g., feed, product, and brine flows; feed pressure, temperature, pH, conductivity, and turbidity; product pH and conductivity; and brine pH and conductivity); and
- process performance records for electrodiagnosis (e.g., polarity, feed temperature and total dissolved solids, product conductivity and total dissolved solids, dilute flow rate, brine make-up, pressures, and volts/amps).

James Hevitt 2/13/95
 Signature and Date

James Hevitt BO 3821
 Name and Certificate Number (please type or print)

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: February, 1998

SD Form No. 12-200.1-720
 Form Title: Monthly Operating Report for Public Water Systems that Treat Their Water and Consecutive PWS that Treat Their Water
 Effective Date: 12-200.1-720
 SDP Application No.:
 Filed in by: CDE

- Refer to Chapter 62-699, F.A.C., for plant staffing requirements. Class A plants must be staffed by a certified operator 24 hours per day for seven days per week; Class B plants must be staffed by a certified operator seven days per week; Class C plants must be staffed/visited by a certified operator seven days per week or at least six days per week depending on the type and capacity of treatment at the plant; and Class D plants must be visited/checked by a certified operator and/or water system representative at least five days per week. The one day per week that a Class C plant may not be staffed/visited should, if possible, be a day when the plant is not in operation; and the two days per week that a Class D plant may not be visited/checked should, if possible, be days when the plant is not in operation and should be non-consecutive days if the plant is in operation six or seven days per week.

I. GENERAL WATER SYSTEM AND WATER TREATMENT PLANT INFORMATION

Water System Name and PWS Identification Number, System Owner, System Type, Service Connections to System, and Population Served by System

- System Name: Indiantown Water Company PWS Identification No.: 4430667
- System Owner Name: Indiantown Company, Inc. Telephone No.: 561-597-2121
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL Zip Code: 34956
- System Type: community; non-transient non-community; non-community; consecutive
- Number of Service Connections at End of Reporting Month: _____
- Total Population Served by System at End of Reporting Month: _____

Water Treatment Plant Name, Permitted Capacity of Plant, Plant Category and Class, and Plant Operators

- Treatment Plant Name: Indiantown Water Company Telephone No.: 561-597-2122
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL Zip Code: 34956
- Permitted Maximum Day Capacity of Plant: 1,296,000 gpd
- Plant Category and Class per Rule 62-699.310(3), F.A.C.: 4-C
- Lead/Chief Plant Operator:

Name	Certificate Number	Class (A, B, C, or D)	Days/Shift(s) Worked
James Hevitt	3821	B	5

Other Certified Plant Operators (attach additional sheets if necessary):

Name	Certificate Number	Class (A, B, C, or D)	Days/Shift(s) Worked
Dean Smiley	5715	B	2
Higino Rodriguez	8378	C	5
Earl Maine	4644	D	5

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: February, 1998

Form No. 62-111.2102B
 Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
 Effective Date: September 18, 1995
 DEP Application No.:
 (Print in by DEP)

II. SUMMARY OF DAILY WATER TREATMENT DATA FOR REPORTING MONTH

• Reporting Month/Year: February, 1998

• Type of Residual Disinfectant Maintained in Distribution System Served by Plant: free chlorine; combined chlorine (chloramine); chlorine dioxide

• Summary of Daily Water Treatment Data for Reporting Month:

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
1	17	605,000	2.1	0.7			
2	16	663,000	1.7	0.6			
3	17	519,000	2.0	1.0			
4	14	488,000	2.1	0.9			
5	12	503,000	2.0	1.3			
6	14	513,000	2.0	1.0			
7	12	448,000	1.5	0.6			
8	14	510,000	2.5	0.2			
9	18	610,000	1.6	0.7			
10	14	537,000	1.0	0.2			
11	15	574,000	1.5	1.0			
12	14	501,000	1.9	0.2			
13	15	567,000	2.0	0.3			
14	14	534,000	2.0	0.4			
15	16	570,000	2.0	0.6			
16	12	539,000	1.7	0.4			
17	16	572,000	1.5	0.6			
18	14	514,000	1.4	0.2			
19	14	543,000	1.2	0.3			
20	16	567,000	1.0	0.2			
21	14	503,000	1.1	0.2			
22	17	536,000	1.4	0.2			
23	16	598,000	1.5	0.6			
24	13	536,000	2.0	0.7			
25	14	514,000	1.5	0.6	6	0.7	
26	15	540,000	1.6	0.2			
27	14	561,000	1.9	0.7			
28	14	536,000	2.4	0.2			
29							

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667
 Treatment Plant Name: Indiantown Water Company
 Reporting Month/Year: FEBRUARY, 1998

DEP Form No.: 62-555.310(2)
 Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and/or Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 18, 1996
 DEP Application No.: _____
 Filed in by DEP: _____

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
30							
31							
Total	XXXXXXX	<u>15,201,000</u>	XXXXXXXXXX	XXXXXXXXXX		XXXXXXXXXXXXXXXXXX	XXXXXXX
Avg.	XXXXXXX	<u>543,000</u>	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXXX
Max.	XXXXXXX	<u>663,000</u>	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXXX

* If at any time the residual disinfectant concentration at the entry to the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

† If at any time the residual disinfectant concentration in the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose and/or flush appropriate portions of the distribution system until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

III. SUMMARY OF USE, AT WATER TREATMENT PLANT, OF POLYMER CONTAINING ACRYLAMIDE, POLYMER CONTAINING EPICHLOROHYDRIN, AND/OR IRON AND MANGANESE SEQUESTANT (complete this part only for the reporting month of December each year)

• Is any polymer containing the monomer acrylamide used at the treatment plant? _____ If yes, the polymer dose and the acrylamide level in the polymer are as follows:

Polymer Dose - _____ ppm* Acrylamide Level - _____ %*

The acrylamide level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for acrylamide exceeds 0.05% dosed at 1 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

• Is any polymer containing the monomer epichlorohydrin used at the treatment plant? _____ If yes, the polymer dose and the epichlorohydrin level in the polymer are as follows:

Polymer Dose - _____ ppm* Epichlorohydrin Level - _____ %*

The epichlorohydrin level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for epichlorohydrin exceeds 0.01% dosed at 20 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667
Treatment Plant Name: Indiantown Water Company
Reporting Month/Year: February, 1999

Form No.:	62-555.330(3)
Form Title:	Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
Effective Date:	December 18, 1994
DEP Application No.:	
	(Filed in by DEP)

• Is any iron and manganese sequestrant used at the treatment plant? _____ If yes, the type of sequestrant, sequestrant dose, etc., are as follows:

Type of Sequestrant (polyphosphate or sodium silicate): _____
Sequestrant Dose (mg/L of phosphate as PO ₄ or mg/L of silicate as SiO ₂): _____
If sodium silicate is used, the amount of added plus naturally occurring silicate = _____ mg/L as SiO ₂ .

If polyphosphate is used, the total phosphate applied shall not exceed 10 mg/L as PO₄ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.; and if sodium silicate is used, the amount of silicate added shall be limited to 20 mg/L as SiO₂ per "Recommended Standards for Water Works."

The amount of added plus naturally occurring silicate shall not exceed 60 mg/L as SiO₂ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.

IV. STATEMENT BY LEAD/CHIEF WATER TREATMENT PLANT OPERATOR

I, the undersigned lead/chief operator of _____, certify that, to the best of my knowledge and belief, the information provided in this report is true and accurate.

Also, I certify that the following additional operations records applicable to this plant were prepared each day a certified operator staffed or visited the plant during the reporting month indicated on this report and that these records will be maintained available for review at the plant site for not less than five years:

- records of amounts of chemicals used and chemical feed rates;
- process performance records for coagulation/flocculation (e.g., source water temperature, pH, turbidity, color, and alkalinity and process effluent pH and alkalinity in addition to chemical feed rates);
- process performance records for sedimentation (e.g., process effluent turbidity and sludge volume produced);
- process performance records for filtration (e.g., process effluent turbidity and color, number of filters in service, filtration rates, unit filter run volumes, head losses, length of filter runs, frequency of backwash, amount of backwash water used, duration of backwash, and backwash rates);
- process performance records for lime-soda ash softening (e.g., source water and process effluent hardness in addition to records for coagulation/flocculation, sedimentation, and filtration);
- process performance records for ion exchange softening (e.g., feed and bypass flows, blend rate, and salt and brine used);
- process performance records for reverse osmosis (e.g., feed, product, and brine flows; feed pressure, temperature, pH, conductivity, and turbidity; product pH and conductivity; and brine pH and conductivity); and
- process performance records for electrodialysis (e.g., polarity, feed temperature and total dissolved solids, product conductivity and total dissolved solids, dilute flow rate, brine make-up, pressures, and volts/amps).

James Hewitt 3/12/98
Signature and Date

James Hewitt BO 3821
Name and Certificate Number (please type or print)

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: MARCH, 1998

DEP Form No.: **82-078 (1-1998)**
 Form Title: **Monthly Operation Report for Public Water Systems For Use Second Year and by Consecutive Public Water Systems that Treat Their Water**
 Effective Date: **EX - 04-10-1998**
 DEP Application No.: _____
 Filed by: **DEP**

Refer to Chapter 62-699, F.A.C., for plant staffing requirements. Class A plants must be staffed by a certified operator 24 hours per day for seven days per week; Class B plants must be staffed by a certified operator seven days per week; Class C plants must be staffed/visited by a certified operator seven days per week or at least six days per week depending on the type and capacity of treatment at the plant; and Class D plants must be visited/checked by a certified operator and/or water system representative at least five days per week. The one day per week that a Class C plant may not be staffed/visited should, if possible, be a day when the plant is not in operation; and the two days per week that a Class D plant may not be visited/checked should, if possible, be days when the plant is not in operation and should be non-consecutive days if the plant is in operation six or seven days per week.

I. GENERAL WATER SYSTEM AND WATER TREATMENT PLANT INFORMATION

Water System Name and PWS Identification Number, System Owner, System Type, Service Connections to System, and Population Served by System

- **System**
 Name: Indiantown Water Company PWS Identification No.: 4430667
- **System Owner**
 Name: Indiantown Company, Inc. Telephone No.: 561-597-2121
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956
- System Type: community; non-transient non-community; non-community; consecutive
- Number of Service Connections at End of Reporting Month: 1719
- Total Population Served by System at End of Reporting Month: _____

Water Treatment Plant Name, Permitted Capacity of Plant, Plant Category and Class, and Plant Operators

- **Treatment Plant**
 Name: Indiantown Water Company Telephone No.: 561-597-2122
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956
- Permitted Maximum Day Capacity of Plant: 1,296,000 gpd
- Plant Category and Class per Rule 62-699.310(3), F.A.C.: 4-C
- Lead/Chief Plant Operator:

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
James Hewitt	3821	B	5

• Other Certified Plant Operators (attach additional sheets if necessary):

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
Dean Smiley	5715	B	2
Rigino Rodriguez	8378	C	5
Earl Maine	4644	D	5

and for Consecutive Public Water Systems that Treat Their Water
 System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: March, 1998

DEP Form No. 12-111.1 (1994)
 Form Title: Monthly Operation Report - Public Water Systems that Use Gravity Water and for Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 18, 1994
 DEP Application No. _____

II. SUMMARY OF DAILY WATER TREATMENT DATA FOR REPORTING MONTH

• Reporting Month/Year: MARCH, 1998

• Type of Residual Disinfectant Maintained in Distribution System Served by Plant: free chlorine; combined chlorine (chloramine); chlorine dioxide

• Summary of Daily Water Treatment Data for Reporting Month:

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
1	15	545,000	2.1	1.3			
2	14	578,000	2.0	0.8			
3	16	547,000	1.8	1.0			
4	13	557,000	1.4	0.8			
5	18	536,000	2.5	0.5			
6	16	571,000	2.5	0.3			
7	16	573,000	2.0	0.6			
8	15	577,000	2.0	0.3			
9	15	599,000	2.5	0.8			
10	15	523,000	1.9	0.8			
11	15	530,000	1.9	0.3			
12	13	510,000	2.0	0.3			
13	14	518,000	2.6	0.5			
14	14	532,000	2.5	0.4			
15	17	566,000	2.5	1.0			
16	17	645,000	2.7	0.8			
17	17	601,000	2.0	0.8			
18	14	542,000	2.5	0.7			
19	14	498,000	2.0	0.9			
20	13	498,000	1.5	0.8			
21	13	482,000	1.2	0.7			
22	14	526,000	1.6	0.6			
23	15	577,000	1.8	0.8			
24	14	564,000	3.0	0.7			
25	15	575,000	1.0	0.8	6	0.7	
26	16	583,000	1.0	0.8			
27	15	593,000	1.7	0.5			
28	18	606,000	2.8	0.4			
29	16	614,000	2.5	0.5			

and for Consecutive Public Water Systems that Treat Their Water
 Form PWS Identification Number: 4430667
 Treatment Plant Name: Indiantown Water Company
 Reporting Month/Year: MARCH, 1978

Form Title: Monthly Operation Report for P. S. Water Systems that Use Ground Water for Consecutive Public Water Systems
 Effective Date: March 18, 1978
 DEP Application No.: _____
 #Bac DEP

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L) ^a	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L) ^b	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L) ^c	
30	16	649,000	1.0	0.6			
31	15	553,000	2.0	0.6			
Total	XXXXXX	17,368,000	XXXXXXXXXX	XXXXXXXXXX		XXXXXXXXXXXXXXXXXX	XXXXXX
Avg.	XXXXXX	560,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXX
Max.	XXXXXX	649,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXX

^a If at any time the residual disinfectant concentration at the entry to the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

^b If at any time the residual disinfectant concentration in the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose and/or flush appropriate portions of the distribution system until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

III. SUMMARY OF USE, AT WATER TREATMENT PLANT, OF POLYMER CONTAINING ACRYLAMIDE, POLYMER CONTAINING EPICHLOROHYDRIN, AND/OR IRON AND MANGANESE SEQUESTRANT (complete this part only for the reporting month of December each year)

• Is any polymer containing the monomer acrylamide used at the treatment plant? _____ If yes, the polymer dose and the acrylamide level in the polymer are as follows:

Polymer Dose - _____ ppm*	Acrylamide Level - _____ %*
---------------------------	-----------------------------

The acrylamide level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for acrylamide exceeds 0.05% dosed at 1 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

• Is any polymer containing the monomer epichlorohydrin used at the treatment plant? _____ If yes, the polymer dose and the epichlorohydrin level in the polymer are as follows:

Polymer Dose - _____ ppm*	Epichlorohydrin Level - _____ %*
---------------------------	----------------------------------

The epichlorohydrin level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for epichlorohydrin exceeds 0.01% dosed at 20 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: MARCH

Form Title:	Monthly Operation Report for Public Water Systems that Use Ground Water and/or Consecutive Public Water Systems that Treat Their Water
Effective Date:	December 18, 1994
DEP Application No.:	
	(Filed in by DEP)

• Is any iron and manganese sequestrant used at the treatment plant? _____ If yes, the type of sequestrant, sequestrant dose, etc., are as follows:

Type of Sequestrant (polyphosphate or sodium silicate): _____
Sequestrant Dose (mg/L of phosphate as PO ₄ or mg/L of silicate as SiO ₂): _____
If sodium silicate is used, the amount of added plus naturally occurring silicate = _____ mg/L as SiO ₂ . ¹

¹ If polyphosphate is used, the total phosphate applied shall not exceed 10 mg/L as PO₄ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.; and if sodium silicate is used, the amount of silicate added shall be limited to 20 mg/L as SiO₂ per "Recommended Standards for Water Works."

¹ The amount of added plus naturally occurring silicate shall not exceed 60 mg/L as SiO₂ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.

IV. STATEMENT BY LEAD/CHIEF WATER TREATMENT PLANT OPERATOR

I, the undersigned lead/chief operator of Indiantown Water Co., certify that, to the best of my knowledge and belief, the information provided in this report is true and accurate.

Also, I certify that the following additional operations records applicable to this plant were prepared each day a certified operator staffed or visited the plant during the reporting month indicated on this report and that these records will be maintained available for review at the plant site for not less than five years:

- records of amounts of chemicals used and chemical feed rates;
- process performance records for coagulation/flocculation (e.g., source water temperature, pH, turbidity, color, and alkalinity and process effluent pH and alkalinity in addition to chemical feed rates);
- process performance records for sedimentation (e.g., process effluent turbidity and sludge volume produced);
- process performance records for filtration (e.g., process effluent turbidity and color, number of filters in service, filtration rates, unit filter run volumes, head losses, length of filter runs, frequency of backwash, amount of backwash water used, duration of backwash, and backwash rates);
- process performance records for lime-soda ash softening (e.g., source water and process effluent hardness in addition to records for coagulation/flocculation, sedimentation, and filtration);
- process performance records for ion exchange softening (e.g., feed and bypass flows, blend rate, and salt and brine used);
- process performance records for reverse osmosis (e.g., feed, product, and brine flows; feed pressure, temperature, pH, conductivity, and turbidity; product pH and conductivity; and brine pH and conductivity); and
- process performance records for electrodialysis (e.g., polarity, feed temperature and total dissolved solids, product conductivity and total dissolved solids, dilute flow rate, brine make-up, pressures, and volts/amps).

James Hewitt
Signature and Date

James Hewitt BO 3821
Name and Certificate Number (please type or print)

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: April 1998

DWP Form No.: 62-699.310(3)
 Form Title: Monthly Operator Report for Public Water Systems, Class A, B, C, or D, and for Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 18, 1997
 DWP Application No.: _____
 Printed by DWP.

Refer to Chapter 62-699, F.A.C., for plant staffing requirements. Class A plants must be staffed by a certified operator 24 hours per day for seven days per week; Class B plants must be staffed by a certified operator seven days per week; Class C plants must be staffed/visited by a certified operator seven days per week or at least six days per week depending on the type and capacity of treatment at the plant; and Class D plants must be visited/checked by a certified operator and/or water system representative at least five days per week. The one day per week that a Class C plant may not be staffed/visited should, if possible, be a day when the plant is not in operation; and the two days per week that a Class D plant may not be visited/checked should, if possible, be days when the plant is not in operation and should be non-consecutive days if the plant is in operation six or seven days per week.

I. GENERAL WATER SYSTEM AND WATER TREATMENT PLANT INFORMATION

Water System Name and PWS Identification Number, System Owner, System Type, Service Connections to System, and Population Served by System

• System
 Name: Indiantown Water Company PWS Identification No.: 4430667
 • System Owner
 Name: Indiantown Company, Inc. Telephone No.: 561-597-2121
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956

• System Type: community; non-transient non-community; non-community; consecutive

• Number of Service Connections at End of Reporting Month: _____

• Total Population Served by System at End of Reporting Month: _____

Water Treatment Plant Name, Permitted Capacity of Plant, Plant Category and Class, and Plant Operators

• Treatment Plant
 Name: Indiantown Water Company Telephone No.: 561-597-2122
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956

• Permitted Maximum Day Capacity of Plant: 1,296,000 gpd

• Plant Category and Class per Rule 62-699.310(3), F.A.C.: 4-C

• Lead/Chief Plant Operator:

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
James Revitt	3821	B	5

• Other Certified Plant Operators (attach additional sheets if necessary):

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
Dean Smiley	5715	B	2
Raymond Rodriguez	6698	C	3
Earl Maine	4644	D	5

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: April, 1998

DEP Form No. 82-111-0102
 Permit Title: Monthly Operating Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 19, 1994
 DEP Application No.: _____
 Filed in by DEP: _____

II. SUMMARY OF DAILY WATER TREATMENT DATA FOR REPORTING MONTH

• Reporting Month/Year: April, 1998

• Type of Residual Disinfectant Maintained in Distribution System Served by Plant: free chlorine; combined chlorine (chloramine); chlorine dioxide

• Summary of Daily Water Treatment Data for Reporting Month:

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
1	15	563,000	2.0	0.4			
2	16	565,000	2.0	0.6			
3	15	576,000	1.6	0.4			
4	17	640,000	1.8	0.4			
5	16	616,000	1.3	0.4			
6	16	654,000	1.0	0.6			
7	18	652,000	2.0	0.5			
8	17	652,000	1.0	0.4			
9	18	657,000	2.1	0.8			
10	16	602,000	2.0	0.5			
11	18	660,000	1.5	0.6			
12	16	636,000	1.5	0.6			
13	17	667,000	1.6	0.4			
14	18	668,000	1.0	0.4			
15	20	697,000	2.5	0.2			
16	19	680,000	2.5	0.6			
17	19	692,000	2.6	0.8			
18	18	687,000	2.4	0.8			
19	18	682,000	1.3	0.7			
20	22	725,000	2.0	0.6			
21	17	667,000	1.0	0.4			
22	15	563,000	1.0	0.6			
23	11	602,000	1.1	0.2			
24	16	614,000	2.0	0.4			
25	17	647,000	1.8	0.4			
26	17	663,000	1.3	0.6			
27	17	694,000	1.6	0.2			
28	22	686,000	2.5	0.4	6	0.7	
29	19	665,000	2.6	0.8			

86

PWS Identification Number: 4430667
 Treatment Plant Name: Indiantown Water Company
 Reporting Month/Year: April, 1998

Effective Date: _____
 DEP Application No.: _____
 Printed by DEP

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
30	16	565,000	2.5	0.6			
31							
Total	XXXXXX	19,337,000	XXXXXXXXXX	XXXXXXXXXX		XXXXXXXXXXXXXXXXXX	XXXXXX
Avg.	XXXXXX	644,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXX
Max.	XXXXXX	725,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXX

* If at any time the residual disinfectant concentration at the entry to the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

† If at any time the residual disinfectant concentration in the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose and/or flush appropriate portions of the distribution system until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

III. SUMMARY OF USE, AT WATER TREATMENT PLANT, OF POLYMER CONTAINING ACRYLAMIDE, POLYMER CONTAINING EPICHLOROHYDRIN, AND/OR IRON AND MANGANESE SEQUESTRANT (complete this part only for the reporting month of December each year)

• Is any polymer containing the monomer acrylamide used at the treatment plant? _____ If yes, the polymer dose and the acrylamide level in the polymer are as follows:

Polymer Dose = _____ ppm* Acrylamide Level = _____ %*

* The acrylamide level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for acrylamide exceeds 0.05% dosed at 1 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

• Is any polymer containing the monomer epichlorohydrin used at the treatment plant? _____ If yes, the polymer dose and the epichlorohydrin level in the polymer are as follows:

Polymer Dose = _____ ppm* Epichlorohydrin Level = _____ %*

* The epichlorohydrin level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for epichlorohydrin exceeds 0.01% dosed at 20 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

87

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667
Treatment Plant Name: Indiantown Water Company
Reporting Month/Year: April, 1998

Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and/or Consecutive Public Water Systems that Treat Their Water
Effective Date: December 19, 1994
DEP Application No.: _____
(Filed in by DEP)

● Is any iron and manganese sequestrant used at the treatment plant? _____ If yes, the type of sequestrant, sequestrant dose, etc., are as follows:

Type of Sequestrant (polyphosphate or sodium silicate): _____
Sequestrant Dose (mg/L of phosphate as PO₄ or mg/L of silicate as SiO₂): _____
If sodium silicate is used, the amount of added plus naturally occurring silicate = _____ mg/L as SiO₂.

* If polyphosphate is used, the total phosphate applied shall not exceed 10 mg/L as PO₄ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.; and if sodium silicate is used, the amount of silicate added shall be limited to 20 mg/L as SiO₂ per "Recommended Standards for Water Works."
* The amount of added plus naturally occurring silicate shall not exceed 60 mg/L as SiO₂ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.

IV. STATEMENT BY LEAD/CHIEF WATER TREATMENT PLANT OPERATOR

I, the undersigned lead/chief operator of Indiantown Water Co., certify that, to the best of my knowledge and belief, the information provided in this report is true and accurate.

Also, I certify that the following additional operations records applicable to this plant were prepared each day a certified operator staffed or visited the plant during the reporting month indicated on this report and that these records will be maintained available for review at the plant site for not less than five years:

- records of amounts of chemicals used and chemical feed rates;
- process performance records for coagulation/flocculation (e.g., source water temperature, pH, turbidity, color, and alkalinity and process effluent pH and alkalinity in addition to chemical feed rates);
- process performance records for sedimentation (e.g., process effluent turbidity and sludge volume produced);
- process performance records for filtration (e.g., process effluent turbidity and color, number of filters in service, filtration rates, unit filter run volumes, head losses, length of filter runs, frequency of backwash, amount of backwash water used, duration of backwash, and backwash rates);
- process performance records for lime-soda ash softening (e.g., source water and process effluent hardness in addition to records for coagulation/flocculation, sedimentation, and filtration);
- process performance records for ion exchange softening (e.g., feed and bypass flows, blend rate, and salt and brine used);
- process performance records for reverse osmosis (e.g., feed, product, and brine flows; feed pressure, temperature, pH, conductivity, and turbidity; product pH and conductivity; and brine pH and conductivity); and
- process performance records for electrodialysis (e.g., polarity, feed temperature and total dissolved solids, product conductivity and total dissolved solids, dilute flow rate, brine make-up, pressures, and volts/amp).

James Hewitt 5/14/98
Signature and Date

James Hewitt BO 3821
Name and Certificate Number (please type or print)

88

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: MAY 1998

OSP Form No.: 62-699.310(3)
 Form Title: Monthly Operation Report for Public Water Systems that Treat Their Water and for Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 10, 1997
 OSP Application No.: _____
 Filed in by OSP: _____

- Refer to Chapter 62-699, F.A.C., for plant staffing requirements. Class A plants must be staffed by a certified operator 24 hours per day for seven days per week; Class B plants must be staffed by a certified operator seven days per week; Class C plants must be staffed/visited by a certified operator seven days per week or at least six days per week depending on the type and capacity of treatment at the plant; and Class D plants must be visited/checked by a certified operator and/or water system representative at least five days per week. The one day per week that a Class C plant may not be staffed/visited should, if possible, be a day when the plant is not in operation; and the two days per week that a Class D plant may not be visited/checked should, if possible, be days when the plant is not in operation and should be non-consecutive days if the plant is in operation six or seven days per week.

I. GENERAL WATER SYSTEM AND WATER TREATMENT PLANT INFORMATION

Water System Name and PWS Identification Number, System Owner, System Type, Service Connections to System, and Population Served by System

- System Name: Indiantown Water Company PWS Identification No.: 4430667
- System Owner Name: Indiantown Company, Inc. Telephone No.: 561-597-2121
- Address: 15851 S.W. Farms Rd./P.O. Box 397
- City: Indiantown State: FL. Zip Code: 34956
- System Type: community; non-transient non-community; non-community; consecutive
- Number of Service Connections at End of Reporting Month: 1,668
- Total Population Served by System at End of Reporting Month: 5,838

Water Treatment Plant Name, Permitted Capacity of Plant, Plant Category and Class, and Plant Operators

- Treatment Plant Name: Indiantown Water Company Telephone No.: 561-597-2122
- Address: 15851 S.W. Farms Rd./P.O. Box 397
- City: Indiantown State: FL. Zip Code: 34956
- Permitted Maximum Day Capacity of Plant: 1,296,000 gpd
- Plant Category and Class per Rule 62-699.310(3), F.A.C.: 4-C
- Lead/Chief Plant Operator:

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
James Hewitt	3821	B	5

Other Certified Plant Operators (attach additional sheets if necessary):

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
Dean Smiley	5715	B	2
XXXXXXXXXX	XXXXXX	XXXX	XXXX
Earl Maine	4644	D	5

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: MAY, 1998

Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
 Effective Date: September 18, 1994
 DEP Application No.: _____
 (Filed in by DEP)

II. SUMMARY OF DAILY WATER TREATMENT DATA FOR REPORTING MONTH

Reporting Month/Year: MAY, 1998

Type of Residual Disinfectant Maintained in Distribution System Served by Plant: free chlorine; combined chlorine (chloramine); chlorine dioxide

Summary of Daily Water Treatment Data for Reporting Month:

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
1	13	503,000	1.5	0.4			
2	14	503,000	1.5	0.4			
3	16	631,000	1.6	0.2			
4	17	698,000	1.5	0.4			
5	18	530,000	2.6	0.5			
6	18	492,000	1.5	0.6			
7	15	554,000	2.5	1.2			
8	16	570,000	2.5	0.9			
9	18	625,000	2.4	1.1			
10	19	678,000	2.5	0.7			
11	10	702,000	2.5	1.0			
12	17	612,000	2.0	1.0			
13	20	672,000	2.0	1.2			
14	20	544,000	2.3	1.2			
15	18	634,000	3.0	1.1			
16	19	652,000	2.7	1.0			
17	20	695,000	1.1	1.0			
18	22	722,000	2.0	1.1			
19	21	693,000	3.3	0.8			
20	20	672,000	2.0	0.6			
21	21	678,000	1.1	0.6			
22	21	682,000	2.0	0.9			
23	21	670,000	2.5	1.0			
24	24	722,000	3.0	1.0			
25	24	757,000	3.5	0.8			
26	24	732,000	3.5	1.1	6	0.9	
27	23	634,000	2.6	1.0			
28	21	649,000	2.5	1.0			
29	15	561,000	1.5	0.8			

90

System PWS Identification Number: 4430667
 Treatment Plant Name: Indiantown Water Company
 Reporting Month/Year: MAY, 1998

...and for consecutive public water systems that treat their water
 Effective Date: December 18, 1994
 DEP Application No.: _____
 Filed in by DEP: _____

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L) ^a	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L) ^b	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L) ^c	
30	17	609,000	1.8	0.8			
31	17	629,000	2.0	0.4			
Total	XXXXXXX	19,763,000	XXXXXXXXXX	XXXXXXXXXX		XXXXXXXXXXXXXXXXXX	XXXXXXX
Avg.	XXXXXXX	637,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXXX
Max.	XXXXXXX	757,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXXX

^a If at any time the residual disinfectant concentration at the entry to the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

^b If at any time the residual disinfectant concentration in the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose and/or flush appropriate portions of the distribution system until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

III. SUMMARY OF USE, AT WATER TREATMENT PLANT, OF POLYMER CONTAINING ACRYLAMIDE, POLYMER CONTAINING EPICHLOROHYDRIN, AND/OR IRON AND MANGANESE SEQUESTANT (complete this part only for the reporting month of December each year)

• Is any polymer containing the monomer acrylamide used at the treatment plant? _____ If yes, the polymer dose and the acrylamide level in the polymer are as follows:

Polymer Dose = _____ ppm^a Acrylamide Level = _____ %^b

^a The acrylamide level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for acrylamide exceeds 0.05% dosed at 1 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

• Is any polymer containing the monomer epichlorohydrin used at the treatment plant? _____ If yes, the polymer dose and the epichlorohydrin level in the polymer are as follows:

Polymer Dose = _____ ppm^a Epichlorohydrin Level = _____ %^b

^a The epichlorohydrin level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for epichlorohydrin exceeds 0.01% dosed at 20 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

and for consecutive public water systems that treat their water
 System PWS Identification Number: 4430667
 Treatment Plant Name: Indiantown Water Company
 Reporting Month/Year: MAY, 1998

Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and/or Conventional Public Water Systems that Treat Their Water
 Effective Date: December 18, 1994
 DEP Application No.: _____
 Filed in by DEP: _____

Is any iron and manganese sequestrant used at the treatment plant? _____ If yes, the type of sequestrant, sequestrant dose, etc., are as follows:

Type of Sequestrant (polyphosphate or sodium silicate): _____
 Sequestrant Dose (mg/L of phosphate as PO₄ or mg/L of silicate as SiO₂): _____
 If sodium silicate is used, the amount of added plus naturally occurring silicate = _____ mg/L as SiO₂.

* If polyphosphate is used, the total phosphate applied shall not exceed 10 mg/L as PO₄ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.; and if sodium silicate is used, the amount of silicate added shall be limited to 20 mg/L as SiO₂ per "Recommended Standards for Water Works."
 * The amount of added plus naturally occurring silicate shall not exceed 60 mg/L as SiO₂ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.

IV. STATEMENT BY LEAD/CHIEF WATER TREATMENT PLANT OPERATOR

I, the undersigned lead/chief operator of Indiantown Water, certify that, to the best of my knowledge and belief, the information provided in this report is true and accurate.

Also, I certify that the following additional operations records applicable to this plant were prepared each day a certified operator staffed or visited the plant during the reporting month indicated on this report and that these records will be maintained available for review at the plant site for not less than five years:

- records of amounts of chemicals used and chemical feed rates;
- process performance records for coagulation/flocculation (e.g., source water temperature, pH, turbidity, color, and alkalinity and process effluent pH and alkalinity in addition to chemical feed rates);
- process performance records for sedimentation (e.g., process effluent turbidity and sludge volume produced);
- process performance records for filtration (e.g., process effluent turbidity and color, number of filters in service, filtration rates, unit filter run volumes, head losses, length of filter runs, frequency of backwash, amount of backwash water used, duration of backwash, and backwash rates);
- process performance records for lime-soda ash softening (e.g., source water and process effluent hardness in addition to records for coagulation/flocculation, sedimentation, and filtration);
- process performance records for ion exchange softening (e.g., feed and bypass flows, blend rate, and salt and brine used);
- process performance records for reverse osmosis (e.g., feed, product, and brine flows; feed pressure, temperature, pH, conductivity, and turbidity; product pH and conductivity; and brine pH and conductivity); and
- process performance records for electrodialysis (e.g., polarity, feed temperature and total dissolved solids, product conductivity and total dissolved solids, dilute flow rate, brine make-up, pressures, and volts/amps).

James Hewitt 6/16/98
 Signature and Date

James Hewitt BO 3821
 Name and Certificate Number (please type or print)

and for Consecutive Public Water Systems that Treat Their Water
 System PWS Identification Number: 4430667
 Treatment Plant Name: Indiantown Water Company
 Reporting Month/Year: JUNE 1998

DEP Form No. 82-001.0102
 Form Title: Monthly Operating Report for Public Water Systems that Use Ground Water and/or Consecutive Public Water Systems and that Treat Their Water
 Effective Date: December 18, 1995
 DEP Application No.: _____ (Filed in by DEP)

- Refer to Chapter 62-699, F.A.C., for plant staffing requirements. Class A plants must be staffed by a certified operator 24 hours per day for seven days per week; Class B plants must be staffed by a certified operator seven days per week; Class C plants must be staffed/visited by a certified operator seven days per week or at least six days per week depending on the type and capacity of treatment at the plant; and Class D plants must be visited/checked by a certified operator and/or water system representative at least five days per week. The one day per week that a Class C plant may not be staffed/visited should, if possible, be a day when the plant is not in operation; and the two days per week that a Class D plant may not be visited/checked should, if possible, be days when the plant is not in operation and should be non-consecutive days if the plant is in operation six or seven days per week.

COPY

I. GENERAL WATER SYSTEM AND WATER TREATMENT PLANT INFORMATION

Water System Name and PWS Identification Number, System Owner, System Type, Service Connections to System, and Population Served by System

• System
 Name: Indiantown Water Company PWS Identification No.: 4430667
 • System Owner
 Name: Indiantown Company, Inc. Telephone No.: 561-597-2121
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956

• System Type: community; non-transient non-community; non-community; consecutive
 • Number of Service Connections at End of Reporting Month: 1563
 • Total Population Served by System at End of Reporting Month: 5,470

Water Treatment Plant Name, Permitted Capacity of Plant, Plant Category and Class, and Plant Operators

• Treatment Plant
 Name: Indiantown Water Company Telephone No.: 561-597-2122
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956
 • Permitted Maximum Day Capacity of Plant: 1,296,000 gpd
 • Plant Category and Class per Rule 62-699.310(3), F.A.C.: 4-C
 • Lead/Chief Plant Operator:

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
James Hevitt	3821	B	5

• Other Certified Plant Operators (attach additional sheets if necessary):

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
Dean Smiley	5715	B	2
_____	_____	_____	_____
Earl Maine	4644	D	5

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: JUNE, 1998

Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 10, 1994
 DEP Application No.: _____
 Filed In by DEP: _____

II. SUMMARY OF DAILY WATER TREATMENT DATA FOR REPORTING MONTH

● Reporting Month/Year: JUNE, 1998

● Type of Residual Disinfectant Maintained in Distribution System Served by Plant: free chlorine; combined chlorine (chloramine); chlorine dioxide

● Summary of Daily Water Treatment Data for Reporting Month:

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
1	17	624,000	2.0	1.1			
2	17	605,000	1.5	0.8			
3	20	650,000	1.8	0.8			
4	21	652,000	2.0	0.6			
5	24	710,000	3.0	0.4			
6	21	705,000	1.7	0.4			
7	20	747,000	0.6	0.4			
8	23	710,000	2.5	0.5			
9	16	634,000	1.2	0.3			
10	21	643,000	1.5	0.4			
11	18	642,000	1.3	0.3			
12	21	670,000	2.5	0.6			
13	20	686,000	2.0	0.8			
14	18	693,000	2.0	0.4			
15	24	750,000	2.5	0.6			
16	16	740,000	2.5	0.5			
17	15	725,000	2.0	0.5			
18	18	704,000	1.1	0.6			
19	24	711,000	2.0	0.4			
20	24	705,000	3.3	0.2			
21	13	603,000	2.4	0.7			
22	8	635,000	1.0	0.4			
23	19	579,000	1.5	0.6			
24	18	630,000	1.5	0.2			
25	16	562,000	1.0	1.0			
26	16	598,000	1.4	0.2			
27	17	625,000	1.5	0.8			
28	30	658,000	0.7	0.5			
29	17	540,000	3.5	1.4			

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667
 Treatment Plant Name: Indiantown Water Company
 Reporting Month/Year: JUNE, 1998

Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and/or Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 19, 1994
 DEP Application No.: _____
 Filed in by DEP: _____

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L) ^a	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L) ^b	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L) ^c	
30	19	624,000	2.5	0.4	6	1.1	
31							
Total	XXXXXXX	19,815,000	XXXXXXXXXX	XXXXXXXXXX		XXXXXXXXXXXXXXXXXX	XXXXXXXX
Avg.	XXXXXXX	660,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXXXX
Max.	XXXXXXX	750,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXXXX

^a If at any time the residual disinfectant concentration at the entry to the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

^b If at any time the residual disinfectant concentration in the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose and/or flush appropriate portions of the distribution system until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

III. SUMMARY OF USE, AT WATER TREATMENT PLANT, OF POLYMER CONTAINING ACRYLAMIDE, POLYMER CONTAINING EPICHLOROHYDRIN, AND/OR IRON AND MANGANESE SEQUESTANT (complete this part only for the reporting month of December each year)

• Is any polymer containing the monomer acrylamide used at the treatment plant? _____ If yes, the polymer dose and the acrylamide level in the polymer are as follows:

Polymer Dose - _____ ppm* Acrylamide Level - _____ %*

^a The acrylamide level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for acrylamide exceeds 0.05% dosed at 1 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

• Is any polymer containing the monomer epichlorohydrin used at the treatment plant? _____ If yes, the polymer dose and the epichlorohydrin level in the polymer are as follows:

Polymer Dose - _____ ppm* Epichlorohydrin Level - _____ %*

^a The epichlorohydrin level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for epichlorohydrin exceeds 0.01% dosed at 20 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

95

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667
Treatment Plant Name: Indiantown Water Company
Reporting Month/Year: JUNE, 1998

Form Title:	Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
Effective Date:	December 18, 1994
DEP Application No.:	
	Filed in by DEP

• Is any iron and manganese sequestrant used at the treatment plant? _____ If yes, the type of sequestrant, sequestrant dose, etc., are as follows:

Type of Sequestrant (polyphosphate or sodium silicate): _____
Sequestrant Dose (mg/L of phosphate as PO ₄ or mg/L of silicate as SiO ₂): _____
If sodium silicate is used, the amount of added plus naturally occurring silicate = _____ mg/L as SiO ₂ .

* If polyphosphate is used, the total phosphate applied shall not exceed 10 mg/L as PO₄ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.; and if sodium silicate is used, the amount of silicate added shall be limited to 20 mg/L as SiO₂ per "Recommended Standards for Water Works."

* The amount of added plus naturally occurring silicate shall not exceed 60 mg/L as SiO₂ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.

IV. STATEMENT BY LEAD/CHIEF WATER TREATMENT PLANT OPERATOR

I, the undersigned lead/chief operator of _____, certify that, to the best of my knowledge and belief, the information provided in this report is true and accurate.

Also, I certify that the following additional operations records applicable to this plant were prepared each day a certified operator staffed or visited the plant during the reporting month indicated on this report and that these records will be maintained available for review at the plant site for not less than five years:

- records of amounts of chemicals used and chemical feed rates;
- process performance records for coagulation/flocculation (e.g., source water temperature, pH, turbidity, color, and alkalinity and process effluent pH and alkalinity in addition to chemical feed rates);
- process performance records for sedimentation (e.g., process effluent turbidity and sludge volume produced);
- process performance records for filtration (e.g., process effluent turbidity and color, number of filters in service, filtration rates, unit filter run volumes, head losses, length of filter runs, frequency of backwash, amount of backwash water used, duration of backwash, and backwash rates);
- process performance records for lime-soda ash softening (e.g., source water and process effluent hardness in addition to records for coagulation/flocculation, sedimentation, and filtration);
- process performance records for ion exchange softening (e.g., feed and bypass flows, blend rate, and salt and brine used);
- process performance records for reverse osmosis (e.g., feed, product, and brine flows; feed pressure, temperature, pH, conductivity, and turbidity; product pH and conductivity; and brine pH and conductivity); and
- process performance records for electrodialysis (e.g., polarity, feed temperature and total dissolved solids, product conductivity and total dissolved solids, dilute flow rate, brine make-up, pressures, and volts/amp).

James Hevitt 7/10/98
Signature and Date

James Hevitt BO 3821
Name and Certificate Number (please type or print)

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: July 1998

DEP Form No. 62-699.310(3)
 Form Title: Monthly Certified Operator Report for Public Water Systems that Treat Their Water and for Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 18, 1997
 DEP Application No.: _____
 Filed in by DEP: _____

- Refer to Chapter 62-699, F.A.C., for plant staffing requirements. Class A plants must be staffed by a certified operator 24 hours per day for some days per week; Class B plants must be staffed by a certified operator seven days per week; Class C plants must be staffed/visited by a certified operator seven days per week or at least six days per week depending on the type and capacity of treatment at the plant; and Class D plants must be visited/checked by a certified operator and/or water system representative at least five days per week. The one day per week that a Class C plant may not be staffed/visited should, if possible, be a day when the plant is not in operation; and the two days per week that a Class D plant may not be visited/checked should, if possible, be days when the plant is not in operation and should be non-consecutive days if the plant is in operation six or seven days per week.

I. GENERAL WATER SYSTEM AND WATER TREATMENT PLANT INFORMATION

Water System Name and PWS Identification Number, System Owner, System Type, Service Connections to System, and Population Served by System

● System
 Name: Indiantown Water Company PWS Identification No.: 4430667

● System Owner
 Name: Indiantown Company, Inc. Telephone No.: 561-597-2121
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956

● System Type: community; non-transient non-community; non-community; consecutive

● Number of Service Connections at End of Reporting Month: 1717

● Total Population Served by System at End of Reporting Month: 5,151

Water Treatment Plant Name, Permitted Capacity of Plant, Plant Category and Class, and Plant Operators

● Treatment Plant
 Name: Indiantown Water Company Telephone No.: 561-597-2122
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956

● Permitted Maximum Day Capacity of Plant: 1,296,000 gpd

● Plant Category and Class per Rule 62-699.310(3), F.A.C.: 4-C

● Lead/Chief Plant Operator:

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
James Revitt	3821	B	5

● Other Certified Plant Operators (attach additional sheets if necessary):

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
Dean Smiley	5715	B	2
William [unclear]	0000	B	5
Earl Maine	4644	D	5
Don Johnson	2816	B	5

and for Consecutive Public Water Systems that Treat Their Water

System FWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: July, 1998

USE Form No. 3212-100-01
 Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and/or Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 18, 1994
 DEP Application No.: _____
 (Printed by DEP)

II. SUMMARY OF DAILY WATER TREATMENT DATA FOR REPORTING MONTH

• Reporting Month/Year: July, 1998

• Type of Residual Disinfectant Maintained in Distribution System Served by Plant: free chlorine; combined chlorine (chloramine); chlorine dioxide

• Summary of Daily Water Treatment Data for Reporting Month:

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
1	20	696,000	2.3	1.0			
2	30	634,000	2.3	0.4			
3	10	647,000	2.0	1.0			
4	23	696,000	2.5	0.4			
5	24	738,000	2.5	0.9			
6	20	721,000	2.1	0.2			
7	21	652,000	2.0	0.5			
8	16	597,000	2.0	0.4			
9	20	628,000	2.2	0.6			
10	19	633,000	2.0	0.2			
11	18	516,000	2.3	0.4			
12	15	490,000	2.0	0.3			
13	17	576,000	2.0	0.5			
14	16	521,000	2.4	0.2			
15	15	517,000	2.0	0.6			
16	15	524,000	1.5	0.3			
17	17	555,000	3.0	0.7			
18	15	633,000	2.1	0.4			
19	20	721,000	1.4	0.6			
20	24	701,000	2.5	0.3			
21	17	546,000	2.0	0.6			
22	15	565,000	3.5	0.6			
23	19	534,000	3.0	0.7			
24	17	550,000	2.0	0.7	6	0.4	
25	19	572,000	3.0	0.8			
26	18	619,000	3.5	0.2			
27	18	606,000	1.5	1.0			
28	18	616,000	1.5	0.6			
29	20	634,000	2.0	0.8			

98

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667
 Treatment Plant Name: Indiantown Water Company
 Reporting Month/Year: July, 1998

DEP Form No. 62-555-9102
 Form Title Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
 Effective Date December 19, 1994
 DEP Application No. _____
 (Filled in by DEP)

• Is any iron and manganese sequestrant used at the treatment plant? _____ If yes, the type of sequestrant, sequestrant dose, etc., are as follows:

Type of Sequestrant (polyphosphate or sodium silicate): _____
 Sequestrant Dose (mg/L of phosphate as PO₄ or mg/L of silicate as SiO₂): _____
 If sodium silicate is used, the amount of added plus naturally occurring silicate = _____ mg/L as SiO₂*

* If polyphosphate is used, the total phosphate applied shall not exceed 10 mg/L as PO₄ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.; and if sodium silicate is used, the amount of silicate added shall be limited to 20 mg/L as SiO₂ per "Recommended Standards for Water Works."
 * The amount of added plus naturally occurring silicate shall not exceed 60 mg/L as SiO₂ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.

IV. STATEMENT BY LEAD/CHIEF WATER TREATMENT PLANT OPERATOR

I, the undersigned lead/chief operator of Indiantown Water Co., certify that, to the best of my knowledge and belief, the information provided in this report is true and accurate.

Also, I certify that the following additional operations records applicable to this plant were prepared each day a certified operator staffed or visited the plant during the reporting month indicated on this report and that these records will be maintained available for review at the plant site for not less than five years:

- records of amounts of chemicals used and chemical feed rates;
- process performance records for coagulation/flocculation (e.g., source water temperature, pH, turbidity, color, and alkalinity and process effluent pH and alkalinity in addition to chemical feed rates);
- process performance records for sedimentation (e.g., process effluent turbidity and sludge volume produced);
- process performance records for filtration (e.g., process effluent turbidity and color, number of filters in service, filtration rates, unit filter run volumes, head losses, length of filter runs, frequency of backwash, amount of backwash water used, duration of backwash, and backwash rates);
- process performance records for lime-soda ash softening (e.g., source water and process effluent hardness in addition to records for coagulation/flocculation, sedimentation, and filtration);
- process performance records for ion exchange softening (e.g., feed and bypass flows, blend rate, and salt and brine used);
- process performance records for reverse osmosis (e.g., feed, product, and brine flows; feed pressure, temperature, pH, conductivity, and turbidity; product pH and conductivity; and brine pH and conductivity); and
- process performance records for electrodialysis (e.g., polarity, feed temperature and total dissolved solids, product conductivity and total dissolved solids, dilute flow rate, brine make-up, pressures, and volts/amp).

James Hewitt 8/7/98
 Signature and Date

James Hewitt BO 3821
 Name and Certificate Number (please type or print)

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: AUGUST 1995

DEP Form No.: 62-699.3 (1995)
 Form Title: Monthly Certificate Report for Public Water Systems that Use Ground Water and/or Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 15, 1994
 DEP Application No.: _____
 Filed in by DEP: _____

- Refer to Chapter 62-699, F.A.C., for plant staffing requirements. Class A plants must be staffed by a certified operator 24 hours per day for some days per week; Class B plants must be staffed by a certified operator seven days per week; Class C plants must be staffed/visited by a certified operator seven days per week or at least six days per week depending on the type and capacity of treatment at the plant; and Class D plants must be visited/checked by a certified operator and/or water system representative at least five days per week. The one day per week that a Class C plant may not be staffed/visited should, if possible, be a day when the plant is not in operation; and the two days per week that a Class D plant may not be visited/checked should, if possible, be days when the plant is not in operation and should be non-consecutive days if the plant is in operation six or seven days per week.

I. GENERAL WATER SYSTEM AND WATER TREATMENT PLANT INFORMATION

Water System Name and PWS Identification Number, System Owner, System Type, Service Connections to System, and Population Served by System:

• System Name: Indiantown Water Company PWS Identification No.: 4430667
 • System Owner Name: Indiantown Company, Inc. Telephone No.: 561-597-2121
Address: 15851 S.W. Farms Rd./P.O. Box 397
City: Indiantown State: FL. Zip Code: 34956

• System Type: community; non-transient non-community; non-community; consecutive

• Number of Service Connections at End of Reporting Month: 1,696

• Total Population Served by System at End of Reporting Month: 5,088

Water Treatment Plant Name, Permitted Capacity of Plant, Plant Category and Class, and Plant Operators

• Treatment Plant Name: Indiantown Water Company Telephone No.: 561-597-2122
Address: 15851 S.W. Farms Rd./P.O. Box 397
City: Indiantown State: FL. Zip Code: 34956

• Permitted Maximum Day Capacity of Plant: 1,296,000 gpd

• Plant Category and Class per Rule 62-699.310(3), F.A.C.: 4-C

• Lead/Chief Plant Operator:

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
James Hewitt	3821	B	5

• Other Certified Plant Operators (attach additional sheets if necessary):

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
Dean Smiley	5715	B	2
Chapman	3821	B	5
Earl Maine	4644	D	5
Don Johnson	2816	B	5

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: Aug / 1998

USE Form No. 82-553.2100
 Form Title: Monthly Operator Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 18, 1994
 DEP Application No.: _____
 Filed in by DEP: _____

II. SUMMARY OF DAILY WATER TREATMENT DATA FOR REPORTING MONTH

• Reporting Month/Year: Aug. 1998

• Type of Residual Disinfectant Maintained in Distribution System Served by Plant: free chlorine; combined chlorine (chloramine); chlorine dioxide

• Summary of Daily Water Treatment Data for Reporting Month:

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
1	22	544,000	2.5	0.8			
2	18	570,000	2.0	0.6			
3	17	630,000	1.0	0.3			
4	15	515,000	1.5	0.2			
5	13	515,000	1.0	0.2			
6	16	601,000	1.0	0.3			
7	11	448,000	1.0	0.2			
8	13	437,000	1.0	0.3			
9	14	470,000	1.4	0.4			
10	14	557,000	1.5	0.5			
11	14	458,000	1.5	0.4			
12	13	506,000	1.4	0.2			
13	14	527,000	1.4	0.2			
14	17	585,000	1.7	0.2			
15	16	588,000	2.0	0.2			
16	14	598,000	1.5	0.3			
17	19	678,000	1.9	0.2			
18	18	629,000	1.9	0.2			
19	15	592,000	2.0	0.4			
20	17	621,000	1.8	0.4			
21	12	451,000	1.5	0.2			
22	13	404,000	1.1	0.6			
23	14	472,000	2.5	0.2			
24	13	539,000	1.6	0.4			
25	15	576,000	0.5	0.2			
26	16	566,000	1.5	0.2	6	0.8	
27	15	564,000	1.9	0.3			
28	16	565,000	3.5	0.4			
29	15	545,000	2.5	0.4			

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667
 Treatment Plant Name: Indiantown Water Company
 Reporting Month/Year: Aug, 1998

DEP Form No.: 62-881.910(3)
 Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 13, 1994
 DEP Application No.: _____
 (Filed in by DEP)

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
30	17	615,000	2.8	0.8			
31	17	656,000	2.0	0.4			
Total	XXXXXXX	17,022,000	XXXXXXXXXX	XXXXXXXXXX		XXXXXXXXXXXXXXXXXX	XXXXXXX
Avg.	XXXXXXX	549,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXX
Max.	XXXXXXX	678,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXX

* If at any time the residual disinfectant concentration at the entry to the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

† If at any time the residual disinfectant concentration in the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose and/or flush appropriate portions of the distribution system until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

III. SUMMARY OF USE, AT WATER TREATMENT PLANT, OF POLYMER CONTAINING ACRYLAMIDE, POLYMER CONTAINING EPICHLOROHYDRIN, AND/OR IRON AND MANGANESE SEQUESTANT (complete this part only for the reporting month of December each year)

• Is any polymer containing the monomer acrylamide used at the treatment plant? _____ If yes, the polymer dose and the acrylamide level in the polymer are as follows:

Polymer Dose - _____ ppm*	Acrylamide Level - _____ %*
---------------------------	-----------------------------

* The acrylamide level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for acrylamide exceeds 0.05% dosed at 1 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

• Is any polymer containing the monomer epichlorohydrin used at the treatment plant? _____ If yes, the polymer dose and the epichlorohydrin level in the polymer are as follows:

Polymer Dose - _____ ppm*	Epichlorohydrin Level - _____ %*
---------------------------	----------------------------------

* The epichlorohydrin level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for epichlorohydrin exceeds 0.01% dosed at 20 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667
 Treatment Plant Name: Indiantown Water Company
 Reporting Month/Year: Aug. 1993

USE Form No. 62-555.310(3)
 Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 19, 1994
 DEP Application No.: _____
 (Filed in by DEP)

• Is any iron and manganese sequestrant used at the treatment plant? _____ If yes, the type of sequestrant, sequestrant dose, etc., are as follows:

Type of Sequestrant (polyphosphate or sodium silicate): _____
 Sequestrant Dose (mg/L of phosphate as PO₄ or mg/L of silicate as SiO₂): _____
 If sodium silicate is used, the amount of added plus naturally occurring silicate = _____ mg/L as SiO₂*

* If polyphosphate is used, the total phosphate applied shall not exceed 10 mg/L as PO₄ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.; and if sodium silicate is used, the amount of silicate added shall be limited to 20 mg/L as SiO₂ per "Recommended Standards for Water Works."
 * The amount of added plus naturally occurring silicate shall not exceed 60 mg/L as SiO₂ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.

IV. STATEMENT BY LEAD/CHIEF WATER TREATMENT PLANT OPERATOR

I, the undersigned lead/chief operator of Indiantown Water Co., certify that, to the best of my knowledge and belief, the information provided in this report is true and accurate.

Also, I certify that the following additional operations records applicable to this plant were prepared each day a certified operator staffed or visited the plant during the reporting month indicated on this report and that these records will be maintained available for review at the plant site for not less than five years:

- records of amounts of chemicals used and chemical feed rates;
- process performance records for coagulation/flocculation (e.g., source water temperature, pH, turbidity, color, and alkalinity and process effluent pH and alkalinity in addition to chemical feed rates);
- process performance records for sedimentation (e.g., process effluent turbidity and sludge volume produced);
- process performance records for filtration (e.g., process effluent turbidity and color, number of filters in service, filtration rates, unit filter run volumes, head losses, length of filter runs, frequency of backwash, amount of backwash water used, duration of backwash, and backwash rates);
- process performance records for lime-soda ash softening (e.g., source water and process effluent hardness in addition to records for coagulation/flocculation, sedimentation, and filtration);
- process performance records for ion exchange softening (e.g., feed and bypass flows, blend rate, and salt and brine used);
- process performance records for reverse osmosis (e.g., feed, product, and brine flows; feed pressure, temperature, pH, conductivity, and turbidity; product pH and conductivity; and brine pH and conductivity); and
- process performance records for electrodialysis (e.g., polarity, feed temperature and total dissolved solids, product conductivity and total dissolved solids, dilute flow rate, brine make-up, pressures, and volts/amp).

James Hewitt 8/9/93
 Signature and Date

James Hewitt BO 3821
 Name and Certificate Number (please type or print)

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: September 1995

DEP Form No. 62-902.0001
 Form Title: Monthly Operating Report for Public Water Systems and Non-Community Public Water Systems
 Effective Date: September 21, 1994
 DEP Application No.: _____
 Filed in by DEP: _____

Refer to Chapter 62-699, F.A.C., for plant staffing requirements. Class A plants must be staffed by a certified operator 24 hours per day for seven days per week; Class B plants must be staffed by a certified operator seven days per week; Class C plants must be staffed/visited by a certified operator seven days per week or at least six days per week depending on the type and capacity of treatment at the plant; and Class D plants must be visited/checked by a certified operator and/or water system representative at least five days per week. The one day per week that a Class C plant may not be staffed/visited should, if possible, be a day when the plant is not in operation; and the two days per week that a Class D plant may not be visited/checked should, if possible, be days when the plant is not in operation and should be non-consecutive days if the plant is in operation six or seven days per week.

I. GENERAL WATER SYSTEM AND WATER TREATMENT PLANT INFORMATION

Water System Name and PWS Identification Number, System Owner, System Type, Service Connections to System, and Population Served by System

System Name: Indiantown Water Company PWS Identification No.: 4430667

System Owner Name: Indiantown Company, Inc. Telephone No.: 561-597-2121
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956

System Type: community; non-transient non-community; non-community; consecutive

Number of Service Connections at End of Reporting Month: 1,697

Total Population Served by System at End of Reporting Month: 5,091

Water Treatment Plant Name, Permitted Capacity of Plant, Plant Category and Class, and Plant Operators

Treatment Plant Name: Indiantown Water Company Telephone No.: 561-597-2122
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956

Permitted Maximum Day Capacity of Plant: 1,296,000 gpd

Plant Category and Class per Rule 62-699.310(3), F.A.C.: 4-C

Lead/Chief Plant Operator:

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
James Revitt	3821	B	5

Other Certified Plant Operators (attach additional sheets if necessary):

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
Dean Smiley	5715	B	2
Richard Anderson	4478	B	5
Earl Maine	4644	D	5
Don Johnson	2816	B	5

and for Consecutive Public Water Systems that Treat Their Water
 System PWS Identification Number: 4430667
 Treatment Plant Name: Indiantown Water Company
 Reporting Month/Year: Sept, 1998

U.S. EPA Form No. 853-101-01
 Form Title: Monthly Reporting System for Public Water
 Systems that Use Ground Water and/or
 Conventional Public Water Systems for
 Total Trihalomethanes
 Effective Date: December 18, 1993
 DEP Application No.: _____
 Filed in by DEP: _____

II. SUMMARY OF DAILY WATER TREATMENT DATA FOR REPORTING MONTH

- Reporting Month/Year: September 1998
- Type of Residual Disinfectant Maintained in Distribution System Served by Plant: free chlorine; combined chlorine (chloramine); chlorine dioxide
- Summary of Daily Water Treatment Data for Reporting Month:

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
1	16	577,000	3.3	0.4			
2	14	506,000	2.5	0.4			
3	15	530,000	2.0	0.8			
4	16	583,000	2.5	0.6			
5	15	545,000	3.0	0.9			
6	14	491,000	2.5	0.5			
7	15	569,000	2.0	1.0			
8	15	550,000	2.5	0.2			
9	13	442,000	2.0	1.0			
10	14	438,000	2.0	0.6			
11	15	434,000	2.1	1.0			
12	11	398,000	2.3	0.4			
13	16	516,000	3.5	1.0			
14	15	602,000	1.5	0.3			
15	18	527,000	2.0	0.6			
16	16	477,000	3.5	0.6			
17	15	436,000	3.5	0.7			
18	14	433,000	3.5	0.6			
19	16	454,000	3.5	0.4			
20	16	507,000	3.5	0.2			
21	16	500,000	3.5	1.0			
22	16	515,000	3.0	1.6	6	0.4	
23	16	520,000	2.5	1.1			
24	15	438,000	3.5	1.7			
25	16	485,000	2.5	0.9			
26	15	457,000	2.5	0.4			
27	15	577,000	2.5	1.0			
28	16	630,000	2.5	0.6			
29	17	614,000	2.8	0.5			

FOR CONSECUTIVE PUBLIC WATER SYSTEMS THAT TEST THEIR WATER
 PWS Identification Number: 4430667
 Treatment Plant Name: Indiantown Water Company
 Reporting Month/Year: September 1998

Approved Date: _____
 DEP Application No.: _____
 Printed in by DEP

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L) ^a	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L) ^a	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L) ^a	
30	17	617,000	3.5	1.0			
31							
Total	XXXXXXX	15,995,000	XXXXXXXXXX	XXXXXXXXXX		XXXXXXXXXXXXXXXXXX	XXXXXXX
Avg.	XXXXXXX	533,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXX
Max.	XXXXXXX	630,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXX

^a If at any time the residual disinfectant concentration at the entry to the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

^b If at any time the residual disinfectant concentration in the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose and/or flush appropriate portions of the distribution system until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

III. SUMMARY OF USE, AT WATER TREATMENT PLANT, OF POLYMER CONTAINING ACRYLAMIDE, POLYMER CONTAINING EPICHLOROHYDRIN, AND/OR IRON AND MANGANESE SEQUESTANT (complete this part only for the reporting month of December each year)

• Is any polymer containing the monomer acrylamide used at the treatment plant? _____ If yes, the polymer dose and the acrylamide level in the polymer are as follows:

Polymer Dose = _____ ppm ^a	Acrylamide Level = _____ % ^a
---------------------------------------	---

^a The acrylamide level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for acrylamide exceeds 0.05% dosed at 1 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

• Is any polymer containing the monomer epichlorohydrin used at the treatment plant? _____ If yes, the polymer dose and the epichlorohydrin level in the polymer are as follows:

Polymer Dose = _____ ppm ^a	Epichlorohydrin Level = _____ % ^a
---------------------------------------	--

^a The epichlorohydrin level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for epichlorohydrin exceeds 0.01% dosed at 20 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

Form for Consecutive Public Water Systems that Treat Their Water
 Form PWS Identification Number: 4430667
 Treatment Plant Name: Indiantown Water Company
 Reporting Month/Year: September 1998

Form Title: Monthly Operation Report for Public Water Systems that Use Chemicals and/or Sedimentation Public Water Systems for Total Dissolved Solids
 Effective Date: December 18, 1994
 DEP Application No.: _____
 Printed by DEP

• Is any iron and manganese sequestant used at the treatment plant? _____ If yes, the type of sequestant, sequestant dose, etc., are as follows:

Type of Sequestant (polyphosphate or sodium silicate): _____
Sequestant Dose (mg/L of phosphate as PO ₄ or mg/L of silicate as SiO ₂): _____
If sodium silicate is used, the amount of added plus naturally occurring silicate = _____ mg/L as SiO ₂ . ¹

¹ If polyphosphate is used, the total phosphate applied shall not exceed 10 mg/L as PO₄ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.; and if sodium silicate is used, the amount of silicate added shall be limited to 20 mg/L as SiO₂ per "Recommended Standards for Water Works."
¹ The amount of added plus naturally occurring silicate shall not exceed 60 mg/L as SiO₂ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.

IV. STATEMENT BY LEAD/CHIEF WATER TREATMENT PLANT OPERATOR

I, the undersigned lead/chief operator of _____, certify that, to the best of my knowledge and belief, the information provided in this report is true and accurate.

Also, I certify that the following additional operations records applicable to this plant were prepared each day a certified operator staffed or visited the plant during the reporting month indicated on this report and that these records will be maintained available for review at the plant site for not less than five years:

- records of amounts of chemicals used and chemical feed rates;
- process performance records for coagulation/flocculation (e.g., source water temperature, pH, turbidity, color, and alkalinity and process effluent pH and alkalinity in addition to chemical feed rates);
- process performance records for sedimentation (e.g., process effluent turbidity and sludge volume produced);
- process performance records for filtration (e.g., process effluent turbidity and color, number of filters in service, filtration rates, unit filter run volumes, head losses, length of filter runs, frequency of backwash, amount of backwash water used, duration of backwash, and backwash rates);
- process performance records for lime-soda ash softening (e.g., source water and process effluent hardness in addition to records for coagulation/flocculation, sedimentation, and filtration);
- process performance records for ion exchange softening (e.g., feed and bypass flows, blend rate, and salt and brine used);
- process performance records for reverse osmosis (e.g., feed, product, and brine flows; feed pressure, temperature, pH, conductivity, and turbidity; product pH and conductivity; and brine pH and conductivity); and
- process performance records for electro dialysis (e.g., polarity, feed temperature and total dissolved solids, product conductivity and total dissolved solids, dilute flow rate, brine make-up, pressures, and volts/amps).

James Hewitt 10/9/98
 Signature and Date

James Hewitt BO 3821
 Name and Certificate Number (please type or print)

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: October, 1998

Use Form No. 62-699.310
 Form Title: Monthly Operating Report for Public Water Systems that Treat Their Water and for Consecutive Public Water Systems that Treat Their Water
 Effective Date: September 18, 1998
 DEP Application No.: _____
 Filed in by: DBS

- Refer to Chapter 62-699, F.A.C., for plant staffing requirements. Class A plants must be staffed by a certified operator 24 hours per day for seven days per week; Class B plants must be staffed by a certified operator seven days per week; Class C plants must be staffed/visited by a certified operator seven days per week or at least six days per week depending on the type and capacity of treatment at the plant; and Class D plants must be visited/checked by a certified operator and/or water system representative at least five days per week. The one day per week that a Class C plant may not be staffed/visited should, if possible, be a day when the plant is not in operation; and the two days per week that a Class D plant may not be visited/checked should, if possible, be days when the plant is not in operation and should be non-consecutive days if the plant is in operation six or seven days per week.

COPY

I. GENERAL WATER SYSTEM AND WATER TREATMENT PLANT INFORMATION

Water System Name and PWS Identification Number, System Owner, System Type, Service Connections to System, and Population Served by System:

● System Name: Indiantown Water Company PWS Identification No.: 4430667
 ● System Owner Name: Indiantown Company, Inc. Telephone No.: 561-597-2121
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956

● System Type: community; non-transient non-community; non-community; consecutive

● Number of Service Connections at End of Reporting Month: 1698

● Total Population Served by System at End of Reporting Month: 5094

Water Treatment Plant Name, Permitted Capacity of Plant, Plant Category and Class, and Plant Operators

● Treatment Plant Name: Indiantown Water Company Telephone No.: 561-597-2122
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956

● Permitted Maximum Day Capacity of Plant: 1,296,000 gpd

● Plant Category and Class per Rule 62-699.310(3), F.A.C.: 4-C

● Lead/Chief Plant Operator:

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
James Revitt	3821	B	5

● Other Certified Plant Operators (attach additional sheets if necessary):

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
Dean Smiley	5715	B	2
Michael Robinson	5888	B	5
Earl Maine	4644	D	5
Don Johnson	2816	B	5

and for Consecutive Public Water Systems that Treat Their Water
 System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: October 1998

Systems that Use Ground Water and/or
 Surface Public Water Sources Fall
 Under This Rule
 Effective Date: October 18, 1994
 DEP Application No.: _____
 Filed in by DEP

II. SUMMARY OF DAILY WATER TREATMENT DATA FOR REPORTING MONTH

• Reporting Month/Year: October 1998

• Type of Residual Disinfectant Maintained in Distribution System Served by Plant: free chlorine; combined chlorine (chloramine);
 chlorine dioxide

• Summary of Daily Water Treatment Data for Reporting Month:

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
1	17	664,000	2.5	1.0			
2	14	644,000	3.5	0.2			
3	19	626,000	3.5	1.6			
4	24	703,000	3.5	0.2			
5	19	744,000	3.5	1.8			
6	23	667,000	3.0	0.2			
7	20	703,000	3.5	1.8			
8	21	721,000	2.0	0.2			
9	19	715,000	2.0	1.6			
10	24	754,000	2.0	0.2			
11	24	837,000	1.3	1.4			
12	24	836,000	1.5	0.2			
13	20	725,000	1.0	0.3			
14	21	803,000	1.5	0.2			
15	24	837,000	1.1	0.2			
16	21	858,000	1.0	0.3			
17	21	904,000	1.1	0.2			
18	23	894,000	3.5	0.6			
19	24	934,000	3.5	1.0	6	0.8	
20	21	836,000	3.4	0.7			
21	21	745,000	2.0	1.2			
22	15	609,000	1.0	0.2			
23	15	613,000	1.0	1.0			
24	15	619,000	1.0	0.2			
25	17	763,000	1.0	0.4			
26	16	721,000	1.0	0.2			
27	17	714,000	3.5	1.0			
28	18	763,000	2.5	0.5			
29	19	781,000	3.0	1.2			

System PWS Identification Number: 4430667
 Treatment Plant Name: Indiantown Water Company
 Reporting Month/Year: October, 1998

Effective Date: December 18, 1994
 DEP Application No.: _____
 Filed in by DEP: _____

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
30	19	795,000	3.0	2.6			
31	20	860,000	3.5	1.4			
Total	XXXXXX	23,503,000	XXXXXXXXXX	XXXXXXXXXX		XXXXXXXXXXXXXXXXXX	XXXXXX
Avg.	XXXXXX	755,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXX
Max.	XXXXXX	934,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXX

* If at any time the residual disinfectant concentration at the entry to the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

† If at any time the residual disinfectant concentration in the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose and/or flush appropriate portions of the distribution system until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

III. SUMMARY OF USE, AT WATER TREATMENT PLANT, OF POLYMER CONTAINING ACRYLAMIDE, POLYMER CONTAINING EPICHLOROHYDRIN, AND/OR IRON AND MANGANESE SEQUESTANT (complete this part only for the reporting month of December each year)

• Is any polymer containing the monomer acrylamide used at the treatment plant? _____ If yes, the polymer dose and the acrylamide level in the polymer are as follows:

Polymer Dose = _____ ppm*	Acrylamide Level = _____ %*
---------------------------	-----------------------------

* The acrylamide level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for acrylamide exceeds 0.05% dosed at 1 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

• Is any polymer containing the monomer epichlorohydrin used at the treatment plant? _____ If yes, the polymer dose and the epichlorohydrin level in the polymer are as follows:

Polymer Dose = _____ ppm*	Epichlorohydrin Level = _____ %*
---------------------------	----------------------------------

* The epichlorohydrin level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for epichlorohydrin exceeds 0.01% dosed at 20 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

System PWS Identification Number: 4430667
Treatment Plant Name: Indiantown Water Company
Reporting Month/Year: October 1998

Issued by the DEP
Consent Decree
Final Date
December 18, 1994
Filing by DEP

• Is any iron and manganese sequestrant used at the treatment plant? _____ If yes, the type of sequestrant, sequestrant dose, etc., are as follows:

Type of Sequestrant (polyphosphate or sodium silicate): _____
Sequestrant Dose (mg/L of phosphate as PO₄ or mg/L of silicate as SiO₂): _____
If sodium silicate is used, the amount of added plus naturally occurring silicate = _____ mg/L as SiO₂.

* If polyphosphate is used, the total phosphate applied shall not exceed 10 mg/L as PO₄, per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.; and if sodium silicate is used, the amount of silicate added shall be limited to 20 mg/L as SiO₂, per "Recommended Standards for Water Works."
* The amount of added plus naturally occurring silicate shall not exceed 60 mg/L as SiO₂, per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.

IV. STATEMENT BY LEAD/CHIEF WATER TREATMENT PLANT OPERATOR

I, the undersigned lead/chief operator of _____, certify that, to the best of my knowledge and belief, the information provided in this report is true and accurate.

Also, I certify that the following additional operations records applicable to this plant were prepared each day a certified operator staffed or visited the plant during the reporting month indicated on this report and that these records will be maintained available for review at the plant site for not less than five years:

- records of amounts of chemicals used and chemical feed rates;
- process performance records for coagulation/flocculation (e.g., source water temperature, pH, turbidity, color, and alkalinity and process effluent pH and alkalinity in addition to chemical feed rates);
- process performance records for sedimentation (e.g., process effluent turbidity and sludge volume produced);
- process performance records for filtration (e.g., process effluent turbidity and color, number of filters in service, filtration rates, unit filter run volumes, head losses, length of filter runs, frequency of backwash, amount of backwash water used, duration of backwash, and backwash rates);
- process performance records for lime-soda ash softening (e.g., source water and process effluent hardness in addition to records for coagulation/flocculation, sedimentation, and filtration);
- process performance records for ion exchange softening (e.g., feed and bypass flows, blend rate, and salt and brine used);
- process performance records for reverse osmosis (e.g., feed, product, and brine flows; feed pressure, temperature, pH, conductivity, and turbidity; product pH and conductivity; and brine pH and conductivity); and
- process performance records for electrodialysis (e.g., polarity, feed temperature and total dissolved solids, product conductivity and total dissolved solids, dilute flow rate, brine make-up, pressures, and volts/amp).

James Hewitt 11/4/98
Signature and Date

James Hewitt BO 3821
Name and Certificate Number (please type or print)

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: November, 1998

62-699.310(3)
 Form Title: Monthly Generation Report for Public Water Systems that Use Ground Water and/or Consecutive Public Water Systems and
 Effective Date: December 18, 1998
 DEP Application No.: _____
 Filed in by DEP: _____

Refer to Chapter 62-699, F.A.C., for plant staffing requirements. Class A plants must be staffed by a certified operator 24 hours per day for some days per week; Class B plants must be staffed by a certified operator seven days per week; Class C plants must be staffed/visited by a certified operator seven days per week or at least six days per week depending on the type and capacity of treatment at the plant; and Class D plants must be visited/checked by a certified operator and/or water system representative at least five days per week. The one day per week that a Class C plant may not be staffed/visited should, if possible, be a day when the plant is not in operation; and the two days per week that a Class D plant may not be visited/checked should, if possible, be days when the plant is not in operation and should be non-consecutive days if the plant is in operation six or seven days per week.

I. GENERAL WATER SYSTEM AND WATER TREATMENT PLANT INFORMATION

Water System Name and PWS Identification Number, System Owner, System Type, Service Connections to System, and Population Served by System

System Name: Indiantown Water Company PWS Identification No.: 4430667

System Owner Name: Indiantown Company, Inc. Telephone No.: 561-597-2121
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956

System Type: community; non-transient non-community; non-community; consecutive

Number of Service Connections at End of Reporting Month: 1,698

Total Population Served by System at End of Reporting Month: 5,094

Water Treatment Plant Name, Permitted Capacity of Plant, Plant Category and Class, and Plant Operators

Treatment Plant Name: Indiantown Water Company Telephone No.: 561-597-2122
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956

Permitted Maximum Day Capacity of Plant: 1,296,000 gpd

Plant Category and Class per Rule 62-699.310(3), F.A.C.: 4-C

Lead/Chief Plant Operator:

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
James Hewitt	3821	B	5

Other Certified Plant Operators (attach additional sheets if necessary):

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
Dean Smiley	5715	B	2
Miguel Rodriguez	3070	C	5
Earl Maine	4644	D	5
Dani Johnson	2816	B	5

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: November, 1998

Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and/or Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 18, 1998
 DEP Application No.: _____
 (Filed in by DEP)

II. SUMMARY OF DAILY WATER TREATMENT DATA FOR REPORTING MONTH

• Reporting Month/Year: November, 1998

• Type of Residual Disinfectant Maintained in Distribution System Served by Plant: free chlorine; combined chlorine (chloramine); chlorine dioxide

• Summary of Daily Water Treatment Data for Reporting Month:

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
1	19	857,000	2.5	0.5			Hydrant flushed
2	24	941,000	3.5	1.1			"
3	23	815,000	3.5	1.8			"
4	17	692,000	3.5	1.6			
5	14	551,000	2.5	1.7			
6	13	593,000	2.0	0.5			
7	16	706,000	2.4	1.7			
8	16	681,000	1.9	0.6			
9	19	736,000	3.5	1.0			
10	16	679,000	2.6	0.8			
11	16	656,000	3.2	1.0			
12	15	671,000	3.0	1.0			
13	16	696,000	1.0	0.4			
14	16	678,000	1.0	0.4			
15	17	797,000	1.5	0.4			
16	16	818,000	1.3	0.2			
17	17	741,000	1.8	0.3			
18	15	742,000	2.0	0.2			
19	16	706,000	1.7	0.3			
20	15	683,000	1.7	0.2			
21	16	674,000	1.5	0.3			
22	17	749,000	1.4	0.3			
23	16	798,000	1.8	0.4			
24	16	728,000	1.6	0.2	6	0.3	
25	15	644,000	1.0	0.2			
26	13	609,000	1.0	0.2			
27	16	714,000	1.6	0.2			
28	16	723,000	1.5	0.3			
29	18	712,000	2.4	0.2			

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: NOVEMBER, 1998

62-555.310(3)

Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water

Effective Date: December 18, 1998

DEP Application No.: _____ Filed in by DEP: _____

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L) ^a	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L) ^b	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L) ^c	
30	16	529,000	2.0	0.6			
31							
Total	XXXXXXX	21,299,000	XXXXXXXXXXXX	XXXXXXXXXXXX		XXXXXXXXXXXXXXXX	XXXXXXX
Avg.	XXXXXXX	709,000	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXX	XXXXXXX
Max.	XXXXXXX	941,000	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXX	XXXXXXX

^a If at any time the residual disinfectant concentration at the entry to the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

^b If at any time the residual disinfectant concentration in the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose and/or flush appropriate portions of the distribution system until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

III. SUMMARY OF USE, AT WATER TREATMENT PLANT, OF POLYMER CONTAINING ACRYLAMIDE, POLYMER CONTAINING EPICHLOROHYDRIN, AND/OR IRON AND MANGANESE SEQUESTRANT (complete this part only for the reporting month of December each year)

• Is any polymer containing the monomer acrylamide used at the treatment plant? _____ If yes, the polymer dose and the acrylamide level in the polymer are as follows:

Polymer Dose = _____ ppm^a Acrylamide Level = _____ %^b

^a The acrylamide level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for acrylamide exceeds 0.05% dosed at 1 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

• Is any polymer containing the monomer epichlorohydrin used at the treatment plant? _____ If yes, the polymer dose and the epichlorohydrin level in the polymer are as follows:

Polymer Dose = _____ ppm^a Epichlorohydrin Level = _____ %^b

^a The epichlorohydrin level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for epichlorohydrin exceeds 0.01% dosed at 20 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

and for Consecutive Public Water Systems ...
 System PWS Identification Number: 4430667
 Treatment Plant Name: Indiantown Water Company
 Reporting Month/Year: November, 1998

Effective Date: December 18, 1998
 DEP Application No.: _____
 (Filled in by DEP)

• Is any iron and manganese sequestrant used at the treatment plant? _____ If yes, the type of sequestrant, sequestrant dose, etc., are as follows:

Type of Sequestrant (polyphosphate or sodium silicate): _____
Sequestrant Dose (mg/L of phosphate as PO ₄ or mg/L of silicate as SiO ₂): _____
If sodium silicate is used, the amount of added plus naturally occurring silicate = _____ mg/L as SiO ₂ .

* If polyphosphate is used, the total phosphate applied shall not exceed 10 mg/L as PO₄ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.; and if sodium silicate is used, the amount of silicate added shall be limited to 20 mg/L as SiO₂ per "Recommended Standards for Water Works."
 * The amount of added plus naturally occurring silicate shall not exceed 60 mg/L as SiO₂ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.

IV. STATEMENT BY LEAD/CHIEF WATER TREATMENT PLANT OPERATOR

I, the undersigned lead/chief operator of _____, certify that, to the best of my knowledge and belief, the information provided in this report is true and accurate.

Also, I certify that the following additional operations records applicable to this plant were prepared each day a certified operator staffed or visited the plant during the reporting month indicated on this report and that these records will be maintained available for review at the plant site for not less than five years:

- records of amounts of chemicals used and chemical feed rates;
- process performance records for coagulation/flocculation (e.g., source water temperature, pH, turbidity, color, and alkalinity and process effluent pH and alkalinity in addition to chemical feed rates);
- process performance records for sedimentation (e.g., process effluent turbidity and sludge volume produced);
- process performance records for filtration (e.g., process effluent turbidity and color, number of filters in service, filtration rates, unit filter run volumes, head losses, length of filter runs, frequency of backwash, amount of backwash water used, duration of backwash, and backwash rates);
- process performance records for lime-soda ash softening (e.g., source water and process effluent hardness in addition to records for coagulation/flocculation, sedimentation, and filtration);
- process performance records for ion exchange softening (e.g., feed and bypass flows, blend rate, and salt and brine used);
- process performance records for reverse osmosis (e.g., feed, product, and brine flows; feed pressure, temperature, pH, conductivity, and turbidity; product pH and conductivity; and brine pH and conductivity); and
- process performance records for electrodialysis (e.g., polarity, feed temperature and total dissolved solids, product conductivity and total dissolved solids, dilute flow rate, brine makeup, pressures, and volts/amperes).

James Hewitt 12/14/98
 Signature and Date

James Hewitt BO 3821
 Name and Certificate Number (please type or print)

116

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: December 1998

62-500.4-1002
 Permit Title: Monthly Operation Report for Public Water Systems that are Subject to Rule 62-500.4-1002
 Effective Date: December 31, 1998
 DEP Application No.: _____
 Filed in by DEP: _____

- Refer to Chapter 62-699, F.A.C., for plant staffing requirements. Class A plants must be staffed by a certified operator 24 hours per day for seven days per week; Class B plants must be staffed by a certified operator seven days per week; Class C plants must be staffed/visited by a certified operator seven days per week or at least six days per week depending on the type and capacity of treatment at the plant; and Class D plants must be visited/checked by a certified operator and/or water system representative at least five days per week. The one day per week that a Class C plant may not be staffed/visited should, if possible, be a day when the plant is not in operation; and the two days per week that a Class D plant may not be visited/checked should, if possible, be days when the plant is not in operation and should be non-consecutive days if the plant is in operation six or seven days per week.

I. GENERAL WATER SYSTEM AND WATER TREATMENT PLANT INFORMATION

Water System Name and PWS Identification Number, System Owner, System Type, Service Connections to System, and Population Served by System

System Name: Indiantown Water Company PWS Identification No.: 4430667

System Owner Name: Indiantown Company, Inc. Telephone No.: 561-597-2121
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956

System Type: community; non-transient non-community; non-community; consecutive

Number of Service Connections at End of Reporting Month: _____

Total Population Served by System at End of Reporting Month: _____

Water Treatment Plant Name, Permitted Capacity of Plant, Plant Category and Class, and Plant Operators

Treatment Plant Name: Indiantown Water Company Telephone No.: 561-597-2122
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956

Permitted Maximum Day Capacity of Plant: 1,296,000 gpd

Plant Category and Class per Rule 62-699.310(3), F.A.C.: 4-C

Lead/Chief Plant Operator:

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
James Revitt	3821	B	5

Other Certified Plant Operators (attach additional sheets if necessary):

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
Dean Smiley	5715	B	2
James Revitt	3821	B	5
Earl Maine	4644	D	5
Don Johnson	2516	B	5

and for consecutive public water systems that treat their water
 System PWS Identification Number: 4430667
 Treatment Plant Name: Indiantown Water Company
 Reporting Month/Year: December, 1998

Form Title: Monthly Operation Report by Public Water
 Systems and the Ground Water and for
 Community Public Water Systems that
 Treat Their Water
 Effective Date: September 16, 1989
 DEP Application No.: _____
 Filed in by DEP: _____

II. SUMMARY OF DAILY WATER TREATMENT DATA FOR REPORTING MONTH

• Reporting Month/Year: December, 1998

• Type of Residual Disinfectant Maintained in Distribution System Served by Plant: free chlorine; combined chlorine (chloramine);
 chlorine dioxide

• Summary of Daily Water Treatment Data for Reporting Month:

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
1	16	629,000	2.0	0.4			
2	16	710,000	2.5	0.6			
3	16	682,000	2.5	0.2			
4	15	690,000	2.7	0.7			
5	15	668,000	2.8	0.4			
6	14	695,000	2.5	0.9			
7	20	812,000	2.5	0.6			
8	15	693,000	2.0	0.6			
9	15	693,000	1.4	0.6			
10	15	693,000	1.8	0.5			
11	16	703,000	2.0	0.4			
12	16	700,000	1.5	0.4			
13	13	644,000	1.4	0.2			
14	16	676,000	1.5	0.6			
15	13	648,000	1.5	0.2			
16	15	655,000	2.0	0.6			
17	13	653,000	2.1	0.4			
18	15	690,000	2.0	0.8			
19	15	658,000	2.0	0.4			
20	14	714,000	1.5	0.3			
21	18	779,000	2.0	0.6			
22	16	744,000	2.7	0.4			
23	17	733,000	2.5	0.6			
24	16	723,000	2.0	0.4			
25	16	757,000	2.5	0.4			
26	15	676,000	2.5	0.7			
27	17	689,000	3.0	0.6			
28	17	778,000	2.6	0.9			
29	17	735,000	2.5	0.5	6	0.5	

Plant PWS Identification Number: 4430667
 Treatment Plant Name: Indiantown Water Company
 Reporting Month/Year: December, 1998

Division of Public Health
 Bureau of Water Control and
 Sanitation
 State of New Jersey
 Trenton, NJ 08646
 Date: December 18, 1998
 DEP Application No.: _____
 Filed in by DEP: _____

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
30	13	682,000	2.4	0.7			
31	17	692,000	2.4	0.2			
Total	XXXXXX	21,701,000	XXXXXXXXXX	XXXXXXXXXX		XXXXXXXXXXXXXXXXXX	XXXXXX
Avg.	XXXXXX	700,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXX
Max.	XXXXXX	812,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXX

* If at any time the residual disinfectant concentration at the entry to the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

† If at any time the residual disinfectant concentration in the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose and/or flush appropriate portions of the distribution system until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

III. SUMMARY OF USE, AT WATER TREATMENT PLANT, OF POLYMER CONTAINING ACRYLAMIDE, POLYMER CONTAINING EPICHLOROHYDRIN, AND/OR IRON AND MANGANESE SEQUESTANT (complete this part only for the reporting month of December each year)

• Is any polymer containing the monomer acrylamide used at the treatment plant? NO If yes, the polymer dose and the acrylamide level in the polymer are as follows:

Polymer Dose - _____ ppm* Acrylamide Level - _____ %*

* The acrylamide level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for acrylamide exceeds 0.05% dosed at 1 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

• Is any polymer containing the monomer epichlorohydrin used at the treatment plant? _____ If yes, the polymer dose and the epichlorohydrin level in the polymer are as follows:

Polymer Dose - _____ ppm* Epichlorohydrin Level - _____ %*

* The epichlorohydrin level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for epichlorohydrin exceeds 0.01% dosed at 20 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

System PWS Identification Number: 4430667
 Treatment Plant Name: IndianTown Water Company
 Reporting Month/Year: December 1998

Consolidated Public Water Systems Act
 Title 16A, Chapter 18
 Effective Date: December 18, 1994
 DEP Application No.: _____
 Filed in by DEP

• Is any iron and manganese sequestant used at the treatment plant? NO If yes, the type of sequestant, sequestant dose, etc., are as follows:

Type of Sequestant (polyphosphate or sodium silicate): _____
 Sequestant Dose (mg/L of phosphate as PO₄ or mg/L of silicate as SiO₂): _____
 If sodium silicate is used, the amount of added plus naturally occurring silicate = _____ mg/L as SiO₂ ¹

¹ If polyphosphate is used, the total phosphate applied shall not exceed 10 mg/L as PO₄ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.; and if sodium silicate is used, the amount of silicate added shall be limited to 20 mg/L as SiO₂ per "Recommended Standards for Water Works."
² The amount of added plus naturally occurring silicate shall not exceed 60 mg/L as SiO₂ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.

IV. STATEMENT BY LEAD/CHIEF WATER TREATMENT PLANT OPERATOR

I, the undersigned lead/chief operator of INDIANTOWN WATER CO., certify that, to the best of my knowledge and belief, the information provided in this report is true and accurate.

Also, I certify that the following additional operations records applicable to this plant were prepared each day a certified operator staffed or visited the plant during the reporting month indicated on this report and that these records will be maintained available for review at the plant site for not less than five years:

- records of amounts of chemicals used and chemical feed rates;
- process performance records for coagulation/flocculation (e.g., source water temperature, pH, turbidity, color, and alkalinity and process effluent pH and alkalinity in addition to chemical feed rates);
- process performance records for sedimentation (e.g., process effluent turbidity and sludge volume produced);
- process performance records for filtration (e.g., process effluent turbidity and color, number of filters in service, filtration rates, unit filter run volumes, head losses, length of filter runs, frequency of backwash, amount of backwash water used, duration of backwash, and backwash rates);
- process performance records for lime-soda ash softening (e.g., source water and process effluent hardness in addition to records for coagulation/flocculation, sedimentation, and filtration);
- process performance records for ion exchange softening (e.g., feed and bypass flows, blend rate, and salt and brine used);
- process performance records for reverse osmosis (e.g., feed, product, and brine flows; feed pressure, temperature, pH, conductivity, and turbidity; product pH and conductivity; and brine pH and conductivity); and
- process performance records for electrodialysis (e.g., polarity, feed temperature and total dissolved solids, product conductivity and total dissolved solids, dilute flow rate, brine make-up, pressures, and volts/amp).

James A. Hewitt 1-12-99
 Signature and Date

James Hewitt BO 3821
 Name and Certificate Number (please type or print)

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: JANUARY, 1999

USE Form No. 62-699.1200
 Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and/or Conventional Public Water Systems that Treat Their Water
 Effective Date: December 18, 1998
 DEP Application No.:
 Filed in by O&M

- Refer to Chapter 62-699, F.A.C., for plant staffing requirements. Class A plants must be staffed by a certified operator 24 hours per day for seven days per week; Class B plants must be staffed by a certified operator seven days per week; Class C plants must be staffed/visited by a certified operator seven days per week or at least six days per week depending on the type and capacity of treatment at the plant; and Class D plants must be visited/checked by a certified operator and/or water system representative at least five days per week. The one day per week that a Class C plant may not be staffed/visited should, if possible, be a day when the plant is not in operation; and the two days per week that a Class D plant may not be visited/checked should, if possible, be days when the plant is not in operation and should be non-consecutive days if the plant is in operation six or seven days per week.

I. GENERAL WATER SYSTEM AND WATER TREATMENT PLANT INFORMATION

Water System Name and PWS Identification Number, System Owner, System Type, Service Connections to System, and Population Served by System

• System Name: Indiantown Water Company PWS Identification No.: 4430667

• System Owner Name: Indiantown Company, Inc. Telephone No.: 561-597-2121

Address: 15851 S.W. Farms Rd./P.O. Box 397

City: Indiantown State: FL. Zip Code: 34956

• System Type: community; non-transient non-community; non-community; consecutive

• Number of Service Connections at End of Reporting Month: 1,625

• Total Population Served by System at End of Reporting Month: 4,875

Water Treatment Plant Name, Permitted Capacity of Plant, Plant Category and Class, and Plant Operators

• Treatment Plant Name: Indiantown Water Company Telephone No.: 561-597-2122

Address: 15851 S.W. Farms Rd./P.O. Box 397

City: Indiantown State: FL. Zip Code: 34956

• Permitted Maximum Day Capacity of Plant: 1,296,000 gpd

• Plant Category and Class per Rule 62-699.310(3), F.A.C.: 4-C

• Lead/Chief Plant Operator:

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
James Hewitt	3821	B	5

• Other Certified Plant Operators (attach additional sheets if necessary):

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
Dean Smiley	5715	B	2
██████████	██████████	██████████	██████████
Earl Maine	4644	D	5
Don Johnson	2816	B	5

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: JANUARY, 1999

Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 18, 1994
 DEP Application No.: _____ (filled in by DEP)

II. SUMMARY OF DAILY WATER TREATMENT DATA FOR REPORTING MONTH

• Reporting Month/Year: JANUARY, 1999

• Type of Residual Disinfectant Maintained in Distribution System Served by Plant: free chlorine; combined chlorine (chloramine); chlorine dioxide

• Summary of Daily Water Treatment Data for Reporting Month:

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
1	17	730,000	2.4	0.4			
2	15	679,000	2.5	0.2			
3	16	700,000	2.4	0.4			
4	18	762,000	2.5	0.2			
5	14	650,000	2.6	0.3			
6	15	675,000	2.0	0.2			
7	15	705,000	2.0	0.6			
8	25	685,000	3.0	0.4			
9	16	683,000	2.5	1.2			
10	18	754,000	3.0	0.6			
11	16	700,000	2.5	1.0			
12	15	710,000	2.0	0.4			
13	16	712,000	1.6	0.9			
14	16	754,000	2.5	0.3			
15	15	703,000	2.0	0.4			
16	15	645,000	1.5	0.3			
17	16	753,000	2.0	0.6			
18	17	775,000	2.3	0.4			
19	17	789,000	2.4	0.5	6	0.5	
20	16	765,000	2.0	0.4			
21	17	766,000	2.2	0.7			
22	16	776,000	2.0	0.5			
23	17	740,000	2.5	0.6			
24	16	801,000	1.5	0.5			
25	16	752,000	2.0	0.2			
26	16	719,000	2.1	0.2			
27	15	725,000	2.5	0.3			
28	17	728,000	2.0	0.5			
29	16	739,000	2.1	0.3			

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
30	16	740,000	2.1	0.6			
31	19	777,000	2.5	0.4			
Total	XXXXXXX	22,589,000	XXXXXXXXXX	XXXXXXXXXX		XXXXXXXXXXXXXXXXXX	XXXXXXXXXX
Avg.	XXXXXXX	728,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXXXXXX
Max.	XXXXXXX	801,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXXXXXX

* If at any time the residual disinfectant concentration at the entry to the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

† If at any time the residual disinfectant concentration in the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose and/or flush appropriate portions of the distribution system until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

III. SUMMARY OF USE, AT WATER TREATMENT PLANT, OF POLYMER CONTAINING ACRYLAMIDE, POLYMER CONTAINING EPICHLOROHYDRIN, AND/OR IRON AND MANGANESE SEQUESTRANT (complete this part only for the reporting month of December each year)

• Is any polymer containing the monomer acrylamide used at the treatment plant? _____ If yes, the polymer dose and the acrylamide level in the polymer are as follows:

Polymer Dose - _____ ppm*	Acrylamide Level - _____ %*
---------------------------	-----------------------------

* The acrylamide level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for acrylamide exceeds 0.05% dosed at 1 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

• Is any polymer containing the monomer epichlorohydrin used at the treatment plant? _____ If yes, the polymer dose and the epichlorohydrin level in the polymer are as follows:

Polymer Dose - _____ ppm*	Epichlorohydrin Level - _____ %*
---------------------------	----------------------------------

* The epichlorohydrin level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for epichlorohydrin exceeds 0.01% dosed at 20 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

123

and for consecutive public water systems that treat their water

System PWS Identification Number: 4430667
 Treatment Plant Name: Indiantown Water Company
 Reporting Month/Year: JANUARY, 1999

Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 19, 1998
 DEP Application No.: _____
 (Filled in by DEP)

• Is any iron and manganese sequestrant used at the treatment plant? _____ If yes, the type of sequestrant, sequestrant dose, etc., are as follows:

Type of Sequestrant (polyphosphate or sodium silicate): _____
 Sequestrant Dose (mg/L of phosphate as PO₄ or mg/L of silicate as SiO₂): _____
 If sodium silicate is used, the amount of added plus naturally occurring silicate = _____ mg/L as SiO₂*

* If polyphosphate is used, the total phosphate applied shall not exceed 10 mg/L as PO₄ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.; and if sodium silicate is used, the amount of silicate added shall be limited to 20 mg/L as SiO₂ per "Recommended Standards for Water Works."

* The amount of added plus naturally occurring silicate shall not exceed 60 mg/L as SiO₂ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.

IV. STATEMENT BY LEAD/CHIEF WATER TREATMENT PLANT OPERATOR

I, the undersigned lead/chief operator of _____, certify that, to the best of my knowledge and belief, the information provided in this report is true and accurate.

Also, I certify that the following additional operations records applicable to this plant were prepared each day a certified operator staffed or visited the plant during the reporting month indicated on this report and that these records will be maintained available for review at the plant site for not less than five years:

- records of amounts of chemicals used and chemical feed rates;
- process performance records for coagulation/flocculation (e.g., source water temperature, pH, turbidity, color, and alkalinity and process effluent pH and alkalinity in addition to chemical feed rates);
- process performance records for sedimentation (e.g., process effluent turbidity and sludge volume produced);
- process performance records for filtration (e.g., process effluent turbidity and color, number of filters in service, filtration rates, unit filter run volumes, head losses, length of filter runs, frequency of backwash, amount of backwash water used, duration of backwash, and backwash rates);
- process performance records for lime-soda ash softening (e.g., source water and process effluent hardness in addition to records for coagulation/flocculation, sedimentation, and filtration);
- process performance records for ion exchange softening (e.g., feed and bypass flows, blend rate, and salt and brine used);
- process performance records for reverse osmosis (e.g., feed, product, and brine flows; feed pressure, temperature, pH, conductivity, and turbidity; product pH and conductivity; and brine pH and conductivity); and
- process performance records for electrodialysis (e.g., polarity, feed temperature and total dissolved solids, product conductivity and total dissolved solids, dilute flow rate, brine make-up, pressures, and volts/amperes).

James Hevitt 2/12/99
 Signature and Date

James Hevitt BO 3821
 Name and Certificate Number (please type or print)

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: Feb. 1999

USE Form No. 62-699.3102
 Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and/or Conventional Public Water Systems and Treatment Works
 Effective Date: December 19, 1998
 DEP Application No.:
 Filed in by DEP:

- Refer to Chapter 62-699, F.A.C., for plant staffing requirements. Class A plants must be staffed by a certified operator 24 hours per day for seven days per week; Class B plants must be staffed by a certified operator seven days per week; Class C plants must be staffed/visited by a certified operator seven days per week or at least six days per week depending on the type and capacity of treatment at the plant; and Class D plants must be visited/checked by a certified operator and/or water system representative at least five days per week. The one day per week that a Class C plant may not be staffed/visited should, if possible, be a day when the plant is not in operation; and the two days per week that a Class D plant may not be visited/checked should, if possible, be days when the plant is not in operation and should be non-consecutive days if the plant is in operation six or seven days per week.

I. GENERAL WATER SYSTEM AND WATER TREATMENT PLANT INFORMATION

Water System Name and PWS Identification Number, System Owner, System Type, Service Connections to System, and Population Served by System:

● **System**
 Name: Indiantown Water Company PWS Identification No.: 4430667

● **System Owner**
 Name: Indiantown Company, Inc. Telephone No.: 561-597-2121
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956

● System Type: community; non-transient non-community; non-community; consecutive

● Number of Service Connections at End of Reporting Month: 1,568

● Total Population Served by System at End of Reporting Month: 5,488

Water Treatment Plant Name, Permitted Capacity of Plant, Plant Category and Class, and Plant Operators

● **Treatment Plant**
 Name: Indiantown Water Company Telephone No.: 561-597-2122
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956

● Permitted Maximum Day Capacity of Plant: 1,296,000 gpd

● Plant Category and Class per Rule 62-699.310(3), F.A.C.: 4-C

● Lead/Chief Plant Operator:

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
James Hewitt	3821	B	5

● Other Certified Plant Operators (attach additional sheets if necessary):

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
Dean Smiley	5715	B	2
Robert Rodriguez	8022	C	5
Earl Maine	4644	D	5
Don Johnson	2816	B	5

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: Feb. 1999

Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 18, 1998
 DEP Application No.: _____
 Filed In by DEP: _____

II. SUMMARY OF DAILY WATER TREATMENT DATA FOR REPORTING MONTH

• Reporting Month/Year: February, 1999

• Type of Residual Disinfectant Maintained in Distribution System Served by Plant: free chlorine; combined chlorine (chloramine); chlorine dioxide

• Summary of Daily Water Treatment Data for Reporting Month:

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
1	17	788,000	2.5	0.4			
2	15	688,000	2.5	0.8			
3	16	697,000	2.3	0.2			
4	13	674,000	2.0	0.6			
5	17	709,000	2.5	0.3			
6	19	543,000	2.2	0.4			
7	18	785,000	2.1	0.3			
8	16	623,000	2.0	0.3			
9	18	782,000	2.0	0.2			
10	16	794,000	2.0	0.4			
11	17	803,000	2.1	0.4			
12	16	764,000	2.1	0.4			
13	16	676,000	2.0	0.5			
14	14	711,000	1.0	0.3			
15	18	772,000	2.0	1.6			
16	17	822,000	2.0	0.6			
17	19	868,000	2.5	2.0			
18	18	868,000	2.0	0.6			
19	19	891,000	2.0	1.0			
20	17	779,000	1.7	0.5			
21	18	867,000	2.5	0.7			
22	20	871,000	3.0	0.6			
23	19	898,000	3.0	0.9	6	0.4	
24	17	853,000	2.5	1.0			
25	21	953,000	2.0	1.0			
26	21	954,000	3.5	1.0			
27	18	876,000	2.0	0.7			
28	20	988,000	2.0	0.9			
29							

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667
 Treatment Plant Name: Indiantown Water Company
 Reporting Month/Year: Feb, 1999

Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water or Consecutive Public Water Systems that Treat Their
 Effective Date: December 31, 99
 DEP Application No.: _____
 Filed in _____

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Report: Emergent or Abnormal Operating Condition
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
30							
31							
Total	XXXXXXXX	<u>22,291,000</u>	XXXXXXXXXXXX	XXXXXXXXXXXX		XXXXXXXXXXXXXXXX	XXXXXX
Avg.	XXXXXXXX	<u>796,000</u>	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXX	XXXXXX
Max.	XXXXXXXX	<u>988,000</u>	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXX	XXXXXX

* If at any time the residual disinfectant concentration at the entry to the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

† If at any time the residual disinfectant concentration in the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose and/or flush appropriate portions of the distribution system until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

III. SUMMARY OF USE, AT WATER TREATMENT PLANT, OF POLYMER CONTAINING ACRYLAMIDE, POLYMER CONTAINING EPICHLOROHYDRIN, AND/OR IRON AND MANGANESE SEQUESTERANT (complete this part only for the reporting month of December each year)

• Is any polymer containing the monomer acrylamide used at the treatment plant? _____ If yes, the polymer dose and the acrylamide level in the polymer are as follows:

Polymer Dose = _____ ppm* Acrylamide Level = _____ %*

The acrylamide level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for acrylamide exceeds 0.05% dosed at 1 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

• Is any polymer containing the monomer epichlorohydrin used at the treatment plant? _____ If yes, the polymer dose and the epichlorohydrin level in the polymer are as follows:

Polymer Dose = _____ ppm* Epichlorohydrin Level = _____ %*

The epichlorohydrin level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for epichlorohydrin exceeds 0.01% dosed at 20 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

127

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667
Treatment Plant Name: Indiantown Water Company
Reporting Month/Year: Feb, 1999

Form Title:	Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
Effective Date:	December 18, 1994
DEP Application No.:	
	(Filed in by DEP)

• Is any iron and manganese sequestrant used at the treatment plant? _____ If yes, the type of sequestrant, sequestrant dose, etc., are as follows:

Type of Sequestrant (polyphosphate or sodium silicate): _____
Sequestrant Dose (mg/L of phosphate as PO ₄ or mg/L of silicate as SiO ₂): _____
If sodium silicate is used, the amount of added plus naturally occurring silicate = _____ mg/L as SiO ₂ . ¹

¹ If polyphosphate is used, the total phosphate applied shall not exceed 10 mg/L as PO₄ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.; and if sodium silicate is used, the amount of silicate added shall be limited to 20 mg/L as SiO₂ per "Recommended Standards for Water Works."

¹ The amount of added plus naturally occurring silicate shall not exceed 60 mg/L as SiO₂ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.

IV. STATEMENT BY LEAD/CHIEF WATER TREATMENT PLANT OPERATOR

I, the undersigned lead/chief operator of _____, certify that, to the best of my knowledge and belief, the information provided in this report is true and accurate.

Also, I certify that the following additional operations records applicable to this plant were prepared each day a certified operator staffed or visited the plant during the reporting month indicated on this report and that these records will be maintained available for review at the plant site for not less than five years:

- records of amounts of chemicals used and chemical feed rates;
- process performance records for coagulation/flocculation (e.g., source water temperature, pH, turbidity, color, and alkalinity and process effluent pH and alkalinity in addition to chemical feed rates);
- process performance records for sedimentation (e.g., process effluent turbidity and sludge volume produced);
- process performance records for filtration (e.g., process effluent turbidity and color, number of filters in service, filtration rates, unit filter run volumes, head losses, length of filter runs, frequency of backwash, amount of backwash water used, duration of backwash, and backwash rates);
- process performance records for lime-soda ash softening (e.g., source water and process effluent hardness in addition to records for coagulation/flocculation, sedimentation, and filtration);
- process performance records for ion exchange softening (e.g., feed and bypass flows, blend rate, and salt and brine used);
- process performance records for reverse osmosis (e.g., feed, product, and brine flows; feed pressure, temperature, pH, conductivity, and turbidity; product pH and conductivity; and brine pH and conductivity); and
- process performance records for electrodialysis (e.g., polarity, feed temperature and total dissolved solids, product conductivity and total dissolved solids, dilute flow rate, brine make-up, pressures, and volts/amperes).

James Hewitt
Signature and Date

James Hewitt BO 3821
Name and Certificate Number (please type or print)

128

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: MARCH 1999

DEP Form No.:	62-699.310(3)
Form Title:	Monthly Operation Report for Public Water Systems that Treat Ground Water and/or Consecutive Public Water Systems that Treat Their Water
Effective Date:	December 19, 1998
DEP Application No.:	
Printed by DEP:	

- Refer to Chapter 62-699, F.A.C., for plant staffing requirements. Class A plants must be staffed by a certified operator 24 hours per day for seven days per week; Class B plants must be staffed by a certified operator seven days per week; Class C plants must be staffed/visited by a certified operator seven days per week or at least six days per week depending on the type and capacity of treatment at the plant; and Class D plants must be visited/checked by a certified operator and/or water system representative at least five days per week. The one day per week that a Class C plant may not be staffed/visited should, if possible, be a day when the plant is not in operation; and the two days per week that a Class D plant may not be visited/checked should, if possible, be days when the plant is not in operation and should be non-consecutive days if the plant is in operation six or seven days per week.

I. GENERAL WATER SYSTEM AND WATER TREATMENT PLANT INFORMATION

Water System Name and PWS Identification Number, System Owner, System Type, Service Connections to System, and Population Served by System:

- System Name: Indiantown Water Company PWS Identification No.: 4430667
- System Owner Name: Indiantown Company, Inc. Telephone No.: 561-597-2121
Address: 15851 S.W. Farms Rd./P.O. Box 397
City: Indiantown State: FL. Zip Code: 34956
- System Type: community; non-transient non-community; non-community; consecutive
- Number of Service Connections at End of Reporting Month: 1715
- Total Population Served by System at End of Reporting Month: 6,002

Water Treatment Plant Name, Permitted Capacity of Plant, Plant Category and Class, and Plant Operators

- Treatment Plant Name: Indiantown Water Company Telephone No.: 561-597-2122
Address: 15851 S.W. Farms Rd./P.O. Box 397
City: Indiantown State: FL. Zip Code: 34956
- Permitted Maximum Day Capacity of Plant: 1,296,000 gpd
- Plant Category and Class per Rule 62-699.310(3), F.A.C.: 4-C
- Lead/Chief Plant Operator:

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
James Hewitt	3821	B	5

- Other Certified Plant Operators (attach additional sheets if necessary):

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
Dean Smiley	5715	B	2
XXXXXXXXXXXX	XXXXXX	XX	XX
Earl Maine	4644	D	5
Don Johnson	2816	B	5

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: MARCH, 1999

Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 19, 1995
 DEP Application No.: _____
 Filled in by DEP: _____

II. SUMMARY OF DAILY WATER TREATMENT DATA FOR REPORTING MONTH

- Reporting Month/Year: MARCH, 1999
- Type of Residual Disinfectant Maintained in Distribution System Served by Plant: free chlorine; combined chlorine (chloramine); chlorine dioxide
- Summary of Daily Water Treatment Data for Reporting Month:

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
1	23	986,000	3.5	1.0			
2	22	959,000	3.5	1.4			
3	18	900,000	2.0	0.8			
4	19	818,000	2.5	1.0			
5	19	786,000	2.4	0.9			
6	19	611,000	2.2	1.0			
7	20	967,000	1.2	0.8			
8	16	946,000	1.0	0.5			
9	19	873,000	3.5	0.7			
10	20	911,000	2.5	1.7			
11	20	985,000	2.3	1.6			
12	22	900,000	2.5	0.4			
13	20	915,000	2.0	1.0			
14	17	920,000	1.6	0.5			
15	17	938,000	1.0	2.4	6	0.5	
16	18	770,000	2.5	0.4			
17	21	861,000	3.0	0.9			
18	21	905,000	2.8	0.9			
19	21	900,000	3.5	1.0			
20	21	915,000	3.5	0.7			
21	18	904,000	3.0	1.1			
22	18	858,000	2.5	0.6			
23	20	834,000	2.4	1.0			
24	20	822,000	3.0	0.4			
25	19	833,000	2.0	0.9			
26	20	872,000	2.5	0.6			
27	20	828,000	2.3	0.9			
28	20	858,000	2.2	0.4			
29	21	847,000	1.5	0.7			

System PWS Identification Number: 4430667
 Treatment Plant Name: Indiantown Water Company
 Reporting Month/Year: MARCH, 1999

REGULATORY REPORT FOR PUBLIC WATER SYSTEMS THAT USE CHLORINE AND/OR CHLORAMINE PUBLIC WATER SYSTEMS
 Issue Date: December 18, 1998
 DEP Application No.: _____
 (Filed in by DEP)

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
30	21	827,000	1.5	0.4			
31	22	810,000	2.8	0.8			
Total	XXXXXX	27,059,000	XXXXXXXXXX	XXXXXXXXXX		XXXXXXXXXXXXXXXXXX	XXXXXX
Avg.	XXXXXX	872,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXX
Max.	XXXXXX	986,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXX	XXXXXX

* If at any time the residual disinfectant concentration at the entry to the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

† If at any time the residual disinfectant concentration in the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose and/or flush appropriate portions of the distribution system until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

III. SUMMARY OF USE, AT WATER TREATMENT PLANT, OF POLYMER CONTAINING ACRYLAMIDE, POLYMER CONTAINING EPICHLOROHYDRIN, AND/OR IRON AND MANGANESE SEQUESTERANT (complete this part only for the reporting month of December each year)

• Is any polymer containing the monomer acrylamide used at the treatment plant? _____ If yes, the polymer dose and the acrylamide level in the polymer are as follows:

Polymer Dose - _____ ppm* Acrylamide Level - _____ %*

* The acrylamide level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for acrylamide exceeds 0.05% dosed at 1 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

• Is any polymer containing the monomer epichlorohydrin used at the treatment plant? _____ If yes, the polymer dose and the epichlorohydrin level in the polymer are as follows:

Polymer Dose - _____ ppm* Epichlorohydrin Level - _____ %*

* The epichlorohydrin level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for epichlorohydrin exceeds 0.01% dosed at 20 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: MARCH, 1999

8. 222 310(3)

Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water

Effective Date: December 12, 1994

DEP Application No.: _____

(Filled in by DEP)

• Is any iron and manganese sequestrant used at the treatment plant? _____ If yes, the type of sequestrant, sequestrant dose, etc., are as follows:

Type of Sequestrant (polyphosphate or sodium silicate): _____

Sequestrant Dose (mg/L of phosphate as PO₄ or mg/L of silicate as SiO₂): _____

If sodium silicate is used, the amount of added plus naturally occurring silicate = _____ mg/L as SiO₂.¹

¹ If polyphosphate is used, the total phosphate applied shall not exceed 10 mg/L as PO₄ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.; and if sodium silicate is used, the amount of silicate added shall be limited to 20 mg/L as SiO₂ per "Recommended Standards for Water Works."

¹ The amount of added plus naturally occurring silicate shall not exceed 60 mg/L as SiO₂ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.

IV. STATEMENT BY LEAD/CHIEF WATER TREATMENT PLANT OPERATOR

I, the undersigned lead/chief operator of _____, certify that, to the best of my knowledge and belief, the information provided in this report is true and accurate.

Also, I certify that the following additional operations records applicable to this plant were prepared each day a certified operator staffed or visited the plant during the reporting month indicated on this report and that these records will be maintained available for review at the plant site for not less than five years:

- records of amounts of chemicals used and chemical feed rates;
- process performance records for coagulation/flocculation (e.g., source water temperature, pH, turbidity, color, and alkalinity and process effluent pH and alkalinity in addition to chemical feed rates);
- process performance records for sedimentation (e.g., process effluent turbidity and sludge volume produced);
- process performance records for filtration (e.g., process effluent turbidity and color, number of filters in service, filtration rates, unit filter run volumes, head losses, length of filter runs, frequency of backwash, amount of backwash water used, duration of backwash, and backwash rates);
- process performance records for lime-soda ash softening (e.g., source water and process effluent hardness in addition to records for coagulation/flocculation, sedimentation, and filtration);
- process performance records for ion exchange softening (e.g., feed and bypass flows, blend rate, and salt and brine used);
- process performance records for reverse osmosis (e.g., feed, product, and brine flows; feed pressure, temperature, pH, conductivity, and turbidity; product pH and conductivity; and brine pH and conductivity); and
- process performance records for electrodialysis (e.g., polarity, feed temperature and total dissolved solids, product conductivity and total dissolved solids, dilute flow rate, brine make-up, pressures, and volts/amps).

Signature and Date

James Hevitt BO 3821
Name and Certificate Number (please type or print)

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: April, 1999

Use Form No. 62-699.310
 Form Title: Monthly Operation Report for Public Water Systems that Treat Their Water
 Effective Date: November 19, 1988
 DEP Application No.: _____
 Printed by DEP.

Refer to Chapter 62-699, F.A.C., for plant staffing requirements. Class A plants must be staffed by a certified operator 24 hours per day for seven days per week; Class B plants must be staffed by a certified operator seven days per week; Class C plants must be staffed/visited by a certified operator seven days per week or at least six days per week depending on the type and capacity of treatment at the plant; and Class D plants must be visited/checked by a certified operator and/or water system representative at least five days per week. The one day per week that a Class C plant may not be staffed/visited should, if possible, be a day when the plant is not in operation; and the two days per week that a Class D plant may not be visited/checked should, if possible, be days when the plant is not in operation and should be non-consecutive days if the plant is in operation six or seven days per week.

I. GENERAL WATER SYSTEM AND WATER TREATMENT PLANT INFORMATION

Water System Name and PWS Identification Number, System Owner, System Type, Service Connections to System, and Population Served by System

- **System**
 Name: Indiantown Water Company PWS Identification No.: 4430667
- **System Owner**
 Name: Indiantown Company, Inc. Telephone No.: 561-597-2121
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956
- System Type: community; non-transient non-community; non-community; consecutive
- Number of Service Connections at End of Reporting Month: 1792
- Total Population Served by System at End of Reporting Month: 5376

Water Treatment Plant Name, Permitted Capacity of Plant, Plant Category and Class, and Plant Operators

- **Treatment Plant**
 Name: Indiantown Water Company Telephone No.: 561-597-2122
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956
- Permitted Maximum Day Capacity of Plant: 1,296,000 gpd
- Plant Category and Class per Rule 62-699.310(3), F.A.C.: 4-C
- Lead/Chief Plant Operator:

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
James Hewitt	3821	B	5

• Other Certified Plant Operators (attach additional sheets if necessary):

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
Dean Smiley	5715	B	2
Higino Rodriguez	2378	C	5
Earl Maine	4644	D	5
Don Johnson	2816	B	5

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: April, 1999

Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water

Effective Date: December 18, 1994

DEP Application No.: _____

Filed In by DEP: _____

II. SUMMARY OF DAILY WATER TREATMENT DATA FOR REPORTING MONTH

• Reporting Month/Year: April, 1999

• Type of Residual Disinfectant Maintained in Distribution System Served by Plant: free chlorine; combined chlorine (chloramine); chlorine dioxide

• Summary of Daily Water Treatment Data for Reporting Month:

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
1	15	815,000	1.5	0.4			
2	19	900,000	3.5	1.4			
3	18	866,000	2.7	0.4			
4	18	792,000	2.2	1.0			
5	21	901,000	1.9	0.5			
6	21	923,000	2.0	0.5			
7	18	860,000	2.0	0.3			
8	21	878,000	2.8	0.6			
9	20	912,000	2.3	0.6			
10	23	958,000	2.0	1.0			
11	24	727,000	2.5	0.3			
12	24	900,000	3.5	1.3			
13	21	930,000	2.0	0.3			
14	22	967,000	2.5	1.0			
15	19	905,000	1.5	0.3			
16	18	901,000	1.4	0.9			
17	19	963,000	2.0	0.2			
18	17	948,000	2.0	0.7			
19	17	923,000	1.7	0.3			
20	13	882,000	1.5	0.5			
21	17	892,000	1.4	0.3			
22	18	903,000	2.0	0.6			
23	22	924,000	2.5	0.4			
24	21	883,000	3.0	0.5			
25	18	907,000	2.1	0.3			
26	20	991,000	1.5	0.4			
27	18	946,000	1.7	0.4			
28	18	881,000	1.2	0.6	6	0.5	
29	14	646,000	1.0	0.5			

System PWS Identification Number: 4430667
 Treatment Plant Name: Indiantown Water Company
 Reporting Month/Year: April, 1999

62-555-3700
 Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and/or Conventional Public Water Systems
 Issue This Form: December 18, 1997
 Effective Date: _____
 DEP Application No.: _____
 (Filed in by DEP)

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
30	11	634,000	3.5	0.5			
31							
Total	XXXXXXX	26,528,000	XXXXXXXXXX	XXXXXXXXXX		XXXXXXXXXXXXXXXXXX	XXXXXXXXXX
Avg.	XXXXXXX	795,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXX
Max.	XXXXXXX	991,000	XXXXXXXXXX	XXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXX

* If at any time the residual disinfectant concentration at the entry to the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

† If at any time the residual disinfectant concentration in the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose and/or flush appropriate portions of the distribution system until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

III. SUMMARY OF USE, AT WATER TREATMENT PLANT, OF POLYMER CONTAINING ACRYLAMIDE, POLYMER CONTAINING EPICHLOROHYDRIN, AND/OR IRON AND MANGANESE SEQUESTRANT (complete this part only for the reporting month of December each year)

• Is any polymer containing the monomer acrylamide used at the treatment plant? _____ If yes, the polymer dose and the acrylamide level in the polymer are as follows:

Polymer Dose = _____ ppm* Acrylamide Level = _____ %*

* The acrylamide level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for acrylamide exceeds 0.05% dosed at 1 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

• Is any polymer containing the monomer epichlorohydrin used at the treatment plant? _____ If yes, the polymer dose and the epichlorohydrin level in the polymer are as follows:

Polymer Dose = _____ ppm* Epichlorohydrin Level = _____ %*

* The epichlorohydrin level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for epichlorohydrin exceeds 0.01% dosed at 20 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

135

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667
Treatment Plant Name: Indiantown Water Company
Reporting Month/Year: April 1999

Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
Effective Date: December 19, 1998
DEF Application No.: _____
(Filed in by DEP)

Is any iron and manganese sequestrant used at the treatment plant? _____ If yes, the type of sequestrant, sequestrant dose, etc., are as follows:

Type of Sequestrant (polyphosphate or sodium silicate): _____
Sequestrant Dose (mg/L of phosphate as PO₄ or mg/L of silicate as SiO₂): _____
If sodium silicate is used, the amount of added plus naturally occurring silicate = _____ mg/L as SiO₂.

If polyphosphate is used, the total phosphate applied shall not exceed 10 mg/L as PO₄ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.; and if sodium silicate is used, the amount of silicate added shall be limited to 20 mg/L as SiO₂ per "Recommended Standards for Water Works."
The amount of added plus naturally occurring silicate shall not exceed 60 mg/L as SiO₂ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.

IV. STATEMENT BY LEAD/CHIEF WATER TREATMENT PLANT OPERATOR

I, the undersigned lead/chief operator of _____, certify that, to the best of my knowledge and belief, the information provided in this report is true and accurate.

Also, I certify that the following additional operations records applicable to this plant were prepared each day a certified operator staffed or visited the plant during the reporting month indicated on this report and that these records will be maintained available for review at the plant site for not less than five years:

- records of amounts of chemicals used and chemical feed rates;
- process performance records for coagulation/flocculation (e.g., source water temperature, pH, turbidity, color, and alkalinity and process effluent pH and alkalinity in addition to chemical feed rates);
- process performance records for sedimentation (e.g., process effluent turbidity and sludge volume produced);
- process performance records for filtration (e.g., process effluent turbidity and color, number of filters in service, filtration rates, unit filter run volumes, head losses, length of filter runs, frequency of backwash, amount of backwash water used, duration of backwash, and backwash rates);
- process performance records for lime-soda ash softening (e.g., source water and process effluent hardness in addition to records for coagulation/flocculation, sedimentation, and filtration);
- process performance records for ion exchange softening (e.g., feed and bypass flows, blend rate, and salt and brine used);
- process performance records for reverse osmosis (e.g., feed, product, and brine flows; feed pressure, temperature, pH, conductivity, and turbidity; product pH and conductivity; and brine pH and conductivity); and
- process performance records for electrodialysis (e.g., polarity, feed temperature and total dissolved solids, product conductivity and total dissolved solids, dilute flow rate, brine make-up pressures, and volts/amps).

James A. Hewitt 5/10/99
Signature and Date

James Hewitt BO 3821
Name and Certificate Number (please type or print)

COPY

and for Consecutive Public Water Systems that Treat Their Water
 System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company
 Reporting Month/Year: May 1999

Use Form No. 62-900.1 (1998)
 Form Title: Monthly Operating Report for Public Water Systems that Treat Ground Water and/or Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 15, 1994
 DEP Application No.: _____
 Filed in by DEP: _____

- Refer to Chapter 62-699, F.A.C., for plant staffing requirements. Class A plants must be staffed by a certified operator 24 hours per day for seven days per week; Class B plants must be staffed by a certified operator seven days per week; Class C plants must be staffed/visited by a certified operator seven days per week or at least six days per week depending on the type and capacity of treatment at the plant; and Class D plants must be visited/checked by a certified operator and/or water system representative at least five days per week. The one day per week that a Class C plant may not be staffed/visited should, if possible, be a day when the plant is not in operation; and the two days per week that a Class D plant may not be visited/checked should, if possible, be days when the plant is not in operation and should be non-consecutive days if the plant is in operation six or seven days per week.

I. GENERAL WATER SYSTEM AND WATER TREATMENT PLANT INFORMATION

Water System Name and PWS Identification Number, System Owner, System Type, Service Connections to System, and Population Served by System

● System Name: Indiantown Water Company PWS Identification No.: 4430667
 ● System Owner Name: Indiantown Company, Inc. Telephone No.: 561-597-2121
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956

- System Type: community; non-transient non-community; non-community; consecutive
- Number of Service Connections at End of Reporting Month: 1728
- Total Population Served by System at End of Reporting Month: 5184

Water Treatment Plant Name, Permitted Capacity of Plant, Plant Category and Class, and Plant Operators

● Treatment Plant Name: Indiantown Water Company Telephone No.: 561-597-2122
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956

- Permitted Maximum Day Capacity of Plant: 1,296,000 gpd
- Plant Category and Class per Rule 62-699.310(3), F.A.C.: 4-C
- Lead/Chief Plant Operator:

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
James Hewitt	3821	B	5

● Other Certified Plant Operators (attach additional sheets if necessary):

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
Dean Smiley	5715	B	2
Walter Rodriguez	5888	C	5
Earl Maine	4644	D	5
Don Johnson	2816	B	5

and for Consecutive Public Water Systems that Treat Their Water
 System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: MAY 1999

84-288.8120h
 Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 18, 1995
 DEP Application No.: _____
 Filed in by DEP: _____

II. SUMMARY OF DAILY WATER TREATMENT DATA FOR REPORTING MONTH

• Reporting Month/Year: MAY 1999

• Type of Residual Disinfectant Maintained in Distribution System Served by Plant: free chlorine; combined chlorine (chloramine); chlorine dioxide

• Summary of Daily Water Treatment Data for Reporting Month:

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
1	17	711,000	3.5	1.1			
2	17	696,000	3.5	0.9			
3	17	757,000	3.5	1.0			
4	19	770,000	3.0	1.3			
5	19	875,000	2.2	0.8			
6	24	850,000	3.0	1.3			
7	21	836,000	3.5	1.0			
8	24	827,000	2.5	1.0			
9	20	830,000	3.0	1.0			
10	17	676,000	2.5	1.1			
11	17	716,000	2.5	0.6			
12	16	643,000	1.0	1.2			
13	15	658,000	2.5	0.7			
14	17	709,000	2.5	1.3			
15	17	670,000	2.2	0.6			
16	17	740,000	1.5	1.0			
17	19	802,000	2.1	0.4			
18	20	794,000	3.0	1.0			
19	22	872,000	3.5	0.6			
20	18	712,000	2.5	1.1			
21	24	864,000	3.0	0.9			
22	18	706,000	3.0	1.4			
23	18	677,000	3.0	1.0			
24	20	766,000	3.0	1.5			
25	21	816,000	3.0	1.2	6	2.7	
26	18	776,000	1.5	1.6			
27	24	846,000	2.6	1.0			
28	24	910,000	3.2	1.4			
29	24	906,000	3.5	1.1			

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667
 Treatment Plant Name: Indiantown Water Company
 Reporting Month/Year: MAY, 1999

62-655.310(d)

Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water

Effective Date: December 19, 1994
 DEP Application No.: _____
 (Filed in by DEP)

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
30	19	797,000	2.6	1.2			
31	17	714,000	1.6	0.8			
Total	XXXXXXX	23,952,000	XXXXXXXXXXXX	XXXXXXXXXXXX		XXXXXXXXXXXXXXXX	XXXXXXX
Avg.	XXXXXXX	772,000	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXX
Max.	XXXXXXX	910,000	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXX

* If at any time the residual disinfectant concentration at the entry to the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

† If at any time the residual disinfectant concentration in the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose and/or flush appropriate portions of the distribution system until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

III. SUMMARY OF USE, AT WATER TREATMENT PLANT, OF POLYMER CONTAINING ACRYLAMIDE, POLYMER CONTAINING EPICHLOROHYDRIN, AND/OR IRON AND MANGANESE SEQUESTANT (complete this part only for the reporting month of December each year)

● Is any polymer containing the monomer acrylamide used at the treatment plant? _____ If yes, the polymer dose and the acrylamide level in the polymer are as follows:

Polymer Dose - _____ ppm*	Acrylamide Level - _____ %*
---------------------------	-----------------------------

* The acrylamide level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for acrylamide exceeds 0.05% dosed at 1 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

● Is any polymer containing the monomer epichlorohydrin used at the treatment plant? _____ If yes, the polymer dose and the epichlorohydrin level in the polymer are as follows:

Polymer Dose - _____ ppm*	Epichlorohydrin Level - _____ %*
---------------------------	----------------------------------

* The epichlorohydrin level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for epichlorohydrin exceeds 0.01% dosed at 20 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667
Treatment Plant Name: Indiantown Water Company
Reporting Month/Year: MAY, 1999

Form Title:	Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
Effective Date:	December 19, 1994
DEP Application No.:	
	(Filled in by DEP)

• Is any iron and manganese sequestrant used at the treatment plant? _____ If yes, the type of sequestrant, sequestrant dose, etc., are as follows:

Type of Sequestrant (polyphosphate or sodium silicate): _____
Sequestrant Dose (mg/L of phosphate as PO ₄ or mg/L of silicate as SiO ₂): _____
If sodium silicate is used, the amount of added plus naturally occurring silicate = _____ mg/L as SiO ₂ . ¹

¹ If polyphosphate is used, the total phosphate applied shall not exceed 10 mg/L as PO₄ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.; and if sodium silicate is used, the amount of silicate added shall be limited to 20 mg/L as SiO₂ per "Recommended Standards for Water Works."

¹ The amount of added plus naturally occurring silicate shall not exceed 60 mg/L as SiO₂ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.

IV. STATEMENT BY LEAD/CHIEF WATER TREATMENT PLANT OPERATOR

I, the undersigned lead/chief operator of _____, certify that, to the best of my knowledge and belief, the information provided in this report is true and accurate.

Also, I certify that the following additional operations records applicable to this plant were prepared each day a certified operator staffed or visited the plant during the reporting month indicated on this report and that these records will be maintained available for review at the plant site for not less than five years:

- records of amounts of chemicals used and chemical feed rates;
- process performance records for coagulation/flocculation (e.g., source water temperature, pH, turbidity, color, and alkalinity and process effluent pH and alkalinity in addition to chemical feed rates);
- process performance records for sedimentation (e.g., process effluent turbidity and sludge volume produced);
- process performance records for filtration (e.g., process effluent turbidity and color, number of filters in service, filtration rates, unit filter run volumes, head losses, length of filter runs, frequency of backwash, amount of backwash water used, duration of backwash, and backwash rates);
- process performance records for lime-soda ash softening (e.g., source water and process effluent hardness in addition to records for coagulation/flocculation, sedimentation, and filtration);
- process performance records for ion exchange softening (e.g., feed and bypass flows, blend rate, and salt and brine used);
- process performance records for reverse osmosis (e.g., feed, product, and brine flows; feed pressure, temperature, pH, conductivity, and turbidity; product pH and conductivity; and brine pH and conductivity); and
- process performance records for electrodialysis (e.g., polarity, feed temperature and total dissolved solids, product conductivity and total dissolved solids, dilute flow rate, brine make-up, pressures, and volts/amps).

James Hewitt 6/19/99
Signature and Date

James Hewitt BO 3821
Name and Certificate Number (please type or print)

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: June, 1999

DBP Form No. 1
 PWS Title: Monthly Operation Report for Public Water Systems that Use Ground Water and/or Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 15, 1998
 DBP Application No.: _____
 Filed in by DBP: _____

- Refer to Chapter 62-699, F.A.C., for plant staffing requirements. Class A plants must be staffed by a certified operator 24 hours per day for seven days per week; Class B plants must be staffed by a certified operator seven days per week; Class C plants must be staffed/visited by a certified operator seven days per week or at least six days per week depending on the type and capacity of treatment at the plant; and Class D plants must be visited/checked by a certified operator and/or water system representative at least five days per week. The one day per week that a Class C plant may not be staffed/visited should, if possible, be a day when the plant is not in operation; and the two days per week that a Class D plant may not be visited/checked should, if possible, be days when the plant is not in operation and should be non-consecutive days if the plant is in operation six or seven days per week.

I. GENERAL WATER SYSTEM AND WATER TREATMENT PLANT INFORMATION

Water System Name and PWS Identification Number, System Owner, System Type, Service Connections to System, and Population Served by System

• **System**
 Name: Indiantown Water Company PWS Identification No.: 4430667

• **System Owner**
 Name: Indiantown Company, Inc. Telephone No.: 561-597-2121
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956

• System Type: community; non-transient non-community; non-community; consecutive

• Number of Service Connections at End of Reporting Month: 1,733

• Total Population Served by System at End of Reporting Month: 5,199

Water Treatment Plant Name, Permitted Capacity of Plant, Plant Category and Class, and Plant Operators

• **Treatment Plant**
 Name: Indiantown Water Company Telephone No.: 561-597-2122
 Address: 15851 S.W. Farms Rd./P.O. Box 397
 City: Indiantown State: FL. Zip Code: 34956

• Permitted Maximum Day Capacity of Plant: 1,296,000 gpd

• Plant Category and Class per Rule 62-699.310(3), F.A.C.: 4-C

• Lead/Chief Plant Operator:

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
James Hewitt	3821	B	5

• Other Certified Plant Operators (attach additional sheets if necessary):

Name	Certificate Number	Class (A, B, C, or D)	Day(s)/Shift(s) Worked
Dean Smiley	5715	B	2
Regina Rodriguez	5715	B	2
Earl Maine	4644	D	5
Don Johnson	2816	B	5

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: June, 1999

Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 18, 1994
 DEP Application No.: _____
 Filed in by DEP

II. SUMMARY OF DAILY WATER TREATMENT DATA FOR REPORTING MONTH

• Reporting Month/Year: JUNE, 1999

• Type of Residual Disinfectant Maintained in Distribution System Served by Plant: free chlorine; combined chlorine (chloramine); chlorine dioxide

• Summary of Daily Water Treatment Data for Reporting Month:

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
1	19	746,000	1.5	0.8			
2	18	785,000	2.0	0.4			
3	17	625,000	2.2	0.7			
4	18	708,000	2.0	0.3			
5	17	675,000	1.5	0.6			
6	17	742,000	1.5	0.4			
7	19	700,000	1.6	0.4			
8	15	544,000	1.5	0.3			
9	16	580,000	1.4	0.6			
10	17	620,000	1.4	0.2			
11	14	627,000	1.3	0.4			
12	16	607,000	2.0	0.3			
13	15	630,000	2.5	0.3			
14	18	709,000	3.0	0.9			
15	16	657,000	3.0	0.4			
16	16	653,000	3.0	0.4			
17	10	552,000	2.5	0.6			
18	13	555,000	2.6	0.6			
19	13	551,000	2.3	0.5			
20	14	555,000	2.4	0.5			
21	15	595,000	2.5	0.5			
22	16	594,000	2.5	0.6			
23	13	555,000	2.5	0.5	6	0.4	
24	14	466,000	2.5	0.6			
25	15	674,000	2.0	0.4			
26	13	526,000	2.0	0.4			
27	13	544,000	2.1	0.5			
28	15	561,000	2.7	0.3			
29	15	556,000	2.0	0.6			

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667

Treatment Plant Name: Indiantown Water Company

Reporting Month/Year: JULNE, 1999

Form No. 62-555-310(3)
 Form Title: Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
 Effective Date: December 19, 1998
 DEP Application No.: _____
 (Filed in by DEP)

Day of the Month	Hours Plant in Operation	Quantity of Finished Water Produced by Plant (gallons)	Lowest Residual Disinfectant Concentration at Entry to Distribution System (mg/L)*	Residual Disinfectant in Distribution System			Reported Emergency or Abnormal Operating Conditions
				Lowest Residual Disinfectant Concentration at Remote Point (mg/L)†	Number of Instances Where Residual Disinfectant Measurements Taken at Total Coliform Sampling Points	Lowest Residual Disinfectant Concentration at Total Coliform Sampling Points (mg/L)†	
30	13	535,000	2.0	0.3			
31							
Total	XXXXXXX	18,427,000	XXXXXXXXXXXX	XXXXXXXXXXXX		XXXXXXXXXXXXXXXXXX	XXXXXXX
Avg.	XXXXXXX	614,000	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXX
Max.	XXXXXXX	785,000	XXXXXXXXXXXX	XXXXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXXXXXXXXXXXXXXX	XXXXXXX

* If at any time the residual disinfectant concentration at the entry to the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

† If at any time the residual disinfectant concentration in the distribution system drops below the equivalent of 0.2 mg/L of free available chlorine, immediately increase the chlorine dose and/or flush appropriate portions of the distribution system until the residual disinfectant concentration is at least equivalent to 0.2 mg/L of free available chlorine and notify the Department or the appropriate ACPHU by wire or telephone within 24 hours pursuant to Rule 62-555.350(3), F.A.C.

III. SUMMARY OF USE, AT WATER TREATMENT PLANT, OF POLYMER CONTAINING ACRYLAMIDE, POLYMER CONTAINING EPICHLOROHYDRIN, AND/OR IRON AND MANGANESE SEQUESTANT (complete this part only for the reporting month of December each year)

• Is any polymer containing the monomer acrylamide used at the treatment plant? _____ If yes, the polymer dose and the acrylamide level in the polymer are as follows:

Polymer Dose - _____ ppm*	Acrylamide Level - _____ %*
---------------------------	-----------------------------

* The acrylamide level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for acrylamide exceeds 0.05% dosed at 1 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

• Is any polymer containing the monomer epichlorohydrin used at the treatment plant? _____ If yes, the polymer dose and the epichlorohydrin level in the polymer are as follows:

Polymer Dose - _____ ppm*	Epichlorohydrin Level - _____ %*
---------------------------	----------------------------------

* The epichlorohydrin level provided on this form may be based on the polymer manufacturer's certification or on third-party certification. If the combination (or product) of dose and monomer level for epichlorohydrin exceeds 0.01% dosed at 20 ppm (or equivalent), it is a violation of State primary drinking water standards per Rules 62-550.310(2)(d) and 62-550.325(1), F.A.C.

and for Consecutive Public Water Systems that Treat Their Water

System PWS Identification Number: 4430667
Treatment Plant Name: Indiantown Water Company
Reporting Month/Year: June, 1999

Form Title:	Monthly Operation Report for Public Water Systems that Use Ground Water and for Consecutive Public Water Systems that Treat Their Water
Effective Date:	December 19, 1994
DEP Application No.:	
(Filed in by DEP)	

● Is any iron and manganese sequestrant used at the treatment plant? _____ If yes, the type of sequestrant, sequestrant dose, etc., are as follows:

Type of Sequestrant (polyphosphate or sodium silicate): _____
Sequestrant Dose (mg/L of phosphate as PO ₄ or mg/L of silicate as SiO ₂): _____
If sodium silicate is used, the amount of added plus naturally occurring silicate = _____ mg/L as SiO ₂ . ¹

¹ If polyphosphate is used, the total phosphate applied shall not exceed 10 mg/L as PO₄ per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.; and if sodium silicate is used, the amount of silicate added shall be limited to 20 mg/L as SiO₂, per "Recommended Standards for Water Works."

² The amount of added plus naturally occurring silicate shall not exceed 60 mg/L as SiO₂, per "Recommended Standards for Water Works," which is incorporated by reference in Rule 62-555.330(3), F.A.C.

IV. STATEMENT BY LEAD/CHIEF WATER TREATMENT PLANT OPERATOR

I, the undersigned lead/chief operator of _____, certify that, to the best of my knowledge and belief, the information provided in this report is true and accurate.

Also, I certify that the following additional operations records applicable to this plant were prepared each day a certified operator staffed or visited the plant during the reporting month indicated on this report and that these records will be maintained available for review at the plant site for not less than five years:

- records of amounts of chemicals used and chemical feed rates;
- process performance records for coagulation/flocculation (e.g., source water temperature, pH, turbidity, color, and alkalinity and process effluent pH and alkalinity in addition to chemical feed rates);
- process performance records for sedimentation (e.g., process effluent turbidity and sludge volume produced);
- process performance records for filtration (e.g., process effluent turbidity and color, number of filters in service, filtration rates, unit filter run volumes, head losses, length of filter runs, frequency of backwash, amount of backwash water used, duration of backwash, and backwash rates);
- process performance records for lime-soda ash softening (e.g., source water and process effluent hardness in addition to records for coagulation/flocculation, sedimentation, and filtration);
- process performance records for ion exchange softening (e.g., feed and bypass flows, blend rate, and salt and brine used);
- process performance records for reverse osmosis (e.g., feed, product, and brine flows; feed pressure, temperature, pH, conductivity, and turbidity; product pH and conductivity; and brine pH and conductivity); and
- process performance records for electrodialysis (e.g., polarity, feed temperature and total dissolved solids, product conductivity and total dissolved solids, dilute flow rate, brine make-up, pressures, and volts/amp).

James Hewitt 7-13-99
Signature and Date

James Hewitt BO 3821
Name and Certificate Number (please type or print)

Wastewater Operating Reports

Domestic Wastewater Treatment Plant Monthly Operating Report

Part II - General Information

- (1) Month July Year 1997
 (2) Plant's DER Identification Number 5143P03291
 (3) Plant Name INDIANTOWN WASTEWATER TREATMENT PLANT
 (4) Plant Address PO Box 397, 163rd Ave
ROCKING PARK
 (5) City INDIANTOWN
 (6) County MARTIN
 (7) Phone Number (561) 597-2121
 (8) Permit Number D.O. # 091826
 (9) Plant Type B-C
 (10) Test Site Identification Number 00002
 (11) Fecal Coliform Sample Method
 Membrane Filter Most Probable Number
 (12) Type of Effluent Disposal or Reclaimed Water Reuse
EVAP./PURC. Ponds/IRRIGATION
 (13) Limited Wet Weather Discharge Activated
 Yes No Not Applicable
 (14) Cumulative Days of Wet Weather Discharge _____
 (15) Plant Staffing
 Day Shift Operator Class _____ Cert. No. _____
 Evening Shift Operator Class _____ Cert. No. _____
 Night Shift Operator Class _____ Cert. No. _____
 Lead Operator [Signature] # B. 6805
 Signature Cert. No.

Parameter	Units	STORET Code	Value
(16) Monthly average daily flow	mgd	050053	1.18
(17) Permitted capacity	mgd	-	1.500
(18) Three-month average daily flow	mgd	-	1.391
(19) Percent of permitted capacity	%	-	78%
(20) CBOD ₅ Effluent	mg/L	080082	7.4
(21) CBOD ₅ Effluent	lbs/day	-	N/A
(22) TSS Effluent	mg/L	900201	1.5
(23) TSS Effluent	lbs/day	-	N/A
(24) Minimum pH		-	6.9
(25) Maximum pH		-	7.4
(26) Total N	mg/L	000600	N/A
(27) TKN	mg/L	000625	N/A
(28) Ammonia (NH ₃ · N)	mg/L	000610	N/A
(29) Nitrate	mg/L	071850	N/A
(30) Total Phosphorus	mg/L	000665	N/A
(31) Minimum Chlorine Residual	mg/L	-	0.6
(32) Maximum Chlorine Residual	mg/L	-	2.1
(33) Other Effluent Parameters			*
* <u>RAINFALL</u>			
* <u>5.1 INCHES</u>			
* <u>TO 7/15/97</u>			
* <u>277,528 GALLONS</u>			


Domestic Wastewater Treatment Plant Monthly Operating Report

Month July Year 1997

(34)

Day of the Month	Flow (mgd)	Chlorine Residual after Contact	Chlorine Residual after Dechlorination	CBOD ₅ Influent (mg/L)	TSS Influent (mg/L)	CBOD ₅ Effluent (mg/L)	TSS Effluent (mg/L)	pH Effluent	TKN Effluent (mg/L)	NH ₃ - N Effluent (mg/L)	Nitrate Effluent (mg/L)	Total P Effluent (mg/L)	Fecal Coliform (#/100ml)	Filterine CBOD	Filterine TSS	Filterine Furan
1	380	1.6		220	150	11	2.1	7.1								
2	380	1.4						7.2					1.0			
3	330	1.2						7.0								
4	390	1.3						7.2								
5	380	1.6						7.2								
6	410	2.1						7.3								
7	400	1.7						7.0								
8	380	1.4		170	310	5.9	<1	7.1					6.5	<1		
9	400	1.6						7.2					<1			<1
10	390	1.4						7.2								
11	320	1.4						7.2								
12	370	1.4						7.1								
13	400	1.1						7.0								
14	380	1.3						7.2								
15	380	1.7		170	260	7.5	1.3	7.1					6.7	2.2		
16	340	1.0						7.2					2.0			4.0
17	430	0.8						7.4								
18	350	1.2						7.2								
19	380	0.7						7.2								
20	560	0.6						7.1								
21	550	0.9						7.2								
22	470	1.6		140	240	6.6	1.1	7.0					6.7	1.4		
23	420	1.1						7.1					<1			1
24	460	0.8						7.0								
25	470	0.7						7.1								
26	470	0.9						7.0								
27	470	1.3						7.1								
28	420	0.9						7.2								
29	390	1.3		170	140	6.2	1.8	7.0					4.1	1.9		
30	400	1.4						6.8					<1			<1
31	430	0.8						6.9								

Lead Operator: This is to certify that I am familiar with the information contained in this report and that to the best of my knowledge and belief, the information is true, complete, and accurate.

Signed: 

Date: 8-15-97

Name (Please Type) DEAN S. SMILEY, JR.

Company Name INDIANTOWN COMPANY, INC.

Telephone No (Please Type) (561) 577-2121

Domestic Wastewater Treatment Plant Monthly Operating Report

Part II - General Information

- (1) Month August Year 1997
- (2) Plant's DER Identification Number 5143P03291
- (3) Plant Name INDIAN TOWN WASTEWATER TREATMENT PLANT
- (4) Plant Address P.O. Box 397, 168th Ave
Brook Park
- (5) City Indian Town
- (6) County Martin
- (7) Phone Number (561) 597-2121
- (8) Permit Number DO 43-091836
- (9) Plant Type 2-C
- (10) Test Site Identification Number 0002
- (11) Fecal Coliform Sample Method
 Membrane Filter Most Probable Number
- (12) Type of Effluent Disposal or Reclaimed Water Reuse
Evap / Pump Pond / Irrigation
- (13) Limited Wet Weather Discharge Activated
 Yes No Not Applicable
- (14) Cumulative Days of Wet Weather Discharge None
- (15) Plant Staffing
- Day Shift Operator Class _____ Cert. No. _____
- Evening Shift Operator Class _____ Cert. No. _____
- Night Shift Operator Class _____ Cert. No. _____
- Lead Operator [Signature] B-6805
 Signature _____ Cert. No. _____

Parameter	Units	STORET Code	Value
(16) Monthly average daily flow	mgd	050053	.497
(17) Permitted capacity	mgd	-	1,500
(18) Three-month average daily flow	mgd	-	1,433
(19) Percent of permitted capacity	%	-	87%
(20) CBOD ₅ Effluent	mg/L	080082	3.4
(21) CBOD ₅ Effluent	lbs/day	-	N/A
(22) TSS Effluent	mg/L	900201	1.7
(23) TSS Effluent	lbs/day	-	N/A
(24) Minimum pH		-	6.7
(25) Maximum pH		-	7.3
(26) Total N	mg/L	000600	N/A
(27) TKN	mg/L	000625	N/A
(28) Ammonia (NH ₃ · N)	mg/L	000610	N/A
(29) Nitrate	mg/L	071850	N/A
(30) Total Phosphorus	mg/L	000665	N/A
(31) Minimum Chlorine Residual	mg/L	-	0.5
(32) Maximum Chlorine Residual	mg/L	-	1.7
(33) Other Effluent Parameters			*
* Gallons of Sludge Wasted to Digester			
200,164 Gallons			

Domestic Wastewater Treatment Plant Monthly Operating Report

(34)

Month AUGUST Year 1997

Day of the Month	Flow (mgd)	Chlorine Residual after Contact	Chlorine Residual after Dechlorination	CBOD ₅ Influent (mg/L)	TSS Influent (mg/L)	CBOD ₅ Effluent (mg/L)	TSS Effluent (mg/L)	pH Effluent	TKN Effluent (mg/L)	NH ₃ - N Effluent (mg/L)	Nitrate Effluent (mg/L)	Total P Effluent (mg/L)	Fecal Coliform (#/100ml)	Filterine CBOD	Filterine TSS	Filterine Fische
1	.370	1.4						7.0								
2	.530	1.3						7.1								
3	.530	1.0						7.3								
4	.490	1.3						7.0								
5	.480	1.1		150	93	3.9	2.1	6.9						3.3	2.9	
6	.470	1.7						7.0					<1			<1
7	.440	1.2						7.1								
8	.410	1.6						6.9								
9	.510	1.4						7.0								
10	.480	1.2						7.0								
11	.450	1.0						7.1								
12	.520	0.8		130	250	3.4	1.2	6.9						3.5	1.2	
13	.450	1.1						6.9					-1			-1
14	.470	1.5						7.0								
15	.560	0.8						6.9								
16	.550	0.5						7.0								
17	.570	0.7						6.9								
18	.550	0.6						6.7								
19	.480	0.8		170	130	3.1	1.4	6.8								
20	.510	1.2						6.9					<1			
21	.530	1.0						7.1								
22	.520	0.8						7.0								
23	.560	0.6						7.0								
24	.520	0.6						7.0								
25	.570	0.8						6.9								
26	.520	0.7		140	86	3.3	1.9	7.2						3.7	1.7	
27	.560	0.9						7.1					1.0			32
28	.430	1.1						7.0								
29	.430	1.2						7.2								
30	.470	1.0						7.0								
31	.470	1.0						7.1								

Lead Operator: This is to certify that I am familiar with the information contained in this report and that to the best of my knowledge and belief, this information is true, complete, and accurate.

Signed: _____

Date: 9-11-97

Name (Please Type) DEAN S. SMILEY, JR.

Company Name INDIAN TOWN COMPANY, INC.

Telephone No (Please Type) (561) 577-2121


Domestic Wastewater Treatment Plant Monthly Operating Report

(34)

Month SEPTEMBER Year 1997

Day of the Month	Flow (mgd)	Chlorine Residual after Contact	Chlorine Residual after Dechlorination	CBOD ₅ Influent (mg/L)	TSS Influent (mg/L)	CBOD ₅ Effluent (mg/L)	TSS Effluent (mg/L)	pH Effluent	TKN Effluent (mg/L)	NH ₃ - N Effluent (mg/L)	Nitrate Effluent (mg/L)	Total P Effluent (mg/L)	Fecal Coliform (#/100ml)	FILTRATE CBOD	FILTRATE TSS	FILTRATE FURTHER
1	.460	0.9						7.1								
2	.460	1.2		180	160	4.1	1.3	7.0								
3	.440	1.1						7.0					< 1			
4	.530	1.5						7.1								
5	.560	1.1						7.0								
6	.540	0.9						7.0								
7	.500	1.3						7.1								
8	.500	1.0						7.2								
9	.380	0.6		210	180	3.8	2.2	7.2					< 2	1.9		
10	.450	1.4						7.0					< 1		< 1	
11	.440	1.0						7.2								
12	.420	1.6						7.0								
13	.490	2.1						7.0								
14	.600	1.0						7.0								
15	.540	0.7						7.2								
16	.560	0.7		110	180	4.2	< 1	6.9								
17	.520	0.9						7.1					< 1			
18	.460	1.0						7.0								
19	.480	0.8						7.2								
20	.510	0.7						7.0								
21	.470	0.6						7.1								
22	.490	0.9						7.1								
23	.540	0.8		250	120	3.2	2.0	7.1					2.7	1.7		
24	.440	1.0						7.2					9		10	
25	.430	0.7						7.0								
26	.400	1.5						7.1								
27	.560	1.0						7.2								
28	.610	1.1						7.0								
29	.550	0.8						7.1								
30	.460	1.3		150	150	6.8	< 1	7.0					4.9	1.6		
31																

Lead Operator: This is to certify that I am familiar with the information contained in this report and that to the best of my knowledge and belief, this information is true, complete and accurate.

Signed: 

Date: 10-13-97

Name (Please Type) DEW S. SMILEY, JR.

Company Name INDIANTOWN COMPANY, INC.

Telephone No. (Please Type) (561) 577-2121

Domestic Wastewater Treatment Plant Monthly Operating Report

Part II - General Information

- (1) Month OCTOBER Year 1997
- (2) Plant's DER Identification Number 5143F03291
- (3) Plant Name INDIANWOOD WASTEWATER TREATMENT PLANT
- (4) Plant Address P.O. BOX 397, 168th AVE
ROCKHURST PARK
- (5) City INDIANTOWN
- (6) County MARTIN
- (7) Phone Number (561) 597-3496
- (8) Permit Number D.P. # 071236
- (9) Plant Type 2-C
- (10) Test Site Identification Number 20002
- (11) Fecal Coliform Sample Method
 Membrane Filter Most Probable Number
- (12) Type of Effluent Disposal or Reclaimed Water Reuse
EVAP. / PAVED PLOTS / IRRIGATION
- (13) Limited Wet Weather Discharge Activated
 Yes No Not Applicable
- (14) Cumulative Days of Wet Weather Discharge None
- (15) Plant Staffing
- Day Shift Operator Class _____ Cert. No. _____
- Evening Shift Operator Class _____ Cert. No. _____
- Night Shift Operator Class _____ Cert. No. _____
- Lead Operator A. [Signature] B-6815
 Signature Cert. No.

Parameter	Units	STORET Code	Value
(16) Monthly average daily flow	mgd	050053	422
(17) Permitted capacity	mgd	-	1500
(18) Three-month average daily flow	mgd	-	471
(19) Percent of permitted capacity	%	-	94%
(20) CBOD ₅ Effluent	mg/L	080082	3.8
(21) CBOD ₅ Effluent	lbs/day	-	N/A
(22) TSS Effluent	mg/L	900201	2.0
(23) TSS Effluent	lbs/day	-	N/A
(24) Minimum pH		-	6.9
(25) Maximum pH		-	7.2
(26) Total N	mg/L	000600	N/A
(27) TKN	mg/L	000625	N/A
(28) Ammonia (NH ₃ · N)	mg/L	000610	N/A
(29) Nitrate	mg/L	071850	N/A
(30) Total Phosphorus	mg/L	000665	N/A
(31) Minimum Chlorine Residual	mg/L	-	0.8
(32) Maximum Chlorine Residual	mg/L	-	1.7
(33) Other Effluent Parameters			*
* GALLONS OF SLUDGE WASTED TO DIGESTER			
200,164 GALLONS			


Domestic Wastewater Treatment Plant Monthly Operating Report

Month October Year 1997

(34)

Day of the Month	Flow (mgd)	Chlorine Residual after Contact	Chlorine Residual after Dechlorination	CBOD ₅ Influent (mg/L)	TSS Influent (mg/L)	CBOD ₅ Effluent (mg/L)	TSS Effluent (mg/L)	pH Effluent	TKN Effluent (mg/L)	NH ₃ - N Effluent (mg/L)	Nitrate Effluent (mg/L)	Total P Effluent (mg/L)	Fecal Coliform (#/100ml)	Filtrate CBOD	Filtrate TSS	Filtrate Fluoride
1	.490	1.5						6.9					1.0			130
2	.490	1.2						7.0								
3	.410	1.7						7.0								
4	.480	1.6						7.1								
5	.510	1.2						7.1								
6	.440	1.5						7.0								
7	.430	1.2		240	32	2.7	1.4	7.1						3.0	<1	
8	.440	1.6						7.0					<1			18
9	.420	1.2						7.2								
10	.410	0.8						7.0								
11	.410	1.3						7.0								
12	.410	1.5						7.2								
13	.420	1.2						7.0								
14	.430	1.5		190	120	3.9	1.4	7.1								
15	.390	1.6						6.9					5.0			
16	.400	1.3						7.1								
17	.340	1.0						7.0								
18	.420	1.0						7.2								
19	.400	1.4						7.0								
20	.410	0.9						7.1								
21	.420	0.9		210	120	4.2	2.7	7.0								
22	.390	1.0						7.0					2.0			
23	.400	1.3						7.0								
24	.450	1.0						7.0								
25	.440	1.0						7.1								
26	.340	1.6						7.0								
27	.510	1.2						7.2								
28	.310	1.4		250	220	4.2	2.5	7.2						7.3	2.2	
29	.400	1.5						7.2					1.0			<1
30	.390	1.1						7.1								
31	.400	1.6						7.2								

Lead Operator: This is to certify that I am familiar with the information contained in this report and that to the best of my knowledge and belief, this information is true, complete, and accurate.

Signed: 
 Name (Please Type) DEAN S. SMILEY JR.
 Company Name TURKANTOWN COMPANY, INC.

Date: 11-17-97
 Telephone No (Please Type) (561) 597-2121

Domestic Wastewater Treatment Plant Monthly Operating Report

Part II - General Information

- (1) Month NOVEMBER Year 1997
- (2) Plant's DER Identification Number 5143P03291
- (3) Plant Name INDIANTOWN WASTEWATER TREATMENT PLANT
- (4) Plant Address P.O. BOX 397, 168TH AVENUE
BOOKER PARK
- (5) City INDIANTOWN
- (6) County MARTIN
- (7) Phone Number (561) 597-3496
- (8) Permit Number D.O. 43-091836
- (9) Plant Type 2-C
- (10) Test Site Identification Number 00002
- (11) Fecal Coliform Sample Method
 Membrane Filter Most Probable Number
- (12) Type of Effluent Disposal or Reclaimed Water Reuse
EVAP./PORC. PONDS / IRRIGATION
- (13) Limited Wet Weather Discharge Activated
 Yes No Not Applicable
- (14) Cumulative Days of Wet Weather Discharge NONE
- (15) Plant Staffing
- Day Shift Operator Class _____ Cert. No. _____
- Evening Shift Operator Class _____ Cert. No. _____
- Night Shift Operator Class _____ Cert. No. _____
- Lead Operator [Signature] Cert. No. 11805

Parameter	Units	STORET Code	Value
(16) Monthly average daily flow	mgd	050053	400
(17) Permitted capacity	mgd	-	500
(18) Three-month average daily flow	mgd	-	438
(19) Percent of permitted capacity	%	-	88%
(20) CO_2 Effluent	mg/L	080082	4.4
(21) $CBOD_5$ Effluent	lbs/day	-	N/A
(22) TSS Effluent	mg/L	900201	3
(23) TSS Effluent	lbs/day	-	N/A
(24) Minimum pH		-	6.8
(25) Maximum pH		-	7.4
(26) Total N	mg/L	000600	N/A
(27) TKN	mg/L	000625	N/A
(28) Ammonia ($NH_3 - N$)	mg/L	000610	N/A
(29) Nitrate	mg/L	071850	N/A
(30) Total Phosphorus	mg/L	000665	N/A
(31) Minimum Chlorine Residual	mg/L	-	0.6
(32) Maximum Chlorine Residual	mg/L	-	2.2
(33) Other Effluent Parameters			*
* GALLONS OF SLUDGE WASTED TO DIGESTER			
109,292 GALLONS			


Domestic Wastewater Treatment Plant Monthly Operating Report

Month NOVEMBER Year 1992

(34)

Day of the Month	Flow (mgd)	Chlorine Residual after Contact	Chlorine Residual after Dechlorination	CBOD ₅ Influent (mg/L)	TSS Influent (mg/L)	CBOD ₅ Effluent (mg/L)	TSS Effluent (mg/L)	pH Effluent	TKN Effluent (mg/L)	NH ₃ - N Effluent (mg/L)	Nitrate Effluent (mg/L)	Total P Effluent (mg/L)	Fecal Coliform (#/100ml)	Filterable COD	Filterable TSS	Filterable Fiber
1	420	1.6						7.1								
2	420	1.2						7.0								
3	430	1.0						7.2								
4	390	0.6		190	130	7.5	1.7	7.3						6.9	11.4	
5	420	1.3						7.2					10			13
6	420	1.0						7.2								
7	560	1.4						7.1								
8	420	1.0						7.0								
9	410	0.9						6.8								
10	380	1.2						7.2								
11	400	1.3						6.8								
12	380	1.2		400	140	3.1	2.3	7.2						2.5	4.1	
13	380	1.4						7.2					9			<1
14	450	0.8						7.1								
15	410	0.7						7.2								
16	380	0.9						7.5								
17	420	0.9						7.3								
18	350	0.8		260	130	2.8	2.2	7.2						2.1	2.3	
19	400	1.1						7.4					<1			<1
20	320	0.7						7.2								
21	390	0.7						7.2								
22	370	1.0						7.1								
23	350	0.9						7.2								
24	420	1.4						7.1								
25	340	1.5		260	160	4.3	3.6	7.0						8.3	3.1	
26	430	1.3						7.0					<1			<1
27	420	1.4						7.1								
28	390	2.2						7.1								
29	420	2.0						7.2								
30	460	1.7						7.3								
31																

Lead Operator: This is to certify that I am familiar with the information contained in this report and that to the best of my knowledge and belief, this information is true, complete and accurate.

Signed: 

Date: 12-15-97

Name (Please Type) DEAN S. SMILEY, JR.

Company Name JULIANTOWN COMPANY, INC.

Telephone No. (Please Type) (561) 597-2121


Domestic Wastewater Treatment Plant Monthly Operating Report

(34)

Month DECEMBER Year 1997

Day of the Month	Flow (mgd)	Chlorine Residual after Contact	Chlorine Residual after Dechlorination	CBOD ₅ Influent (mg/L)	TSS Influent (mg/L)	CBOD ₅ Effluent (mg/L)	TSS Effluent (mg/L)	pH Effluent	TKN Effluent (mg/L)	NH ₃ - N Effluent (mg/L)	Nitrate Effluent (mg/L)	Total P Effluent (mg/L)	Fecal Coliform (#/100ml)	Filterable CBOD	Filterable TSS	Filterable Fecals
1	430	1.0						7.2								
2	380	1.3		250	140	3.7	2.2	7.0						3.2	1.2	
3	370	1.5						7.1					<1			<1
4	430	2.2						7.0								
5	390	1.7						7.1								
6	420	0.8						6.9								
7	450	0.6						7.2								
8	390	0.9						7.2								
9	390	2.1		380	250	3.5	<1	7.4						4.5	<1	
10	410	1.7						7.3					<1			<1
11	370	1.4						7.3								
12	380	1.0						7.3								
13	440	1.5						7.3								
14	490	1.5						7.3								
15	500	1.1						7.3								
16	450	1.3		330	310	4.2	1.6	7.3						3.7	7.7	
17	370	1.6						7.3					<1			<1
18	440	1.2						7.3								
19	410	1.1						7.2								
20	460	1.0						7.1								
21	450	1.0						7.3								
22	470	1.0						7.3								
23	400	1.0		200	120	4.8	2.0	7.1						5.0	2.3	
24	410	1.0						6.9					<1			<1
25	450	1.0						7.6								
26	460	1.0						7.1								
27	480	1.0						7.0								
28	430	1.0						7.0								
29	430	1.3						7.1								
30	430	1.2		110	110	2.1	2.1	7.0						5.0	1.9	
31	450	1.0						7.2					7.0			5.2

Lead Operator: This is to certify that I am familiar with the information contained in this report and that to the best of my knowledge and belief, this information is true, complete, and accurate.

Signed: 

Date: 1-14-98

Name (Please Type) DEAN S. SMILEY, JR.

Company Name TUDANTOWN COMPANY, INC.

Telephone No (Please Type) (561) 577-2121

Domestic Wastewater Treatment Plant Monthly Operating Report

Part II - General Information

- (1) Month January Year 1998
- (2) Plant's DER Identification Number 5143P03291
- (3) Plant Name INDIAN-DOWN WASTEWATER TREATMENT PLANT
- (4) Plant Address P.O. BOX 297 165TH AVE
EAGLE PARK
- (5) City TULSA
- (6) County MARTIN
- (7) Phone Number 1-800-597-3496
- (8) Permit Number 20-23-191236
- (9) Plant Type 2-C
- (10) Test Site Identification Number 00002
- (11) Fecal Coliform Sample Method
 Membrane Filter Most Probable Number
- (12) Type of Effluent Disposal or Reclaimed Water Reuse
Flow / Flow / Flow / Flow / Flow / Flow / Flow / Flow / Flow / Flow
- (13) Limited Wet Weather Discharge Activated
 Yes No Not Applicable
- (14) Cumulative Days of Wet Weather Discharge None
- (15) Plant Staffing
- Day Shift Operator Class _____ Cert. No. _____
- Evening Shift Operator Class _____ Cert. No. _____
- Night Shift Operator Class _____ Cert. No. _____
- Lead Operator N.J. [Signature] R. G. [Signature]
 Signature Cert. No.

Parameter	Units	STORET Code	Value
(16) Monthly average daily flow	mgd	050053	445
(17) Permitted capacity	mgd	-	500
(18) Three-month average daily flow	mgd	-	425
(19) Percent of permitted capacity	%	-	85%
(20) CBOD ₅ Effluent	mg/L	080082	7.7
(21) CBOD ₅ Effluent	lbs/day	-	N/A
(22) TSS Effluent	mg/L	900201	2.4
(23) TSS Effluent	lbs/day	-	N/A
(24) Minimum pH		-	6.9
(25) Maximum pH		-	7.5
(26) Total N	mg/L	000600	N/A
(27) TKN	mg/L	000625	N/A
(28) Ammonia (NH ₃ · N)	mg/L	000610	N/A
(29) Nitrate	mg/L	071850	N/A
(30) Total Phosphorus	mg/L	000655	N/A
(31) Minimum Chlorine Residual	mg/L	-	0.8
(32) Maximum Chlorine Residual	mg/L	-	1.8
(33) Other Effluent Parameters		*	
* CAUTION: [Signature]			
[Signature]			
198,936 [Signature]			

Domestic Wastewater Treatment Plant Monthly Operating Report


Date Reported On: _____
Page 2 of 2

Month December Year 1978

(3)

Day of the Month	Flow (mgd)	Chlorine Residual after Contact	Chlorine Residual after Dechlorination	CBOD ₅ Influent (mg/L)	TSS Influent (mg/L)	CBOD ₅ Effluent (mg/L)	TSS Effluent (mg/L)	pH Effluent	TKN Effluent (mg/L)	NH ₃ - N Effluent (mg/L)	Nitrate Effluent (mg/L)	Total P Effluent (mg/L)	Fecal Coliform (#/100ml)	Filtering CBOD	Filtering TSS	Filtering Fines
1	440	1.8						7.0								
2	440	1.4						7.3								
3	440	1.4						7.2								
4	470	1.3						7.4								
5	440	1.0						7.5								
6	500	1.5		310	200	5.6	1.5	7.2					5.9	1.0		
7	470	1.2						7.3				1.0			< 1	
8	470	1.0						7.2								
9	460	1.1						7.0								
10	460	1.4						7.1								
11	470	1.2						7.0								
12	440	1.2						7.2								
13	470	1.6		260	170	8.3	1.7	7.2					6.5	1.5		
14	470	1.2						7.0				< 1			< 1	
15	470	1.5						7.1								
16	470	1.5						7.1								
17	480	1.2						7.1								
18	450	1.4						7.2								
19	450	1.1						7.1								
20	470	1.3		190	120	9.8	2.7	7.2					1.2	2.3		
21	440	1.5						7.1				2.0			4.0	
22	510	1.7						7.1								
23	420	1.3						7.0								
24	450	1.0						7.0								
25	450	1.0						6.9								
26	430	1.4						7.1								
27	450	1.1		200	190	7.1	3.5	7.0					5.0	2.4		
28	440	1.5						7.3				< 1				11
29	470	1.2						7.2								
30	460	1.0						7.0								
31	460	1.0						7.0								

Lead Operator: This is to certify that I am familiar with the information contained in this report and that to the best of my knowledge and belief, this information is true, complete and accurate.

Signed: 

Date: 12-17-78

Name (Please Type) DEAN S. SMILEY, JR.

Company Name TUPLANTOWN COMPANY, INC.

Telephone No (Please Type) (561) 597-2121


Domestic Wastewater Treatment Plant Monthly Operating Report

Month FEBRUARY Year 1998

(34)

Day of the Month	Flow (mgd)	Chlorine Residual after Contact	Chlorine Residual after Dechlorination	CBOD ₅ Influent (mg/L)	TSS Influent (mg/L)	CBOD ₅ Effluent (mg/L)	TSS Effluent (mg/L)	pH Effluent	TKN Effluent (mg/L)	NH ₃ - N Effluent (mg/L)	Nitrate Effluent (mg/L)	Total P Effluent (mg/L)	Fecal Coliform (#/100mg)	Filterable COD	Filterable TSS	Filterable Fluoride
1	.480	1.1						7.0								
2	.490	1.3						7.1								
3	.470	1.1		200	120	6.4	2.8	7.2						5.6	2.3	
4	.490	1.4						7.1					41			1.0
5	.440	1.0						7.3								
6	.510	1.5						7.2								
7	.520	1.1						7.2								
8	.510	1.4						7.4								
9	.460	1.5						7.1								
10	.490	1.6		160	100	3.6	2.6	7.1						5.0	2.3	
11	.470	1.2						7.1					41			41
12	.440	1.1						7.2								
13	.340	1.5						7.0								
14	.390	1.5						7.0								
15	.510	1.0						7.1								
16	.650	1.0						7.0								
17	.690	0.8		120	200	17	4.6	7.1						13	4.9	
18	.620	1.1						7.0					41			2
19	.650	0.8						7.0								
20	.690	0.7						7.1								
21	.650	0.6						7.1								
22	.640	0.7						7.0								
23	.630	0.9						7.1								
24	.560	1.2		200	120	6.2	3.8	7.3						6.0	2.9	
25	.520	1.5						7.1					41			41
26	.540	1.3						7.2								
27	.490	1.3						7.1								
28	.570	1.3						6.9								
29																
30																
31																

Lead Operator: This is to certify that I am familiar with the information contained in this report and that to the best of my knowledge and belief, this information is true, complete and accurate.

Signed: 

Date: 3-16-98

Name (Please Type) DEAN S. SMILEY, JR.

Company Name INDIANTOWN COMPANY, INC.

Telephone No (Please Type) (561) 597-2121


Domestic Wastewater Treatment Plant Monthly Operating Report

Month March Year 1998

(3)

Day of the Month	Flow (mgd)	Chlorine Residual after Contact	Chlorine Residual after Dechlorination	CBOD ₅ Influent (mg/L)	TSS Influent (mg/L)	CBOD ₅ Effluent (mg/L)	TSS Effluent (mg/L)	pH Effluent	TKN Effluent (mg/L)	NH ₃ - N Effluent (mg/L)	Nitrate Effluent (mg/L)	Total P Effluent (mg/L)	Fecal Coliform (#/100ml)	Filterine CBOD	Filterine TSS	Filterine Filter
1	1630	0.9						7.0								
2	1550	1.2						7.1								
3	1570	1.5		150	160	3.8	2.5	7.1						3.1	2.2	
4	1500	1.7						7.1					<1			<1
5	1400	1.4						7.0								
6	1570	1.6						7.1								
7	1510	1.2						7.1								
8	1530	1.5						6.9								
9	1610	1.0						7.1								
10	1530	1.0		190	120	4.1	6.0	7.1					4.0	5.8		
11	1530	1.2						7.1					1.0			<1
12	1400	1.5						7.2								
13	1440	1.7						7.3								
14	1520	1.3						7.2								
15	1540	1.5						7.2								
16	1450	1.2						7.2								
17	1550	1.0		1100	190	4.1	7.5	7.2					3.2	7.1		
18	1490	1.3						7.0					<1			<1
19	1630	1.0						7.2								
20	1670	1.1						7.0								
21	1630	1.2						7.1								
22	1550	1.0						7.0								
23	1580	0.8						7.2								
24	1550	1.0		190	120	7.4	3.0	7.0					5.2	7.4		
25	1510	1.3						7.3					<1			<1
26	1510	0.6						7.3								
27	1420	1.1						7.0								
28	1510	1.2						7.1								
29	1520	1.3						7.2								
30	1490	1.1						7.1								
31	1440	1.5		220	170	6.1	4.9	7.0					7.1	4.1		

Lead Operator: This is to certify that I am familiar with the information contained in this report and that to the best of my knowledge and belief, this information is true, complete and accurate.

Signed: 

Date: 4-14-98

Name (Please Type) DEAN S. SMILEY, JR.

Company Name INDIANTOWN COMPANY, INC.

Telephone No (Please Type) (561) 597-2121

Domestic Wastewater Treatment Plant Monthly Operating Report

Part II - General Information

(1) Month APRIL Year 1998

(2) Plant's DER Identification Number 5143P03291

(3) Plant Name INDIAN TOWN WASTEWATER TREATMENT PLANT

(4) Plant Address P.O. BOX 397, 168TH AVE
 BOCKEE PARK

(5) City INDIAN TOWN

(6) County MARTIN

(7) Phone Number (561) 597-3496

(8) Permit Number D.O. 43-091836

(9) Plant Type Z-C

(10) Test Site Identification Number 00002

(11) Fecal Coliform Sample Method
 Membrane Filter Most Probable Number

(12) Type of Effluent Disposal or Reclaimed Water Reuse
EVAP./ PERC. PUNDS./ IRRIGATION

(13) Limited Wet Weather Discharge Activated
 Yes No Not Applicable

(14) Cumulative Days of Wet Weather Discharge NONE

(15) Plant Staffing

Day Shift Operator Class _____ Cert. No. _____

Evening Shift Operator Class _____ Cert. No. _____

Night Shift Operator Class _____ Cert. No. _____

Lead Operator [Signature] B-6265
 Signature Cert. No.

Parameter	Units	STORET Code	Value
(16) Monthly average daily flow	mgd	050053	413
(17) Permitted capacity	mgd	-	500
(18) Three-month average daily flow	mgd	-	491
(19) Percent of permitted capacity	%	-	98%
(20) CBOD ₅ Effluent	mg/L	080082	9
(21) CBOD ₅ Effluent	lbs/day	-	N/A
(22) TSS Effluent	mg/L	900201	5.8
(23) TSS Effluent	lbs/day	-	N/A
(24) Minimum pH		-	6.9
(25) Maximum pH		-	7.4
(26) Total N	mg/L	000600	N/A
(27) TKN	mg/L	000625	N/A
(28) Ammonia (NH ₃ · N)	mg/L	000610	N/A
(29) Nitrate	mg/L	071850	N/A
(30) Total Phosphorus	mg/L	000665	N/A
(31) Minimum Chlorine Residual	mg/L	-	0.8
(32) Maximum Chlorine Residual	mg/L	-	2.2
(33) Other Effluent Parameters		*	
* GALLONS OF SLUDGE WASTED TO DIGESTOR:			
162,096 GALLONS			

164

Domestic Wastewater Treatment Plant Monthly Operating Report

Date: APRIL 1998
 Page: 3 of 3

39

Month APRIL Year 1998

Day of the Month	Flow (mgd)	Chlorine Residual after Contact	Chlorine Residual after Dechlorination	CBOD ₅ Influent (mg/L)	TSS Influent (mg/L)	CBOD ₅ Effluent (mg/L)	TSS Effluent (mg/L)	pH Effluent	TKN Effluent (mg/L)	NH ₃ - N Effluent (mg/L)	Nitrate Effluent (mg/L)	Total P Effluent (mg/L)	Fecal Coliform (MPN/100ml)	Filterable COD	Filterable TSS	Filterable Fluoride
1	.500	1.2						7.0					2.0			1.0
2	.460	1.5						7.1								
3	.490	1.2						7.0								
4	.470	1.4						7.1								
5	.430	1.2						7.0								
6	.360	1.0		270	170	3.7	3.4	6.9						3.0	3.4	
7	.450	1.4						7.3					1.0			<1.0
8	.430	1.1						7.1								
9	.410	1.5						7.3								
10	.420	1.5						7.2								
11	.440	1.3						7.0								
12	.450	1.5						7.2								
13	.410	2.2		250	140	11	6.4	7.1						9.2	4.4	
14	.301	1.6						7.3					<1.0			<1.0
15	.410	1.2						7.2								
16	.350	1.5						7.4								
17	.320	1.1						7.2								
18	.430	1.0						7.0								
19	.420	0.9						7.0								
20	.370	1.5		240	190	14	6.7	7.3						9.9	5.8	
21	.390	1.5						7.1					<1.0			<1.0
22	.420	1.0						7.3								
23	.380	0.8						7.0								
24	.360	1.1						7.1								
25	.390	1.6						7.0								
26	.430	1.2						7.2								
27	.340	1.7		260	150	7.5	6.5	7.1						8.1	7.7	
28	.420	1.5						7.1					<1			1.0
29	.310	1.0						7.3								
30	.450	1.6						7.2								

I, the Operator, This is to certify that I am familiar with the information contained in this report and that to the best of my knowledge and belief, this information is true, complete and accurate.

Signature: [Handwritten Signature]

Date: 5-14-98

Name: DEW S. SMILEY, JR.

Company Name: LUDLOW TOWN COMPANY, INC.

Telephone No (Please Type): (561) 577-2121

Domestic Wastewater Treatment Plant Monthly Operating Report

Part II - General Information

(1) Month May Year 1998
 (2) Plant's DER Identification Number 5143P03291
 (3) Plant Name INDIAN TOWN WASTEWATER TREATMENT PLANT
 (4) Plant Address RD. Box 397, 168th Ave
ROCKHUR PARK
 (5) City INDIAN TOWN
 (6) County MARTIN
 (7) Phone Number (561) 597-3496
 (8) Permit Number DD. 43-091836
 (9) Plant Type 2-C
 (10) Test Site Identification Number 00002
 (11) Fecal Coliform Sample Method
 Membrane Filter Most Probable Number
 (12) Type of Effluent Disposal or Reclaimed Water Reuse
Evap. / Perc. Ponds / Irrigation
 (13) Limited Wet Weather Discharge Activated
 Yes No Not Applicable
 (14) Cumulative Days of Wet Weather Discharge None
 (15) Plant Staffing
 Day Shift Operator Class _____ Cert. No. _____
 Evening Shift Operator Class _____ Cert. No. _____
 Night Shift Operator Class _____ Cert. No. _____
 Lead Operator [Signature] R-6805
 Signature Cert. No.


Parameter	Units	STORET Code	Value
(16) Monthly average daily flow	mgd	050053	1,375
(17) Permitted capacity	mgd	-	1,500
(18) Three-month average daily flow	mgd	-	.439
(19) Percent of permitted capacity	%	-	88%
(20) CBOD ₅ Effluent	mg/L	080082	9
(21) CBOD ₅ Effluent	lbs/day	-	N/A
(22) TSS Effluent	mg/L	900201	4
(23) TSS Effluent	lbs/day	-	N/A
(24) Minimum pH		-	6.9
(25) Maximum pH		-	7.3
(26) Total N	mg/L	000600	N/A
(27) TKN	mg/L	000625	N/A
(28) Ammonia (NH ₃ - N)	mg/L	000610	N/A
(29) Nitrate	mg/L	071850	N/A
(30) Total Phosphorus	mg/L	000665	N/A
(31) Minimum Chlorine Residual	mg/L	-	0.9
(32) Maximum Chlorine Residual	mg/L	-	1.8
(33) Other Effluent Parameters			*
* GALLONS OF			
SLUDGE WASTED			
TO SLURRY:			
305,772 GALLONS			

Domestic Wastewater Treatment Plant Monthly Operating Report

Month May Year 1998

Day of the Month	Flow (mgd)	Chlorine Residual after Contact	Chlorine Residual after Dechlorination	CBOD ₅ Influent (mg/L)	TSS Influent (mg/L)	CBOD ₅ Effluent (mg/L)	TSS Effluent (mg/L)	pH Effluent	TKN Effluent (mg/L)	NH ₃ - N Effluent (mg/L)	Nitrate Effluent (mg/L)	Total P Effluent (mg/L)	Fecal Coliform (#/100ml)	Future CBOD	Future TSS	Future Fishes
1	400	1.1						6.9								
2	460	1.0						7.0								
3	460	1.6						6.9								
4	410	1.2		230	170	7.7	3.2	7.1					6.4	5.5		
5	400	1.3						7.1				<1			<1	
6	400	1.6						7.2								
7	360	1.1						7.1								
8	350	1.4						7.3								
9	400	0.9						7.2								
10	390	1.0						7.0								
11	380	1.5		260	240	11	5.2	7.0					7.5	3.2		
12	390	1.5						7.0				<1			<10	
13	370	1.1						7.2								
14	360	1.4						7.3								
15	310	1.6						7.1								
16	360	1.2						7.3								
17	370	1.5						7.0								
18	370	1.6		250	180	7.3	3.2	7.2								
19	340	1.2						7.0				<1				
20	390	1.5						7.2								
21	320	1.7						7.0								
22	350	1.8						7.1								
23	370	1.7						7.0								
24	370	1.5						7.2								
25	410	1.2						7.1								
26	370	1.6		260	220	11	4.1	7.0								
27	340	1.4						7.0				<1				
28	320	1.1						7.1								
29	340	1.5						7.2								
30	360	1.2						7.0								
31	410	1.0						7.1								

Lead Operator: This is to certify that I am familiar with the information contained in this report and that to the best of my knowledge and belief, this information is true, complete and accurate.

Signed: 

Date: 6-16-98

Name (Please Type) DEAN S. SMILEY, JR.

Company Name TULANTOWN COMPANY, INC.

Telephone No (Please Type) (561) 577-2121

Domestic Wastewater Treatment Plant Monthly Operating Report

Month JUNE Year 1998

Day of the Month	Flow (mgd)	Chlorine Residual after Contact	Chlorine Residual after Dechlorination	COD ₅ Influent (mg/L)	TSS Influent (mg/L)	COD ₅ Effluent (mg/L)	TSS Effluent (mg/L)	pH Effluent	TKN Effluent (mg/L)	NH ₃ - N Effluent (mg/L)	Nitrate Effluent (mg/L)	Total P Effluent (mg/L)	Fecal Coliform (#/100ml)	Effluent COD	Effluent TSS	Effluent Fluoride
1	380		0.9	260	120	6.8	3.6	6.9								
2	360		1.4					7.0					<1			
3	300		1.1					7.0								
4	320		1.1					7.1								
5	360		1.5					7.2								
6	380		1.0					7.0								
7	360		1.0					7.0								
8	350		1.3	330	180	6.6	3.2	6.9								
9	340		1.5					7.1					<1			
10	320		1.1					7.2								
11	330		1.6					7.0								
12	320		1.3					7.2								
13	370		1.2					7.1								
14	400		1.3					7.2								
15	350		1.6	280	180	7.4	2.2	7.3								
16	360		1.2					7.2					<1			
17	360		1.5					7.1								
18	380		1.5					7.3								
19	300		1.1					7.3								
20	340		1.0					7.1								
21	410		1.0					7.2								
22	370		1.3	210	170	8.7	3.5	7.0								
23	360		1.5					7.1					<1			
24	440		1.5					6.9								
25	350		1.5					7.4								
26	430		1.2					6.9								
27	490		1.3					7.1								
28	410		1.5					7.0								
29	420		1.1	270	120	12	2.4	7.1								
30	350		1.0					7.2					<1			
31																

Lead Operator: This is to certify that I am familiar with the information contained in this report and that to the best of my knowledge and belief, this information is true, complete and accurate.

Signed: 

Date: 7-14-98

Name (Please Type) DEAN S. SMILEY JR.

Company Name INDIANTOWN COMPANY, INC.

Telephone No (Please Type) (561) 577-2121


Domestic Wastewater Treatment Plant Monthly Operating Report

Part II - General Information

- (1) Month July Year 1998
- (2) Plant's DER Identification Number 5143P03291
- (3) Plant Name INDIAN TOWN WASTEWATER TREATMENT PLANT
- (4) Plant Address P.O. BOX 397, 168TH AVE. ROCKY PARK
- (5) City INDIAN TOWN
- (6) County MARTIN
- (7) Phone Number (561) 597-3496
- (8) Permit Number D.O. #3-091836
- (9) Plant Type 2-C
- (10) Test Site Identification Number 00002
- (11) Fecal Coliform Sample Method
 Membrane Filter Most Probable Number
- (12) Type of Effluent Disposal or Reclaimed Water Reuse
EVAP / PERC. PONDS / IRRIGATION
- (13) Limited Wet Weather Discharge Activated
 Yes No Not Applicable
- (14) Cumulative Days of Wet Weather Discharge NONE
- (15) Plant Staffing
- Day Shift Operator Class _____ Cert. No. _____
- Evening Shift Operator Class _____ Cert. No. _____
- Night Shift Operator Class _____ Cert. No. _____
- Lead Operator [Signature] R-1305
 Signature Cert. No.

Parameter	Units	STORET Code	Value
(16) Monthly average daily flow	mgd	050053	382
(17) Permitted capacity	mgd	-	500
(18) Three-month average daily flow	mgd	-	375
(19) Percent of permitted capacity	%	-	75%
(20) CaCO_3 Effluent	mg/L	060082	9
(21) CBOD_5 Effluent	lbs/day	-	N/A
(22) TSS Effluent	mg/L	900201	2
(23) TSS Effluent	lbs/day	-	N/A
(24) Minimum pH		-	6.9
(25) Maximum pH		-	7.5
(26) Total N	mg/L	000600	N/A
(27) TKN	mg/L	000625	N/A
(28) Ammonia ($\text{NH}_3 \cdot \text{N}$)	mg/L	000610	N/A
(29) Nitrate	mg/L	071850	N/A
(30) Total Phosphorus	mg/L	000665	N/A
(31) Minimum Chlorine Residual	mg/L	-	0.7
(32) Maximum Chlorine Residual	mg/L	-	1.7
(33) Other Effluent Parameters			*
* GALLONS OF SLUDGE WASTED TO DREDGING; 247,020 GALLONS			

Domestic Wastewater Treatment Plant Monthly Operating Report



Month July Year 1998

(3)

Day of the Month	Flow (mgd)	Chlorine Residual after Contact	Chlorine Residual after Dechlorination	CBOD ₅ Influent (mg/L)	TSS Influent (mg/L)	CBOD ₅ Effluent (mg/L)	TSS Effluent (mg/L)	pH Effluent	TKN Effluent (mg/L)	NH ₃ - N Effluent (mg/L)	Nitrite Effluent (mg/L)	Total P Effluent (mg/L)	Fecal Coliform (#/100ml)	Filtering CBOD	Filtering TSS	Filtering Furan
1	340	1.6						7.5								
2	330	1.0						7.3								
3	380	1.0						7.0								
4	380	0.9						7.2								
5	380	1.0						7.2								
6	410	1.4		290	140	5.4	1.9	7.3								
7	390	1.2						7.3					<1			
8	380	1.6						7.1								
9	360	0.9						7.3								
10	310	1.0						7.4								
11	380	1.3						7.5								
12	390	1.2						7.5								
13	410	1.6		270	160	3.9	1.7	7.3								
14	540	0.9						7.2					<1			
15	430	1.0						7.0								
16	470	0.8						6.9								
17	400	1.1						7.2								
18	430	0.9						7.0								
19	420	0.8						7.1								
20	380	1.2		270	88	6.8	2.0	7.3								
21	350	0.7						7.3					<1			
22	390	1.0						7.4								
23	390	1.3						7.1								
24	320	0.9						7.2								
25	380	1.3						7.2								
26	360	1.0						7.5								
27	390	1.2		170	110	18	2.1	7.3								
28	350	1.4						7.3					1.0			
29	340	1.7						7.2								
30	310	1.1						7.0								
31	360	0.8						7.2								

Lead Operator: This is to certify that I am familiar with the information contained in this report and that to the best of my knowledge and belief, this information is true, complete, and accurate.

Signed:

Date: 8-14-98

Name (Please Type) DEAN S. SMILEY, JR.

Company Name INDIANTOWN COMPANY, INC.

Telephone No (Please Type) (561) 597-2121

Domestic Wastewater Treatment Plant Monthly Operating Report

Part II - General Information

(1) Month AUGUST Year 1998

(2) Plant's DER Identification Number 5143 P03291

(3) Plant Name INDIAN TOWN WASTEWATER TREATMENT PLANT

(4) Plant Address P.O. Box 997, 149th Ave
 ROCKY PARK

(5) City INDIAN TOWN

(6) County NEEDHAM

(7) Phone Number (561) 597-3496

(8) Permit Number NO. 43-091836

(9) Plant Type 2-C

(10) Test Site Identification Number 00002

(11) Fecal Coliform Sample Method
 Membrane Filter Most Probable Number

(12) Type of Effluent Disposal or Reclaimed Water Reuse
EVAP./PERC. POND/IRRIGATION

(13) Limited Wet Weather Discharge Activated
 Yes No Not Applicable

(14) Cumulative Days of Wet Weather Discharge NONE

(15) Plant Staffing

Day Shift Operator Class _____ Cert. No. _____

Evening Shift Operator Class _____ Cert. No. _____

Night Shift Operator Class _____ Cert. No. _____

Lead Operator [Signature] B-6805
 Signature Cert. No.

Parameter	Units	STORET Code	Value
(16) Monthly average daily flow	mgd	050053	1,384
(17) Permitted capacity	mgd	-	1,500
(18) Three-month average daily flow	mgd	-	1,378
(19) Percent of permitted capacity	%	-	76%
(20) CBOD ₅ Effluent	mg/L	080082	7.6
(21) CBOD ₅ Effluent	lbs/day	-	N/A
(22) TSS Effluent	mg/L	900201	2.3
(23) TSS Effluent	lbs/day	-	N/A
(24) Minimum pH		-	6.9
(25) Maximum pH		-	7.5
(26) Total N	mg/L	000600	N/A
(27) TKN	mg/L	000625	N/A
(28) Ammonia (NH ₃ · N)	mg/L	000610	N/A
(29) Nitrate	mg/L	071850	N/A
(30) Total Phosphorus	mg/L	000665	N/A
(31) Minimum Chlorine Residual	mg/L	-	0.5
(32) Maximum Chlorine Residual	mg/L	-	2.0
(33) Other Effluent Parameters			*
* GALLONS OF			
SLUDGE WASTED TO			
DIGESTER:			
230,864 GALLONS:			

172

Domestic Wastewater Treatment Plant Monthly Operating Report

Month August Year 1998

33

Day of the Month	Flow (mgd)	Chlorine Residual after Contact	Chlorine Residual after Dechlorination	CBOD ₅ Influent (mg/L)	TSS Influent (mg/L)	CBOD ₅ Effluent (mg/L)	TSS Effluent (mg/L)	pH Effluent	TKN Effluent (mg/L)	NH ₃ - N Effluent (mg/L)	Nitrate Effluent (mg/L)	Total P Effluent (mg/L)	Fecal Coliform (#/100ml)	Filterable COD	Filterable TSS	Filterable Fiber
1	1,350	2.9						6.9								
2	1,370	1.0						7.2								
3	1,350	1.4		250	330	9.4	2.6	7.4								
4	1,320	1.6						7.3					1.0			
5	1,360	0.7						7.5								
6	1,400	1.0						7.4								
7	1,420	1.8						7.1								
8	1,450	1.4						7.3								
9	1,390	0.8						7.2								
10	1,470	1.2		200	140	5.5	3.3	7.4								
11	1,390	0.5						7.2					< 1			
12	1,400	0.9						7.1								
13	1,390	1.3						7.2								
14	1,320	1.0						7.3								
15	1,370	1.1						7.2								
16	1,390	1.0						7.2								
17	1,390	1.3		170	76	5.6	2.0	7.4								
18	1,390	1.5						7.3					< 1			
19	1,300	1.4						7.1								
20	1,370	1.1						7.5								
21	1,450	0.8						7.2								
22	1,440	1.0						7.2								
23	1,420	1.0						7.4								
24	1,460	1.2		170	100	12	1.8	7.2								
25	1,370	0.8						7.4					< 1			
26	1,380	1.4						7.3								
27	1,320	1.1						7.4								
28	1,370	1.5						7.0								
29	1,340	1.1						7.2								
30	1,410	0.9						7.0								
31	1,340	2.0		210	120	5.6	1.9	7.2								

Lead Operator: This is to certify that I am familiar with the information contained in this report and that to the best of my knowledge and belief, this information is true, complete and accurate.

Signed: 

Date: 8-14-98

Name (Please Type) DEN S. SMILEY, JR.

Company Name TUDANTOWN COMPANY, INC.

Telephone No. (Please Type) (561) 577-2121

Domestic Wastewater Treatment Plant Monthly Operating Report

Part II - General Information

- (1) Month SEPTEMBER Year 1998
- (2) Plant's DER Identification Number 5143 P03291
- (3) Plant Name INDIANTOWN WASTEWATER
 TREATMENT PLANT
- (4) Plant Address PO Box 397, 168th Ave
 ROCKY PARK
- (5) City INDIANTOWN
- (6) County HARTMAN
- (7) Phone Number (561) 597-3496
- (8) Permit Number 2.0 WS-001836
- (9) Plant Type ? - C
- (10) Test Site Identification Number 00002
- (11) Fecal Coliform Sample Method
 Membrane Filter Most Probable Number
- (12) Type of Effluent Disposal or Reclaimed Water Reuse _____
EVAP. / FLOW. FWD. / IRRIGATION
- (13) Limited Wet Weather Discharge Activated
 Yes No Not Applicable
- (14) Cumulative Days of Wet Weather Discharge NINE
- (15) Plant Staffing
- Day Shift Operator Class _____ Cert. No. _____
- Evening Shift Operator Class _____ Cert. No. _____
- Night Shift Operator Class _____ Cert. No. _____
- Lead Operator [Signature] B-6805
 Signature Cert. No.

Parameter	Units	STORET Code	Value
(16) Monthly average daily flow	mgd	050053	,473
(17) Permitted capacity	mgd	-	,500
(18) Three-month average daily flow	mgd	-	,413
(19) Percent of permitted capacity	%	-	83%
(20) CBOD ₅ Effluent	mg/L	060082	12.1
(21) CBOD ₅ Effluent	lbs/day	-	N/A
(22) TSS Effluent	mg/L	900201	2.4
(23) TSS Effluent	lbs/day	-	N/A
(24) Minimum pH		-	7.0
(25) Maximum pH		-	7.4
(26) Total N	mg/L	000600	N/A
(27) TKN	mg/L	000625	N/A
(28) Ammonia (NH ₃ · N)	mg/L	000610	N/A
(29) Nitrate	mg/L	071850	N/A
(30) Total Phosphorus	mg/L	000665	N/A
(31) Minimum Chlorine Residual	mg/L	-	0.5
(32) Maximum Chlorine Residual	mg/L	-	1.6
(33) Other Effluent Parameters			*
COLLOIDS OR SLUDGE			
WASTED TO DIGESTER			
* 288,580 MILLIGRAMS			

Domestic Wastewater Treatment Plant Monthly Operating Report

Month Sept. Year 1998

Day of the Month	Flow (mgd)	Chlorine Residual after Contact	Chlorine Residual after Dechlorination	CBOD ₅ Influent (mg/L)	TSS Influent (mg/L)	CBOD ₅ Effluent (mg/L)	TSS Effluent (mg/L)	pH Effluent	TKN Effluent (mg/L)	NH ₃ - N Effluent (mg/L)	Nitrate Effluent (mg/L)	Total P Effluent (mg/L)	Fecal Coliform (MPN/100ml)	Filterable COD	Filterable TSS	Filterable Furan
1	1,350	1.0						7.2					<1			
2	1,380	0.8						7.3								
3	1,390	1.3						7.4								
4	1,390	0.7						7.1								
5	1,400	1.6						7.4								
6	1,400	0.6						7.4								
7	1,450	1.0						7.2								
8	1,420	0.8		210	110	19	2.2	7.3								
9	1,380	1.2						7.2					<1			
10	1,420	0.9						7.3								
11	1,390	1.3						7.2								
12	1,450	0.8						7.2								
13	1,410	0.9						7.1								
14	1,400	0.7		180	150	13	2.5	7.3								
15	1,400	1.1						7.0								
16	1,470	1.1						7.3								
17	1,450	0.8						7.4								
18	1,530	1.4						7.3								
19	1,570	0.7						7.3								
20	1,520	0.9						7.2								
21	1,580	1.0		160	92	8.3	2.8	7.1								
22	1,560	1.2						7.1					<1			
23	1,440	0.9						7.3								
24	1,520	1.4						7.2								
25	1,660	0.8						7.3								
26	1,650	0.9						7.2								
27	1,630	0.5						7.0								
28	1,550	0.7		160	71	8.1	2.0	7.3								
29	1,520	1.4						7.2					TNTC			
30	1,510	0.8						7.1								
31																

I, 10-02-98 ROCHANE C Lead Operator, certify that I am familiar with the information contained in this report and that to the best of my knowledge and belief, this information is true, complete and accurate.

Signed: [Signature]
 Name (Please Type) DEAN S. SMITH, JR.
 Company Name TUDANTOWN COMPANY, INC.

Date: 10/12/98
 Telephone No (Please Type) (561) 577-2121

Domestic Wastewater Treatment Plant Monthly Operating Report

Part II - General Information

(1) Month OCTOBER Year 1998

(2) Plant's DER Identification Number 5143P03291

(3) Plant Name INDIAN TOWN WASTEWATER TREATMENT PLANT

(4) Plant Address P.O. BOX 397, 168TH AVE
ROCKER PARK

(5) City INDIAN TOWN

(6) County MARTIN

(7) Phone Number (561) 597-3496

(8) Permit Number D.O. 43-001-006

(9) Plant Type 2-C

(10) Test Site Identification Number 00002

(11) Fecal Coliform Sample Method
 Membrane Filter Most Probable Number

(12) Type of Effluent Disposal or Reclaimed Water Reuse
EVAP. PERC. PONDS / IRRIGATION

(13) Limited Wet Weather Discharge Activated
 Yes No Not Applicable

(14) Cumulative Days of Wet Weather Discharge NONE

(15) Plant Staffing

Day Shift Operator Class _____	Cert. No. _____
Evening Shift Operator Class _____	Cert. No. _____
Night Shift Operator Class _____	Cert. No. _____
Lead Operator <u>[Signature]</u>	Cert. No. <u>A-6805</u>


Parameter	Units	STORET Code	Value
(16) Monthly average daily flow	mgd	050053	426
(17) Permitted capacity	mgd	-	500
(18) Three-month average daily flow	mgd	-	428
(19) Percent of permitted capacity	%	-	85%
(20) CBOD ₅ Effluent	mg/L	080082	2
(21) CBOD ₅ Effluent	lbs/day	-	N/A
(22) TSS Effluent	mg/L	900201	2.4
(23) TSS Effluent	lbs/day	-	N/A
(24) Minimum pH		-	7.0
(25) Maximum pH		-	7.9
(26) Total N	mg/L	000600	N/A
(27) TKN	mg/L	000625	N/A
(28) Ammonia (NH ₃ - N)	mg/L	000610	N/A
(29) Nitrate	mg/L	071850	N/A
(30) Total Phosphorus	mg/L	000655	N/A
(31) Minimum Chlorine Residual	mg/L	-	0.6
(32) Maximum Chlorine Residual	mg/L	-	2.2
(33) Other Effluent Parameters			*
<u>LOADS OF SLUDGE</u>			
<u>TO DIRT STAKE</u>			
<u>131,396 GALLONS</u>			

Domestic Wastewater Treatment Plant Monthly Operating Report

Month October Year 1998

Day of the Month	Flow (mgd)	Chlorine Residual after Contact	Chlorine Residual after Dechlorination	CBOC ₂ Influent (mg/L)	TSS Influent (mg/L)	CBOC ₂ Effluent (mg/L)	TSS Effluent (mg/L)	pH Effluent	TKN Effluent (mg/L)	NH ₃ - N Effluent (mg/L)	Nitrate Effluent (mg/L)	Total P Effluent (mg/L)	Facal Coliform (#/100ml)	Filter # C600	Filter # TSS	Filter # Filter
1	470	2.2						7.3								
2	400	1.4						7.3								
3	490	2.1						7.3								
4	460	2.1						7.4								
5	470	1.5		200	200	<2	1.7	7.3								
6	460	1.7						7.3					<1			
7	430	1.3						7.4								
8	400	1.9						7.1								
9	420	1.0						7.2								
10	460	0.6						7.2								
11	460	0.8						7.1								
12	440	1.2		210	220	2.0	3.1	7.3								
13	380	1.5						7.4					1.0			
14	380	1.1						7.2								
15	400	1.7						7.3								
16	430	1.4						7.4								
17	410	1.2						7.3								
18	440	1.6						7.3								
19	420	1.1		190	120	<2	2.2	7.2								
20	420	1.4						7.3					<1			
21	500	1.6						7.4								
22	430	1.0						7.0								
23	320	1.4						7.3								
24	450	1.5						7.1								
25	470	1.6						7.3								
26	410	1.0		220	130	2.1	2.7	7.2								
27	380	1.6						7.1					<1			
28	420	0.9						7.2								
29	320	1.5						7.4								
30	410	1.6						7.3								
31	390	1.2						7.4								

I, the undersigned Operator, certify that I am familiar with the information contained in this report and that to the best of my knowledge and belief, this information is true, complete and accurate.

Signed: 

Date: 11/12/98

Name (Please Type) DEAN S. SMILEY, JR.

Company Name INDIAN TOWN COMPANY, INC.

Telephone No (Please Type) (561) 597-2121

Domestic Wastewater Treatment Plant Monthly Operating Report

Part II - General Information

- (1) Month NOVEMBER Year 1998
- (2) Plant's DER Identification Number 5143 P03291
- (3) Plant Name INDIAN TOWN WASTEWATER TREATMENT PLANT
- (4) Plant Address P.O. Box 397, 168th Ave
ROCKY PARK
- (5) City INDIAN TOWN
- (6) County MARTIN
- (7) Phone Number (561) 597-3496
- (8) Permit Number D.O. 43-091836
- (9) Plant Type 2-C
- (10) Test Site Identification Number 00002
- (11) Fecal Coliform Sample Method
 Membrane Filter Most Probable Number
- (12) Type of Effluent Disposal or Reclaimed Water Reuse
EVAP. PERC. Ponds / IRRIGATION
- (13) Limited Wet Weather Discharge Activated
 Yes No Not Applicable
- (14) Cumulative Days of Wet Weather Discharge None
- (15) Plant Staffing
- Day Shift Operator Class _____ Cert. No. _____
- Evening Shift Operator Class _____ Cert. No. _____
- Night Shift Operator Class _____ Cert. No. _____
- Lead Operator [Signature] A-6805
 Signature Cert. No.

Parameter	Units	STORET Code	Value
(16) Monthly average daily flow	mgd	050053	.513
(17) Permitted capacity	mgd	-	.500
(18) Three-month average daily flow	mgd	-	.471
(19) Percent of permitted capacity	%	-	94%
(20) CBOD ₅ Effluent	mg/L	080082	3.6
(21) CBOD ₅ Effluent	lbs/day	-	N/A
(22) TSS Effluent	mg/L	900201	4.7
(23) TSS Effluent	lbs/day	-	N/A
(24) Minimum pH		-	6.9
(25) Maximum pH		-	7.4
(26) Total N	mg/L	000600	N/A
(27) TXN	mg/L	000625	N/A
(28) Ammonia (NH ₃ · N)	mg/L	000610	N/A
(29) Nitrate	mg/L	071850	N/A
(30) Total Phosphorus	mg/L	000665	N/A
(31) Minimum Chlorine Residual	mg/L	-	0.5
(32) Maximum Chlorine Residual	mg/L	-	1.6
(33) Other Effluent Parameters		*	
			131,396 Gallons *
			WASTED TO DIGESTION


Domestic Wastewater Treatment Plant Monthly Operating Report

Month NOVEMBER Year 1998

(3)

Day of the Month	Flow (mgd)	Chlorine Residual after Contact	Chlorine Residual after Dechlorination	CBOD ₅ Influent (mg/L)	TSS Influent (mg/L)	CBOD ₅ Effluent (mg/L)	TSS Effluent (mg/L)	pH Effluent	TKN Effluent (mg/L)	NH ₃ - N Effluent (mg/L)	Nitrate Effluent (mg/L)	Total P Effluent (mg/L)	Fecal Coliform (#/100ml)	Filter's CBOD	Filter's TSS	Filter's Fecal
1	.400	0.6						7.4								
2	.380	1.0		250	160	<2	3.5	7.2								
3	.390	1.3						7.3					<1			
4	.590	0.9						7.3								
5	.770	0.6						7.2								
6	.730	0.8						7.0								
7	.670	0.6						7.1								
8	.640	0.5						7.2								
9	.610	0.9		150	89	2.2	2.9	7.1								
10	.570	0.7						7.0					2			
11	.570	0.6						7.1								
12	.520	0.9						7.3								
13	.530	1.1						7.1								
14	.540	1.0						7.1								
15	.550	1.0						7.1								
16	.480	0.8		290	150	3.9	4.2	7.0								
17	.440	1.2						7.4					<1			
18	.420	0.8						7.3								
19	.420	0.5						6.9								
20	.460	0.9						7.0								
21	.450	0.9						7.1								
22	.480	1.1						7.2								
23	.440	1.4		160	120	5.9	8.5	7.1								
24	.470	1.4						6.9					<1			
25	.480	1.6						7.0								
26	.490	1.4						7.1								
27	.470	1.0						7.0								
28	.480	0.9						7.1								
29	.450	0.8						7.1								
30	.460	1.2		220	120	4.1	4.3	7.2								
31																

I, the Head Operator, certify that I am familiar with the information contained in this report and that to the best of my knowledge and belief, this information is true, complete, and accurate.

Signed: 

Date: 12/15/98

Name (Please Type) DEAN S. SMILEY, JR.

Company Name TURKANTOWN COMPANY, INC.

Telephone No (Please Type) (561) 597-2121

Domestic Wastewater Treatment Plant Monthly Operating Report

Part II - General Information

- (1) Month DECEMBER Year 1998
- (2) Plant's DER Identification Number 5143 P03291
- (3) Plant Name INDIANTOWN WASTEWATER TREATMENT PLANT
- (4) Plant Address P.O. BOX 397, 168TH AVE
BOOKER PARK
- (5) City INDIANTOWN
- (6) County MARTIN
- (7) Phone Number (561) 597-3496
- (8) Permit Number D.O. 43-091836
- (9) Plant Type 2-C
- (10) Test Site Identification Number 00002
- (11) Fecal Coliform Sample Method
 Membrane Filter Most Probable Number
- (12) Type of Effluent Disposal or Reclaimed Water Reuse
EVAP. POND & PLOTS / IRRIGATION
- (13) Limited Wet Weather Discharge Activated
 Yes No Not Applicable
- (14) Cumulative Days of Wet Weather Discharge NONE

(15) Plant Staffing

Day Shift Operator Class _____ Cert. No. _____

Evening Shift Operator Class _____ Cert. No. _____

Night Shift Operator Class _____ Cert. No. _____

Lead Operator [Signature] A-6805
Signature Cert. No.

Parameter	Units	STORET Code	Value
(16) Monthly average daily flow	mgd	050053	406
(17) Permitted capacity	mgd	-	500
(18) Three-month average daily flow	mgd	-	448
(19) Percent of permitted capacity	%	-	90%
(20) CBOD ₅ Effluent	mg/L	080082	6.1
(21) CBOD ₅ Effluent	lbs/day	-	N/A
(22) TSS Effluent	mg/L	900201	4.4
(23) TSS Effluent	lbs/day	-	N/A
(24) Minimum pH		-	6.9
(25) Maximum pH		-	7.5
(26) Total N	mg/L	000600	N/A
(27) TKN	mg/L	000625	N/A
(28) Ammonia (NH ₃ - N)	mg/L	000610	N/A
(29) Nitrate	mg/L	071850	N/A
(30) Total Phosphorus	mg/L	000665	N/A
(31) Minimum Chlorine Residual	mg/L	-	0.8
(32) Maximum Chlorine Residual	mg/L	-	1.6
(33) Other Effluent Parameters			*
* GALLONS OF			
SLUDGE WASTED			
TO DIGESTION:			
(255,424)			

Domestic Wastewater Treatment Plant Monthly Operating Report

Month December Year 1978

(3)

Day of the Month	Flow (mgd)	Chlorine Residual after Contact	Chlorine Residual after Dechlorination	CBOD ₅ Influent (mg/L)	TSS Influent (mg/L)	CBOD ₅ Effluent (mg/L)	TSS Effluent (mg/L)	pH Effluent	TKN Effluent (mg/L)	NH ₃ - N Effluent (mg/L)	Nitrate Effluent (mg/L)	Total P Effluent (mg/L)	Fecal Coliform (#/100ml)	Effluent CBOD	Effluent TSS	Effluent Fecal
1	430	1.4						7.3					< 1			
2	400	1.0						7.2								
3	450	1.6						7.3								
4	430	1.2						6.9								
5	440	1.1						7.0								
6	420	0.8						7.2								
7	430	1.3		210	130	3.4	3.9	7.0								
8	400	1.6						7.1					< 1			
9	400	1.0						7.3								
10	410	1.4						7.2								
11	410	1.0						7.1								
12	450	1.5						7.3								
13	430	1.2						7.2								
14	430	1.1		190	88	7.5	4.5	7.2								
15	430	1.4						7.0					< 1			
16	320	1.6						7.4								
17	360	1.2						7.1								
18	360	1.0						7.3								
19	400	1.0						7.1								
20	440	1.0						7.0								
21	380	1.5		270	140	4.1	3.7	7.2								
22	430	1.5						7.1					< 1			
23	370	1.6						7.1								
24	410	0.9						7.3								
25	400	0.7						7.5								
26	420	0.8						7.4								
27	400	1.6						7.1								
28	330	1.5		320	140	6.1	5.6	7.2								
29	410	1.8						7.4					< 1			
30	380	1.2						7.3								
31	410	0.8						7.0								

Plant Operator: This is to certify that I am familiar with the information contained in this report and that to the best of my knowledge and belief, this information is true, complete and accurate.

Signed: 

Date: 1-14-99

Name (Please Type) DEAN S. SMILEY, JR.

Company Name INDIAN TOWN COMPANY, INC.

Telephone No (Please Type) (561) 577-2121

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

PERMITTEE NAME: Indiantown Utilities
 MAILING ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
 MONITORING PERIOD From: 1/31/99
 LIMIT: Final
 CLASS SIZE: Minor

To: 1/31/99
 REPORT: Monthly
 GROUP: Domestic

FACILITY: Indiantown Company Wastewater Treatment Plant
 LOCATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
 GMS ID NO.: 5143P03291
 DISCHARGE POINT NUMBER: D001
 PLANT SIZE/TREATMENT TYPE: IIC


WAFR SITE NO.: 20552
 GMS TEST SITE NO.: _____

COUNTY: Martin

NO DISCHARGE FROM SITE

Parameter	Sample Measurement	Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		Report (Daily Max.)	Report (Month Avg.)								
Flow	Sample Measurement	0	0		0	0	0	0	0	0	0
STORET No. 50050 Mon. Site No. EFF-1	Permit Measurement			mgd						Hourly during any discharge	Calculated Flow
TRC for dechlorination	Sample Measurement	0	0		0	0	0	0	0	0	0
STORET No. 50060 Mon. Site No. EFF-1	Permit Measurement				0.01 (Max.)			mg/L		Daily during any discharge	Grab
pH	Sample Measurement	0	0		0	0	0	0	0	0	0
STORET No. 00406 Mon. Site No. EFF-1	Permit Measurement				6.0 (Min.)	8.5 (Max.)		S.U.		Daily during any discharge	Grab
Oxygen, Dissolved (DO)	Sample Measurement	0	0		0	0	0	0	0	0	0
STORET No. 00300 Mon. Site No. EFF-1	Permit Measurement				5.0 (Min.)			mg/L		Daily during any discharge	Grab
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (YY/MM/DD)
ROBERT M. POST / PRESIDENT		(521) 597-2121	2/22/99

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

182

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

MITTEE NAME: Indiantown Utilities
 MAILING ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
 MONITORING PERIOD From: 1/01/99
 LIMIT: Final
 CLASS SIZE: Minor

To: 1/31/99
 REPORT: Monthly
 GROUP: Domestic

CITY: Indiantown Company Wastewater Treatment Plant
 LOCATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
 GMS ID NO.: 5143P03291
 DISCHARGE POINT NUMBER: D002
 PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
 GMS TEST SITE NO.: _____

COUNTY: Martin

NO DISCHARGE FROM SITE

183

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		Sample Measurement	Permit Measurement		Report (Daily Max.)	Report (Month Avg.)					
ET No. 000307 Site No. EFF-2 for dechlorination	Sample Measurement	0	0	0	0	0	0	0	0	0	0
	Permit Measurement			mgd						Hourly during any discharge	Calculated Flow
ET No. 000601 Site No. EFF-2	Sample Measurement	0	0	0	0	0	0	0	0	0	0
	Permit Measurement				0.01 (Max.)			mg/L		Daily during any discharge	Grab
ET No. 000607 Site No. EFF-2 on, Dissolved (DO)	Sample Measurement	0	0	0	0	0	0	0	0	0	0
	Permit Measurement				6.0 (Min.)	8.5 (Max.)		S.U.		Daily during any discharge	Grab
ET No. 000300 Site No. EFF-2	Sample Measurement	0	0	0	0	0	0	0	0	0	0
	Permit Measurement				5.0 (Min.)			mg/L		Daily during any discharge	Grab
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

MITTEE NAME: Indiantown Utilities
 LONG ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
 MONITORING PERIOD From: 1/01/99
 LIMIT: Final
 CLASS SIZE: Minor

To: 1/31/99
 REPORT: Monthly
 GROUP: Domestic

ILITY: Indiantown Company Wastewater Treatment Plant
 ATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
 GMS ID NO.: 5143P03291
 DISCHARGE POINT NUMBER: D003
 PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
 GMS TEST SITE NO.: _____

NTY: Martin

NO DISCHARGE FROM SITE

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		Sample Measurement	Permit Measurement		Sample Measurement	Permit Measurement	Sample Measurement				
	Sample Measurement	0	0	0	0	0	0	0	0	0	0
Site No. EPP-3	Permit Measurement	DA Report (Daily Max.)	LA Report (Month Avg.)	mgd						Hourly during any discharge	Calculated Flow
	Sample Measurement	0	0	0	0	0	0	0	0	0	0
Site No. EPP-3	Permit Measurement				6.0 (Min.)	8.5 (Max.)		S.U.		Daily during any discharge	grab
for dechlorination	Sample Measurement	0	0	0	0	0	0	0	0	0	0
Site No. EPP-3	Permit Measurement				0.01 (Max.)			mg/L		Daily during any discharge	Grab
en, Dissolved (DO)	Sample Measurement	0	0	0	0	0	0	0	0	0	0
Site No. EPP-3	Permit Measurement				5.0 (Min.)			mg/L		Daily during any discharge	Grab
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

181

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Southeast District, P.O. Box 15425, West Palm Beach, 33416

ISSUING NAME: Indiantown Utilities
 ISSUING ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
 MONITORING PERIOD From: 1/01/99
 LIMIT: Final
 CLASS SIZE: Minor

To: 1/31/99
 REPORT: Monthly
 GROUP: Domestic

PLANT TYPE: Indiantown Company Wastewater Treatment Plant
 LOCATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
 GMS ID NO.: 5143P03291
 DISCHARGE POINT NUMBER: R001
 PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
 GMS TEST SITE NO.: _____

CITY: Martin

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
ET No. 00050 Site No. EPP-6	Sample Measurement	.335		MGD					0		
	Permit Measurement	0.4 (An.Avg.)		mgd						continuous with 5 readings/Week	Flow Meters with Totalizer
ET No. 00050 Site No. EPP-6	Sample Measurement	.422		MGD					0		
	Permit Measurement	Report (Mo.Avg.)		mgd						continuous with 5 readings/Week	Flow Meters with Totalizer
ET No. 00082 Site No. EPP-6	Sample Measurement				6.9			Mg/L	0		
	Permit Measurement				20.0 (An.Avg.)			mg/L		Weekly	8-hour FPC
ET No. 00082 Site No. EPP-6	Sample Measurement				2.8		3.5	Mg/L	0		
	Permit Measurement				25.0 (Mo.Avg.)	40.0/report (Week.Avg.)	60.0 (Max.)	mg/L		Weekly	8-hour FPC
ET No. 00030 Site No. EPP-6	Sample Measurement				3.5			Mg/L	0		
	Permit Measurement				20.0 (An.Avg.)			mg/L		Weekly	8-hour FPC
ET No. 00030 Site No. EPP-6	Sample Measurement				4.0		4.3	Mg/L	0		
	Permit Measurement				30.0 (Mo.Avg.)	45.0/report (Week.Avg.)	60.0 (Max.)	mg/L		Weekly	8-hour FPC
ET No. 00000 Site No. EPP-6	Sample Measurement				6.9	7.4		S.U.	0		
	Permit Measurement				6.0 (Min.)	8.5 (Max.)		S.U.		Continuous	pH meter with 24 hour recording meter

186

DISCHARGE MONITORING REPORT - PART A (Continued)

CITY NAME: Indiantown Company Wastewater Treatment Plant

PERMIT NUMBER: FL0029939-001-DW1P

DISCHARGE POINT NUMBER: R001

WAFR SITE No.: 20552

Parameter		Quantity or Loading	Units	Quality or Concentration	Units	No. Ex.	Frequency of Analysis	Sample Type
Ammonia Nitrogen	Sample Measurement	*						
Ammonia Nitrogen	Permit Measurement			12.0 (Max.)	mg/L		Weekly	Grab
Phosphorus, Total as P	Sample Measurement	*						
Phosphorus, Total as P	Permit Measurement			Report (Max.)	mg/L		Weekly	8-hour FPC
Phosphorus, Total as P	Sample Measurement	*						
Phosphorus, Total as P	Permit Measurement			Report (Max.)	mg/L		Weekly	8-hour FPC
Coliform Bacteria	Sample Measurement			0.19	*/100ml	0		
Coliform Bacteria	Permit Measurement			200 (An.Avg.)	#/100mL		Weekly	Grab
Coliform Bacteria	Sample Measurement			0	*/100ml	0		
Coliform Bacteria	Permit Measurement			Report (Mo. Geo. Mean)	#/100mL		Weekly	Grab
Chlorine for disinfection	Sample Measurement			0.5	mg/L	0		
Chlorine for disinfection	Permit Measurement			0.5 (Min.)	mg/L		Continuous	TRC meter with 24 hour recording chart

* DID NOT START TESTING FOR THESE PARAMETERS UNTIL 2/15/99

081

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Southeast District, P.O. Box 15425, West Palm Beach, 33416

ISSUE NAME: Indiantown Utilities
 MAILING ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DWIP
 MONITORING PERIOD From: 1/01/99
 LIMIT: Final
 CLASS SIZE: Minor

To: 1/31/99
 REPORT: Monthly
 GROUP: Domestic

CITY: Indiantown Company Wastewater Treatment Plant
 LOCATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
 GMS ID NO.: 5143P03291
 DISCHARGE POINT NUMBER: R002
 PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
 GMS TEST SITE NO.: _____

CITY: Martin

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.		
ET No. 00050 Site No. EPP-7	Sample Measurement	0.100						MGD	0		
	Permit Measurement	0.107 (An.Avg.)		mgd						Continuous with 5 readings/Week	Flow Meters with Totalizer
ET No. 00050 Site No. EPP-7	Sample Measurement		0.066					MGD	0		
	Permit Measurement		Report (Mo.Avg.)	mgd						Frequency of Analysis	Sample Type
ET No. 00052 Site No. EPP-6	Sample Measurement				6.9			M ₂ /L	0		
	Permit Measurement				20.0 (An.Avg.)			mg/L		Weekly	8-hour FPC
ET No. 00052 Site No. EPP-6	Sample Measurement				2.8		3.5	M ₂ /L	0		
	Permit Measurement				25.0 (Mo.Avg.)	40.0/report (Week.Avg.)	60.0 (Max.)	mg/L		Weekly	8-hour FPC
ET No. 00053 Site No. EPP-6	Sample Measurement				3.5			M ₂ /L	0		
	Permit Measurement				20.0 (An.Avg.)			mg/L		Weekly	8-hour FPC
ET No. 00053 Site No. EPP-6	Sample Measurement				4.0		4.3	M ₂ /L	0		
	Permit Measurement				30.0 (Mo.Avg.)	45.0/report (Week.Avg.)	60.0 (Max.)	mg/L		Weekly	8-hour FPC
ET No. 00054 Site No. EPP-6	Sample Measurement				6.9	7.4		S.U.	0		
	Permit Measurement				6.0 (Min.)	8.5 (Max.)		S.U.		Continuous	pH meter with 24 hour recording meter

Parameter No. 4709		Quantity or Loading	Units	Quality or Concentration	Units	No. Ex.	Frequency of Analysis	Sample Type
Ammonia Nitrogen	Sample Measurement	*						
Ammonia Nitrogen ET No. 0002 Site No. EFF-16 Total as N	Permit Measurement			12.0 (Max.)	mg/L		Weekly	Grab
Phosphorus	Sample Measurement	*						
Phosphorus ET No. 0002 Site No. EFF-16 Total as P	Permit Measurement			Report (Max.)	mg/L		Weekly	8-hour FPC
Coliform Bacteria	Sample Measurement	*						
Coliform Bacteria ET No. 0002 Site No. EFF-16	Permit Measurement			Report (Max.)	mg/L		Weekly	8-hour FPC
Coliform Bacteria	Sample Measurement			0.19	#/100ml	0		
Coliform Bacteria ET No. 0002 Site No. EFF-16	Permit Measurement			200 (An.Avg.)	#/100ml		Weekly	Grab
Chlorine Residual	Sample Measurement			0	#/100ml	0		
Chlorine Residual ET No. 0002 Site No. EFF-16 or disinfection	Permit Measurement			Report (Mo.Geo.Mean)	#/100ml		Weekly	Grab
Chlorine Residual	Sample Measurement			0.5	mg/L	0		
Chlorine Residual ET No. 0002 Site No. EFF-16	Permit Measurement			0.5 (Min.)	mg/L		Continuous	TRC meter with 24 hour recording chart

* DID NOT START TESTING FOR THESE PARAMETERS UNTIL 2/15/99

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Southeast District, P.O. Box 15425, West Palm Beach, 33416

ISSUING NAME: Indiantown Utilities
ISSUING ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DWIP
MONITORING PERIOD From: 1/01/99
LIMIT: Final
CLASS SIZE: Minor

To: 1/31/99
REPORT: Monthly
GROUP: Domestic

FACILITY: Indiantown Company Wastewater Treatment Plant
LOCATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: Influent Monitoring Point
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

OWNER: Martin

Parameter		Quantity or Loading	Units	Quality or Concentration	Units	No. Ex.	Frequency of Analysis	Sample Type
	Sample Measurement	*						
ET No. INF-1	Permit Measurement	0.585 (3-Mo. Avg.)	Report (Mo. Avg.)	mgd			Continuous	Flow Meters
	Sample Measurement			187.5	mg/L	0		
ET No. INF-1	Permit Measurement		Report (Mo. Avg.)		mg/L		Weekly	16-hour FPC
	Sample Measurement			127.5	mg/L	0		
ET No. INF-1	Permit Measurement		Report (Mo. Avg.)		mg/L		Monthly	16-hour FPC

* INF-1 METER NOT INSTALLED YET / TO MEET NEW PERMIT CONDITIONS;

DAILY SAMPLE RESULTS - PART B
(PAGE ONE)

File Number: FL0029939-001-DW1P
Year: JANUARY/1999

Three-month Average Daily Flow: 448
Daily Flow % of Permitted
Capacity: 77%

423

of the Month near/Unit/Monitoring Location Site Number	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30/31		
(mgd), EFF-6	100	100	520	140	130	120	100	110	130	130	110	390	390	390	440	450	430	420	330	390	390	450	470	450	400	430	390	440	450	440		
(mgd), EFF-7																																
(mgd), INF-1																																
DS (mg/L), EFF-6				2.6							2.4							2.8							3.5							
DS (mg/L), INF-1				150							280							130							190							
mg/L, EFF-6				3.3							4.1							4.1							4.3							
mg/L, INF-1				110							130							160							170							
(d. units), EFF-6	7.2	7.2	7.0	7.2	6.9	7.1	7.3	7.1	7.4	7.1	7.1	7.3	7.2	7.4	7.2	7.2	7.0	7.1	7.1	7.3	7.2	7.3	7.3	7.2	7.1	7.2	7.2	7.3	7.1	7.0	7.2	
Coliform Bacteria (#/100 mL), EFF-6				<1								<1								<1					<1							
Retention time for Fecal Coliform Bacteria sample, EFF-6				1830								0830								0830					0830							
For Disinfection (mg/L), EFF-6	1.0	1.0	0.7	1.2	1.0	1.4	1.7	1.1	0.8	1.2	1.0	1.4	1.0	0.6	1.5	2.0	2.2	1.6	1.6	1.9	2.2	0.8	1.0	0.5	1.1	1.5	1.5	1.8	1.9	1.6	1.6	
Nitrogen (as N) (mg/L), EFF-6																																
Phosphorus (as P) (mg/L), EFF-6																																
c, as N, EFF-6																																

101

Operator Class Certificate No. Name:
 Shift Operator Class A-6805 Certificate No. 6805 Name: DEAN S. SMILBY JR.
 Shift Operator Class B-3634 Certificate No. 3634 Name: DON C. JOHNSON, SR.
 Shift Operator Class B-6747 Certificate No. 6747 Name: JAMES G. HEWITT

Effluent Disposal or Reclaimed Water Reuse: EVAP / POKE PUMPS / IRRIGATION
 Wet Weather Discharge Activated: Yes ___ No ___ Not Applicable X If yes, cumulative days of wet weather discharge: ___
 Additional sheets necessary to list all certified operators necessary for required operations: ___

DAILY SAMPLE RESULTS - PART B
(PAGE TWO)

Number: FL0029939-001-DW1P
Year: *January 1999*

Three-month Average Daily Flow: n/a
Daily Flow % of Permitted: n/a
Capacity:

of the Month	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30/31	
Reason/Unit/Monitoring Location Site Number																															
(mgd), EFF-1																															
(mgd), EFF-2																															
(mgd), EFF-3																															
(For Dechlorination) (mg/L), EFF-1																															
(For Dechlorination) (mg/L), EFF-2																															
(For Dechlorination) (mg/L), EFF-3																															
(d. units), EFF-1																															
(d. units), EFF-2																															
(d. units), EFF-3																															
cn, Dissolved (DO), EFF-1																															
cn, Dissolved (DO), EFF-2																															
cn, Dissolved (DO), EFF-3																															
Station Pond Water Elevation, EFF-1																															
Station Pond Water Elevation, EFF-2																															
Station Pond Water Elevation, EFF-3																															
Station Pond Water Elevation, EFF-4																															
Station Pond Water Elevation, EFF-5																															
elevation below the overflow, EFF-1	+2'																														
elevation below the overflow, EFF-2	+2'																														
elevation below the overflow, EFF-3	+2'																														
elevation below the overflow, EFF-4	+2'																														
elevation below the overflow, EFF-5	+2'																														

10

→ NEW POND STAFFS (NOT INSTALLED) / ELEVATIONS (NOT SHOT) TO MEET NEW PERMIT CONDITIONS AT THIS TIME :

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

PERMITTEE NAME: Indiantown Utilities
 MAILING ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DWIP
 MONITORING PERIOD From: 1/21/99
 LIMIT: Final
 CLASS SIZE: Minor

To: 1/21/99
 REPORT: Annual
 GROUP: Domestic

FACILITY: Indiantown Company Wastewater Treatment Plant
 LOCATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
 GMS ID NO.: 5143P03291
 DISCHARGE POINT NUMBER: D001
 PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
 GMS TEST SITE NO.:

COUNTY: Martin

CHECK HERE IF NO TOXIC SAMPLING WAS REQUIRED DURING THE YEAR

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
96-hr Acute Static Renewal Ceriodaphnia dubia STORET No. TAN 3B Mon. Site No. EFF-1	Sample Measurement	0	0	0	0	0	0	0	0	0	0
	Permit Measurement				LC 50 >100 % (minimum)		percent		Annual	four grab samples over a 24-hour day	
96-hr Acute Static Renewal- Cyprinella leedsii STORET No. TAN 6H Mon. Site No. EFF-1	Sample Measurement	0	0	0	0	0	0	0	0	0	0
	Permit Measurement				LC 50 >100 % (minimum)		percent		Annual	four grab samples over a 24-hour day	
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

192

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

ISSUE NAME: Indiantown Utilities
 ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DWIP
 MONITORING PERIOD From: 1/01/99
 LIMIT: Final
 CLASS SIZE: Minor

To: 1/31/99
 REPORT: Annual
 GROUP: Domestic

FACILITY: Indiantown Company Wastewater Treatment Plant
 LOCATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
 GMS ID NO.: 5143P03291
 DISCHARGE POINT NUMBER: D002
 PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
 GMS TEST SITE NO.: _____

PROPERTY: Martin

CHECK HERE IF NO TOXIC SAMPLING WAS REQUIRED DURING THE YEAR

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Acute Static Renewal Cephalexin Permit No. EPA-2-2	Sample Measurement	0	0	0	0	0	0	0	0	0	0
	Permit Measurement				LC 50 >100 % (minimum)			percent		Annual	four grab samples over a 24 hour day
Acute Static Renewal Cephalexin Permit No. EPA-2-2	Sample Measurement	0	0	0	0	0	0	0	0	0	0
	Permit Measurement				LC 50 >100 % (minimum)			percent		Annual	four grab samples over a 24 hour day
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

193

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

ITTEE NAME: Indiantown Utilities
 ING ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
 MONITORING PERIOD From: 1/01/99
 LIMIT: Final
 CLASS SIZE: Minor

To: 1/31/99
 REPORT: Annual
 GROUP: Domestic

ITY: Indiantown Company Wastewater Treatment Plant
 TION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
 GMS ID NO.: 5143P03291
 DISCHARGE POINT NUMBER: D003
 PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
 GMS TEST SITE NO.: _____

ITY: Martin

CHECK HERE IF NO TOXIC SAMPLING WAS REQUIRED DURING THE YEAR

104

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Acute Static Renewal aphala dobia	Sample Measurement	0	0	0	0	0	0	0	0	0	0
	Permit Measurement				LC 50 >100 % (minimum)			percent		Annual	four grab samples over a 24 hour day
Acute Static Renewal- ella todi	Sample Measurement	0	0	0	0	0	0	0	0	0	0
	Permit Measurement				LC 50 >100 % (minimum)			percent		Annual	four grab samples over a 24 hour day
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

ISSUE NAME: Indiantown Utilities
ISSUING ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
MONITORING PERIOD From: 2/01/99
LIMIT: Final
CLASS SIZE: Minor

To: 2/28/99
REPORT: Monthly
GROUP: Domestic

CITY: Indiantown Company Wastewater Treatment Plant
LOCATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: D001
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

TYPE: Martin


NO DISCHARGE FROM SITE

Parameter	Sample Measurement	Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		Report (Daily Max.)	Report (Month Avg.)								
	0	0	0	mgd	0	0	0	0	0	0	0
	0	0	0	mgd						Hourly during any discharge	Calculated Flow
	0	0	0	mg/L	0.01 (Max.)			0	0	Daily during any discharge	Grab
	0	0	0		0	0	0	0	0	0	0
	0	0	0	S.U.	6.0 (Min.)	8.5 (Max.)		0	0	Daily during any discharge	Grab
	0	0	0		0	0	0	0	0	0	0
	0	0	0	mg/L	5.0 (Min.)			0	0	Daily during any discharge	Grab

195

00400

I, the undersigned, under penalty of law that I have personally examined and am familiar with the information submitted herein; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.

TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (YY/MM/DD)
Robert M. Post President		(561) 597-3496	4/09/99

STATEMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

mailed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

MITTEE NAME: Indiantown Utilities
ILDNO ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
MONITORING PERIOD From: 2/01/99
LIMIT: Final
CLASS SIZE: Minor

To: 2/28/99
REPORT: Monthly
GROUP: Domestic

ILITY: Indiantown Company Wastewater Treatment Plant
ATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: D002
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

NTY: Martin

NO DISCHARGE FROM SITE

Parameter	Sample Measurement	Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		0	0		0	0	0				
Residual Chlorine for disinfection	Permit Measurement	Report (Daily Max.)	Report (Month Avg.)	mgd						Hourly during any discharge	Calculated Flow
	Sample Measurement	0	0	0	0	0	0	0	0	0	0
	Permit Measurement				0.01 (Max.)			mg/L		Daily during any discharge	Grab
	Sample Measurement	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (DO)	Permit Measurement				6.0 (Min.)	8.5 (Max.)		S.U.		Daily during any discharge	Grab
	Sample Measurement	0	0	0	0	0	0	0	0	0	0
	Permit Measurement				5.0 (Min.)			mg/L		Daily during any discharge	Grab
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

196

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

PERMITTEE NAME: Indiantown Utilities
 MAILING ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
 MONITORING PERIOD From: 2/01/99
 LIMIT: Final
 CLASS SIZE: Minor

To: 2/28/99
 REPORT: Monthly
 GROUP: Domestic

FACILITY: Indiantown Company Wastewater Treatment Plant
 LOCATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
 GMS ID NO.: 5143P03291
 DISCHARGE POINT NUMBER: D003
 PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
 GMS TEST SITE NO.: _____

COUNTY: Martin

NO DISCHARGE FROM SITE

Parameter	Sample Measurement	Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		Report (Daily Max.)	Report (Month Avg.)		(mgd)	(Min.)	(Max.)				
Flow	Sample Measurement	0	0	0	0	0	0	0	0	0	
STORET No. 50030 Mon. Site No. EFF-3	Permit Measurement									Hourly during any discharge	
pH	Sample Measurement	0	0	0	0	0	0	0	0	0	
STORET No. 00406 Mon. Site No. EFF-3	Permit Measurement				6.0 (Min.)	8.5 (Max.)		S.U.		Daily during any discharge	
TRC for dechlorination	Sample Measurement	0	0	0	0	0	0	0	0	0	
STORET No. 50060 Mon. Site No. EFF-3	Permit Measurement				0.01 (Max.)			mg/L		Daily during any discharge	
Oxygen, Dissolved (DO)	Sample Measurement	0	0	0	0	0	0	0	0	0	
STORET No. 00300 Mon. Site No. EFF-3	Permit Measurement				5.0 (Min.)			mg/L		Daily during any discharge	
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

197

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Southeast District, P.O. Box 15425, West Palm Beach, 33416

MITTEE NAME: Indiantown Utilities
LINE ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
MONITORING PERIOD From: 2/01/99
LIMIT: Final
CLASS SIZE: Minor

To: 2/28/99
REPORT: Monthly
GROUP: Domestic

ILITY: Indiantown Company Wastewater Treatment Plant
ATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: R001
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

NTY: Martin

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
	Sample Measurement	.341		MGD					0		
	Permit Measurement	0.4		mgd						continuous with 5 readings/Week	Flow Meters with Totalizer
	Sample Measurement	.333		MGD					0		
	Permit Measurement	Report (Mo.Avg.)		mgd						continuous with 5 readings/Week	Flow Meters with Totalizer
	Sample Measurement				6.6			Mg/L	0		
	Permit Measurement				20.0 (An.Avg.)			mg/L		Weekly	8-hour FPC
	Sample Measurement				4.8			Mg/L	0		
	Permit Measurement				25.0 (Mo.Avg.)	40.0/report (Week.Avg.)	60.0 (Max.)	mg/L		Weekly	8-hour FPC
	Sample Measurement				3.6			Mg/L	0		
	Permit Measurement				20.0 (An.Avg.)			mg/L		Weekly	8-hour FPC
	Sample Measurement				4.1			Mg/L	0		
	Permit Measurement				30.0 (Mo.Avg.)	45.0/report (Week.Avg.)	60.0 (Max.)	mg/L		Weekly	8-hour FPC
	Sample Measurement				6.8	7.1		S.U.	0		
	Permit Measurement				6.0 (Min.)	8.5 (Max.)		S.U.		Continuous	pH meter with 24 hour recording meter

198

00400

DISCHARGE MONITORING REPORT - PART A (Continued)

Plant Name: Indiantown Company Wastewater Treatment Plant

PERMIT NUMBER: FL0029939-001-DW1P

DISCHARGE POINT NUMBER: R004

WAFR SITE No.: 20552

Parameter	Sample Measurement	Quantity or Loading	Units	Quality or Concentration		Units	No. Ex.	Frequency of Analysis	Sample Type
	Sample Measurement			15		Mg/L	1		
	Permit Measurement			12.0 (Max.)		mg/L		Weekly	Grab
Iron, Total as N	Sample Measurement			19		Mg/L	0		
	Permit Measurement			Report (Max.)		mg/L		Weekly	8-hour FPC
Phosphorus, Total as P	Sample Measurement			4.5		Mg/L	0		
	Permit Measurement			Report (Max.)		mg/L		Weekly	8-hour FPC
Coliform Bacteria	Sample Measurement			0.70		#/100 mL	0		
	Permit Measurement			200 (An. Avg.)		#/100 mL		Weekly	Grab
Coliform Bacteria	Sample Measurement			0	0	#/100 mL	0		
	Permit Measurement			Report (Mo. Geo. Mean)	800 (Max.)	#/100 mL		Weekly	Grab
for disinfection	Sample Measurement			0.8		Mg/L	0		
	Permit Measurement			0.5 (Min)		mg/L		Continuous	TRC meter with 24 hour recording chart

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Southeast District, P.O. Box 15425, West Palm Beach, 33416

MITTEE NAME: Indiantown Utilities
MAILING ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
MONITORING PERIOD From: 2/01/99
LIMIT: Final
CLASS SIZE: Minor

To: 2/28/99
REPORT: Monthly
GROUP: Domestic

CITY: Indiantown Company Wastewater Treatment Plant
LOCATION: 13851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: R002
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

CITY: Martin

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.		
	Sample Measurement	0.084		MGD					0		
	Permit Measurement	0.107 (An.Avg.)		mgd						Continuous with 5 readings/Week	Flow Meters with Totalizer
	Sample Measurement		0.073	MGD					0		
	Permit Measurement		Report (Mo.Avg.)	mgd						Frequency of Analysis	Sample Type
	Sample Measurement				6.6			mg/L	0		
	Permit Measurement				20.0 (An.Avg.)			mg/L		Weekly	8-hour FPC
	Sample Measurement				4.8			mg/L	0		
	Permit Measurement				25.0 (Mo.Avg.)	40.0/report (Week.Avg.)	60.0 (Max.)	mg/L		Weekly	8-hour FPC
	Sample Measurement				3.6			mg/L	0		
	Permit Measurement				20.0 (An.Avg.)			mg/L		Weekly	8-hour FPC
	Sample Measurement				11.1			mg/L	0		
	Permit Measurement				30.0 (Mo.Avg.)	45.0/report (Week.Avg.)	60.0 (Max.)	mg/L		Weekly	8-hour FPC
	Sample Measurement				6.4	7.1		S.U.	0		
	Permit Measurement				6.0 (Min.)	8.5 (Max.)		S.U.		Continuous	pH meter with 24 hour recording meter

200

-00400

DISCHARGE MONITORING REPORT - PART A (Continued)

PLANT NAME: Indiantown Company Wastewater Treatment Plant

PERMIT NUMBER: FL0029939-001-DW1P DISCHARGE POINT NUMBER: R002

WAFR SITE No.: 20552

Parameter		Quantity or Loading	Units	Quality or Concentration		Units	No. Ex.	Frequency of Analysis	Sample Type
ic, B	Sample Measurement			15		Mg/L	1		
Site No. BFF-5	Permit Measurement			12.0 (Max.)		mg/L		Weekly	Grab
gca, Total as N	Sample Measurement			19		Mg/L	0		
Site No. BFF-5	Permit Measurement			Report (Max.)		mg/L		Weekly	8-hour FPC
hours, Total as P	Sample Measurement			4.5		Mg/L	0		
Site No. BFF-5	Permit Measurement			Report (Max.)		mg/L		Weekly	8-hour FPC
Coliform Bacteria	Sample Measurement			0.20		#/100ml	0		
Site No. BFF-7	Permit Measurement			200 (An.Avg.)		#/100mL		Weekly	Grab
Coliform Bacteria	Sample Measurement			0	0	#/100ml	0		
Site No. BFF-7	Permit Measurement			Report (Mo. Geo. Mean)	800 (Max.)	#/100mL		Weekly	Grab
for disinfection	Sample Measurement			0.8		Mg/L	0		
	Permit Measurement			0.5 (Min.)		mg/L		Continuous	TRC meter with 24 hour recording chart

201

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Southeast District, P.O. Box 15425, West Palm Beach, 33416

MITTEE NAME: Indiantown Utilities
 LINE ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
 MONITORING PERIOD From: 2/01/99
 LIMIT: Final
 CLASS SIZE: Minor

To: 2/28/99
 REPORT: Monthly
 GROUP: Domestic

LITY: Indiantown Company Wastewater Treatment Plant
 ATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
 GMS ID NO.: 5143P03291
 DISCHARGE POINT NUMBER: Influent Monitoring Point
 PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
 GMS TEST SITE NO.: _____

NTY: Martin

Parameter	Sample Measurement	Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		(3-Mo. Avg.)	Report (Mo. Avg.)								
	Sample Measurement	*									
	Permit Measurement	0.385	Report (Mo. Avg.)	mgd						Continuous	Flow Meters
	Sample Measurement				220			mg/L	0		
	Permit Measurement				Report (Mo. Avg.)			mg/L		Weekly	16-hour FPC
	Sample Measurement				190			mg/L	0		
	Permit Measurement				Report (Mo. Avg.)			mg/L		Monthly	16-hour FPC

* METER NOT INSTALLED YET TO MEET NEW PERMIT CONDITIONS :

**DAILY SAMPLE RESULTS - PART B
(PAGE ONE)**

Number: FL0029939-001-DW1P
 Year: February / 1999

Three-month Average Daily Flow: 411
 Daily Flow % of Permitted
 Capacity: 70%

of the Month	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30/31
Monitoring Location Site Number																														
(mg/L) EFF-6	.45	.42	.44	.38	.43	.39	.43	.41	.35	.43	.35	.40	.37	.45	.45	.38	.41	.37	.43	.40	.39	.41	.37	.40	.39	.38	.45	.42		
(mg/L) EFF-7	.101	.090	.098	.106	.087			.123	.103	.109	.096	.111			.106	.100	.108	.097	.109			.112	.089	.107	.099	.102				
(mg/L) EFF-1																														
35 (mg/L) EFF-6	<2							4.6							5.5							6.9								
35 (mg/L) EFF-1	220							240							250							170								
(mg/L) EFF-6	4.3							2.7							6.7							2.8								
(mg/L) EFF-1	200							150							300							110								
(d. units) EFF-6	7.1	7.3	7.2	6.9	6.8	7.1	7.0	7.1	7.0	7.1	7.0	7.1	7.0	6.9	6.9	7.2	7.1	7.1	7.2	7.3	7.4	7.3	7.1	7.0	7.0	7.2	7.1	7.1		
Coliform Bacteria (#/100 mL), EFF-6		<1										<1				<1							<1							
Standard for Fecal Coliform Bacteria sample, EFF-6		1850										1850				1850							1850							
Fecundation (mg/L), EFF-6	1.6	0.9	1.3	1.6	1.0	1.4	1.1	1.6	1.8	1.3	1.6	1.8	1.6	2.2	2.0	1.5	2.2	1.7	1.6	2.2	1.9	1.2	0.8	1.3	1.6	1.2	1.0	1.1		
Nitrogen (as N) (mg/L), EFF-6															15							19								
Phosphorus (as P) (mg/L), EFF-6															4.0							4.5								
c. as N, EFF-6															9.3							15								

203

Operator: _____ Class: A Certificate No. 6805 Name: DEAN S. SMILEY JR.
 Shift Operator: _____ Class: B Certificate No. 3634 Name: JOHN C. JOHNSON, SR.
 Shift Operator: _____ Class: B Certificate No. 6747 Name: JAMES G. HAWITT
 Operator: _____ Class: _____ Certificate No. _____ Name: _____

Effluent Disposal or Reclaimed Water Reuse: EVAP. / PONDING / PONDS / IRRIGATION
 Wet Weather Discharge Activated: Yes ___ No ___ Not Applicable X If yes, cumulative days of wet weather discharge: _____
 Additional sheets necessary to list all certified operators necessary for required operations: _____

**DAILY SAMPLE RESULTS - PART B
(PAGE TWO)**

Number: FL0029939-001-DW1P

Year: *February / 1999*

Three-month Average Daily Flow: n/a
 Daily Flow % of Permitted: n/a
 Capacity:

of 30 days	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30/31
Monitoring Location Site Number																														
(mg/L), EFF-1																														
(mg/L), EFF-2																														
(mg/L), EFF-3																														
For Disinfection (mg/L), EFF-1																														
For Disinfection (mg/L), EFF-2																														
For Disinfection (mg/L), EFF-3																														
(d. units), EFF-1																														
(d. units), EFF-2																														
(d. units), EFF-3																														
ca, Dissolved (DO), EFF-1																														
ca, Dissolved (DO), EFF-2																														
ca, Dissolved (DO), EFF-3																														
Water Pond Water Elevation, EFF-1																														
Water Pond Water Elevation, EFF-2																														
Water Pond Water Elevation, EFF-3																														
Water Pond Water Elevation, EFF-4																														
Water Pond Water Elevation, EFF-5																														
elevation below the overflow, EFF-1																														
elevation below the overflow, EFF-2																														
elevation below the overflow, EFF-3																														
elevation below the overflow, EFF-4																														
elevation below the overflow, EFF-5																														

204

→ NEW POND STAFFS (NOT INSTALLED) + ELEVATION (NOT SHOT) TO MEET
 NEW PERMIT CONDITIONS AT THIS TIME :

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

MITTEE NAME: Indiantown Utilities
LINE ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
MONITORING PERIOD From: 2/01/99
LIMIT: Final
CLASS SIZE: Minor

To: 2/28/99
REPORT: Annual
GROUP: Domestic

FACILITY: Indiantown Company Wastewater Treatment Plant
LOCATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: D001
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

PROPERTY: Martin

CHECK HERE IF NO TOXIC SAMPLING WAS REQUIRED DURING THE YEAR

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Acute Static Renewal depths double	Sample Measurement	0	0	0	0	0	0	0	0	0	0
REYNOLDS (SH & A) Slo...	Permit Measurement				LC 50 >100 % (minimum)			percent		Annual	four grab samples over a 24 hour day
Acute Static Renewal inella head	Sample Measurement	0	0	0	0	0	0	0	0	0	0
REYNOLDS (SH & A) Slo...	Permit Measurement				LC 50 >100 % (minimum)			percent		Annual	four grab samples over a 24 hour day
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report for: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

WITNESS NAME: Indiantown Utilities
 MAILING ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DWIP
 MONITORING PERIOD From: 2/01/99
 LIMIT: Final
 CLASS SIZE: Minor

To: 2/28/99
 REPORT: Annual
 GROUP: Domestic

CITY: Indiantown Company Wastewater Treatment Plant
 ADDRESS: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
 GMS ID NO.: 5143P03291
 DISCHARGE POINT NUMBER: D002
 PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
 GMS TEST SITE NO.: _____

COUNTY: Martin

CHECK HERE IF NO TOXIC SAMPLING WAS REQUIRED DURING THE YEAR

Parameter	Measurement	Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Acute Toxic Renewal discharge limits	Sample Measurement	0	0	0	0	0	0	0	0	0	0
Chloride	Permit Measurement				LC 50 >100% (minimum)			percent		Annual	four grab samples over a 24 hour day
Acute Toxic Renewal-natural levels	Sample Measurement	0	0	0	0	0	0	0	0	0	0
Chloride	Permit Measurement				LC 50 >100% (minimum)			percent		Annual	four grab samples over a 24 hour day
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

206

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

WITTEE NAME: Indiantown Utilities
LINE ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DWIP
MONITORING PERIOD From: 2/21/99
LIMIT: Final
CLASS SIZE: Minor

To: 2/28/99
REPORT: Annual
GROUP: Domestic

CITY: Indiantown Company Wastewater Treatment Plant
LOCATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: S143P03291
DISCHARGE POINT NUMBER: D003
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

COUNTY: Martin

CHECK HERE IF NO TOXIC SAMPLING WAS REQUIRED DURING THE YEAR

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Acute Static Renewal duplication factor	Sample Measurement	0	0	0	0	0	0	0	0	0	0
Chloride	Permit Measurement				LC 50 >100 % (minimum)			percent		Annual	four grab samples over a 24 hour day
Acute Static Renewal nonsimultaneous	Sample Measurement	0	0	0	0	0	0	0	0	0	0
Chloride	Permit Measurement				LC 50 >100 % (minimum)			percent		Annual	four grab samples over a 24 hour day
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

207

GROUNDWATER MONITORING REPORT - PART D

Number:
 Date:
 Sample Collected:
 Is well purged before sampling?

FLA0129939-DWIP-001 - Indiantown Company WWTF
 2/99
 2/09/99
 Yes No

Monitoring Location Site Number: MWC-1/R001
 Well Type: Compliance
 Ground Water Class: G-II

Parameter	Store Code	Sampling Methods	Samples Filtered(Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
level (depth measurement)	82545		N/N	N/A	Tape	10'	N/A
Hardness (as CaCO ₃)	00620		N	U	EPA 300.0	ND	0.060 M/L
Total Suspended Solids	00515			U	EPA 160.1	330 M/L	10 M/L
Total Recoverable	00978			HNO ₃	EPA 200.7	ND	0.0030 M/L
Total Recoverable	00941			U	EPA 300.0	51 M/L	7.5 M/L
Total Recoverable	01113			HNO ₃	EPA 200.7	ND	0.0010 M/L
Total Recoverable	01118			HNO ₃	EPA 200.7	0.0033 M/L	0.0020 M/L
Total Recoverable	01114			HNO ₃	EPA 200.7	0.016 M/L	0.0030 M/L
Copper	31616			U	M7222D	ND	1.0 µg/100mL
	00406			U	M7222D	6.5	0.50
	00945			U	EPA 300.0	22 M/L	2.5 M/L
Nitrogen (as N)	00600			H ₂ SO ₄	EPA 300.0	1.9 M/L	0.20 M/L
Phosphorus (as P)	00665			H ₂ SO ₄	EPA 300.0	0.17 M/L	0.050 M/L
Conductance	00095			U	EPA 120.1	510 µmhos/cm	2.0 µmhos/cm

208

Notes and Explanation:

GROUNDWATER MONITORING REPORT - PART D

FLA0129939-DWIP-001 - Indiantown Company WWTF

Monitoring Location Site Number:

MWC-2 / R002

Well Type:

Compliance

Ground Water Class:

G-II

Sample Obtained: 2/99
 Sample Date: 2/16/99
 Well pumped before sampling? Yes No

Parameter	Store Code	Sampling Methods	Samples Filtered(Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
level (water measurement)	82545	TAPR	N/A	N/A	TAPR	25"	N/A
(as P)	00620	BALBR	N	U	EPA 300.0	ND	0.060 mg/L
Hardness (Total)	00515			U	EPA 160.1	110 mg/L	10 mg/L
(Total Recoverable)	00978			HNO ₃	EPA 200.7	ND	0.0050 mg/L
(as P)	00941			U	EPA 300.0	86 mg/L	7.5 mg/L
(Total Recoverable)	01113			HNO ₃	EPA 200.7	ND	0.0016 mg/L
(Total Recoverable)	01118			HNO ₃	EPA 200.7	0.0049 mg/L	0.0020 mg/L
Total Recoverable	01114			HNO ₃	EPA 200.7	ND	0.0030 mg/L
Coliforms	31616			SG	M9222D	ND	1.0 / 100 mL
	00486			U	MORVIC	6.1 ⁵⁰	0 ⁵⁰
(as P)	00945			U	EPA 300.0	4.3 mg/L	2.5 mg/L
(as P)	00600			H ₂ SO ₄	EPA 351.2	5.5 mg/L	0.120 mg/L
(as P)	00665			H ₂ SO ₄	EPA 365.4	2.11 mg/L	0.050 mg/L
(Compliance)	00095			U	EPA 120.1	610 ^{mg/L}	7.0 ^{mg/L}

209

Notes and Explanation:

GROUNDWATER MONITORING REPORT - PART D

Number: FLA0129939-DWIP-001 - Indiantown Company WWTF
 Year: 2/99
 Sample Collected: 2/09/99
 Well Pumped before sampling? Yes No

Monitoring Location Site Number: MWB-1 / R001
 Well Type: Background
 Ground Water Class: G-II

Parameter	Store Code	Sampling Methods	Samples Filtered(Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
Level (Measurement)	82545	Tape	N/A	N/A	Tape	4'	N/A
(as P)	00620	Balance	N	U	EPA 300.0	ND	0.060 Mg/L
Dissolved Solids	00515	Balance	N	U	EPA 160.1	280 Mg/L	10 Mg/L
Total Recoverable	00978	Balance	N	H ₂ O ₂	EPA 200.7	ND	0.0050 Mg/L
As	00941	Balance	N	U	EPA 300.0	86 Mg/L	7.5 Mg/L
Total Recoverable	01113	Balance	N	H ₂ O ₂	EPA 200.7	ND	0.0010 Mg/L
Total Recoverable	01118	Balance	N	H ₂ O ₂	EPA 200.7	ND	0.0050 Mg/L
Total Recoverable	01114	Balance	N	H ₂ O ₂	EPA 200.7	0.0020 Mg/L	0.0020 Mg/L
Chloride	31616	Tape	N	U	Mercuric	ND	1.0000 U/100ml
	00486	Balance	N	U	Mercuric	4.7 ug	0.50
	00945	Balance	N	U	EPA 300.0	2.8 Mg/L	0.25 Mg/L
Ammonia (as N)	00600	Balance	N	H ₂ SO ₄	EPA 300.2	2.0 Mg/L	0.20 Mg/L
Ammonia (as P)	00665	Balance	N	H ₂ SO ₄	EPA 360.4	0.18 Mg/L	0.050 Mg/L
Conductance	00095	Balance	N	U	EPA 160.1	100 uS/cm	2.0 uS/cm

210

Notes and Explanation:

GROUNDWATER MONITORING REPORT - PART D

FLA0129939-DWIP-001 - Indiantown Company WWTF

Monitoring Location Site Number:

MWB-2/R002

2/99
2/16/99
the cap removed before sampling? Yes No

Well Type:

Background

Ground Water Class:

G-II

Parameter	Store Code	Sampling Methods	Samples Filtered(Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
Temperature (measurement)	82545	TAPR	N/A	N/A	TAPR	12"	N/A
Iron (as Fe)	00620	BALLOW	N	U	EPA 300.0	ND	0.060 mg/L
Iron (as Fe) recoverable	00515			U	EPA 160.1	270 mg/L	10 mg/L
Iron (as Fe) Total Recoverable	00978			H ₂ O ₂	EPA 200.7	ND	0.0050 mg/L
Iron (as Fe) Total Recoverable	00941			U	EPA 300.0	79 mg/L	7.5 mg/L
Iron (as Fe) Total Recoverable	01113			H ₂ O ₂	EPA 200.7	ND	0.0010 mg/L
Iron (as Fe) Total Recoverable	01118			H ₂ O ₂	EPA 200.7	0.0027 mg/L	0.0020 mg/L
Iron (as Fe) Total Recoverable	01114			H ₂ O ₂	EPA 200.7	ND	0.0030 mg/L
Iron (as Fe)	31616			U	MA 222D	ND	1.0 mg/L / 100 mg/L
Iron (as Fe)	00488			U	MATHEK	5.9 mg/L	0.50 mg/L
Iron (as Fe)	00945			U	EPA 300.0	ND	2.5 mg/L
Iron (as Fe)	00600			H ₂ SO ₄	EPA 351.2	5.5 mg/L	0.20 mg/L
Iron (as Fe)	00665			H ₂ SO ₄	EPA 365.4	0.72 mg/L	0.050 mg/L
Iron (as Fe)	00095			U	EPA 120.1	480 mg/L	2.0 mg/L

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

ISSUE NAME: Indiantown Utilities
 MAILING ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
 MONITORING PERIOD From: 3/01/99
 LIMIT: Final
 CLASS SIZE: Minor

To: 3/31/99
 REPORT: Monthly
 GROUP: Domestic

WASTEWATER TREATMENT PLANT: Indiantown Company Wastewater Treatment Plant
 LOCATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
 GMS ID NO.: 5143P03291
 DISCHARGE POINT NUMBER: D001
 PLANT SIZE/TREATMENT TYPE: IIC


WAFR SITE NO.: 20552
 GMS TEST SITE NO.:

NO DISCHARGE FROM SITE

OPERATOR: Martin

Parameter	Sample Measurement	Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		Report (Daily Max.)	Report (Month Avg.)		0	0	0				
Chlorine	Permit Measurement	0	0	mgd	0	0	0	0	0	Hourly during any discharge	Calculated Flow
Free Chlorine	Sample Measurement	0	0	0	0	0	0	0	0	0	0
Free Chlorine	Permit Measurement				0.01 (Max.)			mg/L		Daily during any discharge	Grab
Dissolved Oxygen (DO)	Sample Measurement	0	0	0	0	0	0	0	0	0	0
Dissolved Oxygen (DO)	Permit Measurement				6.0 (Min.)	8.5 (Max.)		S.U.		Daily during any discharge	Grab
Dissolved Oxygen (DO)	Sample Measurement	0	0	0	0	0	0	0	0	0	0
Dissolved Oxygen (DO)	Permit Measurement				5.0 (Min.)			mg/L		Daily during any discharge	Grab
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

I, the undersigned, under penalty of law that I have personally examined and am familiar with the information submitted herein; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.

TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (YY/MM/DD)
Robert M. Post President		(561) 597-3496	4/23/99

STATEMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

MITTEE NAME: Indiantown Utilities
 BILLING ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
 MONITORING PERIOD From: 3/01/99
 LIMIT: Final
 CLASS SIZE: Minor

To: 3/31/99
 REPORT GROUP: Monthly Domestic

PLANT: Indiantown Company Wastewater Treatment Plant
 LOCATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
 GMS ID NO.: 5143P03291
 DISCHARGE POINT NUMBER: D002
 PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
 GMS TEST SITE NO.:

CITY: Martin

NO DISCHARGE FROM SITE

213

Parameter	Sample Measurement	Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		Report (Daily Max.)	Report (Month Avg.)								
Residual Chlorine (for dechlorination)	0	0	0	mgd	0	0	0	0	0	Hourly during any discharge	Calculated Flow
Residual Chlorine (Site No. EFF-2)	0	0	0	mg/L	0.01 (Max.)			0	0	Daily during any discharge	Grab
Residual Chlorine (Site No. EFF-2)	0	0	0	mg/L	0	0	0	0	0	0	0
Residual Chlorine (Site No. EFF-2)	0	0	0	mg/L	6.0 (Min.)	8.5 (Max.)		S.U.		Daily during any discharge	Grab
Residual Chlorine (Site No. EFF-2)	0	0	0	mg/L	0	0	0	0	0	0	0
Residual Chlorine (Site No. EFF-2)	0	0	0	mg/L	5.0 (Min.)			0	0	Daily during any discharge	Grab

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

MITTEE NAME: Indiantown Utilities
ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
MONITORING PERIOD From: 3/31/99
LIMIT: Final
CLASS SIZE: Minor

To: 3/31/99
REPORT GROUP: Monthly Domestic

PLANT NAME: Indiantown Company Wastewater Treatment Plant
ADDRESS: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: D003
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

CITY: Martin

NO DISCHARGE FROM SITE

Parameter	Sample Measurement	Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		(Daily Max.)	(Month Avg.)		(Min.)	(Max.)	(Min.)				
Flow	0	0	0	mgd	0	0	0	0	0	Hourly during any discharge	Calculated Flow
Chlorine Residual	0	0	0	S.U.	6.0 (Min.)	8.5 (Max.)	0	0	0	Daily during any discharge	grab
Free Chlorine	0	0	0	mg/L	0.01 (Max.)	0	0	0	0	Daily during any discharge	Grab
Dissolved Oxygen (DO)	0	0	0	mg/L	5.0 (Min.)	0	0	0	0	Daily during any discharge	Grab

7/2

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Southeast District, P.O. Box 15425, West Palm Beach, 33416

MITTEE NAME: Indiantown Utilities
 LONG ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
 MONITORING PERIOD From: 3/01/99
 LIMIT: Final
 CLASS SIZE: Minor

To: 3/31/99
 REPORT: Monthly
 GROUP: Domestic

ILITY: Indiantown Company Wastewater Treatment Plant
 ATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
 GMS ID NO.: 5143P03291
 DISCHARGE POINT NUMBER: R001
 PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
 GMS TEST SITE NO.:

NTY: Martin

Parameter		Quantity or Loading	Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
	Sample Measurement	335	MGD				MGD	0		
LET No. 50050 SITE No. EPP-6	Permit Measurement	30.4 (An.Avg.)	mgd						continuous with 5 readings/Week	Flow Meters with Totalizer
	Sample Measurement	355	MGD				MGD	0		
LET No. 50050 SITE No. EPP-6	Permit Measurement	Report (Mo.Avg.)	mgd						continuous with 5 readings/Week	Flow Meters with Totalizer
	Sample Measurement			6.6			Mg/L	0		
LET No. 50050 SITE No. EPP-6	Permit Measurement			20.0 (An.Avg.)			mg/L		Weekly	8-hour FPC
	Sample Measurement			4.5			Mg/L	0		
LET No. 50050 SITE No. EPP-6	Permit Measurement			25.0 (Mo.Avg.)	40.0/report (Week.Avg.)	60.0 (Max.)	mg/L		Weekly	8-hour FPC
	Sample Measurement			3.7			Mg/L	0		
LET No. 50050 SITE No. EPP-6	Permit Measurement			20.0 (An.Avg.)			mg/L		Weekly	8-hour FPC
	Sample Measurement			5.5			Mg/L	0		
LET No. 50050 SITE No. EPP-6	Permit Measurement			30.0 (Mo.Avg.)	45.0/report (Week.Avg.)	60.0 (Max.)	mg/L		Weekly	8-hour FPC
	Sample Measurement			6.7	7.4		S.U.	0		
LET No. 50050 SITE No. EPP-6	Permit Measurement			6.0 (Min.)	8.5 (Max.)		S.U.		Continuous	pH meter with 24 hour recording meter

215

DISCHARGE MONITORING REPORT - PART A (Continued)

UTILITY NAME: Indiantown Company Wastewater Treatment Plant

PERMIT NUMBER: FL0029939-001-DW1P

DISCHARGE POINT NUMBER: R004

WAFR SITE No.: 20552

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
ate, as N	Sample Measurement				14			mg/L	3		
Sample No. BPF-6	Permit Measurement				12.0 (Max.)			mg/L		Weekly	Grab
phorus, Total as P	Sample Measurement				2.1			mg/L	0		
Sample No. BPF-6	Permit Measurement				Report (Max.)			mg/L		Weekly	8-hour FPC
phorus, Total as P	Sample Measurement				4.6			mg/L	0		
Sample No. BPF-6	Permit Measurement				Report (Max.)			mg/L		Weekly	8-hour FPC
Coliform Bacteria	Sample Measurement				0.19			#/100ml	0		
Sample No. BPF-6	Permit Measurement				200 (An. Avg.)			#/100mL		Weekly	Grab
Coliform Bacteria	Sample Measurement				0.20	1		#/100ml	0		
Sample No. BPF-6	Permit Measurement				Report (Mo. Geo. Mean)	800 (Max.)		#/100mL		Weekly	Grab
for disinfection	Sample Measurement				1.2						
Sample No. BPF-6	Permit Measurement				0.5 (Min.)			mg/L		Continuous	TRC meter with 24 hour recording chart

276

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

mail this report to: Department of Environmental Protection, Southeast District, P.O. Box 15425, West Palm Beach, 33416

MITTEE NAME: Indiantown Utilities
LINE ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DWIP
MONITORING PERIOD From: 3/01/99
LIMIT: Final
CLASS SIZE: Minor

To: 3/31/99
REPORT:
GROUP: Monthly Domestic

ILITY: Indiantown Company Wastewater Treatment Plant
ATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: R002
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.:

NTY: Martin

Parameter	Sample Measurement	Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.		
	Sample Measurement	0.079		MGD				MGD	0		
	Permit Measurement	0.107 (An.Avg.)		mgd						Continuous with 5 readings/Week	Flow Meters with Totalizer
	Sample Measurement		0.045	MGD				MGD	0		
	Permit Measurement		Report (Mo.Avg.)	mgd						Frequency of Analysis	Sample Type
	Sample Measurement				6.6			M/L	0		
	Permit Measurement				20.0 (An.Avg.)			mg/L		Weekly	8-hour FPC
	Sample Measurement				4.5			M/L	0		
	Permit Measurement				25.0 (Mo.Avg.)	40.0/report (Week.Avg.)	60.0 (Max.)	mg/L		Weekly	8-hour FPC
	Sample Measurement				3.7			M/L	0		
	Permit Measurement				20.0 (An.Avg.)			mg/L		Weekly	8-hour FPC
	Sample Measurement				5.5			M/L	0		
	Permit Measurement				30.0 (Mo.Avg.)	45.0/report (Week.Avg.)	60.0 (Max.)	mg/L		Weekly	8-hour FPC
	Sample Measurement				6.9	7.4		S.U.	0		
	Permit Measurement				6.0 (Min.)	8.5 (Max.)		S.U.		Continuous	pH meter with 24 hour recording meter

217

DISCHARGE MONITORING REPORT - PART A (Continued)

UTILITY NAME: Indiantown Company Wastewater Treatment Plant

PERMIT NUMBER: FL0029939-001-DW1P DISCHARGE POINT NUMBER: R002

WAFR SITE No.: 20552

Parameter	Sample Measurement	Quantity or Loading		Units	Quality or Concentration		Units	No. Ex.	Frequency of Analysis	Sample Type
Ammonia Nitrogen	Sample Measurement				14		Mg/L	3		
Ammonia Nitrogen	Permit Measurement				12.0 (Max.)		mg/L		Weekly	Grab
Ammonia Nitrogen	Sample Measurement				2.1		Mg/L	0		
Ammonia Nitrogen	Permit Measurement				Report (Max.)		mg/L		Weekly	8-hour FPC
Ammonia Nitrogen	Sample Measurement				4.6		Mg/L	0		
Ammonia Nitrogen	Permit Measurement				Report (Max.)		mg/L		Weekly	8-hour FPC
Coliform Bacteria	Sample Measurement				0.19		#/100 mL	0		
Coliform Bacteria	Permit Measurement				200 (An.Avg.)		#/100mL		Weekly	Grab
Coliform Bacteria	Sample Measurement				0.20	1	#/100 mL	0		
Coliform Bacteria	Permit Measurement				Report (Mo. Geo. Mean)	800 (Max.)	#/100mL		Weekly	Grab
Chlorine Residual	Sample Measurement				1.2		Mg/L	0		
Chlorine Residual	Permit Measurement				0.5 (Min.)		mg/L		Continuous	TRC meter with 24 hour recording chart

218

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Southeast District, P.O. Box 15425, West Palm Beach, 33416

UTILITY NAME: Indiantown Utilities
MAILING ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
MONITORING PERIOD From: 10/01/99
LIMIT: Final
CLASS SIZE: Minor

To: 9/31/99
REPORT: Monthly
GROUP: Domestic

CITY: Indiantown Company Wastewater Treatment Plant
LOCATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: S143P03291
DISCHARGE POINT NUMBER: Influent Monitoring Point
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

CITY: Martin

Parameter	Sample Measurement	Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
EDM No. INF-15	Permit Measurement	* 0.585	Report (Mo. Avg.)	mgd						Continuous	Flow Meters
EDM No. INF-15	Sample Measurement				246			mg/L	0		
EDM No. INF-15	Permit Measurement				Report (Mo. Avg.)			mg/L		Weekly	16-hour FPC
EDM No. INF-15	Sample Measurement				220			mg/L	0		
EDM No. INF-15	Permit Measurement				Report (Mo. Avg.)			mg/L		Monthly	16-hour FPC

* METER NOT INSTALLED TO MEET NEW PERMIT CONDITIONS;

b7c

DAILY SAMPLE RESULTS - PART B
(PAGE ONE)

Plant Number: FL0029939-001-DWIP
 Date/Year: 3/99

Three-month Average Daily Flow: .409
 Daily Flow % of Permitted
 Capacity: 70%

of the Month	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30/31
meter/Unit/Monitoring Location Site Number																														
(mgd), EFF-6	410	390	400	400	370	380	380	410	340	380	370	400	440	460	420	410	420	380	400	370	400	410	420	370	370	420	410	430	370/410	
(mgd), EFF-7	110	101	107	121	100			107	119																113	108		105	111/122	
(mgd), INF-1																														
SS (mg/L), EFF-6	3.9							2.4							4.6							5.4							6.2	
SS (mg/L), INF-1	230							210							360							220							210	
mg/L, EFF-6	2.2							5.0							4.6							10							5.7	
mg/L, INF-1	150							140							380							170							260	
sd. units, EFF-6	7.0	6.9	7.1	7.4	7.2	7.1	7.1	7.0	7.0	7.1	7.0	7.0	7.1	7.0	7.0	7.0	7.2	7.1	7.2	7.1	7.1	7.1	7.1	7.0	7.3	7.1	7.1	7.0	7.2	7.0/7.3
Coliform Bacteria (#/100 mL), EFF-6		ND								ND						ND							1.0						ND	
Retention time for Fecal Coliform Bacteria sample, EFF-6		0815								0815						0815							0815							0815
For Disinfection (mg/L), EFF-6	1.7	1.9	2.2	1.8	1.5	1.5	2.1	1.6	1.8	1.5	1.9	2.2	2.2	2.1	2.2	1.7	2.1	1.6	1.9	1.8	2.0	1.9	1.6	1.5	2.0	2.2	1.4	1.7	1.2	1.6/2.2
Nitrogen (as N) (mg/L), EFF-6	21							20							17							16							12	
Phosphorus (as P) (mg/L), EFF-6	4.0							4.0							3.6							4.6							3.2	
sd. as N, EFF-6		14							14							14							6.1						3.1	

220

Staffing:

Shift Operator	Class <u>A</u>	Certificate No. <u>6805</u>	Name: <u>DEAN S. SMILBY JR.</u>
Shift Operator	Class <u>B</u>	Certificate No. <u>3624</u>	Name: <u>DON C. JOHNSON SR.</u>
Shift Operator	Class <u>B</u>	Certificate No. <u>6717</u>	Name: <u>JAMES G. HOWITT</u>
Operator	Class _____	Certificate No. _____	Name: _____

Effluent Disposal or Reclaimed Water Reuse: EVAP. / POND / IRRIGATION

Wet Weather Discharge Activated: Yes ___ No ___ Not Applicable X If yes, cumulative days of wet weather discharge: _____

If additional sheets necessary to list all certified operators necessary for required operations.

Date for
 Reporting
 (Month/Day/Year)
 Reporting
 Station
 No.

**DAILY SAMPLE RESULTS - PART B
(PAGE TWO)**

Permit Number: FL0029939-001-DW1P
 Reporting Year:

Three-month Average Daily Flow: n/a
 Daily Flow % of Permitted Capacity: n/a

of the Month	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30/31
Water/Unit/Monitoring Location Site Number																														
(mgd), EFF-1																														
(mgd), EFF-2																														
(mgd), EFF-3																														
(For Dechlorination) (mg/L), EFF-1																														
(For Dechlorination) (mg/L), EFF-2																														
(For Dechlorination) (mg/L), EFF-3																														
(d. units), EFF-1																														
(d. units), EFF-2																														
(d. units), EFF-3																														
cn, Dissolved (DO), EFF-1																														
cn, Dissolved (DO), EFF-2																														
cn, Dissolved (DO), EFF-3																														
Station Pond Water Elevation, EFF-1																														
Station Pond Water Elevation, EFF-2																														
Station Pond Water Elevation, EFF-3																														
Station Pond Water Elevation, EFF-4																														
Station Pond Water Elevation, EFF-5																														
elevation below the overflow, EFF-1																														
elevation below the overflow, EFF-2																														
elevation below the overflow, EFF-3																														
elevation below the overflow, EFF-4																														
elevation below the overflow, EFF-5																														

221

→ New Pond Structures (Not Installed) - Elevations (Not Shot)
 To meet new permit conditions at this time

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

MITTEE NAME: Indiantown Utilities
LINE ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
MONITORING PERIOD From: 3/01/99
LIMIT: Final
CLASS SIZE: Minor

To: 3/31/99
REPORT: Annual
GROUP: Domestic

ILITY: Indiantown Company Wastewater Treatment Plant
ATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: D001
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.:

NTY: Martin

CHECK HERE IF NO TOXIC SAMPLING WAS REQUIRED DURING THE YEAR

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Acute Static Renewal depths daily	Sample Measurement	0	0	0	0	0	0	0	0	0	0
LETING ANTI SITE NO. 1111	Permit Measurement				LC 50 >100 % (minimum)			percent		Annual	four grab samples over a 24 hour day
Acute Static Renewal nella loads	Sample Measurement	0	0	0	0	0	0	0	0	0	0
RET No. TAN 6H Site No. 1111	Permit Measurement				LC 50 >100 % (minimum)			percent		Annual	four grab samples over a 24 hour day
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

222

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

WASTE NAME: Indiantown Utilities
ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
MONITORING PERIOD From: 3/1/99
LIMIT: Final
CLASS SIZE: Minor

To: 3/31/99
REPORT: Annual
GROUP: Domestic

CITY: Indiantown Company Wastewater Treatment Plant
ADDRESS: 15851 S.W. Farms Road
 Indiantown, FL 34956
CONTACT: Martin

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: D002
PLANT SIZE/TREATMENT TYPE: IIC
WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

CHECK HERE IF NO TOXIC SAMPLING WAS REQUIRED DURING THE YEAR

Parameter	Measurement	Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Acute Static Renewal daphnia dubia	Sample Measurement	0	0	0	0	0	0	0	0	0	0
Chlorine Residual	Permit Measurement				LC 50 >100 % (minimum)			percent		Annual	four grab samples over a 24 hour day
Acute Static Renewal velociferia	Sample Measurement	0	0	0	0	0	0	0	0	0	0
Chlorine Residual	Permit Measurement				LC 50 >100 % (minimum)			percent		Annual	four grab samples over a 24 hour day
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

213

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

WITTEE NAME: Indiantown Utilities
LINE ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
MONITORING PERIOD From: 3/01/99
LIMIT: Final
CLASS SIZE: Minor

To: 3/31/99
REPORT GROUP: Annual Domestic

ILITY: Indiantown Company Wastewater Treatment Plant
ATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: D003
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

NTY: Martin

CHECK HERE IF NO TOXIC SAMPLING WAS REQUIRED DURING THE YEAR

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Acute Static Renewal daphnia dubia	Sample Measurement	0	0	0	0	0	0	0	0	0	0
USEPA SIB	Permit Measurement				LC 50 >100 % (minimum)			percent		Annual	four grab samples over a 24 hour day
Acute Static Renewal nela loadi	Sample Measurement	0	0	0	0	0	0	0	0	0	0
RET SIB	Permit Measurement				LC 50 >100 % (minimum)			percent		Annual	four grab samples over a 24 hour day
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

224

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

ITTEE NAME: Indiantown Utilities
 ING ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DWIP
 MONITORING PERIOD From: 4/01/99
 LIMIT: Final
 CLASS SIZE: Minor

To: 4/30/99
 REPORT: Monthly
 GROUP: Domestic

ITY: Indiantown Company Wastewater Treatment Plant
 TION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
 GMS ID NO.: 5143P03291
 DISCHARGE POINT NUMBER: D001
 PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
 GMS TEST SITE NO.:


NO DISCHARGE FROM SITE

TY: Martin

Parameter	Sample Measurement	Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		Report (Daily Max.)	Report (Month Avg.)								
	Sample Measurement	0	0	0	0	0	0	0	0	0	0
	Permit Measurement	Report (Daily Max.)	Report (Month Avg.)	mgd						Hourly during any discharge	Calculated Flow
	Sample Measurement	0	0	0	0	0	0	0	0	0	0
	Permit Measurement				0.01 (Max.)			mg/L		Daily during any discharge	Grab
0440	Sample Measurement	0	0	0	0	0	0	0	0	0	0
	Permit Measurement				6.0 (Min.)	8.5 (Max.)		S.U.		Daily during any discharge	Grab
	Sample Measurement	0	0	0	0	0	0	0	0	0	0
	Permit Measurement				5.0 (Min.)			mg/L		Daily during any discharge	Grab
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

225

Under penalty of law that I have personally examined and am familiar with the information submitted herein; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.

TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (YY/MM/DD)
Robert M. Post President		(561) 597-3496	5/17/99

CONTENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

MITTEE NAME: Indiantown Utilities
MAILING ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
MONITORING PERIOD From: 1/6/99
LIMIT: Final
CLASS SIZE: Minor

To: 1/30/99
REPORT: Monthly
GROUP: Domestic

CITY: Indiantown Company Wastewater Treatment Plant
LOCATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: D002
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

NO DISCHARGE FROM SITE

COUNTY: Martin

Parameter	Sample Measurement	Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		D	0		0	0	0				
Residual Chlorine (mg/L)	Permit Measurement	0	0	mgd	0	0	0	0	0	Hourly during any discharge	Calculated - Flow
for dechlorination	Sample Measurement	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	Permit Measurement	0	0	0	0.01 (Max.)			mg/L		Daily during any discharge	Grab
0.040	Sample Measurement	0	0	0	0	0	0	0	0	0	0
226 Residual Chlorine (mg/L)	Permit Measurement	0	0	0	6.0 (Min.)	8.5 (Max.)		S.U.		Daily during any discharge	Grab
on, Dissolved (DO)	Sample Measurement	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	Permit Measurement	0	0	0	5.0 (Min.)			mg/L		Daily during any discharge	Grab
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

MITTEE NAME: Indiantown Utilities
MAILING ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
MONITORING PERIOD From: 4/01/99
LIMIT: Final
CLASS SIZE: Minor

To: 4/30/99
REPORT GROUP: Monthly Domestic

PLANT NAME: Indiantown Company Wastewater Treatment Plant
LOCATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: S143P03291
DISCHARGE POINT NUMBER: D003
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

OPERATOR: Martin

NO DISCHARGE FROM SITE

Parameter	Sample Measurement	Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		No Report (Daily-Max.)	Report (Month Avg.)		mgd						
	0	0	0	0	0	0	0	0	0	0	0
	Permit Measurement	No Report (Daily-Max.)	Report (Month Avg.)	mgd						Hourly during any discharge	Calculated Flow
	0	0	0	0	0	0	0	0	0	0	0
	Permit Measurement				6.0 (Min.)	8.5 (Max.)	S.U.			Daily during any discharge	grab
	0	0	0	0	0	0	0	0	0	0	0
	Permit Measurement				0.01 (Max.)		mg/L			Daily during any discharge	Grab
	0	0	0	0	0	0	0	0	0	0	0
	Permit Measurement				5.0 (Min.)		mg/L			Daily during any discharge	Grab
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

227

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Southeast District, P.O. Box 15425, West Palm Beach, 33416

MITTEE NAME: Indiantown Utilities
LINE ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DWIP
MONITORING PERIOD From: 4/01/99
LIMIT: Final
CLASS SIZE: Minor

To: 4/30/99
REPORT: Monthly
GROUP: Domestic

ILITY: Indiantown Company Wastewater Treatment Plant
ATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: R001
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

NTY: Martin

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
	Sample Measurement	.342		MGD				MGD	0		
	Permit Measurement	0.4 (An.Avg.)		mgd						continuous with 5 readings/Week	Flow Meters with Totalizer
	Sample Measurement		.394	MGD				MGD	0		
	Permit Measurement		Report (Mo.Avg.)	mgd						continuous with 5 readings/Week	Flow Meters with Totalizer
	Sample Measurement				6.2			Mg/L	0		
	Permit Measurement				20.0 (An.Avg.)			mg/L		Weekly	8-hour FPC
	Sample Measurement				4.2			Mg/L	0		
	Permit Measurement				25.0 (Mo.Avg.)	40.0/report (Week.Avg.)	60.0 (Max.)	mg/L		Weekly	8-hour FPC
	Sample Measurement				3.6			Mg/L	0		
	Permit Measurement				20.0 (An.Avg.)			mg/L		Weekly	8-hour FPC
	Sample Measurement				4.1			Mg/L	0		
	Permit Measurement				30.0 (Mo.Avg.)	45.0/report (Week.Avg.)	60.0 (Max.)	mg/L		Weekly	8-hour FPC
	Sample Measurement				6.7	7.6		S.U.	0		
	Permit Measurement				6.0 (Min.)	8.5 (Max.)		S.U.		Continuous	pH meter with 24 hour recording meter

228

No. EPT

DISCHARGE MONITORING REPORT - PART A (Continued)

PLANT NAME: Indiantown Company Wastewater Treatment Plant

PERMIT NUMBER: FL0029939-001-DWIP DISCHARGE POINT NUMBER: R001

WAFR SITE No.: 20552

Parameter		Quantity or Loading	Units	Quality or Concentration	Units	No. Ex.	Frequency of Analysis	Sample Type
Ammonia Nitrogen, as N	Sample Measurement			7.7	mg/L	0		
Ammonia Nitrogen, as N	Permit Measurement			12.0 (Max.)	mg/L		Weekly	Grab
Ammonia Nitrogen, Total as N	Sample Measurement			18	mg/L	0		
Ammonia Nitrogen, Total as N	Permit Measurement			Report (Max.)	mg/L		Weekly	8-hour FPC
Orthophosphate, Total as P	Sample Measurement			5.1	mg/L	0		
Orthophosphate, Total as P	Permit Measurement			Report (Max.)	mg/L		Weekly	8-hour FPC
Coliform Bacteria	Sample Measurement			0.14	#/100mL	0		
Coliform Bacteria	Permit Measurement			200 (An. Avg.)	#/100mL		Weekly	Grab
Coliform Bacteria	Sample Measurement			0	#/100mL	0		
Coliform Bacteria	Permit Measurement			Report (Mo. Geo. Mean)	800 (Max.)		Weekly	Grab
Chlorine Residual for disinfection	Sample Measurement			1.2	mg/L	0		
Chlorine Residual for disinfection	Permit Measurement			0.5 (Min.)	mg/L		Continuous	TRC meter with 24 hour recording chart

229

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

on ~~Completed~~ mail this report to: Department of Environmental Protection, Southeast District, P.O. Box 15425, West Palm Beach, 33416

MONITOR NAME: Indiantown Utilities
MAILING ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
MONITORING PERIOD From: 4/10/99
LIMIT: Final
CLASS SIZE: Minor

To: 4/30/99
REPORT GROUP: Monthly Domestic

CITY: Indiantown Company Wastewater Treatment Plant
LOCATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: R002
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

CITY: Martin

230

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.		
	Sample Measurement	0.070		MGD				MGD	0		
	Permit Measurement	0.107 (An.Avg.)		mgd						Continuous with 5 readings/Week	Flow Meters with Totalizer
	Sample Measurement		0.081	MGD				MGD	0		
	Permit Measurement		Report (Mo.Avg.)	mgd						Frequency of Analysis	Sample Type
	Sample Measurement				6.2			Mg/L	0		
	Permit Measurement				20.0 (An.Avg.)			mg/L		Weekly	8-hour FPC
	Sample Measurement				4.2			Mg/L	0		
	Permit Measurement				25.0 (Mo.Avg.)	40.0/report (Week.Avg.)	60.0 (Max.)	mg/L		Weekly	8-hour FPC
	Sample Measurement				3.6			Mg/L	0		
	Permit Measurement				20.0 (An.Avg.)			mg/L		Weekly	8-hour FPC
	Sample Measurement				4.1			Mg/L	0		
	Permit Measurement				30.0 (Mo.Avg.)	45.0/report (Week.Avg.)	60.0 (Max.)	mg/L		Weekly	8-hour FPC
	Sample Measurement				6.7	7.6		SU	0		
	Permit Measurement				6.0 (Min.)	8.5 (Max.)		S.U.		Continuous	pH meter with 24 hour recording meter

DISCHARGE MONITORING REPORT - PART A (Continued)

ILITY NAME: Indiantown Company Wastewater Treatment Plant

PERMIT NUMBER: FL0029939-001-DW1P

DISCHARGE POINT NUMBER: R002

WAFR SITE No.: 20552

Parameter		Quantity or Loading	Units	Quality or Concentration	Units	No. Ex.	Frequency of Analysis	Sample Type
16, as N 3/111 KPL	Sample Measurement			7.7	Mg/L	0		
CE Site No. EPP-6	Permit Measurement			12.0 (Max.)	mg/L		Weekly	Grab
per, Total as N	Sample Measurement			18	Mg/L	0		
CE Site No. EPP-5	Permit Measurement			Report (Max.)	mg/L		Weekly	8-hour FPC
horat, Yield as P 2/10/11/11	Sample Measurement			5.7	Mg/L	0		
CE Site No. EPP-5	Permit Measurement			Report (Max.)	mg/L		Weekly	8-hour FPC
Coliform Bacteria N-1114	Sample Measurement			0.14	#/100mL	0		
CE Site No. EPP-7	Permit Measurement			200 (An.Avg.)	#/100mL		Weekly	Grab
Coliform Bacteria	Sample Measurement			0	#/100mL	0		
CE Site No. EPP-7	Permit Measurement			Report (Mo. Geo. Mean)	800 (Max.)		Weekly	Grab
for disinfection	Sample Measurement			1.2	Mg/L	0		
CE Site No. EPP-7	Permit Measurement			0.5 (Min.)	mg/L		Continuous	TRC meter with 24 hour recording chart

231

No. EFF-
 No. BPT

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Southeast District, P.O. Box 15425, West Palm Beach, 33416

WITTEE NAME: Indiantown Utilities
LINE ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
MONITORING PERIOD From: 4/10/99
LIMIT: Final
CLASS SIZE: Minor

To: 4/30/99
REPORT: Monthly
GROUP: Domestic

CITY: Indiantown Company Wastewater Treatment Plant
LOCATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: Influent Monitoring Point
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

CITY: Martin

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
	Sample Measurement	*									
	Permit Measurement	0.585	Report (Mo. Avg.)	mgd						Continuous	Flow Meters
	Sample Measurement				265			mg/L	0		
	Permit Measurement				Report (Mo. Avg.)					Weekly	16-hour FPC
	Sample Measurement				195			mg/L	0		
	Permit Measurement				Report (Mo. Avg.)					Monthly	16-hour FPC

* METER NOT YET INSTALLED TO MEET NEW PERMIT CONDITIONS

**DAILY SAMPLE RESULTS - PART B
(PAGE ONE)**

File Number: FL0029939-001-DW1P
 Year: 2005
 Name: [unclear]

Three-month Average Daily Flow: 400
 Daily Flow % of Permitted
 Capacity: 68%

of the Month name/USE/monitoring Location Site Number	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30/31
(mg/L), EFF-6	100	360	380	370	380	360	380	370	400	410	420	400	370	330	380	450	450	420	420	400	370	400	370	430	450	400	370	370	380	370
(mg/L), EFF-7	116	103			111	109	101	105	097			118	110	125	100	107			113	121	116	090	111			115	107	151	126	108
(mg/L), INF-1																														
DS (mg/L), EFF-6					3.9							4.7								5.2						3.1				
DS (mg/L), INF-1					250							330								240						240				
mg/L), EFF-6					4.6							4.8								3.8						3.2				
mg/L), INF-1					180							190								190						220				
td. units), EFF-6	7.1	7.2	7.2	7.2	7.2	7.0	7.2	7.1	7.3	7.1	7.3	7.2	7.2	7.2	7.2	7.6	7.4	7.2	7.1	6.9	7.0	7.2	7.1	7.1	7.0	7.2	7.4	7.2	7.3	
Coliform Bacteria (#/100 mL), EFF-6						ND							ND							ND						ND				
ation time for Fecal Coliform Bacteria sample, EFF-6						0815							0815							0815							0815			
(For Disinfection) (mg/L), EFF-6	2.2	1.6	1.9	2.1	1.5	1.8	2.0	1.7	2.8	2.1	2.0	1.6	1.2	1.5	1.6	1.6	1.6	1.5	1.9	1.9	1.4	1.9	1.4	1.6	1.4	1.8	1.5	1.7	1.4	
Nitrogen (as N) (mg/L), EFF-6					12							18								16						10				
Phosphorus (as P) (mg/L), EFF-6					3.4							5.7								3.3						4.0				
g, as N, EFF-6						3.3						*								7.7						0.48				

233

DO NOT WRITE IN THESE SPACES

Signature: _____ Name: _____
 Shift Operator Class A Certificate No. 6205 Name: _____
 Shift Operator Class B Certificate No. 2634 Name: _____
 Shift Operator Class B Certificate No. 6777 Name: _____

Effluent Disposal or Reclaimed Water Reuse: EVAPORATION / PUMP POND / IRRIGATION
 Wet Weather Discharge Activated: Yes ___ No ___ Not Applicable X If yes, cumulative days of wet weather discharge: _____
 Additional sheets necessary to list all certified operators necessary for required operations.

**DAILY SAMPLE RESULTS - PART B
(PAGE TWO)**

it Number: FL0029939-001-DW1P
 h/Year:

Three-month Average Daily Flow: n/a
 Daily Flow % of Permitted Capacity: n/a

of the Month	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30/31	
near/Under Monitoring Location Site Number																															
(mg/l), EFF-1																															
(mg/l), EFF-2																															
(mg/l), EFF-3																															
(For Dechlorination) (mg/L), EFF-1																															
(For Dechlorination) (mg/L), EFF-2																															
(For Dechlorination) (mg/L), EFF-3																															
id. water, EFF-1																															
id. water, EFF-2																															
id. water, EFF-3																															
ca, Dissolved (DO), EFF-1																															
ca, Dissolved (DO), EFF-2																															
ca, Dissolved (DO), EFF-3																															
inlet Pond Water Elevation, EFF-1																															
inlet Pond Water Elevation, EFF-2																															
inlet Pond Water Elevation, EFF-3																															
inlet Pond Water Elevation, EFF-4																															
inlet Pond Water Elevation, EFF-5																															
elevation below the overflow, EFF-1																															
elevation below the overflow, EFF-2																															
elevation below the overflow, EFF-3																															
elevation below the overflow, EFF-4																															
elevation below the overflow, EFF-5																															

234

→ Now Pond Stairs (NOT INSTALLED + FISHWAYS (NOT SHOT) TO MEET NEW PERMIT REQUIREMENTS

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

MITTEE NAME: Indiantown Utilities
LINE ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
MONITORING PERIOD From: 4/01/99
LIMIT: Final
CLASS SIZE: Minor

To: 4/30/99
REPORT GROUP: Annual Domestic

ILP/STP NO: Indiantown Company Wastewater Treatment Plant
ATTN: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: D001
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

NTS: 100% Martin

CHECK HERE IF NO TOXIC SAMPLING WAS REQUIRED DURING THE YEAR

Parameter	Quantity or Loading	Units	Quality or Concentration				Units	No. Ex.	Frequency of Analysis	Sample Type
Acute Static Renewal daphnia dubia	0	0	0	0	0	0	0	0	0	
Permit Measurement			LC 50 >100% (minimum)			percent		Annual	four grab samples over a 24 hour day	
Acute Static Renewal inella leadi	0	0	0	0	0	0	0	0	0	
Permit Measurement			LC 50 >100% (minimum)			percent		Annual	four grab samples over a 24 hour day	
Sample Measurement										
Permit Measurement										
Sample Measurement										
Permit Measurement										
Sample Measurement										
Permit Measurement										
Sample Measurement										
Permit Measurement										
Sample Measurement										
Permit Measurement										

235

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

CITY NAME: Indiantown Utilities
ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DWIP
MONITORING PERIOD From: 4/01/99
LIMIT: Final
CLASS SIZE: Minor

To: 4/30/99
REPORT GROUP: Annual Domestic

CITY: Indiantown Company Wastewater Treatment Plant
LOCATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: D002
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

CITY: Martin

CHECK HERE IF NO TOXIC SAMPLING WAS REQUIRED DURING THE YEAR

236

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Acute Toxic Renewal taphala dubia	Sample Measurement	0	0	0	0	0	0	0	0	0	0
ETP	Permit Measurement				LC 50 >100 % (minimum)			percent		Annual	four grab samples over a 24 hour day
Acute Toxic Renewal nela load	Sample Measurement	0	0	0	0	0	0	0	0	0	0
ETP	Permit Measurement				LC 50 >100 % (minimum)			percent		Annual	four grab samples over a 24 hour day
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

MITTEE NAME: Indiantown Utilities
MAILING ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DWIP
MONITORING PERIOD From: 4/01/99
LIMIT: Final
CLASS SIZE: Minor

To: 4/30/99
REPORT GROUP: Monthly Domestic

FACILITY: Indiantown Company Wastewater Treatment Plant
LOCATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: D003
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

OPERATOR: Martin

NO DISCHARGE FROM SITE

Parameter	Sample Measurement	Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		(Daily Max.)	(Month Avg.)		(Min.)	(Max.)					
	0	0	0	0	0	0	0	0	0	0	0
Site No. EPP-3	Permit Measurement	Report (Daily Max.)	Report (Month Avg.)	mgd						Hourly during any discharge	Calculated Flow
00400	Sample Measurement	0	0	0	0	0	0	0	0	0	0
Site No. EPP-3	Permit Measurement				6.0 (Min.)	8.5 (Max.)	S.U.			Daily during any discharge	grab
for dechlorination	Sample Measurement	0	0	0	0	0	0	0	0	0	0
Site No. EPP-3	Permit Measurement				0.01 (Max.)		mg/L			Daily during any discharge	Grab
237 cn, Dissolved (DO)	Sample Measurement	0	0	0	0	0	0	0	0	0	0
Site No. EPP-3	Permit Measurement				5.0 (Min.)		mg/L			Daily during any discharge	Grab
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

VITTEE NAME: Indiantown Utilities
LINE ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DWIP
MONITORING PERIOD From: 4/01/99
LIMIT: Final
CLASS SIZE: Minor

To: 4/30/99
REPORT: Annual
GROUP: Domestic

CITY: Indiantown Company Wastewater Treatment Plant
ATTENTION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: D003
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

NTY: Martin

CHECK HERE IF NO TOXIC SAMPLING WAS REQUIRED DURING THE YEAR

Parameter		Quantity or Loading			Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Acute Static Renewal daphnia dubia	Sample Measurement	0	0	0	0	0	0	0	0	0	0
Chloride	Permit Measurement				LC 50 >100 % (minimum)			percent		Annual	four grab samples over a 24 hour day
Acute Static Renewal netto total	Sample Measurement	0	0	0	0	0	0	0	0	0	0
RETENTION TIME	Permit Measurement				LC 50 >100 % (minimum)			percent		Annual	four grab samples over a 24 hour day
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

238

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

ISSUE NAME: Indiantown Utilities
ISSUING ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
MONITORING PERIOD From: 5/01/99
LIMIT: Final
CLASS SIZE: Minor

To: 5/31/99
REPORT: Monthly
GROUP: Domestic

ACTIVITY: Indiantown Company Wastewater Treatment Plant
LOCATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: D001
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

ACTIVITY: Martin

NO DISCHARGE FROM SITE

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		D	D		D	D	D				
	Sample Measurement	0	0	D	0	0	0	0	0	0	0
	Permit Measurement	Report (Daily Max.)	Report (Month Avg.)	mgd						Hourly during any discharge	Calculated Flow
	Sample Measurement	0	0	D	0	0	0	0	0	0	0
	Permit Measurement				0.01 (Max.)			mg/L		Daily during any discharge	Grab
	Sample Measurement	0	0	D	0	0	0	0	0	0	0
	Permit Measurement				6.0 (Min.)	8.5 (Max.)		S.U.		Daily during any discharge	Grab
	Sample Measurement	0	0	D	0	0	0	0	0	0	0
	Permit Measurement				5.0 (Min.)			mg/L		Daily during any discharge	Grab
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

239

I, under penalty of law that I have personally examined and am familiar with the information submitted herein; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.

TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT Robert M. Post President	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT 	TELEPHONE NO (561) 597-3496	DATE (YY/MM/DD) 96 6/14/99
--	---	---------------------------------------	---

IDENTIFY AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

No. TAB
No. TITL

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

MITTEE NAME: Indiantown Utilities
 LINE ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DWIP
 MONITORING PERIOD From: 2/01/99
 LIMIT: Final
 CLASS SIZE: Minor

To: 5/31/99
 REPORT: Monthly
 GROUP: Domestic

ILITY: Indiantown Company Wastewater Treatment Plant
 ATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
 GMS ID NO.: 5143P03291
 DISCHARGE POINT NUMBER: D002
 PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
 GMS TEST SITE NO.:

NO DISCHARGE FROM SITE

NTY: Martin

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
	Sample Measurement	0	0	0	0	0	0	0	0	0	0
Permit Report (Daily Max.)	Permit Measurement	0	0	mgd						Hourly during any discharge	Calculated Flow
	Sample Measurement	0	0	0	0	0	0	0	0	0	0
Permit Report (Month Avg.)	Permit Measurement				0.01 (Max.)			mg/L		Daily during any discharge	Grab
	Sample Measurement	0	0	0	0	0	0	0	0	0	0
Permit Report (Daily Max.)	Permit Measurement				6.0 (Min.)	8.5 (Max.)		S.U.		Daily during any discharge	Grab
	Sample Measurement	0	0	0	0	0	0	0	0	0	0
Permit Report (Month Avg.)	Permit Measurement				5.0 (Min.)			mg/L		Daily during any discharge	Grab
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

240

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

* Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

MITTEE NAME: Indiantown Utilities
 LINO ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
 MONITORING PERIOD From: 5/21/99
 LIMIT: Final
 CLASS SIZE: Minor

To: 5/31/99
 REPORT: Monthly
 GROUP: Domestic

ILITY: Indiantown Company Wastewater Treatment Plant
 ATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
 GMS ID NO.: 5143P03291
 DISCHARGE POINT NUMBER: D003
 PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
 GMS TEST SITE NO.: _____

NTY: Martin

NO DISCHARGE FROM SITE

Parameter	Sample Measurement	Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		Report (Daily Max.)	Report (Month Avg.)								
Site No. EPT-3	0	0	0	mgd	0	0	0	0	0	Hourly during any discharge	Calculated Flow
Site No. EPT-3	0	0	0		0	0	0	0	0	Daily during any discharge	grab
for dechlorination	0	0	0		6.0 (Min.)	8.5 (Max.)		S.U.		Daily during any discharge	grab
Site No. EPT-3	0	0	0		0.01 (Max.)			mg/L		Daily during any discharge	Grab
en, Dissolved (DO)	0	0	0		0	0	0	0	0	Daily during any discharge	Grab
Site No. EPT-3					5.0 (Min.)			mg/L		Daily during any discharge	Grab

247

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Southeast District, P.O. Box 15425, West Palm Beach, 33416

MITTEE NAME: Indiantown Utilities
 LINE ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
 MONITORING PERIOD From: 5/27/79
 LIMIT: Final
 CLASS SIZE: Minor

To: 5/31/79
 REPORT: Monthly
 GROUP: Domestic

FACILITY: Indiantown Company Wastewater Treatment Plant
 LOCATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
 GMS ID NO.: 5143P03291
 DISCHARGE POINT NUMBER: R001
 PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
 GMS TEST SITE NO.: _____

CITY: Martin

242

Parameter	Quantity or Loading	Units	Quality or Concentration	Units	No. Ex.	Frequency of Analysis	Sample Type
Sample Measurement	.351	MGD		MGD	0		
Permit Measurement	0.4 (An. Avg.)	mgd				continuous with 5 readings/Week	Flow Meters with Totalizer
Sample Measurement	.391	MGD		MGD	0		
Permit Measurement	Report (Mo. Avg.)	mgd				continuous with 5 readings/Week	Flow Meters with Totalizer
Sample Measurement			5.7	mg/L	0		
Permit Measurement			20.0 (An. Avg.)	mg/L		Weekly	8-hour FPC
Sample Measurement			5.8	mg/L	0		
Permit Measurement			25.0 (Mo. Avg.)	mg/L		Weekly	8-hour FPC
			40.0/report (Week. Avg.)				
			60.0 (Max.)				
Sample Measurement			3.4	mg/L	0		
Permit Measurement			20.0 (An. Avg.)	mg/L		Weekly	8-hour FPC
Sample Measurement			1.7	mg/L	0		
Permit Measurement			30.0 (Mo. Avg.)	mg/L		Weekly	8-hour FPC
			45.0/report (Week. Avg.)				
			60.0 (Max.)				
Sample Measurement			7.0	S.U.	0		
Permit Measurement			6.0 (Min.)	S.U.		Continuous	pH meter with 24 hour recording meter
			7.8				
			8.5 (Max.)				

DISCHARGE MONITORING REPORT - PART A (Continued)

UTILITY NAME: Indiantown Company Wastewater Treatment Plant

PERMIT NUMBER: FL0029939-001-DW1P

DISCHARGE POINT NUMBER: R004

WAFR SITE No.: 20552

Parameter	Sample Measurement	Quantity or Loading		Units	Quality or Concentration		Units	No. Ex.	Frequency of Analysis	Sample Type
Ammonia Nitrogen, as N No. 3005	Sample Measurement				2.21		Mg/L	0		
REDACTED Site No. EFF-6	Permit Measurement				12.0 (Max.)		mg/L		Weekly	Grab
Orthophosphate, Total as P No. 3005	Sample Measurement				13.0		Mg/L	0		
REDACTED Site No. EFF-6	Permit Measurement				Report (Max.)		mg/L		Weekly	8-hour FPC
Ammonia Nitrogen, Total as N No. 3005	Sample Measurement				3.9		Mg/L	0		
REDACTED Site No. EFF-6	Permit Measurement				Report (Max.)		mg/L		Weekly	8-hour FPC
Coliform Bacteria	Sample Measurement				0.4		#/100mL	0		
REDACTED Site No. EFF-6	Permit Measurement				200 (An. Avg.)		#/100mL		Weekly	Grab
Coliform Bacteria	Sample Measurement				3	11	#/100mL	0		
REDACTED Site No. EFF-6	Permit Measurement				Report (Mo. Geo. Mean)	800 (Max.)	#/100mL		Weekly	Grab
Chlorine Residual for disinfection	Sample Measurement				1.0		Mg/L	0		
REDACTED Site No. EFF-6	Permit Measurement				0.5 (Min.)		mg/L		Continuous	TRC meter with 24 hour recording chart

243

NAME
Address
City
State
Zip

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Southeast District, P.O. Box 15425, West Palm Beach, 33416

MITTEE NAME: Indiantown Utilities
MAILING ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
MONITORING PERIOD From: _____
LIMIT: Final
CLASS SIZE: Minor

To: _____
REPORT: Monthly
GROUP: Domestic

UTILITY: Indiantown Company Wastewater Treatment Plant
LOCATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: R002
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

PROPERTY: Martin

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.		
	Sample Measurement	.063		MGD				MGD	0		
REPT NO. 00000001 SITE NO. EPP-6	Permit Measurement	0.107 (An.Avg.)		mgd						Continuous with 5 readings/Week	Flow Meters with Totalizer
	Sample Measurement		.105	MGD				MGD	0		
REPT NO. 00000001 SITE NO. EPP-6	Permit Measurement		Report (Mo.Avg.)	mgd						Frequency of Analysis	Sample Type
	Sample Measurement				2.7			MGD	0		
REPT NO. 00000001 SITE NO. EPP-6	Permit Measurement				20.0 (An.Avg.)			mg/L		Weekly	8-hour FPC
	Sample Measurement				3.8			MGD	0		
REPT NO. 00000001 SITE NO. EPP-6	Permit Measurement				25.0 (Mo.Avg.)	40.0/report (Week.Avg.)	60.0 (Max.)	mg/L		Weekly	8-hour FPC
	Sample Measurement				3.4			MGD	0		
REPT NO. 00000001 SITE NO. EPP-6	Permit Measurement				20.0 (An.Avg.)			mg/L		Weekly	8-hour FPC
	Sample Measurement				1.7			MGD	0		
REPT NO. 00000001 SITE NO. EPP-6	Permit Measurement				30.0 (Mo.Avg.)	45.0/report (Week.Avg.)	60.0 (Max.)	mg/L		Weekly	8-hour FPC
	Sample Measurement				7.0	7.8		S.U.	0		
REPT NO. 00000001 SITE NO. EPP-6	Permit Measurement				6.0 (Min.)	8.5 (Max.)		S.U.		Continuous	pH meter with 24 hour recording meter

DISCHARGE MONITORING REPORT - PART A (Continued)

PLANT NAME: Indiantown Company Wastewater Treatment Plant

PERMIT NUMBER: FL0029939-001-DW1P

DISCHARGE POINT NUMBER: R002

WAFR SITE No.: 20552

Parameter		Quantity or Loading	Units	Quality or Concentration		Units	No. Ex.	Frequency of Analysis	Sample Type
Ammonia Nitrogen	Sample Measurement			2.21		mg/L	0		
Ammonia Nitrogen	Permit Measurement			12.0 (Max.)		mg/L		Weekly	Grab
Ammonia Nitrogen, Total as N	Sample Measurement			13.0		mg/L	0		
Ammonia Nitrogen, Total as N	Permit Measurement			Report (Max.)		mg/L		Weekly	8-hour FPC
Ammonia Nitrogen, Total as P	Sample Measurement			3.7		mg/L	0		
Ammonia Nitrogen, Total as P	Permit Measurement			Report (Max.)		mg/L		Weekly	8-hour FPC
Coliform Bacteria	Sample Measurement			8.4		#/100ml	0		
Coliform Bacteria	Permit Measurement			200 (An.Avg.)		#/100ml		Weekly	Grab
Coliform Bacteria	Sample Measurement			3	11	#/100ml	0		
Coliform Bacteria	Permit Measurement			Report (Mo. Geo. Mean)	800 (Max.)	#/100ml		Weekly	Grab
Chlorine Residual for disinfection	Sample Measurement			1.0		mg/L	0		
Chlorine Residual for disinfection	Permit Measurement			0.5 (Min.)		mg/L		Continuous	TRC meter with 24 hour recording chart

245

Form No. 3005B

PLANT NAME

No. 0002
No. 0001

DAILY SAMPLE RESULTS - PART B
(PAGE ONE)

it Number: FL0029939-001-DWIP
Year: 2013
Date: 11/11/13

Three-month Average Daily Flow:
Daily Flow % of Permitted
Capacity:

of the Month	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30/31	
meter/Units/Monitoring Location Site Number																															
(mgd), EFF-6	370	430	350	340	350	380	350	370	450	400	400	380	310	400	430	420	430	350	370	370	430	350	410	370	410	360	380	400	350	400	
(mgd), INF-7			119	225	103	281	151			121	163	115	171				203	224	178	115	114			241	252	207	154	175			
(mgd), INF-1																															
DS (mg/L), EFF-6				4.1							5.6							4.4							3.2						
DS (mg/L), INF-1											2.21							3.15						2.55							
mg/L), EFF-6				1.2							2.2							2.4							1.0						
mg/L), INF-1				2.02							2.70							1.68							1.90						
(d. units), EFF-6	1.3	7.1	7.1	7.3	7.1	7.2	7.4	7.2	7.4	7.2	7.2	7.8	7.2	7.1	7.0	7.1	7.1	7.2	7.4	7.1	7.3	7.3	7.1	7.1	7.2	7.1	7.1	7.0	7.2	7.2/7.0	
Coliform Bacteria (#/100 mL), EFF-6				1							1							1							1						
ation time for Fecal Coliform Bacteria sample, EFF-6				1500							1500							1500							1500						
(For Disinfection) (mg/L), EFF-6	1.9	1.4	1.5	1.8	1.8	1.4	2.7	1.8	1.7	1.5	1.9	2.0	1.5	1.2	1.0	1.6	1.3	1.8	1.8	1.4	1.5	1.7	1.7	1.3	1.8	1.5	1.8	2.1	1.7/1.5		
Nitrogen (as N) (mg/L), EFF-6				15.0							10.4							9.17							5.15						
Phosphorus (as P) (mg/L), EFF-6				2.12							3.2							2.54							3.17						
c, as N, EFF-6				2.21							1.66							0.04							0.16						

247

Staffing:
 Shift Operator Class A Certificate No. 6805 Name: JUAN S. SMILBY, JR.
 Shift Operator Class B Certificate No. 3634 Name: DON C. JOHNSON, SR.
 Shift Operator Class B Certificate No. 6747 Name: JAMES G. HUNTT

Effluent Disposal or Reclaimed Water Reuse: EVAP/PORC. PONDS/IRRIGATION
 Wet Weather Discharge Activated: Yes ___ No ___ Not Applicable X If yes, cumulative days of wet weather discharge: _____
 Additional sheets necessary to list all certified operators necessary for required operations: _____

**DAILY SAMPLE RESULTS - PART B
(PAGE TWO)**

Number: FL0029939-001-DW1P
Year:

Three-month Average Daily Flow: n/a
Daily Flow % of Permitted: n/a
Capacity:

of the Month	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30/31
Water/Unit/Monitoring Location Site Number																														
(mgd), EFF-1																														
(mgd), EFF-2																														
(mgd), EFF-3																														
(For Dechlorination) (mg/L), EFF-1																														
(For Dechlorination) (mg/L), EFF-2																														
(For Dechlorination) (mg/L), EFF-3																														
(d. units), EFF-1																														
(d. units), EFF-2																														
(d. units), EFF-3																														
cn, Dissolved (DO), EFF-1																														
cn, Dissolved (DO), EFF-2																														
cn, Dissolved (DO), EFF-3																														
Station Pond Water Elevation, EFF-1																														
Station Pond Water Elevation, EFF-2																														
Station Pond Water Elevation, EFF-3																														
Station Pond Water Elevation, EFF-4																														
Station Pond Water Elevation, EFF-5																														
elevation below the overflow, EFF-1																														
elevation below the overflow, EFF-2																														
elevation below the overflow, EFF-3																														
elevation below the overflow, EFF-4																														
elevation below the overflow, EFF-5																														

248

Since there have been no rain for several days, the water levels will be reflected in the same manner.

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

ISSUE NAME: Indiantown Utilities
 MAILING ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
 MONITORING PERIOD From: 5/01/99
 LIMIT: Final
 CLASS SIZE: Minor

To: 5/31/99
 REPORT: Annual
 GROUP: Domestic

CITY: Indiantown Company Wastewater Treatment Plant
 LOCATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
 GMS ID NO.: 5143P03291
 DISCHARGE POINT NUMBER: D002
 PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
 GMS TEST SITE NO.: _____

ACTIVITY: Martin

CHECK HERE IF NO TOXIC SAMPLING WAS REQUIRED DURING THE YEAR

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Acute Static Renewal Jephtha dicitia	Sample Measurement	0	0	0	0	0	0	0	0	0	0
ETP STATION 001 Site No. EPP 001	Permit Measurement				LC 50 >100 % (minimum)			percent		Annual	four grab samples over a 24 hour day
Acute Static Renewal neffa loadal	Sample Measurement	0	0	0	0	0	0	0	0	0	0
RECONSTRUCTION PLANT Site No. EPP 001	Permit Measurement				LC 50 >100 % (minimum)			percent		Annual	four grab samples over a 24 hour day
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

252

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

UTILITY NAME: Indiantown Utilities
 ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
 MONITORING PERIOD From: 5/01/99
 LIMIT: Final
 CLASS SIZE: Minor

To: 5/31/99
 REPORT: Annual
 GROUP: Domestic

LOCATION: Indiantown Company Wastewater Treatment Plant
 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
 GMS ID NO.: 5143P03291
 DISCHARGE POINT NUMBER: D003
 PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
 GMS TEST SITE NO.: _____

UTILITY: Martin

CHECK HERE IF NO TOXIC SAMPLING WAS REQUIRED DURING THE YEAR

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Acute Static Renewal daphnia dubia	Sample Measurement	0	0	0	0	0	0	0	0	0	0
RETENTION	Permit Measurement				LC 50 >100 % (minimum)			percent		Annual	four grab samples over a 24 hour day
Acute Static Renewal nela leael	Sample Measurement	0	0	0	0	0	0	0	0	0	0
RETENTION	Permit Measurement				LC 50 >100 % (minimum)			percent		Annual	four grab samples over a 24 hour day
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

251

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

ITTEE NAME: Indiantown Utilities
 ING ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
 MONITORING PERIOD From: 5/01/99
 LIMIT: Final
 CLASS SIZE: Minor

To: 6/30/99
 REPORT: Monthly
 GROUP: Domestic

ITY: Indiantown Company Wastewater Treatment Plant
 TION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
 GMS ID NO.: S143P03291
 DISCHARGE POINT NUMBER: D001
 PLANT SIZE/TREATMENT TYPE: IIC


WAFR SITE NO.: 20552
 GMS TEST SITE NO.: _____

NO DISCHARGE FROM SITE

TY: Martin

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
	Sample Measurement	0	0	0	0	0	0		0	0	0
	Permit Measurement	Report (Daily Max.)	Report (Month Avg.)	mgd						Hourly during any discharge	Calculated Flow
	Sample Measurement	0	0	0	0	0	0		0	0	0
	Permit Measurement				0.01 (Max.)			mg/L		Daily during any discharge	Grab
	Sample Measurement	0	0	0	0	0	0		0	0	0
	Permit Measurement				6.0 (Min.)	8.5 (Max.)		S.U.		Daily during any discharge	Grab
	Sample Measurement	0	0	0	0	0	0		0	0	0
	Permit Measurement				5.0 (Min.)			mg/L		Daily during any discharge	Grab
	Sample Measurement	0	0	0	0	0	0		0	0	0
	Permit Measurement										
	Sample Measurement	0	0	0	0	0	0		0	0	0
	Permit Measurement										

under penalty of law that I have personally examined and am familiar with the information submitted herein; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.

TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (YY/MM/DD)
Robert M. Post President		(561) 597-3496	7/26/99

CONTENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

DEAN S. SMILEY
 SIGNING IN LIEU OF RM. POST ABSENCE!

252

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

on ~~Completed~~ mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

MITTEE NAME: Indiantown Utilities
 ILING ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
 MONITORING PERIOD From: 6/21/99
 LIMIT: Final
 CLASS SIZE: Minor

To: 6/30/99
 REPORT: Monthly
 GROUP: Domestic

ILITY: Indiantown Company Wastewater Treatment Plant
 ATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
 GMS ID NO.: S143P03291
 DISCHARGE POINT NUMBER: D002
 PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
 GMS TEST SITE NO.:

NO DISCHARGE FROM SITE

NTY: Martin

253

Parameter	Sample Measurement	Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		Report (Daily Max.)	Report (Month Avg.)		mgd						
for dechlorination	0	0	0	0	0	0	0	0	0	Hourly during any discharge	Calculated Flow
Site No. EPP-2	0	0	0	0	0	0	0	0	0	Daily during any discharge	Grab
Site No. EPP-2	0	0	0	0	0	0	0	0	0	Daily during any discharge	Grab
en, Dissolved (DU)	0	0	0	0	6.0 (Min.)	8.5 (Max.)	0	0	0	Daily during any discharge	Grab
Site No. EPP-2	0	0	0	0	5.0 (Min.)		0	0	0	Daily during any discharge	Grab

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

MAILING ADDRESS:
INDIAN TOWN UTILITIES
 P. O. BOX 397
 Indian town, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
MONITORING PERIOD From: 6/01/99
LIMIT: Final
CLASS SIZE: Minor

To: 6/30/99
REPORT: Monthly
GROUP: Domestic

INDIAN TOWN COMPANY WASTEWATER TREATMENT PLANT
 15851 S.W. Farms Road
 Indian town, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: D003
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

NAME: Martin

NO DISCHARGE FROM SITE

Parameter	Sample Measurement	Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		(Daily Max.)	(Month Avg.)		(Min.)	(Max.)	(S.U.)				
SS	Sample Measurement	0	0	0	0	0	0	0	0	0	0
SS	Permit Measurement	(Daily Max.)	(Month Avg.)	mgd						Hourly during any discharge	Calculated Flow
SS	Sample Measurement	0	0	0	0	0	0	0	0	0	0
SS	Permit Measurement				6.0 (Min.)	8.5 (Max.)	S.U.			Daily during any discharge	Grab
for disinfection	Sample Measurement	0	0	0	0	0	0	0	0	0	0
SS	Permit Measurement				0.01 (Max.)		mg/L			Daily during any discharge	Grab
cn, Dissolved (DO)	Sample Measurement	0	0	0	0	0	0	0	0	0	0
SS	Permit Measurement				5.0 (Min.)		mg/L			Daily during any discharge	Grab
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

254

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

* Completed mail this report to: Department of Environmental Protection, Southeast District, P.O. Box 15425, West Palm Beach, 33416

MITTEE NAME: Indiantown Utilities
LINE ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
MONITORING PERIOD From: 6/30/99
LIMIT: Final
CLASS SIZE: Minor

To: 6/30/99
REPORT: Monthly
GROUP: Domestic

CITY: Indiantown
LOCATION: Indiantown Company Wastewater Treatment Plant
 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: S143P03291
DISCHARGE POINT NUMBER: R001
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

NTY: Martin

255

Parameter	Measurement	Quantity or Loading	Units	Quality or Concentration	Units	No. Ex.	Frequency of Analysis	Sample Type	
	Sample Measurement	352 HH	MGD		MGD	0			
	Permit Measurement	0.4 (An.Avg.)	mgd				continuous with 5 readings/Week	Flow Meters with Totalizer	
	Sample Measurement	420	MGD		MGD	0			
	Permit Measurement	Report (Mo.Avg.)	mgd				continuous with 5 readings/Week	Flow Meters with Totalizer	
	Sample Measurement			5.3	Mg/L	0			
	Permit Measurement			20.0 (An.Avg.)	mg/L		Weekly	8-hour FPC	
	Sample Measurement			3.0	Mg/L	0			
	Permit Measurement			25.0 (Mo.Avg.)	40.0/report (Week.Avg.)	60.0 (Max.)	mg/L	Weekly	8-hour FPC
	Sample Measurement			3.2	Mg/L	0			
	Permit Measurement			20.0 (An.Avg.)			mg/L	Weekly	8-hour FPC
	Sample Measurement			0.6	Mg/L	0			
	Permit Measurement			30.0 (Mo.Avg.)	45.0/report (Week.Avg.)	60.0 (Max.)	mg/L	Weekly	8-hour FPC
	Sample Measurement			6.7	SU	0			
	Permit Measurement			6.0 (Min.)	8.5 (Max.)		S.U.	Continuous	pH meter with 24 hour recording meter

No. 3005
 No. EFF-6

DISCHARGE MONITORING REPORT - PART A (Continued)

UTILITY NAME: Indiantown Company Wastewater Treatment Plant

PERMIT NUMBER: FL0029939-001-DW1P

DISCHARGE POINT NUMBER: R004

WAFR SITE No.: 20552

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Ammonia, as N	Sample Measurement				6.4			Mg/L	0		
Ammonia, as N	Permit Measurement				12.0 (Max.)			mg/L		Weekly	Grab
Ammonia, Total as N	Sample Measurement				13.2			Mg/L	0		
Ammonia, Total as N	Permit Measurement				Report (Max.)			mg/L		Weekly	8-hour FPC
Orthophosphorus, Total as P	Sample Measurement				3.9			Mg/L	0		
Orthophosphorus, Total as P	Permit Measurement				Report (Max.)			mg/L		Weekly	8-hour FPC
Coliform Bacteria	Sample Measurement				0.39			#/100 mL	0		
Coliform Bacteria	Permit Measurement				200 (An. Avg.)			#/100 mL		Weekly	Grab
Coliform Bacteria	Sample Measurement				0 or < 1	< 1		#/100 mL	0		
Coliform Bacteria	Permit Measurement				Report (Mo. Geo. Mean)	800 (Max.)		#/100 mL		Weekly	Grab
Chlorine Residual for disinfection	Sample Measurement				1.0			Mg/L	0		
Chlorine Residual for disinfection	Permit Measurement				0.5 (Min.)			mg/L		Continuous	TRC meter with 24 hour recording chart

250

No. 3005
 No. EFF-6

No. 3005
 No. EFF-6

UTILITY NAME:

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Southeast District, P.O. Box 15425, West Palm Beach, 33416

MITTEE NAME: Indiantown Utilities
LINE ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
MONITORING PERIOD From: _____
LIMIT: Final
CLASS SIZE: Minor

To: _____
REPORT: Monthly
GROUP: Domestic

ILITY: Indiantown Company Wastewater Treatment Plant
ATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: R002
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

NTY: Martin

Parameter		Quantity or Loading	Units	Quality or Concentration			Units	No. Ex.		
	Sample Measurement	0.059	MGD				MGD	0		
	Permit Measurement	0.107 (An.Avg.)	mgd						Continuous with 5 readings/Week	Flow Meters with Totalizer
	Sample Measurement	.140	MGD				MGD	0		
	Permit Measurement	Report (Mo.Avg.)	mgd						Frequency of Analysis	Sample Type
	Sample Measurement			5.3			Mg/L	0		
	Permit Measurement			20.0 (An.Avg.)			mg/L		Weekly	8-hour FPC
	Sample Measurement			3.0		6.4	Mg/L	0		
	Permit Measurement			25.0 (Mo.Avg.)	40.0/report (Week.Avg.)	60.0 (Max.)	mg/L		Weekly	8-hour FPC
	Sample Measurement			3.2			Mg/L	0		
	Permit Measurement			20.0 (An.Avg.)			mg/L		Weekly	8-hour FPC
	Sample Measurement			0.6		2.6	Mg/L	0		
	Permit Measurement			30.0 (Mo.Avg.)	45.0/report (Week.Avg.)	60.0 (Max.)	mg/L		Weekly	8-hour FPC
	Sample Measurement			6.9	7.6		S.U.	0		
	Permit Measurement			6.0 (Min.)	8.5 (Max.)		S.U.		Continuous	pH meter with 24 hour recording meter

257

DISCHARGE MONITORING REPORT - PART A (Continued)

UTILITY NAME: Indiantown Company Wastewater Treatment Plant

PERMIT NUMBER: FL0029939-001-DW1P

DISCHARGE POINT NUMBER: R002

WAFR SITE No.: 20552

Parameter	Measurement	Quantity or Loading	Units	Quality or Concentration		Units	No. Ex.	Frequency of Analysis	Sample Type
Ammonia Nitrogen, as N	Sample Measurement			6.4		Mg/L	0		
Ammonia Nitrogen, as N	Permit Measurement			12.0 (Max.)		mg/L		Weekly	Grab
Phosphorus, Total as P	Sample Measurement			13.2		Mg/L	0		
Phosphorus, Total as P	Permit Measurement			Report (Max.)		mg/L		Weekly	8-hour FPC
Chloride	Sample Measurement			3.9		Mg/L	0		
Chloride	Permit Measurement			Report (Max.)		mg/L		Weekly	8-hour FPC
Coliform Bacteria	Sample Measurement			0.39		#/100 mL	0		
Coliform Bacteria	Permit Measurement			200 (An. Avg.)		#/100 mL		Weekly	Grab
Coliform Bacteria for disinfection	Sample Measurement			0 or < 1	< 1	#/100 mL	0		
Coliform Bacteria for disinfection	Permit Measurement			Report (Mo. Geo. Mean)	800 (Max.)	#/100 mL		Weekly	Grab
Chlorine Residual	Sample Measurement			1.0		Mg/L	0		
Chlorine Residual	Permit Measurement			0.5 (Min.)		mg/L		Continuous	TRC meter with 24 hour recording chart

258

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

No. 0
No. 0000
No. 0000

No. 0000
No. 0000

Completed mail this report to: Department of Environmental Protection, Southeast District, P.O. Box 15425, West Palm Beach, 33416

MITTEE NAME: Indiantown Utilities
LINE ADDRESS: P. O. BOX 397
Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
MONITORING PERIOD From:
LIMIT: Final
CLASS SIZE: Minor

To: Monthly
REPORT GROUP: Domestic

CITY: Indiantown Company Wastewater Treatment Plant
LOCATION: 15851 S.W. Farms Road
Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: Influent Monitoring Point
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.:

COUNTY: Martin

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
	Sample Measurement	*							0		
ET No. 0000000000 SHE No. INP-1	Permit Measurement	0.385 (3-Mo. Avg.)	Report (Mo. Avg.)	mgd						Continuous	Flow Meters
	Sample Measurement				231			Mg/L	0		
ET No. 0000000000 SHE No. INP-1	Permit Measurement				Report (Mo. Avg.)			mg/L		Weekly	16-hour FPC
	Sample Measurement				169			Mg/L	0		
ET No. 0000000000 SHE No. INP-1	Permit Measurement				Report (Mo. Avg.)			mg/L		Monthly	16-hour FPC

259

* Row Watch Motor NOT YET INSTALLED TO MONIT NEW PERMIT REQUIREMENTS:

No. 0000
No. 0000
No. 0000

Completed

No. 0000
No. 0000

**DAILY SAMPLE RESULTS - PART B
(PAGE ONE)**

File Number: FL0029939-001-DWIP
 1/Year:

Three-month Average Daily Flow: .402
 Daily Flow % of Permitted
 Capacity: 67%

of the Month	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30/31	
Monitoring Location Site Number																															
(mgd), EFF-6	380	370	370	330	380	430	430	450	480	350	410	410	380	390	400	370	420	390	450	440	400	420	420	490	470	490	490	450	460	440	
(mgd), EFF-7	194	172	151	214			201	165	190	222	187			115	178	184	217	234			201	192	223	193	237		163	185	181		
(mgd), INF-1																															
DS (mg/L), EFF-6	2.1						6.4							2.4							2.0								2.0		
DS (mg/L), INF-1	231						188							265							225								246		
mg/L, EFF-6	2.6						2.6							1.6							1.0								2.2		
mg/L, INF-1	191						130							214							128								181		
id. units), EFF-6	7.3	7.1	7.2	7.2	7.3	6.9	7.5	7.5	7.2	7.1	7.3	7.2	7.0	7.1	7.2	7.3	7.2	7.3	7.1	7.0	7.2	7.2	7.3	7.4	7.4	7.6	7.5	7.3	7.0	7.2	
Coliform Bacteria (#/100 mL), EFF-6	<1							<1							<1						<1								<1		
tion time for Fecal Coliform Bacteria sample, EFF-6	1710							0705							1730						1625								1745		
(For Disinfection) (mg/L), EFF-6	1.7	2.2	1.8	1.3	1.5	2.2	2.1	2.2	2.0	1.6	1.9	2.2	2.2	2.0	1.8	1.2	1.6	1.5	1.4	1.0	1.2	1.6	1.8	1.2	1.3	1.3	1.0	1.4	1.6	1.1	
Nitrogen (as N) (mg/L), EFF-6	8.8							13.2						7.7							17.5								13.0		
Phosphorus (as P) (mg/L), EFF-6	3.6							3.9						3.7							3.8								3.6		
c, as N, EFF-6	.47							4.1						.61							6.4								6.0		

260

Staffing:
 Shift Operator Class A Certificate No. 6805 Name: DEAN S. SMILY, JR.
 Shift Operator Class B Certificate No. 3634 Name: DON C. JOHNSON, SR.
 Shift Operator Class B Certificate No. 6747 Name: JAMES G. HEWITT
 Operator Class _____ Certificate No. _____ Name: _____

Effluent Disposal or Reclaimed Water Reuse: EVAP/PERC. POND/IRRIGATION
 Wet Weather Discharge Activated: Yes ___ No ___ Not Applicable X If yes, cumulative days of wet weather discharge: _____
 Additional sheets necessary to list all certified operators necessary for required operations: _____

**DAILY SAMPLE RESULTS - PART B
(PAGE TWO)**

it Number: FL0029939-001-DWIP
h/Year:

Three-month Average Daily Flow: n/a
Daily Flow % of Permitted: n/a
Capacity:

of the Month Monitoring Location Site Number	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30/31
(mgd), EFF-1																														
(mgd), EFF-2																														
(mgd), EFF-3																														
(For Dechlorination) (mg/L), EFF-1																														
(For Dechlorination) (mg/L), EFF-2																														
(For Dechlorination) (mg/L), EFF-3																														
(d. units), EFF-1																														
(d. units), EFF-2																														
(d. units), EFF-3																														
cn, Dissolved (DO), EFF-1																														
cn, Dissolved (DO), EFF-2																														
cn, Dissolved (DO), EFF-3																														
ation Pond Water Elevation, EFF-1																														
ation Pond Water Elevation, EFF-2																														
ation Pond Water Elevation, EFF-3																														
ation Pond Water Elevation, EFF-4																														
ation Pond Water Elevation, EFF-5																														
levation below the overflow, EFF-1																														
levation below the overflow, EFF-2																														
levation below the overflow, EFF-3																														
levation below the overflow, EFF-4																														
levation below the overflow, EFF-5																														

261

POND ELEVATIONS WILL BE RECORDED ON DAILY D.M.K.s

of the Month
Unit/Min
01, 51

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

MITTEE NAME: Indiantown Utilities
MAILING ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
MONITORING PERIOD From: 6/01/99
LIMIT: Final
CLASS SIZE: Minor

To: 6/30/99
REPORT: Annual
GROUP: Domestic

PLANT NAME: Indiantown Company Wastewater Treatment Plant
LOCATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: D001
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

OWNER: Martin

CHECK HERE IF NO TOXIC SAMPLING WAS REQUIRED DURING THE YEAR

262

Parameter	Sample Measurement	Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Acute Toxicity (5 min LC50)	Sample Measurement	0	0	0	0	0	0	0	0	0	0
Chronic Toxicity (30 day LC50)	Permit Measurement				LC 50 > 100 % (minimum)			percent		Annual	four grab samples over a 24 hour day
Acute Toxicity (5 min LC50)	Sample Measurement	0	0	0	0	0	0	0	0	0	0
Chronic Toxicity (30 day LC50)	Permit Measurement				LC 50 > 100 % (minimum)			percent		Annual	four grab samples over a 24 hour day
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

☐ Check and mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

MITTY NAME: Indiantown Utilities
LINE ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DW1P
MONITORING PERIOD From: 6/10/99
LIMIT: Final
CLASS SIZE: Minor

To: 6/30/99
REPORT: Annual
GROUP: Domestic

ILTN AT: Indiantown Company Wastewater Treatment Plant
 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: D002
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

NT: Martin

CHECK HERE IF NO TOXIC SAMPLING WAS REQUIRED DURING THE YEAR:

263

Parameter	Measurement	Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Acetic Acid Renewal	Sample Measurement	0	0	0	0	0	0	0	0	0	0
LC 50	Permit Measurement				LC 50 > 100% (minimum)			percent		Annual	four grab samples over a 24 hour day
Acetic Acid Renewal	Sample Measurement	0	0	0	0	0	0	0	0	0	0
LC 50	Permit Measurement				LC 50 > 100% (minimum)			percent		Annual	four grab samples over a 24 hour day
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

Completed mail this report to: Department of Environmental Protection, Wastewater Facilities Management Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

ISSUE NAME: Indiantown Utilities
ISSUING ADDRESS: P. O. BOX 397
 Indiantown, FL 34956

PERMIT NUMBER: FL0029939-001-DWIP
MONITORING PERIOD From: 10/01/99
LIMIT: Final
CLASS SIZE: Minor

To: 6/30/99
REPORT: Annual
GROUP: Domestic

CITY: Indiantown Company Wastewater Treatment Plant
LOCATION: 15851 S.W. Farms Road
 Indiantown, FL 34956

FACILITY ID: FL0029939
GMS ID NO.: 5143P03291
DISCHARGE POINT NUMBER: D003
PLANT SIZE/TREATMENT TYPE: IIC

WAFR SITE NO.: 20552
GMS TEST SITE NO.: _____

CITY: Martin

CHECK HERE IF NO TOXIC SAMPLING WAS REQUIRED DURING THE YEAR

Parameter	Measurement	Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Acute Static Renewal toxicity	Sample Measurement	0	0	0	0	0	0	0	0	0	0
	Permit Measurement				LC 50 >100 % (minimum)			percent		Annual	four grab samples over a 24 hour day
Acute Static Renewal toxicity	Sample Measurement	0	0	0	0	0	0	0	0	0	0
	Permit Measurement				LC 50 >100 % (minimum)			percent		Annual	four grab samples over a 24 hour day
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										
	Sample Measurement										
	Permit Measurement										

264