



ORIGINAL

March 9, 2000

Via Federal Express

Ms. Blanca Bayo
Division of Water and Wastewater
Florida Public Service Commission
Tallahassee, FL 32399-0850

Re: Docket No. 981663-WU; Application for staff-assisted rate case in Orange County by Tangerine Water Company, Inc.

Dear Ms. Bayo:

Enclosed herewith for filing in the above-referenced docket are the following documents:

1. Original and seven (7) copies (pursuant to rule 25-22.028 (2), Florida Administrative Code) of Florida Water's Motion for Extension of Time to Comply with Commission Order.
2. A disk in Word Perfect containing a copy of the Motion.

*Received
diskette
3/13*

Please acknowledge receipt of these documents by stamping the extra copy of this letter "filed" and returning the same to me.

Sincerely,

Matthew J. Feil
Staff Attorney

AFA	1
APP	_____
CAF	_____
CMU	_____
CTR	_____
EAG	_____
LEG	1
MAS	_____
OPC	_____
RRR	_____
SEC	1
MAW	_____
OTH	_____

Enclosures

RECEIVED & FILED
mar
FPSC-BUREAU OF RECORDS

MAIL ROOM
00 MAR 10 PM 1:10

DOCUMENT NUMBER-DATE

03131 MAR 10 8

FPSC-RECORDS/REPORTING

** No DISKETTE INCLUDED.*

Florida Water Services Corporation / P.O. Box 609520 / Orlando, Florida 32860-9520 / Phone 407/598-4100

Water For Florida's Future

ORIGINAL

In Re: Application for) DOCKET NO. 981663-WU
staff-assisted rate case in)
Orange County by Tangerine Water)
Company, Inc.)
_____)

Motion for Extension of Time to
Comply with Commission Order

COMES NOW, FLORIDA WATER SERVICES CORPORATION
(hereinafter "Florida Water"), as successor in interest to
the utility assets of Tangerine Water Company, Inc. through
the undersigned counsel, files this Motion for Extension of
Time to Comply with Commission Order.

1. By Order Number PSC-99-1399-PAA-WU, issued July 21,
1999, in the captioned docket, Tangerine Water
Company, Inc. (hereinafter "Tangerine") was required
to complete the following items within 180 days from
the date of the order:

- a. Install a DEP required chlorine alarm;
- b. Install a DEP required transfer switch;
- c. Complete all DEP required electrical work;
- d. Repair the number one pump;

DOCUMENT NUMBER-DATE

03131 MAR 108

FPSC-RECORDS/REPORTING

- e. Complete the required line looping;
 - f. Acquire a hand held computer for meter reading;
and
 - g. Investigate customer deposits to determine who
has established a satisfactory payment record.
2. On January 7, 2000 Florida Water acquired the utility assets of Tangerine, subject to Commission approval of the purchase. An application for transfer of said facilities from Tangerine to Florida Water is being prepared and should be filed a few days hence.
3. To date, items lettered d, f and g from paragraph 2 above have been completed: (d) and (g) by Tangerine and (f) by Florida Water. Had Tangerine continued to own the utility facilities, Tangerine would have complied with the Order, but because a sale to Florida Water was anticipated after the Order, Florida Water will complete the required items.
4. Florida Water intends to complete the remaining items by the end of August, 2000, as reflected in the attached schedule. Therefore, Florida Water asks the

Commission for additional time to comply with the outstanding Order requirements.

Wherefore, Florida Water files this Motion for Extension of Time to Comply with Commission Order PSC-99-1399-PAA-WU.

Respectfully submitted,



MATTHEW J. FEIL, ESQ.
Florida Water Services Corporation
P.O. Box 609520
Orlando, FL 32860-9520
(407) 598-4260

CERTIFICATE OF SERVICE

I HEREBY CERTIFY that a copy of the foregoing Motion was furnished by Federal Express to Ms. Donna Clemons, Staff Attorney, Florida Public Service Commission, 2540 Shumard Oak Boulevard, Tallahassee, FL 32399-0850 on this 9th day of March, 2000



MATTHEW J. FEIL, ESQ.

Tangerine Water System

Completion Schedule for FPSC Required Improvements

Item	Proposed Correction	2000									
		Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	
Automatic Transfer Switch, plus Required Electrical Work	Install ATS, plus electrical system rewiring and code required upgrades			Bid/Award	Permit	Construct					
Chlorine Alarm	Convert to Hypochlorination			Design	Design	Design	Permit	Construct	Clear		
Looping of 1" Water Main	2" Loop, tying to 2" at each end			Survey	Design	Design	Permit	Bid/Award	Construct	Clear	