

FLORIDA PUBLIC SERVICE COMMISSION

DOCKET NO. 000154-SU

RULE TITLE:

RULE NO.:

Flows to be Used for Wastewater

Treatment Plan Used and Useful Calculations 25-30.432

The Florida Public Service Commission announces a second staff rule development workshop to be held on Rule 25-30.432, F.A.C., Flows to be used for Wastewater Treatment Plant Used and Useful Calculations, at the following time and place.

DATE AND TIME: Tuesday, May 9, 2000, at 1:30 P.M.

PLACE: Room 180, Betty Easley Conference Center, 4075 Esplanade Way, Tallahassee, FL 32399-0862.

PURPOSE AND EFFECT: To adopt a rule specifying the time period to be used in the equation for calculating the used and useful percentage of wastewater treatment plant.

SUBJECT AREA TO BE ADDRESSED: Flow data for calculating the used and useful percentage for wastewater treatment plant.

SPECIFIC AUTHORITY: 350.127(2), 367.121(1)(f), FS

LAW IMPLEMENTED: 367.081(2), FS

The Notice of Proposed Rule Development and the preliminary text of the rule was published in the May 1, 1998, Florida Administrative Weekly, Volume 24, Number 18, and Volume 25, Number 18, May 7, 1999.

A copy of the agenda may be obtained after May 1, 2000, from Mary Diskerud, Division of Appeals, Public Service Commission, 2540

RECEIVED  
2000 MAR 29 AM 10:57  
DEPARTMENT OF STATE  
TALLAHASSEE, FLORIDA

- AFA \_\_\_\_\_
- APP \_\_\_\_\_
- CAF \_\_\_\_\_
- CMU \_\_\_\_\_
- CTR \_\_\_\_\_
- EAG \_\_\_\_\_
- LEG \_\_\_\_\_
- MAS \_\_\_\_\_
- OPC \_\_\_\_\_
- RRR \_\_\_\_\_
- SEC \_\_\_\_\_
- VVAW \_\_\_\_\_
- JTH \_\_\_\_\_

DOCUMENT NUMBER-DATE  
**03873 MAR 29 8**  
FPSC-RECORDS/REPORTING

Shumard Oak Blvd., Tallahassee, FL 32399-0850, (850) 413-6090.

THE PRELIMINARY TEXT OF THE PROPOSED RULE IS:

25-30.432 Flows to be Used for Wastewater Treatment Plant Used and Useful Calculations. The used and useful percentage of a wastewater treatment plant shall be calculated using a ratio of actual flows, plus the amount calculated pursuant to Rule 25-30.431 and minus excess infiltration and inflow, to the permitted plant capacity. The denominator shall be the plant capacity as stated on the permit issued by the Department of Environmental Protection for the utility's treatment plant. The flows in the numerator shall be the flow data stated in the same unit of measurement as the denominator.

Specific Authority 350.167(2), 367.121(1)(f), FS.

Law Implemented 367.081(2), FS.

History--New.