


ORIGINAL

Handwritten signature



April 17, 2000

Mr. Joseph D. Jenkins, Director
Division of Electric and Gas
Public Service Commission
Capital Circle Office Center
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850



Dear Mr. Jenkins:

Enclosed are twenty-five (25) corrected copies of Schedules 3.1, 3.2 and 3.3 of JEA's 2000 Ten Year Site Plan filing, as required by the Public Service Commission.

If you have any questions regarding this response or any additional questions, please contact Chuck Bond at (904) or me at (904) 665-6216.

Thank You,

Mary Guyton-Baker

Mary Guyton-Baker
Engineer, Capacity Planning

MAIL ROOM
00 APR 19 AM 9 57

DOCUMENT NO.
04827-00
4-19-00

**Schedule 3.1
History And Forecast of Summer Peak Demand
Base Case**

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
Calendar Year	Total	Wholesale	Retail	Interruptible	Residential Load Mngt.	Residential Conservation	C/I Load Mngt	C/I Conservation	Net Firm Demand
1990	1,789	40	1,749	0	0	0	0	0	1,789
1991	1,756	47	1,709	0	0	0	0	0	1,756
1992	1,881	56	1,825	0	0	0	0	0	1,881
1993	1,998	60	1,938	0	0	0	0	0	1,998
1994	1,918	53	1,865	0	0	0	0	0	1,918
1995	2,067	66	2,001	0	0	0	0	0	2,067
1996	2,114	64	2,050	0	0	0	0	0	2,114
1997	2,051	70	1,981	80	0	0	0	0	2,131
1998	2,232	86	2,146	106	0	0	0	0	2,338
1999	2,281	92	2,189	146	0	0	0	0	2,427
2000	2,384	98	2,286	150	0	0	0	0	2,534
2001	2,461	103	2,358	154	0	0	0	0	2,615
2002	2,539	108	2,431	158	0	0	0	0	2,697
2003	2,619	113	2,506	162	0	0	0	0	2,780
2004	2,700	118	2,582	166	0	0	0	0	2,865
2005	2,782	123	2,659	170	0	0	0	0	2,952
2006	2,866	128	2,738	174	0	0	0	0	3,040
2007	2,952	133	2,819	178	0	0	0	0	3,130
2008	3,039	138	2,901	183	0	0	0	0	3,222
2009	3,128	143	2,985	188	0	0	0	0	3,316

000000-PW

DOCUMENT NUMBER-DATE
04827 APR 198
FPSC-RECORDS/REPORTING

Schedule 3.2
History And Forecast of Winter Peak Demand
Base Case

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
Calendar Year	Total	Wholesale	Retail	Interruptible	Residential Load Mngt.	Residential Conservation	C/I Load Mngt	C/I Conservation	Net Firm Demand
1990	2,012	73	1,939	0	0	0	0	0	2,012
1991	1,725	64	1,661	0	0	0	0	0	1,725
1992	1,881	69	1,812	0	0	0	0	0	1,881
1993	1,791	66	1,725	0	0	0	0	0	1,791
1994	1,936	70	1,866	0	0	0	0	0	1,936
1995	2,190	82	2,108	0	0	0	0	0	2,190
1996	2,401	88	2,313	0	0	0	0	0	2,401
1997	1,950	72	1,878	36	0	0	0	0	1,986
1998	1,910	68	1,842	65	0	0	0	0	1,975
1999	2,303	93	2,210	100	0	0	0	0	2,403
2000	2,464	98	2,366	102	0	0	0	0	2,566
2001	2,548	103	2,445	105	0	0	0	0	2,653
2002	2,634	108	2,526	107	0	0	0	0	2,742
2003	2,722	112	2,610	110	0	0	0	0	2,832
2004	2,812	117	2,695	113	0	0	0	0	2,924
2005	2,903	122	2,781	116	0	0	0	0	3,018
2006	2,996	127	2,869	118	0	0	0	0	3,114
2007	3,091	132	2,959	121	0	0	0	0	3,212
2008	3,188	137	3,051	124	0	0	0	0	3,312
2009	3,286	142	3,144	128	0	0	0	0	3,414

Schedule 3.3
History And Forecast of Net Energy for Load - GWH
Base Case

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
Calendar Year	Total	Residential Conservation	C/I Conservation	Retail	Wholesale	Utility Use & Losses	Net Energy for Load	Load Factor %
1990	8,538	0	0	8,358	180	258	8,538	48
1991	8,835	0	0	8,604	231	487	8,835	57
1992	9,028	0	0	8,710	318	431	9,028	55
1993	9,609	0	0	9,260	349	628	9,609	55
1994	9,609	0	0	9,296	313	388	9,609	57
1995	10,326	0	0	9,977	349	667	10,326	54
1996	10,515	0	0	10,141	374	398	10,515	50
1997	10,665	0	0	10,271	394	570	10,665	57
1998	11,470	0	0	11,019	451	442	11,470	56
1999	11,740	0	0	11,286	454	547	11,740	55
2000	12,123	0	0	11,668	455	607	12,123	54
2001	12,505	0	0	12,030	475	612	12,505	54
2002	12,894	0	0	12,400	493	614	12,894	54
2003	13,289	0	0	12,786	504	621	13,289	54
2004	13,692	0	0	13,159	533	605	13,692	53
2005	14,102	0	0	13,551	551	596	14,102	53
2006	14,519	0	0	13,949	571	582	14,519	53
2007	14,945	0	0	14,355	590	564	14,945	53
2008	15,378	0	0	14,770	609	543	15,378	53
2009	15,820	0	0	15,196	624	521	15,820	53