

ORIGINAL

**BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION**

In Re: Petition for )  
Determination of Need for an )  
Electrical Power Plant in )  
St. Lucie County by Panda )  
Midway Power Partners, L.P. )  
\_\_\_\_\_ )

DOCKET NO. 000289-EU

**DIRECT TESTIMONY OF**

**FRANCIS P. GAFFNEY**

**ON BEHALF OF**

**PANDA MIDWAY POWER PARTNERS, L. P.**

**April 24, 2000**

DOCUMENT NUMBER-DATE  
05046 APR 24 8  
FPSC-RECORDS/REPORTING

**BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION**  
**IN RE: PETITION FOR DETERMINATION OF NEED**  
**FOR AN ELECTRICAL POWER PLANT IN ST. LUCIE COUNTY**  
**BY PANDA MIDWAY POWER PARTNERS, L.P.**  
**FPSC DOCKET NO. 000289-EU**

**DIRECT TESTIMONY OF FRANCIS P. GAFFNEY**

1

2 **Q: Please state your name and business address.**

3 A: My name is Francis P. Gaffney, and my business address is 800 North Magnolia Ave.,  
4 Suite 300, Orlando, FL 32803-3274.

5

6 **Q: What is your occupation?**

7 A: I am employed by R. W. Beck, Inc. as a Principal Engineer in Transmission Planning  
8 and Analysis.

9

10 **Q: Please describe your duties with R. W. Beck, Inc. as applicable to the subject of**  
11 **your testimony.**

12 A: I am responsible for transmission planning and operations studies for clients of  
13 R. W. Beck. These studies include generation interconnection studies, and interface  
14 limit studies involving load flow, short circuit and stability analyses.

15

16 **Q: Please summarize your educational background and experience.**

17 A: I have a Bachelor of Science, Magna Cum Laude, from Northeastern University in  
18 Electrical Engineering with a specialization in Electric Power Engineering. I have a  
19 Master of Engineering from Rensselaer Polytechnic Institute, in Electric Power  
20 Engineering. I have also completed all course work towards a Master of Science in

1 Management from Lesley College. I am a member of the Eta Kappa Nu (Electrical  
2 Engineering) and Tau Beta Pi (Engineering) National Honor Societies.

3 I have more than fourteen years of engineering work experience. I worked for  
4 more than ten years with Boston Edison Company. For five of those years I was  
5 assigned to the transmission planning organization, and for two years, I managed the  
6 organization. For the past four years, I have worked for R. W. Beck and a subsidiary,  
7 TAVA/R. W. Beck, Inc., with continuing responsibilities in transmission planning. I  
8 have performed load flow studies, stability analyses, short circuit studies, electro-  
9 magnetic switching studies, harmonics studies, and other transmission related analyses,  
10 using varied software programs (e.g., PTI's PSS/E, GE's PSLF, EPRI's EMTP). These  
11 studies include generator interconnection studies, regional export/import studies, critical  
12 clearing time studies, rail electrification interconnection studies (harmonics), annual  
13 reliability assessment studies, short circuit mitigation studies, and others. Each of these  
14 studies examines the impact on the system or particular facilities. In addition to my  
15 extensive technical analysis experience, I was also a member of the New England  
16 Power Pool's Stability Task Force and several NEPOOL working groups.

17 For more information, my Curriculum Vitae is Exhibit FPG-1.  
18

19 **Q: Have you previously testified before regulatory authorities and courts?**

20 **A: Yes, I have testified at the Federal Energy Regulatory Commission ("FERC") on**  
21 **transmission related issues.**  
22



1

2 **Q: With what similar projects has R. W. Beck been involved, and in what capacity?**

3 A: R. W. Beck has performed numerous studies for generator interconnection, including  
4 merchant power plants. Our role has included: Fatal Flaw Studies, System Impact  
5 Studies, reviews of System Impact Studies, and testimony on behalf of our clients.

6

7 **Q: What are your responsibilities with respect to the Project that is the subject of**  
8 **these proceedings?**

9 A: R. W. Beck has been retained to perform load flow and stability studies to evaluate the  
10 impacts on the transmission system of the proposed Project as a merchant plant selling  
11 wholesale power to other utilities in peninsular Florida. I have the primary  
12 responsibility for conducting these studies and evaluating the impact on the  
13 transmission system.

14

15 **TRANSMISSION INTERCONNECTION FOR THE PANDA MIDWAY POWER**  
16 **STATION**

17

18 **Q: Please describe the transmission facilities by which the Panda Midway Plant will**  
19 **be connected to the Florida transmission grid.**

20 A: Panda Midway is proposed to have a nine breaker Project 500 kV substation. The six  
21 turbines will be separately connected by their own Generator Step-up Units ("GSU's")  
22 to the Project 500 kV substation. Two new 500 kV lines will interconnect the Project  
23 500 kV substation with the existing Midway 500 kV substation and appropriate  
24 breakers and associated equipment installed at the Midway substation.



1 is solved, the load flow program will use mathematical methods to simulate flows and  
2 voltages on the modeled system based on the impedance of the system and the load  
3 flow inputs.

4 When examining the impact on the transmission system of a new generator, the  
5 system is first evaluated without the proposed project, the Base Case, and then  
6 evaluated with the Project, the Alternate Case. Electric utilities compile information  
7 about their power systems in load flow models and file these models at FERC as part of  
8 the FERC 715 filing. This is typically a good starting point for creating a Base Case – a  
9 case that represents the condition of the system before the change to the system being  
10 studied. An Alternate Case is then created to represent the system change being studied  
11 (e.g., adding a generator) and results of the load flow analysis of the Alternate Case are  
12 compared to results from the Base Case to examine the incremental impact of the  
13 system change.

14  
15 **Q: How did you conduct the load flow analysis?**

16 **A:** We created three Base Cases without the Project: 1) Peak Load or 100% load level,  
17 2) “Shoulder” Load or 60% load level, and 3) Light Load or 40% load level. Three  
18 different load levels were evaluated to reflect the varied conditions on the transmission  
19 system. Peak load is used for planning purposes to demonstrate that the resource’s  
20 ability to serve load at the time the resource is most needed. Light load can represent a  
21 “worst case” for the transmission system in the immediate vicinity of the project as  
22 loads are reduced in the area requiring more exports from the region. The light load  
23 snapshot is used only for planning purposes since it does not always reflect that many  
24 units will be off-line or close to their minimum load dispatch levels. It is the purpose of  
25 the market price study as discussed by Mr. Davis to determine when the resource will

1 be dispatched on an economic basis. "Shoulder" load, or mid-load levels, can be the  
2 "worst case" for regions importing or exporting power. We evaluated the performance  
3 of the three Base Cases by testing a comprehensive set of contingencies to create a  
4 baseline performance for the existing power system.

5 We then modified the three Base Cases to include the Project and tested these  
6 three Alternate Cases using the same set of contingencies. The results of the Alternate  
7 Cases were compared with the Base Cases to evaluate the incremental impact of the  
8 Project on the performance of the power system.

9 This approach is common practice and is valuable because criteria violations in  
10 the existing system (if any) can be identified and any new criteria violations caused by  
11 the incremental impact of the project can be separately identified.

12  
13 **Q: How did you develop the peak load Base Case?**

14 **A:** We obtained the 2004 FERC 715 filed summer peak load flow case from the FERC's  
15 web-site. We reviewed the ten-year site plans for each of the peninsular Florida utilities,  
16 the ten-year site plan of the Florida Reliability Coordinating Council ("FRCC"), and the  
17 Florida Public Service Commission's ("FPSC") review of the ten-year site plan. From  
18 these site plans, we included the generating projects and transmission reinforcements  
19 scheduled to be in service by 2004. We also included other Merchant Generator  
20 Projects that were publicly announced and have petitioned for a Certificate of Need  
21 (e.g., Duke New Smyrna and PG&E Okeechobee). After adding the new generation  
22 resources, we made adjustments to other generating plants within peninsular Florida  
23 (generally turning off peaking units based on FERC Form 1 data on capacity factor,  
24 heat rate and operating costs) to maintain the same level of Florida Import as in the filed  
25 FERC 715 load flow case (approximately 2,350 MW).



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

**Q: How did you develop the shoulder load and light load Base Cases?**

A: Using the peak load case above, we scaled the load down within peninsular Florida to the 60% and 40% load levels. We maintained the 2,350 MW Florida Import level at the 60% load level and reduced Florida Import to about 1,000 MW at the 40% load level. We then adjusted generation within Florida to match load and losses, subtracting out the Florida Import. We adjusted the generation using the following guidelines:

1. Generation was turned off and reduced in the following order: (i) gas turbines and diesels, (ii) oil and gas fired steam units, (iii) repowered and green-field combined cycle plants, and (iv) coal plants. We did not turn off any nuclear units, large coal units, or cogeneration facilities except as noted below.
2. When deciding among generators with the same technology guideline we considered FERC Form 1 data for capacity factor, heat rate and costs (or forecasted heat rate and cost information for new units).
3. A general preference was given to keeping plants in close proximity to the Project in service. This results in a conservative study by increasing area export conditions and stressing the transmission system. In converse, plants far away from the Project will have little effect on the regional impacts of the Project.
4. A general preference was given to turning off generation in south Florida to enhance north to south flow through Florida.

At the 40% load level, we assumed that one nuclear unit would be out of service for maintenance and/or refueling because 40% load level would likely be a fall or spring minimum load. For conservatism, we chose Turkey Point because it is distant from the proposed plant site, and, by taking this south of Miami unit out of service, it increases north to south flows.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24

**Q: How were the Alternate Cases created?**

A: Each of the three Base Cases was modified by including the Project at peak output (projected to be 1,040 MW) and adjusting generation within peninsular Florida using the same factors as previously mentioned.

**Q: In the load flow analysis, did you study the combined effects of Panda Midway and Panda Leesburg?**

A: Yes. The Base Cases excluded in the Panda Midway and Panda Leesburg projects (defined collectively as "Projects") and the Alternate Cases included the Projects. Because of the distance between the Projects, the impacts of each are easily separated and identifiable from each other.

**Q: Did you evaluate the Project's capability to deliver power outside of Florida?**

A: No. I understand from Panda Midway that their intent is to sell wholesale power within peninsular Florida, and accordingly R. W. Beck was not asked to evaluate sales outside of peninsular Florida.

**Q: What steady state voltage and rating criteria were used in your study?**

A: The transmission planning criteria used in the study are in accordance with "*FRCC Planning Principles and Guides*", and in accordance with FPL Planning Criteria as published with FPL's FERC 715 filing. The FRCC guides are not specific regarding quantitative criteria. The guides define probable contingencies as single contingencies (e.g., loss of any one element), and state, "Transmission systems should be capable of

1 delivering generator unit output to meet projected customer demands during normal and  
2 probable contingencies.”

3 FPL Planning Criteria as published with FPL’s FERC 715 filing are as follows:  
4 “FPL has adopted transmission planning criteria that are consistent with the planning  
5 criteria established by the Florida Reliability Coordinating Council (FRCC) in its  
6 *Principles and Guides for Planning Reliable Bulk Electric Systems*. FPL has applied  
7 these planning criteria in a manner consistent with prudent utility practice. These  
8 criteria are included as part of the attachments to this response. There may have been  
9 isolated cases for which FPL may have determined it prudent to deviate from these  
10 criteria. The overall customers involved, the probability of an outage occurring, as well  
11 as other factors may have influenced this decision.

12 The criteria are used for planning purposes and not for operating the system.  
13 Some operating parameters such as time limited Emergency Ratings may be factored  
14 into the planning process provided there is sufficient time for operator actions without  
15 jeopardizing the safety and reliability of the transmission system ...”

16 FPL does use Emergency Ratings according to their criteria, when there is  
17 sufficient time for operator response. If an overload is caused by the Project, a potential  
18 response would be to reduce the output of the Project post-contingency to alleviate  
19 overload concerns. Therefore, for the purposes of the study performed, it is assumed  
20 that Emergency Ratings can be used.

21 The transmission planning criteria used in the study are in accordance with  
22 “*FRCC Planning Principles and Guides*”. Because neither the FRCC guides nor the  
23 FPL criteria are specific, we used the following planning criteria, which are used by  
24 Florida Power Corporation (“FPC”):

- 1           ♦ Voltage should be between 95% and 105% of nominal voltage for both normal
- 2           conditions and contingencies.
- 3           ♦ Loading on transmission lines and transformers should be under the Normal
- 4           Rating (Rating 1) under normal conditions (Contingency 0).
- 5           ♦ Under contingency conditions, the loading should be under the Emergency
- 6           Rating (Rating 2).

7

8   **Q:    What areas were monitored in your analysis?**

9   A:    All of the peninsular Florida areas were monitored down to the 69 kV level.

10

11   **Q:    Please define contingency.**

12   A:    The Florida Reliability Coordinating Council defines a contingency as an “unexpected  
13   loss of a system element”. Generally, a contingency is loss of any one transmission  
14   element, such as a transmission line, transformer or generator. The loss of the element  
15   could be due to any number of reasons such as lightning, birds, equipment failure,  
16   human error, etc. Although many failures are temporary and will be restored in less than  
17   fifteen seconds, for the purposes of the load flow study, the contingency is assumed to  
18   be long term (minutes to hours). The significance of a contingency is that while a  
19   transmission element is out of service, other transmission elements share in transmitting  
20   the power formerly being transmitted by the element that was lost, thereby increasing  
21   the non-outaged elements’ loadings, potentially causing an overload situation or a  
22   voltage violation. In a load flow study, many different contingencies are tested.

23

1 **Q: How did you select the contingencies used in your steady state analysis?**

2 A: The "*FRCC Planning Principles and Guides*" define a "Probable Contingency" as "the  
3 loss of any single element (generating unit, transmission line or transformer." In  
4 accordance with these principles and guides, we tested, one at a time, every line and  
5 transformer contingency from 69 kV and up within the vicinity of the Project to assess  
6 the impact of the Project on the regional transmission system. We also tested, one at a  
7 time, every line and transformer contingency from 230 kV and up within peninsular  
8 Florida. In addition, we tested, one at a time, every generator contingency from 100  
9 MW and up within peninsular Florida.

10 **STABILITY ANALYSIS**

11

12 **Q: Were you able to complete your stability analysis?**

13 A: No. The Florida Reliability Coordinating Council (FRCC) was asked to provide a  
14 stability case for the study, but, a case was not made available. The stability case is not  
15 available from the FERC 715 filing either. Therefore, the dynamic stability data were  
16 obtained from the Mid-Atlantic Area Council ("MAAC") System Dynamics Database  
17 Working Group ("SDDWG") database representing the entire eastern U.S.  
18 interconnection for the year 2003 summer peak. This data is publicly available from the  
19 MAAC web-site, which is accessible via the Pennsylvania - New Jersey - Maryland  
20 ("PJM") web-site ([www.pjm.com](http://www.pjm.com)). However, due to the complexity of this very large  
21 (over 30,000 bus) model, we are still in the process of performing the study. Results  
22 will be made available shortly.

23

1 Q: **How are you conducting the stability analysis?**

2 A: In a similar fashion to the load flow analysis, a Base, peak load case was created and  
3 the performance of the power system was benchmarked with this Base Case. Then, the  
4 new plant was added and generation adjusted to create an Alternate Case. The results of  
5 the Alternate Case will be compared with the results of the Base Case to assess the  
6 incremental impact of the Project.

7

8 Q: **How did you develop the contingency list used for your stability analysis?**

9 A: We will simulate three-phase faults at either end of all 500 kV lines within Florida, and  
10 partially into Georgia. We will also study faults on 230 kV lines in close proximity to  
11 the Project.

12

13 Q: **In the stability analysis, will you study the combined effects of Panda Midway and  
14 Panda Leesburg?**

15 A: Yes. The Base Cases excluded the Projects, and there are two Alternate Cases, one that  
16 includes only Panda Leesburg, and another that includes both Panda Leesburg and  
17 Panda Midway.

18

19

#### **SYSTEM IMPACT STUDY RESULTS**

20

21 Q: **What were the results of the load flow study?**

22 A: Exhibit FPG-3 shows the results of the load flow study. When analyzing the results we  
23 take several factors into consideration. These factors are:

- 1           1. Is the element overloaded in the Base Case? If the element is overloaded in the  
2           Base Case, then the overload is a Pre-Existing condition and it is likely that the  
3           Project would not be responsible for upgrades required to solve the overload  
4           concern. This also holds true if the results of the study indicate the same element is  
5           overloaded for other contingencies.
- 6           2. Does the overload exceed the Emergency Rating for a contingency (Rating 2)? If  
7           the loading does not exceed the element's Emergency Rating (Rating 2), then the  
8           line is able to carry the loading under contingency conditions.
- 9           3. Does the overload exceed 15% of the Normal Rating if the Normal Rating (Rating  
10          1) equals the Emergency Rating (Rating 2)? Frequently, in the FERC 715 filed  
11          case, Rating 2 is published as the same as Rating 1. This can be due to several  
12          reasons. The filing entity may not have calculated an Emergency Rating for that  
13          element and, therefore, published the Normal Rating as the Emergency Rating.  
14          Typically, an Emergency Rating of a line is about 15% greater than the Normal  
15          Rating. Tampa Electric Company ("TECO") uses this 115% of Normal Rating in  
16          their planning criteria (as published in their FERC 715 filing). The Normal and  
17          Emergency Ratings may also be equal due to other reasons, such as the line may be  
18          "sag" restricted, (e.g., restricted by clearance to ground of the conductor). Usually,  
19          this can be easily fixed by re-tensioning the line and possibly making minor  
20          modifications to some transmission structures. In addition, there might be minor  
21          equipment that limits the line, such as a disconnect switch.
- 22          4. Is the difference between the Base Case and the Alternate Case significant (e.g.,  
23          greater than a 5% increase)? If the difference between the loading in the Base Case  
24          and the Alternate Case is insignificant, then the Project does not contribute  
25          significantly to the concern.

1 5. Is the location of the overloaded line distant from the Project? If the location of the  
2 overloaded element is distant from the project, then the cause of the overload is  
3 likely something other than the Project.

4 6. Is the overload insignificant? If the overload is very small (e.g., 101% to 103%),  
5 then the overload is within the error tolerances of the study, and/or it may be that  
6 the situation can be resolved through an operating measure, such as reducing the  
7 output of the Project, to eliminate the overload.

8

9 **Q: Are there any potential concerns for integrating the Project into the Florida**  
10 **transmission grid.**

11 **A:** There are two potential concerns:  
12 ♦ There is potential concern for the Hartman 138 kV/69 kV transformers.  
13 ♦ There is concern for the Midway to Citrus and Citrus to Hartman 138 kV lines.

14

15 **Q: Would you explain the potential concern for the Hartman 138 kV / 69 kV**  
16 **transformers?**

17 **A:** There is a 69 kV system underlying the 230 and 138 kV system on the east coast of  
18 Florida in the Fort Pierce and Vero Beach area. There are several feeds from the 138 kV  
19 system into the 69 kV system, and, on loss of one of those feeds into the 69 kV system,  
20 other feeds into the 69 kV system become heavily loaded. In the peak load Base Case,  
21 the loss of the Emerson to Fv-Ctyln 138 kV line (one of the feeds into the 69 kV  
22 system) causes the Hartman 138 kV / 69 kV transformers to be loaded to 83% - 84% of  
23 Rating 1, without the Project. Note that, as published in the FERC 715 loadflow  
24 database, Rating 1 equals Rating 2 (50 MVA) for these transformers.



1           The Project causes Hartman to be a stronger source to the 69 kV system,  
2 increasing the loading of the transformers to a contingency loading of 120% - 122% of  
3 Rating 1 for the same contingency. This is of potential concern because it exceeds the  
4 115% of Rating 1 that is typical of an Emergency Rating. However, transformers,  
5 because they are oil filled, take longer to heat up than overhead transmission lines.  
6 Therefore, the Emergency Ratings of transformers are often greater than 115% of  
7 Rating 1, and, since the loading exceeds Rating 1 by only 120%-122%, it is likely that  
8 the overload is within an Emergency Rating for the transformer.

9           For example, the American National Standards Institute ("ANSI") Standard  
10 C57.92-1981 lists a two hour Emergency Rating for a typical transformer (65 degrees  
11 Celsius rise, Forced-Air-Cooled Transformer rated over 133% of self-cooled rating with  
12 an equivalent load of 70% of maximum nameplate rating pre-contingency, 30 degrees  
13 Celsius ambient temperature) as 129% of Normal Rating with no loss of life. A one-  
14 hour rating under the same conditions is 145% of Normal Rating. So, if the  
15 transformers comply with the ANSI standards, the transformers should be able to carry  
16 this contingency loading.

17           My conclusion is that any significant adverse impact caused by the Project to  
18 these transformers can be eliminated through calculating an Emergency Rating and/or  
19 through operating measures to reduce the output of the Project post-contingency.  
20

21 **Q:    Would you explain the potential concern for the 138 kV lines from Midway to**  
22 **Citrus and from Citrus to Hartman?**

23 **A:**Similar to the above situation, there are several feeds into the 138 kV system from the  
24 230 kV system in the Fort Pierce and Vero Beach area. In the Base Case, without the  
25 Project, if the Emerson 230 kV to 138 kV transformer is lost, the 115 kV lines fed from

1 the 230 kV at Midway (Midway to Citrus to Hartman) become heavily loaded to 87%  
2 of Rating 1. Note that, as published in the FERC 715 loadflow database, Rating 1  
3 equals Rating 2 (272 MVA) for these lines.

4 The Project does cause Midway to be a stronger source to the 138 kV system,  
5 increasing the loading of the lines to a contingency loading of 133% of Rating 1 for the  
6 same contingency. This is of potential concern because it exceeds the 115% of Rating 1  
7 that is typical of an Emergency Rating.

8 There are a couple of options for addressing the overloads of this 138 kV  
9 corridor:

- 10 ♦ Upgrade the Midway to Citrus and Citrus to Hartman lines (estimated cost of  
11 \$1.5 to \$2 million).
- 12 ♦ Install a series reactor to limit flow on this line (estimated cost of about  
13 \$500,000).

14 Preliminary analysis on the effectiveness of the series reactor was performed. This  
15 preliminary analysis indicated that the reactor effectively eliminates the overloads on  
16 this 138 kV corridor while not causing adverse conditions to other parallel lines.

17 The cost-effective solution appears to be a series reactor with an estimated cost of  
18 \$500,000.

19 My conclusion is that any significant adverse impact caused by the Project to  
20 these 138 kV lines can be eliminated either through reconductoring / upgrading the  
21 lines, or through installation of a series reactor.

22  
23 **Q: Did you perform sensitivities to Florida Interface import levels?**

24 **A:** No. The location of the Panda Midway Project is sufficiently distant from the Florida  
25 Interface that the Project will have negligible impact from a load flow perspective on

1 the capability to import power into Florida, and vice versa. The study was performed at  
2 a conservative level of a Florida Import near its maximum firm capability.  
3

4 **Q: Did you study voltage stability?**

5 A: No. Generally, voltage instability (e.g., voltage collapse) is caused by transferring large  
6 amounts of power over large distances (e.g., from Georgia to South Florida) without  
7 sufficient active voltage regulation. The addition of Panda Midway will not adversely  
8 impact active voltage regulation, and, in fact, should improve the voltage stability of  
9 Georgia to South Florida transfers by providing mid-point active voltage regulation.  
10

#### 11 **SHORT CIRCUIT AND STABILITY RESULTS**

12  
13 **Q: Are you able to make any observations regarding the results of the stability  
14 analysis or short circuit calculations?**

15 A: Theoretically, a large, active source near the center of the east coast of Florida should  
16 not have an adverse impact on stability limits from Georgia to Florida. I expect study  
17 results to confirm that the Project will have no significant adverse impact on the system  
18 from a stability perspective. I have no observations concerning short circuit calculations  
19 yet.  
20



**FRANCIS P. GAFFNEY**

**Rensselaer Polytechnic Inst.:** Master of Engineering in Electric Power Engineering, GPA 4/4

**Northeastern University:** B.S. in Electrical Engineering, Power Systems, GPA 3.6 / 4

---

Since 1982, Mr. Gaffney has developed a diverse expertise in most aspects of the electric utility business, especially the electric power delivery business. During his career, he has been employed as:

- Transmission Planning Manager, expert in transmission planning studies and generator interconnection studies.
- National Director of Operations of a Y2k Consulting Firm, successfully operated \$15M company.
- Manager of Delivery System Design, all aspects: transmission, substation, distribution and protective relaying.
- Power Quality / Technology Expert.
- Project / Program Manager for many, varying projects.
- Marketing and Sales Manager.
- Strategic Planning / Change Management.

**Transmission Planning**

Managed the Transmission Planning group of Boston Edison. Principal Engineer with R. W. Beck specializing in transmission planning studies.

- ◆ Former member of several NEPOOL Committees, including the Stability Task Force, the Southeast Mass. and Rhode Island (SEMA/RI) export study, and the Hydro-Quebec Phase II export study.
- ◆ Performed numerous load-flow, stability, short circuit and electro-magnetic transient studies. Some major categories of studies are listed below:
  - Import Studies (e.g., Boston Import) (loadflow)
  - Major load interconnection studies (e.g., bulk substations, Amtrak rail electrification) (loadflow, short circuit)
  - Export Studies (e.g., SEMA/RI Export) (loadflow, stability)
  - Critical Clearing Time studies (stability)
  - Control System Contingency Studies (stability)
  - Capacitor switching studies (electro-magnetic transient)
  - Performed several interface limit studies, including Southeast Mass / Rhode Island Export, Hydro-Quebec Phase II export and involvement with the New York to New England interface and Maine to New Brunswick interface, both loadflow and stability analyses
  - Performed numerous generator interconnection studies in various regions of the country, including NEPOOL, WSCC, SERC and FRCC (e.g., Fatal Flaw Studies,

System Impact Studies, Facilities Studies, Minimum Interconnection Studies, etc.), load flow, short circuit and stability analyses.

- ◆ Due diligence expert review for several merchant generator interconnections.
- ◆ Testified at FERC and local courts on transmission related subjects.
- ◆ Experienced with several different programs, including GE PSLF, PTI PSS/E, and EPRI EMTP.

### **Delivery System Design**

Managed Delivery System Design for R. W. Beck, all aspects, including: transmission design (overhead and underground), substation, distribution and protective relaying. Managed Distribution Design, Senior Substation and Protective Relay Engineer for Boston Edison. Prepared numerous specifications, drawings, etc. for complete design packages. Performed numerous protective relay coordination studies. Performed several due diligence asset evaluations.

### **Operations Management**

National Director of Operations for a start-up, limited duration, Year 2000 consulting firm. Developed work processes, developed employee reference manuals, conducted training, developed project manager tools, successfully managed the company's first project, helping the company achieve in the black operations within 6 months of start-up. Developed work management tools, metrics, backlog report, operations forecast pro-forma and other operations management tools to successfully operate the \$15M company. Developed Exit Plan to successfully manage overhead costs while meeting commitments to clients and breaking even during the last 4 months of operation.

With Boston Edison, major contributor in numerous projects to improve operations, including: work process redesign, core business system requirements / replacement, change management efforts, etc. Major contributor to a Customer Response Program - evaluated adequacy and integration alternatives of existing IT "back-office" infrastructure, including: customer care system, work management system, materials management system, energy management system and AM/FM GIS System. Facilitated a culture change program (Pacific Institute's Investment in Excellence).

With R. W. Beck, performed several management audits of utility operations.

### **Power Quality / Technology**

Power Quality expert. While at Boston Edison, consulted to numerous commercial and industrial customers. Helped develop a profitable Power Quality consulting business by developing work processes, standard cost estimates, marketing material and training the sales team. Proposed and participated in market research of residential, commercial and industrial customers of many sizes for power quality services. Taught seminars on power quality. Initiated a project to install power quality meters throughout the distribution system to measure the quality of power being delivered to customers. Power quality / reliability metrics expert.

With Boston Edison, company's expert on new technologies such as fuel cells, power electronics, superconducting, renewable energy sources, flywheels, etc. Performed cost benefit analyses, due diligence on start-up firms. Conducted training.

### **Project / Program Management**

Managed several Y2k Remediation Programs successfully – on schedule, under budget. High quality delivery, such that clients expanded the scope to triple and quadruple the size of the projects. High client satisfaction, thank you letters received for a job well done. Design projects managed on schedule on budget.

### **Strategic Planning / Change Management**

With Boston Edison. Managed a project studying the convergence of delivery utilities (e.g., electric, communications, water, gas). Principle contributor for entrepreneurial project to develop a power system for a high bandwidth communication system for a Regional Bell Operating Company. Project Manger for a Distribution Business Pilot, a program to isolate a section of the distribution system, treat it as its own P&L center, and evaluate modifications in technology and operations on P&L. Facilitated a culture change program (Pacific Institute's Investment in Excellence). Developed a business plan to transition the engineering group into an engineering consulting group.

With R. W. Beck. Major contributor to develop a business plan for a schedule coordinator business. Major contributor to develop a model for the revenue cycle services marketplace that would allow revenue cycle services to be open to competition. Major contributor to develop a business plan for non-utility entities to enter the energy services business sector.

### **Honors**

- Honorable Mention, Young Outstanding Electrical Engineer from the Eta Kappa Nu National Honor Society, 1991.
- Member of the Tau Beta Pi National Honor Society for Engineers
- Eta Kappa Nu National Honor Society for Electrical Engineers

### **Memberships and Continuing Education**

- Completed course work for BS in Management, Lesley College, Cambridge, MA, 1995, GPA 3.8/4
- Leadership Development Program, University of Maryland & Center for Creative Leadership, 1995.
- Industrial Power System Engineering, Power Technologies, Inc., Schenectady, NY (2.7 C.E.U's)
- Member for the Institute of Electrical and Electronics Engineers (IEEE)

**FRCC GENERATION INTERCONNECTION  
LOAD FLOW AND STABILITY STUDY  
VOLUME 1: LOAD FLOW STUDY**

**MIDWAY SITE**

**PANDA MIDWAY POWER PARTNERS, L.P.**

**APRIL 24, 2000**



# GENERATION INTERCONNECTION LOAD FLOW AND STABILITY STUDY TABLE OF CONTENTS

<b>INTRODUCTION .....</b>	<b>1</b>
<b>THE PROPOSED "PROJECT" .....</b>	<b>1</b>
<b>LOAD FLOW STUDY METHODOLOGY .....</b>	<b>1</b>
<b>MODELING / STUDY ASSUMPTIONS .....</b>	<b>2</b>
CASE DEVELOPMENT.....	3
DISPATCH ASSUMPTIONS .....	4
CONTINGENCIES.....	4
MONITORED INFORMATION.....	5
<b>EVALUATION CRITERIA .....</b>	<b>5</b>
FRCC SPECIFIC CRITERIA .....	5
REGIONAL UTILITIES' SPECIFIC CRITERIA.....	6
TECO Single Contingency Planning Criteria .....	6
Florida Power Corporation Planning Criteria .....	6
Florida Power and Light Planning Criteria .....	6
CRITERIA USED FOR THIS STUDY .....	7
<b>RESULTS.....</b>	<b>8</b>
<b>ANALYSIS .....</b>	<b>10</b>
THE HARTMAN 138 kV TO 69 kV TRANSFORMERS.....	10
THE HARTMAN TO CITRUS TO MIDWAY 138 kV LINES .....	10
<b>APPENDIX A: LOAD FLOW RESULTS.....</b>	<b>1</b>
100% LOAD LEVEL .....	1
60% LOAD LEVEL .....	10
40% LOAD LEVEL .....	12
<b>APPENDIX B: CONTINGENCY LIST .....</b>	<b>1</b>

This report has been prepared for the use of the client for the specific purposes identified in the report. The conclusions, observations and recommendations contained herein attributed to R.W. Beck, Inc. constitute the opinions of R. W. Beck, Inc. To the extent that statements, information and opinions provided by the client or others have been used in the preparation of this report, R.W. Beck, Inc. has relied upon the same to be accurate, and for which no assurances are intended and no representations or warranties are made. R.W. Beck, Inc. makes no certification and gives no assurances except as explicitly set forth in this report.

Copyright 2000, R. W. Beck, Inc.  
All rights reserved.



**PANDA MIDWAY**

**FRCC GENERATION INTERCONNECTION**  
**LOAD FLOW AND STABILITY STUDY**

---

**INTRODUCTION**

In accordance with your request, this report summarizes the results of our load flow and stability study to examine the technical aspects of interconnecting a proposed 1000 MW plant addition to the Florida transmission grid.

**THE PROPOSED "PROJECT"**

The Proposed Project is two, two-on-one F-Series 500 MW combined cycle units. The proposed Project site near the Midway substation. The proposed plant will be referred to as the Project throughout the remainder of the report. The output of the proposed plant would be sold within Florida.

The proposed interconnection for the project will be to the existing Midway 500 kV substation via two new 500 kV lines.

**LOAD FLOW STUDY METHODOLOGY**

The goal of the Load Flow Analysis is to perform an evaluation of the incremental impact of the Project on the loading of the regional transmission system. To achieve this goal, R. W. Beck uses the following process:

1. A Base Case is developed to establish a baseline performance of the system before the Project.
2. Alternative Case(s) are then developed which include the Project.
3. Single contingency analysis is then performed on all of the cases.
4. Results from the Alternative Case(s) are compared to the results from the Base Case to evaluate the incremental impact of the Project on the loading of the transmission system.
5. The results are analyzed and presented.

R. W. Beck uses General Electric's PSLF program to run the load flow cases.

The purpose of the technical evaluation is to determine if upgrades to the existing transmission system are likely to be required to integrate the Project to

---

the transmission grid. This study does not determine when and if the proposed Project would be dispatched. It instead evaluates the impact of the proposed generation on the planned transmission system, i.e., the Base Case configuration. The transmission loadings are evaluated against the applicable line or transformer capability ratings to determine whether it is likely that particular system components will require upgrade, replacement or additional protection as a condition for interconnecting the proposed Project. This study is not purported to represent a comprehensive review or analysis of physical interconnection alternatives, operational conditions, right-of-way or permitting from a cost or technical standpoint.

When studying generation export conditions, worst case conditions are often at lighter load levels. Near minimum (approx. 40-50%) load levels sometimes result in worst case conditions on the transmission system in close proximity to the Project, and "shoulder" load levels (approx. 60-70%) sometimes result in worst case conditions for multiple generating plants exporting from a region. Therefore, analysis was also performed at these lighter load levels.

### **MODELING / STUDY ASSUMPTIONS**

As with all load flow analyses, the results of the study are driven by the assumptions used in developing the load flow models. To minimize the impact of these assumptions, R. W. Beck starts the process with a FERC 715 load flow case model, and then details the changes made to the model in evaluating the resource addition. The most significant assumptions impacting the identified necessary improvements include:

- The "Merchant" (or other planned) Generation added to the Base Case load flow model.
- The re-dispatch of existing units used to offset the new projects, including the Client's project.

This section discusses these assumptions, and others made in performing the study, such as contingencies evaluated and information monitored.

R. W. Beck reviewed the Ten-Year Site Plans for the FRCC and Florida utilities to determine what transmission system improvements and generator additions are planned to be added to the system, as well as other announced regional generation additions.

TABLE 1

NEW GENERATION IN REGION INCLUDED IN BASE CASE

Developer	Type	Plant / Location	MW	ISD	Comments
Florida Power Corp.	CT	Intercession City	329	2001	Planned
Florida Power Corp	CC	Hines Energy Complex	470	2000	Already in FERC 715 2004 Case
FPL	CC	Fort Myers Repowering	926	2002	Already in FERC 715 2004 Case
FPL	CC	Sanford Repowering	2,280	2003	Already in FERC 715 2004 Case
Gainesville	CC	Kelly Unit 8 Repowering	110	2001	Planned
JEA	CT	Brandy Branch	149	2001	Planned
JEA	CFB	Northside	276	2002	Planned
FMPA	CC	Cane Island	240	2001	Already in FERC 715 2004 Case
Lakeland	CC	MacIntosh 5	337	2002	Already in FERC 715 2004 Case
SECI	CC	Paynes Creek	488	2002	Already in FERC 715 2004 Case
TECo	CC	Gannon Repowering	1,475	2004	Planned
Reliant	CT	Holopaw	460	2002	Planned
Duke Energy Power	CC	New Smyrna Beach	460	2001	Planned
PG&E Generating	CC	Okeechobee Co.	560	2003	Planned
IPS/Avon Park	CT	Hardee Co.	460	2001	Planned
Panda Midway	CC	Midway	1,000	2003	Not included in Base Case, included in Alternate Case

CASE DEVELOPMENT

The 2004 summer peak load flow model filed at the Federal Energy Regulatory Commission ("FERC") by the FRCC was used as a starting point to create the cases for the study. The utilities in the State file load flow cases at FERC annually. The load flow cases submitted include projections for several different years. Each load flow case for a future year includes projected loads and the planned generation additions and dispatch, and transmission improvements to meet those loads. Each load flow case must have an equal amount of generation and load. R. W. Beck relies upon these load flow models but does not independently verify all of the data in the models.

The FERC 715 case is modified to incorporate the Announced Regional Generation (see Table 1) to create a 100% Base Case. The load was scaled to a 60% load level and a 40% load level and generation redispached within peninsular Florida to create a 60% Base Case and a 40% Base Case, respectively. The method used to redispach the generation is described in the following section: Dispatch Assumptions.

The Base Cases were then further modified to create the Alternate Cases by including the Project (and the Panda Midway project).

A total of six (6) cases were developed:

1. 100% Load Level Base Case
2. 60% Load Level Base Case
3. 40% Load Level Base Case

4. 100% Load Level Alternate Case
5. 60% Load Level Alternate Case
6. 40% Load Level Alternate Case

The essential difference between the Base Cases and the Alternate Cases is that the Base Case do not include Panda Midway nor Panda Midway, while the Alternate Cases do.

### **DISPATCH ASSUMPTIONS**

As discussed in the previous section, generation is adjusted from the FERC 715 case to accommodate the Announced Regional Generation assumed in the study (see Table 1) to create the Base Cases. Generation is further adjusted to accommodate the proposed plant to create the Alternative Case(s). Generation is adjusted considering the following factors:

- Turned off and reduced generation in the following order: (i) gas turbines and diesels, (ii) oil and gas fired steam units, (iii) repowered and green-field combined cycle plants, (iv) coal plants.
- FERC Form 1 data for capacity factor, heat rate and costs (or forecasted heat rate and cost information for new units), when deciding among generators in the same technology.
- A general preference was given to keep plants in close proximity to the Project in service for a conservative study by increasing area export conditions and stressing the transmission system. And visa versa, plants far away from the Project will have little effect on the regional impacts of the Project.
- A general preference was given to enhance north to south flow through Florida (e.g., turning off generation in south Florida) further stressing the system.

At the 40% load level, we assumed that one nuclear unit would be out of service for maintenance and/or refueling because 40% load level would likely be a fall or spring minimum load. For conservatism, we chose Turkey Point because it is distant from the proposed Project, and, by taking this south of Miami unit out of service it increases north to south flows.

### **CONTINGENCIES**

A single contingency analysis was performed, in other words, one line or transformer is taken out of service at a time. To perform the contingency analyses, R. W. Beck created a contingency list containing all 230 kV and above transmission lines and transformers within peninsular Florida, all 69 kV to 138 kV lines and transformers in the region of the Project, and all generators larger than

100 MW within peninsular Florida. Appendix B is a list of the contingencies studied.

### **MONITORED INFORMATION**

For the Contingency analyses, R. W. Beck monitored voltages and flows on lines and transformers 69 kV and higher within peninsular Florida to assess any violations outside of the planning criteria described in the following sections.

### **EVALUATION CRITERIA**

Criteria are necessary to evaluate the performance of the transmission system within this analysis. This section describes 1) the coordinating council reliability criteria, 2) the regional utilities' reliability criteria, and 3) the criteria used for evaluation in this analysis.

### **FRCC SPECIFIC CRITERIA**

FRCC has established Planning Principal and Guides, including criteria for reliability in system planning. While the FRCC states that this reliability criteria is not mandated by the FRCC, its purpose is to promote maximum coordination of planning, construction and utilization of generation and transmission facilities involved in interconnected operations. FRCC recognizes that the reliability of power supply in local areas is the responsibility of the individual FRCC members and each member has internal criteria for planning and reliability. The current FRCC Planning Principals and Guides, as posted at the FRCC Web site, were adopted on September 25, 1996.

FRCC lists several guidelines pertaining to transmission adequacy, security, coordination, and protection systems. The guidelines define probable contingencies as single contingencies (e.g., loss of any one element), and states that: "Transmission systems should be capable of delivering generator unit output to meet projected customer demands during normal and probable contingencies." In general, the guidelines reflect typical transmission planning criteria, but are rather broad and offer few specific parameters. For example, the FRCC guidelines include no numerical targets for line and transformer loading or voltage specifications for either normal (Rating 1) or contingency conditions (Rating 2).

R. W. Beck has assumed that the two ratings provided in the load flow models correspond to the normal and emergency ratings when the two ratings are different.

- Rating 1 – Normal Rating
- Rating 2 – Emergency Rating

**REGIONAL UTILITIES' SPECIFIC CRITERIA**

**TECO SINGLE CONTINGENCY PLANNING CRITERIA**

Excerpted from TECO's 1998 FERC 715 Filing, Part 4.

TRANSMISSION SYSTEM LOADING LIMITS	
Transmission System Conditions	Acceptable Loading Limit for Transmission Lines and Transformers
Single Contingency, pre-switching	115% or less
Single Contingency, after all switching	100% or less
Bus Outages, pre-switching	115% or less
Bus Outages, after all switching	100% or less

**FLORIDA POWER CORPORATION PLANNING CRITERIA**

The Florida Power Corp. (FPC) Planning Criteria as published with FPC's FERC 715 filing is as follows:

- Voltage should be between 95% and 105% of nominal voltage for both normal conditions and contingencies.
- Loading on transmission lines and transformers should be under the Normal Rating under normal conditions.
- Under contingency conditions, the loading should be under the Emergency Rating.

**FLORIDA POWER AND LIGHT PLANNING CRITERIA**

The Florida Power and Light (FPL) Planning Criteria as published with FPL's FERC 715 filing is as follows:

"FPL has adopted transmission planning criteria that are consistent with the planning criteria established by the Florida Reliability Coordinating Council (FRCC) in its *Principles and Guides for Planning Reliable Bulk Electric Systems*. FPL has applied these planning criteria in a manner consistent with prudent utility practice. These criteria are included as part of the attachments to this response. There may have been isolated cases for which FPL may have determined it prudent to deviate from these criteria. The overall customers involved, the probability of an outage occurring, as well as other factors may have influenced this decision.

The criteria are used for planning purposes and not for operating the system. Some operating parameters such as time limited emergency ratings may be factored into the planning process provided there is sufficient time for operator

actions without jeopardizing the safety and reliability of the transmission system.”

FPL does use emergency ratings according to their criteria, when there is sufficient time for operator response. If an overload is caused by the project, a potential response would be to reduce the output of the Project post-contingency to alleviate overload concerns. Therefore, for the purposes of this study, it is assumed that emergency ratings can be used.

### CRITERIA USED FOR THIS STUDY

The transmission planning criteria used in the study are in accordance with “FRCC Planning Principles and Guides”. Because neither the FRCC guides nor the FPL criteria are specific, we used the following planning criteria, which is somewhat standard and is used by FPC:

- Voltage should be between 95% and 105% of nominal voltage for both normal conditions and contingencies.
- Loading on transmission lines and transformers should be under the Normal Rating (Rating 1) under normal conditions (Contingency 0).
- Under contingency conditions, the loading should be under the Emergency Rating (Rating 2).

The results of the contingency analyses for the Alternate Cases are compared with the Base Case loadings for the same contingency to determine if the new facilities were responsible for any new overloads. The Results section details the overloads in the Alternative Cases, both with and without contingencies. The overloads are compared to the Base Case results to make an assessment of the severity of the overload, specifically, the incremental impact on the overloaded facility of integration of the Project. The following table lists guidelines used by R. W. Beck to evaluate the incremental impact of the Project.

- Is the element overloaded in the Base Case? If the element is overloaded in the Base Case, then, the overload is a Pre-Existing condition and it is likely that the Project would not be responsible for any upgrades required to solve the overload concern. This also holds true if the results of the study indicate the same element is overloaded for other contingencies.
- Does the overload exceed the Emergency Rating for a contingency (Rating 2)? If the loading does not exceed the element's Emergency Rating (Rating 2), then, the line is able to carry the loading under contingency conditions.
- Does the overload exceed 15% of the Normal Rating if the Normal Rating (Rating 1) equals the Emergency Rating (Rating 2)? Frequently, in the FERC 715 filed case, Rating 2 is published as the same as Rating 1. This can be due to several reasons. The filing entity may not have calculated an emergency rating for that element and, therefore, published the Normal Rating as the Emergency Rating. The line may be “sag” restricted, e.g.,



restricted by clearance to ground of the conductor. Often, this can be easily fixed by re-tensioning the line and possibly minor modifications to some transmission structures. Or there may be minor equipment that limits the line, such as a disconnect switch. Typically, emergency ratings are about 15% greater than normal ratings (for example, TECO's planning criteria described above specifically mentions 15%). Therefore, for purposes of the analysis, if Rating 1 equals Rating 2, then the line is not reported as a new overload unless the overload exceed 115% of Rating 1. Note that if the line is sag limited, or otherwise limited, some corrective action may be necessary to achieve this emergency rating.

- Is the difference between the Base Case and the Alternate Case significant (e.g., greater than a 5% increase)? If the difference between the loading in the Base Case and the Alternate Case is insignificant, then the Project does not contribute significantly to the concern.
- Is the location of the overloaded line distant from the Project? If the location of the overloaded element is distant from the project, then, the cause of the overload is likely something other than the Project.
- Is the overload insignificant? If the overload is very small (e.g., 101% to 103%), then, the overload is within error tolerances of the study, and/or it may be that the situation can be resolved through an operating measure, such as reducing the output of the Project, to eliminate the overload.

### RESULTS

Appendix A consists of a series of tables listing all of the cases where Rating 1 was exceeded for both normal conditions (Contingency Number 0) and contingency conditions (preceded by a contingency number). Each line loading is listed in MW, MVAR and MVA for both the Base Case and Alternate Case, for the same contingency at the same load level. The rating is also reported as Rating 1 / Rating 2, and the percentage of the rating is reported for both the Base Case and the Alternate Case for each load level.

The tables are organized by Load Level (e.g., 100% or Peak, 60% or Shoulder, and 40% or Light), and by the following categories (see discussion in the Evaluation Criteria section):

## PANDA MIDWAY LOAD FLOW STUDY

<b>Potential Concerns</b>	These are lines and transformers that are of potential concern to integrating the project into the transmission grid.
<b>Overloaded for Another Contingency in the Base Case</b>	These are lines that are overloaded for another contingency, and possibly another load level, in one of the base cases
<b>Less than a 5% Increase from the Base Case</b>	These are lines where the loading increased only marginally
<b>Distant from the Project</b>	These are overloads distant from the Project.
<b>Minor Overload</b>	The overload is minor (e.g., 101% to 103%).
<b>Does not Exceed Rating 2 for a Contingency</b>	These lines are actually not overloaded since Rating 2 is not exceeded
<b>Does not Exceed 115% of Rating 1 for a Contingency if Rating 1 Equals Rating 2</b>	115% of Rating 1 is a typical value for an emergency rating, but, the emergency rating is either not published, or, is limited by another factor, often a minor factor (e.g., sag limited)
<b>Pre-Existing Violations</b>	These are lines overloaded in the Base Case for the same contingency.

Below is a table summarizing the results that are of potential concern to integrating the project into the interconnected peninsular Florida system. Note that the highest loading is shown in the table and the line may be overloaded for other load levels.

### POTENTIAL CONCERNS

All under peak load conditions:

Overload			Outage		Base Case Ldg MVA	Alt. Case Ldg MVA	Rating MVA	Base Case (% of Rating 1)	Alt. Case (% of Rating 1)
Xfmr	Hart-Fmp	Hartman 138/69kv	Emerson	Fv-CtyIn 138kv	42	61	50/ 50	84%	122%
Xfmr	Hart-Fmp	Hartman 138/69kv #2	Emerson	Fv-CtyIn 138kv	41	60	50/ 50	83%	120%
Line	Citrus	Hartman 138kv	Emerson	Emerson 138/230kv	238	362	272/ 272	87%	133%
Line	Citrus	Midway 138kv	Emerson	Emerson 138/230kv	238	362	272/ 272	87%	133%

## ANALYSIS

The results discussed in the previous section caused potential concerns in two areas:

1. The Hartman 138 kV to 69 kV transformers
2. The Hartman to Citrus to Midway 138 kV lines.

### THE HARTMAN 138 kV TO 69 kV TRANSFORMERS

There is a 69 kV system underlying the 230 and 138 kV system on the east coast of Florida in the Fort Pierce and Vero Beach area. There are several feeds from the 138 kV system into the 69 kV system, and, on loss of one of those feeds into the 69 kV system, other feeds into the 69 kV system become heavily loaded. In the peak load Base Case, the loss of the Emerson to Fv-Ctyln 138 kV line (one of the feeds into the 69 kV system) causes the Hartman 138 kV / 69 kV transformers to be loaded to 83-84% of Rating, without the Project. Note that, as published in the FERC 715 load flow database, Rating 1 equals Rating 2 (50 MVA) for these transformers.

The Project does cause Hartman to be a stronger source to the 69 kV system, increasing the loading of the transformers to a contingency loading of 120-122% of Rating 1 for the same contingency. This is of potential concern because it does exceed the 115% of Rating 1 that is typical of an emergency rating. However, transformers, because they are oil filled, take longer to heat up than overhead transmission lines. Therefore, the emergency ratings of transformers are often greater than 115% of Rating 1, and, since the loading exceeds Rating 1 by only 120%-122%, it is likely that the overload is within an emergency rating for the transformer.

For example, the American National Standards Institute (ANSI) Standard C57.92-1981 lists an two (2) hour emergency rating for a typical transformer (65 degrees C rise, Forced-Air-Cooled Transformer rated over 133% of self-cooled rating with an equivalent load of 70% of maximum nameplate rating pre-contingency, 30 degrees C ambient temperature) as 129% of normal rating with no loss of life. An one (1) hour rating under the same conditions is 145% of normal rating. So, if the transformers comply with the ANSI standards, the transformers should be able to carry this contingency loading.

The cost effective solution appears to be to calculate long term and short term emergency ratings for the transformers and to back down the Project output post-contingency to bring the transformer loading to within the appropriate rating.

### THE HARTMAN TO CITRUS TO MIDWAY 138 kV LINES

Similar to the above situation, there are several feeds into the 138 kV system from the 230 kV system. In the Base Case, without the Project, if the Emerson 230 kV to

138 kV transformer is lost, the 115 kV lines fed from the 230 kV at Midway (Midway to Citrus to Hartman) becomes heavily loaded to 87% of Rating 1. Note that, as published in the FERC 715 load flow database, Rating 1 equals Rating 2 (272 MVA) for these lines.

The Project does cause Midway to be a stronger source to the 138 kV system, increasing the loading of the lines to a contingency loading of 133% of Rating 1 for the same contingency. This is of potential concern because it does exceed the 115% of Rating 1 that is typical of an emergency rating.

There are a few options for addressing the overloads of this 138 kV corridor.

1. Upgrade the Midway to Citrus and Citrus to Hartman lines (estimated cost of \$1.5 to \$2M).
2. Install a series reactor to limit flow on this line (estimated cost of about \$500,000).

Preliminary analysis on the effectiveness of the series reactor was performed. This preliminary analysis indicated that the reactor effectively eliminates the overloads on this 138 kV corridor while not causing adverse conditions to other parallel lines.

The cost-effective solution appears to be a series reactor with an estimated cost of \$500,000.

## APPENDIX A: LOAD FLOW RESULTS

---

---

4/20/00

N:\005551\032789\Testimony\FPG-2- Midway 4-19.doc



100% LOAD LEVEL

POTENTIAL CONCERNS

No. Overload	Area	Outage	Base Case Ldg			Alt. Case Ldg			Rating	Base Case		Alt. Case	
			MW	MVar	MVA	MW	MVar	MVA		MVA	Rtg1	Rtg2	Rtg1
4	Xlmr Hart-Fmp to Hartman 138/ 69kv	FTP Emerson to Fv-Ctyln 138kv	41	9	42	61	7	61	50/ 50	84%	84%	122%	122%
4	Xlmr Hart-Fmp to Hartman 138/ 69kv #2	FTP Emerson to Fv-Ctyln 138kv	41	9	41	60	7	60	50/ 50	83%	83%	120%	120%
90	Line Citrus to Hartman 138kv	FPL Emerson to Emerson 138/230kv	236	25	238	359	46	362	272/ 272	87%	87%	133%	133%
90	Line Citrus to Midway 138kv	FPL Emerson to Emerson 138/230kv	-236	-25	238	-359	-46	362	272/ 272	87%	87%	133%	133%

DISTANT FROM THE PROJECT

No. Overload	Area	Outage	Base Case Ldg			Alt. Case Ldg			Rating	Base Case		Alt. Case	
			MW	MVar	MVA	MW	MVar	MVA		MVA	Rtg1	Rtg2	Rtg1
143	Line Enola to Umatilla 69kv	FPC Hainesck to Sorrento 230kv	122	-9	122	161	-15	161	126/ 138	94%	88%	125%	117%
228	Line Martin W to Reddick (1) 69kv	FPC Archer to Plrd 230kv	33	4	33	40	0	40	32/ 38	102%	88%	121%	104%
234	Line Bell Tp to Trenton (2) 69kv	FPC Ft Wht S to Newberry 230kv	-33	10	34	-41	13	43	32/ 38	107%	90%	136%	114%
234	Line Martin W to Reddick (1) 69kv	FPC Ft Wht S to Newberry 230kv	35	3	35	39	0	39	32/ 38	106%	92%	120%	103%
237	Line Inglis to Lebanon (3) 69kv	FPC Newberry to Wilcox 230kv	38	-2	38	40	-3	40	32/ 38	115%	99%	123%	106%
267	Line Homsatp2 to Villa Tp (4) 115kv	FPC Brkridge to Cryst Rv 500kv	-121	58	135	-131	61	145	137/ 137	98%	98%	105%	105%
267	Line Martin W to Reddick (1) 69kv	FPC Brkridge to Cryst Rv 500kv	35	3	35	39	1	39	32/ 38	106%	92%	118%	102%

**LESS THAN A 5% INCREASE FROM THE BASE CASE**

No. Overload	Area	Outage	Base Case Ldg			Alt. Case Ldg			Rating	Base Case		Alt. Case				
			MW	MVar	MVA	MW	MVar	MVA		MVA	Rtg1	Rtg2	Rtg1	Rtg2		
62	Line	Midway to Turnpike 230kv	FPL	Indn Twn	to Bridge 230kv	636	190	664	652	191	679	647/ 647	99%	99%	101%	101%
181	Line	Dade Cty to Dc Notap 69kv	TEC	Lk Tarpn	to Brkridge 500kv	63	5	63	66	4	66	63/ 63	98%	98%	103%	103%
181	Line	Dc Notap to Ft King 69kv	TEC	Lk Tarpn	to Brkridge 500kv	63	5	63	66	4	66	63/ 63	98%	98%	103%	103%
181	Line	Hudson to Hudsontp 115kv	FPC	Lk Tarpn	to Brkridge 500kv	287	82	298	296	84	307	246/ 302	119%	99%	122%	102%

**DOES NOT EXCEED RATING 2 FOR A CONTINGENCY**

No. Overload	Area	Outage	Base Case Ldg			Alt. Case Ldg			Rating	Base Case		Alt. Case				
			MW	Mvar	MVA	MW	Mvar	MVA		MVA	Rtg1	Rtg2	Rtg1	Rtg2		
6	Xfmr	Emerson to Emerson 138/230kv	FPL	Citrus	to Hartman 138kv	-276	.	279	-412	-21	413	400/ 577	70%	49%	104%	72%
7	Xfmr	Emerson to Emerson 138/230kv	FPL	Citrus	to Midway 138kv	-276	-38	279	-412	-21	413	400/ 577	70%	49%	104%	72%
90	Xfmr	Midway to Midway 138/230kv #2	FPL	Emerson	to Emerson 138/230kv	-170	-11	170	-225	-29	226	224/ 286	77%	60%	103%	79%
144	Line	Curry Fd to Stanton 230kv	FPC	Hainesck	to Cent Fla 230kv	-404	0	404	-459	-25	460	444/ 553	88%	73%	100%	83%
144	Xfmr	Dallas to Dallas 69/230kv	FPC	Hainesck	to Cent Fla 230kv	-140	-52	150	-145	-49	153	150/ 280	102%	53%	104%	55%
144	Line	Leesbg E to Midway 69kv	FPC	Hainesck	to Cent Fla 230kv	-78	23	81	-136	34	141	126/ 143	63%	56%	109%	98%
155	Xfmr	Clmt Est to Clmt Est 69/230kv	FPC	Clmt Est	to Winderme 230kv	-178	-22	179	-253	-17	254	250/ 280	73%	64%	103%	91%
170	Line	Hudson to Hudsontp 115kv	FPC	Lk Tarpn	to Hudson 230kv	250	68	259	258	68	266	246/ 302	103%	86%	106%	88%
177	Line	Higgins to Griffin 115kv	FPC	Griffin	to Kathleen 230kv	-137	59	149	-117	47	126	142/ 168	104%	89%	88%	75%
178	Line	Avon Pkn to Frostprf 69kv	FPC	Griffin	to West 230kv	78	-4	78	76	-3	76	75/ 82	102%	95%	100%	93%
178	Line	Juneau-W to Gannon 138kv	TEC	Griffin	to West 230kv	-305	-18	305	-294	-18	295	300/ 300	102%	102%	98%	98%
178	Line	So Gib to B Bend 230kv	TEC	Griffin	to West 230kv	-656	-174	679	-613	-170	636	634/ 634	103%	103%	96%	96%
180	Line	Hudson to Hudsontp 115kv	FPC	Lk Tarpn	to Lkt-Dum2 500kv	238	72	249	243	69	252	246/ 302	99%	83%	100%	84%
181	Line	Higgins to Griffin 115kv	FPC	Lk Tarpn	to Brkridge 500kv	-156	51	164	-151	48	158	142/ 168	118%	98%	113%	94%
181	Line	Disston to N East B 115kv	FPC	Lk Tarpn	to Brkridge 500kv	-124	-72	143	-124	-79	147	144/ 183	98%	79%	101%	80%
181	Xfmr	River-S to River-S 69/230kv	TEC	Lk Tarpn	to Brkridge 500kv	-214	-42	218	-210	-43	214	224/ 232	100%	94%	98%	92%
181	Line	11th Ave to So Gib 230kv	TEC	Lk Tarpn	to Brkridge 500kv	-599	-214	636	-577	-212	615	634/ 634	102%	102%	98%	98%
181	Xfmr	Hkrs Pt to Hkrspt-S 138/ 69kv	TEC	Lk Tarpn	to Brkridge 500kv	175	50	182	174	50	181	168/ 187	108%	98%	108%	97%
189	Line	Curry Fd to Stanton 230kv	FPC	Deland W	to Silvr Sp 230kv	-395	1	395	-465	-26	465	444/ 553	86%	71%	101%	84%

APPENDIX A: RESULTS

No. Overload	Area	Outage	Base Case Ldg			Alt. Case Ldg			Rating MVA	Base Case		Alt. Case					
			MW	Mvar	MVA	MW	Mvar	MVA		Rtg1	Rtg2	Rtg1	Rtg2				
195	Line	Curry Fd to Stanton 230kv	FPC	N Longwd	to	Wtr Spgs 230kv	-401	-15	402	-459	-47	461	444/ 553	87%	72%	101%	83%
198	Xfmr	Stc East to Stc East 230/ 69kv	OUC	Taylr Ck	to	Holopaw 230kv	147	15	147	154	18	155	150/ 168	98%	88%	103%	92%
198	Line	Stc East to Stc Nth 69kv	OUC	Taylr Ck	to	Holopaw 230kv	127	-5	127	133	-4	134	116/ 144	109%	88%	115%	93%
199	Line	Curry Fd to Stanton 230kv	FPC	Wtr Pk E	to	Wtr Spgs 230kv	-490	-27	491	-495	-36	496	444/ 553	107%	89%	108%	90%
204	Line	Babspktp to Indlketp 69kv	FPC	Avon Pk	to	Ft Meade 230kv	-64	36	73	-59	34	68	75/ 82	101%	89%	94%	83%
204	Line	Frostprf to Indlketp 69kv	FPC	Avon Pk	to	Ft Meade 230kv	66	-31	73	61	-29	67	75/ 82	101%	89%	94%	82%
207	Line	Avon Pkn to Frostprf 69kv	FPC	Barcola	to	West 230kv	77	-4	77	76	-3	76	75/ 82	102%	94%	101%	93%
216	Line	Union Hl to Dadect T 69kv	FPC	Kathleen	to	Zephyr N 230kv	125	29	128	128	28	131	126/ 150	99%	85%	102%	87%
216	Xfmr	River-S to River-S 69/230kv	TEC	Kathleen	to	Zephyr N 230kv	-226	-26	227	-221	-26	223	224/ 232	103%	98%	101%	96%
217	Line	Avon Pkn to Frostprf 69kv	FPC	N Bartow	to	Pebb 230kv	79	-3	79	78	-3	78	75/ 82	104%	96%	104%	96%
218	Line	Avon Pkn to Frostprf 69kv	FPC	N Bartow	to	Selose T 230kv	79	-3	79	79	-4	79	75/ 82	104%	96%	104%	96%
223	Line	Avon Pkn to Frostprf 69kv	FPC	Wik Wale	to	Selose T 230kv	77	-4	78	77	-3	77	75/ 82	102%	94%	102%	94%
227	Line	Mcntshtp to Reddick 69kv	FPC	Archer	to	Martin W 230kv	-25	6	26	-33	10	34	32/ 38	81%	68%	107%	90%
232	Line	Bell Tp to Trenton 69kv	FPC	Ft Wht N	to	Ft Wht S 230kv	-29	10	31	-35	11	37	32/ 38	97%	81%	116%	97%
232	Line	Jasper to Wghtchpl 115kv	FPC	Ft Wht N	to	Ft Wht S 230kv	-8	30	31	-7	34	35	35/ 43	95%	74%	103%	80%
234	Line	Bell Tp to Neals Tp 69kv	FPC	Ft Wht S	to	Newberry 230kv	23	-13	26	31	-17	35	32/ 38	82%	69%	111%	93%
207	Line	Barcola to Pebb 230kv	FPC	Barcola	to	West 230kv	574	-16	574	529	-9	529	492/ 542	112%	106%	103%	98%
208	Line	Avon Pkn to Frostprf 69kv	FPC	Barcola	to	Pebb 230kv	81	-4	81	79	-3	80	75/ 82	106%	98%	105%	97%
359	Xfmr	River-N to River-N 230/ 69kv	TEC	11th Ave	to	So Gib 230kv	222	70	233	215	66	225	224/ 234	104%	100%	100%	96%
370	Xfmr	River-N to River-N 230/ 69kv	TEC	So Gib	to	B Bend 230kv	223	68	233	216	65	226	224/ 234	104%	100%	101%	96%
378	Line	Barcola to Pebb 230kv	FPC	Polkplnt	to	Hardesub 230kv	543	-27	544	517	-21	517	492/ 542	106%	100%	101%	95%
237	Line	Lebanon to Ottcktp 69kv	FPC	Newberry	to	Willcox 230kv	33	-6	33	35	-7	36	32/ 38	105%	88%	113%	95%
238	Line	Ottcktp to Usher Tp 69kv	FPC	Newberry	to	Cr Plant 230kv	16	-21	26	21	-25	32	32/ 38	84%	69%	103%	85%
242	Line	Jasper to Wghtchpl 115kv	FPC	Suwannee	to	Sterling 230kv	-19	35	40	-18	34	38	35/ 43	117%	93%	111%	88%
245	Xfmr	Dallas to Dailas 69/230kv	FPC	Andersen	to	Holder 230kv	-142	-50	150	-144	-49	152	150/ 280	103%	54%	104%	54%
246	Line	Brkridge to Brksvl W 115kv	FPC	Brkridge	to	Brksvwtp 230kv	246	-10	246	254	-15	255	246/ 302	98%	81%	101%	84%
246	Line	Hudson to Hudsonp 115kv	FPC	Brkridge	to	Brksvwtp 230kv	246	72	256	250	67	259	246/ 302	102%	85%	103%	86%
249	Line	Sprghltp to Heritgtp 115kv	FPC	Brkridge	to	Hudson 230kv	121	-53	133	129	-56	141	136/ 169	96%	78%	102%	83%
251	Line	Hudson to Hudsonp 115kv	FPC	Brksvwtp	to	Gulfpine 230kv	260	66	268	267	64	274	246/ 302	107%	89%	109%	91%
256	Line	Jasper to Wghtchpl 115kv	FPC	Cr Plant	to	Cryst R4 230kv	-15	38	41	-14	37	39	35/ 43	120%	95%	115%	91%
256	Xfmr	Dallas to Dallas 69/230kv	FPC	Cr Plant	to	Cryst R4 230kv	-142	-48	150	-145	-46	152	150/ 280	102%	53%	104%	54%



APPENDIX A: RESULTS

No.	Overload	Area	Outage	Base Case Ldg			Alt. Case Ldg			Rating	Base Case		Alt. Case					
				MW	Mvar	MVA	MW	Mvar	MVA		MVA	Rtg1	Rtg2	Rtg1	Rtg2			
256	Line Juneau-W	to Gannon	138kv	TEC	Cr Plant	to Cryst R4	230kv	-303	-19	304	-297	-19	297	300/300	101%	101%	99%	99%
259	Xfmr Dallas	to Dallas	69/230kv	FPC	Dallas	to Silvr Sp	230kv	-121	-52	132	-145	-47	153	150/280	90%	47%	104%	54%
260	Xfmr Dallas	to Dallas	69/230kv	FPC	Martin W	to Silv Spn	230kv	-143	-50	151	-147	-48	155	150/280	104%	54%	106%	55%
266	Xfmr Dallas	to Dallas	69/230kv	FPC	Brdg-Dum	to Brkridge	500kv	-138	-52	148	-141	-49	149	150/280	101%	53%	102%	53%
267	Xfmr Dallas	to Dallas	69/230kv	FPC	Brkridge	to Cryst Rv	500kv	-145	-45	152	-149	-47	157	150/280	104%	55%	107%	56%
267	Line Disston	to N East B	115kv	FPC	Brkridge	to Cryst Rv	500kv	-123	-97	157	-123	-97	156	144/183	111%	88%	107%	85%
267	Line Zephyr N	to Zephyrhl	69kv	FPC	Brkridge	to Cryst Rv	500kv	141	13	141	143	9	143	126/150	109%	94%	111%	95%
267	Line Hudson	to Hudsontp	115kv	FPC	Brkridge	to Cryst Rv	500kv	237	91	254	241	87	256	246/302	104%	85%	103%	85%
267	Line Tri-City	to Ulmerton	115kv	FPC	Brkridge	to Cryst Rv	500kv	1	-118	118	-2	-126	126	125/137	97%	88%	101%	92%
267	Line River-N	to Gte-Coll	69kv	TEC	Brkridge	to Cryst Rv	500kv	138	38	143	135	37	140	143/143	102%	102%	99%	99%
267	Xfmr River-S	to River-S	69/230kv	TEC	Brkridge	to Cryst Rv	500kv	-221	-45	226	-217	-45	222	224/232	104%	98%	102%	95%
267	Line Chapman	to Gannon	230kv	TEC	Brkridge	to Cryst Rv	500kv	-523	-130	539	-504	-126	520	550/550	104%	104%	99%	99%
267	Xfmr Hkrs Pt	to Hkrspt-S	138/69kv	TEC	Brkridge	to Cryst Rv	500kv	176	51	183	175	50	182	168/187	109%	99%	109%	98%
267	Line Pt Sutttn	to Baymet T	69kv	TEC	Brkridge	to Cryst Rv	500kv	-67	-21	71	-66	-19	68	72/121	102%	59%	98%	57%
271	Line Jasper	to Wghtchpl	115kv	FPC	Cryst Rv	to Cryst R5	500kv	-13	36	38	-12	35	37	35/43	113%	89%	109%	87%
271	Line Juneau-W	to Gannon	138kv	TEC	Cryst Rv	to Cryst R5	500kv	-304	-21	305	-297	-19	298	300/300	102%	102%	99%	99%
281	Line Hudson	to Hudsontp	115kv	FPC	Anclote	to Seven Sp	230kv	253	70	263	258	73	268	246/302	105%	87%	106%	89%
283	Line Hudson	to Hudsontp	115kv	FPC	Gulfpine	to Seven Sp	230kv	260	66	268	267	65	274	246/302	107%	89%	109%	91%
336	Xfmr Ocala I	to Ocala-1	230/69kv	FPC	Ocala 2	to Silv Spn	230kv	145	59	157	145	59	157	150/165	104%	94%	104%	95%
336	Xfmr Ocala I	to Ocala-1	230/69kv #2	FPC	Ocala 2	to Silv Spn	230kv	145	59	157	145	59	157	150/165	105%	95%	105%	95%
347	Line Avon Pkn	to Frostprf	69kv	FPC	Osceola	to Lkagnes	230kv	79	-3	79	78	-3	78	75/82	103%	95%	103%	95%
349	Xfmr Hkrs Pt	to Hkrspt-S	138/69kv	TEC	Sheld	to Jaxsn230	230kv	175	47	181	174	47	180	168/187	108%	97%	107%	96%
351	Line Juneau-W	to Gannon	138kv	TEC	Dlmbrly-W	to Dlmbrly-E	230kv	-301	-22	302	-294	-22	294	300/300	101%	101%	98%	98%
351	Xfmr Hkrs Pt	to Hkrspt-S	138/69kv	TEC	Dlmbrly-W	to Dlmbrly-E	230kv	176	49	182	174	48	181	168/187	109%	98%	108%	97%
351	Line So Gib	to B Bend	230kv	TEC	Dlmbrly-W	to Dlmbrly-E	230kv	-647	-184	673	-616	-182	643	634/634	102%	102%	97%	97%
352	Xfmr Hkrs Pt	to Hkrspt-S	138/69kv	TEC	Dlmbrly-E	to Chapman	230kv	177	51	184	176	49	183	168/187	110%	98%	109%	98%
354	Line Hydepk-N	to Hydepk-S	69kv	TEC	Ohio-N	to 11th Ave	230kv	-144	-14	145	-136	-14	137	143/143	105%	102%	99%	96%
354	Line Hydepk-N	to Matz-N T	69kv	TEC	Ohio-N	to 11th Ave	230kv	120	6	121	112	6	113	120/120	104%	104%	97%	97%
354	Line River-N	to Gte-Coll	69kv	TEC	Ohio-N	to 11th Ave	230kv	143	31	146	138	31	141	143/143	101%	101%	97%	97%
354	Xfmr River-S	to River-S	69/230kv	TEC	Ohio-N	to 11th Ave	230kv	-218	-31	221	-213	-31	215	224/232	101%	95%	98%	93%
366	Xfmr Hamptn	to Hamptn	230/69kv	TEC	Sr60-N	to Sr60-N T	230kv	216	60	224	215	60	223	224/242	100%	93%	99%	92%

APPENDIX A: RESULTS

No.	Overload	Area	Outage	Base Case Ldg			Alt. Case Ldg			Rating MVA	Base Case		Alt. Case	
				MW	Mvar	MVA	MW	Mvar	MVA		Rtg1	Rtg2	Rtg1	Rtg2
366	Line So Gib to B Bend 230kv	TEC	Sr60-N to Sr60-N T 230kv	-648	-184	674	-621	-183	647	634/ 634	102%	102%	98%	98%
367	Xfmr River-S to River-S 69/230kv	TEC	Sr60-S to Sr60-S T 230kv	-219	-29	221	-215	-30	217	224/ 232	101%	95%	99%	93%
367	Line So Gib to B Bend 230kv	TEC	Sr60-S to Sr60-S T 230kv	-641	-180	665	-614	-178	640	634/ 634	101%	101%	97%	97%
370	Line Higgins to Griffin 115kv	FPC	So Gib to B Bend 230kv	-133	51	142	-124	47	133	142/ 168	101%	85%	93%	79%
370	Line Cooldg to Juneau-W 138kv	TEC	So Gib to B Bend 230kv	-242	25	243	-234	23	235	249/ 249	101%	101%	97%	97%
370	Xfmr Sr60-N to Sr60-N 230/ 69kv	TEC	So Gib to B Bend 230kv	192	60	201	189	58	198	196/ 208	103%	97%	101%	95%
370	Line Ruskint2 to Delweb 69kv	TEC	So Gib to B Bend 230kv	81	16	83	79	15	81	82/ 82	101%	101%	98%	98%
371	Line So Gib to B Bend 230kv	TEC	Ruskin T to B Bend 230kv	-652	-172	674	-625	-171	648	634/ 634	102%	102%	98%	98%
388	Xfmr Dallas to Dallas 69/230kv	FPC	Brdg-Dum to Brkridge 500/230kv	-138	-52	148	-141	-49	149	150/ 280	101%	53%	102%	53%
356	Line Juneau-W to Gannon 138kv	TEC	River-N to Sr60-S T 230kv	-303	-19	303	-296	-19	297	300/ 300	101%	101%	99%	99%
356	Xfmr Hkrs Pt to Hkrspt-S 138/ 69kv	TEC	River-N to Sr60-S T 230kv	175	47	182	174	46	180	168/ 187	108%	97%	107%	96%
359	Line Higgins to Griffin 115kv	FPC	11th Ave to So Gib 230kv	-134	51	143	-125	48	133	142/ 168	101%	86%	94%	79%
359	Line Cooldg to Juneau-W 138kv	TEC	11th Ave to So Gib 230kv	-248	22	249	-238	20	239	249/ 249	104%	104%	99%	99%
359	Line Cargill to Baymet T 69kv	TEC	11th Ave to So Gib 230kv	94	26	97	89	24	92	93/ 93	105%	105%	99%	99%
359	Xfmr Sr60-N to Sr60-N 230/ 69kv	TEC	11th Ave to So Gib 230kv	188	59	197	184	57	193	196/ 208	100%	95%	98%	93%
359	Line Nitrm T to Pt Suttm 69kv	TEC	11th Ave to So Gib 230kv	-80	-17	82	-76	-15	77	72/ 120	116%	68%	109%	64%
359	Line Pt Suttm to Baymet T 69kv	TEC	11th Ave to So Gib 230kv	-93	-21	95	-88	-19	90	72/ 121	135%	79%	128%	75%
360	Xfmr River-S to River-S 69/230kv	TEC	Hamptn to Hamptn T 230kv	-225	-34	227	-220	-35	223	224/ 232	104%	98%	102%	96%
360	Xfmr Hkrs Pt to Hkrspt-S 138/ 69kv	TEC	Hamptn to Hamptn T 230kv	178	49	185	177	48	183	168/ 187	110%	99%	109%	98%
360	Line Mulb-S to Sandbl-W 69kv	TEC	Hamptn to Hamptn T 230kv	-143	-16	144	-137	-17	138	143/ 143	103%	103%	98%	98%
364	Xfmr Hkrs Pt to Hkrspt-S 138/ 69kv	TEC	Gannon to Sr60-N T 230kv	177	46	183	175	46	181	168/ 187	109%	98%	108%	97%
366	Line Juneau-W to Gannon 138kv	TEC	Sr60-N to Sr60-N T 230kv	-300	-21	300	-293	-21	294	300/ 300	100%	100%	98%	98%

**OVERLOAD DOES NOT EXCEED 115% OF RATING 1 IF RATING 1 EQUALS RATING 2**

No. Overload	Area	Outage	Base Case Ldg			Alt. Case Ldg			Rating	Base Case		Alt. Case				
			MW	MVar	MVA	MW	MVar	MVA		MVA	Rtg1	Rtg2	Rtg1	Rtg2		
90	Line Hartman	to F Pierce 138kv	FPL	Emerson	to Emerson 138/230kv	165	39	169	263	39	266	241/ 241	71%	71%	112%	112%
139	Xfmr Hart-Fmp	to Hartman 138/ 69kv #2	FTP	Hartman	to Hart-Fmp 69/138kv	38	-10	40	49	-11	50	50/ 50	81%	81%	102%	102%
140	Xfmr Hart-Fmp	to Hartman 138/ 69kv	FTP	Hartman	to Hart Fmp 69/138kv #2	39	-10	40	49	-11	50	50/ 50	82%	82%	103%	103%
181	Xfmr Brkridge	to Brdg-Dum 230/500kv	FPC	Lk Tarpn	to Brkridge 500kv	-676	-146	691	-710	-146	725	750/ 750	96%	96%	101%	101%

**PRE-EXISTING VIOLATIONS - OVERLOADED IN THE BASE CASE WITHOUT THE PROJECT**

No. Overload	Area	Outage	Base Case Ldg			Alt. Case Ldg			Rating	Base Case		Alt. Case				
			MW	MVar	MVA	MW	MVar	MVA		MVA	Rtg1	Rtg2	Rtg1	Rtg2		
0	Line Howey Tp	to Howeymtr 69kv	FPC	No Outage		32	11	33	32	11	33	32/ 38	102%	87%	103%	88%
0	Line Howeymtr	to Howey 69kv	FPC	No Outage		32	10	33	32	11	33	31/ 37	106%	89%	107%	90%
0	Line Dlarpttp	to Dalasmet 69kv	FPC	No Outage		-59	-29	66	-54	-30	62	50/ 62	132%	106%	125%	100%
0	Line Dlarpttp	to Belview 69kv	FPC	No Outage		67	29	73	67	29	73	52/ 52	141%	141%	142%	142%
0	Line Dalasmet	to Dallas 69kv	FPC	No Outage		-59	-29	66	-55	-30	62	50/ 62	132%	106%	125%	101%
0	Xfmr Dallas	to Dallas 69/230kv	FPC	No Outage		-137	-50	146	-140	-49	148	150/ 280	100%	52%	101%	53%
0	Line Martin W	to Reddick 69kv	FPC	No Outage		33	4	33	36	2	36	32/ 38	100%	86%	110%	95%
0	Line Brt St T	to Lee 138kv	FPL	No Outage		-221	-78	234	-221	-78	234	173/ 173	137%	137%	137%	137%
0	Line Corbett	to Lee 138kv	FPL	No Outage		-171	-58	181	-171	-58	181	173/ 173	103%	103%	103%	103%
0	Xfmr Miccosk	to Miccosk 115/ 69kv	FPC	No Outage		28	11	30	28	11	30	20/ 20	152%	152%	152%	152%
0	Line Hudson	to Sea P Tp 115kv	FPC	No Outage		126	50	135	126	50	135	114/ 114	118%	118%	118%	118%
0	Xfmr Juneau-E	to Juneau-E 138/ 69kv	TEC	No Outage		184	27	186	181	27	183	168/ 183	111%	102%	109%	100%
0	Xfmr Hkrs Pt	to Hkrspt-S 138/ 69kv	TEC	No Outage		173	46	179	172	45	178	168/ 187	107%	96%	106%	95%
18	Line Britgoab	to Morris 69kv	FPL	Okechobe	to Morris 69kv	-54	-87	103	-54	-87	103	44/ 44	235%	235%	235%	235%
57	Line Midway	to Wh Ctytp 138kv	FPL	Sanpiper	to Turnpike 230kv	252	93	268	252	93	268	241/ 241	110%	110%	110%	110%
95	Xfmr Sherman	to Sherman 69/230kv	FPL	Sherman	to Sherman 69/230kv #2	-58	-6	58	-58	-6	58	50/ 50	120%	120%	120%	120%
113	Line Midway	to Wh Ctytp 138kv	FPL	Sanpiper	to Sanpiper 138/230kv	252	93	268	252	93	268	241/ 241	110%	110%	110%	110%
131	Xfmr Hart-Fmp	to Hartman 138/ 69kv	FTP	Ftp-Ga C	to Fv-Ctyln 138kv	58	1	58	58	5	58	50/ 50	115%	115%	116%	116%

APPENDIX A: RESULTS

No. Overload	Area	Outage	Base Case Ldg			Alt. Case Ldg			Rating	Base Case		Alt. Case	
			MW	MVar	MVA	MW	MVar	MVA		MVA	Rtg1	Rtg2	Rtg1
131	Xfmr Hart-Fmp	to Hartman 138/ 69kv #2 FTP Ftp-Ga C to Fv-Ctyln 138kv	57	1	57	57	4	57	50/ 50	113%	113%	113%	113%
141	Xfmr Hart-Fmp	to Hartman 138/ 69kv FTP Garden C to Ftp-Ga C 69/138kv	58	1	58	58	5	58	50/ 50	115%	115%	116%	116%
141	Xfmr Hart-Fmp	to Hartman 138/ 69kv #2 FTP Garden C to Ftp-Ga C 69/138kv	57	1	57	57	4	57	50/ 50	113%	113%	113%	113%
151	Xfmr Altamont	to Altamont 69/230kv FPC Spg Lake to Altamont 230kv	-231	-45	236	-213	-69	224	200/ 224	122%	105%	117%	100%
177	Xfmr Juneau-E	to Juneau-E 138/ 69kv TEC Griffin to Kathleen 230kv	187	27	188	182	27	184	168/ 183	112%	103%	109%	100%
178	Xfmr Juneau-E	to Juneau-E 138/ 69kv TEC Griffin to West 230kv	190	27	192	184	27	186	168/ 183	114%	105%	111%	102%
181	Xfmr Juneau-E	to Juneau-E 138/ 69kv TEC Lk Tarpn to Brkridge 500kv	191	37	194	188	37	192	168/ 183	116%	106%	114%	105%
181	Line Juneau-W	to Gannon 138kv TEC Lk Tarpn to Brkridge 500kv	-310	-35	312	-305	-36	308	300/ 300	107%	107%	105%	105%
181	Line So Gib	to B Bend 230kv TEC Lk Tarpn to Brkridge 500kv	-710	-293	768	-689	-286	746	634/ 634	117%	117%	114%	114%
189	Line Dlarpttp	to Dalasmet 69kv FPC Deland W to Silvr Sp 230kv	-60	-28	66	-58	-29	64	50/ 62	134%	107%	130%	104%
189	Line Dalasmet	to Dallas 69kv FPC Deland W to Silvr Sp 230kv	-60	-28	66	-58	-29	65	50/ 62	134%	107%	130%	104%
201	Xfmr Juneau-E	to Juneau-E 138/ 69kv TEC Loughman to Intersn 230kv	186	27	188	183	27	185	168/ 183	112%	103%	110%	101%
202	Xfmr Juneau-E	to Juneau-E 138/ 69kv TEC Loughman to Wlk Wale 230kv	186	27	188	183	27	185	168/ 183	112%	103%	110%	101%
204	Line Avon Pkn	to Frostprf 69kv FPC Avon Pk to Ft Meade 230kv	101	-6	101	95	-6	95	75/ 82	135%	123%	128%	116%
214	Line Avon Pkn	to Frostprf 69kv FPC Ft Meade to Wlk Wale 230kv	88	-4	88	88	-4	88	75/ 82	115%	106%	116%	107%
214	Line Barcola	to Pebb 230kv FPC Ft Meade to Wlk Wale 230kv	582	-13	582	574	-4	574	492/ 542	114%	107%	112%	106%
216	Xfmr Juneau-E	to Juneau-E 138/ 69kv TEC Kathleen to Zephyr N 230kv	189	28	191	186	29	188	168/ 183	114%	105%	112%	103%
227	Line Martin W	to Reddick 69kv FPC Archer to Martin W 230kv	42	1	42	50	-3	50	32/ 38	127%	109%	152%	131%
238	Line Inglis	to Lebanon 69kv FPC Newberry to Cr Plant 230kv	43	-8	43	49	-9	50	32/ 38	132%	114%	152%	132%
238	Line Lebanon	to Ottrcktp 69kv FPC Newberry to Cr Plant 230kv	38	-12	39	44	-14	46	32/ 38	123%	103%	143%	120%
238	Line Martin W	to Reddick 69kv FPC Newberry to Cr Plant 230kv	38	2	38	43	-1	43	32/ 38	116%	100%	130%	112%
245	Line Dlarpttp	to Dalasmet 69kv FPC Andersen to Holder 230kv	-68	-27	73	-62	-29	68	50/ 62	148%	118%	138%	110%
245	Line Dalasmet	to Dallas 69kv FPC Andersen to Holder 230kv	-68	-27	74	-62	-29	69	50/ 62	148%	118%	138%	111%
255	Xfmr Juneau-E	to Juneau-E 138/ 69kv TEC Cr Plant to Cryst Re 230kv	185	31	188	182	30	185	168/ 183	112%	103%	110%	101%
256	Line So Gib	to B Bend 230kv TEC Cr Plant to Cryst R4 230kv	-668	-175	690	-640	-172	663	634/ 634	105%	105%	101%	101%
256	Line Dlarpttp	to Dalasmet 69kv FPC Cr Plant to Cryst R4 230kv	-70	-24	74	-65	-26	70	50/ 62	149%	119%	142%	113%
256	Line Dalasmet	to Dallas 69kv FPC Cr Plant to Cryst R4 230kv	-70	-24	74	-65	-26	70	50/ 62	149%	120%	142%	114%
256	Xfmr Juneau-E	to Juneau-E 138/ 69kv TEC Cr Plant to Cryst R4 230kv	188	28	190	185	27	187	168/ 183	113%	104%	111%	102%
264	Xfmr Oc R-Oak	to Oc R-Oak 230/ 69kv FPC Ocala 1 to Ocala 1 230kv	147	74	165	147	74	165	150/ 165	110%	100%	110%	100%
267	Line Juneau-W	to Gannon 138kv TEC Brkridge to Cryst Rv 500kv	-319	-37	322	-316	-36	318	300/ 300	113%	113%	110%	110%
267	Line Higgins	to Griffin 115kv FPC Brkridge to Cryst Rv 500kv	-190	56	198	-183	61	193	142/ 168	146%	119%	141%	115%

**APPENDIX A: RESULTS**

No.	Overload	Area	Outage	Base Case Ldg			Alt. Case Ldg			Rating	Base Case		Alt. Case	
				MW	MVar	MVA	MW	MVar	MVA		MVA	Rtg1	Rtg2	Rtg1
267	Line Dlarpttp to Dalasmet 69kv	FPC	Brkridge to Cryst Rv 500kv	-63	-27	69	-59	-29	66	50/ 62	139%	111%	132%	106%
267	Line Dalasmet to Dallas 69kv	FPC	Brkridge to Cryst Rv 500kv	-63	-27	69	-59	-29	66	50/ 62	139%	111%	132%	106%
267	Line 11th Ave to So Gib 230kv	TEC	Brkridge to Cryst Rv 500kv	-658	-240	701	-637	-226	676	634/ 634	114%	114%	109%	109%
267	Line So Gib to B Bend 230kv	TEC	Brkridge to Cryst Rv 500kv	-768	-337	838	-748	-315	812	634/ 634	130%	130%	125%	125%
267	Line Dade Cty to Dc Notap 69kv	TEC	Brkridge to Cryst Rv 500kv	64	10	65	66	7	66	63/ 63	100%	100%	103%	103%
267	Line Dc Notap to Ft King 69kv	TEC	Brkridge to Cryst Rv 500kv	64	10	65	66	7	66	63/ 63	100%	100%	103%	103%
271	Line Dlarpttp to Dalasmet 69kv	FPC	Cryst Rv to Cryst R5 500kv	-65	-26	70	-60	-28	66	50/ 62	141%	113%	134%	107%
271	Line Dalasmet to Dallas 69kv	FPC	Cryst Rv to Cryst R5 500kv	-65	-26	70	-60	-28	66	50/ 62	141%	113%	134%	107%
271	Xfmr Juneau-E to Juneau-E 138/ 69kv	TEC	Cryst Rv to Cryst R5 500kv	189	28	191	186	27	188	168/ 183	114%	105%	112%	103%
267	Xfmr Juneau-E to Juneau-E 138/ 69kv	TEC	Brkridge to Cryst Rv 500kv	195	39	199	193	38	197	168/ 183	118%	110%	117%	108%
349	Xfmr Juneau-E to Juneau-E 138/ 69kv	TEC	Sheld to Jaxsn230 230kv	188	28	191	186	28	188	168/ 183	113%	104%	112%	103%
350	Xfmr Juneau-E to Juneau-E 138/ 69kv	TEC	Sheld to Ohio-S 230kv	210	37	213	201	36	204	168/ 183	127%	116%	122%	112%
352	Xfmr Juneau-E to Juneau-E 138/ 69kv	TEC	Dimbry-E to Chapman 230kv	190	30	192	186	30	188	168/ 183	114%	105%	112%	103%
354	Xfmr 11th Ave to Eleven-E 230/ 69kv	TEC	Ohio-N to 11th Ave 230kv	254	71	263	247	67	256	224/ 246	118%	107%	114%	104%
356	Xfmr Juneau-E to Juneau-E 138/ 69kv	TEC	River-N to Sr60-S T 230kv	191	29	193	187	29	190	168/ 183	115%	106%	113%	104%
357	Xfmr Juneau-E to Juneau-E 138/ 69kv	TEC	River-S to B Bend 230kv	188	31	191	185	31	187	168/ 183	113%	104%	112%	102%
358	Xfmr Juneau-E to Juneau-E 138/ 69kv	TEC	Chapman to Gannon 230kv	216	39	220	211	39	215	168/ 183	131%	120%	128%	117%
358	Xfmr Hkrs Pt to Hkrspt-S 138/ 69kv	TEC	Chapman to Gannon 230kv	181	52	188	179	51	186	168/ 187	112%	101%	111%	100%
363	Xfmr Juneau-E to Juneau-E 138/ 69kv	TEC	Gannon to Sr60-S T 230kv	192	30	195	189	30	191	168/ 183	116%	106%	114%	105%
363	Xfmr Hkrs Pt to Hkrspt-S 138/ 69kv	TEC	Gannon to Sr60-S T 230kv	191	52	198	190	51	197	168/ 187	118%	106%	117%	105%
366	Xfmr Hkrs Pt to Hkrspt-S 138/ 69kv	TEC	Sr60-N to Sr60-N T 230kv	181	51	188	180	50	186	168/ 187	112%	100%	111%	100%
367	Xfmr Hkrs Pt to Hkrspt-S 138/ 69kv	TEC	Sr60-S to Sr60-S T 230kv	194	54	202	193	53	200	168/ 187	120%	108%	119%	107%
370	Xfmr River-S to River-S 69/230kv	TEC	So Gib to B Bend 230kv	-252	-35	254	-245	-34	247	224/ 232	116%	110%	113%	107%
370	Xfmr Hkrs Pt to Hkrspt-S 138/ 69kv	TEC	So Gib to B Bend 230kv	191	58	199	189	57	198	168/ 187	119%	107%	118%	106%
370	Xfmr Belcrk to Belcrk 230/ 69kv	TEC	So Gib to B Bend 230kv	246	58	252	240	56	246	224/ 247	113%	103%	110%	100%
370	Xfmr Ruskin T to Ruskin 230/ 69kv	TEC	So Gib to B Bend 230kv	173	49	179	169	45	175	168/ 175	107%	103%	104%	100%
271	Line So Gib to B Bend 230kv	TEC	Cryst Rv to Cryst R5 500kv	-673	-179	696	-645	-172	668	634/ 634	106%	106%	101%	101%
299	Line Putnam to Tocol 230kv	FPL	Greenlnd to Swtzrlnd 230kv	391	165	424	392	164	425	402/ 402	102%	102%	103%	103%
309	Line Osceola to Studio 69kv	TEC	Can Isl to Ouocitp1 230kv	154	9	155	159	11	160	143/ 143	106%	106%	110%	110%
310	Line Osceola to Studio 69kv	TEC	Can Isl to Ouocitp2 230kv	151	3	151	159	8	159	143/ 143	104%	104%	111%	111%
319	Line Osceola to Studio 69kv	TEC	Taft to Ouocitp1 230kv	154	9	155	159	11	160	143/ 143	106%	106%	110%	110%

**APPENDIX A: RESULTS**

No.	Overload	Area	Outage	Base Case Ldg			Alt. Case Ldg			Rating	Base Case		Alt. Case	
				MW	MVar	MVA	MW	MVar	MVA		MVA	Rtg1	Rtg2	Rtg1
323	Line Osceola to Studio 69kv	TEC	Ouccitp2 to Osceola 230kv	151	3	151	159	8	159	143/143	104%	104%	111%	111%
352	Line Juneau-W to Gannon 138kv	TEC	Dlmbr-E to Chapman 230kv	-313	-26	314	-305	-25	306	300/300	105%	105%	102%	102%
352	Xfmr Chapman to Chapman 230/69kv	TEC	Dlmbr-E to Chapman 230kv	232	60	240	222	59	230	224/224	107%	107%	103%	103%
352	Line So Gib to B Bend 230kv	TEC	Dlmbr-E to Chapman 230kv	-670	-194	697	-639	-190	667	634/634	106%	106%	101%	101%
353	Xfmr Juneau-E to Juneau-E 138/69kv	TEC	Ohio-N to Ohio-S 230kv	195	29	197	190	29	193	168/183	117%	108%	115%	105%
354	Line Cooldg to Ohio 138kv	TEC	Ohio-N to 11th Ave 230kv	191	-41	195	180	-38	184	186/186	107%	107%	100%	100%
354	Line Juneau-W to Gannon 138kv	TEC	Ohio-N to 11th Ave 230kv	-328	-29	329	-319	-31	320	300/300	112%	112%	108%	108%
370	Line Cooldg to Ohio 138kv	TEC	So Gib to B Bend 230kv	194	-45	199	186	-44	191	186/186	111%	111%	106%	106%
370	Line Juneau-W to Gannon 138kv	TEC	So Gib to B Bend 230kv	-332	-26	333	-324	-27	325	300/300	115%	115%	111%	111%
370	Line Seven8-T to Twelfth 69kv	TEC	So Gib to B Bend 230kv	103	13	104	98	11	99	93/93	115%	115%	108%	108%
357	Line Gannon to Sr60-S T 230kv	TEC	River-S to B Bend 230kv	477	127	494	468	127	485	402/402	118%	118%	115%	115%
357	Line So Gib to B Bend 230kv	TEC	River-S to B Bend 230kv	-665	-181	689	-639	-180	664	634/634	105%	105%	101%	101%
358	Line River-N to Gte-Coll 69kv	TEC	Chapman to Gannon 230kv	156	33	160	151	33	154	143/143	111%	111%	107%	107%
358	Xfmr River-S to River-S 69/230kv	TEC	Chapman to Gannon 230kv	-247	-36	250	-240	-36	242	224/232	114%	108%	111%	104%
358	Line Fort6 T to Gte-Coll 69kv	TEC	Chapman to Gannon 230kv	-133	-16	134	-128	-17	129	128/128	108%	108%	104%	104%
358	Line Juneau-W to Gannon 138kv	TEC	Chapman to Gannon 230kv	-332	-30	333	-323	-30	325	300/300	113%	113%	110%	110%
358	Line Gannon to Sr60-S T 230kv	TEC	Chapman to Gannon 230kv	452	111	465	436	106	449	402/402	110%	110%	107%	107%
358	Line So Gib to B Bend 230kv	TEC	Chapman to Gannon 230kv	-717	-225	751	-682	-216	716	634/634	114%	114%	109%	109%
359	Line Cooldg to Ohio 138kv	TEC	11th Ave to So Gib 230kv	200	-42	204	191	-40	195	186/186	114%	114%	108%	108%
359	Xfmr River-S to River-S 69/230kv	TEC	11th Ave to So Gib 230kv	-250	-36	252	-243	-36	245	224/232	116%	109%	112%	106%
359	Line Juneau-W to Gannon 138kv	TEC	11th Ave to So Gib 230kv	-336	-29	337	-328	-30	329	300/300	116%	116%	113%	113%
359	Xfmr Hkrs Pt to Hkrspt-S 138/69kv	TEC	11th Ave to So Gib 230kv	181	55	189	179	54	187	168/187	112%	101%	112%	100%
359	Line Seven8-T to Twelfth 69kv	TEC	11th Ave to So Gib 230kv	97	13	98	92	12	93	93/93	108%	108%	102%	102%
363	Line Juneau-W to Gannon 138kv	TEC	Gannon to Sr60-S T 230kv	-309	-20	309	-302	-21	303	300/300	103%	103%	101%	101%

**60% LOAD LEVEL**

**DISTANT FROM THE PROJECT**

No. Overload	Area	Outage	Base Case Ldg			Alt. Case Ldg			Rating MVA	Base Case		Alt. Case				
			MW	MVar	MVA	MW	MVar	MVA		Rtg1	Rtg2	Rtg1	Rtg2			
181 Line	Dade Cty	to Dc Notap 69kv	TEC	Lk Tarpn	to Brkridge 500kv	64	-8	64	74	-9	75	63/ 63	99%	99%	116%	116%
181 Line	Dc Notap	to Ft King 69kv	TEC	Lk Tarpn	to Brkridge 500kv	64	-8	64	74	-9	75	63/ 63	99%	99%	116%	116%
267 Line	Brkridge	to Brk98 Tp 115kv	FPC	Brkridge	to Cryst Rv 500kv	-117	102	155	-139	122	185	137/ 137	112%	112%	132%	132%
267 Line	Brk98 Tp	to Hammcktp 115kv	FPC	Brkridge	to Cryst Rv 500kv	-128	94	159	-151	112	188	137/ 137	114%	114%	135%	135%
385 Xfmr	Lk Tarpn	to Lkt-Dum2 230/500kv	FPC	Lkt-Dum1	to Lk Tarpn 500/230kv	-768	55	770	-874	87	878	750/ 750	103%	103%	117%	117%
386 Xfmr	Lk Tarpn	to Lkt-Dum1 230/500kv	FPC	Lkt-Dum2	to Lk Tarpn 500/230kv	-760	55	762	-865	87	870	750/ 750	102%	102%	116%	116%
143 Line	Enola	to Umatilla 69kv	FPC	Hainesck	to Sorrento 230kv	114	-20	116	141	-21	142	126/ 138	90%	84%	110%	103%
249 Line	Sprghltp	to Heritgtp 115kv	FPC	Brkridge	to Hudson 230kv	139	-56	150	158	-64	171	136/ 169	107%	88%	123%	101%
248 Line	Homsatp2	to Villa Tp (1) 115kv	FPC	Brkridge	to Cryst Re 230kv	-132	59	145	-151	69	166	137/ 137	104%	104%	119%	119%

**DOES NOT EXCEED RATING 2 FOR A CONTINGENCY**

No. Overload	Area	Outage	Base Case Ldg			Alt. Case Ldg			Rating MVA	Base Case		Alt. Case				
			MW	MVar	MVA	MW	MVar	MVA		Rtg1	Rtg2	Rtg1	Rtg2			
170 Line	Hudson	to Hudson 115kv	FPC	Lk Tarpn	to Hudson 230kv	237	52	243	255	53	261	246/ 302	96%	80%	103%	86%
181 Line	Higgins	to Griffin 115kv	FPC	Lk Tarpn	to Brkridge 500kv	-137	60	149	-143	64	157	142/ 168	104%	89%	109%	93%
181 Line	Sprghltp	to Heritgtp 115kv	FPC	Lk Tarpn	to Brkridge 500kv	108	-48	119	128	-58	140	136/ 169	86%	70%	101%	83%
181 Line	Brkridge	to Brksvwtp 230kv	FPC	Lk Tarpn	to Brkridge 500kv	655	68	659	722	84	727	677/ 812	97%	80%	109%	90%
181 Line	Brkridge	to Hudson 230kv	FPC	Lk Tarpn	to Brkridge 500kv	613	40	615	686	61	689	677/ 812	91%	75%	103%	85%
181 Line	Hudson	to Hudson 115kv	FPC	Lk Tarpn	to Brkridge 500kv	259	51	264	280	52	285	246/ 302	105%	88%	113%	94%
227 Line	Martin W	to Reddick 69kv	FPC	Archer	to Martin W 230kv	21	4	22	37	-2	37	32/ 38	66%	57%	112%	97%
234 Line	Bell Tp	to Trenton 69kv	FPC	Ft Wht S	to Newberry 230kv	-26	8	27	-33	14	36	32/ 38	85%	72%	110%	94%
238 Line	Inglis	to Lebanon 69kv	FPC	Newberry	to Cr Plant 230kv	28	-8	29	33	-9	34	32/ 38	87%	75%	103%	90%
247 Line	Cr Plant	to Cryst Re 230kv	FPC	Brkridge	to Cr Plant 230kv	671	106	679	717	121	727	677/ 812	96%	84%	103%	90%
249 Line	Heritgtp	to Hudson 115kv	FPC	Brkridge	to Hudson 230kv	120	-69	139	140	-79	160	136/ 169	99%	82%	115%	95%

**APPENDIX A: RESULTS**

No. Overload	Area	Outage	Base Case Ldg			Alt. Case Ldg			Rating	Base Case		Alt. Case				
			MW	MVar	MVA	MW	MVar	MVA		MVA	Rtg1	Rtg2	Rtg1	Rtg2		
251 Line	Hudson	to Hudsontp 115kv	FPC	Brksvwt	to Gulfpine 230kv	250	50	255	266	50	271	246/ 302	101%	84%	107%	90%
267 Line	Cryst Rs	to Villa Tp 115kv	FPC	Brkridge	to Cryst Rv 500kv	171	-65	183	197	-77	212	173/ 215	103%	85%	120%	99%
267 Line	Cr Plant	to Cryst Re 230kv	FPC	Brkridge	to Cryst Rv 500kv	674	153	691	733	192	757	677/ 812	98%	85%	107%	93%
267 Line	Zephyr N	to Zephyrhl 69kv	FPC	Brkridge	to Cryst Rv 500kv	118	-11	119	133	-9	133	126/ 150	92%	79%	103%	89%
283 Line	Hudson	to Hudsontp 115kv	FPC	Gulfpine	to Seven Sp 230kv	250	50	255	266	50	271	246/ 302	101%	85%	107%	90%
371 Line	Manatee	to B Bend 230kv	FPL	Ruskin T	to B Bend 230kv	-937	157	950	-856	130	865	900/ 900	101%	101%	92%	92%
371 Line	Ruskmt8	to B Bend 230kv	TEC	Ruskin T	to B Bend 230kv	-506	7	506	-465	10	465	478/ 478	101%	101%	93%	93%

**OVERLOAD DOES NOT EXCEED 15% GREATER THAN RATING 1 IF RATING 1 EQUALS RATING 2**

No. Overload	Area	Outage	Base Case Ldg			Alt. Case Ldg			Rating	Base Case		Alt. Case				
			MW	MVar	MVA	MW	MVar	MVA		MVA	Rtg1	Rtg2	Rtg1	Rtg2		
181 Xfmr	Brkridge	to Brdg-Dum 230/500kv	FPC	Lk Tarpn	to Brkridge 500kv	-710	-71	713	-789	-89	794	750/ 750	98%	98%	109%	109%
247 Line	Brkridge	to Brk98 Tp 115kv	FPC	Brkridge	to Cr Plant 230kv	-90	81	121	-107	92	141	137/ 137	87%	87%	101%	101%
247 Line	Brk98 Tp	to Hammcktp 115kv	FPC	Brkridge	to Cr Plant 230kv	-99	75	124	-117	85	144	137/ 137	89%	89%	104%	104%
247 Line	Hammcktp	to Tc Ranch 115kv	FPC	Brkridge	to Cr Plant 230kv	-105	72	127	-122	81	147	137/ 137	92%	92%	106%	106%
247 Line	Homsatp2	to Tc Ranch 115kv	FPC	Brkridge	to Cr Plant 230kv	117	-64	133	136	-72	153	137/ 137	95%	95%	110%	110%
247 Line	Homsatp2	to Villa Tp 115kv	FPC	Brkridge	to Cr Plant 230kv	-127	58	140	-146	66	160	137/ 137	101%	101%	115%	115%
248 Line	Brkridge	to Brk98 Tp 115kv	FPC	Brkridge	to Cryst Re 230kv	-95	82	125	-111	95	146	137/ 137	90%	90%	105%	105%
248 Line	Brk98 Tp	to Hammcktp 115kv	FPC	Brkridge	to Cryst Re 230kv	-104	76	129	-121	88	150	137/ 137	93%	93%	108%	108%
248 Line	Hammcktp	to Tc Ranch 115kv	FPC	Brkridge	to Cryst Re 230kv	-109	73	132	-127	84	153	137/ 137	95%	95%	110%	110%
248 Line	Homsatp2	to Tc Ranch 115kv	FPC	Brkridge	to Cryst Re 230kv	122	-65	138	140	-74	159	137/ 137	99%	99%	114%	114%
267 Line	Dade Cty	to Dc Notap 69kv	TEC	Brkridge	to Cryst Rv 500kv	62	-7	62	72	-8	72	63/ 63	96%	96%	112%	112%
267 Line	Dc Notap	to Ft King 69kv	TEC	Brkridge	to Cryst Rv 500kv	62	-7	62	72	-8	72	63/ 63	96%	96%	112%	112%



PRE-EXISTING VIOLATIONS - OVERLOADED IN THE BASE CASE WITHOUT THE PROJECT

No. Overload	Area	Outage	Base Case Ldg			Alt. Case Ldg			Rating	Base Case		Alt. Case				
			MW	MVar	MVA	MW	MVar	MVA		MVA	Rtg1	Rtg2	Rtg1	Rtg2		
18	Line Britgoab	to Morris 69kv	FPL	Okechobe	to Morris 69kv	-53	-88	102	-53	-88	102	44/ 44	235%	235%	235%	235%
20	Line Plumosus	to Oakes 138kv	FPL	Bee Line	to Plumosus 138kv #99	220	-54	226	221	-53	227	221/ 221	101%	101%	101%	101%
179	Xfmr Lk Tarpn	to Lkt-Dum2 230/500kv	FPC	Lk Tarpn	to Lkt-Dum1 500kv	-768	55	770	-874	87	878	750/ 750	103%	103%	117%	117%
180	Xfmr Lk Tarpn	to Lkt-Dum1 230/500kv	FPC	Lk Tarpn	to Lkt-Dum2 500kv	-760	55	762	-865	87	870	750/ 750	102%	102%	116%	116%
267	Line Hammcktp	to Tc Ranch 115kv	FPC	Brkridge	to Cryst Rv 500kv	-134	91	161	-157	108	190	137/ 137	116%	116%	137%	137%
267	Line Homsatp2	to Tc Ranch 115kv	FPC	Brkridge	to Cryst Rv 500kv	148	-80	168	173	-94	197	137/ 137	120%	120%	141%	141%
267	Line Homsatp2	to Villa Tp 115kv	FPC	Brkridge	to Cryst Rv 500kv	-158	74	175	-183	88	203	137/ 137	125%	125%	146%	146%
267	Line Higgins	to Griffin 115kv	FPC	Brkridge	to Cryst Rv 500kv	-167	78	184	-174	86	194	142/ 168	128%	110%	135%	115%
346	Line Havana	to Quincy 115kv	FPC	Sub 20	to S Bainbr 230kv	-89	55	105	-89	55	105	83/ 103	129%	102%	128%	101%
346	Line Woodruff	to Scholz 2 115kv	FPC	Sub 20	to S Bainbr 230kv	-131	24	133	-131	24	133	119/ 124	113%	107%	113%	107%

40% LOAD LEVEL

DISTANT FROM THE PROJECT

No. Overload	Area	Outage	Base Case Ldg			Alt. Case Ldg			Rating	Base Case		Alt. Case				
			MW	MVar	MVA	MW	MVar	MVA		MVA	Rtg1	Rtg2	Rtg1	Rtg2		
267	Line Brkridge	to Brk98 Tp 115kv	FPC	Brkridge	to Cryst Rv 500kv	-114	92	146	-127	107	166	137/ 137	105%	105%	119%	119%
267	Line Brk98 Tp	to Hammcktp 115kv	FPC	Brkridge	to Cryst Rv 500kv	-122	85	148	-136	98	168	137/ 137	107%	107%	120%	120%
143	Line Enola	to Umatilla 69kv	FPC	Hainesck	to Sorrento 230kv	110	-24	113	137	-27	140	126/ 138	87%	82%	108%	101%
227	Line Mcntshp	to Reddick 69kv	FPC	Archer	to Martin W 230kv	-32	12	34	-36	14	39	32/ 38	106%	90%	120%	101%
248	Line Homsatp2	to Villa Tp (1) 115kv	FPC	Brkridge	to Cryst Re 230kv	-122	56	134	-129	60	142	137/ 137	96%	96%	102%	102%
267	Line Hammcktp	to Tc Ranch (2) 115kv	FPC	Brkridge	to Cryst Rv 500kv	-126	81	150	-140	95	169	137/ 137	108%	108%	122%	122%
267	Line Homsatp2	to Tc Ranch (3) 115kv	FPC	Brkridge	to Cryst Rv 500kv	136	-72	154	152	-83	173	137/ 137	110%	110%	124%	124%
267	Line Homsatp2	to Villa Tp (1) 115kv	FPC	Brkridge	to Cryst Rv 500kv	-143	66	157	-159	77	177	137/ 137	113%	113%	127%	127%

**DOES NOT EXCEED RATING 2 FOR A CONTINGENCY**

No. Overload	Area	Outage	Base Case Ldg			Alt. Case Ldg			Rating	Base Case		Alt. Case				
			MW	Mvar	MVA	MW	Mvar	MVA		MVA	Rtg1	Rtg2	Rtg1	Rtg2		
224 Line	Union Hl	to Dadect T 69kv	FPC	Kath-Dum	to Kathleen 500kv	117	-11	118	130	-11	130	126/ 150	91%	78%	101%	87%
225 Line	Union Hl	to Dadect T 69kv	FPC	Kathleen	to Cert Fla 500kv	117	-11	118	130	-11	130	126/ 150	91%	78%	101%	87%
227 Line	Cara Tp	to Mentshtp 69kv	FPC	Archer	to Martin W 230kv	-27	16	31	-31	18	36	32/ 38	98%	83%	112%	94%
227 Line	Cara Tp	to Willistn 69kv	FPC	Archer	to Martin W 230kv	24	-18	30	28	-21	35	32/ 38	94%	79%	108%	91%
232 Line	Bell Tp	to Neals Tp 69kv	FPC	Ft Wht N	to Ft Wht S 230kv	32	-16	36	33	-16	36	32/ 38	112%	95%	112%	95%
232 Line	High Spg	to Neals Tp 69kv	FPC	Ft Wht N	to Ft Wht S 230kv	-28	20	35	-28	20	35	32/ 38	108%	91%	108%	92%
238 Line	Inglis	to Lebanon 69kv	FPC	Newberry	to Cr Plant 230kv	36	-10	37	35	-10	36	32/ 38	113%	97%	111%	96%
238 Line	Lebanon	to Ottcktp 69kv	FPC	Newberry	to Cr Plant 230kv	33	-13	36	32	-13	35	32/ 38	110%	93%	109%	92%
249 Line	Sprghltp	to Heritgtp 115kv	FPC	Brkridge	to Hudson 230kv	131	-49	140	141	-54	152	136/ 169	101%	83%	109%	90%
249 Line	Heritgtp	to Hudson 115kv	FPC	Brkridge	to Hudson 230kv	119	-62	134	129	-68	145	136/ 169	96%	79%	104%	86%
267 Line	Cryst Rs	to Villa Tp 115kv	FPC	Brkridge	to Cryst Rv 500kv	152	-57	162	168	-68	182	173/ 215	92%	76%	102%	84%
387 Line	Union Hl	to Dadect T 69kv	FPC	Kath-Dum	to Kathleen 500/230kv	117	-11	118	130	-11	130	126/ 150	91%	78%	101%	87%

**OVERLOAD DOES NOT EXCEED 15% GREATER THAN RATING 1 IF RATING 1 EQUALS RATING 2**

No. Overload	Area	Outage	Base Case Ldg			Alt. Case Ldg			Rating	Base Case		Alt. Case				
			MW	Mvar	MVA	MW	Mvar	MVA		MVA	Rtg1	Rtg2	Rtg1	Rtg2		
177 Line	Dade Cty	to Dc Notap 69kv	TEC	Griffin	to Kathleen 230kv	58	-12	60	69	-13	70	63/ 63	92%	92%	108%	108%
177 Line	Dc Notap	to Ft King 69kv	TEC	Griffin	to Kathleen 230kv	58	-12	60	69	-13	70	63/ 63	92%	92%	108%	108%
178 Line	Dade Cty	to Dc Notap 69kv	TEC	Griffin	to West 230kv	56	-12	57	65	-13	67	63/ 63	88%	88%	103%	103%
178 Line	Dc Notap	to Ft King 69kv	TEC	Griffin	to West 230kv	56	-12	57	65	-13	67	63/ 63	88%	88%	103%	103%
179 Xfmr	Lk Tarpn	to Lkt-Dum2 230/500kv	FPC	Lk Tarpn	to Lkt-Dum1 500kv	-730	60	733	-811	83	815	750/ 750	98%	98%	109%	109%
180 Xfmr	Lk Tarpn	to Lkt-Dum1 230/500kv	FPC	Lk Tarpn	to Lkt-Dum2 500kv	-723	60	726	-804	82	808	750/ 750	97%	97%	108%	108%
181 Line	Dade Cty	to Dc Notap 69kv	TEC	Lk Tarpn	to Brkridge 500kv	62	-12	64	68	-13	70	63/ 63	98%	98%	108%	108%
181 Line	Dc Notap	to Ft King 69kv	TEC	Lk Tarpn	to Brkridge 500kv	62	-12	64	68	-13	70	63/ 63	98%	98%	108%	108%

**APPENDIX A: RESULTS**

No. Overload	Area	Outage	Base Case Ldg			Alt. Case Ldg			Rating	Base Case		Alt. Case	
			MW	Mvar	MVA	MW	Mvar	MVA		MVA	Rtg1	Rtg2	Rtg1
267 Xfmr Kathleen	to Kath-Dum	FPC Brkridge to Cryst Rv 500kv	-590	54	592	-776	81	780	750/ 750	79%	79%	104%	104%
267 Line Dade Cty	to Dc Notap 69kv	TEC Brkridge to Cryst Rv 500kv	60	-11	61	66	-12	67	63/ 63	95%	95%	104%	104%
267 Line Dc Notap	to Ft King 69kv	TEC Brkridge to Cryst Rv 500kv	60	-11	61	66	-12	67	63/ 63	95%	95%	104%	104%
385 Xfmr Lk Tarpn	to Lkt-Dum2 230/500kv	FPC Lkt-Dum1 to Lk Tarpn 500/230kv	-730	60	733	-811	83	815	750/ 750	98%	98%	109%	109%
386 Xfmr Lk Tarpn	to Lkt-Dum1 230/500kv	FPC Lkt-Dum2 to Lk Tarpn 500/230kv	-723	60	726	-804	82	808	750/ 750	97%	97%	108%	108%

**PRE-EXISTING VIOLATIONS - OVERLOADED IN THE BASE CASE WITHOUT THE PROJECT**

No. Overload	Area	Outage	Base Case Ldg			Alt. Case Ldg			Rating	Base Case		Alt. Case	
			MW	MVar	MVA	MW	MVar	MVA		MVA	Rtg1	Rtg2	Rtg1
18 Line Britgoab	to Morris 69kv	FPL Okechobe to Morris 69kv	-53	-88	102	-53	-88	102	44/ 44	235%	235%	235%	235%
65 Line Martin	to Sherman 230kv	FPL Midway to Sherman 230kv	-512	132	529	-512	132	529	502/ 502	101%	101%	101%	101%
227 Line Martin W	to Reddick 69kv	FPC Archer to Martin W 230kv	39	-5	40	44	-7	44	32/ 38	121%	105%	134%	116%
232 Line Bell Tp	to Trenton 69kv	FPC Ft Wht N to Ft Wht S 230kv	-36	13	38	-36	13	39	32/ 38	119%	101%	120%	102%
234 Line Bell Tp	to Neals Tp 69kv	FPC Ft Wht S to Newberry 230kv	38	-20	43	37	-19	42	32/ 38	134%	114%	129%	110%
234 Line Bell Tp	to Trenton 69kv	FPC Ft Wht S to Newberry 230kv	-42	17	46	-41	16	44	32/ 38	141%	120%	136%	116%
234 Line High Spg	to Neals Tp 69kv	FPC Ft Wht S to Newberry 230kv	-34	25	42	-32	24	41	32/ 38	130%	111%	125%	107%

## APPENDIX B: CONTINGENCY LIST

---

C- 1	Line	123 EMERSON	230kV	to	266 MIDWAY	230kV	Ckt	1
C- 2	Line	122 EMERSON	138kV	to	441 F PIERCE	138kV	Ckt	99
C- 3	Line	122 EMERSON	138kV	to	449 OSLO	138kV	Ckt	1
C- 4	Line	122 EMERSON	138kV	to	9383 FV-C TYLN	138kV	Ckt	1
C- 5	Line	123 EMERSON	230kV	to	464 MALABAR	230kV	Ckt	99
C- 6	Line	191 CITRUS	138kV	to	229 HARTMAN	138kV	Ckt	1
C- 7	Line	191 CITRUS	138kV	to	240 MIDWAY	138kV	Ckt	1
C- 8	Line	197 WARFIELD	230kV	to	263 INDN TWN	230kV	Ckt	1
C- 9	Line	197 WARFIELD	230kV	to	265 MARTIN	230kV	Ckt	1
C- 10	Line	201 BL GLADE	69kV	to	210 PAHOKEE	69kV	Ckt	99
C- 11	Line	201 BL GLADE	69kV	to	214 SO BAY	69kV	Ckt	1
C- 12	Line	201 BL GLADE	69kV	to	214 SO BAY	69kV	Ckt	2
C- 13	Line	203 W PM BCH	69kV	to	204 DATURA	69kV	Ckt	1
C- 14	Line	203 W PM BCH	69kV	to	204 DATURA	69kV	Ckt	2
C- 15	Line	205 MARTIN	69kV	to	277 BRYANT	69kV	Ckt	99
C- 16	Line	208 OKECHOBE	69kV	to	213 SHERMAN	69kV	Ckt	2
C- 17	Line	208 OKECHOBE	69kV	to	213 SHERMAN	69kV	Ckt	99
C- 18	Line	208 OKECHOBE	69kV	to	6781 MORRIS	69kV	Ckt	1
C- 19	Line	210 PAHOKEE	69kV	to	277 BRYANT	69kV	Ckt	1
C- 20	Line	218 BEE LINE	138kV	to	245 PLUMOSUS	138kV	Ckt	99
C- 21	Line	218 BEE LINE	138kV	to	250 RIVIERA	138kV	Ckt	1
C- 22	Line	222 BOYNTON	138kV	to	223 CEDAR	138kV	Ckt	1
C- 23	Line	222 BOYNTON	138kV	to	578 QUANTUM	138kV	Ckt	1
C- 24	Line	223 CEDAR	138kV	to	249 RANCH	138kV	Ckt	99
C- 25	Line	223 CEDAR	138kV	to	257 YAMATO	138kV	Ckt	99
C- 26	Line	223 CEDAR	138kV	to	596 HYPOLUXO	138kV	Ckt	1
C- 27	Line	229 HARTMAN	138kV	to	441 F PIERCE	138kV	Ckt	1
C- 28	Line	229 HARTMAN	138kV	to	4001 HART-FMP	138kV	Ckt	1
C- 29	Line	232 HOBE	138kV	to	245 PLUMOSUS	138kV	Ckt	98
C- 30	Line	232 HOBE	138kV	to	245 PLUMOSUS	138kV	Ckt	99
C- 31	Line	232 HOBE	138kV	to	247 PT SEWEL	138kV	Ckt	1
C- 32	Line	232 HOBE	138kV	to	247 PT SEWEL	138kV	Ckt	99
C- 33	Line	237 LANTANA	138kV	to	578 QUANTUM	138kV	Ckt	1
C- 34	Line	237 LANTANA	138kV	to	596 HYPOLUXO	138kV	Ckt	1
C- 35	Line	240 MIDWAY	138kV	to	796 WH CTYTP	138kV	Ckt	1
C- 36	Line	245 PLUMOSUS	138kV	to	539 OAKES	138kV	Ckt	1
C- 37	Line	247 PT SEWEL	138kV	to	685 MONTEREY	138kV	Ckt	1
C- 38	Line	249 RANCH	138kV	to	250 RIVIERA	138kV	Ckt	98
C- 39	Line	249 RANCH	138kV	to	250 RIVIERA	138kV	Ckt	99
C- 40	Line	249 RANCH	138kV	to	253 W PM BCH	138kV	Ckt	1
C- 41	Line	249 RANCH	138kV	to	253 W PM BCH	138kV	Ckt	99
C- 42	Line	249 RANCH	138kV	to	547 OSCEOLA	138kV	Ckt	99
C- 43	Line	250 RIVIERA	138kV	to	253 W PM BCH	138kV	Ckt	99
C- 44	Line	250 RIVIERA	138kV	to	539 OAKES	138kV	Ckt	99
C- 45	Line	250 RIVIERA	138kV	to	600 RECWAY	138kV	Ckt	1
C- 46	Line	251 SO BAY	138kV	to	547 OSCEOLA	138kV	Ckt	1
C- 47	Line	251 SO BAY	138kV	to	549 OKEELNTA	138kV	Ckt	1

---

4/20/00

## APPENDIX B: CONTINGENCY LIST

C- 48	Line	255 WEST	138kV	to	449 OSLO	138kV	Ckt	1
C- 49	Line	255 WEST	138kV	to	457 WABASSO	138kV	Ckt	1
C- 50	Line	255 WEST	138kV	to	9381 WEST-FMP	138kV	Ckt	1
C- 51	Line	256 WH CITY	138kV	to	441 F PIERCE	138kV	Ckt	1
C- 52	Line	256 WH CITY	138kV	to	796 WH CTYTP	138kV	Ckt	1
C- 53	Line	257 YAMATO	138kV	to	990 DEERFDTP	138kV	Ckt	99
C- 54	Line	258 CEDAR	230kV	to	268 RANCH	230kV	Ckt	1
C- 55	Line	258 CEDAR	230kV	to	273 YAMATO	230kV	Ckt	99
C- 56	Line	258 CEDAR	230kV	to	535 CORBETT	230kV	Ckt	99
C- 57	Line	259 SANPIPER	230kV	to	532 TURNPIKE	230kV	Ckt	1
C- 58	Line	261 HOBE	230kV	to	582 BRIDGE	230kV	Ckt	1
C- 59	Line	263 INDN TWN	230kV	to	265 MARTIN	230kV	Ckt	99
C- 60	Line	263 INDN TWN	230kV	to	266 MIDWAY	230kV	Ckt	1
C- 61	Line	263 INDN TWN	230kV	to	268 RANCH	230kV	Ckt	99
C- 62	Line	263 INDN TWN	230kV	to	582 BRIDGE	230kV	Ckt	1
C- 63	Line	265 MARTIN	230kV	to	270 SHERMAN	230kV	Ckt	1
C- 64	Line	266 MIDWAY	230kV	to	268 RANCH	230kV	Ckt	99
C- 65	Line	266 MIDWAY	230kV	to	270 SHERMAN	230kV	Ckt	1
C- 66	Line	266 MIDWAY	230kV	to	272 ST LUCIE	230kV	Ckt	1
C- 67	Line	266 MIDWAY	230kV	to	272 ST LUCIE	230kV	Ckt	2
C- 68	Line	266 MIDWAY	230kV	to	272 ST LUCIE	230kV	Ckt	3
C- 69	Line	266 MIDWAY	230kV	to	532 TURNPIKE	230kV	Ckt	1
C- 70	Line	268 RANCH	230kV	to	535 CORBETT	230kV	Ckt	1
C- 71	Line	268 RANCH	230kV	to	535 CORBETT	230kV	Ckt	99
C- 72	Line	274 CORBETT	500kV	to	275 MARTIN	500kV	Ckt	1
C- 73	Line	274 CORBETT	500kV	to	275 MARTIN	500kV	Ckt	2
C- 74	Line	274 CORBETT	500kV	to	276 MIDWAY	500kV	Ckt	1
C- 75	Line	274 CORBETT	500kV	to	666 CONSRVTN	500kV	Ckt	1
C- 76	Line	275 MARTIN	500kV	to	276 MIDWAY	500kV	Ckt	1
C- 77	Line	275 MARTIN	500kV	to	476 POINSETT	500kV	Ckt	1
C- 78	Line	276 MIDWAY	500kV	to	476 POINSETT	500kV	Ckt	1
C- 79	Line	479 CLEWSTN9	138kV	to	637 HEND-FPL	138kV	Ckt	1
C- 80	Line	479 CLEWSTN9	138kV	to	864 MONT-FPL	138kV	Ckt	1
C- 81	Line	479 CLEWSTN9	138kV	to	6783 S CLEWIS	138kV	Ckt	1
C- 82	Line	530 SANPIPER	138kV	to	685 MONTEREY	138kV	Ckt	99
C- 83	Line	530 SANPIPER	138kV	to	796 WH CTYTP	138kV	Ckt	99
C- 84	Line	532 TURNPIKE	230kV	to	582 BRIDGE	230kV	Ckt	99
C- 85	Line	549 OKEELNTA	138kV	to	637 HEND-FPL	138kV	Ckt	1
C- 86	Line	582 BRIDGE	230kV	to	601 PLUMOSUS	230kV	Ckt	99
C- 87	Line	596 HYPOLUXO	138kV	to	5451 HYPO-FMP	138kV	Ckt	1
C- 88	Line	637 HEND-FPL	138kV	to	6601 HEND-FMP	138kV	Ckt	1
C- 89	Line	864 MONT-FPL	138kV	to	6769 MONTURA	138kV	Ckt	1
C- 90	Transformer	122 EMERSON	138kV	to	123 EMERSON	230kV	Ckt	1
C- 91	Transformer	203 W PM BCH	69kV	to	253 W PM BCH	138kV	Ckt	1
C- 92	Transformer	203 W PM BCH	69kV	to	253 W PM BCH	138kV	Ckt	2
C- 93	Transformer	205 MARTIN	69kV	to	265 MARTIN	230kV	Ckt	1
C- 94	Transformer	213 SHERMAN	69kV	to	270 SHERMAN	230kV	Ckt	1
C- 95	Transformer	213 SHERMAN	69kV	to	270 SHERMAN	230kV	Ckt	2
C- 96	Transformer	214 SO BAY	69kV	to	251 SO BAY	138kV	Ckt	1
C- 97	Transformer	214 SO BAY	69kV	to	251 SO BAY	138kV	Ckt	2
C- 98	Transformer	223 CEDAR	138kV	to	258 CEDAR	230kV	Ckt	1

4/20/00

## APPENDIX B: CONTINGENCY LIST

C-99	Transformer	223 CEDAR	138kV	to	258 CEDAR	230kV	Ckt	2
C-100	Transformer	232 HOBE	138kV	to	261 HOBE	230kV	Ckt	1
C-101	Transformer	240 MIDWAY	138kV	to	266 MIDWAY	230kV	Ckt	1
C-102	Transformer	240 MIDWAY	138kV	to	266 MIDWAY	230kV	Ckt	2
C-103	Transformer	245 PLUMOSUS	138kV	to	601 PLUMOSUS	230kV	Ckt	1
C-104	Transformer	249 RANCH	138kV	to	268 RANCH	230kV	Ckt	1
C-105	Transformer	249 RANCH	138kV	to	268 RANCH	230kV	Ckt	2
C-106	Transformer	250 RIVIERA	138kV	to	212 RIVIERA	69kV	Ckt	1
C-107	Transformer	250 RIVIERA	138kV	to	212 RIVIERA	69kV	Ckt	2
C-108	Transformer	257 YAMATO	138kV	to	273 YAMATO	230kV	Ckt	1
C-109	Transformer	273 YAMATO	230kV	to	257 YAMATO	138kV	Ckt	2
C-110	Transformer	274 CORBETT	500kV	to	535 CORBETT	230kV	Ckt	1
C-111	Transformer	275 MARTIN	500kV	to	265 MARTIN	230kV	Ckt	1
C-112	Transformer	276 MIDWAY	500kV	to	266 MIDWAY	230kV	Ckt	1
C-113	Transformer	530 SANPIPER	138kV	to	259 SANPIPER	230kV	Ckt	1
C-114	Line	9382 VER-SOUT	138kV	to	9383 FV-CTYLN	138kV	Ckt	1
C-115	Line	9396 DOWNTNS	69kV	to	9397 VB SUB7	69kV	Ckt	1
C-116	Line	9396 DOWNTNS	69kV	to	9404 VB SUB1	69kV	Ckt	1
C-117	Line	9397 VB SUB7	69kV	to	9398 VB SUB6	69kV	Ckt	1
C-118	Line	9397 VB SUB7	69kV	to	9403 VB SUB8	69kV	Ckt	1
C-119	Line	9398 VB SUB6	69kV	to	9399 VBSUB12	69kV	Ckt	1
C-120	Line	9398 VB SUB6	69kV	to	9400 VB SUB9	69kV	Ckt	1
C-121	Line	9399 VBSUB12	69kV	to	9400 VB SUB9	69kV	Ckt	1
C-122	Line	9399 VBSUB12	69kV	to	9404 VB SUB1	69kV	Ckt	1
C-123	Line	9400 VB SUB9	69kV	to	9401 VB SUB1	69kV	Ckt	1
C-124	Line	9401 VB SUB1	69kV	to	9402 VBSUB11	69kV	Ckt	1
C-125	Line	9401 VB SUB1	69kV	to	9404 VB SUB1	69kV	Ckt	1
C-126	Line	9402 VBSUB11	69kV	to	9403 VB SUB8	69kV	Ckt	1
C-127	Line	9403 VB SUB8	69kV	to	9404 VB SUB1	69kV	Ckt	1
C-128	Transformer	9397 VB SUB7	69kV	to	9381 WEST-FMP	138kV	Ckt	1
C-129	Transformer	9397 VB SUB7	69kV	to	9381 WEST-FMP	138kV	Ckt	2
C-130	Transformer	9403 VB SUB8	69kV	to	9382 VER-SOUT	138kV	Ckt	1
C-131	Line	4002 FTP-GA C	138kV	to	9383 FV-CTYLN	138kV	Ckt	1
C-132	Line	4011 HARTMAN	69kV	to	4012 SAVANNAH	69kV	Ckt	1
C-133	Line	4011 HARTMAN	69kV	to	4014 LAWNWOOD	69kV	Ckt	1
C-134	Line	4012 SAVANNAH	69kV	to	4013 HD KING	69kV	Ckt	1
C-135	Line	4013 HD KING	69kV	to	4016 KING GEN	69kV	Ckt	1
C-136	Line	4014 LAWNWOOD	69kV	to	4015 GARDEN C	69kV	Ckt	1
C-137	Line	4015 GARDEN C	69kV	to	4016 KING GEN	69kV	Ckt	1
C-138	Line	4016 KING GEN	69kV	to	4017 CAUSEWAY	69kV	Ckt	1
C-139	Transformer	4011 HARTMAN	69kV	to	4001 HART-FMP	138kV	Ckt	1
C-140	Transformer	4011 HARTMAN	69kV	to	4001 HART-FMP	138kV	Ckt	2
C-141	Transformer	4015 GARDEN C	69kV	to	4002 FTP-GA C	138kV	Ckt	1
C-142	Line	266 MIDWAY	230kV	to	464 MALABAR	230kV	Ckt	99
C-143	Line	2068 HAINESCK	230kV	to	2072 SORRENTO	230kV	Ckt	1
C-144	Line	2068 HAINESCK	230kV	to	3521 CENT FLA	230kV	Ckt	1
C-145	Line	2069 LOCKHART	230kV	to	2073 SPG LAKE	230kV	Ckt	1
C-146	Line	2069 LOCKHART	230kV	to	2168 WOODSMER	230kV	Ckt	1
C-147	Line	2070 PIEDMONT	230kV	to	2071 WELCH RD	230kV	Ckt	1
C-148	Line	2070 PIEDMONT	230kV	to	2074 WEKIVA	230kV	Ckt	1
C-149	Line	2070 PIEDMONT	230kV	to	2168 WOODSMER	230kV	Ckt	1

4/20/00

## APPENDIX B: CONTINGENCY LIST

C-150	Line	2071 WELCH RD	230kV	to	2072 SORRENTO	230kV	Ckt	1
C-151	Line	2073 SPG LAKE	230kV	to	2580 ALTAMONT	230kV	Ckt	1
C-152	Line	2074 WEKIVA	230kV	to	2584 MYRTL LK	230kV	Ckt	1
C-153	Line	2163 CAMP LK	230kV	to	2167 WINDERME	230kV	Ckt	1
C-154	Line	2163 CAMP LK	230kV	to	3521 CENT FLA	230kV	Ckt	1
C-155	Line	2164 CLMT EST	230kV	to	2167 WINDERME	230kV	Ckt	1
C-156	Line	2164 CLMT EST	230kV	to	3521 CENT FLA	230kV	Ckt	1
C-157	Line	2165 INTERNAT	230kV	to	2166 LK BRYAN	230kV	Ckt	1
C-158	Line	2165 INTERNAT	230kV	to	2167 WINDERME	230kV	Ckt	1
C-159	Line	2166 LK BRYAN	230kV	to	2167 WINDERME	230kV	Ckt	2
C-160	Line	2166 LK BRYAN	230kV	to	2883 INTERCSN	230kV	Ckt	1
C-161	Line	2166 LK BRYAN	230kV	to	2883 INTERCSN	230kV	Ckt	2
C-162	Line	2167 WINDERME	230kV	to	2168 WOODSMER	230kV	Ckt	1
C-163	Line	2167 WINDERME	230kV	to	5701 SO WOOD	230kV	Ckt	1
C-164	Line	2168 WOODSMER	230kV	to	5700 PINEHILL	230kV	Ckt	1
C-165	Line	2267 E CLRWTR	230kV	to	2269 LK TARPEN	230kV	Ckt	1
C-166	Line	2267 E CLRWTR	230kV	to	3834 ANCLOTE	230kV	Ckt	1
C-167	Line	2267 E CLRWTR	230kV	to	3932 ULMERTON	230kV	Ckt	1
C-168	Line	2268 HIGGINS	230kV	to	2269 LK TARPEN	230kV	Ckt	1
C-169	Line	2269 LK TARPEN	230kV	to	2270 PALM HBR	230kV	Ckt	1
C-170	Line	2269 LK TARPEN	230kV	to	3836 HUDSON	230kV	Ckt	1
C-171	Line	2269 LK TARPEN	230kV	to	3837 SEVEN SP	230kV	Ckt	1
C-172	Line	2269 LK TARPEN	230kV	to	3932 ULMERTON	230kV	Ckt	1
C-173	Line	2269 LK TARPEN	230kV	to	8000 SHELD	230kV	Ckt	1
C-174	Line	2269 LK TARPEN	230kV	to	8000 SHELD	230kV	Ckt	2
C-175	Line	2269 LK TARPEN	230kV	to	8000 SHELD	230kV	Ckt	3
C-176	Line	2270 PALM HBR	230kV	to	3930 LARGO	230kV	Ckt	1
C-177	Line	2271 GRIFFIN	230kV	to	2884 KATHLEEN	230kV	Ckt	1
C-178	Line	2271 GRIFFIN	230kV	to	6102 WEST	230kV	Ckt	1
C-179	Line	2288 LK TARPEN	500kV	to	2289 LKT-DUM1	500kV	Ckt	1
C-180	Line	2288 LK TARPEN	500kV	to	2290 LKT-DUM2	500kV	Ckt	1
C-181	Line	2288 LK TARPEN	500kV	to	3550 BRKRIDGE	500kV	Ckt	1
C-182	Line	2437 DEBARY	230kV	to	2439 DUMMY 1	230kV	Ckt	1
C-183	Line	2437 DEBARY	230kV	to	2440 DUMMY 2	230kV	Ckt	1
C-184	Line	2437 DEBARY	230kV	to	2441 DUMMY 3	230kV	Ckt	1
C-185	Line	2437 DEBARY	230kV	to	2442 ORANGE C	230kV	Ckt	1
C-186	Line	2437 DEBARY	230kV	to	2582 LK EMMA	230kV	Ckt	1
C-187	Line	2437 DEBARY	230kV	to	2585 N LONGWD	230kV	Ckt	1
C-188	Line	2438 DELAND W	230kV	to	2442 ORANGE C	230kV	Ckt	1
C-189	Line	2438 DELAND W	230kV	to	3529 SILVR SP	230kV	Ckt	1
C-190	Line	2581 ECON	230kV	to	2586 RIO PINR	230kV	Ckt	1
C-191	Line	2581 ECON	230kV	to	2589 WTR PK E	230kV	Ckt	1
C-192	Line	2582 LK EMMA	230kV	to	2590 WTR SPGS	230kV	Ckt	1
C-193	Line	2583 MEADWD S	230kV	to	5704 TAFT	230kV	Ckt	1
C-194	Line	2584 MYRTL LK	230kV	to	2585 N LONGWD	230kV	Ckt	1
C-195	Line	2585 N LONGWD	230kV	to	2590 WTR SPGS	230kV	Ckt	1
C-196	Line	2586 RIO PINR	230kV	to	2591 CURRY FD	230kV	Ckt	1
C-197	Line	2587 SKY LAKE	230kV	to	5701 SO WOOD	230kV	Ckt	1
C-198	Line	2588 TAYLR CK	230kV	to	2882 HOLOPAW	230kV	Ckt	1
C-199	Line	2589 WTR PK E	230kV	to	2590 WTR SPGS	230kV	Ckt	1
C-200	Line	2591 CURRY FD	230kV	to	5705 STANTON	230kV	Ckt	1

4/20/00

## APPENDIX B: CONTINGENCY LIST

C-201	Line	2876 LOUGHMAN	230kV	to	2883 INTERCSN	230kV	Ckt	1
C-202	Line	2876 LOUGHMAN	230kV	to	2891 WLK WALE	230kV	Ckt	1
C-203	Line	2877 AVON PK	230kV	to	2880 FISH CRK	230kV	Ckt	1
C-204	Line	2877 AVON PK	230kV	to	2881 FT MEADE	230kV	Ckt	1
C-205	Line	2878 BARCOLA	230kV	to	2887 HINES	230kV	Ckt	1
C-206	Line	2878 BARCOLA	230kV	to	2887 HINES	230kV	Ckt	2
C-207	Line	2878 BARCOLA	230kV	to	6102 WEST	230kV	Ckt	1
C-208	Line	2878 BARCOLA	230kV	to	9050 PEBB	230kV	Ckt	1
C-209	Line	2879 CANOE CK	230kV	to	2882 HOLOPAW	230kV	Ckt	1
C-210	Line	2879 CANOE CK	230kV	to	2891 WLK WALE	230kV	Ckt	1
C-211	Line	2881 FT MEADE	230kV	to	2887 HINES	230kV	Ckt	1
C-212	Line	2881 FT MEADE	230kV	to	2889 TIGERBAY	230kV	Ckt	1
C-213	Line	2881 FT MEADE	230kV	to	2890 VANDOLAH	230kV	Ckt	1
C-214	Line	2881 FT MEADE	230kV	to	2891 WLK WALE	230kV	Ckt	1
C-215	Line	2882 HOLOPAW	230kV	to	7431 STC EAST	230kV	Ckt	1
C-216	Line	2884 KATHLEEN	230kV	to	3530 ZEPHYR N	230kV	Ckt	1
C-217	Line	2885 N BARTOW	230kV	to	9050 PEBB	230kV	Ckt	1
C-218	Line	2885 N BARTOW	230kV	to	9130 SELOSE T	230kV	Ckt	1
C-219	Line	2887 HINES	230kV	to	2889 TIGERBAY	230kV	Ckt	1
C-220	Line	2888 TIGER PL	230kV	to	2889 TIGERBAY	230kV	Ckt	1
C-221	Line	2888 TIGER PL	230kV	to	2889 TIGERBAY	230kV	Ckt	2
C-222	Line	2890 VANDOLAH	230kV	to	7121 CC PLANT	230kV	Ckt	1
C-223	Line	2891 WLK WALE	230kV	to	9130 SELOSE T	230kV	Ckt	1
C-224	Line	2911 KATH-DUM	500kV	to	2913 KATHLEEN	500kV	Ckt	1
C-225	Line	2913 KATHLEEN	500kV	to	3551 CENT FLA	500kV	Ckt	1
C-226	Line	3159 ARCHER	230kV	to	3171 HAILE	230kV	Ckt	1
C-227	Line	3159 ARCHER	230kV	to	3528 MARTIN W	230kV	Ckt	1
C-228	Line	3159 ARCHER	230kV	to	4102 PKRD	230kV	Ckt	1
C-229	Line	3160 CRAWFDVL	230kV	to	3164 GUM BAY	230kV	Ckt	1
C-230	Line	3160 CRAWFDVL	230kV	to	3167 PERRY	230kV	Ckt	1
C-231	Line	3160 CRAWFDVL	230kV	to	7600 HOPKINS	230kV	Ckt	1
C-232	Line	3162 FT WHT N	230kV	to	3163 FT WHT S	230kV	Ckt	1
C-233	Line	3162 FT WHT N	230kV	to	3169 SUWANNEE	230kV	Ckt	1
C-234	Line	3163 FT WHT S	230kV	to	3165 NEWBERRY	230kV	Ckt	1
C-235	Line	3163 FT WHT S	230kV	to	3171 HAILE	230kV	Ckt	1
C-236	Line	3164 GUM BAY	230kV	to	3166 P ST JOE	230kV	Ckt	1
C-237	Line	3165 NEWBERRY	230kV	to	3170 WILCOX	230kV	Ckt	1
C-238	Line	3165 NEWBERRY	230kV	to	3522 CR PLANT	230kV	Ckt	1
C-239	Line	3166 P ST JOE	230kV	to	17860 CALLAWAY	230kV	Ckt	1
C-240	Line	3167 PERRY	230kV	to	3169 SUWANNEE	230kV	Ckt	1
C-241	Line	3168 SUWAN PK	230kV	to	3169 SUWANNEE	230kV	Ckt	1
C-242	Line	3169 SUWANNEE	230kV	to	11870 STERLING	230kV	Ckt	1
C-243	Line	3171 HAILE	230kV	to	6736 HAIL MIL	230kV	Ckt	1
C-244	Line	3515 ANDERSEN	230kV	to	3521 CENT FLA	230kV	Ckt	1
C-245	Line	3515 ANDERSEN	230kV	to	3527 HOLDER	230kV	Ckt	1
C-246	Line	3518 BRKRIDGE	230kV	to	3520 BRKSVWTP	230kV	Ckt	1
C-247	Line	3518 BRKRIDGE	230kV	to	3522 CR PLANT	230kV	Ckt	1
C-248	Line	3518 BRKRIDGE	230kV	to	3523 CRYST RE	230kV	Ckt	1
C-249	Line	3518 BRKRIDGE	230kV	to	3836 HUDSON	230kV	Ckt	1
C-250	Line	3519 BRKSVL W	230kV	to	3520 BRKSVWTP	230kV	Ckt	1
C-251	Line	3520 BRKSVWTP	230kV	to	3835 GULFPINE	230kV	Ckt	1

4/20/00



## APPENDIX B: CONTINGENCY LIST

C-252	Line	3521 CENT FLA	230kV	to	3525 DALLAS	230kV	Ckt	1
C-253	Line	3521 CENT FLA	230kV	to	3527 HOLDER	230kV	Ckt	1
C-254	Line	3521 CENT FLA	230kV	to	3529 SILVR SP	230kV	Ckt	1
C-255	Line	3522 CR PLANT	230kV	to	3523 CRYST RE	230kV	Ckt	1
C-256	Line	3522 CR PLANT	230kV	to	3524 CRYST R4	230kV	Ckt	1
C-257	Line	3522 CR PLANT	230kV	to	3527 HOLDER	230kV	Ckt	1
C-258	Line	3522 CR PLANT	230kV	to	3527 HOLDER	230kV	Ckt	2
C-259	Line	3525 DALLAS	230kV	to	3529 SILVR SP	230kV	Ckt	1
C-260	Line	3528 MARTIN W	230kV	to	7120 SILV SPN	230kV	Ckt	1
C-261	Line	3529 SILVR SP	230kV	to	3531 OCALA 1	230kV	Ckt	1
C-262	Line	3529 SILVR SP	230kV	to	7120 SILV SPN	230kV	Ckt	1
C-263	Line	3529 SILVR SP	230kV	to	7120 SILV SPN	230kV	Ckt	2
C-264	Line	3531 OCALA 1	230kV	to	6296 OCALA 1	230kV	Ckt	1
C-265	Line	3531 OCALA 1	230kV	to	7120 SILV SPN	230kV	Ckt	1
C-266	Line	3548 BRDG-DUM	500kV	to	3550 BRKRIDGE	500kV	Ckt	1
C-267	Line	3550 BRKRIDGE	500kV	to	3555 CRYST RV	500kV	Ckt	1
C-268	Line	3551 CENT FLA	500kV	to	3552 CENT-DM2	500kV	Ckt	1
C-269	Line	3551 CENT FLA	500kV	to	3553 CENT-DUM	500kV	Ckt	1
C-270	Line	3551 CENT FLA	500kV	to	3555 CRYST RV	500kV	Ckt	1
C-271	Line	3555 CRYST RV	500kV	to	3556 CRYST R5	500kV	Ckt	1
C-272	Line	3702 40TH ST	230kV	to	3704 NORTHEST	230kV	Ckt	1
C-273	Line	3702 40TH ST	230kV	to	3705 PASADENA	230kV	Ckt	1
C-274	Line	3703 BARTOW	230kV	to	3704 NORTHEST	230kV	Ckt	1
C-275	Line	3703 BARTOW	230kV	to	3704 NORTHEST	230kV	Ckt	2
C-276	Line	3704 NORTHEST	230kV	to	3706 PNLRCOV	230kV	Ckt	1
C-277	Line	3704 NORTHEST	230kV	to	3932 ULMERTON	230kV	Ckt	1
C-278	Line	3704 NORTHEST	230kV	to	3932 ULMERTON	230kV	Ckt	2
C-279	Line	3705 PASADENA	230kV	to	3931 SEMINOLE	230kV	Ckt	1
C-280	Line	3833 ANC COOL	230kV	to	3834 ANCLOTE	230kV	Ckt	1
C-281	Line	3834 ANCLOTE	230kV	to	3837 SEVEN SP	230kV	Ckt	1
C-282	Line	3834 ANCLOTE	230kV	to	3930 LARGO	230kV	Ckt	1
C-283	Line	3835 GULFPINE	230kV	to	3837 SEVEN SP	230kV	Ckt	1
C-284	Line	3929 BLCHR RD	230kV	to	3930 LARGO	230kV	Ckt	1
C-285	Line	3929 BLCHR RD	230kV	to	3932 ULMERTON	230kV	Ckt	1
C-286	Line	3930 LARGO	230kV	to	3931 SEMINOLE	230kV	Ckt	1
C-287	Line	4650 CENTR PK	230kV	to	4875 NORTHSDE	230kV	Ckt	1
C-288	Line	4650 CENTR PK	230kV	to	4950 ROBNWOOD	230kV	Ckt	1
C-289	Line	4650 CENTR PK	230kV	to	4960 SJRPP	230kV	Ckt	1
C-290	Line	4650 CENTR PK	230kV	to	4960 SJRPP	230kV	Ckt	2
C-291	Line	4650 CENTR PK	230kV	to	4972 S KERNAN	230kV	Ckt	1
C-292	Line	4700 FIRESTNE	230kV	to	4865 NORMANDY	230kV	Ckt	1
C-293	Line	4700 FIRESTNE	230kV	to	6673 BLK CK.	230kV	Ckt	1
C-294	Line	4710 FT CAROL	230kV	to	4830 MILL CVE	230kV	Ckt	1
C-295	Line	4710 FT CAROL	230kV	to	4960 SJRPP	230kV	Ckt	1
C-296	Line	4735 GREENLND	230kV	to	4750 HARTLEY	230kV	Ckt	1
C-297	Line	4735 GREENLND	230kV	to	4955 SE JAX	230kV	Ckt	1
C-298	Line	4735 GREENLND	230kV	to	4972 S KERNAN	230kV	Ckt	1
C-299	Line	4735 GREENLND	230kV	to	4985 SWTZRLND	230kV	Ckt	1
C-300	Line	4865 NORMANDY	230kV	to	4875 NORTHSDE	230kV	Ckt	1
C-301	Line	4865 NORMANDY	230kV	to	4897 PATILLO	230kV	Ckt	2
C-302	Line	4865 NORMANDY	230kV	to	4960 SJRPP	230kV	Ckt	1

4/20/00

## APPENDIX B: CONTINGENCY LIST

C-303	Line	4865 NORMANDY	230kV	to	5005 WEST JAX	230kV	Ckt	1
C-304	Line	4875 NORTHSDE	230kV	to	5005 WEST JAX	230kV	Ckt	1
C-305	Line	4897 PATILLO	230kV	to	4960 SJRPP	230kV	Ckt	2
C-306	Line	4950 ROBNWOOD	230kV	to	4955 SE JAX	230kV	Ckt	1
C-307	Line	5351 KIS MARY	230kV	to	5704 TAFT	230kV	Ckt	1
C-308	Line	5352 CAN ISL	230kV	to	5353 KIS CLAY	230kV	Ckt	1
C-309	Line	5352 CAN ISL	230kV	to	5800 OUCCITP1	230kV	Ckt	1
C-310	Line	5352 CAN ISL	230kV	to	5801 OUCCITP2	230kV	Ckt	1
C-311	Line	5701 SO WOOD	230kV	to	5704 TAFT	230kV	Ckt	1
C-312	Line	5702 PERSHING	230kV	to	5705 STANTON	230kV	Ckt	1
C-313	Line	5702 PERSHING	230kV	to	5705 STANTON	230kV	Ckt	2
C-314	Line	5702 PERSHING	230kV	to	5708 R-22	230kV	Ckt	1
C-315	Line	5703 IND RIV	230kV	to	5705 STANTON	230kV	Ckt	1
C-316	Line	5703 IND RIV	230kV	to	5705 STANTON	230kV	Ckt	2
C-317	Line	5704 TAFT	230kV	to	5705 STANTON	230kV	Ckt	1
C-318	Line	5704 TAFT	230kV	to	5706 AIP	230kV	Ckt	1
C-319	Line	5704 TAFT	230kV	to	5800 OUCCITP1	230kV	Ckt	1
C-320	Line	5706 AIP	230kV	to	5709 R-23	230kV	Ckt	1
C-321	Line	5707 AIRPORT	230kV	to	5708 R-22	230kV	Ckt	1
C-322	Line	5707 AIRPORT	230kV	to	5709 R-23	230kV	Ckt	1
C-323	Line	5801 OUCCITP2	230kV	to	7890 OSCEOLA	230kV	Ckt	1
C-324	Line	6101 MCINTOSH	230kV	to	6104 TENOROC	230kV	Ckt	1
C-325	Line	6101 MCINTOSH	230kV	to	9150 LKAGNES	230kV	Ckt	1
C-326	Line	6102 WEST	230kV	to	6106 I-STATE	230kV	Ckt	1
C-327	Line	6103 EATON PK	230kV	to	6104 TENOROC	230kV	Ckt	1
C-328	Line	6103 EATON PK	230kV	to	6105 CREWSLK	230kV	Ckt	1
C-329	Line	6104 TENOROC	230kV	to	6106 I-STATE	230kV	Ckt	1
C-330	Line	6104 TENOROC	230kV	to	6114 MP4-230	230kV	Ckt	1
C-331	Line	6104 TENOROC	230kV	to	6115 MP5-230	230kV	Ckt	1
C-332	Line	6105 CREWSLK	230kV	to	9050 PEBB	230kV	Ckt	1
C-333	Line	6105 CREWSLK	230kV	to	9100 RECKER	230kV	Ckt	1
C-334	Line	6296 OCALA 1	230kV	to	6299 OC R-OAK	230kV	Ckt	1
C-335	Line	6297 OCALA 2	230kV	to	6299 OC R-OAK	230kV	Ckt	1
C-336	Line	6297 OCALA 2	230kV	to	7120 SILV SPN	230kV	Ckt	1
C-337	Line	6673 BLK CK.	230kV	to	6694 KEY HTS.	230kV	Ckt	1
C-338	Line	6682 FLRAHM.	230kV	to	6694 KEY HTS.	230kV	Ckt	1
C-339	Line	6682 FLRAHM.	230kV	to	6707 RIVRVU	230kV	Ckt	1
C-340	Line	6707 RIVRVU	230kV	to	7119 SEMINOLE	230kV	Ckt	1
C-341	Line	7119 SEMINOLE	230kV	to	7120 SILV SPN	230kV	Ckt	1
C-342	Line	7119 SEMINOLE	230kV	to	7120 SILV SPN	230kV	Ckt	2
C-343	Line	7121 CC PLANT	230kV	to	9090 HARDESUB	230kV	Ckt	1
C-344	Line	7600 HOPKINS	230kV	to	7620 SUB 20	230kV	Ckt	1
C-345	Line	7607 SUB 7	230kV	to	7620 SUB 20	230kV	Ckt	1
C-346	Line	7620 SUB 20	230kV	to	10218 S BAINBR	230kV	Ckt	1
C-347	Line	7890 OSCEOLA	230kV	to	9150 LKAGNES	230kV	Ckt	1
C-348	Line	8000 SHELD	230kV	to	8010 DLMBRY-W	230kV	Ckt	1
C-349	Line	8000 SHELD	230kV	to	8100 JAXSN230	230kV	Ckt	1
C-350	Line	8000 SHELD	230kV	to	8120 OHIO-S	230kV	Ckt	1
C-351	Line	8010 DLMBRY-W	230kV	to	8020 DLMBRY-E	230kV	Ckt	1
C-352	Line	8020 DLMBRY-E	230kV	to	8400 CHAPMAN	230kV	Ckt	1
C-353	Line	8110 OHIO-N	230kV	to	8120 OHIO-S	230kV	Ckt	1

4/20/00

## APPENDIX B: CONTINGENCY LIST

C-354	Line	8110 OHIO-N	230kv	to	8500 11TH AVE	230kv	Ckt	1
C-355	Line	8300 RIVER-N	230kv	to	8310 RIVER-S	230kv	Ckt	1
C-356	Line	8300 RIVER-N	230kv	to	8750 SR60-S T	230kv	Ckt	1
C-357	Line	8310 RIVER-S	230kv	to	8900 B BEND	230kv	Ckt	1
C-358	Line	8400 CHAPMAN	230kv	to	8700 GANNON	230kv	Ckt	1
C-359	Line	8500 11TH AVE	230kv	to	8860 SO GIB	230kv	Ckt	1
C-360	Line	8600 HAMPTN	230kv	to	8610 HAMPTN T	230kv	Ckt	1
C-361	Line	8610 HAMPTN T	230kv	to	8700 GANNON	230kv	Ckt	1
C-362	Line	8610 HAMPTN T	230kv	to	9050 PEBB	230kv	Ckt	1
C-363	Line	8700 GANNON	230kv	to	8750 SR60-S T	230kv	Ckt	1
C-364	Line	8700 GANNON	230kv	to	8760 SR60-N T	230kv	Ckt	1
C-365	Line	8700 GANNON	230kv	to	8850 BELCRK	230kv	Ckt	1
C-366	Line	8730 SR60-N	230kv	to	8760 SR60-N T	230kv	Ckt	1
C-367	Line	8740 SR60-S	230kv	to	8750 SR60-S T	230kv	Ckt	1
C-368	Line	8760 SR60-N T	230kv	to	8900 B BEND	230kv	Ckt	1
C-369	Line	8850 BELCRK	230kv	to	9050 PEBB	230kv	Ckt	1
C-370	Line	8860 SO GIB	230kv	to	8900 B BEND	230kv	Ckt	1
C-371	Line	8870 RUSKIN T	230kv	to	8900 B BEND	230kv	Ckt	1
C-372	Line	8880 RUSKMTR8	230kv	to	8900 B BEND	230kv	Ckt	1
C-373	Line	8890 BIGBGT-T	230kv	to	8900 B BEND	230kv	Ckt	1
C-374	Line	8900 B BEND	230kv	to	9010 MINES W	230kv	Ckt	1
C-375	Line	9000 POLKPLNT	230kv	to	9030 BRADLY T	230kv	Ckt	1
C-376	Line	9000 POLKPLNT	230kv	to	9050 PEBB	230kv	Ckt	1
C-377	Line	9000 POLKPLNT	230kv	to	9050 PEBB	230kv	Ckt	2
C-378	Line	9000 POLKPLNT	230kv	to	9090 HARDESUB	230kv	Ckt	1
C-379	Line	9010 MINES W	230kv	to	9020 MINES E	230kv	Ckt	1
C-380	Line	9020 MINES E	230kv	to	9030 BRADLY T	230kv	Ckt	1
C-381	Line	9100 RECKER	230kv	to	9110 ARIANA	230kv	Ckt	1
C-382	Line	9100 RECKER	230kv	to	9150 LKAGNES	230kv	Ckt	1
C-383	Line	9100 RECKER	230kv	to	9160 GAPWAY	230kv	Ckt	1
C-384	Line	9120 SELOSE	230kv	to	9130 SELOSE T	230kv	Ckt	1
C-385	Transformer	2289 LKT-DUM1	500kv	to	2269 LK TARP	230kv	Ckt	1
C-386	Transformer	2290 LKT-DUM2	500kv	to	2269 LK TARP	230kv	Ckt	1
C-387	Transformer	2911 KATH-DUM	500kv	to	2884 KATHLEEN	230kv	Ckt	1
C-388	Transformer	3548 BRDG-DUM	500kv	to	3518 BRKRIDGE	230kv	Ckt	1
C-389	Transformer	3552 CENT-DM2	500kv	to	3521 CENT FLA	230kv	Ckt	1
C-390	Transformer	3553 CENT-DUM	500kv	to	3521 CENT FLA	230kv	Ckt	1
C-391	Line	2163 CAMP LK	230kv	to	90000 MIDWAY	230kv	Ckt	1
C-392	Line	2164 CLMT EST	230kv	to	90000 MIDWAY	230kv	Ckt	1
C-393	Line	90000 MIDWAY	230kv	to	3521 CENT FLA	230kv	Ckt	1
C-394	Line	90000 MIDWAY	230kv	to	3521 CENT FLA	230kv	Ckt	2

4/20/00