

LAW OFFICES

MARTIN, ADE, BIRCHFIELD & MICKLER, P.A.

ORIGINAL

JAMES L. ADE
LYNDA R. AYCOCK
W. O. BIRCHFIELD
TIMOTHY A. BURLEIGH
JASON E. CAMPBELL
CHARLES L. CRANFORD
STEPHEN H. DURANT
T. WILLIAM GLOCKER
MICHAEL E. GOODBREAD, JR.
STEPHEN D. HALKER
SHARON ROBERTS HENDERSON
BARBARA CHRISTIE JOHNSTON

ONE INDEPENDENT DRIVE - SUITE 3000
JACKSONVILLE, FLORIDA 32202

MAILING ADDRESS:
POST OFFICE BOX 59
JACKSONVILLE, FLORIDA 32201
TELEPHONE (904) 354-2050
TELECOPIER (904) 354-5842

MAUREEN E. MCKINLEY
ROBERT O. MICKLER
JOHN D. MILTON, JR.
JAMES A. NOLAN, III
DANIEL B. NUNN, JR.
SCOTT G. SCHILDBERG
ALLAN E. WULBERN

OF COUNSEL
LEWIS S. LEE

RALPH H. MARTIN (1917-1999)
L. PETER JOHNSON (1942-1988)

May 24, 2000

VIA FACSIMILE
(850) 413-7000

Richard Redemann
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Re: Application by United Water Florida Inc. for
an Extension of Service Area in Nassau County,
Florida, Docket No. 000391-WS

Dear Mr. Redemann:

Pursuant to your request for additional information in
connection with the above-referenced matter, enclosed please find
an information sheet from United Water Florida Inc.

If you have any additional questions or comments regarding
this matter, please do not hesitate to call me.

Sincerely yours,

Scott G. Schildberg

SGS:arr
Enclosures

cc: Mr. Gary R. Moseley
Mr. John Pine
Ms. Blanca Bayo

APP _____
CAF _____
CMP _____
COM _____
CTR _____
ECR _____
LEG _____
OPC _____
PAI _____
RGO _____
SEC _____
SER _____
OTH _____

MAY 25 AM 8
MAIL ROOM

DOCUMENT NUMBER-DATE

06481 MAY 25 B

FPSC-RECORDS/REPORTING

Oyster Bay Development

I. Treatment facilities - water only

Water: Yulee Grid; total grid capacity

- a. Lofton Oaks
 - 1. Ground storage size: 35,000 gallons
 - 2. Hydro tank size: 5000 gallons
- b. Otter Run
 - 1. Ground storage size: 70,000 gallons
 - 2. Hydro tank size: 5000 gallons
- c. Yulee Regional
 - 1. Ground storage size: 300,000 gallons
 - 2. Hydro tank size: 500 gpm HSP, FVC pump 1500 gpm

II. Size of lines (to be donated)

- a. Water: 12" - 5070'
 - 8" - 701'
 - 4" - 208'
 - 2" - 367'
- b. Gravity sewer: 8" - 5180'
- c. Force main: 8" - 3812'

III. Lift Station

- a. Size: 40' x 40'
- b. Configuration: Flyqt with 463 impeller; 30 HP @ 128' head
- c. Number: 1