

ORIGINAL

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

In Re: Petition for Determination of)
Need for an Electrical Power Plant in)
Polk County by Calpine Construction)
Finance Company, L.P.)

DOCKET NO. 000442-EI

TESTIMONY AND EXHIBITS

OF

KENNETH J. SLATER

ON BEHALF OF

**CALPINE CONSTRUCTION FINANCE
COMPANY, L.P.**

DOCUMENT NUMBER-DATE

10249 AUG 21 8

FPSC-RECORDS/REPORTING

IN RE: PETITION FOR DETERMINATION OF NEED
FOR THE OSPREY ENERGY CENTER BY
CALPINE CONSTRUCTION FINANCE COMPANY, L.P.,
FPSC DOCKET NO. 000442-EI

DIRECT TESTIMONY OF KENNETH J. SLATER

1 Q: Please state your name and business address.

2 A: My name is Kenneth J. Slater. My business address is 3370
3 Habersham Road, Atlanta, Georgia 30305.

4
5 Q: By whom are you employed and in what positions?

6 A: I am President and Chief Executive Officer of Slater
7 Consulting, which I founded in August 1990. The firm is a
8 small engineering-economic and management consultancy with
9 particular expertise in energy and public utility matters.
10 The services, which the firm offers to various participants in
11 the utility business, include analysis of supply/demand
12 options, reliability, operating situations and events, new
13 technologies and industry developments, strategic decisions,
14 public policy matters and ratemaking issues.

15
16 Q: Please describe your duties with Slater Consulting.

17 A: I am the President and Chief Executive Officer of Slater
18 Consulting. Although I am responsible for the overall
19 management and operation of the Company, I spend most of my
20 time working on client projects.

21

DIRECT TESTIMONY OF KENNETH J. SLATER

PROFESSIONAL QUALIFICATIONS AND EXPERIENCE

1

2 **Q: Please summarize your educational background and experience.**

3 A: I obtained a Bachelor of Science degree in Pure Mathematics
4 and Physics in 1960 and a Bachelor of Engineering degree in
5 Electrical Engineering in 1962, both at the University of
6 Sydney, Australia. I also received a Master of Applied
7 Science degree in Management Sciences at the University of
8 Waterloo in Ontario, Canada in 1974.

9

10 **Q: Please summarize your employment history and work experience.**

11 A: I have almost forty years of experience in the energy and
12 utility industries in the United States, Canada and Australia.
13 Prior to founding Slater Consulting, I was Senior Vice
14 President and Chief Engineer at Energy Management Associates,
15 Inc. ("EMA") in Atlanta, where I worked from 1983 to 1990. At
16 EMA, after initially contributing to the firm's utility
17 software development functions, I became the head of its
18 consulting practice, leading or making significant
19 contributions to a number of consulting engagements related to
20 valuation or analysis of power supplies and power supply
21 contracts, supply/demand planning, damages assessments,
22 operating reserve requirements, replacement power cost
23 calculations, utility merger valuations, operational
24 integration of utility systems, power pooling, system

DIRECT TESTIMONY OF KENNETH J. SLATER

1 reliability, ratemaking, power dispatching and gas supply
2 studies. From 1969 until 1983, I worked in the Canadian
3 utility industry. From 1975 to 1983, I ran my own firm,
4 Slater Energy Consultants, Inc., in Toronto, Canada and
5 consulted widely in Canada and the United States for
6 utilities, governments, public enquiry commissions, utility
7 customers and other consulting firms. It was during this time
8 and my time at EMA that I was a major developer of PROMOD
9 III®, (now renamed PROMOD IV®), a widely recognized electric
10 utility planning and reliability model.

11 From 1969 through 1974, I worked as an Engineer, and then
12 as a Senior Engineer at Ontario Hydro, where I headed the
13 Production Development Section of the utility's Operating
14 Department. There I developed computer models, including one
15 which, for more than 20 years, produced the daily generation
16 schedules for the Ontario Hydro system, and another, the
17 original PROMOD, which was used for coordination and
18 optimization of production planning and resource management.
19 In 1974 and 1975, I worked as Manager of Engineering at the
20 Ontario Energy Board (Ontario's utility regulatory commission)
21 and in 1975 and 1976, I served as Research Director for the
22 Royal Commission on Electric Power Planning (also in Ontario).

23 Prior to 1969, I was employed by the Electricity
24 Commission of New South Wales, the largest electric utility in
25 Australia, where I was responsible for the day-to-day

DIRECT TESTIMONY OF KENNETH J. SLATER

1 operation of one of the six regions comprising that system.
2 A copy of my resume is included as Exhibit KJS-1.

3
4 **Q: Have you previously testified before regulatory authorities or**
5 **courts?**

6 **A:** Yes. I have provided expert testimony in regulatory
7 proceedings in California, Florida, Georgia, Idaho, Indiana,
8 Iowa, Louisiana, New Mexico, New York, Nova Scotia, Ontario,
9 Pennsylvania, Prince Edward Island, South Carolina, Texas,
10 Virginia, and Wisconsin, and at the Federal Energy Regulatory
11 Commission. I have also appeared in Federal Bankruptcy Court
12 and state courts in Florida, Nebraska, Texas and Virginia, and
13 in civil arbitration proceedings in Louisiana, Nevada, New
14 England, and Pennsylvania. I have also served on many
15 occasions as an expert examiner for a Royal Commission in
16 Ontario that was charged with studying and evaluating electric
17 power planning in the Province of Ontario. I have also served
18 as a member of a panel of arbitrator/valuers in a proceeding
19 under the American Arbitration Association concerned with the
20 value of a cogeneration plant.

21
22 **Q: Are you a registered professional engineer?**

23 **A:** Yes, I am a registered professional engineer in Ontario.

24

DIRECT TESTIMONY OF KENNETH J. SLATER

PURPOSE AND SUMMARY OF TESTIMONY

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24

Q: What is the purpose of your testimony in this proceeding?

A: I am testifying on behalf of Calpine Construction Finance Company, L.P. ("Calpine"), to provide the results of various analyses, prepared by me or under my direction and supervision, that address various aspects of the Osprey Energy Center (the "Osprey Project" or simply the "Project") and its projected impacts on the Peninsular Florida power supply system. Specifically, my testimony addresses:

1. how the Osprey Project will operate in the Peninsular Florida power supply system;
2. the impacts that the Osprey Project will have on overall fuel consumption, power supply costs, and emissions from electricity generation for Peninsular Florida power supply;
3. the cost-effectiveness of the Osprey Project as a power supply resource for Peninsular Florida; and
4. the impact of the Osprey Project's presence on Peninsular Florida reserves and reliability.

Q: Please summarize your understanding of the Osprey Project.

A: I understand the Osprey Project to be a 529 megawatt ("MW") natural gas-fired combined cycle electric generating plant that will be located in Auburndale, Florida, and

DIRECT TESTIMONY OF KENNETH J. SLATER

1 interconnected to the Peninsular Florida power supply grid at
2 the Recker Substation of Tampa Electric Company ("TECO"). The
3 Project will have summer generating capability of
4 approximately 496 MW and winter capability of approximately
5 578 MW, without duct-firing and power augmentation. The
6 Project will utilize advanced technology Siemens-Westinghouse
7 Model 501F combustion turbines in a combined cycle
8 configuration. This design is typical of modern, efficient,
9 advanced technology power plants.

10

11 **Q: Please summarize the main conclusions of your testimony.**

12 **A:** My staff and I prepared analyses of the Peninsular Florida
13 power supply system with and without the Osprey Project using
14 the PROMOD IV® production modeling program. Based on these
15 analyses, it is my opinion that the Osprey Project will make
16 significant and economically valuable contributions to the
17 Peninsular Florida power supply system. Even modeled with
18 conservative assumptions, the Osprey Project is projected:

- 19 1. to operate at annual capacity factors between 86 and 93
20 percent for the entire analysis period, which in our
21 modeling was the first ten years of the Project's
22 commercial life;
- 23 2. to provide significant savings -- 6 trillion to 9
24 trillion Btu per year -- of primary energy used to

DIRECT TESTIMONY OF KENNETH J. SLATER

- 1 generate electricity for use in Peninsular Florida;
- 2 3. to result in significant savings of petroleum fuels and
- 3 coal;
- 4 4. to improve the overall efficiency of electricity
- 5 production and natural gas use in and for Peninsular
- 6 Florida;
- 7 5. to result in wholesale power supply cost savings of
- 8 approximately \$794 million (Net Present Value) over the
- 9 first ten years of the Projects's operations;
- 10 6. to provide enhanced reliability of the power supply
- 11 system in Peninsular Florida; and
- 12 7. to result in significant reductions -- approximately
- 13 8,000 to 23,000 tons per year -- in combined emissions of
- 14 sulfur dioxide and nitrogen oxides from the generation of
- 15 Peninsular Florida's power supply.

16 These results hold true under both our base case

17 assumptions and under "sensitivity cases" that we modeled in

18 which we analyzed the Project's operations and impacts

19 assuming a higher natural gas price forecast, lower load

20 growth, and higher load growth in Peninsular Florida.

21

22 **Q: Are you sponsoring any exhibits to your testimony?**

23 **A: Yes. I am sponsoring the following exhibits.**

24 **KJS-1. Resume' of Kenneth John Slater.**

DIRECT TESTIMONY OF KENNETH J. SLATER

- 1 KJS-2. Fuel Price Assumptions for PROMOD IV® Analyses of
2 Osprey Project Operations.
- 3 KJS-3. Efficiency and Cost-Effectiveness of Peninsular
4 Florida Generating Units, 2003.
- 5 KJS-4. Efficiency and Cost-Effectiveness of Peninsular
6 Florida Generating Units, 2008.
- 7 KJS-5. Peninsular Florida Summary of Existing Capacity As
8 of January 1, 2000.
- 9 KJS-6. Peninsular Florida, Historical and Projected Summer
10 and Winter Firm Peak Demands, 1991-2012.
- 11 KJS-7. Peninsular Florida, Historical and Projected Net
12 Energy for Load and Number of Customers, 1991-2012.
- 13 KJS-8. Osprey Energy Center - Summary of Projected
14 Operations, 2003-2012.
- 15 KJS-9. Osprey Energy Center - Summary of Projected
16 Operations, 2003-2012, Higher Natural Gas Price
17 Sensitivity Analysis.
- 18 KJS-10. Osprey Energy Center - Summary of Projected
19 Operations, 2003-2012, Load Growth Sensitivity
20 Analyses.
- 21 KJS-11. Illustration of Impacts of Osprey Energy Center on
22 Operations of Other Peninsular Florida Power
23 Plants.
- 24 KJS-12. Market Indicators - Average Electric Production
25 Costs by NERC Region, 1997-1999.

DIRECT TESTIMONY OF KENNETH J. SLATER

- 1 KJS-13. Peninsular Florida, Impacts of Osprey Energy Center
2 on Average Electricity Generation Heat Rates and
3 Total Fuel Consumption, 2003-2012.
- 4 KJS-14. Peninsular Florida, Fuel Consumption Impacts of
5 Osprey Energy Center, 2003-2012.
- 6 KJS-15. Peninsular Florida, Summary of Projected Wholesale
7 Energy Cost Savings Due to Osprey Energy Center,
8 Base Case, 2003-2012.
- 9 KJS-16. Peninsular Florida, Summary of Projected Wholesale
10 Energy Cost Savings Due to Osprey Energy Center,
11 Higher Fuel Price Sensitivity Case, 2003-2012.
- 12 KJS-17. Peninsular Florida, Summary of Projected Wholesale
13 Energy Cost Savings Due to Osprey Energy Center,
14 Low Load Growth Sensitivity Case, 2003-2012.
- 15 KJS-18. Peninsular Florida, Summary of Projected Wholesale
16 Energy Cost Savings Due to Osprey Energy Center,
17 High Load Growth Sensitivity Case, 2003-2012.
- 18 KJS-19. Comparison of Peninsular Florida Planned and
19 Proposed Generating Units.
- 20 KJS-20. Summary of Peninsular Florida Capacity, Demand, and
21 Reserve Margin at Time of Summer Peak, Without and
22 With Osprey Energy Center.
- 23 KJS-21. Summary of Peninsular Florida Capacity, Demand, and
24 Reserve Margin at Time of Winter Peak, Without and
25 With Osprey Energy Center.

DIRECT TESTIMONY OF KENNETH J. SLATER

1 KJS-22. Peninsular Florida Utilities' Identified But
2 Uncommitted Capacity Needs, 2003-2009.

3 KJS-23. Peninsular Florida, Emissions Impacts of Osprey
4 Energy Center, 2003-2012.

5 I am also sponsoring the projected annual output values
6 in Table 2 of the Exhibits in support of Calpine's petition
7 for determination of need for the Osprey Energy Center filed
8 on June 19, 2000 and Tables 4, 5, 6, 7, 8, 9, 10, 11, 12, 13,
9 14.A, 14.B, 15, 16.A, 16.B, 17, 18, 19.A, 19.B, and 19.C of
10 those Exhibits. I am also sponsoring the text associated with
11 these tables in the Exhibits to the petition for determination
12 of need for the Osprey Project, and Appendix C to the
13 Exhibits, which is titled DESCRIPTION of PROMOD IV® GENERATION
14 MODELING PROGRAM.

15
16 MODELS, ASSUMPTIONS, AND METHODOLOGY

17 Q: How did you analyze the operations of the Osprey Project
18 within the Peninsular Florida power supply system and the
19 impacts of the Project on that system?

20 A: Under my direction and supervision, Slater Consulting prepared
21 several analyses of the Peninsular Florida power supply
22 system, both with and without the Osprey Project, using the
23 PROMOD IV® computer modeling program. Our analyses treated
24 the Peninsular Florida power supply system as an integrated

DIRECT TESTIMONY OF KENNETH J. SLATER

1 system. Our analyses studied the period beginning with the
2 first year that the Osprey Project is expected to be in
3 service and continued for ten years. Thus, our analyses begin
4 with the Osprey Project coming into commercial service in 2003
5 and continue through 2012. I should note that our analyses
6 actually covered the period through 2014 in order to avoid
7 certain artificial results that may occur in power system
8 modeling when the system is modeled as effectively "shutting
9 down" at the end of the analysis period. (This can occur
10 because if the model is programmed not to have to serve load
11 after a certain date, it will simply postpone maintenance.)

12 The analyses that we performed included a base case and
13 three sensitivity cases, one with a higher natural gas price
14 forecast, one with a lower load growth forecast, and one with
15 a higher load growth forecast.

16
17 **Q: Please briefly describe the PROMOD IV® computer model,**
18 **including a summary of the main input variables used by the**
19 **model and the main output data produced by the model.**

20 **A: PROMOD IV® is a widely known and widely used model that**
21 **simulates the operations of electric power systems. PROMOD**
22 **IV® is primarily used as a production costing model and can**
23 **also be used to evaluate electric system reliability. A brief**
24 **description of PROMOD IV® is included in Appendix C to the**

DIRECT TESTIMONY OF KENNETH J. SLATER

1 Exhibits accompanying Calpine's petition. PROMOD IV® can be
2 used to prepare utility fuel budget forecasts, evaluate the
3 economics and operations of proposed generating capacity
4 additions, project utility operating costs, estimate the
5 prices of firm power and energy in defined markets, project
6 hourly marginal energy costs, and calculate avoided energy
7 costs.

8 The inputs to PROMOD IV® include generating unit data for
9 existing and planned power plants in a defined power supply
10 system, fuel consumption and fuel cost data, load and other
11 utility system data, and data regarding transactions both
12 within and external to the system. The primary outputs are
13 individual utility or system production costs, generation by
14 unit, fuel usage, and reliability information. PROMOD IV®
15 utilizes computationally efficient algorithms that yield
16 results identical to those that would be produced with direct
17 specification of values for all availability states of all
18 units in a power supply system.

19
20 **Q: Who uses the PROMOD IV® model?**

21 **A:** A significant number of electric utility companies in North
22 America have used and continue to use PROMOD IV®. To the best
23 of my knowledge, all four of the major investor-owned
24 utilities in Florida, as well as some of the larger municipal

DIRECT TESTIMONY OF KENNETH J. SLATER

1 and co-operative utilities in Florida, have used PROMOD IV®.

2

3 **Q: Before leading us through your detailed results, could you**
4 **summarize the cost structure and performance you have assumed**
5 **for the Osprey Energy Center?**

6 **A:** I have assumed that the heat rate of the Osprey Energy Center
7 Project will be 6,800 Btu per kilowatt-hour ("kWh") at full
8 load. I assumed that the variable operating and maintenance
9 cost of the Osprey Energy Center Project will be \$1.85 per
10 megawatt-hour ("MWH") in 2000, escalating at 3.0 percent per
11 year. I should add that I also made the conservative
12 assumption that the Osprey Project would have exactly the same
13 heat rate characteristics as all of the other similar
14 technology, new gas-fired combined cycle units planned for
15 Florida except FPL's proposed repowering projects at Sanford
16 and Ft. Myers. I made this assumption in order to avoid
17 "favoring" the Osprey Project in our dispatch modeling,
18 despite the fact that the available evidence indicates that
19 the Osprey Project would in fact be slightly more cost-
20 effective than nearly all of the other planned gas-fired
21 combined cycle units. For FPL's proposed repowering projects,
22 I used heat rate information extracted from FPL's permit
23 applications to the Florida Department of Environmental
24 Protection; these data indicate that, as one would expect, the

DIRECT TESTIMONY OF KENNETH J. SLATER

1 repowering projects are somewhat less efficient than the other
2 new, "greenfield" plants. For example, our analyses indicate
3 that, on an "as-dispatched" basis, FPL's repowering projects
4 will have heat rates of approximately 7,150 to 7,280 Btu/kWh,
5 as compared to heat rates of approximately 6,970 to 7,040
6 Btu/kWh for the new combined cycle units, e.g., the Osprey
7 Project, Cane Island 3, Okeechobee, Payne Creek, Hines 2, Duke
8 New Smyrna Beach, and Purdom. This information is shown in
9 Exhibits _____ and _____ (KJS-3 and KJS-4).

10

11 **Q: Did your analyses include the possibility of the Osprey**
12 **Project's having increased output capability from duct-firing**
13 **and power augmentation?**

14 **A: No. Our modeling analyses were conducted assuming no output**
15 **from duct-firing or power augmentation. If included in the**
16 **Project's final design configuration, these features would**
17 **increase the Project's output during peak conditions and**
18 **further enhance the reliability of the Peninsular Florida**
19 **power supply system.**

20

21 **Q: Did you model the Osprey Project as an additional unit, i.e.,**
22 **a unit that was assumed to be brought into service in addition**
23 **to all other power plants planned for Peninsular Florida, or**
24 **did you assume that the Osprey Project would displace another**

DIRECT TESTIMONY OF KENNETH J. SLATER

1 unit or units that might otherwise have been built by Florida
2 retail-serving utilities or other entities?

3 A: I modeled the Osprey Project as an additional unit, that is,
4 as one that was incorporated into the Peninsular Florida power
5 supply system in addition to all other existing and planned
6 units. The planned units were identified through my review of
7 all of the ten-year site plans that were submitted to the
8 Florida Public Service Commission this year.

9
10 Q: Why did you model the Osprey Project in this manner?

11 A: I modeled the Osprey Project in this way because it will give
12 the most conservative results regarding the cost savings
13 impacts, the fuel savings impacts, and the emissions impacts
14 of the Project. This is a conservative assumption because it
15 models the impacts of the Osprey Project within a more
16 efficient system.

17
18 Q: How would the Osprey Project affect power supply costs if it
19 were developed as a "displacement" unit instead of as an
20 "additional" unit?

21 A: The Osprey Project's actual impact on power supply costs would
22 depend on the precise terms of the contract or contracts that
23 Calpine entered into with the utilities whose units were
24 displaced by the Project. However, if one were to model the

DIRECT TESTIMONY OF KENNETH J. SLATER

1 Project's impact on Peninsular Florida power supply costs
2 treating the system as an integrated whole, the Osprey Project
3 would show greater fuel savings, cost savings, and emissions
4 reductions than in the analyses that we performed treating the
5 Project as an "additional" unit. This is because in the
6 "displacement" case, there is less new, efficient gas-fired
7 combined cycle capacity (like the Osprey Project) in the
8 Peninsular Florida system, and thus the Project would be
9 operating within a system which was, overall, less efficient
10 and more costly to run, which would result directly in its
11 providing greater fuel savings and power supply cost
12 reductions.

13
14 **Q: What, if any, documents did you review in preparing your**
15 **analyses?**

16 **A: We reviewed the 1999 Regional Load & Resource Plan published**
17 **in July 1999 by the Florida Reliability Coordinating Council**
18 **(the "FRCC 1999 Resource Plan") and all ten-year site plans**
19 **submitted to the Commission in the spring of 2000.**

20
21 **Q: What assumptions did you make regarding future fuel prices**
22 **over the period that you analyzed?**

23 **A: In developing the fuel price projections for our analyses, we**
24 **examined historical Florida-specific fuel costs for**

DIRECT TESTIMONY OF KENNETH J. SLATER

1 electricity generation and evaluated the major publicly
2 available fuel price forecasts, which are presented in the
3 Energy Information Administration's ("EIA") Annual Energy
4 Outlook 2000 publication. Our base case fuel price
5 projections were based primarily on the forecasts prepared by
6 EIA but with the gas price projections following those of
7 Resource Data International, Inc. ("RDI"). For the higher gas
8 price sensitivity case, we assumed the EIA projections (the
9 EIA's "reference case") for all fuels. Exhibit _____ (KJS-2)
10 shows the projected fuel prices for both our base case
11 analysis and for the higher natural gas price sensitivity
12 case.

13
14 **Q: What assumptions did you make regarding the electric power**
15 **plants that would be available to serve Peninsular Florida?**

16 **A:** Our assumptions regarding available power plants to provide
17 capacity and energy to Peninsular Florida are summarized in
18 Exhibits _____ and _____ (KJS-3 and KJS-4), which present the
19 projected Peninsular Florida generating fleet for 2003 and
20 2008, respectively. For reference, Exhibit _____ (KJS-5)
21 presents a summary of existing capacity as of January 1, 2000.
22 These data were obtained from the FRCC 1999 Resource Plan and
23 from the ten-year site plans filed with the Commission by
24 Florida utilities in the spring of 2000.

DIRECT TESTIMONY OF KENNETH J. SLATER

1 Q: What assumptions did you make regarding the growth rates of
2 summer and winter peak demands and energy consumption in
3 Peninsular Florida?

4 A: Exhibit _____ (KJS-6) presents the historical and projected
5 summer and winter firm peak demands for Peninsular Florida.
6 Exhibit _____ (KJS-7) presents the historical and projected
7 net energy for load, number of customers, and load factor for
8 Peninsular Florida. For the base case, the load forecast was
9 developed on a company-by-company basis from the 2000 ten-year
10 site plans. Some adjustments were necessary to account for
11 loads which were included in more than one site plan, for one
12 system which does not file a site plan, and for some
13 overstatement of load management impact. We reconciled our
14 company-by-company forecasts with the FRCC 1999 Resource Plan
15 in order to achieve accuracy and completeness.

16

17 Q: What assumptions did you make regarding imports of electric
18 power from outside Peninsular Florida and exports of power
19 from Peninsular Florida to other regions?

20 A: We assumed that imports into Peninsular Florida would be as
21 projected in the FRCC 1999 Resource Plan. We assumed that
22 there would be no significant exports of power from Peninsular
23 Florida to other regions.

24

DIRECT TESTIMONY OF KENNETH J. SLATER

1 **Q: What assumptions did you make regarding the effects of energy**
2 **conservation and demand-side management programs?**

3 **A: We generally assumed that the forecasts of peak demands and**
4 **net energy for load presented in the FRCC 1999 Resource Plan**
5 **and the 2000 ten-year site plans reflected the achievement of**
6 **the Florida retail-serving utilities' Commission-approved**
7 **energy conservation goals. There was one exception to this**
8 **assumption, however: the FRCC projections and some of the site**
9 **plans assume that net energy for load (total energy**
10 **consumption) will reflect maximum possible reductions from**
11 **interruptible, load management, and other energy conservation**
12 **measures and programs. In my opinion, this systematically**
13 **understates total energy consumption because it assumes far**
14 **greater reductions in energy use from interruptible and load**
15 **management customers than are actually realized. Accordingly,**
16 **we adjusted the net energy for load projections upward to**
17 **reflect more realistic energy consumption levels where**
18 **necessary.**

19

20 **Q: How was transmission modeled or treated in your analyses?**

21 **A: We modeled Peninsular Florida as an integrated power supply**
22 **system, with all generation resources available to serve all**
23 **loads. Transmission was assumed to be costless for all**
24 **transactions, such that the most efficient generation**

DIRECT TESTIMONY OF KENNETH J. SLATER

1 resources would be dispatched to serve the Peninsular Florida
2 load, without regard to transmission constraints or tariffs.

3
4 **Q: Do you consider this to be a realistic assumption?**

5 **A: Yes. Because it is not known what transmission augmentations**
6 **will be carried out in the FRCC region in the next twelve**
7 **years, it is best to make an assumption which would not favor**
8 **the Osprey Project over any other new project or over existing**
9 **generation. We made such an assumption.**

10

11 **Q: What, if any, effect would altering this assumption have on**
12 **your analyses of the operations of the Osprey Energy Center?**

13 **A: Altering this assumption would likely have very little effect**
14 **on the actual dispatch of the Osprey Project.**

15

16 **Q: Did you review any documents that you understood to be**
17 **confidential or proprietary to Calpine?**

18 **A: No.**

19

20 **Q: Do you consider any of your input or output data to be**
21 **confidential, proprietary business information from Slater**
22 **Consulting's perspective?**

23 **A: Yes. Our compilation of the generating units and their**
24 **dispatch characteristics, and to some extent the load forecast**

DIRECT TESTIMONY OF KENNETH J. SLATER

1 data, are the intellectual work product of Slater Consulting,
2 developed through significant and substantial effort. We
3 consider this to be confidential, proprietary business
4 information, but we are, of course, willing to disclose it
5 pursuant to appropriate confidentiality protections.

6
7 **OPERATIONS OF THE OSPREY ENERGY CENTER**

8 **Q: What does your base case analysis show regarding the projected**
9 **operations of the Osprey Energy Center?**

10 **A: For the base case, our analyses show that the Osprey Energy**
11 **Center will generally produce between 4,000 and 4,400**
12 **gigawatt-hours ("GWH") annually, indicating annual capacity**
13 **factors between 86 and 93 percent, for the 2003-2012 analysis**
14 **period. Exhibit ____ (KJS-8) shows the projected annual**
15 **energy production from the Osprey Project and the annual**
16 **capacity factors based on the indicated output amounts.**

17 Our analyses also indicate that, in peak demand periods,
18 the Project will make sales equal to the Project's full rated
19 capacity, subject only to outages.

20
21 **Q: What do your analyses show regarding the projected operations**
22 **of the Osprey Project if natural gas prices are higher than**
23 **your base case forecast?**

24 **A: Exhibit _____ (KJS-9) displays the results of this**

DIRECT TESTIMONY OF KENNETH J. SLATER

1 sensitivity analysis, and shows that the Osprey Project will
2 produce between 3,900 and 4,400 GWH annually in this case.
3 That is, it will operate at annual capacity factors between 83
4 and 92 percent.

5
6 **Q: What do your analyses show regarding the projected operations**
7 **of the Osprey Project if Peninsular Florida's load growth is**
8 **higher or lower than in your base case?**

9 **A: Exhibit _____ (KJS-10) shows that load growth will have**
10 **virtually no impact on the operations of the Osprey Project.**

11
12 **Q: What, if any, impacts will the Osprey Project's operation have**
13 **on other power plants in Peninsular Florida?**

14 **A: Generally, the Project will cause less efficient and more**
15 **costly plants to operate at lower output levels. Exhibit**
16 **_____ (KJS-11) shows the modeled impacts of the Osprey**
17 **Project's operations on other units supplying Peninsular**
18 **Florida during two representative days in 2005, one a June**
19 **weekday and one a December weekday. Of course, the actual**
20 **impacts would depend on the actual availability status of all**
21 **units in Peninsular Florida on any given day.**

22
23 **Q: In your opinion, even if the Osprey Project were developed as**
24 **a "merchant" plant, would the Osprey Project make any**

DIRECT TESTIMONY OF KENNETH J. SLATER

1 significant amount of power sales outside Peninsular Florida?

2 A: No. Based on my general knowledge of the Florida and
3 Southeastern Electric Reliability Council ("SERC") markets,
4 including both existing and planned generating capacity for
5 both, and the transmission systems in both markets, I believe
6 that, even if the Osprey Project were not specifically
7 contracted to serve Florida retail-serving utilities, it would
8 be highly unlikely that the Project would make any significant
9 amount of sales outside Peninsular Florida. This is generally
10 because Florida's generation resources are high-cost.

11

12 Q: Are you aware of other evidence that supports your opinion
13 that the Osprey Project will not make significant sales of
14 power outside Peninsular Florida?

15 A: Yes, I am. The PowerDAT data base maintained by Resource Data
16 International, Inc. and reported on a regular basis in Public
17 Utilities Fortnightly shows that the average generation cost
18 (defined as fuel cost plus reported non-fuel operating and
19 maintenance cost) in the FRCC region, i.e., Peninsular
20 Florida, was the highest of all of the reliability regions in
21 the United States for 1997, 1998, and 1999. Exhibit _____
22 (KJS-12) shows that for 1999, the FRCC region's average
23 generating cost was 2.59 cents per kWh, which equals \$25.90
24 per MWh. The region with the next highest cost was the

DIRECT TESTIMONY OF KENNETH J. SLATER

1 Electric Reliability Council of Texas ("ERCOT"), with an
2 average cost of \$24.10 per MWH. The average cost for
3 electricity generation in Florida's nearest neighbor regions
4 was significantly less than in the FRCC region: the average
5 cost for the SERC region was \$17.60, approximately 32 percent
6 less than in FRCC, the average cost for the Southwestern Power
7 Pool ("SPP") region was \$21.10 per MWH, approximately 19
8 percent less than in FRCC, and the average cost for the East
9 Central America Reliability ("ECAR") was \$21.20 per MWH,
10 approximately 18 percent less than in FRCC.

11 In addition, I am aware from reading the power generation
12 trade press that there are significant amounts of new,
13 efficient, relatively low-cost capacity being installed in
14 SERC, ECAR, and other regions. The addition of this new
15 capacity will further reduce the economic viability of power
16 exports from Florida to other regions.

17

18 **FUEL CONSUMPTION IMPACTS OF THE OSPREY ENERGY CENTER**

19 **Q: What, if any, effects will the Osprey Project have on the**
20 **total consumption of primary fuels used to generate the**
21 **electric power supply for Peninsular Florida?**

22 **A: Exhibit _____ (KJS-13) shows the estimated impacts of the**
23 **Osprey Project's operations on total primary energy**
24 **consumption for generating Peninsular Florida's electricity**

DIRECT TESTIMONY OF KENNETH J. SLATER

1 supply for each year from 2003 through 2012. Our modeling
2 analyses show that the Osprey Project can be expected to
3 reduce total fuel consumption by roughly 6 trillion Btu per
4 year to 9 trillion Btu per year over the analysis period.
5 This is a tremendous amount of energy: 6 trillion Btu is
6 approximately the amount of energy in 6 million Mcf
7 (equivalent to 6 billion cubic feet) of natural gas, or the
8 amount of energy in 1 million barrels of residual fuel oil.

9
10 **Q: What effects will the Osprey Project have on the specific**
11 **fuels used to generate the electric power supply for**
12 **Peninsular Florida?**

13 **A: Exhibit _____ (KJS-14) shows the impacts of the Osprey**
14 **Project's operations on the total use of natural gas, No. 6**
15 **(residual) fuel oil, No. 2 fuel oil, nuclear, and coal and**
16 **other solid fuels to generate Peninsular Florida's electricity**
17 **supply for the 2003-2012 analysis period. Page 1 of 2 of**
18 **this exhibit shows the impact on fuel use in millions of Btu,**
19 **and page 2 of 2 of the exhibit shows the impact in terms of**
20 **gigawatt-hours (i.e., thousands of megawatt-hours) generated**
21 **using each fuel type. Generally, the Project results in**
22 **significant decreases in the use of coal and No. 6 oil, with**
23 **a corresponding increase in natural gas use. The Project's**
24 **specific impacts are also illustrated in Exhibit _____**

DIRECT TESTIMONY OF KENNETH J. SLATER

1 (KJS-11), which shows the expected impacts of the Osprey
2 Project's operations on the operations of other units in
3 Peninsular Florida during representative days.

4
5 **Q: It is relatively easy to understand how the Osprey Project,**
6 **with its relatively low heat rate, would reduce the use of gas**
7 **or oil used in less efficient power plants. Can you explain,**
8 **however, how the Osprey Project would displace generation from**
9 **coal-fired power plants?**

10 **A: Of course. Certain coal plants, while they have relatively**
11 **low fuel costs, also have relatively high non-fuel operating**
12 **and maintenance ("O&M") costs. Because dispatch decisions are**
13 **based on total variable costs, in some instances, the sum of**
14 **the Osprey Project's incremental fuel and non-fuel variable**
15 **O&M cost (and the corresponding costs for the other planned**
16 **gas-fired combined cycle units as well) will be less than the**
17 **sum of those costs for coal units. This results in the**
18 **economic dispatch decision being to operate the Osprey Project**
19 **at higher output levels and the relatively higher-cost coal**
20 **units at lower levels.**

21
22 **Q: Please summarize the impact of the Osprey Project's operations**
23 **on the consumption of petroleum fuels for electricity**
24 **generation for Peninsular Florida?**

DIRECT TESTIMONY OF KENNETH J. SLATER

1 A: The Osprey Project's operations will result in significant
2 reductions in the use of petroleum fuels for electricity
3 generation for Peninsular Florida. For example, Exhibit _____
4 (KJS-14) shows savings of approximately 13,122 billion Btu of
5 No. 6 oil and another 518 billion Btu of No. 2 oil in 2004.
6 This translates to a total savings of petroleum fuels of 13.6
7 trillion Btu, or approximately 2.2 million barrels for 2004.

8

9 Q: Will the Osprey Project have any effect on the overall
10 efficiency of natural gas use in Florida?

11 A: Yes. The Osprey Project will increase the overall efficiency
12 of natural gas use in Florida. This will occur as the Osprey
13 Project, with its heat rate of approximately 6,970 Btu/kWh (as
14 dispatched), is dispatched economically in preference to other
15 gas-fired units with less efficient heat rates, e.g., the
16 numerous gas-fired steam units in Florida that have heat rates
17 in the range of 10,000 to 11,000 Btu/kWh.

18

19 Q: What, if any, effect will the Osprey Project have on the
20 overall efficiency of electricity generation for Peninsular
21 Florida?

22 A: The Osprey Project will significantly increase the overall
23 efficiency of electricity generation for Peninsular Florida.
24 Exhibit _____ (KJS-13) shows not only that the Project will

DIRECT TESTIMONY OF KENNETH J. SLATER

1 result in overall savings of 6 trillion to 9 trillion Btu per
2 year for electricity generation, but that the Project will
3 also reduce the average heat rate for Peninsular Florida
4 electricity generation by 24 to 44 Btu per kilowatt-hour, a
5 reduction on the order of 0.4 percent. This is a significant
6 improvement in the overall efficiency of producing
7 approximately 200,000,000 MWH of electricity per year for the
8 fourth largest state in the nation.

9
10 **Q: Why will the Osprey Project have these effects?**

11 **A:** The Osprey Project will have these fuel and energy savings
12 effects because it is significantly more efficient and cost-
13 effective than the vast majority of electric generating plants
14 that currently exist in Peninsular Florida and at least as
15 efficient as virtually all of the new capacity that is planned
16 for Peninsular Florida. Exhibit _____ (KJS-3) shows the
17 estimated dispatch costs and heat rates (as assumed in our
18 PROMOD IV® modeling) for all of the power plants that are
19 expected to be serving Peninsular Florida in 2003. The Osprey
20 Project's dispatch cost of \$28.09 per MWH is lower than the
21 dispatch costs of approximately 34,000 MW of the total
22 capacity of approximately 47,000 MW (including 3,877 MW of
23 nuclear capacity operated as "must run" generation) that is
24 projected to be available to serve Peninsular Florida in that

DIRECT TESTIMONY OF KENNETH J. SLATER

1 year. In addition, the Osprey Project's heat rate of 6,967
2 Btu per kWh is more efficient than virtually all of the
3 generating capacity that is projected to be available to serve
4 Peninsular Florida in that year. Similarly, Exhibit _____
5 (KJS-4) shows the estimated dispatch costs and heat rates for
6 all of the power plants that are expected to be serving
7 Peninsular Florida in 2008. The Osprey Project's dispatch
8 cost of \$32.57 per MWH is lower than the dispatch costs of
9 approximately 38,000 MW of the total of approximately 51,000
10 MW (again including 3,877 MW of nuclear as "must run") that is
11 projected to be available to serve Peninsular Florida in that
12 year. In addition, the Osprey Project's as-dispatched heat
13 rate of 6,984 Btu per kWh is more efficient than virtually all
14 of the generating capacity that is projected to be available
15 to serve Peninsular Florida in that year.

16
17 **Q: Will there be any adverse effect on primary fuel consumption**
18 **and the efficiency of electricity generation for Peninsular**
19 **Florida if the Osprey Project is not brought into service as**
20 **requested by Calpine in this proceeding?**

21 **A: Yes. If the Osprey Project is either delayed or not brought**
22 **into operation at all, Florida will lose the primary fuel**
23 **savings benefits that the Project will provide. As shown**
24 **above, these primary fuel savings are quite significant -- on**

DIRECT TESTIMONY OF KENNETH J. SLATER

1 the order of 6 trillion to 9 trillion Btu per year for each
2 year of the Project's operation.

3
4 **COST-EFFECTIVENESS OF THE OSPREY ENERGY CENTER**

5 **Q: Did your analyses address the cost-effectiveness of the Osprey**
6 **Project as an additional power supply resource in the**
7 **Peninsular Florida power supply system?**

8 **A: Yes.** Our analyses addressed the Project's cost-effectiveness
9 by evaluating the impact that it would have as an incremental
10 power supply resource added into the Peninsular Florida power
11 supply system in addition to all other planned additions, as
12 indicated by the ten-year site plans filed with the Commission
13 this year. Basically, our analyses modeled the total power
14 supply costs for serving Peninsular Florida without the Osprey
15 Project and with the Project. The difference in costs
16 represents the cost savings properly attributable to the
17 Osprey Project.

18
19 **Q: And what did your analyses show?**

20 **A: Our "base case" analyses and our sensitivity analyses showed**
21 **that the Osprey Project will provide significant power supply**
22 **cost savings to Peninsular Florida. Exhibit _____ (KJS-15)**
23 **shows that for the base case, the Project would result in**
24 **power supply cost savings between \$113 million and \$204**

DIRECT TESTIMONY OF KENNETH J. SLATER

1 million per year (in nominal terms), with projected total
2 savings of \$794 million in Net Present Value terms over the
3 Project's first ten years of operations (2003-2012).

4 For the higher natural gas price sensitivity case,
5 Exhibit _____ (KJS-16) shows that the Project will provide
6 power supply cost savings between \$115 million and \$218
7 million per year (in nominal terms), with projected total
8 savings of \$806 million in Net Present Value terms over the
9 Project's first ten years of operations (2003-2012).

10 For the low load growth sensitivity case, Exhibit _____
11 (KJS-17) shows that the Project will provide power supply cost
12 savings between \$47 million and \$219 million per year (in
13 nominal terms), with projected total savings of \$627 million
14 in Net Present Value terms over the Project's first ten years
15 of operations (2003-2012).

16 For the high load growth sensitivity case, Exhibit _____
17 (KJS-18) shows that the Project will provide power supply cost
18 savings between \$88 million and \$410 million per year (in
19 nominal terms), with projected total savings of \$1.12 billion
20 in Net Present Value terms over the Project's first ten years
21 of operations (2003-2012).

22

DIRECT TESTIMONY OF KENNETH J. SLATER

1 Q: How do these total cost savings translate into reductions in
2 the estimated wholesale cost of power for Peninsular Florida?

3 A: Exhibit _____ (KJS-15) shows that for the base case, the
4 estimated reduction in the average wholesale cost of power for
5 Peninsular Florida is approximately \$0.54 to \$0.84 per MWH
6 over the 2003-2012 study period. Exhibit _____ (KJS-16)
7 shows that the impact of the Osprey Project in the higher
8 natural gas price scenario is approximately \$0.55 to \$0.88 per
9 MWH over the study period. Exhibit _____ (KJS-17) shows that
10 for the low load growth scenario, the impact of the Osprey
11 Project would be a reduction in average power supply costs of
12 approximately \$0.23 to \$0.94 per MWH, and that for the high
13 load growth scenario, the impact of the Osprey Project would
14 be a reduction in average power supply costs of approximately
15 \$0.41 to \$1.47 per MWH.

16
17 Q: Will the Osprey Project be the most cost-effective alternative
18 available to serve Peninsular Florida's needs for cost-
19 effective, reliable power?

20 A: In my opinion, yes. The Osprey Project has a favorable heat
21 rate and favorable direct construction costs, as reported by
22 Calpine, when compared to other generating units that are
23 planned or proposed for Peninsular Florida. Combining these
24 factors with the fact that the Project will not be included in

DIRECT TESTIMONY OF KENNETH J. SLATER

1 any retail-serving utility's rate base, but rather the
2 Project's output will only be purchased for resale to retail-
3 serving utilities' customers when such purchases are cost-
4 effective, it is obvious that it is the most cost-effective
5 alternative available. Exhibit _____ (KJS-19) lists planned
6 and proposed generating units for Peninsular Florida. Among
7 the gas-fired combined cycle units, the Osprey Project
8 compares quite favorably: only the Cane Island 3, Duke New
9 Smyrna Beach, and Okeechobee units have comparable heat rates
10 and lower construction costs. Most of the proposed combined
11 cycle capacity, e.g., FPL's repowering units and its proposed
12 unsited units, have significantly higher direct construction
13 costs.

14
15 **Q: What, if anything, could prevent the Osprey Project from being**
16 **a cost-effective power supply resource in the Peninsular**
17 **Florida region?**

18 **A: Only highly unlikely developments, such as the total failure**
19 **of the Project to become operational or a technological change**
20 **so dramatic as to make all of the existing and planned**
21 **Peninsular Florida generating capacity obsolete, could cause**
22 **the Osprey Project not to be cost-effective.**

23

DIRECT TESTIMONY OF KENNETH J. SLATER

1 Q: How does the Osprey Project compare to other existing and
2 planned Peninsular Florida power plants in terms of its
3 projected operating costs?

4 A: In terms of its operating costs, the Osprey Project compares
5 quite favorably to all existing generating plants in
6 Peninsular Florida except those fueled by nuclear fuel and
7 some of those fueled by coal. Referring back to Exhibit
8 _____ (KJS-3), the Commission will see that the Osprey
9 Project is more cost-effective, in terms of its dispatch
10 costs, than approximately 34,000 MW out of the total of 47,000
11 MW (including nuclear as "must run") available to serve
12 Peninsular Florida in 2003. Similarly, Exhibit _____ (KJS-4)
13 shows that the Project is more cost-effective than
14 approximately 38,000 MW of the total of approximately 51,000
15 MW (including nuclear as "must run") of capacity that is
16 projected to be available to serve Peninsular Florida in 2008.
17 As noted above, the Project also compares favorably to other
18 planned and proposed gas-fired combined cycle units.

19 I should add that in our modeling, we intentionally
20 assumed identical heat rate characteristics for all of the new
21 gas-fired combined cycle capacity. We did so in order to be
22 conservative with respect to the Osprey Project's impacts and
23 operations.

24

DIRECT TESTIMONY OF KENNETH J. SLATER

1 Q: One of the criteria that the Commission must consider in a
2 need determination proceeding is whether the proposed power
3 plant will contribute to meeting the need for adequate
4 electricity at a reasonable cost. As you understand this
5 term, will the Osprey Project contribute to meeting Florida's
6 need for adequate electricity at a reasonable cost?

7 A: Yes. In the simplest terms, the Osprey Project is available
8 to Peninsular Florida, and our PROMOD IV® modeling analyses
9 show that it will save between \$627 million and \$1.12 billion
10 in power supply costs for Peninsular Florida in the first ten
11 years of its life, depending on variations in fuel prices and
12 load growth rates. Clearly, if Florida can obtain its needed
13 power supply at savings between half a billion and more than
14 one billion dollars, it would only be reasonable to take
15 advantage of the opportunity. Given the availability of these
16 savings, paying the extra half billion dollars or more would
17 represent paying an unreasonable amount for needed power.

18

19 Q: Will the Project have any effect on potential "price spikes"
20 for wholesale power in Peninsular Florida?

21 A: Yes, the Project can be expected to suppress and reduce the
22 magnitude of prices in basically all hours when the Project is
23 available to serve. (The Project would be expected to be
24 available to serve continuously during all summer and winter

DIRECT TESTIMONY OF KENNETH J. SLATER

1 peak periods, except for unplanned or forced outages.) While
2 our modeling analyses did not address extreme peak conditions,
3 it is obvious that the Project's presence would suppress
4 prices in any extremely tight supply conditions that might be
5 experienced in Peninsular Florida.

6
7 **Q: What, if any, value would the Project have with respect to**
8 **other services? For example, would the Project suppress the**
9 **price of ancillary services in Peninsular Florida?**

10 **A: Generally, the Project will also suppress the cost or price of**
11 **other services, including ancillary services. (Ancillary**
12 **services are defined by the Federal Energy Regulatory**
13 **Commission as (a) Scheduling, System Control and Dispatch**
14 **Service; (b) Reactive Supply and Voltage Control from**
15 **Generation Sources Service; (c) Regulation and Frequency**
16 **Response Service; (d) Energy Imbalance Service; (e) Operating**
17 **Reserve - Spinning Reserve Service; and (f) Operating Reserve**
18 **Supplemental Reserve Service.) While our PROMOD IV® analyses**
19 **only addressed the Osprey Project's value in supplying energy**
20 **and did not include any analyses of the Project's impact on**
21 **the prices of ancillary services, from my experience I can say**
22 **that the Project's presence will suppress the prices of**
23 **ancillary services in Peninsular Florida, especially the**
24 **prices of the various types of reserve services. These**

DIRECT TESTIMONY OF KENNETH J. SLATER

1 effects are likely to be quite significant in Florida once the
2 transmission function is transferred to some form of regional
3 transmission organization that would have the responsibility
4 for procuring ancillary services in the market.

5
6 **Q: Do your analyses take account of the value of economic**
7 **production (e.g., fertilizer, chemicals, services, food**
8 **products, and so on) that could, and presumably would, be**
9 **realized by commercial enterprises in Florida if they were**
10 **able to stay in operation as a result of the Project's**
11 **presence and operation?**

12 **A: No. Our analyses address only the direct impacts on power**
13 **supply costs. The value of maintaining electric service is**
14 **generally significantly greater than the cost of providing**
15 **incremental energy, even in instances where power supplies are**
16 **tight and incremental power is available only at extremely**
17 **high prices, for example, \$1,000 or more per MWH. In my**
18 **experience, the value of "lost production" is frequently**
19 **several times that amount.**

20
21 **Q: What, if anything, do your analyses of the Osprey Energy**
22 **Center's operations show regarding the need for the Project?**

23 **A: Our analyses show that the Project will meet significant need**
24 **in Peninsular Florida for cost-effective power, even if the**

DIRECT TESTIMONY OF KENNETH J. SLATER

1 Project is added onto the projected Peninsular Florida
2 generating fleet in addition to all other planned resources.
3 This is demonstrated by the significant, even dramatic, power
4 supply cost reductions that the Osprey Project will provide.

5 Again, as I indicated above, these analyses provide the
6 most conservative estimate of the Project's contributions to
7 Peninsular Florida, because they model the Project's
8 operations against the backdrop of the greatest amount of new
9 efficient generation in the area. If, pursuant to contracts
10 between Calpine and Peninsular Florida utilities with retail
11 load-serving responsibility, the Osprey Project is constructed
12 instead of another projected unit, it will provide even
13 greater total benefits in terms of reduced power supply costs.

14
15 **Q: Based on your analyses, and in your opinion, will there be any**
16 **adverse effects on total power supply costs for Peninsular**
17 **Florida if the Osprey Project is not brought into service as**
18 **requested by Calpine?**

19 **A: Yes.** Our analyses demonstrate quite clearly that the Project
20 will provide significant, even dramatic, benefits to
21 Peninsular Florida if and when it is brought into service as
22 proposed by Calpine. With respect to power supply costs, if
23 the Project were not brought into service as proposed by
24 Calpine, Florida would lose these benefits, specifically the

DIRECT TESTIMONY OF KENNETH J. SLATER

1 projected cost savings of about \$800 million (Net Present
2 Value) over the Project's first ten years of operation.
3 Losing these benefits would be a significant adverse effect of
4 the Project's not being brought into service as requested by
5 Calpine. Similarly, delaying the Project's commercial
6 operation will cost Florida amounts on the order of \$150
7 million annually for each year of delay.

8
9 **RELIABILITY IMPACTS OF THE OSPREY ENERGY CENTER**

10 **Q: How should the Commission evaluate the impact of the Osprey**
11 **Energy Center on the reliability of the power supply system**
12 **for Peninsular Florida?**

13 **A: The Commission should include the Osprey Project in its**
14 **reliability evaluation for Peninsular Florida as a committed**
15 **resource both under the scenario projected by Calpine, wherein**
16 **the Project's output will be sold to Peninsular Florida**
17 **retail-serving utilities, and in the hypothetical scenario**
18 **where the Project were to be operated as a "merchant" plant.**
19 **In the scenario projected here by Calpine, the Project's**
20 **capacity would also be counted toward meeting the reserve**
21 **margins of the utilities having contractual rights to the**
22 **Project's capacity.**

23

DIRECT TESTIMONY OF KENNETH J. SLATER

1 Q: What impact will the Osprey Project have on the reliability of
2 Peninsular Florida's power supply system?

3 A: The Osprey Project will improve Peninsular Florida reliability
4 by increasing Peninsular Florida reserve margins by
5 approximately 1.2 to 1.3 percent in both summer and winter
6 seasons following the Project's achievement of commercial in-
7 service status. For example, Exhibit _____ (KJS-20) shows
8 that in the summer of 2003, the Project will increase
9 Peninsular Florida's reserve margin from 20.1 percent to 21.3
10 percent. Exhibit _____ (KJS-21) shows similar improvement in
11 winter reserve margins. If the Project's output were
12 purchased by a Florida retail-serving utility instead of that
13 utility constructing its own generation, then the Project
14 would be expected to have comparable effects on that utility's
15 and Peninsular Florida's reliability as the utility's
16 "avoided" unit, allowing for adjustments in the relative
17 availability of the Osprey Project and the utility's unit and,
18 if applicable, in the amount purchased as compared to the
19 capacity of the avoided unit.

20
21 Q: From the perspective of statewide, or Peninsular Florida-wide,
22 reliability, does it matter whether the Osprey Project is
23 under contract to any specific utility or utilities?

24 A: No.

DIRECT TESTIMONY OF KENNETH J. SLATER

1 Q: What, if any, impact would the availability of the Osprey
2 Project have on the ability of Peninsular Florida's retail-
3 serving utilities to maintain service to their retail
4 customers during periods when power supply was short relative
5 to demand?

6 A: The Osprey Project will have significant beneficial effects on
7 the ability of Peninsular Florida retail-serving utilities to
8 maintain uninterrupted service to their firm and non-firm
9 customers. This would apply not only during extreme seasonal
10 peak demand conditions, but any time that supply was "tight"
11 relative to demand. Such conditions have occurred in what are
12 typically regarded as "shoulder" months when demand was higher
13 than projected (though far below annual peak levels) but
14 supply was tight due to scheduled maintenance outages and
15 unexpected outages of generating units.

16 In an extreme winter peak event, the Project's capacity
17 of approximately 578 MW would enable Florida's retail-serving
18 utilities to maintain service to between 115,000 and 165,000
19 residential customers, at an average coincident peak demand of
20 3.5 to 5.0 kilowatts per household. Even in less extreme
21 conditions, the Project's capacity would enable Florida
22 retail-serving utilities to maintain service to more of their
23 customers without implementing direct load control measures or
24 without interrupting service to commercial and industrial

DIRECT TESTIMONY OF KENNETH J. SLATER

1 interruptible customers. In an extreme summer event, the
2 Project's summer capacity of 496 MW would enable Florida's
3 retail-serving utilities to maintain service to between 99,000
4 and 142,000 residential customers or equivalent load.

5

6 **Q: In your opinion, would it be accurate to say that Florida has**
7 **a need for the Osprey Project from a reliability perspective?**

8 **A:** Yes. As Calpine has presented its plans for the Osprey
9 Project, one can only conclude that the Project will meet the
10 needs of Florida retail-serving utilities and their customers,
11 that the Project will do so cost-effectively, and that the
12 Project will enhance the reliability of Peninsular Florida's
13 electric power supply system. It is fairly obvious that if
14 there is an opportunity to add a power supply resource that is
15 cost-effective from the perspective of Florida's ratepayers
16 and that will enhance reliability, then there is a need for
17 that resource. The Commission should remember that the
18 concept of "need" exists with respect to relative economics,
19 and not with respect to some exogenously established
20 reliability criterion. This is because the need depends on
21 the cost of additional resources and on the costs incurred if
22 the system fails to maintain service. The Commission's goal,
23 and the utilities' goal, should be to optimize the level of
24 reserves, not merely to satisfy some reserve margin or loss of

DIRECT TESTIMONY OF KENNETH J. SLATER

1 load probability criterion. If a resource will both enhance
2 reliability and do so cost-effectively, then it is needed.

3
4 **Q: At this time, can you say which utility or utilities need the**
5 **Osprey Project's capacity?**

6 **A: No.** However, Exhibit _____ (KJS-22) shows a compilation of
7 units from seven utilities' ten-year site plans for which
8 permits and other commitments do not appear to be in hand.
9 The capacity represented by these units totals approximately
10 8,700 MW. It is at least possible that the Osprey Project
11 could serve part of this identified need. It is, of course,
12 also possible that Florida retail-serving utilities could
13 choose to purchase the Project's capacity and output in
14 addition to their own planned resource additions, thereby
15 resulting in enhanced reliability for their own systems and to
16 the Peninsular Florida system considered as a whole.

17
18 **Q: Will there be any adverse effects on the reliability of the**
19 **Peninsular Florida power supply system if the Osprey Project**
20 **is not brought into service as requested by Calpine?**

21 **A: Yes.** Reserve margins will be less, by a measurable,
22 significant amount, than if the Project is added. More
23 significantly, in practical terms, Peninsular Florida
24 utilities will be unable to serve approximately 500 MW of load

DIRECT TESTIMONY OF KENNETH J. SLATER

1 (up to approximately 660 MW of load with duct-firing and power
2 augmentation) that they could serve if the Project were
3 constructed as sought by Calpine. This means that, in periods
4 when supply is short relative to demand, the equivalent of
5 99,000 to 185,000 homes will not be served, or will have their
6 service interrupted, if the Project is not built. The actual
7 impacts could be felt by residential customers or by
8 industrial and commercial customers who would have to shut
9 down their operations as a result of power supply shortages.
10 The actual amount of load depends on the season and the final
11 configuration of the Project, i.e., whether it is constructed
12 with duct-firing and power augmentation capability.

13
14 **IMPACTS OF THE OSPREY ENERGY CENTER ON ENVIRONMENTAL**
15 **EMISSIONS FROM ELECTRICITY GENERATION**

16 Q: Did you evaluate the impacts of the Osprey Energy Center's
17 operations on the emissions of pollutants that are associated
18 with electricity generation?

19 A: Yes. Our PROMOD IV® analyses evaluate the impacts on total
20 emissions of sulfur dioxide and nitrogen oxides from the
21 operation of the power plants included in our analyses. In
22 this application, we evaluated the emissions of sulfur dioxide
23 and nitrogen oxides in the various cases with and without the
24 Osprey Project included as a power supply resource for
25 Peninsular Florida.

DIRECT TESTIMONY OF KENNETH J. SLATER

1 Q: What are the projected impacts of the Osprey Energy Center on
2 the emissions of sulfur dioxide and nitrogen oxides associated
3 with producing the electric power supply for Peninsular
4 Florida?

5 A: Exhibit _____ (KJS-23) shows that with the Osprey Project in
6 service in our base case scenario, the emissions of sulfur
7 dioxide are approximately 4,600 to 16,000 tons per year less
8 than if the Osprey Project is not in service. Similarly,
9 Exhibit _____ (KJS-23) shows that the Osprey Energy Center's
10 operations are expected to result in reductions of nitrogen
11 oxides emissions of approximately 3,900 to 7,000 tons per
12 year.

13
14 Q: Will there be any adverse effects on Florida's environment if
15 the Osprey Project is not brought into service as requested by
16 Calpine in this proceeding?

17 A: Yes. The combined emissions of sulfur dioxide and nitrogen
18 oxides from producing Peninsular Florida's electricity supply
19 will be more than eight thousand tons greater in each year
20 that the Osprey Project's operation is delayed.

21
22 Q: Does this conclude your direct testimony?

23 A: Yes. It does.

24

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

In Re: Petition for Determination of)
Need for an Electrical Power Plant in)
Polk County by Calpine Construction)
Finance Company, L.P.)

DOCKET NO. 000442-EI

EXHIBITS

OF

KENNETH J. SLATER

ON BEHALF OF

**CALPINE CONSTRUCTION FINANCE
COMPANY, L.P.**

Technical Qualifications
and
Professional Experience

Kenneth John Slater

EDUCATION

B.Sc., Pure Mathematics and Physics, Sydney University, 1960
B.E., Electrical Engineering, Sydney University, 1962
M.A.Sc., Management Sciences, University of Waterloo, 1974

PROFESSIONAL AFFILIATIONS

Association of Professional Engineers of Ontario
- Registered Professional Engineer
Institute of Electrical and Electronic Engineers
- Member of Power Engineering Society
- Past member of Power System Engineering Committee
- Past member of System Economics subcommittee and working group

EXPERIENCE

1957-62 Mr. Slater was a Junior Professional Officer at the Electricity Commission of New South Wales attending university and undergoing on-the-job training in power station and substation design, construction, protection, maintenance, and operation.

1962-67 Mr. Slater was a Professional Engineer Grades 1 and 2 at The Electricity Commission of New South Wales, engaged in a variety of functions within the areas of Power Station Construction, Generation Planning, System Operation and Load Dispatch.

1967-69 As Assistant Engineer Area Operations/Sydney West (Professional Engineer, Grade 3) with the Electricity Commission of New South Wales, Mr. Slater was responsible for the day-to-day operation of the Sydney West Area (approximately 20% of the State System).

He supervised the day-to-day work of more than 18 operators as they provided safe working conditions for Commission staff and others on system apparatus, and as they provided safe, secure, reliable and economic operation of this portion of the State System.

He performed the liaison function with head office staff, other divisions and customers on all operating activities, directed the performance of complicated operating procedures and trained both regular and emergency operators.

While he was in this and his previous position, Mr. Slater was responsible for the design and manufacture of the live line testing devices used by the Commissions' operators and linemen.

As well, he assumed responsibility for the preparation and execution of "black start" exercises and for the arrangement and detailing of complicated switching for major rearrangements and commissionings on the State System. He also developed original computer applications.

1969-74

As Engineer, and then Senior Engineer, heading the Production Development Section of Ontario Hydro's Operating Department, Mr. Slater was engaged in developing computational procedures and computer programs for Production Economics and Resource Management.

Major contributions included (1) the development and implementation of the computer program which, for more than 20 years, produced the daily generation schedule for the Ontario Hydro System, (2) the formulation of a Stochastic System Model to coordinate and optimize the production planning, maintenance planning, interchange planning and resource management of the Ontario Hydro System, and (3) the development of PROMOD, a Probabilistic Production Cost and Reliability model, the first version of the "core" of the Stochastic Model in (2) above.

As a member of the project group implementing the Operating Department's Data Acquisition and Computer System, he headed a work unit responsible for providing the application programs related to generation scheduling, power interchange and resource management. Also, he held responsibilities in the areas of policy determination, analytical techniques and the planning of future applications.

1974-75 As Manager of Engineering at the Ontario Energy Board, Mr. Slater was heavily involved in public hearings into Ontario Hydro's System Expansion Plans and Financial Policies, and into Ontario Hydro's Bulk Power Rates.

During this time, he provided much of the power system engineering input necessary for the start-up and formulation of the public hearing process related to Ontario Hydro. He also provided the engineering input for the regulation of Ontario's three major investor owned gas utilities.

1975-76 For 12 months, Mr. Slater was a private consultant contracted to the Royal Commission on Electric Power Planning, in Ontario, as its Research Director. During this time, he directed and participated in various studies of different aspects of electricity supply. He was also a member of the panel of expert examiners in a number of the Royal Commission's public hearings.

1976-83 As President of Slater Energy Consultants, Inc., in Toronto, Mr. Slater performed or made major contributions to a number of important assignments at the forefront of the electrical energy industry. These included:

- The Export of Electrical Power
.... a study for the Ontario Ministry of Industry and Tourism.
- Load Management Studies
.... for the Detroit Edison Company.
- California Utilities Increased Integration Study
.... for San Diego Gas & Electric Company, Southern California Edison Company, Los Angeles Department of Water and Power, and Pacific Gas and Electric Company.
- Bradley-Milton 500 kV Transmission Lines
.... a study for the Ontario Ministry of Energy and the Interested Citizens Group (Halton Hills).
- Solar Energy and the Conventional Energy Industries
.... a study for the Canadian Ministry of Energy, Mines and Resources.
- The Expert Examiner for the Ontario Royal Commission on Electric Power Planning during hearings into Priority Projects.

- Various Studies into Unconventional Electrical Resources
.... for the P.E.I. Institute of Man and Resources and the P.E.I
Energy Corporation.
- Analysis and Expert Testimony in Support of Lower Demand
Rates for Lake Ontario Steel Company Limited, Ivaco
Industries Limited and Atlas Steels.
- Claims for Consequential Damages of the Roseton Boiler
Implosions
.... for Consolidated Edison Company, Central Hudson Power
Company and Niagara Mohawk Power Corporation.
- A study of the Potential for Megawatt Scale Wind Power
Plants in Electrical Utilities
.... for the Canadian Ministry of Energy, Mines and Resources.

These studies have included the need to create special and unique power system models and solution techniques and have addressed significant issues of major importance in the electricity supply industry. Mr. Slater also has carried out assignments for the following clients;

Nova Scotia Power Corporation.
The Government of Prince Edward Island.
The New Brunswick Electric Power Commission.
Ontario Energy Corporation.
Ontario Energy Board.
Go-Home Lake Cottagers Associations.
Saskatchewan Power Corporation.
FMC Corporation.
FMC of Canada Limited.
ERCO Industries Limited.
Canadian Occidental Petroleum Ltd.
State Energy Commission (Western Australia).
Toronto District Heating Corporation.

In connection with his consulting activities, Mr. Slater gave expert testimony in the state of Idaho and in the provinces of Ontario and Prince Edward Island.

Mr. Slater also was a principal developer of PROMOD III, a proprietary electric utility production cost and reliability model owned by Energy Management Associates, Inc.. This model was used by over seventy utilities in Canada, the United States, Japan and Australia. Its wide acceptance made it the "Industry Standard" in the U.S..

1983-90

As Vice President and Chief Engineer for Energy Management Associates, Inc., Mr. Slater was responsible for giving technical direction for the development and maintenance of Energy Management Associates, Inc., state-of-the-art software products. As Senior Vice President and Chief Engineer, Mr. Slater was head of the Energy Management Associates, Inc.'s utility consulting practice. He led or made significant contributions to a number of important consulting engagements, including:

- . Study and regulatory testimony concerning the value to the Idaho Power Company system of the interruptibility provisions in F.M.C.'s supply contract.
- . Generation planning studies for Cincinnati Gas and Electric Company, San Diego Gas & Electric Company and the City of Austin Electric Utility Department.
- . Assistance to legal counsel during regulatory litigation regarding the hostile takeover of a major Canadian gas utility holding company (Union Enterprises), including definition and examination of issues, selection of witnesses, and analysis of the opposing case.
- . Development and demonstration of a method for the allocation of the Inland Power Pool's operating reserve requirement among its members.
- . Analysis of replacement power costs during the outage of Niagara Mohawk Power Corporation's Nine Mile Point #1 nuclear unit.
- . Reserve margin assessments for Public Service Company of Indiana, Allegheny Power System Inc., Iowa Electric Light & Power Company, San Diego Gas & Electric Company, and El Paso Electric Company.

- . Examination of the gas supply situation in Southern California and regulatory testimony regarding the "unbundling" of storage service.
- . Evaluation of the operational, planning and financial impacts of merging two large Eastern U.S. electric utilities.
- . Study and regulatory testimony regarding the value and appropriate level of interruptible demand for the Union Gas system.
- . Evaluation of the benefits of increased operational integration of a group of electric utilities.
- . Assistance for Tucson Electric Power Co. and its legal counsel during arbitration of its dispute with San Diego Gas and Electric Company regarding the operation of a large power sale agreement.
- . Analysis of the economics of a third A/C transmission line linking California and Oregon.
- . A seminar on "Power Pooling and Inter-Utility Interconnections" for the management of the Central Electricity Generating Board and other parties involved in U.K. privatisation.
- . Determination of the benefits of pool membership for two electric utilities in the Northeast U.S..
- . Assistance for Riley Stoker Corporation and its legal counsel with the arbitration of direct and consequential damages arising out of the late completion and early poor performance of two major coal-fired generating units. The work included case examination and development, detailed reconstruction of events, analysis of all financial and economic consequences of project delay and performance with separation of fault, analysis of opponent's case and assistance with cross-examination, direct and rebuttal testimony, and assistance with oral and written argument.

Mr. Slater's consulting assignments included the areas of power system planning, operations, reliability, economics, ratemaking and assessment of the worth of unconventional resources. He appeared as an expert witness in regulatory hearings in Idaho, Iowa, Indiana, Florida, California, Texas, Ontario and Nova Scotia and in civil arbitration proceedings in Louisiana and Pennsylvania.

Mr. Slater continued to contribute to the development of E.M.A.'s utility software products. His contributions included being a principal developer of SENDOUT, E.M.A.'s proprietary supply model for gas utilities.

1990- In August 1990, Mr. Slater returned to working in his own practice, in Atlanta, where he heads a small corporation, Slater Consulting, which provides consulting services and expert testimony for various different participants in the utility industry.

Slater Consulting assignments, led by Mr. Slater, have included:

- Assistance to legal council for creditors of a bankrupt utility.
- Analysis and testimony for Texas - New Mexico Power Company regarding prudent alternatives to their decision to build TNP ONE Unit 2.
- Assistance and analysis for a utility and its legal counsel during litigation regarding damages sustained because of interference in a proposed merger of that utility with another utility.
- Analyses and testimony before the New York PSC for Sithe Energies, Inc., in certification proceedings and in numerous avoided cost and buy-back rate proceedings.
- Analyses and testimony for the Independent Power Producers of New York in QF curtailment, buy-back rate and back-up rate proceedings before the New York PSC.
- Analysis and testimony for Southwestern Public Service Co. at FERC and before the New Mexico Public Service Commission regarding the lack of production cost savings from the proposed merger of Central & South West Utilities with El Paso Electric Company.
- Analyses and testimony before the Public Service Commission for Independent Power Producers in Florida regarding QF curtailment.

- Analyses and testimony in Civil Court cases for Independent Power Producers in Florida regarding the correct implementation of contractual dispatchability provisions.
- Testimony before regulatory commissions in New York, Pennsylvania, Texas, Florida and Louisiana regarding various aspects of emerging competition.
- Analyses and testimony before the Georgia Public Service Commission on behalf of Mid-Georgia Co-gen and others regarding avoided costs on the Georgia Power / Southern Company system.
- Analysis and testimony before the Georgia Public Service Commission on behalf of Georgia Power Company regarding the Prudence of Georgia Power's 1978-1980 investment in the Rocky Mountain pumped storage plant.
- Testimony before the regulatory commissions of Texas, Virginia and Wisconsin regarding the fair allocation of utility revenue requirements to individual customer classes.
- Testimony before the United States Bankruptcy Court regarding the value of the non-nuclear assets of Cajun Electric Power Co-operative, Inc.
- Analyses for Sithe Energies, Inc. of the future dispatch and associated energy revenues for numerous generating resources in the Northeast United States.
- Operational planning analyses for Sithe Energies, Inc. regarding numerous existing and new generating resources in the Northeast United States.
- Analyses and testimony in Courts and before arbitrators for the non-operating owners of the South Texas Nuclear Project, the Cooper nuclear unit in Nebraska, and the Millstone 3 nuclear unit in Connecticut concerning the replacement power costs during extended outages.

In connection with these and other assignments, Mr. Slater has appeared as an expert in regulatory proceedings in Florida, Georgia, Louisiana, New Mexico, New York, Pennsylvania, South Carolina, Virginia, Wisconsin and Texas, and at the Federal Energy Regulatory Commission. He has also appeared in Federal Bankruptcy Court, state courts in Virginia, Nebraska, Texas and Florida, and civil arbitration proceedings in Nevada and Pennsylvania.

PUBLICATIONS & PRESENTATIONS

- "Meeting System Demand"
Canada-USSR Electric Power Working Group Electrical Seminar,
Montreal, March, 1973.
- "Stochastic Model for Use in Determining Optimal Power System Operating
Strategies."
Power Devices and Systems Group, Electrical Engineering Department,
University of Toronto - 1973.
- "Economy-Security Functions in Power System Operations"
IEEE Power System Economic Subcommittee Work Group Paper
IEEE Special Publication 75 CH0960-6-PWR-1975.
- "Economy-Security Functions in Power System Operations - A Summary
Introduction."
IEEE Power System Economics Subcommittee Working Group Paper
IEEE T.P.A.S. Sept/Oct 1975 p. 1618.
- "A Large Hydro-Thermal Scheduling Model"
TIMS/ORSA
Miami, November 1976.
- "Generation System Modeling for Planning and Operations"
Atlantic Regional Thermal Conference
Charlottetown, June 1978.
- "The Feasibility of Electricity Export from CANDU Nuclear Generation"
Canadian Nuclear Association
Ottawa, June 1978.
- "Evaluation of the Worth of System Scale Wind Generation to the Prince Edward
Island Electrical Grid."
IEEE Canadian Conference
Toronto, October 1979.
- "The Results of a Study Examining The Possible Impact of Solar Space Heating
on the Electrical Utility in New Brunswick."
The Potential Impacts of the Deployment of Solar Heating on Electrical
Utilities - A workshop sponsored by the Canadian Department of Energy,
Mines and Resources
Ottawa, May 1980.

"Reliability Indices: Their Meanings and Differences"

Planmetrics/Energy Management Associates, Inc. 8th Annual National
Utilities Conference
Chicago, May 1980.

"Description and Bibliography of Major Economy-Security Functions

Part I - Description

Part II - Bibliography (1959-1972)

Part III - Bibliography (1973-1979)"

IEEE Power System Economics Subcommittee Working Group
Papers(3).

IEEE TPAS January 1981, p.211, p.214. p.224.

"PROMOD III Evaluation of the Worth of Grid Connected WECS."

Fifth Annual Wind Energy Symposium, Ryerson Polytechnical Institute
Toronto, December 1982.

"Probabilistic Simulation in Power System Production Models"

China-U.S.A. Power System Meeting, Electrical Power Research
Institute of China

Tianjin, China, June 1985.

"Computer Modeling of Wheeling Arrangements"

Electricity Consumers Resource Council Seminar
Washington, D.C. September 1985.

"Power Systems Reliability Improvement Benefits - A Framework for Analysis"

ASME Energy-Sources Technology Conference
Dallas, February 1987.

**FUEL PRICE ASSUMPTIONS FOR PROMOD IV(R) ANALYSES OF
OSPREY PROJECT OPERATIONS, BASE CASE**

(All Values in cents/mmbtu)

| Year | COAL | | #2 OIL | | #6 OIL | | GAS | | | |
|------|---------------------|----------------------|---------------------|----------------------|---------------------|----------------------|---------------------|--------|----------------------|--------|
| | <u>Lowest Price</u> | <u>Highest Price</u> | <u>Lowest Price</u> | <u>Highest Price</u> | <u>Lowest Price</u> | <u>Highest Price</u> | <u>Lowest Price</u> | | <u>Highest Price</u> | |
| | | | | | | | Winter | Summer | Winter | Summer |
| 2000 | 158.3 | 248.2 | 558.2 | 656.1 | 365.2 | 489.2 | 346.4 | 346.2 | 377.6 | 380.1 |
| 2001 | 157.0 | 246.2 | 510.6 | 600.1 | 323.9 | 433.9 | 376.7 | 347.4 | 410.8 | 381.4 |
| 2002 | 162.5 | 254.8 | 496.1 | 583.1 | 315.5 | 422.6 | 377.2 | 347.4 | 411.4 | 381.4 |
| 2003 | 168.0 | 263.3 | 528.5 | 621.2 | 329.3 | 441.1 | 382.6 | 358.1 | 417.3 | 393.2 |
| 2004 | 173.4 | 271.9 | 561.0 | 659.4 | 343.1 | 459.6 | 393.4 | 368.9 | 429.1 | 405.0 |
| 2005 | 178.3 | 279.6 | 593.0 | 697.0 | 357.1 | 478.3 | 404.2 | 379.7 | 440.9 | 416.8 |
| 2006 | 182.3 | 285.9 | 614.2 | 721.9 | 368.2 | 493.3 | 415.1 | 390.7 | 452.9 | 428.8 |
| 2007 | 186.4 | 292.3 | 636.1 | 747.7 | 379.8 | 508.7 | 427.3 | 404.0 | 466.1 | 443.3 |
| 2008 | 190.6 | 298.9 | 658.8 | 774.4 | 391.6 | 524.6 | 440.7 | 417.6 | 480.8 | 458.3 |
| 2009 | 194.9 | 305.6 | 682.3 | 802.0 | 403.9 | 541.0 | 454.6 | 431.8 | 496.0 | 473.7 |
| 2010 | 199.3 | 312.5 | 706.7 | 830.6 | 416.5 | 558.0 | 468.9 | 446.4 | 511.7 | 489.7 |
| 2011 | 203.7 | 319.4 | 727.3 | 854.9 | 430.7 | 576.9 | 483.8 | 461.4 | 527.9 | 506.1 |
| 2012 | 208.3 | 326.5 | 748.6 | 879.9 | 445.3 | 596.5 | 499.1 | 477.0 | 544.7 | 523.1 |

**FUEL PRICE ASSUMPTIONS FOR PROMOD IV(R) ANALYSES OF
OSPREY PROJECT OPERATIONS, HIGHER GAS PRICE CASE**

(All Values in cents/mmbtu)

| Year | COAL | | #2 OIL | | #6 OIL | | GAS | | | |
|------|---------------------|----------------------|---------------------|----------------------|---------------------|----------------------|---------------------|---------------|----------------------|---------------|
| | <u>Lowest Price</u> | <u>Highest Price</u> | <u>Lowest Price</u> | <u>Highest Price</u> | <u>Lowest Price</u> | <u>Highest Price</u> | <u>Lowest Price</u> | | <u>Highest Price</u> | |
| | | | | | | | <u>Winter</u> | <u>Summer</u> | <u>Winter</u> | <u>Summer</u> |
| 2000 | 158.3 | 248.2 | 558.2 | 656.1 | 365.2 | 489.2 | 346.4 | 346.2 | 377.6 | 380.1 |
| 2001 | 157.0 | 246.2 | 510.6 | 600.1 | 323.9 | 433.9 | 376.7 | 347.4 | 410.8 | 381.4 |
| 2002 | 162.5 | 254.8 | 496.1 | 583.1 | 315.5 | 422.6 | 382.6 | 358.1 | 417.3 | 393.2 |
| 2003 | 168.0 | 263.3 | 528.5 | 621.2 | 329.3 | 441.1 | 393.4 | 368.9 | 429.1 | 405.0 |
| 2004 | 173.4 | 271.9 | 561.0 | 659.4 | 343.1 | 459.6 | 404.2 | 379.7 | 440.9 | 416.8 |
| 2005 | 178.3 | 279.6 | 593.0 | 697.0 | 357.1 | 478.3 | 415.1 | 390.7 | 452.9 | 428.8 |
| 2006 | 182.3 | 285.9 | 614.2 | 721.9 | 368.2 | 493.3 | 430.9 | 411.3 | 470.1 | 451.3 |
| 2007 | 186.4 | 292.3 | 636.1 | 747.7 | 379.8 | 508.7 | 451.9 | 432.8 | 493.2 | 474.9 |
| 2008 | 190.6 | 298.9 | 658.8 | 774.4 | 391.6 | 524.6 | 474.0 | 455.4 | 517.3 | 499.7 |
| 2009 | 194.9 | 305.6 | 682.3 | 802.0 | 403.9 | 541.0 | 497.2 | 479.2 | 542.7 | 525.7 |
| 2010 | 199.3 | 312.5 | 706.7 | 830.6 | 416.5 | 558.0 | 521.6 | 504.2 | 569.4 | 553.0 |
| 2011 | 203.7 | 319.4 | 727.3 | 854.9 | 430.7 | 576.9 | 544.1 | 524.3 | 594.0 | 574.9 |
| 2012 | 208.3 | 326.5 | 748.6 | 879.9 | 445.3 | 596.5 | 564.5 | 545.1 | 616.4 | 597.7 |

EFFICIENCY AND COST-EFFECTIVENESS OF PENINSULAR FLORIDA GENERATING UNITS, 2003

| Plant | Unit | Summer Capacity (MW) | Average Annual Heat Rate (Btu/kwh) | Average Annual Dispatch Cost (\$/MWh) |
|---------------------------------------|------|----------------------------|--|---|
| <u>Nuclear</u> | | | | |
| CRYSTAL | 3 | 805 | Must Run at Maximum Available Capacity | |
| STLUCIE | 1 | 839 | Must Run at Maximum Available Capacity | |
| STLUCIE | 2 | 839 | Must Run at Maximum Available Capacity | |
| TURKEYPT | 3 | 697 | Must Run at Maximum Available Capacity | |
| TURKEYPT | 4 | 697 | Must Run at Maximum Available Capacity | |
| <u>Coal and Petroleum Coke</u> | | | | |
| BIG BEND | 1 | 421 | 9,965 | 30.29 |
| BIG BEND | 2 | 421 | 9,972 | 30.57 |
| BIG BEND | 3 | 428 | 9,956 | 28.72 |
| BIG BEND | 4 | 442 | 9,943 | 26.93 |
| CRYSTAL | 1 | 386 | 9,679 | 25.40 |
| CRYSTAL | 2 | 488 | 9,596 | 25.26 |
| CRYSTAL | 4 | 714 | 9,094 | 23.67 |
| CRYSTAL | 5 | 697 | 9,092 | 23.41 |
| DEERHAVN | 2 | 228 | 10,608 | 25.20 |
| GANNON | 1 | 0 | 9,688 | 31.24 |
| GANNON | 2 | 0 | 9,671 | 31.19 |
| GANNON | 6 | 362 | 10,246 | 35.01 |
| MCINTOSH | 3 | 338 | 9,093 | 23.65 |
| NORTHSID | 1 | 265 | 9,753 | 23.34 |
| NORTHSID | 2 | 265 | 13,156 | 29.42 |
| SCHERER | 4 | 846 | 9,949 | 24.53 |
| SEMINOLE | 1 | 638 | 10,041 | 26.38 |
| SEMINOLE | 2 | 638 | 10,041 | 26.28 |
| ST JOHNS | 1 | 624 | 9,179 | 22.26 |
| ST JOHNS | 2 | 638 | 9,258 | 22.88 |
| STANTON | 1 | 442 | 9,777 | 24.99 |
| STANTON | 2 | 446 | 9,079 | 22.85 |

New Gas Combined Cycle

| | | | | |
|----------|----|------|-------|-------|
| BAYSIDE | 1 | 707 | 7,236 | 29.38 |
| BRANDY B | 4 | 482 | 7,176 | 29.68 |
| CANE IS | 3 | 260 | 6,999 | 28.11 |
| FT MYERS | 3 | 1446 | 7,145 | 29.08 |
| HINES EC | 1 | 470 | 7,049 | 28.30 |
| HINES EC | 2 | 0 | 7,002 | 29.59 |
| KELLEY | 4 | 113 | 8,362 | 36.91 |
| N SMYRNA | 1 | 520 | 6,971 | 28.04 |
| OKEECHOB | 1 | 260 | 6,965 | 27.76 |
| OKEECHOB | 2 | 260 | 6,966 | 27.76 |
| OSPREY | 1 | 520 | 6,967 | 28.09 |
| PAYNECRK | 3 | 520 | 7,001 | 28.14 |
| PURDOM | 8 | 260 | 6,995 | 28.10 |
| SANFORD | 14 | 964 | 7,206 | 29.29 |
| SANFORD | 15 | 964 | 7,208 | 29.29 |

Other Units

| | | | | |
|----------|---|-----|-----------------------|-------|
| ANCLOTE | 1 | 503 | 10,952 | 69.84 |
| ANCLOTE | 2 | 503 | 10,485 | 66.36 |
| AVONPKGT | 1 | 29 | No Significant Output | |
| AVONPKGT | 2 | 29 | No Significant Output | |
| BARTOW | 1 | 115 | 9,982 | 39.38 |
| BARTOW | 2 | 117 | 9,983 | 39.81 |
| BARTOW | 3 | 208 | 9,975 | 38.84 |
| BARTOWGT | 1 | 46 | No Significant Output | |
| BARTOWGT | 2 | 46 | No Significant Output | |
| BARTOWGT | 3 | 46 | No Significant Output | |
| BARTOWGT | 4 | 49 | No Significant Output | |
| BAYBROGT | 1 | 47 | No Significant Output | |
| BAYBROGT | 2 | 47 | No Significant Output | |
| BAYBROGT | 3 | 47 | No Significant Output | |
| BAYBROGT | 4 | 47 | No Significant Output | |
| BGBENDGT | 1 | 12 | No Significant Output | |
| BGBENDGT | 2 | 61 | 11,635 | 75.05 |
| BGBENDGT | 3 | 61 | 11,635 | 75.10 |
| BRANDY B | 1 | 0 | 11,224 | 56.71 |
| BRANDY B | 2 | 0 | 11,266 | 56.96 |
| BRANDY B | 3 | 153 | 11,383 | 56.01 |
| CANE GT | 1 | 30 | 11,166 | 50.91 |
| CANE ISL | 2 | 108 | 9,583 | 42.41 |
| CAPECNVR | 1 | 405 | 9,437 | 40.46 |

| | | | | |
|----------|----|-----|-----------------------|-------|
| CAPECNVR | 2 | 408 | 9,441 | 40.68 |
| CUDJOE D | 1 | 5 | No Significant Output | |
| CUTLER | 5 | 71 | 11,720 | 45.14 |
| CUTLER | 6 | 144 | 11,741 | 45.33 |
| DEBARYGT | 1 | 54 | No Significant Output | |
| DEBARYGT | 2 | 54 | 11,730 | 76.32 |
| DEBARYGT | 3 | 54 | No Significant Output | |
| DEBARYGT | 4 | 54 | No Significant Output | |
| DEBARYGT | 5 | 54 | No Significant Output | |
| DEBARYGT | 6 | 54 | No Significant Output | |
| DEBARYGT | 7 | 88 | 11,890 | 76.92 |
| DEBARYGT | 8 | 88 | 11,890 | 76.97 |
| DEBARYGT | 9 | 88 | 11,880 | 76.91 |
| DEBARYGT | 10 | 88 | 11,880 | 77.09 |
| DEERHAVN | 1 | 85 | 10,604 | 45.57 |
| DRHVN GT | 1 | 18 | 14,471 | 68.60 |
| DRHVN GT | 2 | 18 | 14,471 | 68.80 |
| DRHVN GT | 3 | 75 | 14,471 | 68.15 |
| EVERGL T | 1 | 35 | 17,121 | 74.24 |
| EVERGL T | 2 | 35 | 17,121 | 74.10 |
| EVERGL T | 3 | 35 | 17,121 | 73.81 |
| EVERGL T | 4 | 35 | 17,121 | 73.86 |
| EVERGL T | 5 | 35 | 17,121 | 73.60 |
| EVERGL T | 6 | 35 | 17,121 | 73.92 |
| EVERGL T | 7 | 35 | 17,121 | 73.65 |
| EVERGL T | 8 | 35 | 17,121 | 73.39 |
| EVERGL T | 9 | 35 | 17,121 | 73.35 |
| EVERGL T | 10 | 35 | 17,121 | 73.46 |
| EVERGL T | 11 | 35 | 17,121 | 73.04 |
| EVERGL T | 12 | 35 | No Significant Output | |
| EVERGLDS | 1 | 221 | 9,550 | 38.49 |
| EVERGLDS | 2 | 221 | 9,557 | 38.63 |
| EVERGLDS | 3 | 375 | 9,944 | 39.71 |
| EVERGLDS | 4 | 410 | 9,925 | 39.66 |
| FTMYER T | 1 | 54 | No Significant Output | |
| FTMYER T | 2 | 54 | No Significant Output | |
| FTMYER T | 3 | 54 | No Significant Output | |
| FTMYER T | 4 | 54 | No Significant Output | |
| FTMYER T | 5 | 54 | No Significant Output | |
| FTMYER T | 6 | 54 | No Significant Output | |
| FTMYER T | 7 | 54 | No Significant Output | |
| FTMYER T | 8 | 54 | No Significant Output | |
| FTMYER T | 9 | 54 | No Significant Output | |
| FTMYER T | 10 | 54 | No Significant Output | |
| FTMYER T | 11 | 54 | No Significant Output | |

| | | | | |
|----------|----|-----|-----------------------|-------|
| FTMYER T | 12 | 54 | No Significant Output | |
| FTMYERCT | 13 | 153 | 11,302 | 52.34 |
| FTMYERCT | 14 | 153 | 11,311 | 52.38 |
| GANNONGT | 1 | 12 | No Significant Output | |
| HANSELCC | 2 | 48 | 9,817 | 46.24 |
| HANSELIC | 8 | 3 | 9,300 | 43.19 |
| HANSELIC | 14 | 2 | 9,300 | 43.23 |
| HANSELIC | 15 | 2 | 9,300 | 43.25 |
| HANSELIC | 16 | 2 | 9,300 | 43.25 |
| HANSELIC | 17 | 2 | 9,300 | 43.23 |
| HANSELIC | 18 | 2 | No Significant Output | |
| HANSELIC | 19 | 3 | No Significant Output | |
| HANSELIC | 20 | 3 | 9,300 | 43.25 |
| HARDEE | 1 | 224 | 7,300 | 34.54 |
| HARDEECT | 1 | 74 | 9,732 | 45.33 |
| HIGGNSGT | 1 | 29 | No Significant Output | |
| HIGGNSGT | 2 | 29 | No Significant Output | |
| HIGGNSGT | 3 | 35 | No Significant Output | |
| HIGGNSGT | 4 | 35 | No Significant Output | |
| HOOKERS | 1 | 0 | No Significant Output | |
| HOOKERS | 2 | 0 | No Significant Output | |
| HOOKERS | 3 | 0 | No Significant Output | |
| HOOKERS | 4 | 0 | No Significant Output | |
| HOOKERS | 5 | 0 | No Significant Output | |
| HOPKINGT | 1 | 12 | 14,029 | 60.59 |
| HOPKINGT | 2 | 24 | 13,597 | 63.57 |
| HOPKINS | 1 | 75 | 11,357 | 47.25 |
| HOPKINS | 2 | 238 | 10,652 | 41.92 |
| IND RIVR | 1 | 88 | 10,033 | 42.34 |
| IND RIVR | 2 | 201 | 9,982 | 39.50 |
| IND RIVR | 3 | 319 | 10,469 | 41.65 |
| INDRVRGT | 1 | 37 | 11,540 | 52.40 |
| INDRVRGT | 2 | 37 | 11,540 | 52.51 |
| INDRVRGT | 3 | 108 | 11,100 | 50.84 |
| INDRVRGT | 4 | 108 | 11,100 | 50.84 |
| INTER GT | 1 | 47 | No Significant Output | |
| INTER GT | 2 | 47 | No Significant Output | |
| INTER GT | 3 | 47 | No Significant Output | |
| INTER GT | 4 | 47 | No Significant Output | |
| INTER GT | 5 | 47 | No Significant Output | |
| INTER GT | 6 | 47 | No Significant Output | |
| INTER GT | 7 | 83 | 12,210 | 79.38 |
| INTER GT | 8 | 83 | No Significant Output | |
| INTER GT | 9 | 83 | No Significant Output | |
| INTER GT | 10 | 83 | 12,030 | 77.69 |

| | | | | |
|----------|----|-----|-----------------------|-------|
| INTER GT | 11 | 143 | 12,030 | 78.03 |
| INTER GT | 12 | 76 | 12,572 | 59.75 |
| INTER GT | 13 | 76 | 12,558 | 59.59 |
| INTER GT | 14 | 76 | 12,523 | 59.47 |
| IVEY IC | 1 | 4 | 9,300 | 42.70 |
| IVEY IC | 2 | 5 | 9,300 | 42.71 |
| IVEY IC | 3 | 9 | 12,280 | 54.15 |
| IVEY IC | 4 | 6 | 12,280 | 54.23 |
| IVEY IC | 5 | 4 | 9,300 | 42.70 |
| IVEY IC | 6 | 18 | 9,300 | 42.70 |
| KELLY | 7 | 23 | 16,441 | 68.60 |
| KELLY GT | 1 | 14 | No Significant Output | |
| KELLY GT | 2 | 14 | No Significant Output | |
| KELLY GT | 3 | 14 | No Significant Output | |
| KENEDYGT | 3 | 54 | No Significant Output | |
| KENEDYGT | 4 | 54 | No Significant Output | |
| KENEDYGT | 5 | 54 | No Significant Output | |
| KENEDYGT | 7 | 153 | 11,380 | 56.05 |
| KING | 5 | 8 | 10,483 | 42.59 |
| KING | 6 | 17 | 12,842 | 51.73 |
| KING | 7 | 32 | 12,858 | 54.99 |
| KING | 8 | 50 | 12,710 | 52.43 |
| KING DSL | 1 | 5 | No Significant Output | |
| KING GT | 9 | 23 | 10,500 | 51.01 |
| LARSEN | 8 | 102 | 10,610 | 42.77 |
| LARSENGT | 2 | 10 | No Significant Output | |
| LARSENGT | 3 | 10 | No Significant Output | |
| LAUDER T | 1 | 36 | 15,908 | 66.47 |
| LAUDER T | 2 | 35 | 15,908 | 66.46 |
| LAUDER T | 3 | 35 | 15,908 | 66.53 |
| LAUDER T | 4 | 35 | 15,908 | 66.47 |
| LAUDER T | 5 | 35 | 15,908 | 66.54 |
| LAUDER T | 6 | 35 | 15,908 | 66.44 |
| LAUDER T | 7 | 35 | 15,908 | 66.55 |
| LAUDER T | 8 | 35 | 15,908 | 66.59 |
| LAUDER T | 9 | 35 | 15,908 | 66.62 |
| LAUDER T | 10 | 35 | 15,908 | 66.61 |
| LAUDER T | 11 | 35 | 15,908 | 66.70 |
| LAUDER T | 12 | 35 | 15,908 | 66.71 |
| LAUDER T | 13 | 35 | 16,227 | 67.94 |
| LAUDER T | 14 | 35 | 16,227 | 67.94 |
| LAUDER T | 15 | 35 | 16,227 | 67.92 |
| LAUDER T | 16 | 35 | 16,227 | 68.11 |
| LAUDER T | 17 | 35 | 16,227 | 68.09 |
| LAUDER T | 18 | 35 | 16,227 | 68.04 |

| | | | | |
|----------|----|-----|-----------------------|-------|
| LAUDER T | 19 | 35 | 16,227 | 68.02 |
| LAUDER T | 20 | 35 | 16,227 | 68.19 |
| LAUDER T | 21 | 35 | 16,227 | 68.28 |
| LAUDER T | 22 | 32 | 16,227 | 68.21 |
| LAUDER T | 23 | 32 | 16,227 | 68.15 |
| LAUDER T | 24 | 35 | 16,227 | 68.35 |
| LAUDERCC | 4 | 440 | 7,640 | 32.83 |
| LAUDERCC | 5 | 440 | 7,654 | 33.48 |
| MANATEE | 1 | 819 | 9,928 | 39.50 |
| MANATEE | 2 | 819 | 9,909 | 39.50 |
| MARATHON | 1 | 8 | No Significant Output | |
| MARATHON | 2 | 5 | 9,300 | 42.70 |
| MARATHON | 3 | 8 | 12,280 | 54.18 |
| MARTIN | 1 | 814 | 8,904 | 36.37 |
| MARTIN | 2 | 816 | 8,939 | 36.16 |
| MARTINCC | 3 | 445 | 7,232 | 31.20 |
| MARTINCC | 4 | 445 | 7,235 | 31.08 |
| MARTINCT | 1 | 153 | 11,266 | 52.39 |
| MARTINCT | 2 | 153 | 11,266 | 52.38 |
| MCINT GT | 1 | 17 | 15,000 | 65.71 |
| MCINT IC | 1 | 5 | No Significant Output | |
| MCINTOSH | 1 | 87 | 10,815 | 43.98 |
| MCINTOSH | 2 | 103 | 10,274 | 40.96 |
| MCINTOSH | 5 | 310 | 7,262 | 30.03 |
| NORTH GT | 3 | 52 | No Significant Output | |
| NORTH GT | 4 | 52 | No Significant Output | |
| NORTH GT | 5 | 52 | No Significant Output | |
| NORTH GT | 6 | 52 | No Significant Output | |
| NORTHSID | 3 | 505 | 9,688 | 40.75 |
| OLEAN GT | 1 | 153 | 11,291 | 52.41 |
| OLEAN GT | 2 | 153 | 11,303 | 52.48 |
| OLEAN GT | 3 | 153 | 11,301 | 52.43 |
| OLEAN GT | 4 | 153 | 11,316 | 52.50 |
| OLEAN GT | 5 | 153 | 11,325 | 52.51 |
| PHILLIPS | 1 | 17 | 13,500 | 55.45 |
| PHILLIPS | 2 | 17 | 13,500 | 55.48 |
| POLK CT | 2 | 153 | 11,366 | 54.72 |
| POLK CT | 3 | 153 | 11,348 | 54.74 |
| POLKIGCC | 1 | 250 | 10,079 | 29.97 |
| PURDOM | 7 | 48 | 16,947 | 69.23 |
| PURDOMGT | 1 | 12 | No Significant Output | |
| PURDOMGT | 2 | 12 | No Significant Output | |
| PUTNAMCC | 1 | 249 | 9,115 | 39.31 |
| PUTNAMCC | 2 | 249 | 9,114 | 39.36 |
| REEDYCRK | 1 | 35 | 10,400 | 45.89 |

| | | | | |
|----------|---|-----|-----------------------|-------|
| RIOPINGT | 1 | 15 | No Significant Output | |
| RIVIERA | 3 | 290 | 9,729 | 37.23 |
| RIVIERA | 4 | 290 | 9,729 | 37.52 |
| SANFORD | 3 | 153 | 8,877 | 40.06 |
| SEM CT | 1 | 153 | 11,357 | 54.83 |
| SMITH | 1 | 7 | 18,840 | 75.52 |
| SMITH | 2 | 7 | 18,822 | 75.58 |
| SMITH | 3 | 22 | 16,777 | 70.99 |
| SMITH | 4 | 32 | 16,798 | 71.08 |
| SMITH D | 1 | 9 | No Significant Output | |
| SMITH CC | 1 | 32 | 10,400 | 48.43 |
| SMITH GT | 1 | 26 | No Significant Output | |
| SMITH ST | 1 | 3 | No Significant Output | |
| SMITH ST | 2 | 2 | No Significant Output | |
| SMITH ST | 3 | 6 | No Significant Output | |
| ST CLOUD | 1 | 4 | No Significant Output | |
| ST CLOUD | 2 | 6 | No Significant Output | |
| ST CLOUD | 3 | 6 | No Significant Output | |
| ST CLOUD | 4 | 12 | 10,696 | 73.23 |
| STOCK DS | 1 | 9 | 9,300 | 64.95 |
| STOCK DS | 2 | 9 | 9,300 | 65.06 |
| STOCK GT | 1 | 21 | No Significant Output | |
| STOCK GT | 2 | 16 | No Significant Output | |
| STOCK GT | 3 | 16 | No Significant Output | |
| STOCK IC | 1 | 6 | No Significant Output | |
| SUWAN GT | 1 | 54 | No Significant Output | |
| SUWAN GT | 2 | 54 | No Significant Output | |
| SUWAN GT | 3 | 54 | No Significant Output | |
| SUWANNEE | 1 | 33 | 11,729 | 51.07 |
| SUWANNEE | 2 | 32 | 11,733 | 51.09 |
| SUWANNEE | 3 | 80 | 11,750 | 51.17 |
| SWOOPEIC | 1 | 5 | No Significant Output | |
| TIGERBAY | 1 | 194 | 7,553 | 32.32 |
| TURKEYIC | 1 | 14 | No Significant Output | |
| TURKEYPT | 1 | 410 | 9,433 | 39.54 |
| TURKEYPT | 2 | 400 | 9,395 | 39.80 |
| TURNERGT | 1 | 15 | No Significant Output | |
| TURNERGT | 2 | 15 | No Significant Output | |
| TURNERGT | 3 | 65 | No Significant Output | |
| TURNERGT | 4 | 65 | No Significant Output | |
| UNIV FLA | 1 | 36 | 11,166 | 50.41 |
| VERO BCH | 1 | 13 | 13,041 | 52.60 |
| VERO BCH | 2 | 13 | 8,928 | 38.66 |
| VERO BCH | 3 | 33 | 13,141 | 54.47 |
| VERO BCH | 4 | 56 | 11,739 | 48.61 |
| VERO BCH | 5 | 35 | 11,171 | 45.71 |

NUGs

| | | |
|----------|---|-----|
| AGRICHEM | 1 | 6 |
| AS-AVAIL | 1 | 63 |
| BAY CTY | 1 | 11 |
| BIOENRGY | 1 | 10 |
| BROWARDS | 1 | 54 |
| BROWARDS | 2 | 56 |
| CARGILL | 2 | 15 |
| CEDARBAY | 1 | 250 |
| CFRBIOGN | 1 | 74 |
| DADE CTY | 1 | 43 |
| ELDORADO | 1 | 114 |
| FLASTONE | 1 | 133 |
| HILLSBOR | 1 | 26 |
| INDIANTN | 1 | 330 |
| LAKE CTY | 1 | 13 |
| LAKECOGN | 1 | 110 |
| LFC JEFF | 1 | 9 |
| LFC MADS | 1 | 9 |
| MULB-FPC | 1 | 79 |
| ORANGE | 1 | 22 |
| ORLANDO | 1 | 79 |
| PALMBCH | 1 | 44 |
| PASCO | 1 | 109 |
| PASCOCTY | 1 | 23 |
| PINELLAS | 1 | 40 |
| PINELLAS | 2 | 15 |
| RIDGE | 1 | 40 |
| ROYSTER | 1 | 31 |
| TAMPACTY | 1 | 19 |
| JEA-QFs | | 17 |

External Purchases

| | | |
|--------------|---|------|
| ENTERGY | 1 | 23 |
| SOUTHERN CO. | | 1615 |

Source: PROMOD IV(R) analyses prepared by Slater Consulting

EFFICIENCY AND COST-EFFECTIVENESS OF PENINSULAR FLORIDA GENERATING UNITS, 2008

| Plant | Unit | Summer Capacity (MW) | Average Annual Heat Rate (Btu/kwh) | Average Annual Dispatch Cost (\$/MWh) |
|---------------------------------------|------|----------------------------|--|---|
| <u>Nuclear</u> | | | | |
| CRYSTAL | 3 | 805 | Must Run at Maximum Available Capacity | |
| STLUCIE | 1 | 839 | Must Run at Maximum Available Capacity | |
| STLUCIE | 2 | 839 | Must Run at Maximum Available Capacity | |
| TURKEYPT | 3 | 697 | Must Run at Maximum Available Capacity | |
| TURKEYPT | 4 | 697 | Must Run at Maximum Available Capacity | |
| <u>Coal and Petroleum Coke</u> | | | | |
| BIG BEND | 1 | 421 | 10,017 | 34.67 |
| BIG BEND | 2 | 421 | 10,018 | 35.01 |
| BIG BEND | 3 | 428 | 9,998 | 32.60 |
| BIG BEND | 4 | 442 | 9,980 | 30.78 |
| CRYSTAL | 1 | 386 | 9,682 | 28.16 |
| CRYSTAL | 2 | 488 | 9,600 | 28.04 |
| CRYSTAL | 4 | 714 | 9,124 | 26.57 |
| CRYSTAL | 5 | 697 | 9,121 | 26.10 |
| DEERHAVN | 2 | 228 | 10,609 | 28.60 |
| MCINTOSH | 3 | 338 | 9,099 | 26.95 |
| MCINTOSH | 4 | 288 | 8,492 | 24.19 |
| NORTHSID | 1 | 265 | 9,786 | 26.49 |
| NORTHSID | 2 | 265 | 13,421 | 34.04 |
| SCHERER | 4 | 846 | 9,969 | 27.53 |
| SEMINOLE | 1 | 638 | 10,089 | 29.97 |
| SEMINOLE | 2 | 638 | 10,077 | 29.62 |
| ST JOHNS | 1 | 624 | 9,204 | 25.31 |
| ST JOHNS | 2 | 638 | 9,288 | 25.77 |
| STANTON | 1 | 442 | 9,782 | 27.70 |
| STANTON | 2 | 446 | 9,086 | 26.03 |

New Gas Combined Cycle

| | | | | |
|----------|----|------|-------|-------|
| BAYSIDE | 1 | 707 | 7,221 | 34.15 |
| BAYSIDE | 2 | 715 | 7,186 | 34.01 |
| BRANDY B | 4 | 482 | 7,254 | 34.71 |
| CANE IS | 3 | 260 | 7,026 | 32.74 |
| FT MYERS | 3 | 1446 | 7,203 | 33.90 |
| GREEN CC | 1 | 260 | 6,979 | 32.57 |
| HINES EC | 1 | 470 | 7,082 | 32.95 |
| HINES EC | 2 | 520 | 7,005 | 32.69 |
| HINES EC | 3 | 520 | 7,016 | 32.67 |
| HINES EC | 4 | 520 | 7,020 | 32.74 |
| KELLEY | 4 | 113 | 8,536 | 43.43 |
| MARTINCC | 5 | 380 | 6,804 | 31.96 |
| MARTINCC | 6 | 380 | 6,804 | 31.96 |
| N SMYRNA | 1 | 520 | 6,992 | 32.62 |
| OKEECHOB | 1 | 260 | 6,978 | 32.44 |
| OKEECHOB | 2 | 260 | 6,977 | 32.56 |
| OSPREY | 1 | 520 | 6,984 | 32.57 |
| PAYNECRK | 3 | 520 | 7,037 | 32.76 |
| PURDOM | 8 | 260 | 7,009 | 32.69 |
| SANFORD | 14 | 964 | 7,276 | 34.17 |
| SANFORD | 15 | 964 | 7,282 | 34.17 |
| SEMIN CC | 4 | 260 | 7,010 | 32.67 |
| SEMIN CC | 5 | 260 | 7,011 | 32.67 |
| UNKNOWCC | 1 | 364 | 6,981 | 32.53 |
| UNKNOWCC | 2 | 364 | 6,990 | 32.63 |

Other Units

| | | | | |
|----------|---|-----|-----------------------|-------|
| ANCLOTE | 1 | 503 | 11,581 | 90.11 |
| ANCLOTE | 2 | 503 | 11,378 | 89.16 |
| BARTOW | 1 | 115 | 9,971 | 46.89 |
| BARTOW | 2 | 117 | 10,003 | 46.60 |
| BARTOW | 3 | 208 | 9,978 | 46.05 |
| BARTOWGT | 1 | 46 | No Significant Output | |
| BARTOWGT | 2 | 46 | No Significant Output | |
| BARTOWGT | 3 | 46 | No Significant Output | |
| BARTOWGT | 4 | 49 | No Significant Output | |
| BGBENDGT | 1 | 12 | No Significant Output | |
| BGBENDGT | 2 | 61 | No Significant Output | |
| BGBENDGT | 3 | 61 | No Significant Output | |
| BRANDY B | 3 | 153 | 11,464 | 65.79 |
| CANE GT | 1 | 30 | 11,166 | 59.41 |
| CANE ISL | 2 | 108 | 9,581 | 49.24 |

| | | | | |
|----------|----|-----|-----------------------|-------|
| CAPECNVR | 1 | 405 | 9,444 | 48.37 |
| CAPECNVR | 2 | 408 | 9,444 | 48.47 |
| CUDJOE D | 1 | 5 | No Significant Output | |
| CUTLER | 5 | 71 | 11,721 | 52.49 |
| CUTLER | 6 | 144 | 11,734 | 52.59 |
| DEBARYGT | 1 | 54 | No Significant Output | |
| DEBARYGT | 2 | 54 | No Significant Output | |
| DEBARYGT | 3 | 54 | No Significant Output | |
| DEBARYGT | 4 | 54 | No Significant Output | |
| DEBARYGT | 5 | 54 | No Significant Output | |
| DEBARYGT | 6 | 54 | No Significant Output | |
| DEBARYGT | 7 | 88 | No Significant Output | |
| DEBARYGT | 8 | 88 | No Significant Output | |
| DEBARYGT | 9 | 88 | No Significant Output | |
| DEBARYGT | 10 | 88 | No Significant Output | |
| DEERHAVN | 1 | 85 | 10,609 | 52.93 |
| DRHVN GT | 1 | 18 | No Significant Output | |
| DRHVN GT | 2 | 18 | No Significant Output | |
| DRHVN GT | 3 | 75 | No Significant Output | |
| EVERGL T | 1 | 35 | No Significant Output | |
| EVERGL T | 2 | 35 | No Significant Output | |
| EVERGL T | 3 | 35 | No Significant Output | |
| EVERGL T | 4 | 35 | No Significant Output | |
| EVERGL T | 5 | 35 | No Significant Output | |
| EVERGL T | 6 | 35 | No Significant Output | |
| EVERGL T | 7 | 35 | No Significant Output | |
| EVERGL T | 8 | 35 | No Significant Output | |
| EVERGL T | 9 | 35 | No Significant Output | |
| EVERGL T | 10 | 35 | No Significant Output | |
| EVERGL T | 11 | 35 | No Significant Output | |
| EVERGL T | 12 | 35 | No Significant Output | |
| EVERGLDS | 1 | 221 | 9,546 | 44.78 |
| EVERGLDS | 2 | 221 | 9,551 | 44.71 |
| EVERGLDS | 3 | 375 | 9,897 | 45.90 |
| EVERGLDS | 4 | 410 | 9,892 | 45.91 |
| FTMYER T | 1 | 54 | No Significant Output | |
| FTMYER T | 2 | 54 | No Significant Output | |
| FTMYER T | 3 | 54 | No Significant Output | |
| FTMYER T | 4 | 54 | No Significant Output | |
| FTMYER T | 5 | 54 | No Significant Output | |
| FTMYER T | 6 | 54 | No Significant Output | |
| FTMYER T | 7 | 54 | No Significant Output | |
| FTMYER T | 8 | 54 | No Significant Output | |
| FTMYER T | 9 | 54 | No Significant Output | |
| FTMYER T | 10 | 54 | No Significant Output | |
| FTMYER T | 11 | 54 | No Significant Output | |

| | | | | |
|----------|----|-----|-----------------------|-------|
| FTMYER T | 12 | 54 | No Significant Output | |
| FTMYERCT | 13 | 153 | 11,343 | 61.30 |
| FTMYERCT | 14 | 153 | 11,355 | 61.33 |
| GANNONGT | 1 | 12 | No Significant Output | |
| HANSELCC | 2 | 48 | 9,777 | 53.15 |
| HANSELIC | 8 | 3 | 9,300 | 50.48 |
| HANSELIC | 14 | 2 | 9,300 | 50.50 |
| HANSELIC | 15 | 2 | 9,300 | 50.41 |
| HANSELIC | 16 | 2 | 9,300 | 50.51 |
| HANSELIC | 17 | 2 | 9,300 | 50.42 |
| HANSELIC | 18 | 2 | No Significant Output | |
| HANSELIC | 19 | 3 | No Significant Output | |
| HANSELIC | 20 | 3 | 9,300 | 50.40 |
| HARDEE | 1 | 224 | 7,300 | 39.97 |
| HARDEECT | 1 | 74 | 9,732 | 52.50 |
| HOPKINGT | 1 | 12 | No Significant Output | |
| HOPKINGT | 2 | 24 | No Significant Output | |
| HOPKINS | 1 | 75 | 11,386 | 54.86 |
| HOPKINS | 2 | 238 | 10,636 | 48.54 |
| IND RIVR | 1 | 88 | 10,026 | 49.15 |
| IND RIVR | 2 | 201 | 9,971 | 45.80 |
| IND RIVR | 3 | 319 | 10,463 | 48.23 |
| INDRVRGT | 1 | 37 | 11,540 | 60.96 |
| INDRVRGT | 2 | 37 | 11,540 | 61.06 |
| INDRVRGT | 3 | 108 | 11,100 | 59.03 |
| INDRVRGT | 4 | 108 | 11,100 | 59.15 |
| INTER GT | 1 | 47 | No Significant Output | |
| INTER GT | 2 | 47 | No Significant Output | |
| INTER GT | 3 | 47 | No Significant Output | |
| INTER GT | 4 | 47 | No Significant Output | |
| INTER GT | 5 | 47 | No Significant Output | |
| INTER GT | 6 | 47 | No Significant Output | |
| INTER GT | 7 | 83 | No Significant Output | |
| INTER GT | 8 | 83 | No Significant Output | |
| INTER GT | 9 | 83 | No Significant Output | |
| INTER GT | 10 | 83 | No Significant Output | |
| INTER GT | 11 | 143 | No Significant Output | |
| INTER GT | 12 | 76 | 12,568 | 69.17 |
| INTER GT | 13 | 76 | 12,583 | 69.28 |
| INTER GT | 14 | 76 | 12,567 | 69.23 |
| IVEY IC | 1 | 4 | 9,300 | 50.59 |
| IVEY IC | 2 | 5 | 9,300 | 50.60 |
| IVEY IC | 3 | 9 | 12,280 | 64.70 |
| IVEY IC | 4 | 6 | No Significant Output | |
| IVEY IC | 5 | 4 | 9,300 | 50.58 |
| IVEY IC | 6 | 18 | 9,300 | 50.58 |

| | | | | |
|----------|----|-----|-----------------------|-------|
| KELLY | 7 | 23 | 16,878 | 81.75 |
| KELLY GT | 1 | 14 | No Significant Output | |
| KELLY GT | 2 | 14 | No Significant Output | |
| KELLY GT | 3 | 14 | No Significant Output | |
| KENEDYGT | 3 | 54 | No Significant Output | |
| KENEDYGT | 4 | 54 | No Significant Output | |
| KENEDYGT | 5 | 54 | No Significant Output | |
| KENEDYGT | 7 | 153 | 11,306 | 65.11 |
| KING | 5 | 8 | 10,479 | 49.55 |
| KING | 6 | 17 | 12,844 | 60.53 |
| KING | 7 | 32 | 12,942 | 64.15 |
| KING | 8 | 50 | 12,728 | 61.06 |
| KING DSL | 1 | 5 | No Significant Output | |
| KING GT | 9 | 23 | 10,500 | 59.26 |
| LARSEN | 8 | 102 | 10,610 | 49.95 |
| LARSENGT | 2 | 10 | No Significant Output | |
| LARSENGT | 3 | 10 | No Significant Output | |
| LAUDER T | 1 | 36 | No Significant Output | |
| LAUDER T | 2 | 35 | No Significant Output | |
| LAUDER T | 3 | 35 | No Significant Output | |
| LAUDER T | 4 | 35 | No Significant Output | |
| LAUDER T | 5 | 35 | No Significant Output | |
| LAUDER T | 6 | 35 | No Significant Output | |
| LAUDER T | 7 | 35 | No Significant Output | |
| LAUDER T | 8 | 35 | No Significant Output | |
| LAUDER T | 9 | 35 | No Significant Output | |
| LAUDER T | 10 | 35 | No Significant Output | |
| LAUDER T | 11 | 35 | No Significant Output | |
| LAUDER T | 12 | 35 | No Significant Output | |
| LAUDER T | 13 | 35 | No Significant Output | |
| LAUDER T | 14 | 35 | No Significant Output | |
| LAUDER T | 15 | 35 | No Significant Output | |
| LAUDER T | 16 | 35 | No Significant Output | |
| LAUDER T | 17 | 35 | No Significant Output | |
| LAUDER T | 18 | 35 | No Significant Output | |
| LAUDER T | 19 | 35 | No Significant Output | |
| LAUDER T | 20 | 35 | No Significant Output | |
| LAUDER T | 21 | 35 | No Significant Output | |
| LAUDER T | 22 | 32 | No Significant Output | |
| LAUDER T | 23 | 32 | No Significant Output | |
| LAUDER T | 24 | 35 | No Significant Output | |
| LAUDERCC | 4 | 440 | 7,667 | 38.21 |
| LAUDERCC | 5 | 440 | 7,680 | 38.95 |
| MANATEE | 1 | 819 | 9,857 | 46.72 |
| MANATEE | 2 | 819 | 9,695 | 45.92 |
| MARATHON | 1 | 8 | No Significant Output | |

| | | | | |
|----------|---|-----|-----------------------|-------|
| MARATHON | 2 | 5 | 9,300 | 50.59 |
| MARATHON | 3 | 8 | 12,280 | 64.24 |
| MARTIN | 1 | 814 | 8,941 | 42.10 |
| MARTIN | 2 | 816 | 8,970 | 42.34 |
| MARTINCC | 3 | 445 | 7,263 | 36.26 |
| MARTINCC | 4 | 445 | 7,265 | 36.26 |
| MARTINCT | 1 | 153 | 11,327 | 61.28 |
| MARTINCT | 2 | 153 | 11,335 | 61.29 |
| MCINT GT | 1 | 17 | No Significant Output | |
| MCINT IC | 1 | 5 | No Significant Output | |
| MCINTOSH | 1 | 87 | 10,814 | 50.91 |
| MCINTOSH | 2 | 103 | 10,282 | 47.50 |
| MCINTOSH | 5 | 310 | 7,460 | 35.57 |
| NORTH GT | 3 | 52 | No Significant Output | |
| NORTH GT | 4 | 52 | No Significant Output | |
| NORTH GT | 5 | 52 | No Significant Output | |
| NORTH GT | 6 | 52 | No Significant Output | |
| NORTHSID | 3 | 505 | 9,653 | 50.48 |
| OLEAN GT | 1 | 153 | 11,364 | 61.32 |
| OLEAN GT | 2 | 153 | 11,345 | 61.24 |
| OLEAN GT | 3 | 153 | 11,352 | 61.25 |
| OLEAN GT | 4 | 153 | 11,367 | 61.24 |
| OLEAN GT | 5 | 153 | 11,366 | 61.31 |
| PHILLIPS | 1 | 17 | 13,500 | 65.92 |
| PHILLIPS | 2 | 17 | 13,500 | 65.92 |
| POLK CT | 2 | 153 | 11,353 | 63.94 |
| POLK CT | 3 | 153 | 11,368 | 63.99 |
| POLK CT | 4 | 153 | 11,393 | 64.00 |
| POLK CT | 5 | 153 | 11,345 | 63.89 |
| POLK CT | 6 | 153 | 11,336 | 63.85 |
| POLKIGCC | 1 | 250 | 10,267 | 35.35 |
| PURDOM | 7 | 48 | 18,726 | 87.68 |
| PURDOMGT | 1 | 0 | No Significant Output | |
| PURDOMGT | 2 | 12 | No Significant Output | |
| PUTNAMCC | 1 | 249 | 9,114 | 45.67 |
| PUTNAMCC | 2 | 249 | 9,110 | 45.70 |
| REEDYCRK | 1 | 35 | 10,400 | 53.12 |
| RIVIERA | 3 | 290 | 9,728 | 43.93 |
| RIVIERA | 4 | 290 | 9,738 | 44.25 |
| SANFORD | 3 | 153 | 8,877 | 47.44 |
| SEM CT | 1 | 153 | 11,383 | 64.07 |
| SEM CT | 2 | 153 | 11,422 | 64.21 |
| SEM CT | 3 | 153 | 11,375 | 64.01 |
| SMITH | 1 | 7 | No Significant Output | |
| SMITH | 2 | 7 | No Significant Output | |
| SMITH | 3 | 22 | 16,685 | 82.15 |

| | | | | |
|----------|---|-----|-----------------------|-------|
| SMITH | 4 | 32 | 16,495 | 81.24 |
| SMITH D | 1 | 9 | No Significant Output | |
| SMITH CC | 1 | 32 | 10,400 | 56.17 |
| SMITH GT | 1 | 26 | No Significant Output | |
| SMITH ST | 1 | 3 | No Significant Output | |
| SMITH ST | 2 | 2 | No Significant Output | |
| SMITH ST | 3 | 6 | No Significant Output | |
| ST CLOUD | 1 | 4 | No Significant Output | |
| ST CLOUD | 2 | 6 | No Significant Output | |
| ST CLOUD | 3 | 6 | No Significant Output | |
| ST CLOUD | 4 | 12 | No Significant Output | |
| STOCK DS | 1 | 9 | No Significant Output | |
| STOCK DS | 2 | 9 | No Significant Output | |
| STOCK GT | 1 | 21 | No Significant Output | |
| STOCK GT | 2 | 16 | No Significant Output | |
| STOCK GT | 3 | 16 | No Significant Output | |
| STOCK IC | 1 | 6 | No Significant Output | |
| SUWAN GT | 1 | 54 | No Significant Output | |
| SUWAN GT | 2 | 54 | No Significant Output | |
| SUWAN GT | 3 | 54 | No Significant Output | |
| SWOOPEIC | 1 | 5 | No Significant Output | |
| TIGERBAY | 1 | 194 | 7,577 | 37.45 |
| TURKEYIC | 1 | 14 | No Significant Output | |
| TURKEYPT | 1 | 410 | 9,406 | 46.87 |
| TURKEYPT | 2 | 400 | 9,420 | 46.90 |
| TURNERGT | 3 | 65 | No Significant Output | |
| TURNERGT | 4 | 65 | No Significant Output | |
| UNIV FLA | 1 | 36 | 11,166 | 58.41 |
| VERO BCH | 1 | 13 | 13,115 | 61.76 |
| VERO BCH | 2 | 13 | 8,931 | 42.62 |
| VERO BCH | 3 | 33 | 13,164 | 63.46 |
| VERO BCH | 4 | 56 | 11,785 | 56.74 |
| VERO BCH | 5 | 35 | 11,183 | 53.25 |

NUGs

| | | | | |
|----------|---|-----|--|--|
| AS-AVAIL | 1 | 63 | | |
| BAY CTY | 1 | 11 | | |
| BROWARDS | 1 | 54 | | |
| BROWARDS | 2 | 56 | | |
| CARGILL | 2 | 15 | | |
| CEDARBAY | 1 | 250 | | |
| CFRBIIGN | 1 | 74 | | |
| DADE CTY | 1 | 43 | | |
| ELDORADO | 1 | 114 | | |
| HILLSBOR | 1 | 26 | | |

| | | |
|----------|---|-----|
| INDIANTN | 1 | 330 |
| LAKE CTY | 1 | 13 |
| LAKECOGN | 1 | 110 |
| LFC JEFF | 1 | 9 |
| LFC MADS | 1 | 9 |
| MULB-FPC | 1 | 79 |
| ORANGE | 1 | 22 |
| ORLANDO | 1 | 79 |
| PALMBCH | 1 | 44 |
| PASCO | 1 | 109 |
| PASCOCTY | 1 | 23 |
| PINELLAS | 1 | 40 |
| PINELLAS | 2 | 15 |
| RIDGE | 1 | 40 |
| ROYSTER | 1 | 31 |
| TAMPACTY | 1 | 19 |
| JEA-QFs | | 17 |

External Purchases

| | | |
|--------------|---|------|
| ENTERGY | 1 | 23 |
| SOUTHERN CO. | | 1615 |

Source: PROMOD IV(R) analyses prepared by Slater Consulting.

**PENINSULAR FLORIDA
 SUMMARY OF EXISTING CAPACITY
 AS OF JANUARY 1, 2000**

| UTILITY | NET CAPABILITY | |
|---|----------------|---------------|
| | SUMMER | WINTER |
| FLORIDA KEYS ELECTRIC COOPERATIVE ASSOC., INC 1/ | 22 | 22 |
| FLORIDA MUNICIPAL POWER AGENCY 2/ | 488 | 513 |
| FLORIDA POWER CORPORATION 2/ | 7,659 | 8,267 |
| FLORIDA POWER & LIGHT COMPANY 2/ | 16,444 | 17,234 |
| FORT PIERCE UTILITIES AUTHORITY 1/ | 119 | 119 |
| GAINESVILLE REGIONAL UTILITIES 2/ | 550 | 563 |
| CITY OF HOMESTEAD 1/ | 60 | 60 |
| JACKSONVILLE ELECTRIC AUTHORITY 2/ | 2,629 | 2,734 |
| UTILITY BOARD OF THE CITY OF KEY WEST 1/ | 52 | 52 |
| KISSIMMEE UTILITY AUTHORITY 2/ | 172 | 188 |
| CITY OF LAKELAND 2/ | 614 | 649 |
| CITY OF LAKE WORTH UTILITIES 1/ | 95 | 105 |
| UTILITIES COMMISSION OF NEW SMYRNA BEACH 2/ | 24 | 24 |
| OCALA ELECTRIC UTILITY 1/ | 11 | 11 |
| ORLANDO UTILITIES COMMISSION 2/ | 1,024 | 1,071 |
| REEDY CREEK IMPROVEMENT DISTRICT 1/ | 48 | 49 |
| SEMINOLE ELECTRIC COOPERATIVE INC. 2/ | 1,331 | 1,345 |
| CITY OF ST. CLOUD 1/ | 22 | 21 |
| CITY OF TALLAHASSEE 2/ | 429 | 449 |
| TAMPA ELECTRIC COMPANY 2/ | 3,469 | 3,608 |
| CITY OF VERO BEACH 1/ | 150 | 155 |
| TOTALS | | |
| FRCC UTILITIES EXISTING CAPACITY | 35,412 | 37,239 |
| NON-UTILITY GENERATING FACILITIES (FIRM) | 1,763 | 1,763 |
| NON-UTILITY GENERATING FACILITIES (NON-FIRM) | 97 | 119 |
| TOTAL PENINSULAR FLORIDA EXISTING CAPACITY | 37,272 | 39,121 |

Data Source:

Florida Reliability Coordinating Council

1/ 1999 Regional Load & Resource Plan, Peninsular Florida, July 1999

2/ The net capability values for the summer and winter of 2000 were taken from Schedule 1 of the respective utilities' ten-year site plans filed in April 2000.

**PENNINSULAR FLORIDA, HISTORICAL AND
 PROJECTED SUMMER AND WINTER
 FIRM PEAK DEMANDS**

1999-2012

ACTUAL PEAK DEMAND (MW)

| | 1991 | 1992 | 1993 | 1994 | 1995 | 1996 | 1997 | 1998 |
|---------------|--------|--------|--------|--------|--------|--------|--------|--------|
| SUMMER | 27,662 | 28,930 | 29,748 | 29,321 | 31,801 | 32,315 | 32,924 | 37,153 |
| WINTER | 28,179 | 27,215 | 28,149 | 32,618 | 34,552 | 34,762 | 30,932 | 35,907 |

PROJECTED FIRM PEAK DEMAND (MW)

| | 1999 | 2000 | 2001 | 2002 | 2003 | 2004 | 2005 | 2006 |
|---------------|--------|--------|--------|--------|--------|--------|--------|--------|
| SUMMER | 34,023 | 34,703 | 35,380 | 36,157 | 36,988 | 37,804 | 38,638 | 39,597 |
| WINTER | 35,977 | 36,819 | 37,793 | 38,749 | 39,663 | 40,566 | 41,450 | 42,476 |

PROJECTED FIRM PEAK DEMAND (MW)

| | 2007 | 2008 | 2009 | 2010 | 2011 | 2012 |
|---------------|--------|--------|--------|--------|--------|--------|
| SUMMER | 40,443 | 41,266 | 42,181 | 43,117 | 44,073 | 45,050 |
| WINTER | 43,374 | 44,286 | 45,274 | 46,284 | 47,316 | 48,372 |

Data Source:

Florida Reliability Coordinating Council,
 1991-2008 values, 1999 Regional Load & Resource Plan, Peninsular Florida, July 1999.
 2009-2012 values extrapolated at the FRCC projected average annual compound growth rates for 2005-2008.

**PENINSULAR FLORIDA, HISTORICAL AND
 PROJECTED NET ENERGY FOR LOAD
 AND NUMBER OF CUSTOMERS**

1991-2012

ACTUAL NET ENERGY FOR LOAD (GWH)

| | 1991 | 1992 | 1993 | 1994 | 1995 | 1996 | 1997 | 1998 |
|--------------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| ENERGY | 146,786 | 147,728 | 153,269 | 159,353 | 168,982 | 173,327 | 175,534 | 187,868 |
| LOAD FACTOR | 59.46% | 58.13% | 58.82% | 55.77% | 55.83% | 56.76% | 60.86% | 57.72% |
| CUSTOMERS | 6,155,380 | 6,269,358 | 6,410,797 | 6,550,760 | 6,687,155 | 6,812,603 | 6,948,888 | 7,091,803 |

PROJECTED NET ENERGY FOR LOAD (GWH)

| | 1999 | 2000 | 2001 | 2002 | 2003 | 2004 | 2005 | 2006 |
|--------------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| ENERGY | 186,374 | 196,094 | 200,772 | 203,922 | 208,800 | 213,424 | 217,791 | 222,299 |
| LOAD FACTOR | 59.25% | 60.63% | 60.64% | 60.08% | 60.10% | 59.89% | 59.98% | 59.74% |
| CUSTOMERS | 7,232,307 | 7,375,121 | 7,518,019 | 7,657,962 | 7,795,163 | 7,930,202 | 8,062,647 | 8,194,144 |

PROJECTED NET ENERGY FOR LOAD (GWH)

| | 2007 | 2008 | 2009 | 2010 | 2011 | 2012 |
|--------------------|-----------|-----------|-----------|-----------|-----------|-----------|
| ENERGY | 226,565 | 230,447 | 234,645 | 238,924 | 243,289 | 247,742 |
| LOAD FACTOR | 59.63% | 59.24% | 59.16% | 58.93% | 58.70% | 58.31% |
| CUSTOMERS | 8,325,881 | 8,458,099 | 8,594,181 | 8,732,452 | 8,872,947 | 9,015,703 |

Data Source:

Florida Reliability Coordinating Council,
 1991-1999 Energy values, 1999 Regional Load & Resource Plan, Peninsular Florida, July 1999.
 2000-2012 Energy values obtained from PROMOD IV(R) analyses prepared by Slater Consulting.
 Load factor values were calculated from these energy values and the peak demand values in Table 4.
 1991-2008 Customer values, 1999 Regional Load & Resource Plan, Peninsular Florida, July 1999.
 2009-2012 Customer values extrapolated at the FRCC projected average annual compound growth rates for 2005-2008.

**OSPREY ENERGY CENTER
SUMMARY OF PROJECTED OPERATIONS
2003-2012**

| <u>Year</u> | <u>PROJECTED GENERATION (GWH)</u> | <u>ANNUAL CAPACITY FACTOR %</u> |
|-------------|---|---|
| 2003 | 2,624 | 95.5% |
| 2004 | 4,379 | 92.7% |
| 2005 | 4,293 | 91.1% |
| 2006 | 4,279 | 90.8% |
| 2007 | 4,333 | 92.0% |
| 2008 | 4,254 | 90.0% |
| 2009 | 4,172 | 88.6% |
| 2010 | 4,301 | 91.3% |
| 2011 | 4,070 | 86.4% |
| 2012 | 4,389 | 92.9% |

Source: PROMOD IV(R) analyses prepared by Slater Consulting.

Note: The Project is scheduled to come into service on June 1, 2003. The annual capacity factor reported for 2003 is calculated on the basis of the Project's operations for the period June 1 - December 31, 2003.

OSPREY ENERGY CENTER
SUMMARY OF PROJECTED OPERATIONS, 2003-2012
HIGHER NATURAL GAS PRICE SENSITIVITY ANALYSIS

| <u>Year</u> | <u>PROJECTED GENERATION (GWH)</u> | <u>ANNUAL CAPACITY FACTOR %</u> |
|-------------|---|---|
| 2003 | 2,616 | 95.1% |
| 2004 | 4,351 | 92.1% |
| 2005 | 4,264 | 90.5% |
| 2006 | 4,229 | 89.8% |
| 2007 | 4,266 | 90.6% |
| 2008 | 4,149 | 87.8% |
| 2009 | 4,066 | 86.3% |
| 2010 | 4,161 | 88.3% |
| 2011 | 3,935 | 83.5% |
| 2012 | 4,265 | 90.3% |

Source: PROMOD IV(R) analyses prepared by Slater Consulting.

Notes: (1) The Project is scheduled to come into service on June 1, 2003. The annual capacity factor reported for 2003 is calculated on the basis of the Project's operations for the period June 1 - December 31, 2003.

(2) The Base Case fuel price projections were developed by Slater Consulting based on actual data and the U. S. Energy Information Administration's 2000 Annual Energy Outlook Reference Case Forecast, but with the natural gas price escalations moderated to be more in keeping with the Standard & Poor's DRI forecast, which was included in the EIA's publication as a comparison forecast. The fuel prices for this sensitivity case were the same as for the Base Case except that the prices of natural gas were projected to escalate at the growth rates projected in the EIA Reference Case Forecast.


**OSPREY ENERGY CENTER
SUMMARY OF PROJECTED OPERATIONS
LOAD GROWTH SENSITIVITY ANALYSES, 2003-2012**

| Year | LOW LOAD GROWTH | | BASE LOAD | | HIGH LOAD GROWTH | |
|------|----------------------------------|--------------------------------|----------------------------------|--------------------------------|----------------------------------|--------------------------------|
| | PROJECTED GENERATION (GWH) | ANNUAL CAPACITY FACTOR % | PROJECTED GENERATION (GWH) | ANNUAL CAPACITY FACTOR % | PROJECTED GENERATION (GWH) | ANNUAL CAPACITY FACTOR % |
| 2003 | 2,622 | 95.4% | 2,624 | 95.5% | 2,633 | 95.8% |
| 2004 | 4,364 | 92.4% | 4,379 | 92.7% | 4,400 | 93.1% |
| 2005 | 4,279 | 90.8% | 4,293 | 91.1% | 4,307 | 91.4% |
| 2006 | 4,270 | 90.6% | 4,279 | 90.8% | 4,214 | 89.4% |
| 2007 | 4,139 | 87.9% | 4,333 | 92.0% | 4,441 | 94.3% |
| 2008 | 4,402 | 93.2% | 4,254 | 90.0% | 4,032 | 85.4% |
| 2009 | 4,065 | 86.3% | 4,172 | 88.6% | 4,365 | 92.7% |
| 2010 | 4,357 | 92.5% | 4,301 | 91.3% | 4,267 | 90.6% |
| 2011 | 4,216 | 89.5% | 4,070 | 86.4% | 4,284 | 90.9% |
| 2012 | 4,190 | 88.7% | 4,389 | 92.9% | 4,455 | 94.3% |


Source: PROMOD IV(R) analyses prepared by Slater Consulting.

Assumptions: The Base Case scenario was developed by Slater Consulting based on actual data and consideration of published sources, including the 1999 FRCC Regional Load & Resource Plan and Florida utilities' 2000 ten-year site plans. The Low Load Growth scenario reflects growth rates 0.5 percent per year less than in the Base Case. The High Load Growth scenario reflects growth rates 1.0 percent per year greater than in the Base Case.


PENINSULAR FLORIDA GENERATION - WITHOUT OSPREY
Weekday June 2005




PENINSULAR FLORIDA GENERATION - WITH OSPREY
Weekday June 2005



PENINSULAR FLORIDA GENERATION - WITHOUT OSPREY
Weekday December 2005



PENINSULAR FLORIDA GENERATION - WITH OSPREY
Weekday December 2005



Market Indicators

| NERC Region | | MONTHLY TRENDS | | | Dec. 1998 | Year Ago Percent Change | JANUARY through DECEMBER | | | 1998-1999 Percent Change |
|--|---------------------------|----------------|-----------|-----------|-----------|-------------------------|--------------------------|---------|---------|--------------------------|
| | | Oct. 1999 | Nov. 1999 | Dec. 1999 | | | 1997 | 1998 | 1999 | |
| NPCC  | Electric Generation (gWh) | 16,900 | 17,277 | 18,876 | 14,917 | 26.54% | 182,537 | 182,468 | 231,281 | 26.75% |
| | Production Costs (¢/kWh) | 2.41 | 2.35 | 2.28 | 2.36 | -3.22% | 2.48 | 2.30 | 2.39 | 3.65% |
| | Retail Rates (¢/kWh) | 10.19 | 9.83 | 9.65 | 10.09 | -2.58% | 10.81 | 10.45 | 10.11 | -3.25% |
| MAAC  | Electric Generation (gWh) | 18,924 | 18,925 | 18,789 | 19,777 | -5.00% | 210,399 | 228,685 | 252,746 | 10.52% |
| | Production Costs (¢/kWh) | 2.28 | 2.19 | 2.21 | 1.83 | 20.45% | 2.11 | 1.91 | 2.23 | 16.60% |
| | Retail Rates (¢/kWh) | 7.53 | 7.35 | 7.41 | 8.18 | -10.15% | 8.86 | 8.69 | 8.09 | -6.90% |
| SERC  | Electric Generation (gWh) | 62,249 | 58,045 | 65,901 | 61,472 | 7.20% | 734,118 | 763,603 | 793,411 | 3.90% |
| | Production Costs (¢/kWh) | 1.76 | 1.77 | 1.72 | 1.72 | 0.06% | 1.79 | 1.78 | 1.76 | -0.96% |
| | Retail Rates (¢/kWh) | 5.71 | 5.50 | 5.53 | 5.49 | 0.18% | 5.81 | 5.77 | 5.71 | -1.04% |
| FRCC  | Electric Generation (gWh) | 14,169 | 12,328 | 12,908 | 11,963 | 7.90% | 141,111 | 160,611 | 173,061 | 7.75% |
| | Production Costs (¢/kWh) | 2.89 | 2.76 | 2.43 | 2.33 | 4.37% | 2.67 | 2.39 | 2.59 | 8.40% |
| | Retail Rates (¢/kWh) | 6.88 | 6.90 | 6.85 | 7.06 | -2.27% | 7.30 | 7.13 | 6.96 | -2.38% |
| ECAR  | Electric Generation (gWh) | 44,321 | 43,829 | 48,515 | 44,598 | 8.78% | 529,312 | 526,524 | 560,974 | 6.54% |
| | Production Costs (¢/kWh) | 2.17 | 2.14 | 2.13 | 1.87 | 13.63% | 1.86 | 1.87 | 2.12 | 13.83% |
| | Retail Rates (¢/kWh) | 5.97 | 5.91 | 5.86 | 5.89 | 0.34% | 6.03 | 5.98 | 6.01 | 0.50% |
| MAIN  | Electric Generation (gWh) | 19,231 | 18,992 | 20,268 | 19,895 | 1.88% | 216,491 | 222,092 | 252,018 | 13.47% |
| | Production Costs (¢/kWh) | 1.87 | 1.88 | 1.79 | 1.99 | -10.12% | 2.09 | 2.05 | 1.84 | -10.42% |
| | Retail Rates (¢/kWh) | 6.22 | 5.98 | 5.93 | 6.40 | -6.56% | 6.78 | 6.75 | 6.43 | -4.74% |
| MAPP  | Electric Generation (gWh) | 13,282 | 12,703 | 14,241 | 13,496 | 5.52% | 151,337 | 153,972 | 161,491 | 4.88% |
| | Production Costs (¢/kWh) | 1.35 | 1.37 | 1.39 | 1.44 | -3.41% | 1.50 | 1.51 | 1.42 | -5.77% |
| | Retail Rates (¢/kWh) | 5.50 | 5.57 | 5.62 | 5.49 | 1.46% | 5.68 | 5.75 | 5.79 | 0.70% |
| ERCOT  | Electric Generation (gWh) | 22,973 | 20,370 | 22,048 | 17,796 | 23.89% | 226,751 | 240,026 | 287,310 | 19.70% |
| | Production Costs (¢/kWh) | 2.54 | 2.40 | 2.33 | 1.98 | 18.18% | 2.13 | 2.12 | 2.41 | 13.62% |
| | Retail Rates (¢/kWh) | 6.50 | 5.88 | 5.75 | 5.75 | 2.26% | 6.18 | 6.12 | 6.09 | -0.49% |
| SPP  | Electric Generation (gWh) | 15,144 | 14,715 | 16,133 | 13,562 | 18.95% | 164,934 | 174,334 | 200,862 | 15.22% |
| | Production Costs (¢/kWh) | 2.12 | 2.08 | 2.06 | 1.80 | 14.33% | 1.98 | 1.89 | 2.11 | 11.14% |
| | Retail Rates (¢/kWh) | 5.45 | 5.08 | 5.07 | 5.11 | -0.59% | 5.60 | 5.58 | 5.52 | -1.08% |
| WSCC  | Electric Generation (gWh) | 51,552 | 49,931 | 53,929 | 48,391 | 11.44% | 561,608 | 551,533 | 628,226 | 13.91% |
| | Production Costs (¢/kWh) | 1.86 | 1.67 | 1.58 | 1.47 | 7.28% | 1.56 | 1.50 | 1.60 | 6.87% |
| | Retail Rates (¢/kWh) | 7.30 | 6.64 | 6.75 | 6.56 | 7.11% | 7.18 | 6.95 | 6.89 | -0.86% |

Source: POWERdat Database. POWERdat is a registered trademark of Resource Data International Inc. (RDI) • Boulder, Colo. • 303-444-7788. ©2000 All rights reserved. Note: Monthly production costs are estimated using current fuel prices and most recently reported nonfuel O&M costs for all regulated companies (IOUs, munis, co-ops & federal).

**PENINSULAR FLORIDA, IMPACTS OF OSPREY ENERGY CENTER
ON AVERAGE ELECTRICITY GENERATION HEAT RATES AND
TOTAL FUEL CONSUMPTION, 2003-2012**

| <u>Year</u> | <u>Average Heat Rate (btu/kwh)</u> | | | <u>Total Primary Energy (1000*mmbtu)</u> | | <u>Osprey Net Energy</u> |
|-------------|------------------------------------|------------------------|-------------------|--|------------------------|---------------------------------|
| | <u>Without Osprey</u> | <u>With Osprey</u> | <u>Difference</u> | <u>Without Osprey</u> | <u>With Osprey</u> | <u>Savings (1000*mmbtu)</u> |
| 2003 | 8,864.4 | 8,837.4 | 27.0 | 1,850,893 | 1,845,257 | 5,636 |
| 2004 | 8,781.6 | 8,737.8 | 43.7 | 1,874,198 | 1,864,864 | 9,334 |
| 2005 | 8,747.8 | 8,707.6 | 40.2 | 1,905,197 | 1,896,431 | 8,766 |
| 2006 | 8,662.8 | 8,626.6 | 36.2 | 1,925,724 | 1,917,686 | 8,038 |
| 2007 | 8,606.0 | 8,567.4 | 38.7 | 1,949,829 | 1,941,069 | 8,760 |
| 2008 | 8,576.2 | 8,540.5 | 35.7 | 1,976,351 | 1,968,125 | 8,226 |
| 2009 | 8,536.7 | 8,512.4 | 24.3 | 2,003,095 | 1,997,395 | 5,700 |
| 2010 | 8,546.1 | 8,518.9 | 27.3 | 2,041,883 | 2,035,372 | 6,511 |
| 2011 | 8,553.6 | 8,517.0 | 36.6 | 2,081,005 | 2,072,094 | 8,911 |
| 2012 | 8,575.3 | 8,540.2 | 35.1 | 2,124,464 | 2,115,761 | 8,703 |

Source: PROMOD IV(R) analyses prepared by Slater Consulting.

PENINSULAR FLORIDA FUEL CONSUMPTION IMPACTS OF OSPREY ENERGY CENTER, 2003-2012

(All Values in MMBtu)

| Year | <u>Nuclear</u> | | | <u>Coal and Other Solid Fuels</u> | | | <u>Natural Gas</u> | | | <u>No. 6 Oil</u> | | | <u>No. 2 Oil</u> | | |
|------|---------------------------|------------------------|-------------------------|-----------------------------------|------------------------|-------------------------|---------------------------|------------------------|-------------------------|---------------------------|------------------------|-------------------------|---------------------------|------------------------|-------------------------|
| | <u>Without Osprey</u> | <u>With Osprey</u> | <u>Differ- ence</u> | <u>Without Osprey</u> | <u>With Osprey</u> | <u>Differ- ence</u> | <u>Without Osprey</u> | <u>With Osprey</u> | <u>Differ- ence</u> | <u>Without Osprey</u> | <u>With Osprey</u> | <u>Differ- ence</u> | <u>Without Osprey</u> | <u>With Osprey</u> | <u>Differ- ence</u> |
| 2003 | 295,404 | 295,404 | 0 | 769,940 | 766,231 | 3,709 | 663,815 | 669,766 | (5,951) | 118,105 | 110,713 | 7,392 | 3,629 | 3,143 | 486 |
| 2004 | 321,616 | 321,616 | 0 | 754,909 | 740,695 | 14,214 | 704,970 | 723,490 | (18,520) | 89,530 | 76,408 | 13,122 | 3,173 | 2,655 | 518 |
| 2005 | 316,996 | 316,996 | 0 | 751,478 | 743,067 | 8,411 | 745,061 | 755,649 | (10,588) | 88,372 | 77,868 | 10,504 | 3,290 | 2,851 | 439 |
| 2006 | 303,928 | 303,928 | 0 | 743,161 | 733,395 | 9,766 | 791,044 | 801,777 | (10,733) | 84,927 | 76,126 | 8,801 | 2,664 | 2,460 | 204 |
| 2007 | 312,117 | 312,117 | 0 | 716,668 | 705,680 | 10,988 | 829,301 | 846,518 | (17,217) | 89,310 | 74,427 | 14,883 | 2,433 | 2,327 | 106 |
| 2008 | 326,697 | 326,697 | 0 | 711,361 | 703,313 | 8,048 | 863,388 | 874,371 | (10,983) | 72,295 | 61,396 | 10,899 | 2,610 | 2,348 | 262 |
| 2009 | 294,962 | 294,962 | 0 | 716,748 | 712,157 | 4,591 | 897,024 | 905,427 | (8,403) | 91,584 | 82,485 | 9,099 | 2,777 | 2,364 | 413 |
| 2010 | 321,069 | 321,069 | 0 | 716,779 | 708,527 | 8,252 | 917,233 | 927,076 | (9,843) | 84,616 | 76,538 | 8,078 | 2,186 | 2,162 | 24 |
| 2011 | 316,945 | 316,945 | 0 | 723,043 | 709,318 | 13,725 | 937,705 | 952,935 | (15,230) | 100,807 | 90,683 | 10,124 | 2,505 | 2,213 | 292 |
| 2012 | 331,247 | 331,247 | 0 | 734,896 | 723,896 | 11,000 | 946,332 | 957,427 | (11,095) | 108,899 | 100,566 | 8,333 | 3,090 | 2,625 | 465 |

Source: PROMOD IV(R) analyses prepared by Slater Consulting.

PENINSULAR FLORIDA, FUEL CONSUMPTION IMPACTS OF OSPREY ENERGY CENTER, 2003-2012

(All Values in GWh)

| <u>Year</u> | <u>Nuclear</u> | | | <u>Coal and Other Solid Fuels</u> | | | <u>Natural Gas</u> | | | <u>No. 6 Oil</u> | | | <u>No. 2 Oil</u> | | |
|-------------|---------------------------|------------------------|-------------------------|-----------------------------------|------------------------|-------------------------|---------------------------|------------------------|-------------------------|---------------------------|------------------------|-------------------------|---------------------------|------------------------|-------------------------|
| | <u>Without Osprey</u> | <u>With Osprey</u> | <u>Differ- ence</u> | <u>Without Osprey</u> | <u>With Osprey</u> | <u>Differ- ence</u> | <u>Without Osprey</u> | <u>With Osprey</u> | <u>Differ- ence</u> | <u>Without Osprey</u> | <u>With Osprey</u> | <u>Differ- ence</u> | <u>Without Osprey</u> | <u>With Osprey</u> | <u>Differ- ence</u> |
| 2003 | 28,539 | 28,539 | 0 | 79,879 | 79,444 | 435 | 87,441 | 88,664 | (1,223) | 12,061 | 11,331 | 730 | 357 | 311 | 46 |
| 2004 | 31,071 | 31,071 | 0 | 78,413 | 76,929 | 1,484 | 94,014 | 96,914 | (2,900) | 9,169 | 7,831 | 1,338 | 310 | 263 | 47 |
| 2005 | 30,625 | 30,625 | 0 | 78,211 | 77,290 | 921 | 99,111 | 101,185 | (2,074) | 9,076 | 7,995 | 1,081 | 318 | 278 | 40 |
| 2006 | 29,362 | 29,362 | 0 | 77,429 | 76,407 | 1,022 | 106,125 | 108,042 | (1,917) | 8,702 | 7,840 | 862 | 262 | 243 | 19 |
| 2007 | 30,153 | 30,153 | 0 | 74,651 | 73,490 | 1,161 | 111,992 | 114,720 | (2,728) | 9,139 | 7,641 | 1,498 | 242 | 231 | 11 |
| 2008 | 31,562 | 31,562 | 0 | 74,029 | 73,254 | 775 | 116,868 | 118,757 | (1,889) | 7,394 | 6,328 | 1,066 | 256 | 232 | 24 |
| 2009 | 28,496 | 28,496 | 0 | 74,744 | 74,131 | 613 | 121,351 | 122,947 | (1,596) | 9,385 | 8,471 | 914 | 271 | 234 | 37 |
| 2010 | 31,018 | 31,018 | 0 | 74,622 | 73,742 | 880 | 124,057 | 125,815 | (1,758) | 8,652 | 7,832 | 820 | 209 | 204 | 5 |
| 2011 | 30,620 | 30,620 | 0 | 75,216 | 73,803 | 1,413 | 126,515 | 129,017 | (2,502) | 10,292 | 9,271 | 1,021 | 235 | 207 | 28 |
| 2012 | 32,001 | 32,001 | 0 | 76,502 | 75,472 | 1,030 | 127,443 | 129,382 | (1,939) | 11,093 | 10,254 | 839 | 291 | 247 | 44 |

Source: PROMOD IV(R) analyses prepared by Slater Consulting.

**PENINSULAR FLORIDA, SUMMARY OF PROJECTED WHOLESALE ENERGY
COST SAVINGS DUE TO OSPREY ENERGY CENTER,
BASE CASE, 2003-2012**

| <u>YEAR</u> | <u>FRCC NET ENERGY FOR LOAD (GWH)</u> | <u>AVERAGE ANNUAL MARGINAL ENERGY COST WITH OSPREY (\$/MWH)</u> | <u>AVERAGE ANNUAL MARGINAL ENERGY COST WITHOUT OSPREY (\$/MWH)</u> | <u>WHOLESALE PRICE SUPPRESSION (\$/MWH)</u> | <u>ESTIMATED SAVINGS FROM OSPREY (\$MILLION)</u> | <u>CUMULATIVE NPV @ 10% 2000 DOLLARS (\$MILLION)</u> |
|-------------|---|---|--|---|--|--|
| 2003 | 208,800 | 32.83 | 33.37 | 0.54 | 113 | 85 |
| 2004 | 213,424 | 31.81 | 32.55 | 0.74 | 158 | 193 |
| 2005 | 217,791 | 32.92 | 33.67 | 0.75 | 163 | 294 |
| 2006 | 222,299 | 33.36 | 33.96 | 0.60 | 133 | 369 |
| 2007 | 226,565 | 33.75 | 34.48 | 0.73 | 165 | 454 |
| 2008 | 230,447 | 34.34 | 34.96 | 0.62 | 143 | 521 |
| 2009 | 234,645 | 35.85 | 36.60 | 0.75 | 176 | 595 |
| 2010 | 238,924 | 36.77 | 37.51 | 0.74 | 177 | 664 |
| 2011 | 243,289 | 38.81 | 39.65 | 0.84 | 204 | 735 |
| 2012 | 247,742 | 40.27 | 41.02 | 0.75 | 186 | 794 |

Source: PROMOD IV(R) analyses prepared by Slater Consulting.

**PENINSULAR FLORIDA, SUMMARY OF PROJECTED WHOLESALE ENERGY
COST SAVINGS DUE TO OSPREY ENERGY CENTER,
HIGHER FUEL PRICE SENSITIVITY CASE, 2003-2012**

| YEAR | FRCC NET ENERGY FOR LOAD (GWH) | AVERAGE ANNUAL MARGINAL ENERGY COST WITH OSPREY (\$/MWH) | AVERAGE ANNUAL MARGINAL ENERGY COST WITHOUT OSPREY (\$/MWH) | WHOLESALE PRICE SUPPRESSION (\$/MWH) | ESTIMATED SAVINGS FROM OSPREY (\$MILLION) | CUMULATIVE NPV @ 10% 2000 DOLLARS (\$MILLION) |
|-------------|---|---|--|---|--|--|
| 2003 | 208,800 | 32.88 | 33.43 | 0.55 | 115 | 86 |
| 2004 | 213,424 | 31.92 | 32.59 | 0.67 | 143 | 184 |
| 2005 | 217,791 | 33.06 | 33.81 | 0.75 | 163 | 285 |
| 2006 | 222,299 | 33.71 | 34.35 | 0.64 | 142 | 366 |
| 2007 | 226,565 | 34.49 | 35.22 | 0.73 | 165 | 451 |
| 2008 | 230,447 | 35.43 | 36.09 | 0.66 | 152 | 522 |
| 2009 | 234,645 | 37.29 | 38.03 | 0.74 | 174 | 595 |
| 2010 | 238,924 | 38.76 | 39.53 | 0.77 | 184 | 666 |
| 2011 | 243,289 | 41.04 | 41.87 | 0.83 | 202 | 737 |
| 2012 | 247,742 | 42.63 | 43.51 | 0.88 | 218 | 806 |

Source: PROMOD IV(R) analyses prepared by Slater Consulting.

Note: The Base Case fuel price projections were developed by Slater Consulting based on actual data and the U. S. Energy Information Administration's 2000 Annual Energy Outlook Reference Case Forecast, but with the natural gas price escalations moderated to be more in keeping with the Standard & Poor's DRI forecast, which was included in the EIA's publication as a comparison forecast. The fuel prices for this sensitivity case were the same as for the Base Case except that the prices of natural gas were projected to escalate at the growth rates projected in the EIA's Reference Case Forecast.

**PENINSULAR FLORIDA, SUMMARY OF PROJECTED WHOLESALE ENERGY
COST SAVINGS DUE TO OSPREY ENERGY CENTER,
LOW LOAD GROWTH SENSITIVITY CASE, 2003-2012**

| YEAR | FRCC NET ENERGY FOR LOAD (GWH) | AVERAGE ANNUAL MARGINAL ENERGY COST WITH OSPREY (\$/MWH) | AVERAGE ANNUAL MARGINAL ENERGY COST WITHOUT OSPREY (\$/MWH) | WHOLESALE PRICE SUPPRESSION (\$/MWH) | ESTIMATED SAVINGS FROM OSPREY (\$MILLION) | CUMULATIVE NPV @ 10% 2000 DOLLARS (\$MILLION) |
|-------------|---|---|--|---|--|--|
| 2003 | 205,684 | 32.46 | 32.69 | 0.23 | 47 | 36 |
| 2004 | 209,187 | 30.97 | 31.62 | 0.65 | 136 | 128 |
| 2005 | 212,400 | 32.10 | 32.84 | 0.74 | 157 | 226 |
| 2006 | 215,713 | 32.26 | 32.85 | 0.59 | 127 | 298 |
| 2007 | 218,754 | 32.58 | 33.14 | 0.56 | 123 | 361 |
| 2008 | 221,389 | 33.09 | 33.56 | 0.47 | 104 | 409 |
| 2009 | 224,295 | 34.12 | 34.75 | 0.63 | 141 | 469 |
| 2010 | 227,242 | 34.96 | 35.56 | 0.60 | 136 | 522 |
| 2011 | 230,238 | 36.64 | 37.08 | 0.44 | 101 | 557 |
| 2012 | 233,280 | 37.46 | 38.40 | 0.94 | 219 | 627 |

Source: PROMOD IV(R) analyses prepared by Slater Consulting.

Note: This Low Load Growth scenario reflects growth rates 0.5 percent per year less than in the Base Case.

**PENINSULAR FLORIDA, SUMMARY OF PROJECTED WHOLESALE ENERGY
COST SAVINGS DUE TO OSPREY ENERGY CENTER,
HIGH LOAD GROWTH SENSITIVITY CASE, 2003-2012**

| <u>YEAR</u> | <u>FRCC NET ENERGY FOR LOAD (GWH)</u> | <u>AVERAGE ANNUAL MARGINAL ENERGY COST WITH OSPREY (\$/MWH)</u> | <u>AVERAGE ANNUAL MARGINAL ENERGY COST WITHOUT OSPREY (\$/MWH)</u> | <u>WHOLESALE PRICE SUPPRESSION (\$/MWH)</u> | <u>ESTIMATED SAVINGS FROM OSPREY (\$MILLION)</u> | <u>CUMULATIVE NPV @ 10% 2000 DOLLARS (\$MILLION)</u> |
|-------------|---|---|--|---|--|--|
| 2003 | 215,127 | 34.16 | 34.57 | 0.41 | 88 | 66 |
| 2004 | 222,089 | 33.44 | 34.29 | 0.85 | 189 | 195 |
| 2005 | 228,900 | 35.07 | 35.99 | 0.92 | 211 | 326 |
| 2006 | 235,976 | 35.94 | 36.75 | 0.81 | 191 | 434 |
| 2007 | 242,907 | 36.59 | 37.43 | 0.84 | 204 | 539 |
| 2008 | 249,539 | 38.02 | 39.04 | 1.02 | 255 | 657 |
| 2009 | 256,627 | 40.26 | 41.26 | 1.00 | 257 | 766 |
| 2010 | 263,921 | 42.51 | 43.51 | 1.00 | 264 | 868 |
| 2011 | 271,429 | 46.36 | 47.63 | 1.27 | 345 | 989 |
| 2012 | 279,162 | 49.17 | 50.64 | 1.47 | 410 | 1,119 |

Source: PROMOD IV(R) analyses prepared by Slater Consulting.

Note: This High Load Growth scenario reflects growth rates 1.0 percent per year greater than in the Base Case.

COMPARISON OF PENINSULAR FLORIDA PLANNED AND PROPOSED GENERATING UNITS

| PLANNED & PROPOSED UTILITY/UNIT 1/ | IN-SERVICE YEAR | SUMMER CAPACITY MW | WINTER CAPACITY MW | PRIMARY FUEL | ALTERNATE FUEL | HEAT RATE (Btu/kWh) | EQUIVALENT AVAILABILITY FACTOR % | TOTAL INSTALLED COST (\$/KW) 3/ | DIRECT CONSTRUCTION COST (\$/KW) 3/ | TECHNOLOGY TYPE |
|------------------------------------|-----------------|--------------------|--------------------|--------------|----------------|---------------------|----------------------------------|---------------------------------|-------------------------------------|-----------------------|
| DUKE/NSBPP 2/ | 2002 | 476 | 548 | GAS | NONE | 6,832 | 96 | N/A | \$325 | COMBINED CYCLE |
| OLEANDER 3/ | 2002 | 777 | 910 | GAS | NO. 2 | 9,700 | 97 | N/A | \$235 | COMBUSTION TURBINE |
| OSPREY ENERGY 2/ | 2003 | 496 | 578 | GAS | NONE | 6,800 | 94 | N/A | \$357 | COMBINED CYCLE |
| OKEECHOBEE 2/ | 2003 | 508 | 552 | GAS | NO. 2 | 6,650 | 93 | N/A | \$345 | COMBINED CYCLE |
| FPL/MARTIN CT | 2001 | 298 | 362 | GAS | NO. 2 | 10,450 | 98 | \$371 | \$323 | COMBUSTION TURBINE |
| FPL/FT.MYERS | 2002 | 930 | 1,073 | GAS | NONE | 6,830 | 96 | \$557 | \$502 | COMB. CYCLE/REPOWER |
| FPL/SANFORD 4-5 | 2002 | 1,132 | 1,342 | GAS | NONE | 6,860 | 96 | \$703 | \$591 | COMB. CYCLE/REPOWER |
| FPL/FT.MYERS CT | 2003 | 298 | 362 | GAS | NO. 2 | 10,450 | 98 | \$378 | \$323 | COMBUSTION TURBINE |
| FPL/MARTIN 5-6 | 2006 | 788 | 858 | GAS | NO. 2 | 6,346 | 96 | \$679 | \$484 | COMBINED CYCLE |
| FPL/UNSITED | 2007 | 394 | 429 | GAS | NO. 2 | 6,830 | 96 | \$783 | \$552 | COMBINED CYCLE |
| FPL/UNSITED | 2008 | 394 | 429 | GAS | NO. 2 | 6,830 | 96 | \$798 | \$552 | COMBINED CYCLE |
| FPL/UNSITED | 2009 | 394 | 429 | GAS | NO. 2 | 6,830 | 96 | \$812 | \$552 | COMBINED CYCLE |
| TALLAH/PURDOM 8 | 2000 | 233 | 262 | GAS | NO. 2 | 6,940 | NR | \$483 | \$434 | COMBINED CYCLE |
| FPC/INTRCSS 12-14 | 2000 | 240 | 282 | GAS | NO. 2 | 13,272 | 91 | NOT REPORTED | NOT REPORTED | COMBUSTION TURBINE |
| FPC/HINES 2 | 2003 | 495 | 567 | GAS | NO. 2 | 7,306 | 91 | NOT REPORTED | NOT REPORTED | COMBINED CYCLE |
| FPC/HINES 3 | 2005 | 495 | 567 | GAS | NO. 2 | 7,306 | 91 | NOT REPORTED | NOT REPORTED | COMBINED CYCLE |
| FPC/HINES 4 | 2007 | 495 | 567 | GAS | NO. 2 | 7,306 | 91 | NOT REPORTED | NOT REPORTED | COMBINED CYCLE |
| FPC/HINES 5 | 2009 | 495 | 567 | GAS | NO. 2 | 7,306 | 91 | NOT REPORTED | NOT REPORTED | COMBINED CYCLE |
| TECO/POLK 2 | 2000 | 155 | 180 | GAS | NO. 2 | 10,580 | 94 | NOT REPORTED | NOT REPORTED | COMBUSTION TURBINE |
| TECO/POLK 3 | 2002 | 155 | 180 | GAS | NO. 2 | 10,580 | 94 | NOT REPORTED | NOT REPORTED | COMBUSTION TURBINE |
| TECO/BAYSIDE 1 | 2003 | 698 | 796 | GAS | NO. 2 | 7,080 | 91 | NOT REPORTED | NOT REPORTED | COMBINED CYCLE |
| TECO/BAYSIDE 2 | 2004 | 711 | 802 | GAS | NO. 2 | 7,050 | 91 | NOT REPORTED | NOT REPORTED | COMBINED CYCLE |
| TECO/POLK 4-6 | 2005 | 465 | 540 | GAS | NO. 2 | 10,580 | 94 | NOT REPORTED | NOT REPORTED | COMBUSTION TURBINE |
| TECO/UNSITED | 2009 | 155 | 180 | GAS | NO. 2 | 10,580 | 94 | NOT REPORTED | NOT REPORTED | COMBUSTION TURBINE |
| GVILLE/J.R. KELLY | 2001 | 110 | 110 | GAS | NO. 2 | 8,000 | 84 | \$375 | \$368 | COMBINED CYCLE |
| SEC/PAYNE CRK 4/ | 2002 | 488 | 572 | GAS | NO. 2 | 6,170 | 93 | \$412 | \$378 | COMBINED CYCLE |
| FMPA-KUA CANE 3 | 2001 | 244 | 267 | GAS | NO. 2 | 6,815 | 92 | \$430 | \$320 | COMBINED CYCLE |
| LKLAND McINTSH 5 | 2002 | 337 | 384 | GAS | NO. 2 | 6,523 | 91 | \$749 | \$671 | COMBINED CYCLE |
| LKLAND McINTSH 4 | 2004 | 288 | 288 | PET. COKE | COAL | 8,452 | 81 | \$1,617 | \$1,317 | PRESSURE FLUID BED |
| LKLAND McINTSH 6 | 2009 | 32 | 46 | GAS | NO. 2 | 10,624 | 98 | \$992 | \$742 | COMBUSTION TURBINE |
| JEA KENNEDY CT 7 | 2000 | 149 | 186 | GAS | NO. 2 | 11,120 | 97 | NOT REPORTED | \$261 | COMBUSTION TURBINE |
| JEA BANDY CT 1-3 | 2001 | 149 | 186 | GAS | NO. 2 | 11,120 | 97 | NOT REPORTED | \$264 | COMBUSTION TURBINE |
| JEA NORTHSID 1-2 | 2002 | 265 | 265 | ET. COK | COAL | 9,946 | 90 | NOT REPORTED | \$658 | CIRCULATING FLUID BED |

DATA SOURCES:

- 1/ TOTAL INSTALLED COST AND DIRECT CONSTRUCTION COST DATA IS REPORTED DIRECTLY FROM THE INDIVIDUAL UTILITY'S 2000 TEN-YEAR SITE PLAN, SCHEDULE 9.
- 2/ DUKE/NSBPP, OSPREY ENERGY CENTER, AND OKEECHOBEE GENERATING CO. DATA ARE BASED ON INFORMATION FROM NEED DETERMINATION AND TEN-YEAR SITE PLAN FILINGS AND INCLUDE THE COSTS OF DIRECTLY ASSOCIATED TRANSMISSION LINES. HEAT RATE IS CALCULATED BASED ON HIGHER HEATING VALUE (HHV).
- 3/ OLEANDER POWER PROJECT DATA IS BASED ON INFORMATION FILED IN THE APRIL 2000 TEN-YEAR SITE PLAN, AND INCLUDES THE COST OF DIRECTLY ASSOCIATED TRANSMISSION LINES.
- 4/ SEMINOLE ELECTRIC COOPERATIVE'S HEAT RATE FOR THE PAYNE CREEK UNIT 3 IS REPORTED BASED ON LOWER HEATING VALUE (LHV).

**SUMMARY OF PENINSULAR FLORIDA CAPACITY, DEMAND, AND RESERVE MARGIN
AT TIME OF SUMMER PEAK WITHOUT OSPREY ENERGY CENTER**

| Year | INSTALLED CAPACITY (MW) | NET CONTRACT FIRM | | TOTAL AVAILABLE CAPACITY (MW) | TOTAL PEAK DEMAND (MW) | RESERVE MARGIN W/O EXERCISING LOAD MGMT. & INT. | | LOAD MGMT. & INT. (MW) | FIRM PEAK DEMAND (MW) | RESERVE MARGIN WITH EXERCISING LOAD MGMT. & INT. | |
|------|-------------------------|-------------------|---------------------------------|-------------------------------|------------------------|---|-----------|------------------------|-----------------------|--|-------|
| | | INTERCHG (MW) | PROJECTED TO GRID FROM NUG (MW) | | | % OF PEAK | % OF PEAK | | | | |
| 1999 | 36,125 | 1,640 | 2,076 | 39,841 | 36,788 | 3,053 | 8.30 | 2,765 | 34,023 | 5,818 | 17.10 |
| 2000 | 36,664 | 1,755 | 2,076 | 40,495 | 37,541 | 2,954 | 7.87 | 2,838 | 34,703 | 5,792 | 16.69 |
| 2001 | 39,047 | 1,682 | 2,076 | 42,805 | 38,223 | 4,582 | 11.99 | 2,843 | 35,380 | 7,425 | 20.99 |
| 2002 | 41,372 | 1,658 | 2,055 | 45,085 | 38,959 | 6,126 | 15.72 | 2,802 | 36,157 | 8,928 | 24.69 |
| 2003 | 44,148 | 1,566 | 2,055 | 47,769 | 39,781 | 7,988 | 20.08 | 2,793 | 36,988 | 10,781 | 29.15 |
| 2004 | 45,646 | 1,566 | 2,055 | 49,267 | 40,593 | 8,674 | 21.37 | 2,789 | 37,804 | 11,463 | 30.32 |
| 2005 | 46,002 | 1,566 | 2,045 | 49,613 | 41,433 | 8,180 | 19.74 | 2,795 | 38,638 | 10,975 | 28.40 |
| 2006 | 47,590 | 1,566 | 1,912 | 51,068 | 42,398 | 8,670 | 20.45 | 2,801 | 39,597 | 11,471 | 28.97 |
| 2007 | 48,363 | 1,566 | 1,906 | 51,835 | 43,252 | 8,583 | 19.84 | 2,809 | 40,443 | 11,392 | 28.17 |
| 2008 | 49,547 | 1,566 | 1,891 | 53,004 | 44,066 | 8,938 | 20.28 | 2,800 | 41,266 | 11,738 | 28.44 |

- 1/ 476 MW OF DUKE-NEW SMYRNA CAPACITY ADDED TO THE INSTALLED CAPACITY COLUMN STARTING IN 2002
- 2/ 514 MW OF OKEECHOBEE GENERATING PROJECT ADDED TO THE INSTALLED CAPACITY COLUMN STARTING IN 2003
- 3/ 777 MW OF OLEANDER POWER PROJECT ADDED TO THE INSTALLED CAPACITY COLUMN STARTING IN 2002
- 4/ INSTALLED CAPACITY INCLUDES UPDATED ADDITIONS FROM THE 2000 TEN-YEAR SITE PLANS OF FPL, FPC, & TECO

**SUMMARY OF PENINSULAR FLORIDA CAPACITY, DEMAND, AND RESERVE MARGIN
AT TIME OF SUMMER PEAK WITH OSPREY ENERGY CENTER, 496 MW IN 2003**

| Year | INSTALLED CAPACITY (MW) | NET CONTRACT FIRM | | TOTAL AVAILABLE CAPACITY (MW) | TOTAL PEAK DEMAND (MW) | RESERVE MARGIN W/O EXERCISING LOAD MGMT. & INT. | | LOAD MGMT. & INT. (MW) | FIRM PEAK DEMAND (MW) | RESERVE MARGIN WITH EXERCISING LOAD MGMT. & INT. | |
|------|-------------------------|-------------------|---------------------------------|-------------------------------|------------------------|---|-----------|------------------------|-----------------------|--|-------|
| | | INTERCHG (MW) | PROJECTED TO GRID FROM NUG (MW) | | | % OF PEAK | % OF PEAK | | | | |
| 1999 | 36,125 | 1,640 | 2,076 | 39,841 | 36,788 | 3,053 | 8.30 | 2,765 | 34,023 | 5,818 | 17.10 |
| 2000 | 36,664 | 1,755 | 2,076 | 40,495 | 37,541 | 2,954 | 7.87 | 2,838 | 34,703 | 5,792 | 16.69 |
| 2001 | 39,047 | 1,682 | 2,076 | 42,805 | 38,223 | 4,582 | 11.99 | 2,843 | 35,380 | 7,425 | 20.99 |
| 2002 | 41,372 | 1,658 | 2,055 | 45,085 | 38,959 | 6,126 | 15.72 | 2,802 | 36,157 | 8,928 | 24.69 |
| 2003 | 44,844 | 1,566 | 2,055 | 48,265 | 39,781 | 8,484 | 21.33 | 2,793 | 36,988 | 11,277 | 30.49 |
| 2004 | 46,142 | 1,566 | 2,055 | 49,763 | 40,593 | 9,170 | 22.59 | 2,789 | 37,804 | 11,959 | 31.63 |
| 2005 | 46,498 | 1,566 | 2,045 | 50,109 | 41,433 | 8,676 | 20.94 | 2,795 | 38,638 | 11,471 | 29.69 |
| 2006 | 48,086 | 1,566 | 1,912 | 51,564 | 42,398 | 9,166 | 21.62 | 2,801 | 39,597 | 11,967 | 30.22 |
| 2007 | 48,859 | 1,566 | 1,906 | 52,331 | 43,252 | 9,079 | 20.99 | 2,809 | 40,443 | 11,888 | 29.39 |
| 2008 | 50,043 | 1,566 | 1,891 | 53,500 | 44,066 | 9,434 | 21.41 | 2,800 | 41,266 | 12,234 | 29.65 |

- 1/ 476 MW OF DUKE-NEW SMYRNA CAPACITY ADDED TO THE INSTALLED CAPACITY COLUMN STARTING IN 2002
 - 2/ 514 MW OF OKEECHOBEE GENERATING PROJECT ADDED TO THE INSTALLED CAPACITY COLUMN STARTING IN 2003
 - 3/ 496 MW OF OSPREY ENERGY CENTER ADDED TO THE INSTALLED CAPACITY COLUMN STARTING IN 2003
 - 4/ 777 MW OF OLEANDER POWER PROJECT ADDED TO THE INSTALLED CAPACITY COLUMN STARTING IN 2002
 - 5/ INSTALLED CAPACITY INCLUDES UPDATED ADDITIONS FROM THE 2000 TEN-YEAR SITE PLANS OF FPL, FPC, & TECO
- SOURCES: Florida Reliability Coordinating Council, 1999 Regional Load & Resource Plan, Peninsular Florida, July, 1999

Calpine Construction Finance Company, L.P.

**SUMMARY OF PENINSULAR FLORIDA CAPACITY, DEMAND, AND RESERVE MARGIN
AT TIME OF WINTER PEAK WITHOUT OSPREY ENERGY CENTER**

| Year | NET INSTALLED CAPACITY (MW) | NET CONTRACT FIRM | | TOTAL AVAILABLE CAPACITY (MW) | TOTAL PEAK DEMAND (MW) | RESERVE MARGIN W/O EXERCISING LOAD MGMT. & INT. | | LOAD MGMT. & INT. (MW) | FIRM PEAK DEMAND (MW) | RESERVE MARGIN WITH EXERCISING LOAD MGMT. & INT. | |
|---------|--------------------------------------|-------------------|-----------------------------|--|---------------------------------|---|-----------|---------------------------------|--------------------------------|--|-----------|
| | | INTERCHG (MW) | TO GRID FROM NUG (MW) | | | % OF PEAK | % OF PEAK | | | (MW) | % OF PEAK |
| 1999/00 | 37,803 | 1,772 | 2,129 | 41,704 | 39,989 | 1,715 | 4.29 | 4,012 | 35,977 | 5,727 | 15.92 |
| 2000/01 | 39,662 | 1,694 | 2,129 | 43,485 | 40,929 | 2,556 | 6.24 | 4,110 | 36,819 | 6,666 | 18.10 |
| 2001/02 | 41,952 | 1,671 | 2,129 | 45,752 | 41,865 | 3,887 | 9.28 | 4,072 | 37,793 | 7,959 | 21.06 |
| 2002/03 | 44,146 | 1,566 | 2,108 | 47,820 | 42,808 | 5,012 | 11.71 | 4,059 | 38,749 | 9,071 | 23.41 |
| 2003/04 | 47,543 | 1,566 | 2,108 | 51,217 | 43,726 | 7,491 | 17.13 | 4,063 | 39,663 | 11,554 | 29.13 |
| 2004/05 | 48,892 | 1,566 | 2,098 | 52,556 | 44,651 | 7,905 | 17.70 | 4,085 | 40,566 | 11,990 | 29.56 |
| 2005/06 | 50,233 | 1,566 | 1,965 | 53,764 | 45,553 | 8,211 | 18.03 | 4,103 | 41,450 | 12,314 | 29.71 |
| 2006/07 | 50,823 | 1,566 | 1,959 | 54,348 | 46,600 | 7,748 | 16.63 | 4,124 | 42,476 | 11,872 | 27.95 |
| 2007/08 | 52,584 | 1,566 | 1,944 | 56,094 | 47,502 | 8,592 | 18.09 | 4,128 | 43,374 | 12,720 | 29.33 |
| 2008/09 | 52,555 | 1,566 | 1,944 | 56,065 | 48,441 | 7,624 | 15.74 | 4,155 | 44,286 | 11,779 | 26.60 |

- 1/ 548 MW OF DUKE-NEW SMYRNA CAPACITY ADDED TO THE INSTALLED CAPACITY COLUMN STARTING IN 2002/03
- 2/ 561 MW OF OKEECHOBEE GENERATING PROJECT ADDED TO THE INSTALLED CAPACITY COLUMN STARTING IN 2003/04
- 3/ 910 MW OF OLEANDER POWER PROJECT ADDED TO THE INSTALLED CAPACITY COLUMN STARTING IN 2002/03
- 4/ INSTALLED CAPACITY INCLUDES UPDATED ADDITIONS FROM THE 2000 TEN-YEAR SITE PLANS OF FPL, FPC, & TECO

**SUMMARY OF PENINSULAR FLORIDA CAPACITY, DEMAND, AND RESERVE MARGIN
AT TIME OF WINTER PEAK WITH OSPREY ENERGY CENTER, 578 MW IN 2003/04**

| Year | NET INSTALLED CAPACITY (MW) | NET CONTRACT FIRM | | TOTAL AVAILABLE CAPACITY (MW) | TOTAL PEAK DEMAND (MW) | RESERVE MARGIN W/O EXERCISING LOAD MGMT. & INT. | | LOAD MGMT. & INT. (MW) | FIRM PEAK DEMAND (MW) | RESERVE MARGIN WITH EXERCISING LOAD MGMT. & INT. | |
|---------|--------------------------------------|-------------------|-----------------------------|--|---------------------------------|---|-----------|---------------------------------|--------------------------------|--|-----------|
| | | INTERCHG (MW) | TO GRID FROM NUG (MW) | | | % OF PEAK | % OF PEAK | | | (MW) | % OF PEAK |
| 1999/00 | 37,803 | 1,772 | 2,129 | 41,704 | 39,989 | 1,715 | 4.29 | 3,784 | 35,977 | 5,727 | 15.92 |
| 2000/01 | 39,662 | 1,694 | 2,129 | 43,485 | 40,928 | 2,557 | 6.25 | 3,955 | 36,819 | 6,666 | 18.10 |
| 2001/02 | 41,952 | 1,671 | 2,129 | 45,752 | 41,865 | 3,887 | 9.28 | 4,078 | 37,793 | 7,959 | 21.06 |
| 2002/03 | 44,146 | 1,566 | 2,108 | 47,820 | 42,808 | 5,012 | 11.71 | 4,153 | 38,749 | 9,071 | 23.41 |
| 2003/04 | 48,121 | 1,566 | 2,108 | 51,795 | 43,726 | 8,069 | 18.45 | 4,232 | 39,663 | 12,132 | 30.59 |
| 2004/05 | 49,470 | 1,566 | 2,098 | 53,134 | 44,651 | 8,483 | 19.00 | 4,307 | 40,566 | 12,568 | 30.98 |
| 2005/06 | 50,811 | 1,566 | 1,965 | 54,342 | 45,553 | 8,789 | 19.29 | 4,335 | 41,450 | 12,892 | 31.10 |
| 2006/07 | 51,401 | 1,566 | 1,959 | 54,926 | 46,600 | 8,326 | 17.87 | 4,365 | 42,476 | 12,450 | 29.31 |
| 2007/08 | 53,162 | 1,566 | 1,944 | 56,672 | 47,502 | 9,170 | 19.30 | 4,392 | 43,374 | 13,298 | 30.66 |
| 2008/09 | 53,133 | 1,566 | 1,944 | 56,643 | 48,441 | 8,202 | 16.93 | 4,415 | 44,286 | 12,357 | 27.90 |

- 1/ 548 MW OF DUKE-NEW SMYRNA CAPACITY ADDED TO THE INSTALLED CAPACITY COLUMN STARTING IN 2002/03
- 2/ 561 MW OF OKEECHOBEE GENERATING PROJECT ADDED TO THE INSTALLED CAPACITY COLUMN STARTING IN 2003/04
- 3/ 578 MW OF OSPREY ENERGY CENTER ADDED TO THE INSTALLED CAPACITY COLUMN STARTING IN 2003/04
- 4/ 910 MW OF OLEANDER POWER PROJECT ADDED TO THE INSTALLED CAPACITY COLUMN STARTING IN 2002/03
- 5/ INSTALLED CAPACITY INCLUDES UPDATED ADDITIONS FROM THE 2000 TEN-YEAR SITE PLANS OF FPL, FPC, & TECO

SOURCES: Florida Reliability Coordinating Council, 1999 Regional Load & Resource Plan, Peninsular Florida, July, 1999
Calpine Construction Finance Company, L.P.

**PENINSULAR FLORIDA UTILITIES'
 IDENTIFIED BUT UNCOMMITTED
 CAPACITY NEEDS, 2003-2009**

| <u>UTILITY</u> | <u>MW NEED</u> | <u>TYPE OF CAPACITY</u> | <u>IN-SERVICE YEAR</u> | <u>Field Construction Start Date</u> |
|----------------|----------------|--------------------------------|------------------------|--------------------------------------|
| OUC | 481 | Combined Cycle | 2003 | 9/2001 |
| | 146 | Combustion Turbine | 2007 | 6/2006 |
| Lakeland | 288 | Pressurized Fluidized Bed Coal | 2004 | 6/2002 |
| | 32 | Combustion Turbine | 2009 | 10/2008 |
| JEA | 158 | Combustion Turbine | 2003 | 6/2003 |
| | 250 | Combined Cycle | 2006 | 6/2006 |
| | 168 | Combustion Turbine | 2009 | 6/2009 |
| Seminole | 153 | Combustion Turbine | 2002 | 11/2000 |
| | 244 | Combined Cycle | 2004 | 6/2002 |
| | 153 | Combustion Turbine | 2005 | 6/2003 |
| | 244 | Combined Cycle | 2006 | 11/2004 |
| | 153 | Combustion Turbine | 2007 | 6/2005 |
| FPL | 298 | Combustion Turbine | 2003 | 2002 |
| | 788 | Combined Cycle | 2006 | 2004 |
| | 394 | Combined Cycle | 2007 | 2005 |
| | 394 | Combined Cycle | 2008 | 2006 |
| | 394 | Combined Cycle | 2009 | 2007 |
| FPC | 495 | Combined Cycle | 2003 | 8/2000 |
| | 495 | Combined Cycle | 2005 | 8/2002 |
| | 495 | Combined Cycle | 2007 | 8/2004 |
| | 495 | Combined Cycle | 2009 | 8/2006 |
| TECO | 698 | Combined Cycle | 2003 | 10/2001 |
| | 711 | Combined Cycle | 2004 | 8/2002 |
| | 155 | Combustion Turbine | 2005 | 1/2003 |
| | 155 | Combustion Turbine | 2006 | 1/2004 |
| | 155 | Combustion Turbine | 2008 | 1/2006 |
| | 155 | Combustion Turbine | 2009 | 1/2007 |

Total MW 8,747

Data Source: 2000 Ten-Year Site Plans

PENINSULAR FLORIDA EMISSIONS IMPACTS OF OSPREY ENERGY CENTER, 2003-2012

(All Values in 1000's lbs)

| <u>Year</u> | <u>Sulfur Dioxide</u> | | <u>Nitrogen Oxides</u> | |
|-------------|---------------------------|------------------------|---------------------------|------------------------|
| | <u>Without Osprey</u> | <u>With Osprey</u> | <u>Without Osprey</u> | <u>With Osprey</u> |
| 2003 | 759,691 | 767,350 | 458,702 | 452,861 |
| 2004 | 702,289 | 669,806 | 426,740 | 412,805 |
| 2005 | 695,946 | 674,697 | 423,137 | 413,850 |
| 2006 | 677,817 | 654,902 | 417,541 | 405,467 |
| 2007 | 658,449 | 632,952 | 405,652 | 392,771 |
| 2008 | 639,130 | 611,603 | 391,615 | 382,230 |
| 2009 | 669,806 | 660,623 | 408,957 | 401,142 |
| 2010 | 679,140 | 657,030 | 410,514 | 400,657 |
| 2011 | 702,883 | 677,446 | 418,612 | 407,683 |
| 2012 | 743,653 | 720,617 | 437,591 | 426,875 |

Source: PROMOD IV(R) analyses prepared by Slater Consulting.