


ORIGINAL



TE 

TAMPA ELECTRIC COMPANY
BEFORE THE
FLORIDA PUBLIC SERVICE COMMISSION
DOCKET NO. 000007-EI

TESTIMONY
AND EXHIBIT OF

STANLEY J. MARTIN

DOCUMENT NUMBER-DATE

11893 SEP 21 8

FPSC-RECORDS/REPORTING

1 **BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION**

2 **PREPARED DIRECT TESTIMONY**

3 **OF**

4 **STANLEY J. MARTIN**

5
6 **Q.** Please state your name, address, occupation and employer.

7
8 **A.** My name is Stanley J. Martin. My mailing address is P.O.
9 Box 111, Tampa, Florida 33601, and my business address is
10 Big Bend Station, 13031 Wyandotte Road, Apollo Beach,
11 Florida 33572. I am employed by Tampa Electric Company
12 ("Tampa Electric" or "company") in the position of
13 General Manager, Big Bend Station.

14
15 **Q.** Please provide a brief outline of your educational
16 background and business experience.

17
18 **A.** I received a Bachelor of Science Degree in Electrical
19 Engineering in 1971 from Rutgers University. I began my
20 career with Public Service Electric and Gas Company where
21 I held supervisory positions at both the Mercer and
22 Bergen Generating Stations in maintenance and plant
23 performance departments.

24

1 In April 1975, I began my employment with Tampa Electric
2 at Gannon Station where I held successive positions of
3 Plant Auxiliaries Engineer, Maintenance Planning Engineer
4 and Manager of Maintenance. In September 1983 I was
5 transferred to Big Bend Station as Operations Startup
6 Manager for Big Bend Unit 4, and subsequently held the
7 position of Administrative Manager. In November 1987 I
8 was named General Manager of Production Engineering,
9 responsible for engineering services for the Production
10 Department. In November 1995 I was named to my current
11 position of General Manager, Big Bend Station. I am
12 responsible for directing the overall operations of the
13 station's generating facility.

14
15 Q. What is the purpose of your testimony in this proceeding?

16
17 A. The purpose of my testimony is to describe the compliance
18 activities being performed by Tampa Electric to comply
19 with the Consent Final Judgment ("CFJ") and the Consent
20 Decree that are included in the company's Environmental
21 Cost Recovery Clause ("ECRC") factors for 2001.
22 Specifically, I will describe the technical aspects and
23 the expected costs associated with the activities which
24 will achieve compliance with both the CFJ and the Consent
25 Decree ("the Orders").

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

Q. Have you prepared an exhibit to support your testimony?

A. Yes I have. My Exhibit No. ____ (SJM-1) consists of three documents.

Q. Please describe the environmental activities required by the Orders for which Tampa Electric is seeking ECRC recovery in 2001.

A. In the projection filing for 2001 ECRC factors provided in Tampa Electric witness Karen O. Zwolak's direct testimony and exhibits, Tampa Electric has included costs for three new environmental activities required under the Orders. The first activity is the Flue Gas Desulfurization ("FGD") Optimization and Utilization Program that requires Tampa Electric to reduce SO₂ emissions through both improved reliability and higher removal efficiencies for the FGD systems at Big Bend Station. The second activity requires the company to reduce nitrogen oxide ("NO_x") emissions at Big Bend Station by evaluating and implementing commercially viable NO_x reduction technologies. The third activity is the Particulate Emission ("PM") Minimization and Monitoring Program that requires the company to perform

1 an optimization study and a Best Available Control
2 Technology ("BACT") analysis of its electrostatic
3 precipitators ("ESP"). Based upon the results of the
4 study and analysis, Tampa Electric must make reasonable
5 PM control upgrades at Big Bend Station.

6
7 In Docket No. 000685-EI, Tampa Electric filed with the
8 Florida Public Service Commission for approval of the FGD
9 Optimization and Utilization Program. Tampa Electric
10 filed for approval of its PM and NO_x programs in Docket
11 No. 001186-EI. The company's plans for meeting the
12 Orders' requirements are detailed in the petitions filed
13 in the dockets.

14
15 **FGD Optimization and Utilization Program**

16 **Q.** What are the improvements necessary to comply with the
17 Orders related to the FGD Optimization and Utilization
18 Program?

19
20 **A.** Several improvements are required to increase the
21 utilization of the Big Bend Units 1 and 2 and Unit 3 FGD
22 systems. Tampa Electric has identified three main areas
23 requiring modifications necessary to comply with the
24 Orders. The activities identified are to 1) perform
25 modifications or upgrades to the Big Bend Unit 3 tower

1 modules, 2) make improvements to the Big Bend Units 1 and
2 2 tower module, and 3) make improvements to the support
3 systems serving both FGD systems.
4

5 The improvements necessary for the Big Bend Unit 3 FGD
6 system are more extensive and much more time critical.
7 They must be performed to improve the availability of the
8 Big Bend Unit 3 FGD system to 92 percent from a
9 historical availability of 80 percent and to improve its
10 sulfur dioxide ("SO₂") removal efficiency to 95% as
11 required under the Orders. These upgrades include making
12 improvements to tower internals, ductwork and dampers,
13 fans, absorber and quencher systems, and electrical and
14 control systems. Some of these improvements have already
15 been performed during a unit outage in March and April
16 2000.

17
18 Improvements for the Big Bend Units 1 and 2 FGD system
19 are not expected to be as significant. They primarily
20 include adding a back-up reagent feed system.
21

22 Common support systems will need considerable
23 improvements to ensure the reliability of both FGD
24 systems. The company has identified necessary upgrades

1 for the limestone supply, gypsum dewatering, and stack
2 and wastewater treatment systems.

3
4 Q. Why are these improvements necessary?

5
6 A. Tampa Electric has always had flexibility in operating
7 the Big Bend Unit 3 FGD system so that if a tower or
8 support system were down, the FGD system had enough
9 capacity and redundancy to continue operating Big Bend
10 Unit 4 and operating Unit 3 unscrubbed until the spare
11 tower was returned to service. Likewise, Tampa
12 Electric's anticipated compliance with the Title IV Clean
13 Air Act Amendments ("CAAA") compliance requirements
14 provided operating flexibility that allowed for Big Bend
15 Unit 1 and 2 to operate unscrubbed if a problem occurred
16 in its FGD system.

17
18 The Orders now remove that flexibility and require, with
19 some exceptions, that Big Bend Units 1, 2 and 3 FGD
20 systems operate essentially at all times that their
21 associated generating units are operating. This change
22 in operating requirements, combined with an evaluation of
23 the existing system and review of the FGD operating
24 history, resulted in the identification of specific areas

1 that require the most needed improvements to ensure
2 compliance with the Orders.

3
4 **Q.** What are the projected costs that Tampa Electric expects
5 to incur for the FGD Optimization and Utilization Program
6 in 2000 and 2001?

7
8 **A.** Tampa Electric has projected that capital expenditures
9 will be \$3 million and \$9.4 million for 2000 and 2001,
10 respectively. For O&M expenses, Tampa Electric has
11 projected that approximately \$1.3 million will be spent
12 in 2000 and \$1.2 million in 2001. Details of these
13 projected expenditures are provided in Document No. 1 of
14 my exhibit.

15
16 **Q.** In Tampa Electric's petition requesting recovery of the
17 FGD Optimization and Utilization Program, the company
18 projected \$5.1 million of capital expenditures and \$1.6
19 million of O&M expenses. Why is Tampa Electric
20 requesting an additional \$7.6 million in capital
21 expenditures and another \$1.3 million in O&M expenses?

22
23 **A.** Tampa Electric's estimates included in its petition were
24 initial estimates based on the activities that the
25 company had identified through May 2000. At that time,

1 Tampa Electric anticipated additional compliance
2 activities would be required, but had not yet fully
3 inspected and identified the additional areas which may
4 cause FGD outages nor had it developed engineering
5 solutions, performed thorough cost reviews and performed
6 feasibility analyses. It was not until recently that a
7 more comprehensive evaluation including cost estimates
8 for the FGD optimization could be finalized. At this
9 time, the costs presented above are Tampa Electric's best
10 estimates and may be slightly modified as the detailed
11 engineering is finalized and actual bids for labor and
12 equipment are received.

13
14 **Q.** How were the estimated costs determined for the FGD
15 Optimization and Utilization Program?

16
17 **A.** Tampa Electric's estimated costs were determined by the
18 plant engineering team that utilized 15 years of FGD
19 operational and maintenance experience. The company also
20 utilized suppliers' bids and consultants' expertise in
21 assessing the required work along with related cost
22 estimates.

23
24

- 1 **Q.** Will there be on-going capital and O&M costs attributable
2 to the requirements of the FGD Optimization and
3 Utilization Program?
4
- 5 **A.** Perhaps. Tampa Electric has attempted to identify the
6 key components of the FGD systems that could likely
7 result in FGD outages causing unit unavailability. As
8 components fail or capital improvements are deemed
9 necessary to ensure the required FGD system efficiencies,
10 those costs will be identified and filed with the
11 Commission in future ECRC filings.
12
- 13 **Q.** What are the consequences of not performing the upgrades
14 and improvements to the FGD systems for Big Bend Units 1,
15 2 and 3?
16
- 17 **A.** The FGD systems were designed to meet Title IV of the
18 CAAA requirements which do not require the continuous
19 operation of the systems. Tampa Electric anticipated that
20 in the event of a scrubber malfunction, the company could
21 continue to operate Big Bend Units 1, 2 and 3 unscrubbed.
22 Now, however, the Consent Decree essentially requires
23 these units to operate only when the FGD systems are
24 operating. Therefore, in the event of a malfunction or
25 outage on either FGD system, Tampa Electric would be

1 severely restricted in its unit operations. This could
2 result in significant impacts to Tampa Electric's system
3 through restricted generation and higher fuel and
4 purchased power costs. If the planned program were not
5 implemented, Tampa Electric would not be able to meet the
6 requirements of the Consent Decree.
7

8 Q. What alternatives to the options proposed were
9 considered?

10
11 A. Alternatives considered included the addition of a spare
12 tower module, with and without additional tower module
13 back-up support systems, and purchasing power in the
14 event of FGD systems and/or support systems failure. To
15 purchase power in the event of failure would put native
16 load customers at risk given the potential loss of up to
17 1,320 MW and the wholesale market conditions. All of the
18 alternative options were determined to be significantly
19 more costly than the planned program.
20

21 The company did not consider the option to operate the
22 generating units without the associated FGD systems
23 because it would be in direct violation of the Consent
24 Decree. The option to shut the units down in the event
25 of an extended FGD outage was not considered as an

1 alternative to the work plan due to the severe impact
2 that the potential loss of up to 1,320 MW would have on
3 Tampa Electric's system and the Florida grid.
4

5 **Big Bend NO_x Emissions Reduction Program**

6 Q. Describe the projected costs to comply with the
7 requirements of the Orders to reduce NO_x emissions.
8

9 A. The Orders require Tampa Electric to spend up to \$3
10 million with the goal to reduce NO_x emissions at Big Bend
11 Station. The Consent Decree requires that by December
12 31, 2002, the company must achieve at least a 30 percent
13 reduction below 1998 levels for Big Bend Units 1 and 2
14 and at least a 15 percent reduction in NO_x emissions from
15 Big Bend Unit 3. Tampa Electric has identified projects
16 which are the first steps to decrease NO_x emissions in
17 these units such as burner and windbox modifications and
18 the installation of a neural network system on each of
19 the Big Bend units.
20

21 Q. What are the projected costs that Tampa Electric expects
22 to incur for the Big Bend NO_x Emissions Reduction Program
23 in 2000 and 2001?
24

1 **A.** Tampa Electric has estimated capital expenditures of
2 \$130,000 and \$1,068,000 in 2000 and 2001, respectively.
3 The company does not expect to incur any O&M expenses in
4 2000 but expects to incur \$50,000 in 2001. Details of
5 these projected expenditures are provided in Document No.
6 2 of my exhibit.

7
8 **Q.** How were the estimated costs determined?

9
10 **A.** The costs for the NO_x projects were developed based on
11 data gathered through vendor presentations and
12 quotations. Tampa Electric had several presentations by
13 suppliers of various NO_x reduction technologies. In most
14 cases, the vendors were provided with the details of the
15 Consent Decree and were requested to provide a plan that
16 would allow Tampa Electric to meet those requirements.
17 Most vendors provided such a plan and many provided
18 estimates of how much their plan would cost.

19
20 **Q.** How has Tampa Electric determined that these activities
21 are the most cost-effective means to meet the required NO_x
22 reductions?

23
24 **A.** The costs used in the company's forecast were costs
25 presented during the vendor presentations. Based upon

1 the responses Tampa Electric determined that the best way
2 to meet the early NO_x reduction requirements was to model
3 and modify the burners, and install a neural network on
4 Big Bend Unit 1 in 2001. Accordingly, the company
5 selected a consulting firm to do the burner modeling
6 based upon their experience and their competitive
7 pricing. The consultant provided the cost estimate for
8 the burner modifications.

9
10 **Q.** Are the activities that Tampa Electric is proposing for
11 reducing NO_x emissions compatible with previous NO_x
12 reduction programs?

13
14 **A.** Yes. Tampa Electric has been very successful in
15 achieving NO_x emissions reductions at Big Bend Units 1
16 through 3 through the use of combustion tuning and
17 optimization in order to meet the requirements of Title
18 IV of the CAAA. In Tampa Electric's previous ECRC
19 filings, the company indicated, based on current
20 technology available, the next step to further decrease
21 NO_x emissions would be the installation of a neural
22 network system. A neural network is a data collection
23 system that monitors the various boiler and combustion
24 operating parameters and the NO_x emissions which result
25 from those operating parameters. A database is

1 established which develops relationships between those
2 operating parameters and the NO_x emissions to optimize
3 combustion to achieve lower NO_x emissions. In addition to
4 the neural network, Tampa Electric expects those
5 modifications to the burner and windbox of each unit will
6 aid in the control of airflow to the boiler, improving
7 combustion and reducing NO_x emissions.

8
9 **Q.** What other alternatives were considered for lowering NO_x
10 emissions?

11
12 **A.** Tampa Electric consulted with various experts in the
13 industry to determine the best means to achieve the
14 reductions required. Alternatives considered included
15 the over-fire air system, soot blower optimization and
16 pulverizer optimization using neural networks, coal flow
17 monitoring, reducing flame temperature by water spray,
18 low NO_x burners, coal re-burning and other non-proven
19 technologies. As part of the modeling study, these
20 technologies will be reviewed and evaluated further.

21
22 **Q.** What are the consequences of not performing the NO_x
23 reduction activities?

1 A. Tampa Electric has no other option but to move forward
2 with the early NO_x reductions at Big Bend Station. If
3 these activities are not performed, Tampa Electric will
4 be in violation with the requirements of the Orders.

5

6 **PM Minimization and Monitoring**

7 Q. Please describe the activities and costs projected for
8 ECRC recovery related to the reduction of PM.

9

10 A. The Consent Decree requires Tampa Electric to undertake a
11 performance optimization study and BACT analysis of its
12 ESP at Big Bend Station by May 1, 2003. The company must
13 report on the technical feasibility of installing a PM
14 continuous emissions monitor ("CEM") on one unit at Big
15 Bend Station by March 1, 2002. Specifically, the Consent
16 Decree requires Tampa Electric to:

17

18 • Complete an optimization study to recommend the best
19 operational practices to minimize emissions from
20 each ESP within 12 months after entry into the
21 Consent Decree and implement the recommendations
22 within 60 days after EPA has approved them.

23 • Complete a BACT analysis for upgrading each existing
24 ESP at Big Bend within 12 months after entry into
25 the Consent Decree and complete the installation of

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

the recommendations of the BACT analysis by no later than May 1, 2004.

- Revise previous optimization studies to incorporate new requirements resulting from the BACT analysis.
- Install and operate a PM monitor by March 2002 and evaluate the possibility to install a second monitor.

Tampa Electric has begun the optimization study and the BACT analysis. To accomplish these two activities, Tampa Electric has contracted with Southern Research Institute and Electric Power Research Institute. In addition, Tampa Electric is retaining an environmental consultant to assist in the BACT analysis and is utilizing contractors to perform any physical modifications to facilitate the study and/or analysis. Tampa Electric also plans to utilize its in-house stack test team to perform sampling and testing as necessary.

Tampa Electric has also identified improvements that are necessary to optimize ESP performance such as modifications to the turning vanes and precipitator distribution plates, and upgrades to the controls and software system of the precipitators on Big Bend Unit 1.

1 Q. What environmental costs has Tampa Electric included in
2 its projections for its 2001 ECRC factors related to PM
3 emission reduction?

4
5 A. Capital costs are estimated to be \$165,000 in 2000 and
6 \$928,000 in 2001. O&M expenses for 2000 are estimated to
7 be approximately \$215,000 and \$115,000 in 2001.
8 Additionally, \$168,000 of capital expenditures are
9 expected to be incurred in 2001 to begin the installation
10 of the PM CEM monitor. Details of these projected
11 expenditures are provided in Document No. 3 of my
12 exhibit.

13
14 Q. How were the projected costs determined for the PM
15 minimization program?

16
17 A. Tampa Electric solicited bids for the ESP optimization
18 study and the BACT analysis and selected the most cost-
19 effective approach. Engineering experience and outside
20 consultants were also used to determine costs and
21 activities that needed to be addressed.

22
23 Q. Why are costs for ESP performance improvements and
24 control and software upgrades being incurred prior to the

1 completion and approval of the optimization study and
2 BACT analysis recommendations?

3

4 **A.** The activities being performed prior to the completion
5 and approval of the optimization study and BACT analysis
6 recommendations are activities which are already known
7 and will be included in the optimization study's
8 recommendation. The control and software upgrades from
9 Solvera and ESPert systems will facilitate the collection
10 of meaningful data for these requirements. Modifications
11 to the Big Bend Unit 1 are currently being engineered and
12 are planned to be completed in the upcoming 2001 outage.
13 Tampa Electric expects the requirements for Big Bend Unit
14 2 to be similar to those of Big Bend Unit 1.

15

16 **Q.** What are the consequences of not performing the
17 optimization study and the BACT analysis?

18

19 **A.** The requirements of the Orders are very specific
20 regarding the actions Tampa Electric must take to comply
21 with PM emissions reductions. The company must perform
22 the studies and implement the recommendations. If Tampa
23 Electric did not perform these activities, it would be in
24 violation of the Orders.

25

1 Q. Please summarize your testimony.

2

3 A. Tampa Electric has done extensive work to develop the
4 most prudent and cost effective means to comply with the
5 new requirements of the Orders. In a very short time
6 frame, Tampa Electric has had to begin to assess work to
7 be completed, to plan for opportunities to perform the
8 compliance activities and to provide the best estimates
9 of the costs. As a result, Tampa Electric has identified
10 immediate and essential steps to achieve compliance with
11 the Orders' requirements to reduce SO₂, NO_x and PM.

12

13 Q. Does this conclude your testimony?

14

15 A. Yes it does.

16

17

18

19

20

21

22

23

24

25

TAMPA ELECTRIC COMPANY
EXHIBIT OF STANLEY J. MARTIN
INDEX

| Document No. | Title | Page |
|---------------------|---|-------------|
| 1 | Big Bend FGD Unit 1, 2 and 3 2000/2001 Reliability and Performance Improvement Projects | 21 |
| 2 | Big Bend Station Forecast of Costs for Reductions of NO _x Emissions | 22 |
| 3 | Big Bend Station Forecast of Costs for Reductions of Particulate Matter | 23 |

**BIG BEND FGD UNIT 1, 2 AND 3
2000/2001 RELIABILITY AND PERFORMANCE IMPROVEMENT PROJECTS**

| UNIT 3 TOWER MODULE PROJECTS | | | | |
|-------------------------------------|---|-----------------|--------------|--------------|
| ITEM # | DESCRIPTION | COMPLETION DATE | COSTS(\$K) | |
| | | | CAPITAL | O&M |
| #1 | TOWER PIPING, NOZZLE, AND INTERNAL IMPROVEMENTS | 6/1/01 | 1,003 | 523 |
| #2 | DUCT WORK IMPROVEMENTS | 10/1/00 | 487 | 1,476 |
| #3 | ELECTRICAL SYSTEM RELIABILITY IMPROVEMENTS | 12/1/00 | 236 | 90 |
| #4 | TOWER CONTROL IMPROVEMENTS | 12/1/00 | | 16 |
| #5 | DBA SYSTEM IMPROVEMENTS | 6/1/01 | 120 | |
| #6 | BOOSTER FAN RELIABILITY IMPROVEMENTS | 6/1/01 | 1,069 | 95 |
| #7 | ABSORBER SYSTEM IMPROVEMENTS | 6/1/01 | 2,649 | 103 |
| #8 | QUENCHER SYSTEM IMPROVEMENTS | 10/1/00 | 13 | |
| #9 | TOWER DEMISTER (PACKING) IMPROVEMENTS | 6/1/01 | 380 | |
| \$ TOTALS= | | | 5,967 | 2,303 |

| UNIT 1 & 2 TOWER MODULE PROJECTS | | | | |
|---|--|-----------------|------------|-----------|
| ITEM # | DESCRIPTION | COMPLETION DATE | COSTS(\$K) | |
| | | | CAPITAL | O&M |
| #10 | PREVENTATIVE MAINTENANCE | 12/1/00 | | 25 |
| #11 | OXIDATION AIR CONTROL IMPROVEMENT | 12/1/00 | | 10 |
| #12 | TOWER WATER, AIR, REAGENT AND START-UP PIPING UPGRADES | 12/1/00 | 171 | 20 |
| \$ TOTALS= | | | 171 | 55 |

| TOWER MODULE SUPPORT SYSTEM PROJECTS | | | | |
|---|--|-----------------|---------------|--------------|
| ITEM # | DESCRIPTION | COMPLETION DATE | COSTS(\$K) | |
| | | | CAPITAL | O&M |
| #13 | LIMESTONE SUPPLY RELIABILITY IMPROVEMENTS | 6/1/01 | 2,666 | 24 |
| #14 | GYPSUM DEWATERING IMPROVEMENTS | 6/1/01 | 1,583 | 0 |
| #15 | STACK RELIABILITY IMPROVEMENTS | 6/1/01 | 154 | 69 |
| #16 | WASTE WATER TREATMENT PLANT RELIABILITY IMPROVEMENTS | 12/1/01 | 1,952 | 0 |
| \$ TOTALS= | | | 6,255 | 93 |
| GRAND TOTAL \$= | | | 12,393 | 2,450 |

Big Bend Station Forecast of Costs for Reductions of NO_x Emissions

Year 2001

| Activity | January | February | March | April | May | June | July | August | Septem | October | Novem | Decem | Total |
|---|---------|----------|---------|---------|--------|--------|--------|--------|--------|---------|-------|--------|---------|
| O&M Activities | | | | | | | | | | | | | |
| BB1 Boiler Tuning and Balancing | | | | 10,000 | 10,000 | 10,000 | 10,000 | 10,000 | | | | | 50,000 |
| Capital Activities | | | | | | | | | | | | | |
| Big Bend 1 - Outage Spring of 2001 | | | | | | | | | | | | | |
| BB1 Neural net | 98,000 | 15,000 | 280,000 | 15,000 | 5,000 | 5,000 | 5,000 | 6,000 | 5,000 | 110,000 | 5,000 | 5,000 | 554,000 |
| BB1 Burner and Windbox mods | 105,000 | 14,000 | 104,000 | 150,000 | 12,000 | 4,000 | 4,000 | 3,000 | 3,000 | 3,000 | 3,000 | 4,000 | 409,000 |
| Big Bend 2 - Outage Spring 2002 | | | | | | | | | | | | | |
| BB2 Neural net | | | | | | | | 5,000 | 15,000 | 5,000 | 5,000 | 5,000 | 35,000 |
| BB2 Burner and Windbox mods | | | | | | | | 5,000 | 45,000 | 5,000 | 5,000 | 10,000 | 70,000 |

Total Capital = \$ 1,068,000

Total O&M = \$ 50,000

Total Expenditures = \$ 1,118,000

22

TAMPA ELECTRIC COMPANY
DOCKET NO. 000007-EI
WITNESS: STANLEY J. MARTIN
EXHIBIT NO. _____ (SJM-1)
DOCUMENT NO. 2
FILED: SEPTEMBER 21, 2000

Big Bend Station Forecast of Costs for Reductions of Particulate Matter

Year 2001

| Activity | January | February | March | April | May | June | July | August | Septem | October | Novem | Decem | Total |
|--|---------|----------|---------|---------|-------|-------|--------|--------|---------|---------|-------|-------|---------|
| O&M Activity | | | | | | | | | | | | | |
| Install turning vanes on BB1 | 10,000 | 10,000 | 60,000 | 35,000 | | | | | | | | | 115,000 |
| Capital Activity | | | | | | | | | | | | | |
| Big Bend 1 Spring Outage 2001 | | | | | | | | | | | | | |
| Perforated Plates for BB1 precipitator | 70,000 | 5,000 | 185,000 | 270,000 | 5,000 | | | | | | | | 545,000 |
| Pariculate Matter CEM | 14,500 | 7,000 | 7,500 | 6,000 | 6,000 | 4,000 | 4,000 | 90,000 | 20,000 | 15,000 | 2,000 | 2,000 | 178,000 |
| Big Bend 2 Outage Spring 2002 | | | | | | | | | | | | | |
| Perform Eng/Procure BACT items | | | | 5,000 | 6,000 | 7,000 | 10,000 | 10,000 | 210,000 | 6,000 | 6,000 | 5,000 | 265,000 |

Total Capital = \$ 958,000
 Total O&M = \$ 115,000
 Total Expenditures = \$ 1,103,000

23

TAMPA ELECTRIC COMPANY
 DOCKET NO. 000007-EI
 WITNESS: STANLEY J. MARTIN
 EXHIBIT NO. _____ (SJM-1)
 DOCUMENT NO. 3
 FILED: SEPTEMBER 21, 2000