

2001 Ten-Year Site Plan



2001 Ten-Year Site Plan for Electrical Generating Facilities and Associated Transmission Lines

Submitted to
Florida Public Service Commission

April 2001

DOCUMENT NUMBER-DATE

04201 APR-56

FPSC-RECORDS/REPORTING

27

building a world of difference™



BLACK & VEATCH

Contents

| | |
|---|------|
| Executive Summary | ES-1 |
| 1.0 Introduction..... | 1-1 |
| 1.1 General Description of the Utility..... | 1-1 |
| 1.2 Forecast of Electrical Power Demand and Energy Consumption..... | 1-1 |
| 1.3 Demand-Side Management Programs | 1-1 |
| 1.4 Forecasting Methods and Procedures | 1-2 |
| 1.5 Forecast of Facilities Requirements..... | 1-2 |
| 1.6 Analysis Results and Conclusions | 1-3 |
| 1.7 Environmental and Land Use Information | 1-3 |
| 1.8 Ten-Year Site Plan Schedules..... | 1-3 |
| 2.0 General Description of Utility | 2-1 |
| 2.1 City of Lakeland Historical Background | 2-1 |
| 2.1.1 Founding and Expansion..... | 2-1 |
| 2.1.2 Transmission..... | 2-3 |
| 2.2 General Description: Lakeland Electric..... | 2-6 |
| 2.2.1 Existing Generating Units..... | 2-6 |
| 2.2.2 Capacity and Power Sales Contracts..... | 2-8 |
| 2.2.3 Capacity and Power Purchase Contracts..... | 2-8 |
| 2.2.4 Planned Unit Retirements | 2-8 |
| 2.2.5 Total System Resources..... | 2-9 |
| 2.2.6 Load and Electrical Characteristics | 2-9 |
| 2.2.7 Transmission and Interconnections..... | 2-9 |
| 2.3 Service Area..... | 2-10 |
| 3.0 Forecast of Electrical Power Demand and Energy Consumption..... | 3-1 |
| 3.1 Service Territory Population Forecast | 3-1 |
| 3.2 Number of Accounts Forecast | 3-1 |
| 3.2.1 Residential Accounts | 3-2 |
| 3.2.2 Commercial and Industrial Accounts..... | 3-2 |

Contents (Continued)

| | | |
|-------|--|------|
| 3.3 | Sales Forecast..... | 3-5 |
| 3.3.1 | Residential Sales | 3-5 |
| 3.3.2 | Commercial and Industrial Sales | 3-5 |
| 3.3.3 | Other Sales | 3-6 |
| 3.3.4 | Total Sales..... | 3-6 |
| 3.4 | Net Energy for Load Forecast..... | 3-6 |
| 3.5 | Peak Demand | 3-6 |
| 3.6 | Sensitivity Cases | 3-10 |
| 3.6.1 | High Load Sensitivity | 3-10 |
| 3.6.2 | Low Load Sensitivity | 3-10 |
| 3.6.2 | High and Low Net Energy for Load | 3-10 |
| 4.0 | Demand-Side Management Programs | 4-1 |
| 4.1 | Existing Conservation and Demand-Side Management Programs | 4-1 |
| 4.1.1 | Existing Programs with Demonstrable Demand and Energy Savings | 4-1 |
| 4.1.2 | Non-Measurable Demand and Energy Savings | 4-3 |
| 4.1.3 | Demand-Side Management Technology Research | 4-4 |
| 4.2 | Solar Program Activities..... | 4-5 |
| 4.2.1 | Solar Powered Street Lights..... | 4-5 |
| 4.2.2 | Solar Thermal Collectors for Water Heating | 4-6 |
| 4.2.3 | Utility-Interactive Residential Photovoltaic Systems | 4-6 |
| 4.2.4 | Utility-Interactive Photovoltaic Systems on Polk County Schools..... | 4-7 |
| 4.2.5 | Integrated Photovoltaics for Florida Residences | 4-8 |
| 5.0 | Forecasting Methods and Procedures | 5-1 |
| 5.1 | Integrated Resource Planning | 5-1 |
| 5.2 | Florida Municipal Power Pool | 5-1 |
| 5.3 | Economic Parameters and Evaluation Criteria | 5-1 |
| 5.3.1 | Economic Parameters..... | 5-1 |
| 5.3.2 | Fuel Price Projections | 5-2 |
| 5.3.3 | Fuel Forecast Sensitivities | 5-13 |

Contents (Continued)

| | | |
|-------|---|-----|
| 6.0 | Forecast of Facilities Requirements..... | 6-1 |
| 6.1 | Need for Capacity | 6-1 |
| 6.1.1 | Load Forecast..... | 6-1 |
| 6.1.2 | Reserve Requirements | 6-1 |
| 6.1.3 | Additional Capacity Requirements | 6-1 |
| 7.0 | Analysis Results and Conclusions | 7-1 |
| 7.1 | Economic Evaluation | 7-1 |
| 7.1.1 | Supply-Side Economic Analysis..... | 7-2 |
| 7.1.2 | Demand-Side Economic Analysis | 7-2 |
| 7.2 | Sensitivity Analyses..... | 7-4 |
| 7.3 | Transmission..... | 7-4 |
| 7.4 | Strategic Concerns | 7-4 |
| 7.4.1 | Efficiency | 7-5 |
| 7.4.2 | Reliability Need | 7-5 |
| 7.4.3 | Deregulation..... | 7-5 |
| 7.4.4 | Timing..... | 7-5 |
| 7.4.5 | Fuel Risk | 7-6 |
| 7.4.6 | Environmental Impacts | 7-6 |
| 8.0 | Environmental and Land Use Information | 8-1 |
| 8.1 | Status of Site Certification | 8-1 |
| 8.2 | Land and Environmental Features | 8-1 |
| 8.3 | Air Emissions..... | 8-2 |
| 8.4 | Analysis of 1990 Clean Air Act Amendments | 8-2 |
| 8.4.1 | Authority to Construct | 8-2 |
| 8.4.2 | Title V Operating Permit | 8-2 |
| 8.4.3 | Title IV Acid Rain Permit..... | 8-3 |
| 8.4.4 | Compliance Strategy | 8-3 |
| 8.5 | Waste Supply and Use | 8-3 |
| 8.6 | Wastewater Discharge | 8-3 |
| 8.7 | Fuel Delivery and Storage | 8-4 |
| 9.0 | Ten-Year Site Plan Schedules..... | 9-1 |
| 9.1 | Abbreviations and Descriptions..... | 9-1 |

Contents (Continued)

Tables

| | | |
|------------|---|------|
| Table ES-1 | Ten-Year Reliability Levels Assuming a 188 MW Capacity Addition in 2005 (Winter / Base Case)..... | ES-3 |
| Table 2-1 | Lakeland Electric and Water Utilities Existing Generating Facilities | 2-5 |
| Table 2-2 | Lakeland Electric and Water Utilities Existing Generating Facilities Environmental Considerations for Steam Generating Units..... | 2-6 |
| Table 2-3 | Planned Unit Retirements | 2-8 |
| Table 3-1 | Forecast of Total Accounts and Sales For Lakeland | 3-3 |
| Table 3-2 | Winter Peak Demand – Base Case (MW)..... | 3-8 |
| Table 3-3 | Summer Peak Demand – Base Case (MW)..... | 3-9 |
| Table 3-4 | Winter Peak Demand – High Load (MW)..... | 3-11 |
| Table 3-5 | Summer Peak Demand – High Load (MW) | 3-12 |
| Table 3-6 | Winter Peak Demand – Low Load (MW)..... | 3-13 |
| Table 3-7 | Summer Peak Demand – Low Load (MW) | 3-14 |
| Table 3-8 | Net Energy for Load (MWh) | 3-15 |
| Table 5-1 | 2001 Annual Energy Outlook Real Fuel Price Projections and CAERs..... | 5-3 |
| Table 5-2 | Base Case Fuel Price Forecast Summary (Nominal Delivered Price \$/mmbtu)..... | 5-4 |
| Table 5-3 | FGT Transportation Rates..... | 5-10 |
| Table 5-4 | High Fuel Price Forecast Summary (Delivered Price \$/mmbtu)..... | 5-15 |
| Table 5-5 | Low Fuel Price Forecast Summary (Delivered Price \$/mmbtu)..... | 5-16 |
| Table 5-6 | Constant Differential Fuel Price Forecast Summary (Delivered Price \$/mmbtu)..... | 5-17 |
| Table 6-1 | Summary of System Peak Load Forecast (MW) * | 6-2 |
| Table 6-2 | Projected Reliability Levels - Winter / Base Case..... | 6-3 |
| Table 6-3 | Projected Reliability Levels - Summer / Base Case | 6-4 |
| Table 6-4 | Projected Reliability Levels - Winter / High Case..... | 6-5 |
| Table 6-5 | Projected Reliability Levels - Winter / Low Case | 6-6 |
| Table 7-1 | Ten-Year Reliability Levels Assuming a 188 MW Capacity Addition in 2005 (Winter / Base Case)..... | 7-3 |
| Table 9-1 | Schedule 1.0: Existing Generating Facilities as of December 31, 2000 | 9-3 |
| Table 9-2 | Schedule 2.1: History and Forecast of Energy Consumption and Number of Customers by Customer Class..... | 9-4 |

Contents (Continued)
Tables (Continued)

| | | |
|------------|---|------|
| Table 9-3 | Schedule 2.2: History and Forecast of Energy Consumption and Number of Customers by Customer Class..... | 9-5 |
| Table 9-4 | Schedule 2.3: History and Forecast of Energy Consumption and Number of Customers by Customer Class..... | 9-6 |
| Table 9-5 | Schedule 3.1: History and Forecast of Summer Peak Demand Base Case (MW)..... | 9-7 |
| Table 9-6 | Schedule 3.2: History and Forecast of Winter Peak Demand Base Case (MW)..... | 9-8 |
| Table 9-7 | Schedule 3.3: History and Forecast of Annual Net Energy for Load – GWh Base Case..... | 9-9 |
| Table 9-8 | Schedule 4: Previous Year and Two Year Forecast of Retail Peak Demand and Net Energy for Load by Month..... | 9-10 |
| Table 9-9 | Schedule 5: Fuel Requirements..... | 9-11 |
| Table 9-10 | Schedule 6.1: Energy Sources..... | 9-12 |
| Table 9-11 | Schedule 6.2: Energy Sources..... | 9-13 |
| Table 9-12 | Schedule 7.1: Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Summer Peak..... | 9-14 |
| Table 9-13 | Schedule 7.2: Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Winter Peak..... | 9-15 |
| Table 9-14 | Schedule 8.0: Planned and Prospective Generating Facility Additions and Changes..... | 9-16 |
| Table 9-15 | Schedule 9.1: Status Report and Specifications of Approved Generating Facilities..... | 9-17 |
| Table 9-16 | Schedule 9.2: Status Report and Specifications of Proposed Generating Facilities..... | 9-18 |
| Table 9-17 | Schedule 10: Status Report and Specifications of Proposed Directly Associated Transmission Lines..... | 9-19 |

Figures

| | | |
|------------|---|------|
| Figure 2-1 | Electric System Transmission Map..... | 2-11 |
| Figure 4-1 | Solar Powered Streetlight..... | 4-6 |
| Figure 4-2 | Portable Classroom Topped by PV Panels..... | 4-8 |
| Figure 4-3 | Solar House and Control House..... | 4-9 |
| Figure 5-1 | Gulfstream Natural Gas Pipeline..... | 5-8 |
| Figure 8-1 | Site Location..... | 8-5 |

Executive Summary

This report documents the 2001 Lakeland Electric (Lakeland) Ten-Year Site Plan pursuant to 186.801 Florida Statutes and 25-22.070 - 22.073 Florida Administrative Code. The Ten-Year Site Plan provides information required by this rule. The Plan is divided into nine main sections: Introduction, General Description of Utility, Forecast of Electrical Power Demand and Energy Consumption, Demand-Side Management Programs, Forecasting Methods and Procedures, Forecast of Facilities Requirements, Analysis Results and Conclusions, Environmental and Land Use Information, and Ten-Year Site Plan Schedules.

Power for the City of Lakeland is supplied by Lakeland Electric wholly and jointly owned generating units. Lakeland Electric is also a member of the Florida Municipal Power Pool (FMPP). The total installed generating capacity based on Lakeland's ownership share is 647 MW winter and 614 MW summer as of December 31, 2000. The existing supply system has a broad range of generation technology and capabilities, but is heavily dependent upon natural gas.

Lakeland Electric has projected peak demand growth and energy consumption for the planning period. A banded forecast is provided with a base case growth, high growth, and low growth scenarios. Lakeland has adopted the use of a reserve margin criteria equal to 22 percent in the winter and 20 percent in the summer. Considering the forecasted growth, existing units, retiring units, power sales contracts, and reserve margin criteria, there emerges a need for additional capacity before the winter of 2005/06.

Lakeland Electric currently employs an aggressive demand-side management (DSM) program to improve the efficiency of consumer electricity usage. The DSM program includes two residential and three commercial programs as well as additional energy savings and energy efficiency promotion programs.

As a result of its 2000 Ten-Year Site Plan, Lakeland identified a 288 MW solid fuel unit as the most cost-effective addition to its system. As a result, Lakeland initiated a request for EPC and power purchase proposals (RFP) in June, 2000. Bids were received in December, 2000 and are currently under evaluation along with other options available to Lakeland.

While the evaluation of these options is ongoing, for purposes of the 2001 Ten-Year Site Plan, a 288 MW solid fuel unit (188 MW is Lakeland's assumed share) has been assumed to be installed in June, 2005 at the McIntosh Site (McIntosh 4). Based on the 2000 TYSP, this unit is assumed to be a pressurized fluidized bed combined cycle (PFBC) consisting of three P200 modules with petroleum coke as the primary fuel. As the evaluations of Lakeland's options advance, the plan will be revised as appropriate and

will form the basis of Lakeland's Need for Power filing expected in the spring of 2001. Table ES-1 presents the expansion plan for purposes of the 2001 Ten-Year Site Plan. As seen in this table, if Lakeland secured 188 MW of power in 2005, its capacity needs would be met over the ten year horizon.

In addition to cost considerations, strategic, environmental and land use considerations are being factored into the resource plans. This will ensure that the most cost-effective plan selected is environmentally and socially responsible, consistent with Lakeland Electric's commitment to the community.

Table ES-1
Ten-Year Reliability Levels Assuming a 188 MW Capacity Addition in 2005 (Winter / Base Case)

| Winter Peak Period | Net Generating Capacity (MW) | Unit ¹ Additions/ (Retirements) (MW) | Net System Purchases/ (Sales) (MW) | Net System Capacity (MW) | System Peak Demand | | Reserve Margin | | Excess/ (Deficit) to Maintain 22% Reserve Margin | | |
|--------------------|------------------------------|---|------------------------------------|--------------------------|---|--|--|---|--|--|--|
| | | | | | Before Interruptible and Load Management (MW) | After Interruptible and Load Management (MW) | Before Interruptible and Load Management (%) | After Interruptible and Load Management (%) | Before Interruptible and Load Management (MW) | After Interruptible and Load Management (MW) | |
| 2000/2001 | 647 | L6 (24 MW) | | | | | | | | | |
| 2001/2002 | 891 | M5 CT 268 MW M5 CC 384 MW L7 (50 MW) | (100) | 791 | 691 | 627 | 14.5 | 26.2 | (52.0) | 26.1 | |
| 2002/2003 | 957 | | (100) | 857 | 708 | 644 | 21.0 | 33.1 | (6.8) | 71.3 | |
| 2003/2004 | 957 | | (100) | 857 | 727 | 662 | 17.9 | 29.5 | (29.9) | 49.4 | |
| 2004/2005 | 957 | | (100) | 857 | 745 | 679 | 15.0 | 26.2 | (51.9) | 28.6 | |
| 2005/2006 | 1,058 | M4 188 MW M1 (87 MW) | (100) | 958 | 764 | 697 | 25.4 | 37.4 | 25.9 | 107.7 | |
| 2006/2007 | 1,058 | | (100) | 958 | 781 | 714 | 22.7 | 34.2 | 5.2 | 86.9 | |
| 2007/2008 | 1,058 | | (100) | 958 | 800 | 732 | 19.8 | 30.9 | (18.0) | 65.0 | |
| 2008/2009 | 1,058 | | (100) | 958 | 817 | 749 | 17.3 | 27.9 | (38.7) | 44.2 | |
| 2009/2010 | 1,058 | | (100) | 958 | 836 | 767 | 14.6 | 24.9 | (61.9) | 22.3 | |
| 2010/2011 | 1,058 | | 0 | 1,058 | 853 | 784 | 24.0 | 34.9 | 17.3 | 101.5 | |

¹ L: Larsen Unit
M: McIntosh Unit

1.0 Introduction

This report contains the 2001 Lakeland Electric Ten-Year Site Plan (TYSP) pursuant to Florida Statutes and as adopted by Order No. PSC-97-1373-FOF-EU on October 30, 1997. The Lakeland TYSP reports the status of the utility's resource plans as of December 31, 2000. The TYSP is divided into the following nine sections: Introduction, General Description of Utility, Forecast of Electrical Power Demand and Energy Consumption, Conservation and Demand-Side Management, Forecasting Methods and Procedures, Forecast of Facilities Requirements, Analysis Results and Conclusions, Environmental and Land Use Information, and Ten-Year Site Plan Schedules. The contents of each section is summarized briefly in the remainder of this Introduction.

1.1 General Description of the Utility

Section 2.0 of the TYSP discusses Lakeland's existing generation and transmission facilities. The section includes a historical overview of Lakeland's system, and a description of existing power generating and transmission facilities. This section includes tables which show the source of the utility's current 647 MW of net winter generating capacity and 614 MW of net summer generating capacity (in the year 2000).

1.2 Forecast of Electrical Power Demand and Energy Consumption

Section 3.0 of the TYSP provides a summary of Lakeland's load forecast. Lakeland is projected to remain a winter peaking system throughout the planning period. The projected annual growth rates in peak demand for the winter and summer are 2.29 and 2.20 percent, respectively, for 2001 through 2020.

Net energy for load is projected to grow at an average annual rate of 2.07 percent for 2001 through 2020, a lower growth rate than occurred over the past 10 years. Projections are also developed for high and low load growth scenarios.

1.3 Demand-Side Management Programs

Section 4.0 provides descriptions of the existing conservation and demand-side management programs. Additional details regarding Lakeland's demand-side management programs are on file with the Florida Public Service Commission (FPSC).

Lakeland's current conservation and demand management programs include the following programs for which demand and energy savings can readily be demonstrated:

- Residential Programs:
 - SMART Load Management Program.
 - Loan Program.
- Commercial Programs:
 - Commercial Lighting Program.
 - Thermal Energy Storage Program.
 - High-Pressure Sodium Outdoor Lighting Program.

Lakeland also currently conducts the following conservation and demand-side management programs which promote energy savings and efficiency:

- Residential Programs:
 - Energy Audit Program.
 - Public Awareness Program.
 - Mobile Display Unit.
 - Speakers Bureau.
 - Informational Bill Inserts.
- Commercial Programs:
 - Commercial Audit Program.

1.4 Forecasting Methods and Procedures

Section 5.0 discusses the forecasting methods used for the TYSP and outlines the assumptions applied for system planning. This section also summarizes the integrated resource plan for Lakeland and provides planning criteria for the Florida Municipal Power Pool, of which Lakeland is a member. The integrated resource plan is fully incorporated in the TYSP.

Fuel price projections are provided for coal, natural gas, oil, and petroleum coke; with brief descriptions of the methodology. Three sensitivities are provided for the fuel price forecast: a high fuel price scenario, a low fuel price scenario, and a constant differential scenario.

Assumptions for the economic parameters and evaluation criteria which are being applied in the evaluation are also included in Section 5.0.

1.5 Forecast of Facilities Requirements

Section 6.0 integrates the electrical demand and energy forecast with the conservation and demand-side management forecast to determine Lakeland's require-

ments for the ten-year planning horizon. Application of the reserve margin criteria indicates a need for additional capacity by the winter of 2005/06.

1.6 Analysis Results and Conclusions

Section 7.0 discusses the supply-side evaluation being undertaken by Lakeland to identify the best option for its system. It also discusses the capacity temporarily assumed for the purposes of this report and until a preferred alternative is selected.

1.7 Environmental and Land Use Information

Section 8.0 discusses the land and environmental features of Lakeland's TYSP.

1.8 Ten-Year Site Plan Schedules

Section 9.0 presents the schedules required by the Florida Public Service Commission (FPSC) for the TYSP.

2.0 General Description of Utility

2.1 City of Lakeland Historical Background

2.1.1 *Founding and Expansion*

The City of Lakeland was incorporated on January 1, 1885, when 27 citizens approved and signed the city charter. Shortly thereafter the original light plant was built by Lakeland Light and Power Company at the corner of Cedar Street and Massachusetts Avenue. This plant had an original capacity of 50 kW. On May 26, 1891, plant manager Harry Sloan threw the switch to light Lakeland by electricity for the first time with five arc lamps. Incandescent lights were first installed in 1903.

Public power in Lakeland was established in 1904, when foresighted citizens and municipal officials purchased the small private 50 kW electric light plant from owner Bruce Neff for \$7,500. The need for an expansion led to the construction of a new power plant on the north side of Lake Mirror in 1916. The initial capacity of the Lake Mirror Power Plant is estimated to have been 500 kW. The plant has since been expanded three times. The first expansion occurred in 1922 with the addition of 2,500 kW; in 1925, 5,000 kW additional capacity was added, followed by another 5,000 kW in 1938. With the final expansion, the removal of the initial 500 kW unit was required to make room for the addition of the 5,000 kW generating unit, resulting in a total peak plant capacity of 12,500 kW.

As the community continued to grow, the need for a new power plant emerged and the Charles Larsen Memorial Power Plant was constructed on the southeast shore of Lake Parker in 1949. The initial capacity of the Larsen Plant Steam Unit No. 4 completed in 1950 was 20,000 kW. The first addition to the Larsen Plant was Steam Unit No. 5 (1956) which had a capacity of 25,000 kW. In 1959, Steam Unit No. 6 was added and increased the plant capacity by another 25,000 kW. Three gas turbines, each with a nominal rating of 11,250 kW, were installed as peaking units in 1962. In 1966, a third steam unit capacity addition was made to the Larsen Plant. This was Steam Unit No. 7 having a nominal 44,000 kW capacity and an estimated cost of \$9.6 million. This brought the total Larsen Plant nameplate capacity up to a nominal 147,750 kW.

In the meantime, the Lake Mirror Plant, with its old and obsolete equipment, became relatively inefficient and hence was no longer in active use. It was kept in cold standby and then retired in 1971.

As the city continued to grow during the late 1960's, the demand for power and electricity grew at a rapid rate, making evident the need for a new power plant. A site was purchased on the north side of Lake Parker and construction commenced during

1970. Initially, two diesel units with a peaking capacity of a nominal rating 2,500 kW each were placed into commercial operation in 1970.

Steam Unit No. 1, with a nominal rating of 90,000 kW, was put into commercial operation on February 24, 1971, for a total cost of \$15.22 million. In June of 1976, Steam Unit No. 2 at Plant 3 was placed into commercial operation, with a nominal rated capacity of 114,707 kW and at a cost of \$25.77 million. This addition increased the total capacity of the Lakeland system to approximately 360,000 kW. At this time, Plant 3 was renamed the C. D. McIntosh, Jr. Power Plant in recognition of the former Electric and Water Department director.

On January 2, 1979, construction was started on McIntosh Unit No. 3, a nominal 334 MW coal fired steam generating unit which became commercial on September 1, 1982. The unit is capable of using low sulfur oil as an alternate fuel and supplemented by prepared solid waste. The plant utilized sewage effluent for cooling tower makeup water. This unit is jointly owned with the Orlando Utilities Commission (OUC) which has a 40 percent undivided interest in the unit.

As load continued to grow, Lakeland continually studied and reviewed alternatives for accommodating the additional growth. Alternatives included both demand- and supply-side resources. A wide variety of conservation and demand-side management programs were developed and marketed to Lakeland customers to encourage increased energy efficiency and conservation in keeping with the Florida Energy Efficiency and Conservation Act of 1980 (FEECA). These programs are discussed in further detail in Section 4.0.

Although demand and energy savings arose from Lakeland's conservation and demand-side management programs, additional capacity was required in the early 1990's. Least cost planning studies resulted in the construction of Larsen Unit No. 8, a natural gas fired combined cycle unit with a nameplate generating capability of 124,000 kW. Larsen Unit No. 8 began simple cycle operation in July 1992, and combined cycle operation in November of that year.

In 1994, Lakeland made the decision to retire the first unit at Larsen Plant, Steam Unit No. 4. This unit, put in service in 1950 with a capacity of 20,000 kW, had reached the end of its economic life. In March of 1997, Lakeland placed into cold shutdown, Larsen Unit No. 6, a 25 MW oil fired unit that was also nearing the end of its economic life.

In 1998, Lakeland regained 9 MW (its 60 percent share) from the McIntosh 3 unit after performing non-routine maintenance activities to upgrade the turbine steam path. This capacity is reflected in the unit's current performance ratings. Additional data regarding Lakeland's existing units and system are summarized in Tables 2-1 and 2-2.

In 1998, Lakeland had two long-term power purchase contracts terminated by the suppliers. The first contract was a 20 MW contract with Enron through December of 2001. The second contract, for 10 MW of baseload power, was with TECO and initially scheduled through September of 2006. Both companies paid premiums to Lakeland for the early termination of these contracts. As a result, Lakeland brought Larsen Unit No. 6 out of cold shutdown to meet its reliability requirements.

In 1999, the construction of McIntosh Unit No. 5 Simple Cycle combustion turbine was completed. The unit is in the final stages of extended check out and testing, and is scheduled to be released for commercial operation in May, 2001. The unit will be converted to a combined cycle unit by the addition of a steam turbine generator. Construction of the conversion began July 24, 2000. The scheduled commercial operation date for the combined cycle unit is January of 2002.

2.1.2 Transmission

The first phase of the Lakeland 69 kV transmission system was placed in operation in 1961 with a step-down transformer at the Lake Mirror Plant to feed the 4 kV bus, nine 4 kV feeders, and a new substation in the southwest section of town with two step-down transformers feeding four 12 kV feeders.

In 1966, a 69 kV line was completed from the northwest substation to the southwest substation, completing the loop around town. At the same time, the old tie to Bartow was reinsulated for a 69 kV line and placed in operation, feeding a new step-down substation in Highland City with four 12 kV feeders. In addition, a 69 kV line was completed from Larsen Plant around the southeast section of town to the southwest substation. By 1972, 20 sections of 69 kV lines, feeding a total of nine step-down substations, with a total of 41 distribution feeders, were completed and placed in service. By the fall of 1996, all of the original 4 kV equipment and feeders had been replaced and/or upgraded to 12 kV service. By 1998, 29 sections of 69 kV lines were in service feeding 20 distribution substations.

As the Lakeland system continued to grow, the need for additional and larger transmission facilities grew as well. In 1981, Lakeland's first 230 kV facilities went into service to accommodate Lakeland's McIntosh Unit No. 3 and to tie Lakeland into the State transmission grid at the 230 kV level. A 230 kV line was built from McIntosh Plant to Lakeland's west substation. A 230/69 kV autotransformer was installed at each of those substations to tie the 69 kV and 230 kV transmission systems together. In 1988, a second 230 kV line was constructed from the McIntosh Plant to Lakeland's Eaton Park substation along with a 230/69 kV autotransformer at Eaton Park. That line was the next

phase of the long-range goal to electrically circle the Lakeland service territory with 230 kV transmission to serve as the primary backbone of the system.

In 1999, Lakeland added generation at its McIntosh Power Plant that resulted in a new 230/69/12kV substation being built and energized in March of that year. The substation, Tenoroc, replaced the switching station called North McIntosh. In addition to Tenoroc, another new 230/69/12kV substation was built. The substation, Interstate, went on line June of 1999 and is connected by what was the McIntosh West 230 kV line. This station was built to address concerns about load growth in the areas adjacent to the I-4 corridor which were causing problems at both the 69kV and distribution levels in this area.

Early transmission interconnections with other systems included a 69 kV tie at Larsen Plant with Tampa Electric Company (TECO), established in the mid 1960s. A second tie with TECO was later established at Lakeland's Highland City substation. A 115 kV tie was established in the 1970s with Florida Power Corporation (FPC) and Lakeland's west substation and was subsequently upgraded and replaced with the current two 230 kV lines to FPC in 1981. At the same time, Lakeland interconnected with Orlando Utilities Commission (OUC) at Lakeland's McIntosh Power Plant. In August 1987, the 69 kV TECO tie at Larsen Power Plant was taken out of service and a new 69 kV TECO tie was put in service connecting Lakeland's Orangedale substation to TECO's Polk City substation. In mid-1994, a new 69 kV line was energized connecting Larsen Plant to the Ridge Generating Station (Ridge), an independent power producer. Lakeland has a 30-year firm power-wheeling contract with Ridge to wheel up to 40 MW of their power to FPC. In early 1996, a new substation, East, was inserted in the Larsen Plant to the Ridge 69 kV transmission line. Later in 1996, the third tie line to TECO was built from East to TECO's Gapway substation. The multiple 230 kV interconnection configuration of Lakeland is also tied into the bulk transmission grid and provides access to the 500 kV transmission network via FPC, providing for greater reliability. At the present time, Lakeland has a total of approximately 108.6 miles of the 69 kV transmission and 18.3 miles of the 230 kV transmission lines in service along with five 150 MVA 230/69 kV autotransformers.

Table 2-1
Lakeland Electric and Water Utilities Existing Generating Facilities

| Plant Name | Unit No. | Location | Unit Type ³ | Fuel ⁴ | | Fuel Transport ⁵ | | Alt Fuel Days Use ² | Commercial In-Service Month/Year | Expected Retirement Month/Year | Gen. Max. Nameplate kW | Net Capability | |
|--|-----------------------------------|---------------|------------------------|------------------------|---------------------|-----------------------------|-----|---|----------------------------------|--------------------------------|------------------------|----------------|------------|
| | | | | Pri | Alt | Pri | Alt | | | | | Summer MW | Winter MW |
| Charles Larsen Memorial | 2 | 16-17/28S/24E | GT | NG | DFO | PL | TK | NR | 11/62 | Unknown | 11,500 | 10 | 14 |
| | 3 | | GT | NG | DFO | PL | TK | NR | 12/62 | Unknown | 11,500 | 10 | 14 |
| | 5 | | CA | WH | --- | --- | --- | NR | 04/56 | Unknown | 25,000 | 29 | 31 |
| | 6 | | ST | NG | RFO | PL | TK | NR | 12/59 | 10/01 | 25,000 | 24 | 24 |
| | 7 | | ST | NG | RFO | PL | TK | NR | 02/66 | 01/02 | 50,000 | 50 | 50 |
| | 8 | | CT | NG | DFO | PL | TK | NR | 07/92 | Unknown | 101,520 | <u>73</u> | <u>93</u> |
| Plant Total | | | | | | | | | | | 196 | 226 | |
| C.D. McIntosh, Jr. | IC1 | 4-5/28S/24E | IC | DFO | --- | TK | --- | NR | 01/70 | Unknown | 2,500 | 3 | 3 |
| | IC2 | | IC | DFO | --- | TK | --- | NR | 01/70 | Unknown | 2,500 | 3 | 3 |
| | 1GT | | GT | NG | DFO | PL | TK | NR | 05/73 | Unknown | 26,640 | 17 | 20 |
| | ST1 | | ST | NG | RFO | PL | TK | NR | 02/71 | 10/05 | 103,000 | 87 | 87 |
| | ST2 | | ST | NG | RFO | PL | TK | NR | 06/76 | Unknown | 126,000 | 103 | 103 |
| | ST3 ¹ | | ST | BIT | --- | RR | --- | NR | 09/82 | Unknown | 363,870 | <u>205</u> | <u>205</u> |
| Plant Total | | | | | | | | | | | 418 | 421 | |
| System Total | | | | | | | | | | | 614 | 647 | |
| ¹ Lakeland's 60 percent portion of joint ownership with Orlando Utilities Commission. | | | | | | | | | | | | | |
| ² Lakeland does not maintain records of the number of days that alternate fuel is used. | | | | | | | | | | | | | |
| ³ Unit Type | | | | ⁴ Fuel Type | | | | ⁵ Fuel Transportation Method | | | | | |
| CA | Combined Cycle Steam Part | | | DFO | Distillate Fuel Oil | | | PL | Pipeline | | | | |
| CT | Combined Cycle Combustion Turbine | | | RFO | Residual Fuel Oil | | | TK | Truck | | | | |
| GT | Combustion Gas Turbine | | | BIT | Bituminous Coal | | | RR | Railroad | | | | |
| ST | Steam Turbine | | | WH | Waste Heat | | | | | | | | |
| | | | | NG | Natural Gas | | | | | | | | |

| Table 2-2 Lakeland Electric and Water Utilities Existing Generating Facilities Environmental Considerations for Steam Generating Units | | | | | |
|--|------|-------------|-------------------|-----------------|------|
| Plant Name | Unit | Particulate | Flue Gas Cleaning | | Type |
| | | | SO _x | NO _x | |
| Charles Larsen Memorial | 6 | None | None | None | OTF |
| | 7 | None | None | None | OTF |
| | 8ST | N/A | N/A | N/A | OTF |
| C. D. McIntosh, Jr. | 1 | None | None | None | OTF |
| | 2 | None | LS | FGR | WCTM |
| | 3 | EP | S | LNB | WCTM |
| <p>FGR = Flue gas recirculation LNB = Low NO_x burners EP = Electrostatic precipitators LS = Low sulfur fuel S = Scrubbed OTF = Once-through flow WCTM = Water cooling tower mechanical N/A = Not applicable to waste heat applications</p> | | | | | |
| Source: Lakeland Environmental Staff | | | | | |

2.2 General Description: Lakeland Electric

2.2.1 Existing Generating Units

This section provides additional detail on Lakeland’s existing units and transmission system. Lakeland’s existing generating units are located at the two existing plant sites: Charles Larsen Memorial (Larsen) and C.D. McIntosh Jr. (McIntosh). Both plant sites are located on Lake Parker in Polk County, Florida. The two plants have multiple units with different technologies and fuel types. The following paragraphs provide a summary of the existing generating units for Lakeland. Table 2-1 summarizes the characteristics of the Lakeland generating units.

The Larsen site is located on the southeast shore of Lake Parker in Lakeland. The site has six existing units following the sale of Unit No. 1 to General Electric and its physical removal from the plant in 1998. The total net winter (summer) capacity of the plant is 226 MW (196 MW). Units 2 and 3 have a net winter (summer) rating of 14 MW (10 MW). These units burn natural gas as the primary fuel with diesel backup. Historically, Unit No. 5 consisted of a boiler for steam generation and steam turbine to convert the steam to electrical power. When the

boiler began to show signs of degradation beyond economical repair, a gas turbine with a heat recovery steam generator, Unit No. 8, was added to the facility. This allowed the gas turbine (Unit No. 8) to generate electricity and the waste steam from the turbine to be injected to the Unit No. 5 steam turbine for a combined cycle configuration. The Unit No. 5 steam turbine now has a net winter (summer) rating of 31 MW (29 MW) and the Unit No. 8 combustion turbine has a net winter (summer) rating of 93 MW (73 MW). Unit No. 6 is a net 24 MW steam turbine burning natural gas that was placed in cold shutdown but was returned to service in 1998 due to the termination of the ENRON and TECO power purchase agreements. Unit No. 6 was slated for retirement in March 1999, but due to the delay of commercial operation of McIntosh Unit No. 5, Unit No. 6 remains in operation and is now scheduled for retirement in October, 2001. Unit No. 7 had been derated for several years due to boiler tube problems. The unit underwent significant boiler tube replacement in 1998 to bring the total net capacity of the unit up to 50 MW and is scheduled for retirement as part of a power sales agreement in January of 2002.

The McIntosh site is located in the City of Lakeland along the northeastern shore of Lake Parker and encompasses 513 acres. Electricity generated by the McIntosh units is stepped up in voltage by generator step-up transformers to 69 kV and 230 kV for transmission via the power grid. The McIntosh site currently includes six units in commercial operation having a total net winter and summer capacity of 421 MW and 418 MW, respectively. Unit CT1 consists of a General Electric combustion turbine with a net winter (summer) output rating of 20 MW (17 MW). Unit No. 1 is a natural gas/oil fired General Electric steam turbine with a net winter and summer output of 87 MW. Unit No. 2 is a natural gas/oil fired Westinghouse steam turbine with a winter and summer output of 103 MW. Unit No. 3 is a pulverized coal (primary fuel) fired unit owned 60 percent by Lakeland and 40 percent by OUC. Lakeland's share of the unit yields net winter and summer output of 205 MW. Unit No. 3 includes a wet flue gas scrubber for SO₂ removal and uses treated sewage water for cooling water. Two small diesel units with a net output of 3 MW each are also located at the McIntosh site.

Construction of Lakeland's seventh unit at McIntosh (Unit No. 5) is complete. The unit, a Westinghouse 501G combustion turbine, is scheduled for commercial operation May, 2001. The combustion turbine unit is expected to have a net output of 268 MW (221 MW) in the winter (summer) and will burn natural gas as the primary fuel. The unit has a guaranteed full load heat rate of 9,684 Btu/kWh higher heating value (HHV). This unit will be converted to combined cycle in January 2002. The McIntosh Unit No. 5 conversion has been approved by the FPSC and will consist of adding a heat recovery steam generator (HRSG) with new stack, a steam turbine, electrical generator, cooling tower and condenser, and associated balance-of-plant equipment.

2.2.2 Capacity and Power Sales Contracts

Lakeland had two firm power sales contracts in place as of December 31, 2000. The first contract was with TEA for a 25 MW power sale from the Larsen Unit 7. The term of this transaction was from January 1, 1999 through February 28, 2001. The second power sales contract is with the Florida Municipal Power Agency (FMPA) for capacity and energy. The contract is for 50 MW from December 15, 2000 to June 14, 2001; then 100 MW from June 15, 2001 through December 15, 2010.

Lakeland also shares ownership of the C. D. McIntosh Unit 3 with OUC. The ownership breakdown is a 60 percent share for Lakeland and a 40 percent ownership share for OUC. The energy and capacity delivered to OUC from McIntosh Unit 3 is not considered a power sales contract because of the OUC ownership share.

2.2.3 Capacity and Power Purchase Contracts

Lakeland currently has no power purchase contracts.

2.2.4 Planned Unit Retirements

Lakeland plans to retire older, less efficient units as new capacity comes on line and makes it economical to do so. These new additions will also produce the benefit of increased reliability and lower emissions on a kWh basis compared to the older generating units. Such retirements are consistent with Lakeland’s strategic considerations for the future. Based on these considerations, Table 2-3 shows the units which are scheduled to be retired over the upcoming years based upon the expansion plan identified and pending FPSC approval of capacity additions.

| <u>Unit Name</u> | <u>Current Age (years)</u> | <u>Net Summer Capacity (MW)</u> | <u>Net Winter Capacity (MW)</u> | <u>Anticipated Retirement Date</u> |
|------------------|----------------------------|---------------------------------|---------------------------------|------------------------------------|
| Larsen 6 | 41 | 24 | 24 | 10/2001 |
| Larsen 7 | 35 | 50 | 50 | 01/2002 |
| McIntosh 1 | 30 | 87 | 87 | 10/2005 |

Larsen 6 - removed from cold shutdown to active duty in 1998 to replace the lost capacity from the Enron and TECO contracts - is scheduled for retirement after the summer peak of 2001 and when McIntosh 5 is in commercial operation. Larsen Unit 7 is scheduled to be retired in January of 2002. McIntosh Unit 1 is scheduled for retirement in October of 2005.

2.2.5 Total System Resources

Lakeland's total net capacity for the winter (the winter peak is in January) and summer of 2001 is estimated to be 647 MW and 835 MW, respectively. The total capacity includes the capacity from McIntosh Unit 5 which is expected to be in commercial operation in May of 2001. Of the total 647 MW of winter net capacity, 405 MW, or 63 percent, is gas fired. After McIntosh Unit 5 comes into commercial operation in 2001, 595 MW of the 835 MW of summer net capacity, or 71 percent, will be gas fired.

2.2.6 Load and Electrical Characteristics

Lakeland's load and electrical characteristics have many similarities with those of other peninsular Florida utilities. The peak demand has historically occurred during the winter months. Lakeland's actual total peak demand in the winter of 1999/00 was 661 MW, but was reduced to a net demand of 610 MW after accounting for 51 MW of residential load management. This peak occurred on January 27, 2000. The actual summer peak in 2000 was 552 MW and occurred on July 20, 2000. Lakeland's historical and projected summer and winter peak demands are presented in Section 3.0.

Lakeland is a member of the Florida Municipal Power Pool (FMPP), along with Orlando Utilities Commission (OUC), Florida Municipal Power Agency's (FMPA) All-Requirements Project, and Kissimmee Utility Authority (KUA). The FMPP operates as an hourly energy pool with all FMPP capacity from its four members committed and dispatched together. Commitment and dispatch services for FMPP are provided by OUC. Each member of the FMPP retains the responsibility of adequately planning its own system to meet native load and Florida Reliability Coordinating Council (FRCC) reserve requirements.

2.2.7 Transmission and Interconnections

Lakeland's electric system is interconnected with Florida Power Corporation (FPC) and Orlando Utilities Commission (OUC) via three 230 kV transmission lines, which connect to the West substation and McIntosh substation, respectively, and with Tampa Electric Company (TECO) via three 69 kV ties. In mid-1994, a new 69 kV tie-line was energized from the Larsen Plant to the Ridge Generating Station, an independent power producer. In early 1996, a new substation, East, was inserted in the Larsen Plant to Ridge 69 kV line. Later in 1996, the third tie line to TECO was built from East to TECO's Gapway substation. These ties are sufficient to support the electric system in a peak period. The multiple 230 kV interconnection configuration of Lakeland is also tied into the state bulk transmission grid and provides access to the 500 kV transmission network via FPC. This ultimately provides for greater reliability; however, Lakeland's system has sufficient internal generation to supply its requirements in a peak period independent of its ties. Figure 2-1 shows the Lakeland service territory and transmission

facilities. In addition to these facilities, a 9.4 mile, 230 kV transmission line is proposed between Eaton Park and Crew's Lake. This line is projected to come into service in mid-2001.

At the present time, there are a total of twenty one 69/12 kV substations, feeding more than 90 circuits. Included in this total are six 12 kV feeders connected directly to the generator bus at Larsen Plant. Two of the 69/12 kV substations, West and Eaton Park, have a 230/69 kV autotransformer to tie the 69 kV system to Lakeland's internal 230 kV transmission system via the Tenoroc 230 kV switchyard which also has a 230/69 kV autotransformer. A fifth 230/69 kV autotransformer is located at the Interstate substation that also ties the 69 kV and 230 kV system together.


2.3 Service Area

Lakeland's electric service area is shown on Figure 2-1 and is entirely located in Polk County. Lakeland serves approximately 246 square miles including approximately 199 square miles outside of Lakeland's city limits.



LAKELAND ELECTRIC SYSTEM EXISTING ELECTRIC TRANSMISSION SYSTEM FACILITIES

2000



- LEGEND**
- ☒ POWER PLANT
 - 230KV SWITCHYARD
 - ⊙ 230/66KV SUBSTATION
 - ⊙ 230/12KV SUBSTATION
 - ⊙ 230/89/12KV SUBSTATION
 - ⊙ 66/12KV SUBSTATION
 - ⊕ LAKELAND TIE INTERCONNECT
 - 66KV UNDERGROUND TRANSMISSION LINE
 - 66KV TRANSMISSION LINE
 - 66KV TRANSMISSION TIE INTERCONNECT
 - 230KV TRANSMISSION LINE
 - 230KV TRANSMISSION TIE INTERCONNECT
 - ELECTRIC SERVICE BOUNDARY

- KEY**
- A PALMETTO
 - B GIBSONIA
 - D DRAMEFIELD
 - E GROVE
 - F TEMEROC
 - G GALLOWAY
 - EE HEMP HILL
 - J SOUTHWEST
 - K NORTHWEST
 - L HIGHLAND CITY
 - M MEDULLA
 - N LARSEN
 - O INTERSTATE
 - OB OWENS BROOKWAY
 - P MOUNTOSH
 - Q SOORUM
 - R EATON PARK
 - S SUTTON
 - T WINSTON
 - V DRANEDALE
 - W WEST
 - X EAST
 - Y GLENDALE
 - Z LAKE MIRROR

| REVISION | DATE | BY | DATE | REVISION DESCRIPTION | REVISION DESCRIPTION |
|----------|----------|-------------|----------|--|----------------------|
| 1 | 08/01/00 | W. B. BROWN | 08/01/00 | REVISED DRAWING - INTERCONNECT TO TOWN | |
| 2 | 08/01/00 | W. B. BROWN | 08/01/00 | ADDED INTERCONNECT TO TOWN | |
| 3 | 08/01/00 | W. B. BROWN | 08/01/00 | ADDED INTERCONNECT TO TOWN | |
| 4 | 08/01/00 | W. B. BROWN | 08/01/00 | ADDED INTERCONNECT TO TOWN | |
| 5 | 08/01/00 | W. B. BROWN | 08/01/00 | ADDED INTERCONNECT TO TOWN | |
| 6 | 08/01/00 | W. B. BROWN | 08/01/00 | ADDED INTERCONNECT TO TOWN | |



Figure 2-1
Electric System Transmission Map

3.0 Forecast of Electrical Power Demand and Energy Consumption

Lakeland routinely develops a detailed long-term electric load and energy forecast for use in its long-term planning studies. The primary technique used is econometric although Lakeland also develops a short-term forecast for short-term budgeting and planning purposes using time-series decomposition models. Lakeland develops a detailed, long-term forecast for the following categories on a fiscal year basis, which ends on September 30.

- Service territory population
- Number of accounts
- Sales
- Net energy for load
- Summer peak demand
- Winter peak demand

The following sections discuss each of the forecast categories. The information is presented on a fiscal year basis and is aggregated per the requirements of the Florida Reliability Coordinating Council (FRCC).

3.1 Service Territory Population Forecast

The projections of service territory population utilize regression analysis techniques in which Polk County population and time were the independent variables. Lakeland's projection of Polk County population was adopted from the 1998 Annual Bureau of Economic and Business Research (BEBR). The historical service territory population was derived by using the residential accounts inside and outside the city and multiplying by the number of persons per household from the 1994 Appliance Saturation Survey.

The resulting forecast projects the service territory population to increase at a 1.37 percent average annual growth rate (AAGR) from 2001 through 2020. The historical and forecast service area population estimates are shown in Table 3-1.

3.2 Number of Accounts Forecast

Lakeland forecasts the number of accounts in the following categories:

- Residential
- Commercial:
 - General Service
 - General Service Demand

- Industrial:
 - General Service Large Demand
- Street & Highway Lighting:
 - Private Area Lighting
 - Unmetered
- Other:
 - Electric
 - Water
 - Municipal

For residential, commercial, and industrial accounts, projections are developed for inside and outside the city. The following sections describe the projections, which are presented in Table 3-1.

3.2.1 Residential Accounts

The residential account projection for inside the city was based on a combination of analyses including a regression model using the Polk County Population (PCP) as the independent variable, historical growth rates, and historical ratios of residential accounts to PCP. The residential account projection for outside the city was based on similar analyses. The projection of the total number of residential accounts was a summation of the residential inside and outside the city account projections. The projected AAGR for residential accounts is 1.32 percent for the 2001 through 2020 period. Historical and projected residential accounts are presented in Table 3-1.

3.2.2 Commercial and Industrial Accounts

The General Service (GS) account projection for both inside and outside the city was based on historical trends. The total General Service account projection is the sum of the General Service account projections for inside and outside the city. Historical trends were also analyzed to develop the inside and outside the city projections for General Service Demand (GSD) accounts. The total General Service Demand accounts is the summation of the inside and outside the city General Service Demand accounts.

The General Service Large Demand (GSLD) account projection for inside the city was based on historical relationships between GSLD accounts to PCP, residential accounts to GSLD accounts, GS accounts to GSLD accounts, and GSD accounts to GSLD accounts. The historical trend between GSLD accounts outside to residential accounts outside was used to develop the GSLD outside the city account projection. The total GSLD is the summation of the GSLD inside and outside the city accounts.

The commercial and industrial customer forecasts are presented in Table 3-1. The number of commercial and industrial customers is projected to increase at an AAGR of 1.32 and 1.35 percent, respectively, from 2001 through 2020.

| Fiscal Year | Service Territory Population | Rural and Residential | | | Commercial | | |
|-------------|------------------------------|-----------------------|--------------------------|----------|------------|--------------------------|----------|
| | | GWh | Average No. of Customers | kWh/Cust | GWh | Average No. of Customers | kWh/Cust |
| 1991 | 189,445 | 967 | 76,731 | 12,602 | 522 | 9,517 | 54,849 |
| 1992 | 198,763 | 987 | 77,863 | 12,676 | 526 | 9,664 | 54,429 |
| 1993 | 201,748 | 1,026 | 79,738 | 12,867 | 542 | 9,768 | 55,487 |
| 1994 | 206,040 | 1,080 | 81,542 | 13,245 | 574 | 9,967 | 57,590 |
| 1995 | 210,095 | 1,169 | 82,616 | 14,150 | 594 | 9,999 | 59,406 |
| 1996 | 213,347 | 1,201 | 84,089 | 14,282 | 589 | 9,729 | 60,541 |
| 1997 | 216,782 | 1,173 | 84,149 | 13,940 | 609 | 9,816 | 62,042 |
| 1998 | 218,959 | 1,254 | 86,340 | 14,529 | 634 | 10,127 | 62,644 |
| 1999 | 221,921 | 1,237 | 87,955 | 14,064 | 641 | 10,916 | 58,721 |
| 2000 | 225,558 | 1,274 | 88,813 | 14,345 | 708 | 11,085 | 63,870 |
| Forecast | | | | | | | |
| 2001 | 229,467 | 1,299 | 89,806 | 14,465 | 721 | 11,208 | 64,329 |
| 2002 | 233,047 | 1,331 | 91,127 | 14,606 | 739 | 11,373 | 64,978 |
| 2003 | 236,620 | 1,363 | 92,446 | 14,744 | 757 | 11,538 | 65,609 |
| 2004 | 240,167 | 1,395 | 93,757 | 14,879 | 774 | 11,702 | 66,143 |
| 2005 | 243,674 | 1,427 | 95,065 | 15,011 | 793 | 11,865 | 66,835 |
| 2006 | 247,221 | 1,460 | 96,384 | 15,148 | 810 | 12,029 | 67,337 |
| 2007 | 250,757 | 1,492 | 97,703 | 15,271 | 828 | 12,194 | 67,902 |
| 2008 | 254,295 | 1,525 | 99,026 | 15,400 | 847 | 12,359 | 68,533 |
| 2009 | 257,857 | 1,557 | 100,360 | 15,514 | 864 | 12,526 | 68,977 |
| 2010 | 261,441 | 1,589 | 101,700 | 15,624 | 882 | 12,693 | 69,487 |
| 2011 | 265,001 | 1,622 | 103,037 | 15,741 | 900 | 12,860 | 70,023 |
| 2012 | 268,558 | 1,654 | 104,374 | 15,851 | 919 | 13,027 | 70,514 |
| 2013 | 272,114 | 1,687 | 105,714 | 15,959 | 937 | 13,194 | 70,992 |
| 2014 | 275,671 | 1,720 | 107,057 | 16,063 | 955 | 13,361 | 71,458 |
| 2015 | 279,228 | 1,753 | 108,402 | 16,169 | 973 | 13,529 | 71,929 |
| 2016 | 282,785 | 1,785 | 109,750 | 16,267 | 991 | 13,694 | 72,383 |
| 2017 | 286,341 | 1,818 | 111,100 | 16,362 | 1,009 | 13,866 | 72,789 |
| 2018 | 289,898 | 1,851 | 112,453 | 16,460 | 1,028 | 14,035 | 73,222 |
| 2019 | 293,455 | 1,884 | 113,807 | 16,550 | 1,046 | 14,204 | 73,624 |
| 2020 | 297,012 | 1,917 | 115,132 | 16,647 | 1,064 | 14,369 | 74,057 |
| AAGR | | | | | | | |
| 2001-2020 | 1.37% | 2.07% | 1.32% | 0.74% | 2.07% | 1.32% | 0.74% |

Table 3-1 (Continued)
Forecast of Total Accounts and Sales For Lakeland

| Fiscal Year | Industrial | | | Street and Highway Lighting GWh | Other Sales to Public Authorities GWh | Total Sales to Ultimate Consumers GWh | Utility Use and Losses GWh | NEL GWh |
|-------------|------------|----------------------|-----------|---------------------------------|---------------------------------------|---------------------------------------|----------------------------|---------|
| | GWh | Average No. of Cust. | kWh/Cust | | | | | |
| 1991 | 344 | 45 | 7,644,444 | 11 | 61 | 1,905 | 138 | 2,043 |
| 1992 | 356 | 47 | 7,574,468 | 13 | 65 | 1,947 | 143 | 2,090 |
| 1993 | 381 | 51 | 7,470,588 | 13 | 68 | 2,030 | 155 | 2,185 |
| 1994 | 400 | 51 | 7,843,137 | 14 | 69 | 2,137 | 146 | 2,283 |
| 1995 | 427 | 51 | 8,372,549 | 15 | 74 | 2,279 | 146 | 2,425 |
| 1996 | 436 | 59 | 7,389,831 | 15 | 78 | 2,319 | 116 | 2,435 |
| 1997 | 459 | 61 | 7,524,590 | 16 | 78 | 2,335 | 115 | 2,450 |
| 1998 | 474 | 62 | 7,645,161 | 17 | 80 | 2,460 | 132 | 2,592 |
| 1999 | 486 | 80 | 6,075,000 | 17 | 82 | 2,463 | 112 | 2,575 |
| 2000 | 532 | 85 | 6,258,824 | 18 | 11 | 2,543 | 166 | 2,709 |
| Forecast | | | | | | | | |
| 2001 | 542 | 86 | 6,302,326 | 19 | 10 | 2,591 | 155 | 2,746 |
| 2002 | 556 | 88 | 6,318,182 | 19 | 10 | 2,655 | 159 | 2,814 |
| 2003 | 569 | 89 | 6,393,258 | 19 | 11 | 2,719 | 163 | 2,882 |
| 2004 | 583 | 90 | 6,477,778 | 20 | 11 | 2,783 | 167 | 2,950 |
| 2005 | 596 | 91 | 6,549,451 | 21 | 11 | 2,848 | 170 | 3,018 |
| 2006 | 610 | 93 | 6,559,140 | 21 | 11 | 2,912 | 175 | 3,087 |
| 2007 | 623 | 94 | 6,627,660 | 22 | 12 | 2,977 | 178 | 3,155 |
| 2008 | 636 | 95 | 6,694,737 | 22 | 12 | 3,042 | 182 | 3,224 |
| 2009 | 650 | 96 | 6,770,833 | 23 | 12 | 3,106 | 187 | 3,293 |
| 2010 | 664 | 98 | 6,775,510 | 23 | 13 | 3,171 | 190 | 3,361 |
| 2011 | 678 | 99 | 6,843,566 | 23 | 13 | 3,236 | 194 | 3,430 |
| 2012 | 691 | 100 | 6,911,219 | 24 | 13 | 3,301 | 198 | 3,499 |
| 2013 | 705 | 102 | 6,909,125 | 24 | 13 | 3,366 | 202 | 3,568 |
| 2014 | 718 | 103 | 6,974,172 | 25 | 13 | 3,431 | 206 | 3,637 |
| 2015 | 732 | 104 | 7,039,980 | 25 | 14 | 3,497 | 209 | 3,706 |
| 2016 | 746 | 105 | 7,102,541 | 26 | 14 | 3,562 | 213 | 3,775 |
| 2017 | 759 | 107 | 7,096,969 | 26 | 14 | 3,627 | 258 | 3,885 |
| 2018 | 773 | 108 | 7,159,203 | 27 | 14 | 3,693 | 221 | 3,914 |
| 2019 | 787 | 109 | 7,218,375 | 27 | 15 | 3,758 | 226 | 3,984 |
| 2020 | 801 | 111 | 7,212,803 | 28 | 15 | 3,824 | 229 | 4,053 |
| AAGR | | | | | | | | |
| 2001-2020 | 2.07% | 1.35% | 0.71% | 2.02% | 2.12% | 2.07% | 2.08% | 2.07% |

3.3 Sales Forecast

Lakeland develops energy sales forecasts for each of the account categories presented in Section 3.2.

3.3.1 Residential Sales

The total residential sales were forecast using a regression model with year, heating degree-days, and real per capita income as the independent variables. Residential sales are projected to have an AAGR of 2.07 percent from 2001 through 2020 and are presented in Table 3-1. Residential sales projections inside the city were based on a regression model using year, population, heating and cooling degree days, and real per capita income as the independent variables. Residential sales outside the city were based on the difference between total residential sales and sales inside the city.

3.3.2 Commercial and Industrial Sales

Total General Service sales are the sum of General Service sales inside and outside the city. Projections of commercial and industrial sales inside the city were based on a regression model using employment and heads of households as the independent variables. General Service sales outside the city were based on a regression model using General Service accounts outside the city and population as the independent variables.

The total General Service Demand sales are the summation of the inside and outside General Service Demand sales. General Service Demand sales projections inside the city were based on a regression model using General Service Demand accounts inside and employment as the independent variables. The General Service Demand sales outside the city were based on a regression model using population and real per capita income as the independent variables.

Total General Service Large Demand Sales projections were based on a regression model using real per capita income and population as the independent variable. General Service Large Demand sales projections inside the city were based on a regression model using heads of households and real per capita income as the independent variables. General Service Large Demand sales outside the city are the difference between the Total General Service Large Demand sales and total General Service Large Demand sales inside the city.

Commercial and industrial sales each have a projected AAGR of 2.07 percent for the 2001 through 2020 period, and are presented in Table 3-1.

3.3.3 Other Sales

Municipal sales projections were based on a regression model using year and real per capita income as the independent variables. Water sales were projected using a weighted average of the ratio of water sales to municipal sales and a trend projection. Projections were based on a historical trend using Polk County population. Electric sales projections were based on a ratio of electric sales to municipal sales.

Private Area Lighting inside sales were based on a regression model using private area light accounts and residential accounts inside as the independent variables. Private Area Lighting outside sales were based on a regression model using year as the independent variable. Unmetered sales are those derived from municipal lighting.

Street and highway lighting and other sales have projected AAGRs of 2.02 and 2.12 percent, respectively, for the 2001 through 2020 period and are presented in Table 3-1.

3.3.4 Total Sales

The total sales forecast for the City of Lakeland is a summation of the individual forecasts provided above. Summation of total sales indicates an AAGR of 2.07 percent from 2001 through 2020. This is a lower growth rate than experienced in the past. A 3.26 percent AAGR was experienced over the last 10 years of historical sales. Historical and projected total sales are presented in Table 3-1.

3.4 Net Energy for Load Forecast

Net energy for load is defined as the net electricity generation by a system's own plants, plus energy purchased from others, less the energy delivered for resale to their systems. Lakeland projects the growth rate for total percentage of system energy losses to remain relatively constant. Lakeland's projection of net energy for load includes the effect of energy conservation programs.

The forecasted net energy for load on a calendar year basis, including conservation, for the base case is summarized in Table 3-1. The projected AAGR for the base case is 2.07 percent for the 2001 through 2020 period. The projected AAGR represents a reduction from the historical AAGR of 3.19 percent for the last 10 years.

3.5 Peak Demand

Lakeland uses regression analysis to forecast electric system winter and summer season peak demands for each year. The winter season is defined as November through March and the summer season is defined as April through October. Standard deviations for the sensitivities were calculated within a 95 percent probability interval for sets of

historical data related to winter and summer peaks. The results indicated a base temperature for winter to be 29.66 degrees Fahrenheit. The results indicated a base temperature for summer to be 98.7 degrees Fahrenheit.

Projections of the coincident demand for customers served on the interruptible rate were developed and applied to reduce the projection of total peak demand. Projections of the effect of Lakeland's load management program were likewise developed and applied to reduce the projection of total peak demand.

Projections of the resultant winter and summer peak demand for the base case are included in Tables 3-2 and 3-3, respectively. The projected AAGR for the winter peak demand for the base case after reductions for conservation and interruptible load for the period 2002 through 2020 is 2.29 percent. The projected AAGR for the summer peak demand for the base case after reductions for conservation and interruptible load for the period 2001 through 2020 is 2.21 percent.

Table 3-2
Winter Peak Demand – Base Case (MW)

| Calendar Year | Forecast | Interruptible | Conservation | Forecast Less Conservation Only | Forecast Less Interruptible Only | Forecast Less Conservation and Interruptible |
|-------------------|----------|---------------|--------------|---------------------------------|----------------------------------|--|
| 2000/2001 | | | | | | 655 |
| 2001/2002 | 691 | 12 | 52 | 639 | 679 | 627 |
| 2002/2003 | 708 | 12 | 52 | 656 | 696 | 644 |
| 2003/2004 | 727 | 12 | 53 | 674 | 715 | 662 |
| 2004/2005 | 745 | 13 | 53 | 692 | 732 | 679 |
| 2005/2006 | 764 | 13 | 54 | 710 | 751 | 697 |
| 2006/2007 | 781 | 13 | 54 | 727 | 768 | 714 |
| 2007/2008 | 800 | 13 | 55 | 745 | 787 | 732 |
| 2008/2009 | 817 | 13 | 55 | 762 | 804 | 749 |
| 2009/2010 | 836 | 13 | 56 | 780 | 823 | 767 |
| 2010/2011 | 853 | 13 | 56 | 797 | 840 | 784 |
| 2011/2012 | 872 | 13 | 57 | 815 | 859 | 802 |
| 2012/2013 | 889 | 13 | 57 | 832 | 876 | 819 |
| 2013/2014 | 909 | 14 | 58 | 851 | 895 | 837 |
| 2014/2015 | 926 | 14 | 58 | 868 | 912 | 854 |
| 2015/2016 | 945 | 14 | 59 | 886 | 931 | 872 |
| 2016/2017 | 962 | 14 | 59 | 903 | 948 | 889 |
| 2017/2018 | 981 | 14 | 60 | 921 | 967 | 907 |
| 2018/2019 | 999 | 14 | 60 | 939 | 985 | 925 |
| 2019/2020 | 1,017 | 14 | 61 | 956 | 1,003 | 942 |
| AAGR 2001-2020 | 2.17% | 0.86% | 0.89% | 2.26% | 2.19% | 2.29% |

Table 3-3
Summer Peak Demand – Base Case (MW)

| Calendar Year | Forecast | Interruptible | Conservation | Forecast Less Conservation Only | Forecast Less Interruptible Only | Forecast Less Conservation and Interruptible |
|-------------------|----------|---------------|--------------|---------------------------------|----------------------------------|--|
| 2001 | 584 | 14 | 21 | 563 | 570 | 549 |
| 2002 | 600 | 14 | 22 | 578 | 586 | 564 |
| 2003 | 615 | 14 | 22 | 593 | 601 | 579 |
| 2004 | 629 | 14 | 22 | 607 | 615 | 593 |
| 2005 | 644 | 14 | 22 | 622 | 630 | 608 |
| 2006 | 660 | 14 | 23 | 637 | 646 | 623 |
| 2007 | 676 | 15 | 23 | 653 | 661 | 638 |
| 2008 | 691 | 15 | 23 | 668 | 676 | 653 |
| 2009 | 706 | 15 | 23 | 683 | 691 | 668 |
| 2010 | 722 | 15 | 24 | 698 | 707 | 683 |
| 2011 | 737 | 15 | 24 | 713 | 722 | 698 |
| 2012 | 751 | 15 | 24 | 727 | 736 | 712 |
| 2013 | 766 | 15 | 24 | 742 | 751 | 727 |
| 2014 | 782 | 15 | 25 | 757 | 767 | 742 |
| 2015 | 798 | 16 | 25 | 773 | 782 | 757 |
| 2016 | 813 | 16 | 25 | 788 | 797 | 772 |
| 2017 | 829 | 16 | 26 | 803 | 813 | 787 |
| 2018 | 844 | 16 | 26 | 818 | 828 | 802 |
| 2019 | 859 | 16 | 26 | 833 | 843 | 817 |
| 2020 | 873 | 16 | 26 | 847 | 857 | 831 |
| AAGR 2001-2020 | 2.14% | 0.71% | 1.13% | 2.17% | 2.17% | 2.21% |

3.6 Sensitivity Cases

Lakeland has conducted two sensitivity cases to the base case load forecast, reflecting a high load growth case and a low load growth case. These two sensitivity cases provide a band across which Lakeland can evaluate potential power supply planning alternatives and test the robustness of the base case against higher or lower load growth.

Standard deviations for the sensitivities were calculated within a 95 percent probability interval for sets of historical data related to winter and summer peaks. The results indicated a base temperature for winter to be 29.66 degrees Fahrenheit. The winter results indicated a base temperature for summer to be 98.7 degrees Fahrenheit.

3.6.1 High Load Sensitivity

The high load forecasts for demand and energy were based on a summer temperature of 104.1 degrees, and a winter temperature of 19.47 degrees, Fahrenheit. The high load forecast has an AAGR of 2.00 and 2.22 percent for winter and summer peak demand after reductions for conservation and interruptible load. Tables 3-4 and 3-5 display the winter and summer peak demand forecast and net energy for load for the planning horizon for the high load sensitivity.

3.6.2 Low Load Sensitivity

The low load forecasts for demand and energy were based on a summer temperature of 93.341 degrees, and a winter temperature of 39.847 degrees, Fahrenheit. The low load forecast has an AAGR of 2.78 and 2.17 percent for winter and summer peak demand after reductions for conservation and interruptible load. Tables 3-5 and 3-6 display the winter and summer peak demand forecasts and net energy for load for the planning horizon for the low load sensitivity.

3.6.2 High and Low Net Energy for Load

Based on Lakeland's 95 percent confidence interval, Lakeland developed a banded high and low net energy for load forecast. The high and low forecast was developed using the 2.5 percent interval on either side of the confidence interval. This is expected to catch possible variations in either direction.

Table 3-4
Winter Peak Demand – High Load (MW)

| Calendar Year | Forecast | Interruptible | Conservation | Forecast Less Conservation Only | Forecast Less Interruptible Only | Forecast Less Conservation and Interruptible |
|------------------------|----------|---------------|--------------|---------------------------------|----------------------------------|--|
| 2000/2001 ¹ | | | | | | |
| 2001/2002 | 798 | 12 | 52 | 746 | 786 | 734 |
| 2002/2003 | 816 | 12 | 52 | 764 | 804 | 752 |
| 2003/2004 | 834 | 12 | 53 | 781 | 822 | 769 |
| 2004/2005 | 853 | 13 | 53 | 800 | 840 | 787 |
| 2005/2006 | 871 | 13 | 54 | 817 | 858 | 804 |
| 2006/2007 | 889 | 13 | 54 | 835 | 876 | 822 |
| 2007/2008 | 907 | 13 | 55 | 852 | 894 | 839 |
| 2008/2009 | 925 | 13 | 55 | 870 | 912 | 857 |
| 2009/2010 | 943 | 13 | 56 | 887 | 930 | 874 |
| 2010/2011 | 961 | 13 | 56 | 905 | 948 | 892 |
| 2011/2012 | 979 | 13 | 57 | 922 | 966 | 909 |
| 2012/2013 | 997 | 13 | 57 | 940 | 984 | 927 |
| 2013/2014 | 1,016 | 14 | 58 | 958 | 1,002 | 944 |
| 2014/2015 | 1,034 | 14 | 58 | 976 | 1,020 | 962 |
| 2015/2016 | 1,052 | 14 | 59 | 993 | 1,038 | 979 |
| 2016/2017 | 1,070 | 14 | 59 | 1,011 | 1,056 | 997 |
| 2017/2018 | 1,086 | 14 | 60 | 1,026 | 1,072 | 1,012 |
| 2018/2019 | 1,106 | 14 | 60 | 1,046 | 1,092 | 1,032 |
| 2019/2020 | 1,124 | 14 | 61 | 1,063 | 1,110 | 1,049 |
| AAGR 2001-2020 | 1.92% | 0.86% | 0.89% | 1.99% | 1.94% | 2.00% |

1. Demand projection for the 2000/2001 winter season is not shown since it has passed.

Table 3-5
Summer Peak Demand – High Load (MW)

| Calendar Year | Forecast | Interruptible | Conservation | Forecast Less Conservation Only | Forecast Less Interruptible Only | Forecast Less Conservation and Interruptible |
|-------------------|----------|---------------|--------------|---------------------------------|----------------------------------|--|
| 2001 | 592 | 14 | 21 | 571 | 578 | 557 |
| 2002 | 608 | 14 | 22 | 586 | 594 | 572 |
| 2003 | 623 | 14 | 22 | 601 | 609 | 587 |
| 2004 | 638 | 14 | 22 | 616 | 624 | 602 |
| 2005 | 653 | 14 | 22 | 631 | 639 | 617 |
| 2006 | 670 | 14 | 23 | 647 | 656 | 633 |
| 2007 | 686 | 15 | 23 | 663 | 671 | 648 |
| 2008 | 701 | 15 | 23 | 678 | 686 | 663 |
| 2009 | 716 | 15 | 23 | 693 | 701 | 678 |
| 2010 | 732 | 15 | 24 | 708 | 717 | 693 |
| 2011 | 747 | 15 | 24 | 723 | 732 | 708 |
| 2012 | 763 | 15 | 24 | 739 | 748 | 724 |
| 2013 | 778 | 15 | 24 | 754 | 763 | 739 |
| 2014 | 794 | 15 | 25 | 769 | 779 | 754 |
| 2015 | 810 | 16 | 25 | 785 | 794 | 769 |
| 2016 | 825 | 16 | 25 | 800 | 809 | 784 |
| 2017 | 842 | 16 | 26 | 816 | 826 | 800 |
| 2018 | 857 | 16 | 26 | 831 | 841 | 815 |
| 2019 | 872 | 16 | 26 | 846 | 856 | 830 |
| 2020 | 887 | 16 | 26 | 861 | 871 | 845 |
| AAGR 2001-2020 | 2.15% | 0.71% | 1.13% | 2.19% | 2.18% | 2.22% |

Table 3-6
Winter Peak Demand – Low Load (MW)

| Calendar Year | Forecast | Interruptible | Conservation | Forecast Less Conservation Only | Forecast Less Interruptible Only | Forecast Less Conservation and Interruptible |
|------------------------|----------|---------------|--------------|---------------------------------|----------------------------------|--|
| 2000/2001 ¹ | | | | | | |
| 2001/2002 | 558 | 12 | 52 | 506 | 546 | 494 |
| 2002/2003 | 575 | 12 | 52 | 523 | 563 | 511 |
| 2003/2004 | 594 | 12 | 53 | 541 | 582 | 529 |
| 2004/2005 | 612 | 13 | 53 | 559 | 599 | 546 |
| 2005/2006 | 631 | 13 | 54 | 577 | 618 | 564 |
| 2006/2007 | 648 | 13 | 54 | 594 | 635 | 581 |
| 2007/2008 | 667 | 13 | 55 | 612 | 654 | 599 |
| 2008/2009 | 684 | 13 | 55 | 629 | 671 | 616 |
| 2009/2010 | 703 | 13 | 56 | 647 | 690 | 634 |
| 2010/2011 | 720 | 13 | 56 | 664 | 707 | 651 |
| 2011/2012 | 739 | 13 | 57 | 682 | 726 | 669 |
| 2012/2013 | 757 | 13 | 57 | 700 | 744 | 687 |
| 2013/2014 | 776 | 14 | 58 | 718 | 762 | 704 |
| 2014/2015 | 794 | 14 | 58 | 736 | 780 | 722 |
| 2015/2016 | 812 | 14 | 59 | 753 | 798 | 739 |
| 2016/2017 | 830 | 14 | 59 | 771 | 816 | 757 |
| 2017/2018 | 848 | 14 | 60 | 788 | 834 | 774 |
| 2018/2019 | 866 | 14 | 60 | 806 | 852 | 792 |
| 2019/2020 | 884 | 14 | 61 | 823 | 870 | 809 |
| AAGR 2001-2020 | 2.59% | 0.86% | 0.89% | 2.74% | 2.62% | 2.78% |

1. Demand projection for the 2000/2001 winter season is not shown since it has passed.

Table 3-7
Summer Peak Demand – Low Load (MW)

| Calendar Year | Forecast | Interruptible | Conservation | Forecast Less Conservation Only | Forecast Less Interruptible Only | Forecast Less Conservation and Interruptible |
|-------------------|----------|---------------|--------------|---------------------------------|----------------------------------|--|
| 2001 | 568 | 14 | 21 | 547 | 554 | 533 |
| 2002 | 583 | 14 | 22 | 561 | 569 | 547 |
| 2003 | 597 | 14 | 22 | 575 | 583 | 561 |
| 2004 | 611 | 14 | 22 | 589 | 597 | 575 |
| 2005 | 625 | 14 | 22 | 603 | 611 | 589 |
| 2006 | 640 | 14 | 23 | 617 | 626 | 603 |
| 2007 | 656 | 15 | 23 | 633 | 641 | 618 |
| 2008 | 670 | 15 | 23 | 647 | 655 | 632 |
| 2009 | 684 | 15 | 23 | 661 | 669 | 646 |
| 2010 | 699 | 15 | 24 | 675 | 684 | 660 |
| 2011 | 713 | 15 | 24 | 689 | 698 | 674 |
| 2012 | 727 | 15 | 24 | 703 | 712 | 688 |
| 2013 | 741 | 15 | 24 | 717 | 726 | 702 |
| 2014 | 757 | 15 | 25 | 732 | 742 | 717 |
| 2015 | 772 | 16 | 25 | 747 | 756 | 731 |
| 2016 | 786 | 16 | 25 | 761 | 770 | 745 |
| 2017 | 801 | 16 | 26 | 775 | 785 | 759 |
| 2018 | 815 | 16 | 26 | 789 | 799 | 773 |
| 2019 | 829 | 16 | 26 | 803 | 813 | 787 |
| 2020 | 844 | 16 | 26 | 818 | 828 | 802 |
| AAGR 2001-2020 | 2.11% | 0.71% | 1.13% | 2.14% | 2.14% | 2.17% |

| Calendar Year | Low | Base | High |
|-------------------|-----------|-----------|-----------|
| 2001 | 2,655,815 | 2,746,192 | 2,833,689 |
| 2002 | 2,671,900 | 2,813,947 | 2,949,165 |
| 2003 | 2,701,193 | 2,881,745 | 3,051,652 |
| 2004 | 2,736,808 | 2,949,667 | 3,148,197 |
| 2005 | 2,776,753 | 3,018,100 | 3,241,572 |
| 2006 | 2,819,698 | 3,086,847 | 3,332,712 |
| 2007 | 2,864,510 | 3,155,389 | 3,421,713 |
| 2008 | 2,910,884 | 3,223,856 | 3,509,126 |
| 2009 | 2,958,768 | 3,292,504 | 3,595,520 |
| 2010 | 3,007,859 | 3,361,237 | 3,680,993 |
| 2011 | 3,057,943 | 3,429,994 | 3,765,630 |
| 2012 | 3,109,002 | 3,498,889 | 3,849,684 |
| 2013 | 3,160,880 | 3,567,868 | 3,933,176 |
| 2014 | 3,213,507 | 3,636,933 | 4,016,197 |
| 2015 | 3,266,814 | 3,706,086 | 4,098,804 |
| 2016 | 3,320,743 | 3,775,326 | 4,181,050 |
| 2017 | 3,375,243 | 3,844,649 | 4,262,975 |
| 2018 | 3,430,284 | 3,914,063 | 4,344,625 |
| 2019 | 3,485,816 | 3,983,564 | 4,426,023 |
| 2020 | 3,541,634 | 4,052,941 | 4,506,967 |
| AAGR 2001-2020 | 1.61% | 2.07% | 2.61% |

4.0 Demand-Side Management Programs

Lakeland Electric is committed to reducing system demand and promoting more efficient use of electric energy to the extent to which it is cost-effective for all its consumers. Lakeland has in place several cost-effective Demand-Side Management (DSM) programs and is continuing to pursue additional cost-effective conservation and DSM programs. Presented in this section are the existing programs and the description of additional programs under evaluation. Further details can be found in Lakeland's Demand-Side Management Plan for Docket No. 930556-EG, which is on file with the Florida Public Service Commission.

This section also includes a brief description of Lakeland's advances in solar technology. Lakeland has assumed a leadership position in the deployment and commissioning of numerous solar energy devices and has established their reputation as a pro-solar electric utility.

4.1 Existing Conservation and Demand-Side Management Programs

Lakeland has several existing conservation and demand-side management programs that are currently available and address three major areas of demand-side management:

- Reduction in weather sensitive peak loads.
- Reduction of energy needs on a per customer basis.
- Movement of energy to off-peak hours when it can be generated at a lower cost.

The programs can be divided into two groups: those programs with demonstrable demand and energy savings and programs in which the impact of demand and energy savings cannot be directly measured.

4.1.1 Existing Programs with Demonstrable Demand and Energy Savings

Lakeland has several programs that demonstrate demand and energy savings for the system. The following are programs that are in place currently:

- Residential Programs:
 - SMART Load Management Program.
 - Loan Program.
- Commercial Programs:
 - Commercial Lighting Program.
 - Thermal Energy Storage Program.
 - High-Pressure Sodium Outdoor Lighting Program.

4.1.1.1 Residential Programs.

4.1.1.1.1 SMART Load Management Program. In 1981, Lakeland began the Load Management Program. The program focused on the direct load control of electric water heaters to reduce peak demand. The program was changed in 1990 to cyclically control heating, air conditioning, and ventilation systems, combined with continuous control of water heating. This change came about as newer, more cost-effective control technologies became available. This made control of HVAC systems cost-effective along with continued control of hot water heaters.

Lakeland required all new residential construction projects to have mandatory controls when the program was expanded. Lakeland has since relaxed the mandatory portion of the program for new customers due to diminished cost-effectiveness of the program. The program remains as a voluntary program which is still enjoying good response from its customers and continued demand savings. The SMART program is projected to reduce winter peak demand by 1 kW per account from each water heater control and 1.2 kW per account from control of HVAC systems.

4.1.1.1.2 Loan Program. Lakeland is the administrator for the Loan Program which provides assistance to customers to improve their home's thermal efficiency by upgrading strip heat and split type heating systems to more efficient and economical heat pumps. This program also covers additional insulation and caulking when the customer upgrades their heating system. This is accomplished through a secured utility subsidized, 8 percent low interest loan for 5 years provided through a specific local bank. This program is projected to save 844 kWh per account annually. In December of 1999 Lakeland decided to stop the current Loan Program while it evaluates how best to proceed with the program in the future.

4.1.1.2 Commercial Programs.

4.1.1.2.1 Commercial Lighting Program. The Commercial Lighting Program began in 1996 to enhance/maintain customer lighting levels while reducing the facility's associated energy needs. Commercial/Industrial account managers, in conjunction with energy consultants, perform a thorough lighting audit and provide customers with up-to-date lighting efficiency standards from the Florida Building Code and Federal Energy Policy Act of 1992. Customers are shown that through the installation of energy efficient fixtures these goals can be realized. Account managers also show how quickly a lighting investment can be paid back based on associated energy savings.

4.1.1.2.2 Thermal Energy Storage Program. The Thermal Energy Storage (TES) Program has provided Lakeland's commercial and industrial customers an effective method of transferring cooling and heating requirements to off-peak time periods. This is

accomplished through TES systems that are on par in efficiency with standard systems. Lakeland is implementing two rate tariffs which are designed for load shift technologies, such as TES. This provides further economic incentive for customers to switch to TES technologies.

4.1.1.2.3 High-Pressure Sodium Outdoor Lighting Program. This program is structured to reduce lighting demands through the replacement of mercury vapor streetlights with more energy efficient high-pressure sodium (HPS) lights. The HPS lights reduce energy consumption while maintaining the same level of lighting.

Currently, all streetlights within the city limits are now high-pressure sodium bulbs. Private area lights will continue to be replaced as time allows, while all new lighting will use the HPS lights.

4.1.2 Non-Measurable Demand and Energy Savings

The programs outlined in this section cannot directly be measured in terms of demand and energy savings, but are very important in that they have been shown to influence public behavior and thereby help reduce energy requirements. Lakeland considers the following programs to be important part of its objective to cost-effectively reduce energy consumption:

- Residential Programs:
 - Energy Audit Program.
 - Public Awareness Program.
 - Mobile Display Unit.
 - Speakers Bureau.
 - Informational Bill Inserts.
- Commercial Programs:
 - Commercial Audit Program.

4.1.2.1 Residential Programs.

4.1.2.1.1 Residential Energy Audits. The Energy Audit Program promotes high energy-efficiency in the home and gives the customer an opportunity to learn about other utility conservation programs. The program provides Lakeland with a valuable customer interface and a good avenue for increased customer awareness.

4.1.2.1.2 Public Awareness Program. Lakeland believes that an informed public aware of the need to conserve electricity is the greatest conservation resource. Lakeland's public awareness programs provide customers with information to help them reduce their electric bills by being more conscientious in their energy use.

4.1.2.1.3 Mobile Display Unit. The mobile display unit is presented at a number of area activities each year, including the Engineering Expo held at the University of South

Florida, the Polk County Home Show, and numerous school engagements through the year. The display centers on themes of energy and water conservation, including electric safety.

4.1.2.1.4 Speakers Bureau. Lakeland provides speakers to local group meetings to help inform the public of new energy efficiency technologies and ways to conserve energy in the commercial and residential sectors.

4.1.2.1.5 Informational Bill Inserts. Monthly billing statements provide an excellent avenue for communicating timely energy conservation information to its customers. In this way, Lakeland conveys the message of better utilizing their electric resources on a regular basis in a low cost manner.

4.1.2.2 Commercial Programs.

4.1.2.2.1 Commercial Energy Audits. The Lakeland Commercial Audit Program includes educating customers about high efficiency lighting and thermal energy storage analysis for customers to consider in their efforts to reduce costs associated with their electric usage.

4.1.3 Demand-Side Management Technology Research

Lakeland has made a commitment to study and review promising technologies in the area of conservation and demand-side management. Some of these efforts are summarized below.

4.1.3.1 Direct Expansion Ground Source Heat Pump Study.

In cooperation with ECR Technologies of Lakeland, Lakeland Electric was given the Governor's Energy Award for work in the evaluation and analysis of direct expansion ground source heat pump (GSHP) technology. This technology will reduce weather sensitive loads and promote greater energy efficiency for Lakeland's system. A study of the demand and energy savings associated with this technology was completed in an effort to establish its cost-effectiveness for new construction, as well as retrofitting the technology to existing homes. The original units were installed nearly ten years ago and are still in service. There is little customer interest due to the cost of the units. Currently, no new sites are being developed.

4.1.3.2 Whole House Demand Controller Study.

The concept of this technology is to control multiple appliances in the customer's home. If demand on the utility were to exceed a pre-set level, no additional appliances would be allowed to turn on. There was no customer interest in this program. A large amount of information is maintained by Lakeland for this technology and will be monitored for changes in its effectiveness.

4.1.3.3 Time-of-Day Rates.

Lakeland is currently offering a time of day program and plans to continue as this makes consumers aware of the variation in costs during the day. To date, there has been limited interest by Lakeland's customers in this demand-side management program.

4.2 Solar Program Activities

Lakeland Electric views solar energy devices as distributed generators whether they interconnect to the utility grid or not. As such they can potentially fill the much-desired role that an electric utility needs to avoid future costs of building new (and/or re-working existing) distribution systems.

4.2.1 Solar Powered Street Lights.

Distributed generation produces the energy in end use form at the point of load by the customer, thereby eliminating many of the costs, wastes, pollutants, environmental degradation, and other objections to central station generation.

Solar powered streetlights offer a reliable, cost-effective solution to remote lighting needs. As shown in Figure 4-1, they are completely self-contained, with the ability to generate DC power from photovoltaic modules and batteries. During daylight hours solar energy is stored in the battery bank used to power the lights at night. By installing these self sufficient, stand-alone solar lighting products, Lakeland Electric was able to avoid the construction costs related to expansion of its distribution system into remote areas. These avoided costs are estimated to be approximately \$20,000. It is Lakeland's stated desire to continue to install solar area-lighting products where similar circumstances exist.

Lakeland currently has 20 solar powered streetlights that are in service. Each of these lights replace a traditional 70 watt fixture that Lakeland typically would use in this type of application and displaces the equivalent amount of energy that the 70 watt fixture would use on an annual basis. The primary application for this type of lighting is for remote areas as stated above. Lakeland installed these 20 lights in mid-1994 in a grant program with the cooperation of the Florida Solar Energy Center (FSEC). Lakeland is continuing to collect operational and maintenance data to further assess the long-term cost-effectiveness, maintenance needs, and reliability of this type of lighting.



Figure 4-1
Solar Powered Streetlight

4.2.2 Solar Thermal Collectors for Water Heating.

The most effective application for solar energy is the heating of water for domestic use. Solar water heating provides energy directly to the end-user and results in a high level of end-user awareness. The sun's energy is stored directly in the heated water itself, reducing the effect of converting the energy to other forms.

Lakeland presently owns and operates 29 solar water heaters. These units are installed on the roofs of residential customers' homes, i.e. – at the point of consumption. Since this method of energy delivery bypasses the entire transmission and distribution system, there are other benefits than only avoided generation costs.

In Lakeland's program, each solar water heater remains the property of the utility, thereby allowing the customer to avoid the financial cost of the purchase. Lakeland's return on this investment is realized through the sale of the solar generated energy as a separate line item on the customer's monthly bill. This energy device is monitored by using a utility-utility Btu meter calibrated to read in kWh.

One of the purposes of this program is to demonstrate that solar thermal energy can be accurately metered and profitably sold to the everyday residential end-user of hot water. Lakeland Electric's fleet of 29 solar thermal energy generators displace approximately 3,000 kWh per year per installation on average. Lakeland plans to add an additional 30 units during the year 2001.

4.2.3 Utility-Interactive Residential Photovoltaic Systems

This project is a collaborative effort between the Florida Energy Office (FEO), FSEC, the Lakeland, and Siemens Solar Industries. The primary objectives of this program are to develop approaches and designs that integrate photovoltaic (PV) arrays into residential buildings, and to develop workable approaches to interconnection of PV systems into the utility grid. Lakeland currently has 20 PV systems installed and operating, all of which are directly interconnected to the utility grid. These systems have

an average nominal power rating of approximately 2 kilowatts peak (kWp) and are displacing approximately 2000 kWh per year per installation at standard test conditions.

Lakeland will own, operate, and maintain the systems for at least 5 years. FSEC will conduct periodic site visits for testing and evaluation purposes. System performance data will be collected via telephone modem line for at least 2 years. Lakeland and FSEC will analyze the results of utility and systems simulation tests and prepare recommendations for appropriate interconnection requirements for residential PV systems. FSEC will prepare technical reports on system performance evaluation, onsite utilization, coincidence of PV generation with demand profiles, and utilization of PV generated electricity as a demand-side management option.

4.2.4 Utility-Interactive Photovoltaic Systems on Polk County Schools

Lakeland is also actively involved in a program called "Portable Power." The focus of the program is to install Photovoltaic Systems on portable classrooms in the Polk County School District. This program is a partnership including the City of Lakeland, Polk County School District, Siemens Solar Industries, Florida Solar Energy Research and Education Foundation, Florida Solar Energy Center and the Utility Photovoltaic Group. It will allow seventeen portable classrooms to be enrolled in former President Clinton's "Million Solar Roofs Initiative." With the installation of the photovoltaic systems 80 percent of the electricity requirements for these classrooms will be met.

Along with the photovoltaic systems, there will also be a specially designed curriculum on solar energy appropriate to various grade levels. An education package has been delivered to the schools for their teachers' use in the explanation of solar sciences. By addressing solar energy technologies in today's public school classrooms, Lakeland is informing the next generation of the environmental and economic need for alternate forms of energy production.

The "Portable Power" in the schools, shown in Figure 4-2, will consist of installing 2kWp photovoltaics systems on seventeen portable classrooms. In addition to the educational awareness benefits of photovoltaic programs in schools, there are several practical reasons why portable classrooms are most appropriate as the platforms for photovoltaics. They have nearly flat roofs and are installed in open spaces, so final orientation is of little consequence. Another reason is the primary electric load of the portable classroom is air conditioning, which is reduced by the shading effect of the panels on their short stand-off mounts. Most important, the total electric load on the portable classroom has high coincidence with the output from the PV system. The hot, sunny day which results in the highest cooling requirements also produces the maximum PV output.

Of extreme value to the photovoltaic industry, Lakeland Electric, in a partnership with the FSEC, provided on-site training sessions while installing the solar equipment on these school buildings. Attendees from other electric utilities were enrolled and given a hands-on opportunity to develop the technical and business skills needed to implement their own solar energy projects. The training classes covered all aspects of the solar photovoltaic experience from system design and assembly, safety and reliability, power quality, and troubleshooting to distributed generation and future requirements of deregulation.




Figure 4-2
Portable Classroom Topped by PV Panels

Lakeland will own, operate, and maintain the systems that are installed on these classrooms. Lakeland will monitor the performance and FSEC will conduct periodic testing of the equipment. Through the cooperative effort of the partnership, different ways to use photovoltaics efficiently and effectively in today's society will be evaluated.

4.2.5 Integrated Photovoltaics for Florida Residences

Lakeland's existing integrated photovoltaic program supports former President Clinton's "Million Solar Roofs Initiative". The Department of Energy granted five million dollars for solar electric businesses in addition to the existing privately funded twenty-seven million dollars, for a total of thirty-two million dollars for the program. Through the Utility Photovoltaic Group, the investment will support 1,000 PV systems in

12 states and Puerto Rico and hopes to bring photovoltaics to the main market. The 1,000 systems are part of the 500,000 commitments received for the initiative to date. The goal is to have installed solar devices on one million roofs by the year 2010. Lakeland is helping to accomplish this national goal.

This program provides research in the integration of photovoltaics in newly constructed homes. Two new homes, having identical floor plans, were built in “side-by-side” fashion. The dwellings are being measured for performance under two conditions: occupied and unoccupied. Data is being collected for end-use load and PV system interface. As a research project, the goal is to see how much energy could be saved without factoring in the cost of the efficiency features.




Figure 4-3
Solar House and Control House

The first solar home was unveiled May 28, 1998, in Lakeland, Florida. The home construction includes a 4 kW photovoltaic system, white tiled roof, argon filled windows, exterior wall insulation, improved interior duct system, high performance heat pump and high efficiency appliances. An identical home with strictly conventional construction features was also built as a control home. The homes are 1 block apart and oriented in the same direction as shown in Figure 4-3. For the month of July 1998, the occupied solar home air conditioning consumption was 72 percent lower than the unoccupied

control house. Living conditions were simulated in the unoccupied home. With regard to total power, the solar home used 50 percent less electricity than the air conditioning consumption of the control home.

The solar home was designed to provide enough power during the utility peak that it would not place a net demand on the grid. If the solar home produces more energy than what is being consumed on the premises, the output of the photovoltaic system could be sent into the utility grid. The objective was to test the feasibility of constructing a new, single family residence that was engineered to reduce air conditioning loads to an absolute minimum so most of the cooling and other daytime electrical needs could be accomplished by the PV component.

4.3 Green Pricing Program

Because no long-term budgets have been established for the deployment of solar energy devices, many utilities are dependent on infrequent, somewhat unreliable sources of funding for their solar hardware purchases. To provide for a more regularly available budget, a number of utilities are looking into the voluntary participation of their customers. Recent market studies performed in numerous locations and among diverse population groups reveal a public willingness to pay equal or even slightly higher energy prices knowing that their payments are being directed towards renewable fuels.

The Florida Municipal Electric Association (FMEA) has assembled a workgroup called "Sunsmart". This workgroup is a committee composed of member utilities. Its purpose is to raise environmental awareness and implement "Green Pricing" programs that would call for regular periodic donations from customers who wish to invest in renewables. The Florida Solar Energy Center (FSEC) co-hosts this effort by providing meeting places and website advertising to recruit from statewide responses. A grant from the State of Florida Department of Community Affairs, Florida Energy Office has been appropriated to encourage utility involvement with Green Pricing.

Lakeland Electric is an active member of this committee and is actively pursuing the creation and implementation of a Green Pricing Program. A Green Pricing effort administered by the utility is a further demonstration that Lakeland Electric is engaged in cost-effective alternative energy sources.

5.0 Forecasting Methods and Procedures

This section describes and presents Lakeland's long-term integrated resource planning process, the economic parameter assumptions, plus the fuel price projections being used in the current evaluation process.

5.1 Integrated Resource Planning

Lakeland selects its capacity resources through an integrated resource planning process which it has used for a number of years. Lakeland's planning considers both conservation and demand-side management measures. The integrated resource planning process employed by Lakeland continuously monitors supply and demand-side alternatives and as promising alternatives emerge, they are included in the evaluation process.

5.2 Florida Municipal Power Pool

Lakeland is a member of the Florida Municipal Power Pool (FMPP) along with the Orlando Utilities Commission (OUC), Kissimmee Utility Authority, and the All-Requirements Project of the Florida Municipal Power Agency (FMPA). The four utilities operate as one control area. All FMPP capacity resources are committed and dispatched together from the OUC Operations Center. FMPP has 2,141 MW of summer capacity and 2,249 MW of winter capacity per the 2000 Load and Resource Plan published by the Florida Reliability Coordinating Council.

The FMPP does not provide for the sharing of planning reserves among its members; meaning that they must provide their own reserves. Any member of the FMPP can withdraw from FMPP with 1 year written notice. Lakeland, therefore, must ultimately plan on a stand-alone basis as reflected in this document.

5.3 Economic Parameters and Evaluation Criteria

This section presents the assumed values adopted for economic parameters and inputs used in Lakeland's planning process. The assumptions stated in this section are applied consistently throughout. Subsection 5.3.1 outlines the basic economic assumptions. Subsections 5.3.2 and 5.3.3 outline the base case, high and low, and constant differential fuel forecasts.

5.3.1 Economic Parameters

This section presents the values assumed for the economic parameters currently being used in Lakeland's least-cost planning analysis.

5.3.1.1 Inflation and Escalation Rates. The general inflation rate applied is assumed to be 3.0 percent per year. A 3.0 escalation rate is applied to capital costs and operation and maintenance (O&M) expenses. Fuel price escalation rates are discussed below in Section 5.3.2.

5.3.1.2 Bond Interest Rate. Consistent with the traditional tax exempt financing approach used by Lakeland, the self-owned supply-side alternatives assume 100 percent debt financing. Lakeland's long-term tax exempt bond interest rate is assumed to be 6.0 percent.

5.3.1.3 Present Worth Discount Rate. The present worth discount rate used in the analysis is set equal to Lakeland's assumed bond interest rate of 6.0 percent.

5.3.1.4 Interest During Construction. During construction of the plant, progress payments will be made to the EPC contractor and interest charges will accrue on loan drawdowns. The interest during construction rate is assumed to be 6.0 percent.

5.3.1.5 Fixed Charge Rates. The fixed charge rate is the sum of the project fixed charges as a percent of the project's total initial capital cost. When the fixed charge rate is applied to the initial investment, the product equals the revenue requirements needed to offset fixed costs for a given year. A separate fixed charge rate can be calculated and applied to each year of an economic analysis, but it is most common to use a levelized fixed charge rate that has the same present value as the year by year fixed charged rates. The fixed charge rate for the analysis is based upon an assumed 2.0 percent issuance fee, a 1.0 percent annual insurance cost, and a 6-month debt reserve fund earning interest at a rate equal to the bond interest rate of 6.0 percent. In the planning analysis, a 30-year bond term is assumed for solid fuel alternatives and a 25-year bond term is used for combustion turbine and combined cycles. The resultant levelized fixed charge rates are 8.47 and 9.07 percent, respectively, for the 30-year and 25-year bond terms.

5.3.2 Fuel Price Projections

This section presents the fuel price projections for coal, petroleum coke, natural gas and oil. The base case forecasts are based on Annual Energy Outlook (AEO) 2001 fuel price escalation rates published by the Energy Information Administration (EIA), which is an independent agency of the Department of Energy (DOE). The AEO 2001 energy data is a comprehensive and reliable source of domestic and international energy supply, consumption, and price information.

AEO 2001 provides an energy price forecast through the year 2020 and takes into account a number of important factors, some of which include:

- Restructuring of the U.S. electricity markets.
- Current regulations and legislation affecting the energy markets.

- Current energy issues:
 - Appliance, gasoline and diesel fuel, and renewable portfolio standards.
 - Expansion of natural gas industry.
 - Carbon emissions.
 - Competitive electricity pricing.

AEO 2001 energy information is considered objective and nonpartisan by Lakeland. It is used widely by both government and private sectors to assist in decision-making processes and in analyzing important policy issues.

AEO 2001 publishes real fuel price projections for the individual years of 1998, 1999, 2005, 2010, 2015, and 2020. From these projections, real compounded annual escalation rates (CAERs) can be calculated for 1999-2005, 2005-2010, 2010-2015, and 2015-2020 periods. Table 5-1 shows the real CAERs for the various fuel types. The base case fuel forecast applies these real CAERs and the assumed annual general inflation rate of 3.0 percent to escalate Lakeland's 2000 delivered fuel costs through the year 2020. Table 5-2 shows the resulting nominal fuel price forecast by fuel type used in the economic analyses. Additional assumptions and results of the fuel price forecasts are discussed by fuel type in the following subsections.

Table 5-1
2001 Annual Energy Outlook Real Fuel Price Projections and CAERs

| AEO Forecast | 1999 | 2005 | 2010 | 2015 | 2020 |
|---|-----------|-----------|-----------|-----------|-----------|
| No. 2 Oil,* \$/mmbtu | 4.05 | 4.65 | 4.84 | 5.10 | 5.28 |
| Residual Oil,* \$/mmbtu | 2.42 | 3.52 | 3.88 | 4.00 | 4.07 |
| Coal,* \$/mmbtu | 1.21 | 1.13 | 1.05 | 1.01 | 0.98 |
| Natural Gas,** \$/mmbtu | 2.08 | 2.49 | 2.69 | 2.83 | 3.13 |
| Real CAERs | 1999-2005 | 2005-2010 | 2010-2015 | 2015-2020 | 1998-2020 |
| No. 2 Oil* Real CAERs, percent | 2.33 | 0.80 | 1.05 | 0.70 | 2.23 |
| Residual Oil* Real CAERs, percent | 6.49 | 1.97 | 0.61 | 0.35 | 2.79 |
| Coal* Real CAERs, percent | -1.13 | -1.46 | -0.77 | -0.60 | -1.17 |
| Natural Gas** Real CAERs, percent | 3.04 | 1.56 | 1.02 | 2.04 | 2.01 |
| *Delivered price. | | | | | |
| **Well head price. | | | | | |
| Source: DOE Energy Information Administration website | | | | | |

Table 5-2
Base Case Fuel Price Forecast Summary (Nominal Delivered Price \$/mmbtu)

| | McIntosh 3 Coal | New Unit Coal | Existing Unit NG | New Unit NG | HS Oil | LS Oil | Diesel | McIntosh 4 Pet Coke |
|---|--------------------|------------------|---------------------|-------------|--------|--------|--------|------------------------|
| 2001 | 1.63 | 1.95 | 4.12 | 4.40 | 4.42 | 4.82 | 7.03 | 0.78 |
| 2002 | 1.66 | 1.96 | 4.34 | 4.62 | 4.85 | 5.29 | 7.41 | 0.79 |
| 2003 | 1.69 | 1.97 | 4.58 | 4.85 | 5.32 | 5.80 | 7.81 | 0.81 |
| 2004 | 1.72 | 1.98 | 4.82 | 5.10 | 5.83 | 6.35 | 8.24 | 0.82 |
| 2005 | 1.75 | 2.02 | 5.08 | 5.36 | 6.39 | 6.97 | 8.68 | 0.84 |
| 2006 | 1.78 | 2.05 | 5.29 | 5.57 | 6.71 | 7.32 | 9.01 | 0.85 |
| 2007 | 2.08 | 2.08 | 5.51 | 5.79 | 7.05 | 7.68 | 9.36 | 0.86 |
| 2008 | 2.11 | 2.11 | 5.74 | 6.02 | 7.41 | 8.07 | 9.72 | 0.87 |
| 2009 | 2.14 | 2.14 | 5.98 | 6.26 | 7.78 | 8.48 | 10.09 | 0.89 |
| 2010 | 2.17 | 2.17 | 6.23 | 6.51 | 8.17 | 8.90 | 10.48 | 0.90 |
| 2011 | 2.22 | 2.22 | 6.46 | 6.74 | 8.47 | 9.23 | 10.90 | 0.92 |
| 2012 | 2.27 | 2.27 | 6.70 | 6.98 | 8.77 | 9.56 | 11.35 | 0.94 |
| 2013 | 2.32 | 2.32 | 6.95 | 7.22 | 9.09 | 9.91 | 11.81 | 0.96 |
| 2014 | 2.37 | 2.37 | 7.21 | 7.48 | 9.42 | 10.27 | 12.29 | 0.98 |
| 2015 | 2.42 | 2.42 | 7.48 | 7.75 | 9.76 | 10.64 | 12.80 | 1.00 |
| 2016 | 2.48 | 2.48 | 7.83 | 8.11 | 10.09 | 11.00 | 13.27 | 1.03 |
| 2017 | 2.54 | 2.54 | 8.20 | 8.48 | 10.43 | 11.37 | 13.76 | 1.05 |
| 2018 | 2.60 | 2.60 | 8.59 | 8.87 | 10.78 | 11.75 | 14.28 | 1.08 |
| 2019 | 2.66 | 2.66 | 9.00 | 9.28 | 11.14 | 12.14 | 14.81 | 1.10 |
| 2020 | 2.72 | 2.72 | 9.43 | 9.71 | 11.52 | 12.55 | 15.36 | 1.13 |
| Average Annual Escalation Rate | 2.73% | 1.78% | 4.45% | 4.25% | 5.16% | 5.16% | 4.19% | 1.99% |

5.3.2.1 Natural Gas. Natural gas, also known as methane, is a colorless, odorless fuel that burns cleaner than many other traditional fossil fuels. Natural gas can be used for heating, cooling, and production of electricity, and other industry uses.

Natural gas is found in the Earth's crust. Once the gas is brought to the surface, it is refined to remove impurities such as water, sand, and other gases. The natural gas is then transmitted through pipelines and delivered to the customer either directly from the pipeline or through a distribution company or utility. When natural gas reaches its destination through a pipeline, it is often stored prior to distribution.

5.3.2.1.1 Natural gas supply and availability. Natural gas reserves exist both in the United States and North America mainland and coastal regions. Natural gas reserves are mostly dependent on domestic production. Increasing demand for natural gas as a fuel for both home and heating power production is contributing to the volatility of its price, which in turn has provided incentives for increased production. According to the Energy Information Administration (EIA), by 2020, natural gas demand - measured as a percent of the total U.S. energy market - will increase from the 2000 level of 23 percent to almost 28 percent. This increase in demand will result from further market deregulation and competition throughout the entire energy industry.

5.3.2.1.2 Natural gas transportation. There is currently one transportation company serving Peninsular Florida, Florida Gas Transmission Company (FGT). One additional pipeline, Gulfstream, received final approval from the Federal Energy Regulatory Commission (FERC) in February of 2001.

5.3.2.1.2.1 Florida Gas Transmission Company. FGT is an open access interstate pipeline company transporting natural gas for third parties through its 5,000-mile pipeline system extending from South Texas to Miami, Florida. FGT is a subsidiary of Citrus Corporation, which in turn, is jointly owned by Enron Corporation, the largest integrated natural gas company in America, and El Paso Energy Corporation, one of the largest independent producers of natural gas in the United States.

The FGT pipeline system accesses a diversity of natural gas supply regions, including:

- Anadarko Basin (Texas, Oklahoma, and Kansas).
- Arkona Basin (Oklahoma and Arkansas).
- Texas and Louisiana Gulf Areas (Gulf of Mexico).
- Black Warrior Basin (Mississippi and Alabama).
- Louisiana – Mississippi – Alabama Salt Basin.
- Mobile Bay

FGT's total receipt point capacity is in excess of 3.0 billion cubic feet per day and includes connections with 10 interstate and 10 intrastate pipelines to facilitate transfers of

natural gas into its pipeline system. FGT reports a current delivery capability to Peninsular Florida in excess of 1.4 billion cubic feet per day.

5.3.2.1.2.2 Florida Gas Transmission market area pipeline system. The FGT multiple pipeline system corridor enters the Florida Panhandle in northern Escambia County and runs easterly to a point in southwestern Clay County, where the pipeline corridor turns southerly to pass west of the Orlando area. The mainline corridor then turns to the southeast to a point in southern Brevard County, where it turns south generally paralleling Interstate Highway 95 to the Miami area. A major lateral line (the St. Petersburg Lateral) extends from a junction point in southern Orange County westerly to terminate in the Tampa, St Petersburg, Sarasota area. A major loop corridor (the West Leg Pipeline) branches from the mainline corridor in southeastern Suwannee County to run southward through western Peninsular Florida to connect to the St. Petersburg Lateral system in northeastern Hillsborough County. Each of the above major corridors includes stretches of multiple pipelines (loops) to provide flow redundancy and transport capability. Numerous lateral pipelines extend from the major corridors to serve major local distribution systems and industrial/utility customers.

5.3.2.1.2.3 Florida Gas Transmission expansion projects. FGT filed for FERC approvals of the Phase IV expansion project December 2, 1998. The filing consists of expanding services to Southwest Florida with 139 miles of underground pipelines. The \$268 million Phase IV project will add more than 38,000 horsepower of compression and associated facilities and will provide approximately 197 million cubic feet per day (mmcf/d) of incremental firm transportation service on an average annual basis. FGT announced in May of 2000 that construction related to Phase IV had begun and is scheduled for service by the May 2001 target.

FGT's Phase V expansion project, filed with the FERC on December 1, 1999, will deliver natural gas to a variety of new and current FGT customers and make natural gas available to areas that have not previously had gas service. The Phase V expansion project is intended to add approximately 167 miles of new pipeline and 132,615 horsepower of compression to the existing system. The result of this expansion will be the addition of more than 425 mmcf/d of incremental mainline capacity to Florida. With an estimated cost of \$466 million, the Phase V expansion plan has a target in-service date of April 1, 2002.

The Phase V expansion faced many changes that caused it to file an amended project application with FERC. The Florida Supreme Court ruling that limited the ability of non-utility merchant plants to use the Florida Electrical Power Plant Siting Act prompted the withdrawal of two major Phase V customers, Enron and Dynegy. However, FGT subsequently gained back some of the lost market by signing a long-term

contract with Tampa Electric Company as a Phase V customer. FERC granted preliminary approval to the expansion in November of 2000. The Phase V expansion still requires final environmental approval.

FGT recently concluded an open season for Phase VI. FGT received what it defined as 'a positive response' to the open season. The intent of the project is to provide incremental firm transportation service to Florida. The new pipeline is proposed to extend from Savannah, Georgia to Jacksonville, Florida, with access to Southern LNG Company's liquefied natural gas. Phase VI is scheduled for an in-service date of the Spring of 2003.

FERC approved in November of 2000 FGT's request for the purchase of an undivided interest in Koch Gateway Pipeline's Mobile Bay Lateral. This purchase will give FGT the right to an additional 300,000 mmbtu/day of input capacity. The acquisition is set to become effective April 1, 2002.

5.3.2.1.2.4 Gulfstream pipeline. In September of 2000, two pipelines, Buccaneer and Gulfstream, received one of the two required environmental approvals from FERC. In November of 2000, the developers of the Buccaneer gas pipeline, Williams Energy and Duke Energy, announced their intent to purchase the Gulfstream pipeline from Coastal Corporation.

Duke Energy and Williams Energy will collaborate on the Gulfstream pipeline in lieu of the Buccaneer pipeline. Gulfstream has precedent agreements with 10 large Florida utilities and power generation facilities representing long-term commitments for the majority of its 1.1 billion cubic feet of gas per day capacity. The Gulfstream pipeline was designed primarily to serve Florida utilities and power generation facilities that plan on using high efficiency natural gas turbines to meet the incremental demand for electrical energy.

When installed, the Gulfstream pipeline will be a 744-mile pipeline originating in the Mobile Bay region and crossing the Gulf of Mexico to a landfall in Manatee County (south Tampa Bay). The pipeline is expected to supply Florida with 1.1 billion cubic feet of gas per day serving existing and prospective electric generation and industrial projects in southern Florida. Figure 5-1 shows the proposed route for the Gulfstream pipeline.

The 1.6 billion-dollar pipeline won FERC approval, subject to environmental review, on April 24, 2000. Final environmental and routing approvals by FERC were given in February of 2001. Construction for the Gulfstream pipeline is scheduled to begin June of 2001 with an estimated operation date of June of 2002. Pre-construction activities are currently underway.




Figure 5-1
Gulfstream Natural Gas Pipeline

The first major acquisition of right-of-way occurred July 20, 2000 with a signed agreement between Coastal Corporation and the Manatee County Port Authority. The Gulfstream pipeline gained the permanent right of way easement to cross through Port Manatee. In addition to a payment to Port Manatee, Coastal Corporation will lease up to 190 acres of vacant land at Port Manatee to serve as a logistics base during Gulfstream's construction phase. Florida Power Corporation has announced Gulfstream as the natural gas transportation provider for their newly approved Hines 2 Unit. Currently, 75 percent of the pipeline capacity is under contract.

5.3.2.1.3 Natural gas price forecast. The commodity price forecast for natural gas developed by Lakeland is based on its actual average 2000 natural gas commodity cost, escalated by the AEO escalation rate and the 3.0 percent general inflation rate. For the analysis, a natural gas transportation price was also required and this is expected to differ depending on whether the supply is for an existing unit (linked to previous FGT Phases) or for new units (linked to future Phases). Table 5-2 presents the delivered natural gas price forecast both for existing units and new units.

Lakeland currently has a ten-year contract with FGT for the supply of natural gas for fifty percent of Lakeland's Phase II firm transportation natural gas entitlements. Lakeland plans to enter into long term contracts that will provide between 50 and 60 percent of its natural gas requirements and plans to enter into one to five year (spot market) contracts for the balance of its natural gas requirements.

Natural gas transportation from FGT is currently supplied under two tariffs, FTS-1 and FTS-2. Rates in FTS-1 are based on FGT's Phase II expansion and rates in FTS-2 are based on the Phase III expansion. The Phase III expansion was extensive and rates for FTS-2 transportation are significantly higher than FTS-1. Rates for the Phase IV, Phase V, and any other future expansions will be set by the Federal Energy Regulatory Commission (FERC) rate cases at the completion of the projects. Costs for future expansions are anticipated to be rolled in with Phase III costs and the resultant rates are expected to be similar to the existing Phase III rates. Current FTS-1 and FTS-2 transportation rates along with FGT's interruptible transportation rate ITS-1 are shown in Table 5-3.

For purposes of projecting delivered gas prices, transportation charges of \$0.55/mmbtu were applied for existing units as this is the average cost for Lakeland to obtain natural gas transportation for those units. This average rate is realized through a current mix of FTS-1 and FTS-2 transportation, including consideration of Lakeland's ability to relinquish FTS-2 transportation and acquire other firm and interruptible gas transportation on the market. For new units being considered in the expansion plans, the FTS-2 transportation rate is being used. Transportation rates for existing and new units are considered to be fixed contracted prices and are not escalated.

5.3.2.1.3 Natural gas price forecast. The Petroleum coke is an important fuel for Lakeland. Not only does McIntosh Unit 3 use petroleum coke as a supplemental fuel, but if a solid fuel unit is selected for installation at the McIntosh site (McIntosh Unit 4) it is anticipated to use petroleum coke as its primary fuel. Petroleum coke is a by-product of the oil refining process. This by-product is a solid residue produced from the cracking of heavy residual oil to produce lighter hydrocarbons. Petroleum coke is high in fixed carbon with heating values in the range of 14,200 to 14,600 Btu/lb. Other product characteristics are low volatile content, low ash content, high sulfur content and varying degrees of hardness. The physical and chemical specifications of petroleum coke are a direct function of the oils being processed by the refinery. The amount of petroleum coke produced is increasing due to the increase in refining capacity for heavy crude oils and the declining demand for residual fuel oil. The coking process allows for a higher yield of light oil products, specifically gasoline.

| Table 5-3 FGT Transportation Rates | | | |
|---------------------------------------|------------------------------------|------------------------------------|-------|
| Rates and Surcharges | Rate Schedule | | |
| | FTS-1 w/surcharges (cents/DTH)* | FTS-2 w/surcharges (cents/DTH)* | ITS-1 |
| Reservation | 37.53 | 77.85 | 33.84 |
| Usage | 4.34 | 2.63 | 0.00 |
| Total | 41.87 | 80.48 | 33.84 |
| Fuel Charge | 2.75% | 2.75% | 2.75% |

* A DTH is equivalent to 1 mmbtu or 1 mmcf.

5.3.2.2.1 Petroleum coke supply and availability. While the production of petroleum coke is not the primary product of a refinery, it's production is linked to the production of high value products such as gasoline, jet fuel, diesel and other light products. The increasing demand for these high value products has led to expansions and modifications of current cokers and the addition of new cokers, thus increasing the availability of petroleum coke. The arrival of this new coker capacity began in late 2000 and be completed by early 2004. This incremental coker capacity will add approximately 20 million tons to the annual production capability of petroleum coke. Ninety-two percent of the announced petroleum coke will be produced in the Americas.

Traditionally, the majority of the petroleum coke production has been consumed by the cement, lime and steel industry. But as the availability and acceptance of petroleum coke increases, the use of petroleum coke as a fuel in the electric utility industry will significantly increase a means to remain competitive in a deregulated industry.

Approximately 65 to 70 percent of the petroleum coke produced is a fuel-grade coke, which has a sulfur content of more than four percent. The remaining petroleum coke produced is an anode-grade coke, which has a sulfur content less than four percent. The anode-grade coke is calcined and sold as a premium-grade petroleum coke used in the manufacture of aluminum anodes, furnace electrodes and liners, and shaped graphite products.

Aside from the market dynamics of supply and demand, the primary factor that drives the price of fuel-grade petroleum coke is the sulfur content. A high sulfur content, 6 percent or higher, will normally result in a lower priced product as opposed to a product with a sulfur content in the range of 4.5 to 5.5 percent. A secondary factor to be considered in the price of fuel-grade petroleum coke is the hardness of the petroleum coke. As measured by the Hardgrove Grindability Index (HGI), the harder the petroleum coke, an HGI of less than 40, then typically the lower the market price for the product. Therefore, a fuel-grade petroleum coke product with a high sulfur content and a low HGI will result in the most favorable pricing opportunities.

The availability of a high sulfur, low HGI petroleum coke product is directly tied to the specifications of the heavy crude oils being refined. During the next three to four years there will be available approximately four to six million ton annually of this particular petroleum coke product (high sulfur/low HGI). During the same time frame, another petroleum coke product with a medium range of sulfur of 5 to 5.5 percent and a HGI range of 35 to 40, with an annual production of approximately eight to ten million tons will also be available. This medium grade petroleum coke will be sourced from Venezuela. The pricing of the above products will normally be at a deeper discount than a lower sulfur, (4.5 to 5 percent) and high HGI (48 plus) petroleum coke product. Further, if the lower grade petroleum coke product can be obtained from a foreign based refinery, then the transportation cost will be approximately one-quarter to one-third of the domestic transportation cost.

As the use of fuel-grade petroleum coke has increased and gained acceptance in the electric utility industry, the sophistication of the buyers and seller has increased as well. In the past, the petroleum coke market witnessed contract terms normally a year or less, refineries were not willing to sell direct, and pricing arrangements which were not always market price sensitive. Now sellers of petroleum coke are entering into longer-term contracts, refineries are either selling or entertaining the sale of their product direct and the pricing mechanisms are allowing both the buyer and seller to stay market price sensitive in a longer term arrangement.

Based on Lakeland's research, there would be an adequate supply to support the fuel requirements of McIntosh Unit 4 which, according to preliminary modeling of McIntosh Unit 4, would be approximately 400,000 tons annually.

McIntosh Unit 3 burns approximately 58,000 tons of petroleum coke annually. The petroleum coke burned in McIntosh Unit 3 is a higher grade, lower sulfur, more expensive petroleum coke than what would be burned in McIntosh Unit 4. Therefore, the petroleum coke price forecast resembles the expected price for the low grade, high sulfur and hardness, petroleum coke for a potential petcoke unit at the McIntosh site.

5.3.2.2.2 Petroleum coke transportation. In general, petroleum coke is amenable to transport by truck, rail, barges, ocean going ships, or a combination of these modes of transportation. Currently, petroleum coke for McIntosh 3 is transported to the McIntosh site by truck. For McIntosh Unit 4, the petroleum coke would be shipped to either the port of Charleston, South Carolina or Tampa, and then railed or trucked to Lakeland. The transportation cost for delivery of the petroleum coke would comprise the largest cost component of the delivered petroleum coke price and has been included in the forecasted petroleum coke price.

5.3.2.2.3 Petroleum coke price forecast. The AEO does not include a fuel price forecast for petroleum coke. As a result, the initial petroleum coke price used in the analysis was based on the expected supply and demand conditions in the petroleum coke market in the future. The price escalation used in the forecast considered the link that exists between the price of petroleum coke and the price of coal. This link exists because of the substitutability of these two products by many units if the economics so dictated. Therefore, the base case forecast assumed that the petroleum coke price escalation would track that of coal, as resulting from the projected inflation rate and the AEO real price escalation for coal.

5.3.2.3 Coal. Coal has been used as an energy source for hundreds of years and provided the energy which fueled the Industrial Revolution of the 19th Century and it was a primary fuel of the electric era in the 20th Century. As of 1998, some 37 percent of the electricity generated worldwide and over half (57 percent) of the electricity generated in the United States was produced from coal.

5.3.2.3.1 Coal supply and availability. Lakeland's current coal purchase contracts are approximately 50 percent long-term and 50 percent spot purchases. Spot purchases can extend from several months to two years in length. Lakeland maintains a 30 – 35 day coal supply reserve (90,000 – 110,000 tons) at the McIntosh site.

5.3.2.3.2 Coal transportation. McIntosh Unit 3 is Lakeland's only unit burning coal. Lakeland projects McIntosh Unit 3 will burn approximately 850,000 tons of coal per year. The coal sources are located in eastern Kentucky, which affords Lakeland a single rail line haul via CSX Transportation.

5.3.2.3.3 Coal price forecast. There are two coal price forecasts in Table 5-2 representing the contracted coal price for McIntosh 3 and the projected coal price for a potential new coal unit at the McIntosh site.

Currently, Lakeland purchases coal for McIntosh 3 under a contract which expires in December of 2006. As shown in Table 5-2, after the expiration of this contract, the price assumed for McIntosh 3 coal is the same as that for a potential new unit, and is based on the AEO escalation rate and the 3.0 percent general inflation rate. The two coal

price forecasts then remain equal to one another throughout the remainder of the forecast period. The initial coal price for the new coal unit is based on present market conditions.

5.3.2.4 Fuel Oil

5.3.2.4.1 Fuel oil supply and availability. The city of Lakeland currently obtains all of its fuel oil through spot market purchases and has no long-term contracts. This strategy provides the lowest cost for fuel oil consistent with usage, current price stabilization, and on-site storage. Lakeland's Fuels Section continually monitors the cost-effectiveness of spot market purchasing.

5.3.2.4.2 Fuel oil transportation. Although the City of Lakeland is not a large consumer of fuel oils, a small amount is consumed during operations for backup fuel and diesel unit operations. Fuel oil is transported to Lakeland by truck.

5.3.2.4.3 Fuel oil price forecast. The price forecast for No. 2 and No. 6 fuel oils were developed by Lakeland. Lakeland's actual 2000 fuel oil costs were escalated based on the escalation rate presented in the AEO forecast. The AEO escalation rates were applied over five year intervals and applied to Lakeland's 2000 actual fuel costs plus the 3.0 percent general inflation rate.

5.3.3 Fuel Forecast Sensitivities

While Lakeland carefully forecasts fuel prices based upon available information volatility in the market means that actual fuel prices often vary from the forecasted values. In attempt to bracket the variance of the projected fuel prices, Lakeland utilizes a high and low fuel price forecast. Lakeland also presents a case where a constant price differential is maintained over the planning horizon between natural gas/oil and coal.

5.3.3.1 High Fuel Price Forecast. The high fuel price forecast assumes that higher than expected fuel price escalation occurs over the planning horizon. Lakeland has assumed that for the high fuel price an escalation of 2.5 percent above the base case forecast is a reasonable upper limit. For natural gas, the additional escalation rate is only applied to the commodity price. The forecast is provided in Table 5-4.

5.3.3.2 Low Fuel Price Forecast. The low fuel price forecast assumes that lower than expected fuel price escalation occurs over the planning horizon. Lakeland has assumed that for the low fuel price scenario an escalation of 2.5 percent below the base case forecast is a reasonable lower limit. For natural gas, the lower escalation rate is only applied to the commodity price. The forecast is provided in Table 5-5.

5.3.3.3 Constant Differential Between Fuels. Lakeland also conducts a sensitivity analysis that assumes a constant differential between fuels over the planning horizon. This case uses the 2000 fuel cost differential between the fuels and maintains that same dollar value differential throughout the planning horizon compared to projected coal prices. Table 5-6 displays the fuel price forecast for this scenario.

Table 5-4
High Fuel Price Forecast Summary (Delivered Price \$/mmbtu)

| | McIntosh 3 Coal | New Unit Coal | Existing Unit NG | New Unit NG | HS Oil | LS Oil | Diesel | McIntosh 4 Pet Coke |
|---|--------------------|------------------|---------------------|-------------|--------|--------|--------|------------------------|
| 2001 | 1.68 | 1.95 | 4.23 | 4.50 | 4.55 | 4.96 | 7.24 | 0.80 |
| 2002 | 1.76 | 1.96 | 4.57 | 4.84 | 5.13 | 5.59 | 7.86 | 0.84 |
| 2003 | 1.85 | 1.97 | 4.94 | 5.21 | 5.78 | 6.30 | 8.52 | 0.88 |
| 2004 | 1.94 | 1.98 | 5.34 | 5.62 | 6.52 | 7.10 | 9.25 | 0.92 |
| 2005 | 2.04 | 2.08 | 5.78 | 6.06 | 7.35 | 8.01 | 10.03 | 0.97 |
| 2006 | 2.13 | 2.17 | 6.19 | 6.46 | 7.94 | 8.65 | 10.72 | 1.01 |
| 2007 | 2.27 | 2.27 | 6.62 | 6.90 | 8.59 | 9.36 | 11.47 | 1.06 |
| 2008 | 2.38 | 2.38 | 7.09 | 7.37 | 9.28 | 10.12 | 12.26 | 1.11 |
| 2009 | 2.49 | 2.49 | 7.59 | 7.87 | 10.04 | 10.94 | 13.11 | 1.16 |
| 2010 | 2.60 | 2.60 | 8.13 | 8.41 | 10.85 | 11.83 | 14.01 | 1.21 |
| 2011 | 2.74 | 2.74 | 8.67 | 8.95 | 11.58 | 12.62 | 15.02 | 1.28 |
| 2012 | 2.88 | 2.88 | 9.25 | 9.53 | 12.36 | 13.47 | 16.10 | 1.35 |
| 2013 | 3.03 | 3.03 | 9.88 | 10.15 | 13.19 | 14.37 | 17.25 | 1.42 |
| 2014 | 3.20 | 3.20 | 10.54 | 10.82 | 14.08 | 15.34 | 18.49 | 1.49 |
| 2015 | 3.36 | 3.36 | 11.26 | 11.53 | 15.02 | 16.37 | 19.82 | 1.57 |
| 2016 | 3.55 | 3.55 | 12.13 | 12.41 | 15.99 | 17.42 | 21.17 | 1.66 |
| 2017 | 3.74 | 3.74 | 13.08 | 13.36 | 17.02 | 18.55 | 22.61 | 1.75 |
| 2018 | 3.95 | 3.95 | 14.11 | 14.38 | 18.12 | 19.74 | 24.14 | 1.84 |
| 2019 | 4.16 | 4.16 | 15.22 | 15.49 | 19.29 | 21.02 | 25.79 | 1.94 |
| 2020 | 4.39 | 4.39 | 16.42 | 16.69 | 20.53 | 22.37 | 27.54 | 2.05 |
| Average Annual Escalation Rate | 5.18% | 4.37% | 7.40% | 7.14% | 8.25% | 8.25% | 7.29% | 5.08% |

Table 5-5
Low Fuel Price Forecast Summary (Delivered Price \$/mmbtu)

| | McIntosh 3 Coal | New Unit Coal | Existing Unit NG | New Unit NG | HS Oil | LS Oil | Diesel | McIntosh 4 Pet Coke |
|---|--------------------|------------------|---------------------|-------------|--------|--------|--------|------------------------|
| 2001 | 1.58 | 1.95 | 4.02 | 4.30 | 4.30 | 4.69 | 6.83 | 0.75 |
| 2002 | 1.56 | 1.96 | 4.13 | 4.40 | 4.58 | 4.99 | 6.99 | 0.74 |
| 2003 | 1.54 | 1.97 | 4.23 | 4.51 | 4.88 | 5.32 | 7.15 | 0.73 |
| 2004 | 1.52 | 1.98 | 4.35 | 4.62 | 5.20 | 5.67 | 7.31 | 0.73 |
| 2005 | 1.50 | 1.96 | 4.46 | 4.74 | 5.54 | 6.04 | 7.48 | 0.72 |
| 2006 | 1.48 | 1.92 | 4.52 | 4.80 | 5.65 | 6.16 | 7.54 | 0.70 |
| 2007 | 1.89 | 1.89 | 4.58 | 4.86 | 5.76 | 6.27 | 7.59 | 0.69 |
| 2008 | 1.86 | 1.86 | 4.64 | 4.92 | 5.87 | 6.40 | 7.65 | 0.68 |
| 2009 | 1.83 | 1.83 | 4.70 | 4.98 | 5.98 | 6.52 | 7.70 | 0.67 |
| 2010 | 1.80 | 1.80 | 4.77 | 5.04 | 6.10 | 6.65 | 7.76 | 0.66 |
| 2011 | 1.79 | 1.79 | 4.81 | 5.08 | 6.13 | 6.68 | 7.84 | 0.66 |
| 2012 | 1.77 | 1.77 | 4.85 | 5.13 | 6.16 | 6.72 | 7.92 | 0.65 |
| 2013 | 1.76 | 1.76 | 4.89 | 5.17 | 6.20 | 6.75 | 8.00 | 0.64 |
| 2014 | 1.74 | 1.74 | 4.93 | 5.21 | 6.23 | 6.79 | 8.07 | 0.64 |
| 2015 | 1.73 | 1.73 | 4.97 | 5.25 | 6.27 | 6.83 | 8.15 | 0.63 |
| 2016 | 1.71 | 1.71 | 5.06 | 5.34 | 6.28 | 6.85 | 8.21 | 0.63 |
| 2017 | 1.70 | 1.70 | 5.15 | 5.43 | 6.30 | 6.86 | 8.26 | 0.62 |
| 2018 | 1.69 | 1.69 | 5.25 | 5.52 | 6.32 | 6.88 | 8.31 | 0.62 |
| 2019 | 1.68 | 1.68 | 5.34 | 5.62 | 6.33 | 6.90 | 8.36 | 0.61 |
| 2020 | 1.67 | 1.67 | 5.44 | 5.71 | 6.35 | 6.92 | 8.41 | 0.61 |
| Average Annual Escalation Rate | 0.27% | -0.83% | 1.60% | 1.51% | 2.07% | 2.07% | 1.10% | -1.10% |

Table 5-6
Constant Differential Fuel Price Forecast Summary (Delivered Price \$/mmbtu)

| | McIntosh 3 Coal | New Unit Coal | Existing Unit NG | New Unit NG | HS Oil | LS Oil | Diesel | McIntosh 4 Pet Coke |
|---|--------------------|------------------|---------------------|--------------|--------------|--------------|--------------|------------------------|
| 2001 | 1.63 | 1.95 | 4.12 | 4.40 | 4.42 | 4.82 | 7.03 | 0.78 |
| 2002 | 1.66 | 1.96 | 4.15 | 4.43 | 4.45 | 4.85 | 7.06 | 0.81 |
| 2003 | 1.69 | 1.97 | 4.18 | 4.46 | 4.48 | 4.88 | 7.09 | 0.84 |
| 2004 | 1.72 | 1.98 | 4.22 | 4.49 | 4.52 | 4.91 | 7.13 | 0.87 |
| 2005 | 1.75 | 2.02 | 4.25 | 4.52 | 4.55 | 4.94 | 7.16 | 0.90 |
| 2006 | 1.78 | 2.05 | 4.27 | 4.55 | 4.57 | 4.97 | 7.18 | 0.93 |
| 2007 | 2.08 | 2.08 | 4.57 | 4.85 | 4.87 | 5.27 | 7.48 | 1.22 |
| 2008 | 2.11 | 2.11 | 4.60 | 4.88 | 4.90 | 5.30 | 7.51 | 1.25 |
| 2009 | 2.14 | 2.14 | 4.63 | 4.91 | 4.93 | 5.33 | 7.54 | 1.28 |
| 2010 | 2.17 | 2.17 | 4.66 | 4.94 | 4.96 | 5.36 | 7.57 | 1.32 |
| 2011 | 2.22 | 2.22 | 4.71 | 4.99 | 5.01 | 5.41 | 7.62 | 1.36 |
| 2012 | 2.27 | 2.27 | 4.76 | 5.04 | 5.06 | 5.46 | 7.67 | 1.41 |
| 2013 | 2.32 | 2.32 | 4.81 | 5.09 | 5.11 | 5.51 | 7.72 | 1.46 |
| 2014 | 2.37 | 2.37 | 4.86 | 5.14 | 5.16 | 5.56 | 7.77 | 1.51 |
| 2015 | 2.42 | 2.42 | 4.91 | 5.19 | 5.21 | 5.61 | 7.82 | 1.57 |
| 2016 | 2.48 | 2.48 | 4.97 | 5.25 | 5.27 | 5.67 | 7.88 | 1.62 |
| 2017 | 2.54 | 2.54 | 5.03 | 5.31 | 5.33 | 5.73 | 7.94 | 1.68 |
| 2018 | 2.60 | 2.60 | 5.09 | 5.37 | 5.39 | 5.79 | 8.00 | 1.74 |
| 2019 | 2.66 | 2.66 | 5.15 | 5.43 | 5.45 | 5.85 | 8.06 | 1.81 |
| 2020 | 2.72 | 2.72 | 5.22 | 5.49 | 5.52 | 5.91 | 8.13 | 1.87 |
| Average Annual Escalation Rate | 2.73% | 1.78% | 1.24% | 1.17% | 1.17% | 1.08% | 0.76% | 4.73% |

6.0 Forecast of Facilities Requirements

6.1 Need for Capacity

This section addresses the need for additional electric capacity to serve Lakeland's electric customers in the future. The need for capacity is based on Lakeland's load forecast, reserve margin requirements, power sales contracts, existing generating and unit capability and scheduled retirements of generating units.

6.1.1 Load Forecast

The load forecast described in Section 3.0 is used to determine the need for capacity. A summary of the load forecast for winter and summer peak demand for base, high, and low projections is provided in Table 6-1. The peak demands presented in Table 6-1 reflect reductions for Lakeland's conservation and demand-side management programs and interruptible loads.

6.1.2 Reserve Requirements

Prudent utility planning requires that utilities secure firm generating resources over and above the expected peak system demand to account for unanticipated demand levels and supply constraints. Several methods of estimating the appropriate level of reserve capacity are used. The most commonly used approach is the reserve margin method, which is calculated as follows:

$$\frac{\text{system net capacity} - \text{system net peak demand}}{\text{system net peak demand}}$$

This is the approach used by Lakeland. Lakeland has adopted a 22 percent minimum reserve margin requirement for the winter season and a 20 percent reserve margin for the summer season as its planning criteria.

6.1.3 Additional Capacity Requirements

By comparing the load forecast plus reserves with firm supply, the additional capacity required on a system over time can be identified. Lakeland's requirements for additional capacity are presented in Tables 6-2 through 6-5 which show the projected reliability levels for winter and summer base cases, and winter high and low load demands, respectively. Lakeland's capacity requirements are driven by the winter peak demand forecasts.

| Year | Winter Peak Demand | | | Summer Peak Demand | | |
|------|--------------------|-------|-----|--------------------|------|-----|
| | Base | High | Low | Base | High | Low |
| 2001 | | | | 549 | 557 | 533 |
| 2002 | 627 | 734 | 494 | 564 | 572 | 547 |
| 2003 | 644 | 752 | 511 | 579 | 587 | 561 |
| 2004 | 662 | 769 | 529 | 593 | 602 | 575 |
| 2005 | 679 | 787 | 546 | 608 | 617 | 589 |
| 2006 | 697 | 804 | 564 | 623 | 633 | 603 |
| 2007 | 714 | 822 | 581 | 638 | 648 | 618 |
| 2008 | 732 | 839 | 599 | 653 | 663 | 632 |
| 2009 | 749 | 857 | 616 | 668 | 678 | 646 |
| 2010 | 767 | 874 | 634 | 683 | 693 | 660 |
| 2011 | 784 | 892 | 651 | 698 | 708 | 674 |
| 2012 | 802 | 909 | 669 | 712 | 724 | 688 |
| 2013 | 819 | 927 | 687 | 727 | 739 | 702 |
| 2014 | 837 | 944 | 704 | 742 | 754 | 717 |
| 2015 | 854 | 962 | 722 | 757 | 769 | 731 |
| 2016 | 872 | 979 | 739 | 772 | 784 | 745 |
| 2017 | 889 | 997 | 757 | 787 | 800 | 759 |
| 2018 | 907 | 1,012 | 774 | 802 | 815 | 773 |
| 2019 | 925 | 1,032 | 792 | 817 | 830 | 787 |
| 2020 | 942 | 1,049 | 809 | 831 | 845 | 802 |

*Includes reduction for conservation reductions and interruptible load.

Table 6-2
Projected Reliability Levels - Winter / Base Case

| Year | Net Generating Capacity (MW) | Net System Purchases (MW) | Net System Sales (MW) | Net System Capacity (MW) | System Peak Demand | | Reserve Margin | | Excess/ (Deficit) to Maintain 22% Reserve Margin | |
|-----------|------------------------------|---------------------------|-----------------------|--------------------------|---|--|--|---|--|--|
| | | | | | Before Interruptible and Load Management (MW) | After Interruptible and Load Management (MW) | Before Interruptible and Load Management (%) | After Interruptible and Load Management (%) | Before Interruptible and Load Management (MW) | After Interruptible and Load Management (MW) |
| | | | | | 2000/2001 | 647 | | | | |
| 2001/2002 | 891 | 0 | 100 | 791 | 691 | 627 | 14 | 26 | (52) | 26 |
| 2002/2003 | 957 | 0 | 100 | 857 | 708 | 644 | 21 | 33 | (7) | 71 |
| 2003/2004 | 957 | 0 | 100 | 857 | 727 | 662 | 18 | 29 | (30) | 49 |
| 2004/2005 | 957 | 0 | 100 | 857 | 745 | 679 | 15 | 26 | (52) | 29 |
| 2005/2006 | 870 | 0 | 100 | 770 | 764 | 697 | 1 | 10 | (162) | (80) |
| 2006/2007 | 870 | 0 | 100 | 770 | 781 | 714 | (1) | 8 | (183) | (101) |
| 2007/2008 | 870 | 0 | 100 | 770 | 800 | 732 | (4) | 5 | (206) | (123) |
| 2008/2009 | 870 | 0 | 100 | 770 | 817 | 749 | (6) | 3 | (227) | (144) |
| 2009/2010 | 870 | 0 | 100 | 770 | 836 | 767 | (8) | 0 | (250) | (166) |
| 2010/2011 | 870 | 0 | 0 | 870 | 853 | 784 | 2 | 11 | (171) | (86) |
| 2011/2012 | 870 | 0 | 0 | 870 | 872 | 802 | (0) | 8 | (194) | (108) |
| 2012/2013 | 870 | 0 | 0 | 870 | 889 | 819 | (2) | 6 | (215) | (129) |
| 2013/2014 | 870 | 0 | 0 | 870 | 909 | 837 | (4) | 4 | (239) | (151) |
| 2014/2015 | 870 | 0 | 0 | 870 | 926 | 854 | (6) | 2 | (260) | (172) |
| 2015/2016 | 870 | 0 | 0 | 870 | 945 | 872 | (8) | (0) | (283) | (194) |
| 2016/2017 | 870 | 0 | 0 | 870 | 962 | 889 | (10) | (2) | (304) | (215) |
| 2017/2018 | 870 | 0 | 0 | 870 | 981 | 907 | (11) | (4) | (327) | (237) |
| 2018/2019 | 870 | 0 | 0 | 870 | 999 | 925 | (13) | (6) | (349) | (259) |
| 2019/2020 | 870 | 0 | 0 | 870 | 1,017 | 942 | (14) | (8) | (371) | (279) |

Table 6-3
Projected Reliability Levels - Summer / Base Case

| Year | Net Generating Capacity (MW) | Net System Purchases (MW) | Net System Sales (MW) | Net System Capacity (MW) | System Peak Demand | | Reserve Margin | | Excess/ (Deficit) to Maintain 20% Reserve Margin | |
|------|------------------------------|---------------------------|-----------------------|--------------------------|---|--|--|---|--|--|
| | | | | | Before Interruptible and Load Management (MW) | After Interruptible and Load Management (MW) | Before Interruptible and Load Management (%) | After Interruptible and Load Management (%) | Before Interruptible and Load Management (MW) | After Interruptible and Load Management (MW) |
| 2001 | 835 | 0 | 100 | 735 | 584 | 549 | 26 | 34 | 34 | 76 |
| 2002 | 878 | 0 | 100 | 778 | 600 | 564 | 30 | 38 | 58 | 101 |
| 2003 | 878 | 0 | 100 | 778 | 615 | 579 | 27 | 34 | 40 | 83 |
| 2004 | 878 | 0 | 100 | 778 | 629 | 593 | 24 | 31 | 23 | 66 |
| 2005 | 878 | 0 | 100 | 778 | 644 | 608 | 21 | 28 | 5 | 48 |
| 2006 | 791 | 0 | 100 | 691 | 660 | 623 | 5 | 11 | (101) | (57) |
| 2007 | 791 | 0 | 100 | 691 | 676 | 638 | 2 | 8 | (120) | (75) |
| 2008 | 791 | 0 | 100 | 691 | 691 | 653 | 0 | 6 | (138) | (93) |
| 2009 | 791 | 0 | 100 | 691 | 706 | 668 | (2) | 3 | (156) | (111) |
| 2010 | 791 | 0 | 100 | 691 | 722 | 683 | (4) | 1 | (175) | (129) |
| 2011 | 791 | 0 | 0 | 791 | 737 | 698 | 7 | 13 | (93) | (47) |
| 2012 | 791 | 0 | 0 | 791 | 751 | 712 | 5 | 11 | (110) | (63) |
| 2013 | 791 | 0 | 0 | 791 | 766 | 727 | 3 | 9 | (128) | (81) |
| 2014 | 791 | 0 | 0 | 791 | 782 | 742 | 1 | 7 | (147) | (99) |
| 2015 | 791 | 0 | 0 | 791 | 798 | 757 | (1) | 4 | (167) | (117) |
| 2016 | 791 | 0 | 0 | 791 | 813 | 772 | (3) | 2 | (185) | (135) |
| 2017 | 791 | 0 | 0 | 791 | 829 | 787 | (5) | 1 | (204) | (153) |
| 2018 | 791 | 0 | 0 | 791 | 844 | 802 | (6) | (1) | (222) | (171) |
| 2019 | 791 | 0 | 0 | 791 | 859 | 817 | (8) | (3) | (240) | (189) |
| 2020 | 791 | 0 | 0 | 791 | 873 | 831 | (9) | (5) | (257) | (206) |

Table 6-4
Projected Reliability Levels - Winter / High Case

| Year | Net Generating Capacity (MW) | Net System Purchases (MW) | Net System Sales (MW) | Net System Capacity (MW) | System Peak Demand | | Reserve Margin | | Excess/ (Deficit) to Maintain 22% Reserve Margin | |
|-----------|------------------------------|---------------------------|-----------------------|--------------------------|---|--|--|---|--|--|
| | | | | | Before Interruptible and Load Management (MW) | After Interruptible and Load Management (MW) | Before Interruptible and Load Management (%) | After Interruptible and Load Management (%) | Before Interruptible and Load Management (MW) | After Interruptible and Load Management (MW) |
| | | | | | 2000/2001 | 647 | | | | |
| 2001/2002 | 891 | 0 | 100 | 791 | 798 | 734 | (1) | 8 | (183) | (104) |
| 2002/2003 | 957 | 0 | 100 | 857 | 816 | 752 | 5 | 14 | (139) | (60) |
| 2003/2004 | 957 | 0 | 100 | 857 | 834 | 769 | 3 | 11 | (160) | (81) |
| 2004/2005 | 957 | 0 | 100 | 857 | 853 | 787 | 0 | 9 | (184) | (103) |
| 2005/2006 | 870 | 0 | 100 | 770 | 871 | 804 | (12) | (4) | (293) | (211) |
| 2006/2007 | 870 | 0 | 100 | 770 | 889 | 822 | (13) | (6) | (315) | (233) |
| 2007/2008 | 870 | 0 | 100 | 770 | 907 | 839 | (15) | (8) | (337) | (254) |
| 2008/2009 | 870 | 0 | 100 | 770 | 925 | 857 | (17) | (10) | (359) | (276) |
| 2009/2010 | 870 | 0 | 100 | 770 | 943 | 874 | (18) | (12) | (380) | (296) |
| 2010/2011 | 870 | 0 | 0 | 870 | 961 | 892 | (9) | (2) | (302) | (218) |
| 2011/2012 | 870 | 0 | 0 | 870 | 979 | 909 | (11) | (4) | (324) | (239) |
| 2012/2013 | 870 | 0 | 0 | 870 | 997 | 927 | (13) | (6) | (346) | (261) |
| 2013/2014 | 870 | 0 | 0 | 870 | 1,016 | 944 | (14) | (8) | (370) | (282) |
| 2014/2015 | 870 | 0 | 0 | 870 | 1,034 | 962 | (16) | (10) | (391) | (304) |
| 2015/2016 | 870 | 0 | 0 | 870 | 1,052 | 979 | (17) | (11) | (413) | (324) |
| 2016/2017 | 870 | 0 | 0 | 870 | 1,070 | 997 | (19) | (13) | (435) | (346) |
| 2017/2018 | 870 | 0 | 0 | 870 | 1,086 | 1,012 | (20) | (14) | (455) | (365) |
| 2018/2019 | 870 | 0 | 0 | 870 | 1,106 | 1,032 | (21) | (16) | (479) | (389) |
| 2019/2020 | 870 | 0 | 0 | 870 | 1,124 | 1,049 | (23) | (17) | (501) | (410) |

Table 6-5
Projected Reliability Levels - Winter / Low Case

| Year | Net Generating Capacity (MW) | Net System Purchases (MW) | Net System Sales (MW) | Net System Capacity (MW) | System Peak Demand | | Reserve Margin | | Excess/ (Deficit) to Maintain 22% Reserve Margin | |
|-----------|------------------------------|---------------------------|-----------------------|--------------------------|---|--|--|---|--|--|
| | | | | | Before Interruptible and Load Management (MW) | After Interruptible and Load Management (MW) | Before Interruptible and Load Management (%) | After Interruptible and Load Management (%) | Before Interruptible and Load Management (MW) | After Interruptible and Load Management (MW) |
| 2000/2001 | 647 | | | | | | | | | |
| 2001/2002 | 891 | 0 | 100 | 791 | 558 | 494 | 42 | 60 | 110 | 188 |
| 2002/2003 | 957 | 0 | 100 | 857 | 575 | 511 | 49 | 68 | 156 | 234 |
| 2003/2004 | 957 | 0 | 100 | 857 | 594 | 529 | 44 | 62 | 132 | 212 |
| 2004/2005 | 957 | 0 | 100 | 857 | 612 | 546 | 40 | 57 | 110 | 191 |
| 2005/2006 | 870 | 0 | 100 | 770 | 631 | 564 | 22 | 37 | 0 | 82 |
| 2006/2007 | 870 | 0 | 100 | 770 | 648 | 581 | 19 | 33 | (21) | 61 |
| 2007/2008 | 870 | 0 | 100 | 770 | 667 | 599 | 15 | 29 | (44) | 39 |
| 2008/2009 | 870 | 0 | 100 | 770 | 684 | 616 | 13 | 25 | (64) | 18 |
| 2009/2010 | 870 | 0 | 100 | 770 | 703 | 634 | 10 | 21 | (88) | (3) |
| 2010/2011 | 870 | 0 | 0 | 870 | 720 | 651 | 21 | 34 | (8) | 76 |
| 2011/2012 | 870 | 0 | 0 | 870 | 739 | 669 | 18 | 30 | (32) | 54 |
| 2012/2013 | 870 | 0 | 0 | 870 | 757 | 687 | 15 | 27 | (54) | 32 |
| 2013/2014 | 870 | 0 | 0 | 870 | 776 | 704 | 12 | 24 | (77) | 11 |
| 2014/2015 | 870 | 0 | 0 | 870 | 794 | 722 | 10 | 20 | (99) | (11) |
| 2015/2016 | 870 | 0 | 0 | 870 | 812 | 739 | 7 | 18 | (121) | (32) |
| 2016/2017 | 870 | 0 | 0 | 870 | 830 | 757 | 5 | 15 | (143) | (54) |
| 2017/2018 | 870 | 0 | 0 | 870 | 848 | 774 | 3 | 12 | (165) | (74) |
| 2018/2019 | 870 | 0 | 0 | 870 | 866 | 792 | 0 | 10 | (187) | (96) |
| 2019/2020 | 870 | 0 | 0 | 870 | 884 | 809 | (2) | 8 | (208) | (117) |

The last column of Table 6-2 indicates that using the base winter forecast, 80 MW of capacity is required for the 2005/2006 winter season to maintain a 22 percent reserve margin. The capacity need accounts for the planned retirement of McIntosh 1 in October of 2005. However, even if McIntosh 1 were not retired, Lakeland would still need 7 MW of capacity for the 2005/2006 winter season.

Table 6-3 indicates that 57 MW of capacity is required for the 2006 summer season to maintain a 20 percent reserve margin. Thus, for planning purposes, Lakeland is assumed to be required to add new capacity to meet the first deficit which, absent unit additions, would occur in the winter of 2005/06.

Tables 6-4 and 6-5 show the high and low load forecasts for Lakeland. The high forecast indicates an immediate need for capacity while the low projects a delayed need for capacity until the winter of 2014/2015.

7.0 Analysis Results and Conclusions

This section discusses the status of Lakeland's determination of its optimum expansion plan as of December 31, 2000. At the time of this filing, Lakeland is continuing its evaluation of capacity options including the bids received in response to its RFP. If one or more of these options have the potential to be cost-effective, negotiations will follow the initial evaluations. Therefore, due to strategic considerations, this section describes the methodology being followed in the planning process without specifying a preferred incremental capacity resource either from the RFP or other available options.

However, given the need to show sufficient capacity over a ten year time frame, for purposes of the Ten-Year Site Plan, a 288 MW PFBC unit (188 MW Lakeland's share) is assumed to occur in 2005. This "place holder" is based on the results of the 2000 TYSP and reflects the probable size range and usage of the capacity alternative which will be chosen, but should not be viewed as a preferred alternative since the evaluation of options is ongoing.

7.1 Economic Evaluation

Lakeland's current resource planning cycle was initiated when the analysis for the 2000 TYSP indicated that a solid fuel unit with capacity of approximately 300 MW coming into operation in 2005 would be the incremental capacity addition that is part of the most cost-effective expansion plan.

Based on these results, Lakeland chose to initiate an RFP process as a means to implement the plan in a cost-effective manner, and issued the RFP on June 12, 2000. Given the extreme volatility in the natural gas market recently, and due to Lakeland's dependence on natural gas, the RFP indicated a preference for solid fuel capacity or, if not solid fuel, a guaranteed escalation of fuel costs. Capacity resources from 200 MW to 400 MW were sought, and bidders were informed of the price and non-price criteria which would be used for the evaluation of proposals.

Lakeland held a pre-bidder's conference in August, after which a number of prospective bidders asked that the due date for the proposals be extended beyond the initial due date of October 6, 2000. Lakeland agreed to extend the due date to December 1, 2000 at which time three proposals were received and deemed to be responsive. Two of the three proposals were for circulating fluidized bed (CPB) units burning petroleum coke to be built at the McIntosh site. The third proposal is for purchase power from an integrated coal gas production unit burning petroleum coke with an option for equity participation. Lakeland and FMPPA have entered into a Memorandum of Understanding whereby they will jointly participate in the project or the purchase. Lakeland is

continuing its evaluation of these proposals and other alternatives. The methodology by which Lakeland selected the 288 MW PFBC in the 2000 TYSP is discussed below.

7.1.1 Supply-Side Economic Analysis

The supply-side evaluations of generating unit alternatives were performed using POWROPT, an optimal generation expansion model. Black & Veatch developed POWROPT as an alternative to other optimization programs. POWROPT has been benchmarked against other optimization programs and has proven to be an effective modeling program. The program operates on an hourly chronological basis and is used to determine a set of optimal capacity expansion plans, simulate the operation of each plan, and select the most desirable plan based on cumulative present worth revenue requirements. POWROPT evaluates all combinations of generating unit alternatives and purchase power options on an annual basis while maintaining user-defined reliability criteria. The reserve criterion utilized was a minimum reserve margin of 22 percent for winter and 20 percent for summer. All capacity expansion plans were analyzed over a 20 year period from 2000 to 2019. A number of natural gas and solid fueled alternatives were available for selection in the expansion plans.

The revenue requirements evaluated include system fuel and variable O&M costs, fixed O&M costs for new unit additions (fixed O&M costs were not included for existing units because they are common to all plans), and capital costs for new unit additions (capital costs for existing units were not included since they are common to all plans).

After the optimal generation expansion plan was selected using POWROPT, Black & Veatch's POWRPRO detailed chronological production costing program was used to obtain the annual production cost for the expansion plan.

While options continue to be evaluated, purposes of the Ten Year Site Plan, Table 7-1 displays the reserve margins for the base case assuming 188 MW of additional PFBC capacity is added to the Lakeland system in 2005 (out of a 288 MW unit). As seen in Table 7-1, if this amount of capacity is added, Lakeland's minimum reserve margin will be met for the next ten years.

7.1.2 Demand-Side Economic Analysis

Concurrent with the supply-side analysis, demand side management (DSM) alternatives were evaluated to determine if any cost-effective measures could delay or mitigate the need for the capacity addition. The analysis included all the cost-effective DSM programs identified by Lakeland.

Table 7-1
Ten-Year Reliability Levels Assuming a 188 MW Capacity Addition in 2005 (Winter / Base Case)

| Winter Peak Period | Net Generating Capacity (MW) | Unit ¹ Additions/ (Retirements) (MW) | Net System Purchases/ (Sales) (MW) | Net System Capacity (MW) | System Peak Demand | | Reserve Margin | | Excess/ (Deficit) to Maintain 22% Reserve Margin | | |
|--------------------|------------------------------|---|------------------------------------|--------------------------|---|--|--|---|--|--|--|
| | | | | | Before Interruptible and Load Management (MW) | After Interruptible and Load Management (MW) | Before Interruptible and Load Management (%) | After Interruptible and Load Management (%) | Before Interruptible and Load Management (MW) | After Interruptible and Load Management (MW) | |
| 2000/2001 | 647 | L6 (24 MW) | | | | | | | | | |
| 2001/2002 | 891 | M5 CT 268 MW M5 CC 384 MW L7 (50 MW) | (100) | 791 | 691 | 627 | 14.5 | 26.2 | (52.0) | 26.1 | |
| 2002/2003 | 957 | | (100) | 857 | 708 | 644 | 21.0 | 33.1 | (6.8) | 71.3 | |
| 2003/2004 | 957 | | (100) | 857 | 727 | 662 | 17.9 | 29.5 | (29.9) | 49.4 | |
| 2004/2005 | 957 | | (100) | 857 | 745 | 679 | 15.0 | 26.2 | (51.9) | 28.6 | |
| 2005/2006 | 1,058 | M4 188 MW M1 (87 MW) | (100) | 958 | 764 | 697 | 25.4 | 37.4 | 25.9 | 107.7 | |
| 2006/2007 | 1,058 | | (100) | 958 | 781 | 714 | 22.7 | 34.2 | 5.2 | 86.9 | |
| 2007/2008 | 1,058 | | (100) | 958 | 800 | 732 | 19.8 | 30.9 | (18.0) | 65.0 | |
| 2008/2009 | 1,058 | | (100) | 958 | 817 | 749 | 17.3 | 27.9 | (38.7) | 44.2 | |
| 2009/2010 | 1,058 | | (100) | 958 | 836 | 767 | 14.6 | 24.9 | (61.9) | 22.3 | |
| 2010/2011 | 1,058 | | 0 | 1,058 | 853 | 784 | 24.0 | 34.9 | 17.3 | 101.5 | |

¹ L: Larsen Unit

M: McIntosh Unit

7.2 Sensitivity Analyses

Once the preferred option was selected in the base case, Lakeland performed several sensitivity analyses to measure the impact of important assumptions on the least cost plan. The sensitivity analyses will include the following:

- High load and energy growth.
- Low load and energy growth.
- High fuel price escalation.
- Low fuel price escalation.
- Constant differential between oil/gas and coal prices over the planning horizon.

For each sensitivity analysis, the least cost plan over the planning horizon was identified. The sensitivity analyses was performed over the 20 year planning period used in the base case economic evaluation, with a projection of annual costs and cumulative present worth costs.

7.3 Transmission

Each of the generating evaluated could be installed at the McIntosh site. Evaluation of purchase power alternatives resulting from Lakeland's potential RFP will require evaluation of transmission import capability based on the nature of the individual offer.

Lakeland will continue to make transmission system upgrades as necessary to support load growth on the system. There are no current plans for transmission upgrades with the installation of a unit at the McIntosh site.

7.4 Strategic Concerns

In selecting a power supply alternative, Lakeland must consider certain strategic factors, which reflect the utility's long-term ability to provide economical and reliable electric capacity and energy to its consumers. A number of strategic considerations favor the installation of a solid fuel unit at the McIntosh site (McIntosh Unit 4), although some of these advantages could also be captured in a power purchase having the necessary characteristics and guarantees. The benefits of placing a unit at the McIntosh site include excellent efficiency, existing site which can support the project capacity, electric industry deregulation, environmental benefits, and increased fuel diversity.

7.4.1 Efficiency

Lakeland strives to provide its customers with the lowest rates achievable while maintaining sound operating principles and environmentally clean units. The technologies being considered represent the best available solid fuel technology. With the installation of McIntosh Unit 4 or through a comparable power purchase, the capacity addition will yield high efficiency, it will strengthen Lakeland's fuel diversity and it will provide a very clean burning solution to meet Lakeland's load growth.

7.4.2 Reliability Need

Lakeland will not be able to maintain the minimum reserve margin without installing generation or purchasing power in 2005 under the base assumptions. McIntosh Unit 4 or a comparable capacity purchase offers the ability to meet Lakeland's expected load growth and reserve margin requirement of 22 percent in the winter and 20 percent in the summer. Also, with the increased fuel diversity, Lakeland customers will benefit from a more reliable power source, less subject to extreme volatility in the natural gas market.

7.4.3 Deregulation

In a deregulated environment, a solid fuel unit located in central Florida would be an economical unit due to its high efficiency, low heat rate and enhanced stability due to fuel diversity. This would ensure competitive generation for Lakeland customers and Florida residents. This will help ensure that Lakeland remains a competitive provider of electric generation for the future and reduces the risk that McIntosh 4 would become a stranded asset should retail access occur in the state.

7.4.4 Timing

With the installation of McIntosh Unit 4 or should Lakeland enter into a firm power purchase, Lakeland will benefit in many ways. The installation of McIntosh Unit 4 will counteract the scheduled retirements of older less efficient units. Customers will benefit from the replacement of older generation with cleaner more efficient generation. The financial savings from more efficient generation and fewer emissions will be passed along to the customers.

Lakeland has the opportunity to utilize its strategic advantage of low cost tax exempt municipal financing for the more capital intensive McIntosh Unit 4. The ability to use the tax exempt financing may not continue to be available as the industry deregulates.

7.4.5 Fuel Risk

If the option selected involves the construction of McIntosh Unit 4 which utilizes petroleum coke, Lakeland's natural gas dependency will decrease. The unit would also be capable of burning the coal used for McIntosh 3, thus providing Lakeland with fuel diversity should the petroleum coke supply be interrupted or should fuel economics justify a switch to coal. These advantages will also be available from purchase power fueled with petroleum coke or coal.

Currently Lakeland is dependent on natural gas. As of December 31, 2000, Lakeland is 67 percent dependent on natural gas. By December of 2005, Lakeland's generation mix will be 78 percent dependent on natural gas. The installation of McIntosh Unit 4 will significantly decrease Lakeland's dependency on natural gas in 2006 to 62 percent and create a more diverse and proportionate fuel dependency. With increased fuel diversity, Lakeland will become a more reliable source of energy generation for Lakeland's customers, FMPP, and the state of Florida.

7.4.6 Environmental Impacts

Should Lakeland chose to install a solid fuel unit at the McIntosh site, the use of the existing site minimizes environmental impacts and reduces the time and effort required for licensing. The low level of emissions with the units being considered reduces the risk associated with future environmental regulations while reducing emissions within the state through displacement and retirement of other less efficient units. Additional environmental considerations are discussed in the next section.

8.0 Environmental and Land Use Information

Lakeland's 2001 Ten-Year Site Plan includes McIntosh Unit 5 for which the simple cycle installation is complete and formal commercial operation is scheduled for May 1, 2001. The combined cycle conversion of McIntosh Unit 5 was approved by the PSC on May 10, 1999 in order No. PSC-99-0931-FOF-EM and construction began July 24, 2000. The Site Certification Application for McIntosh Unit No. 5 Steam Cycle which was filed with all the agencies for the Site Certification, contains detailed environmental and land use information.

Lakeland's Ten-Year Site Plan includes an assumed 188 MW share of McIntosh Unit 4, although as mentioned, the final capacity and unit are subject to change pending Lakeland's ongoing evaluation of options. The specific configuration of McIntosh Unit 4 will be determined as part of the Request for Proposal (RFP) process. For purposes of the Ten-Year Site Plan, McIntosh Unit 4 is assumed to a jointly owned 288 MW pressurized fluidized bed combined cycle (PFBC) with petroleum coke as the primary fuel and coal as the secondary fuel. Should another solid fuel unit ultimately be selected for installation at the McIntosh site, much of the following will also apply.

8.1 Status of Site Certification

Lakeland initiated a RFP process for the purchase of power or installation of new generation. Based on the progress of the RFP bid evaluation currently underway, Lakeland plans to file Need for Power and Site Certification Applications in the spring of 2001.

8.2 Land and Environmental Features

Control devices will be used to reduce emissions from either a new unit constructed at McIntosh or a unit constructed to provide purchase power.

Reclaimed water from treated sewage effluent is available for cooling water for a unit constructed at McIntosh. Use of reclaimed water will conserve valuable water resources. It is assumed that cooling tower blowdown will be treated for reuse as part of the design features of a unit constructed at McIntosh. Return of wastewater to the City Wastewater Treatment Facility may be possible which would reduce costs but there is limited additional capacity for this alternative. Existing fuel handling and storage facilities at McIntosh will be used, eliminating additional environmental impacts from these facilities. The location of the proposed site and the existing land use with adjacent

areas is shown on Figure 8-1. The proposed site layout for a PFBC unit is also provided in Figure 8-1.

8.3 Air Emissions

The proposed commercial operating date is June of 2005. Estimated emissions for a PFBC are as follows:

- SO₂, lb/MBtu – 0.20 (requires zero stage cyclone and sorbent consumption of 40,000 lb/hr per module with 8 percent fuel sulfur).
- NO_x, lb/MBtu – 0.09
- CO, lb/MBtu – 0.022
- Particulate, lb/MBtu – 0.011

8.4 Analysis of 1990 Clean Air Act Amendments

The City of Lakeland considers the impacts to its community and Peninsular Florida a vital portion of its strategic planning. While the Florida Electrical Power Plant Siting Act carefully bifurcates the need for the power plant from the environmental impacts of the facility, the Clean Air Act requirements have a great impact on the power plant's cost and performance.

8.4.1 Authority to Construct

A new unit is required to comply with the Clean Air Act and the current Florida air quality requirements stemming from the Act. Lakeland's Authority to Construct (ATC) permit for a new unit will be obtained through the Site Certification Process. One aspect of the ATC permit will be the determination of Best Available Control Technology (BACT). Major criteria pollutants included in the BACT analysis are SO₂, NO_x, VOC, CO, and PM/PM10. Lakeland believes that the inherently low emission profile will meet BACT requirements.

8.4.2 Title V Operating Permit

Along with the ATC, the unit will be required to obtain an operating permit under Title V of the Clean Air Act. All units at the McIntosh and Larsen sites will be ultimately included in a single Title V permit. Requirements under the Title V permit for a new unit will require similar emissions control and operations to those required under the ATC and BACT determination.

8.4.3 Title IV Acid Rain Permit

In addition to the construction and operating permit requirements of the Unit, the regulations implementing the Acid Rain provisions of the Clean Air Act Amendments require that electric utility units obtain acid rain permits.

8.4.4 Compliance Strategy

A new unit will emit relatively low levels of sulfur dioxide while running on either petroleum coke or coal. An affected unit must have allowances available for emission of sulfur dioxide to comply with its future Title IV Acid Rain permit. Lakeland's ATC permit will set a limit of sulfur dioxide emissions. Lakeland's share for current operation of the McIntosh and Larsen Units result in a combined sulfur dioxide emission rate of approximately 8,680 tons per year for 1999. Lakeland currently has 12,809 allowances available annually leaving enough allowances for a new unit. Purchasing allowances will be the compliance strategy utilized if, for any reason, Lakeland's existing allowances are insufficient.

8.5 Waste Supply and Use

Cooling water supply for a new unit at McIntosh will be reclaimed sewage treatment plant effluent water using the existing reclaimed water pipeline at the site. Additional filtration facilities will be required to ensure the water quality is suitable for the cooling towers and to meet Florida requirements for reuse. Process makeup for ash systems will primarily be cooling tower blowdown. Demineralized water supply will be treated well water using a new demineralizer system.



8.6 Wastewater Discharge

An existing wastewater disposal pump station and pipeline exists at McIntosh which transports wastewater back to the City's wastewater treatment plants for treatment and disposal. Because of pending discharge salinity restrictions, there may not be capacity for additional cooling tower blowdown wastewater to be disposed at the treatment facilities. Therefore, it has been assumed that cooling tower blowdown wastewater will be treated on-site at McIntosh for reuse. Cooling tower blowdown quality is suitable for direct reuse in ash conditioning systems. Excess blowdown would need to be treated by a process using reverse osmosis and evaporation technology to produce a low salinity product water and a solid waste that could be landfilled.

8.7 Fuel Delivery and Storage

A new unit at McIntosh is expected to burn 100 percent petroleum coke. The secondary fuel will be the same coal as burned in McIntosh Unit 3. The choice of the secondary fuel saves in the cost of an additional fuel storage space. Unit trains or trucks will deliver the petroleum coke. The coal is presently delivered by unit train to the site.

A separate storage pile for petroleum coke is planned adjacent to the existing coal pile for McIntosh Unit 3. Coal for secondary fuel use will be stored in the existing McIntosh Unit 3 coal pile.



CITY OF LAKELAND
DEPARTMENT
OF ELECTRIC
& WATER
UTILITIES

| | | | | |
|-------------|------|----|---------|-------------|
| PROJECT NO. | DATE | BY | CHKD BY | APPROVED BY |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

MANTON
PLANNING



9.0 Ten-Year Site Plan Schedules

The following section presents the schedules required by the Ten-Year Site Plan rules for the Florida Public Service Commission. Lakeland has attempted to provide complete information for the FPSC whenever possible.

9.1 Abbreviations and Descriptions

The following abbreviations are used throughout the Ten-Year Site Plan Schedules.

| <u>Abbreviation</u> | <u>Description</u> |
|-----------------------------------|--|
| Unit Type | |
| CA | Combined Cycle Steam Part |
| GT | Combustion Gas Turbine |
| ST | Steam Turbine |
| CT | Combined Cycle Combustion Turbine |
| NG | Natural Gas |
| Fuel Type | |
| DFO | Distillate Fuel Oil |
| RFO | Residual Fuel Oil |
| BIT | Bituminous Coal |
| WH | Waste Heat |
| WH | Waste Heat |
| Fuel Transportation Method | |
| PL | Pipeline |
| TK | Truck |
| RR | Railroad |
| Unit Status Code | |
| RE | Retired |
| TS | Construction Complete, not yet in commercial operation |
| U | Under Construction |
| P | Planned for installation |

Table 9-1
Schedule 1.0: Existing Generating Facilities as of December 31, 2000

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) | (11) | (12) | (13) | (14) |
|--|------------------|---------------|-----------|------|-----|----------------|-----|--------------------------------|----------------------------------|--------------------------------|------------------------|-----------------------------|------------|
| Plant Name | Unit No. | Location | Unit Type | Fuel | | Fuel Transport | | Alt Fuel Days Use ³ | Commercial In-Service Month/Year | Expected Retirement Month/Year | Gen. Max. Nameplate kW | Net Capability ² | |
| | | | | Pri | Alt | Pri | Alt | | | | | Summer MW | Winter MW |
| Charles Larsen Memorial | 2 | 16-17/28S/24E | GT | NG | DFO | PL | TK | NR | 11/62 | Unknown | 11,500 | 10 | 14 |
| | 3 | | GT | NG | DFO | PL | TK | NR | 12/62 | Unknown | 11,500 | 10 | 14 |
| | 5 | | CA | WH | --- | --- | --- | NR | 04/56 | Unknown | 25,000 | 29 | 31 |
| | 6 | | ST | NG | RFO | PL | TK | NR | 12/59 | 10/01 | 25,000 | 24 | 24 |
| | 7 | | ST | NG | RFO | PL | TK | NR | 02/66 | 01/02 | 50,000 | 50 | 50 |
| | 8 | | CT | NG | DFO | PL | TK | NR | 07/92 | Unknown | 101,520 | <u>73</u> | <u>93</u> |
| Plant Total | | | | | | | | | | | | 196 | 226 |
| C.D. McIntosh, Jr. | IC1 | 4-5/28S/24E | IC | DFO | --- | TK | --- | NR | 01/70 | Unknown | 2,500 | 3 | 3 |
| | IC2 | | IC | DFO | --- | TK | --- | NR | 01/70 | Unknown | 2,500 | 3 | 3 |
| | 1GT | | GT | NG | DFO | PL | TK | NR | 05/73 | Unknown | 26,640 | 17 | 20 |
| | ST1 | | ST | NG | RFO | PL | TK | NR | 02/71 | 10/05 | 103,000 | 87 | 87 |
| | ST2 | | ST | NG | RFO | PL | TK | NR | 06/76 | Unknown | 126,000 | 103 | 103 |
| | ST3 ¹ | | ST | BIT | --- | RR | --- | NR | 09/82 | Unknown | 363,870 | <u>205</u> | <u>205</u> |
| Plant Total | | | | | | | | | | | | 418 | 421 |
| System Total | | | | | | | | | | | | 614 | 647 |
| ¹ Lakeland's 60 percent portion of joint ownership with Orlando Utilities Commission. | | | | | | | | | | | | | |
| ² Net Normal. | | | | | | | | | | | | | |
| ³ Lakeland does not maintain records of the number of days that alternate fuel is used. | | | | | | | | | | | | | |
| Source: Lakeland Power Production Unit Rating Group | | | | | | | | | | | | | |

| Table 9-2 Schedule 2.1: History and Forecast of Energy Consumption and Number of Customers by Customer Class | | | | | | | | |
|---|---------------------|-----------------------|-------|--------------------------|--------------------------------------|------------|--------------------------|--------------------------------------|
| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) |
| Fiscal Year | Rural & Residential | | | | | Commercial | | |
| | Population | Members per Household | GWh | Average No. of Customers | Average kWh Consumption per Customer | GWh | Average No. of Customers | Average kWh Consumption per Customer |
| 1991 | 189,445 | 2.47 | 967 | 76,731 | 12,602 | 522 | 9,517 | 54,849 |
| 1992 | 198,763 | 2.55 | 987 | 77,863 | 12,676 | 526 | 9,664 | 54,429 |
| 1993 | 201,748 | 2.53 | 1,026 | 79,738 | 12,867 | 542 | 9,768 | 55,487 |
| 1994 | 206,040 | 2.53 | 1,080 | 81,542 | 13,245 | 574 | 9,967 | 57,590 |
| 1995 | 210,095 | 2.54 | 1,169 | 82,616 | 14,150 | 594 | 9,999 | 59,406 |
| 1996 | 213,347 | 2.54 | 1,201 | 84,089 | 14,282 | 589 | 9,729 | 60,541 |
| 1997 | 216,782 | 2.58 | 1,173 | 84,149 | 13,940 | 609 | 9,816 | 62,042 |
| 1998 | 218,959 | 2.54 | 1,254 | 86,340 | 14,529 | 634 | 10,127 | 62,644 |
| 1999 | 221,921 | 2.52 | 1,237 | 87,955 | 14,064 | 641 | 10,916 | 58,721 |
| 2000 | 225,558 | 2.54 | 1,274 | 88,813 | 14,345 | 708 | 11,085 | 63,870 |
| Forecast | | | | | | | | |
| 2001 | 229,467 | 2.56 | 1,299 | 89,806 | 14,465 | 721 | 11,208 | 64,329 |
| 2002 | 233,047 | 2.56 | 1,331 | 91,127 | 14,606 | 739 | 11,373 | 64,978 |
| 2003 | 236,620 | 2.56 | 1,363 | 92,446 | 14,744 | 757 | 11,538 | 65,609 |
| 2004 | 240,167 | 2.56 | 1,395 | 93,757 | 14,879 | 774 | 11,702 | 66,143 |
| 2005 | 243,674 | 2.56 | 1,427 | 95,065 | 15,011 | 793 | 11,865 | 66,835 |
| 2006 | 247,221 | 2.56 | 1,460 | 96,384 | 15,148 | 810 | 12,029 | 67,337 |
| 2007 | 250,757 | 2.57 | 1,492 | 97,703 | 15,271 | 828 | 12,194 | 67,902 |
| 2008 | 252,295 | 2.55 | 1,525 | 99,026 | 15,400 | 847 | 12,359 | 68,533 |
| 2009 | 257,857 | 2.57 | 1,557 | 100,360 | 15,514 | 864 | 12,526 | 68,977 |
| 2010 | 261,441 | 2.57 | 1,589 | 101,700 | 15,624 | 882 | 12,693 | 69,487 |

| Table 9-3 Schedule 2.2: History and Forecast of Energy Consumption and Number of Customers by Customer Class | | | | | | | |
|---|------------|-----------------------------|--|---------------------------|--|---|--|
| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) |
| Fiscal Year | Industrial | | | Railroads and Railways | Street & Highway Lighting GWh | Other Sales to Public Authorities GWh | Total Sales to Ultimate Consumers GWh |
| | GWh | Average No. of Customers | Average kWh Consumption per Customer | | | | |
| 1991 | 344 | 45 | 7,644,444 | 0 | 11 | 61 | 1,905 |
| 1992 | 356 | 47 | 7,574,468 | 0 | 13 | 65 | 1,947 |
| 1993 | 381 | 51 | 7,470,588 | 0 | 13 | 68 | 2,030 |
| 1994 | 400 | 51 | 7,843,137 | 0 | 14 | 69 | 2,137 |
| 1995 | 427 | 51 | 8,372,549 | 0 | 15 | 74 | 2,279 |
| 1996 | 436 | 59 | 7,389,831 | 0 | 15 | 78 | 2,319 |
| 1997 | 459 | 61 | 7,524,590 | 0 | 16 | 78 | 2,335 |
| 1998 | 474 | 62 | 7,645,161 | 0 | 17 | 80 | 2,460 |
| 1999 | 486 | 80 | 6,075,000 | 0 | 17 | 82 | 2,463 |
| 2000 | 532 | 85 | 6,258,824 | 0 | 18 | 11 | 2,543 |
| Forecast | | | | | | | |
| 2001 | 542 | 86 | 6,302,326 | 0 | 19 | 10 | 2,591 |
| 2002 | 556 | 88 | 6,318,182 | 0 | 19 | 10 | 2,655 |
| 2003 | 569 | 89 | 6,393,258 | 0 | 19 | 11 | 2,719 |
| 2004 | 583 | 90 | 6,477,778 | 0 | 20 | 11 | 2,783 |
| 2005 | 596 | 91 | 6,549,451 | 0 | 21 | 11 | 2,848 |
| 2006 | 610 | 93 | 6,559,140 | 0 | 21 | 11 | 2,912 |
| 2007 | 623 | 94 | 6,627,660 | 0 | 22 | 12 | 2,977 |
| 2008 | 636 | 95 | 6,694,737 | 0 | 22 | 12 | 3,042 |
| 2009 | 650 | 96 | 6,770,833 | 0 | 23 | 12 | 3,106 |
| 2010 | 664 | 98 | 6,775,510 | 0 | 23 | 13 | 3,171 |

| Table 9-4 Schedule 2.3: History and Forecast of Energy Consumption and Number of Customers by Customer Class | | | | | |
|---|-------------------------|-----------------------------|----------------------------|----------------------------------|---------------------------|
| (1) | (2) | (3) | (4) | (5) | (6) |
| Fiscal Year | Sales for Resale GWh | Utility Use & Losses GWh | Net Energy for Load GWh | Other Customers (Average No.) | Total No. of Customers |
| 1991 | 0 | 138 | 2,043 | 0 | 86,293 |
| 1992 | 0 | 143 | 2,090 | 0 | 87,574 |
| 1993 | 0 | 155 | 2,185 | 0 | 89,557 |
| 1994 | 0 | 146 | 2,283 | 0 | 91,560 |
| 1995 | 0 | 146 | 2,425 | 0 | 92,666 |
| 1996 | 0 | 116 | 2,435 | 0 | 93,877 |
| 1997 | 0 | 115 | 2,450 | 0 | 94,026 |
| 1998 | 0 | 132 | 2,592 | 0 | 96,529 |
| 1999 | 0 | 112 | 2,575 | 0 | 98,951 |
| 2000 | 0 | 166 | 2,709 | 0 | 99,983 |
| Forecast | | | | | |
| 2001 | 0 | 155 | 2,746 | 0 | 101,100 |
| 2002 | 0 | 159 | 2,814 | 0 | 102,588 |
| 2003 | 0 | 163 | 2,882 | 0 | 104,073 |
| 2004 | 0 | 167 | 2,950 | 0 | 105,549 |
| 2005 | 0 | 170 | 3,018 | 0 | 107,021 |
| 2006 | 0 | 175 | 3,087 | 0 | 108,506 |
| 2007 | 0 | 178 | 3,155 | 0 | 109,991 |
| 2008 | 0 | 182 | 3,224 | 0 | 111,480 |
| 2009 | 0 | 187 | 3,293 | 0 | 112,982 |
| 2010 | 0 | 190 | 3,361 | 0 | 114,491 |

| Table 9-5 Schedule 3.1: History and Forecast of Summer Peak Demand Base Case (MW) | | | | | | | | | |
|--|-------|-----------|--------|------------|-----------------|--------------|-----------------------|--------------|-----------------|
| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) |
| Year | Total | Wholesale | Retail | Interrupt. | Residential | | Commercial/Industrial | | Net Firm Demand |
| | | | | | Load Management | Conservation | Load Management | Conservation | |
| 1991 | 424 | 0 | 424 | 0 | 0 | 0 | 0 | 0 | 424 |
| 1992 | 434 | 0 | 434 | 0 | 0 | 0 | 0 | 0 | 434 |
| 1993 | 477 | 0 | 477 | 0 | 0 | 0 | 0 | 0 | 477 |
| 1994 | 455 | 0 | 455 | 0 | 0 | 0 | 0 | 0 | 455 |
| 1995 | 481 | 0 | 481 | 0 | 0 | 0 | 0 | 0 | 481 |
| 1996 | 490 | 0 | 490 | 0 | 0 | 0 | 0 | 0 | 482 |
| 1997 | 509 | 0 | 509 | 0 | 0 | 0 | 0 | 0 | 509 |
| 1998 | 535 | 0 | 535 | 0 | 0 | 0 | 0 | 0 | 535 |
| 1999 | 557 | 0 | 557 | 0 | 22 | 0 | 0 | 0 | 535 |
| 2000 | 573 | 0 | 573 | 0 | 21 | 0 | 0 | 0 | 552 |
| Forecast | | | | | | | | | |
| 2001 | 584 | 0 | 584 | 14 | 21 | 0 | 0 | 0 | 549 |
| 2002 | 600 | 0 | 600 | 14 | 22 | 0 | 0 | 0 | 564 |
| 2003 | 615 | 0 | 615 | 14 | 22 | 0 | 0 | 0 | 579 |
| 2004 | 629 | 0 | 629 | 14 | 22 | 0 | 0 | 0 | 593 |
| 2005 | 644 | 0 | 644 | 14 | 22 | 0 | 0 | 0 | 608 |
| 2006 | 660 | 0 | 660 | 14 | 23 | 0 | 0 | 0 | 623 |
| 2007 | 676 | 0 | 676 | 15 | 23 | 0 | 0 | 0 | 638 |
| 2008 | 691 | 0 | 691 | 15 | 23 | 0 | 0 | 0 | 653 |
| 2009 | 706 | 0 | 706 | 15 | 23 | 0 | 0 | 0 | 668 |
| 2010 | 722 | 0 | 722 | 15 | 24 | 0 | 0 | 0 | 683 |

| Table 9-6 Schedule 3.2: History and Forecast of Winter Peak Demand Base Case (MW) | | | | | | | | | |
|--|-------|-----------|--------|------------|-----------------|--------------|-----------------|--------------|-----------------|
| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) |
| Year | Total | Wholesale | Retail | Interrupt. | Residential | | Comm./Ind. | | Net Firm Demand |
| | | | | | Load Management | Conservation | Load Management | Conservation | |
| 1991/1992 | 464 | 0 | 464 | 0 | 20 | 0 | 0 | 0 | 444 |
| 1992/1993 | 480 | 0 | 480 | 0 | 23 | 0 | 0 | 0 | 457 |
| 1993/1994 | 485 | 0 | 485 | 0 | 0 | 0 | 0 | 0 | 445 |
| 1994/1995 | 578 | 0 | 578 | 0 | 40 | 0 | 0 | 0 | 538 |
| 1995/1996 | 655 | 0 | 655 | 0 | 45 | 0 | 0 | 0 | 610 |
| 1996/1997 | 552 | 0 | 552 | 0 | 0 | 0 | 0 | 0 | 552 |
| 1997/1998 | 476 | 0 | 476 | 0 | 0 | 0 | 0 | 0 | 476 |
| 1998/1999 | 611 | 0 | 611 | 0 | 0 | 0 | 0 | 0 | 611 |
| 1999/2000 | 661 | 0 | 661 | 0 | 51 | 0 | 0 | 0 | 610 |
| 2000/2001 | 706 | 0 | 706 | 0 | 51 | 0 | 0 | 0 | 655 |
| Forecast | | | | | | | | | |
| 2001/02 | 691 | 0 | 691 | 12 | 52 | 0 | 0 | 0 | 627 |
| 2002/03 | 708 | 0 | 708 | 12 | 52 | 0 | 0 | 0 | 644 |
| 2003/04 | 727 | 0 | 727 | 12 | 53 | 0 | 0 | 0 | 662 |
| 2004/05 | 745 | 0 | 745 | 13 | 53 | 0 | 0 | 0 | 679 |
| 2005/06 | 764 | 0 | 764 | 13 | 54 | 0 | 0 | 0 | 697 |
| 2006/07 | 781 | 0 | 781 | 13 | 54 | 0 | 0 | 0 | 714 |
| 2007/08 | 800 | 0 | 800 | 13 | 55 | 0 | 0 | 0 | 732 |
| 2008/09 | 817 | 0 | 817 | 13 | 55 | 0 | 0 | 0 | 749 |
| 2009/10 | 836 | 0 | 836 | 13 | 56 | 0 | 0 | 0 | 767 |
| 2010/11 | 853 | 0 | 853 | 13 | 56 | 0 | 0 | 0 | 784 |

| Table 9-7 Schedule 3.3: History and Forecast of Annual Net Energy for Load – GWh Base Case | | | | | | | | |
|--|-------|--------------------------|-------------------------|--------|-----------|----------------------|---------------------|---------------|
| (1) | (2) | (3) | (5) | (6) | (7) | (8) | (9) | (10) |
| Fiscal Year | Total | Residential Conservation | Comm./Ind. Conservation | Retail | Wholesale | Utility Use & Losses | Net Energy for Load | Load Factor % |
| 1991 | 1,760 | 0 | 0 | 1,760 | 0 | 138 | 1,898 | 49.2 |
| 1992 | 1,801 | 0 | 0 | 1,801 | 0 | 143 | 1,944 | 50.0 |
| 1993 | 1,851 | 0 | 0 | 1,851 | 0 | 155 | 2,006 | 50.1 |
| 1994 | 1,972 | 0 | 0 | 1,972 | 0 | 146 | 2,118 | 54.3 |
| 1995 | 2,100 | 0 | 0 | 2,100 | 0 | 146 | 2,246 | 47.7 |
| 1996 | 2,206 | 0 | 0 | 2,206 | 0 | 116 | 2,322 | 43.5 |
| 1997 | 2,216 | 0 | 0 | 2,216 | 0 | 115 | 2,331 | 48.2 |
| 1998 | 2,300 | 1 | 0 | 2,299 | 0 | 132 | 2,431 | 58.3 |
| 1999 | 2,353 | 1 | 0 | 2,352 | 0 | 112 | 2,464 | 46.0 |
| 2000 | 2,543 | 0 | 0 | 2,543 | 0 | 166 | 2,709 | 50.7 |
| Forecast | | | | | | | | |
| 2001 | 2,591 | 0 | 0 | 2,591 | 0 | 155 | 2,746 | 47.9 |
| 2002 | 2,655 | 0 | 0 | 2,655 | 0 | 159 | 2,814 | 51.2 |
| 2003 | 2,719 | 0 | 0 | 2,719 | 0 | 163 | 2,882 | 51.1 |
| 2004 | 2,783 | 0 | 0 | 2,783 | 0 | 167 | 2,950 | 50.9 |
| 2005 | 2,848 | 0 | 0 | 2,848 | 0 | 170 | 3,018 | 50.7 |
| 2006 | 2,912 | 0 | 0 | 2,912 | 0 | 175 | 3,087 | 50.6 |
| 2007 | 2,977 | 0 | 0 | 2,977 | 0 | 178 | 3,155 | 50.4 |
| 2008 | 3,042 | 0 | 0 | 3,042 | 0 | 182 | 3,224 | 50.3 |
| 2009 | 3,106 | 0 | 0 | 3,106 | 0 | 187 | 3,293 | 50.2 |
| 2010 | 3,171 | 0 | 0 | 3,171 | 0 | 190 | 3,361 | 50.0 |

| Table 9-8 Schedule 4: Previous Year and Two Year Forecast of Retail Peak Demand and Net Energy for Load by Month | | | | | | |
|---|--------------------------------|---------|--------------------------------|---------|--------------------------------|---------|
| (1) | (2) | (3) | (4) | (5) | (6) | (7) |
| Month | Actual | | 2001 Forecast | | 2002 Forecast | |
| | Peak Demand ¹ MW | NEL GWh | Peak Demand ¹ MW | NEL GWh | Peak Demand ¹ MW | NEL GWh |
| January | 610 | 211,021 | 655 | 231,112 | 627 | 236,846 |
| February | 508 | 190,059 | 557 | 199,796 | 577 | 204,753 |
| March | 407 | 195,373 | 483 | 204,416 | 501 | 209,487 |
| April | 416 | 194,644 | 444 | 197,480 | 456 | 202,379 |
| May | 504 | 246,358 | 501 | 231,511 | 514 | 237,254 |
| June | 532 | 251,453 | 539 | 252,529 | 553 | 258,794 |
| July | 552 | 262,095 | 544 | 265,298 | 559 | 271,880 |
| August | 539 | 269,321 | 549 | 269,440 | 564 | 276,125 |
| September | 528 | 253,700 | 533 | 250,804 | 548 | 257,025 |
| October | 510 | 210,893 | 489 | 222,953 | 502 | 228,355 |
| November | 476 | 195,837 | 455 | 199,018 | 468 | 203,839 |
| December | 597 | 228,570 | 550 | 221,835 | 565 | 227,210 |

¹After Load Management, Conservation and Interruptible Load exercised as needed.

Table 9-9
Schedule 5: Fuel Requirements

| (1) | (2) | (3) | (4) | (5) - (16) Calendar Year | | | | | | | | | | | |
|------|-------------------------|--------|--------------|--------------------------|---------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | | | | (5) | (6) | (7) | (8) | (9) | (10) | (11) | (12) | (13) | (14) | (15) | (16) |
| | Fuel Requirements | Type | Units | 1999 - Actual | 2000 - Actual | 2001 | 2002 | 2003 | 2004 | 2005 | 2006 | 2007 | 2008 | 2009 | 2010 |
| (1) | Nuclear | | Trillion Btu | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (2) | Coal ¹ | | 1000 Ton | 455 | 580 | 472 | 454 | 457 | 462 | 554 | 637 | 602 | 640 | 752 | 757 |
| (3) | | Total | 1000 BBL | 181 | 196 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (4) | | Steam | 1000 BBL | 181 | 196 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (5) | | CC | 1000 BBL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (6) | | CT | 1000 BBL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (7) | | Diesel | 1000 BBL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (8) | Distillate ³ | Total | 1000 BBL | 3 | 4 | 10 | 1 | 1 | 1 | 1 | 2 | 2 | 2 | 2 | 3 |
| (9) | | Steam | 1000 BBL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (10) | | CC | 1000 BBL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (11) | | CT | 1000 BBL | 3 | 4 | 10 | 1 | 1 | 1 | 1 | 2 | 2 | 2 | 2 | 3 |
| (12) | | Diesel | 1000 BBL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (13) | Natural Gas | Total | 1000 MCF | 9,280 | 8,121 | 17,342 | 14,307 | 14,608 | 14,984 | 13,862 | 12,553 | 13,613 | 13,324 | 11,907 | 12,267 |
| (14) | | Steam | 1000 MCF | 3,769 | 3,150 | 3,350 | 1,683 | 1,658 | 1,718 | 1,509 | 892 | 914 | 872 | 751 | 793 |
| (15) | | CC | 1000 MCF | 5,120 | 3,559 | 5,410 | 12,571 | 12,893 | 13,206 | 12,295 | 11,578 | 12,406 | 12,152 | 10,944 | 11,237 |
| (16) | | CT | 1000 MCF | 391 | 1,412 | 8,582 | 53 | 57 | 60 | 58 | 83 | 293 | 300 | 212 | 237 |
| (17) | | Diesel | 1000 MCF | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (18) | Other | | Trillion Btu | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

¹ Includes Petroleum Coke and Refuse Derived Fuel.
² Residual includes #4, #5 and #6 oil.
³ Distillate includes #1, #2 oil, kerosene, jet fuel and amounts used at coal burning plants for flame stabilization and on start up.

Table 9-10
Schedule 6.1: Energy Sources

| Table 9-10 Schedule 6.1: Energy Sources | | | | | | | | | | | | | | | |
|--|-------------------------|--------|-------|---------------|---------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) | (11) | (12) | (13) | (14) | (15) | (16) |
| | Fuel Requirements | Type | Units | Calendar Year | | | | | | | | | | | |
| | | | | 1999 - Actual | 2000 - Actual | 2001 | 2002 | 2003 | 2004 | 2005 | 2006 | 2007 | 2008 | 2009 | 2010 |
| (1) | Firm Interchange | | GWh | (18) | (28) | (466) | (581) | (577) | (577) | (579) | (567) | (564) | (561) | (597) | (595) |
| (2) | Nuclear | | GWh | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (3) | Residual ² | Total | GWh | 100 | 136 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (4) | | Steam | GWh | 99 | 136 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (5) | | CC | GWh | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (6) | | CT | GWh | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (7) | | Diesel | GWh | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (8) | Distillate ³ | Total | GWh | 0 | 2 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| (9) | | Steam | GWh | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (10) | | CC | GWh | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (11) | | CT | GWh | 0 | 2 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| (12) | | Diesel | GWh | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (13) | Natural Gas | Total | GWh | 1,192 | 1,087 | 1,760 | 1,992 | 2,046 | 2,097 | 1,906 | 1,728 | 1,887 | 1,848 | 1,638 | 1,687 |
| (14) | | Steam | GWh | 631 | 626 | 321 | 154 | 153 | 158 | 139 | 82 | 87 | 83 | 71 | 76 |
| (15) | | CC | GWh | 534 | 343 | 595 | 1,834 | 1,889 | 1,935 | 1,763 | 1,641 | 1,775 | 1,739 | 1,547 | 1,591 |
| (16) | | CT | GWh | 27 | 118 | 844 | 4 | 4 | 4 | 4 | 5 | 25 | 26 | 20 | 20 |
| (17) | Coal ¹ | Total | GWh | 1,301 | 1,512 | 1,451 | 1,402 | 1,412 | 1,429 | 1,690 | 1,925 | 1,831 | 1,936 | 2,251 | 2,268 |
| (18) | Net Energy for Load | | GWh | 2,575 | 2,709 | 2,746 | 2,814 | 2,882 | 2,950 | 3,018 | 3,087 | 3,155 | 3,224 | 3,293 | 3,361 |

¹ Includes Petroleum Coke and Refuse Derived Fuel.

² Residual includes #4, #5 and #6 oil.

³ Distillate includes #1, #2 oil, kerosene, jet fuel and amounts used at coal burning plants for flame stabilization and on start up.

| Table 9-11 Schedule 6.2: Energy Sources | | | | | | | | | | | | | | | |
|--|-------------------------------|--------|-------|---------------|---------------|------|------|------|------|------|------|------|------|------|------|
| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) | (11) | (12) | (13) | (14) | (15) | (16) |
| | Energy Source | Type | Units | Calendar Year | | | | | | | | | | | |
| | | | | 1999 - Actual | 2000 - Actual | 2001 | 2002 | 2003 | 2004 | 2005 | 2006 | 2007 | 2008 | 2009 | 2010 |
| (1) | Firm Interchange ⁴ | | % | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| (2) | Nuclear | | % | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| (3) | Residual ² | Total | % | 4% | 5% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| (4) | | Steam | % | 4% | 5% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| (5) | | CC | % | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| (6) | | CT | % | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| (7) | | Diesel | % | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| (8) | Distillate ³ | Total | % | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| (9) | | Steam | % | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| (10) | | CC | % | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| (11) | | CT | % | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| (12) | | Diesel | % | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| (13) | Natural Gas | Total | % | 46% | 40% | 55% | 59% | 59% | 60% | 53% | 47% | 51% | 49% | 42% | 43% |
| (14) | | Steam | % | 25% | 23% | 10% | 5% | 4% | 5% | 4% | 2% | 2% | 2% | 2% | 2% |
| (15) | | CC | % | 21% | 13% | 19% | 54% | 55% | 55% | 49% | 45% | 48% | 46% | 40% | 40% |
| (16) | | CT | % | 1% | 4% | 26% | 0% | 0% | 0% | 0% | 0% | 1% | 1% | 1% | 1% |
| (17) | Coal ¹ | Total | % | 50% | 55% | 45% | 41% | 41% | 41% | 47% | 53% | 49% | 51% | 58% | 57% |
| (18) | Net Energy for Load | | % | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% | 100% |

¹ Includes Petroleum Coke and Refuse Derived Fuel.
² Residual includes #4, #5 and #6 oil.
³ Distillate includes #1, #2 oil, kerosene, jet fuel and amounts used at coal burning plants for flame stabilization and on start up.

Table 9-12
Schedule 7.1: Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Summer Peak

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | | (9) | (10) | (11) | (12) |
|------|--------------------------|----------------------|----------------------|-------------------------------------|--------------------------|-------------------------|--|-----|-----------------------|---|------|------|
| Year | Total Installed Capacity | Firm Capacity Import | Firm Capacity Export | Projected Firm Net To Grid from NUG | Total Capacity Available | System Firm Peak Demand | Reserve Margin Before Maintenance ¹ | | Scheduled Maintenance | Reserve Margin After Maintenance ¹ | | |
| | MW | MW | MW | MW | MW | MW | MW | % | MW | MW | % | |
| 2001 | 835 | 0 | 150 | 0 | 685 | 549 | 136 | 25% | 0 | 136 | 25% | |
| 2002 | 878 | 0 | 100 | 0 | 778 | 564 | 214 | 38% | 0 | 214 | 38% | |
| 2003 | 878 | 0 | 100 | 0 | 778 | 579 | 199 | 34% | 0 | 199 | 34% | |
| 2004 | 878 | 0 | 100 | 0 | 778 | 593 | 185 | 31% | 0 | 185 | 31% | |
| 2005 | 1,066 | 0 | 100 | 0 | 966 | 608 | 358 | 59% | 0 | 358 | 59% | |
| 2006 | 979 | 0 | 100 | 0 | 879 | 623 | 256 | 41% | 0 | 256 | 41% | |
| 2007 | 979 | 0 | 100 | 0 | 879 | 638 | 241 | 38% | 0 | 241 | 38% | |
| 2008 | 979 | 0 | 100 | 0 | 879 | 653 | 226 | 35% | 0 | 226 | 35% | |
| 2009 | 979 | 0 | 100 | 0 | 879 | 668 | 211 | 32% | 0 | 211 | 32% | |
| 2010 | 979 | 0 | 100 | 0 | 879 | 683 | 196 | 29% | 0 | 196 | 29% | |

¹ Included exercising Load Management and Interruptible Load.

| Table 9-13 Schedule 7.2: Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Winter Peak | | | | | | | | | | | | |
|--|--------------------------|----------------------|----------------------|-------------------------------------|--------------------------|-------------------------|--|-----|-----------------------|---|------|------|
| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | | (9) | (10) | (11) | (12) |
| Year | Total Installed Capacity | Firm Capacity Import | Firm Capacity Export | Projected Firm Net To Grid from NUG | Total Capacity Available | System Firm Peak Demand | Reserve Margin Before Maintenance ¹ | | Scheduled Maintenance | Reserve Margin After Maintenance ¹ | | |
| | MW | MW | MW | MW | MW | MW | MW | % | MW | MW | % | |
| 2001 | 647 | 57 | 0 | 0 | 704 | 655 | 49 | 7% | 0 | 49 | 7% | |
| 2002 | 891 | 0 | 100 | 0 | 791 | 627 | 164 | 26% | 0 | 164 | 26% | |
| 2003 | 957 | 0 | 100 | 0 | 857 | 644 | 213 | 33% | 0 | 213 | 33% | |
| 2004 | 957 | 0 | 100 | 0 | 857 | 662 | 195 | 29% | 0 | 195 | 29% | |
| 2005 | 957 | 0 | 100 | 0 | 857 | 679 | 178 | 26% | 0 | 178 | 26% | |
| 2006 | 1,058 | 0 | 100 | 0 | 958 | 697 | 261 | 37% | 0 | 261 | 37% | |
| 2007 | 1,058 | 0 | 100 | 0 | 958 | 714 | 244 | 34% | 0 | 244 | 34% | |
| 2008 | 1,058 | 0 | 100 | 0 | 958 | 732 | 226 | 31% | 0 | 226 | 31% | |
| 2009 | 1,058 | 0 | 100 | 0 | 958 | 749 | 209 | 28% | 0 | 209 | 28% | |
| 2010 | 1,058 | 0 | 100 | 0 | 958 | 767 | 191 | 25% | 0 | 191 | 25% | |

¹ Included exercising Load Management and Interruptible Load

Table 9-14
Schedule 8.0: Planned and Prospective Generating Facility Additions and Changes

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) | (11) | (12) | (13) | (14) | (15) |
|-------------------------|----------|-------------|-----------|------|------|----------------|------|----------------------|--------------------------------|------------------------------|-------------------------|------------------|------------------|--------|
| Plant Name | Unit No. | Location | Unit Type | Fuel | | Fuel Transport | | Const Start Mo/Yr | Commercial In-Service Mo/Yr | Expected Retirement Mo/Yr | Gen Max Nameplate kW | Net Capability | | Status |
| | | | | Pri. | Alt. | Pri. | Alt. | | | | | Sum MW | Win MW | |
| Charles Larsen Memorial | 6 | Polk County | ST | NG | RFO | PL | TK | | | 10/01 | 25,000 | 24 | 24 | RE |
| | 7 | | ST | NG | RFO | PL | TK | | | 01/02 | 50,000 | 50 | 50 | RE |
| C.D. McIntosh Jr. | 1 | Polk County | ST | NG | RFO | PL | TK | | | 10/05 | 103,000 | 87 | 87 | RE |
| | 5 CT | | CT | NG | RFO | PL | TK | 06/98 | 05/01 | Unknown | 249,000 | 221 | 268 | TS |
| | 5 CC | | ST | WH | | | | 07/00 | 01/02 | Unknown | 120,000 | 120 | 120 | U |
| | 4 PFBC | | ST | PC | BIT | RR | RR | 01/02 | 06/05 | Unknown | 288,000 | 188 ¹ | 188 ¹ | P |

¹Lakeland's ownership share.

| Table 9-15 Schedule 9.1: Status Report and Specifications of Approved Generating Facilities | |
|--|---|
| (1) Plant Name and Unit Number: | McIntosh Unit 5 |
| (2) Capacity: | |
| (3) Summer MW | 120 MW (steam turbine only) |
| (4) Winter MW | 120 MW (steam turbine only) |
| (5) Technology Type: | Combined Cycle |
| (6) Anticipated Construction Timing: | |
| (7) Field Construction Start-date: | 07/01/00 |
| (8) Commercial In-Service date: | 01/01/02 |
| (9) Fuel | |
| (10) Primary | Waste Heat |
| (11) Alternate | |
| (12) Air Pollution Control Strategy: | Ultra Low NOx burners. If emissions of 9 ppm or below cannot be met with Ultra Low NOx burners, Lakeland will convert the unit and install a conventional SCR with a 7.5 ppm limit. |
| (13) Cooling Method: | Mechanical Cooling Tower |
| (14) Total Site Area. | 9.5 acres. |
| (15) Construction Status: | Combustion turbine complete. Steam turbine planned |
| (16) Certification Status: | Need for Power approved. Site Certification approved. |
| (17) Status with Federal Agencies: | Approved. |
| (18) Projected Unit Performance Data: | |
| (19) Planned Outage Factor (POF) | 4.38 percent |
| (20) Forced Outage Factor (FOF): | 4.5 percent |
| (21) Equivalent Availability Factor (EAF): | 91.2 percent |
| (22) Resulting Capacity Factor (%): | 91.2 percent |
| (23) Average Net Operating Heat Rate (ANOHR): | 6,523 Btu/kWh |
| (24) Projected Unit Financial Data: | |
| (25) Book Life: | 25 years |
| (26) Total Installed Cost (In-Service year \$/kW): | 748.99 |
| (27) Direct Construction Cost (\$/kW): | 670.83 |
| (28) AFUDC Amount (\$/kW): | 32.03 |
| (29) Escalation (\$/kW): | 46.13 |
| (30) Fixed O&M (\$/kW-yr): | 1.133 |
| (31) Variable O&M (\$/MWh): | 1.266 |
| (32) K factor | 1.2283 |

Table 9-16
Schedule 9.2: Status Report and Specifications of Proposed Generating Facilities

| | |
|--|--|
| (1) Plant Name and Unit Number: | McIntosh Unit 4 |
| (2) Capacity: | |
| (3) Summer MW | 288 MW (Lakeland ownership share of 188 MW) |
| (4) Winter MW | 288 MW (Lakeland ownership share of 188 MW) |
| (5) Technology Type: | Pressurized Fluidized Bed Combine Cycle |
| (6) Anticipated Construction Timing: | |
| (7) Field Construction Start-date: | 06/01/02 |
| (8) Commercial In-Service date: | 06/01/05 |
| (9) Fuel | |
| (10) Primary | Petroleum Coke |
| (11) Alternate | Coal |
| (12) Air Pollution Control Strategy: | SNCR, limestone, fabric filters or electrostatic precipitators for particulate matter. |
| (13) Cooling Method: | Cooling Tower |
| (14) Total Site Area: | PFBC Island dimensions: 510-ft.x560 ft. for Unit itself, Total site 513 acres). |
| (15) Construction Status: | None. |
| (16) Certification Status: | Filing planned April 2001. |
| (17) Status with Federal Agencies: | No status. |
| (18) Projected Unit Performance Data: | |
| (19) Planned Outage Factor (POF): | 7.6 percent |
| (20) Forced Outage Factor (FOF): | 12.0 percent |
| (21) Equivalent Availability Factor (EAF): | 81 percent |
| (22) Resulting Capacity Factor (%): | 81 percent |
| (23) Average Net Operating Heat Rate (ANOHR): | 9,575 Btu/kWh |
| (24) Projected Unit Financial Data: | |
| (25) Book Life: | 30 years |
| (26) Total Installed Cost (In-Service year \$/kW): | 1,500 |
| (27) Direct Construction Cost (\$/kW): | 1,200 |
| (28) AFUDC Amount (\$/kW): | 135 |
| (29) Escalation (\$/kW): | 165 |
| (30) Fixed O&M (\$/kW-yr): | 9.18 |
| (31) Variable O&M (\$/MWh): | 4.53 (including limestone) |
| (32) K factor | 1.2355 |

| Table 9-17 Schedule 10: Status Report and Specifications of Proposed Directly Associated Transmission Lines | | |
|---|-------------------------------------|---------------|
| (1) | Point of Origin and Termination: | None planned. |
| (2) | Number of Lines: | None planned. |
| (3) | Right of Way: | None planned. |
| (4) | Line Length: | None planned. |
| (5) | Voltage: | None planned. |
| (6) | Anticipated Construction Time: | None planned. |
| (7) | Anticipated Capital Investment: | None planned. |
| (8) | Substations: | None planned. |
| (9) | Participation with Other Utilities: | None planned. |