

STEEL  
HECTOR  
& DAVIS

REGISTERED LIMITED LIABILITY PARTNERSHIP

ORIGINAL

Steel Hector & Davis LLP  
215 South Monroe, Suite 601  
Tallahassee, Florida 32301-1804  
850.222.2300  
850.222.8410 Fax  
www.steelhector.com

Charles A. Guyton  
850.222.3423

July 16, 2002

RECEIVED FPSC  
02 JUL 16 PM 4:09  
COMMISSION  
CLERK

**-VIA HAND DELIVERY-**

Ms. Blanca S. Bayó  
Division of the Commission Clerk  
and Administrative Services  
Florida Public Service Commission  
2540 Shumard Oak Blvd.  
Tallahassee, FL 32399-0850

Re: Docket Nos. 020262-EI and 020263-EI

Dear Ms. Bayó:

On March 22, 2002, Florida Power & Light Company ("FPL") filed a Petition for Determination of Need for an Electrical Power Plant - Martin Unit 8 and a Petition for Determination of Need for an Electrical Power Plant - Manatee Unit 3. FPL's two petitions were assigned Docket Nos. 020262-EI and 020263-EI, respectively.

On April 22, 2002, FPL moved to hold both proceedings in abeyance to allow FPL to undertake a Supplemental Request for Proposals (Supplemental RFP). On April 29, 2002, FPL filed an emergency motion for waiver of Rule 25-22.080(2), F.A.C., to allow deferral of the hearing schedule if, as a result of the Supplemental RFP, Martin Unit 8 and Manatee Unit 3 were determined to be the most cost-effective alternatives to meet FPL's 2005 and 2006 need. By Order No. PSC-02-0571-PCO-EI, Commissioner Deason, acting as prehearing officer, substantially granted FPL's emergency motion to hold both proceedings in abeyance, and by Order No. PSC-02-0703-PCO-EI, the Commission granted FPL's emergency waiver of Rule 25-22.080(2).

- AUS \_\_\_\_\_
- CAF \_\_\_\_\_
- CMP \_\_\_\_\_
- COM 5 + orig let
- CTR \_\_\_\_\_
- ECR 7
- GCL \_\_\_\_\_
- OFC \_\_\_\_\_
- MMS \_\_\_\_\_
- SEC \_\_\_\_\_
- OTH 1 to

FPL has completed its Supplemental RFP. FPL's analysis shows that Martin Unit 8 and Manatee Unit 3 are the most cost-effective options to meet FPL's 2005 and 2006 need for capacity. Consequently, FPL is now prepared, consistent with Order Nos. PSC-02-0571-PCO-EI

RECEIVED & FILED

*MW*

FPSC BUREAU OF RECORDS

07384-02 thru 07400-0

*each file*

Miami

West Palm Beach

Tallahassee

Key West

London

Caracas

São Paulo

Rio de Janeiro

and PSC-02-0703-PCO-EI, for the Commission to proceed with its evaluation of the need for those two units in Docket Nos. 020262-EI and 020263-EI. The documents enclosed herewith, as described below, provide the information required for that evaluation.

Enclosed for filing on behalf of FPL in Docket Nos. 020262-EI and 020263-EI are the original and fifteen copies of:

- (1) FPL's Motion for Leave to Amend Petitions for Determination of Need
- (2) FPL's Amended Petition for Determination of Need for an Electrical Power Plant-Martin Unit 8
- (3) FPL's Amended Petition for Determination of Need for an Electrical Power Plant-Manatee Unit 3

Because the same analysis supported FPL's assessment of its 2005 and 2006 capacity needs and its determination that Martin Unit 8 and Manatee Unit 3 were the most cost-effective alternatives to meet the needs, FPL previously filed a motion to consolidate both dockets. Consistent with its motion to consolidate, FPL filed along with its original Need Determination petitions a single Need Study for Electrical Power Plant and a single set of Need Study Appendices, as well as a common set of testimony for both dockets. FPL continues to seek consolidation of these dockets for hearing.

In support of its amended Petitions for Determination of Need for Martin Unit 8 and Manatee Unit 3, FPL is filing the original and 15 copies of the following documents:

- (1) Need Study For Electrical Power Plant, 2005-2006
- (2) Need Study Appendices A - D
- (3) Need Study Appendices E - J
- (4) Need Study Appendices K - O
- (5) Direct Testimony of Dr. William E. Avera
- (6) Direct Testimony of C. Dennis Brandt
- (7) Direct Testimony of Moray P. Dewhurst
- (8) Direct Testimony of Leonardo E. Green
- (9) Direct Testimony of Rene Silva
- (10) Direct Testimony of Dr. Steven R. Sim

- (11) Direct Testimony of Donald R. Stillwagon
- (12) Direct Testimony of Alan S. Taylor
- (13) Direct Testimony of William L. Yeager
- (14) Direct Testimony of Gerard Yupp

These documents reflect the results of FPL's Supplemental RFP and supercede the Need Study and Appendices and its Direct Testimony filed on March 22, 2002, in support of its initial Petitions for Determination of Need. Therefore, FPL hereby withdraws the March 22 Need Study and Appendices and the March 22 Direct Testimony.

Copies of the enclosed documents, are being provided to counsel for all parties of record. Under separate cover letter, FPL is filing its confidential appendices to the Need Study and a Request for Confidential Classification for the confidential appendices.


With the interruption of these proceedings for the Supplemental RFP, it is important that FPL's need determination proceedings be heard expeditiously. Prior to the Commission's granting of FPL's Emergency Motion To Hold The Proceedings In Abeyance, the parties had agreed to a schedule that would result in a hearing on October 2-4, 2002, a Commission decision on November 19, 2002, and a final order no later than December 4, 2002. FPL needs to preserve this schedule in order to meet its scheduled in-service date of June 2005 for both Martin Unit 8 and Manatee Unit 3. To facilitate this schedule, FPL has: (a) included more detailed data in the enclosed Need Study and Appendices than is required by Commission rule; (b) filed its direct testimony along with its amended petitions; (c) worked out with the intervenors free access to the primary analytical tools used in conducting the economic analysis of the Supplemental RFP; (d) agreed to a Confidentiality Agreement and process to allow intervenor access to most confidential data; and (e) agreed to expedited discovery. FPL will continue to work with the Commission and the parties to facilitate the Commission's prompt consideration of these proceedings.

Any delay in these proceedings would place at risk the in-service dates of Martin Unit 8 and Manatee Unit 3. In the event of delay, FPL would not achieve its 20 percent reserve margin criteria (or even a 15 percent reserve margin) in the summer of 2005. Without purchases of capacity to replace these facilities, an option which may not be available for the full capacity of these units, the reliability of FPL's system could be significantly adversely impacted to the detriment of FPL's customers. In the event of a delay, if FPL were to attempt to purchase capacity and energy to replace these units, FPL likely would pay higher costs than the costs it would incur if these units had met their in-service dates. Thus, delay also would adversely impact the costs paid by FPL's customers.

Because a delay would cause adverse impacts upon FPL's customers, FPL respectfully requests that these proceedings be processed according to the previously agreed schedule and that an Order on Procedure be issued. Such an order should place reasonable limits on discovery, encourage intervenors to coordinate discovery as they have previously agreed to do,

expedite discovery as previously agreed and set forth the agreed-to schedule, thereby facilitating the administration of these proceedings.

Respectfully submitted,

  
\_\_\_\_\_  
R. Wade Litchfield  
Charles A. Guyton

Attorneys for Florida Power  
& Light Company

CAG/gc  
Enclosures

cc: Counsel for Parties of Record

MIA2001 122447v1

**BEFORE THE FLORIDA  
PUBLIC SERVICE COMMISSION**

**DOCKET NOS. 020262-EI, 020263-EI  
FLORIDA POWER & LIGHT COMPANY**

**JULY 16, 2002**

**IN RE: PETITION FOR DETERMINATION OF NEED FOR  
PROPOSED ELECTRICAL POWER PLANT  
IN MARTIN COUNTY  
OF FLORIDA POWER & LIGHT COMPANY**

**IN RE: PETITION FOR DETERMINATION OF NEED FOR  
PROPOSED ELECTRICAL POWER PLANT  
IN MANATEE COUNTY  
OF FLORIDA POWER & LIGHT COMPANY**

**DIRECT TESTIMONY & EXHIBITS OF:**

**WILLIAM L. YEAGER**

DOCUMENT NUMBER-DATE

**07399 JUL 16 02**

1                   **BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION**

2                   **FLORIDA POWER & LIGHT COMPANY**

3                   **DIRECT TESTIMONY OF WILLIAM L. YEAGER**

4                   **DOCKET NOS. 020262-EI, 020263-EI**

5                   **JULY 16, 2002**

6  
7           **Q.    Please state your name and business address.**

8           A.    My name is William L. Yeager. My business address is Florida Power &  
9           Light Company, Power Generation Division, 700 Universe Boulevard, Juno  
10          Beach, Florida, 33408-0420.

11  
12          **Q.    By whom are you employed and what is your position?**

13          A.    I am employed by Florida Power & Light Company ("FPL" or the  
14          "Company") as General Manager of Florida Projects.

15  
16          **Q.    Please describe your duties and responsibilities in that position.**

17          A.    I am responsible for the overall management and direction of licensing,  
18          engineering, procurement, construction and start-up activities associated with  
19          new supply-side generation projects for the Company. This includes the  
20          proposed Martin Unit 8 and Manatee Unit 3 combined cycle generation  
21          projects.

22  
23          **Q.    Please describe your educational background and business experience.**

24          A.    I received a Bachelor of Mechanical Engineering from the Georgia Institute of

1 Technology in 1982. I am a registered professional Engineer in the State of  
2 Florida and a member of the American Society of Mechanical Engineers.

3  
4 I began my career as a mechanical engineer with FPL in 1982. In 1987, I was  
5 lead engineer for the preliminary engineering phase of Lauderdale Units 4&5,  
6 two 400 MW combined cycle repowered units that came on line in 1992.

7  
8 From 1988 to 1991, I was the Project Engineering Manager for FPL's Martin  
9 Units 3&4, two 400 MW combined cycle capacity additions. This project is  
10 noteworthy in the history of power generation because the four General  
11 Electric (GE) Model 7221 combustion turbines were the first to utilize the  
12 DLN2 dry low NO<sub>x</sub> combustion system. The project overcame significant  
13 issues associated with this first of a kind installation – exceeding all  
14 performance and reliability targets and finishing under budget and on  
15 schedule.

16  
17 Following completion of Martin Units 3&4, I spent the next four years in  
18 various management capacities at the FPL Martin Plant site, increasing my  
19 operational knowledge of combined cycle and conventional oil/gas-fired  
20 power plants. I then spent two years as Operations Manager for ESI (now  
21 FPL Energy), an unregulated affiliate of FPL, and two years as FPL's  
22 Manager of Combustion Turbines. From 1999 through 2001, I was Plant  
23 General Manager of FPL's Manatee Plant.

1       **Q.    What is the purpose of your testimony in this proceeding?**

2       A.    I describe the site and unit characteristics for the combined cycle power plants  
3           proposed for FPL’s Martin and Manatee plant sites, including the size,  
4           number and types of units, their heat rates and operating characteristics (i.e.,  
5           equivalent availability factor, equivalent forced outage rate, capacity factor,  
6           and operating costs), the fuel types, the estimated cost of each installation, and  
7           the projected in-service dates. I discuss FPL’s experience with building and  
8           operating combined cycle generating plants and demonstrate that the  
9           assumptions made for the Martin and Manatee projects are reasonable and  
10          achievable.

11  
12       **Q.    Are you sponsoring an exhibit in this case?**

13       A.    Yes. It consists of the following documents:

- |    |                |  |
|----|----------------|--|
| 14 | Document WLY-1 | Typical 4x1 CC Unit Process Diagram              |
| 15 | Document WLY-2 | FPL Operational Combined Cycle Plants & FPL      |
| 16 |                | Combined Cycle Construction Projects In Progress |
| 17 | Document WLY-3 | Martin Plant Vicinity Map                        |
| 18 | Document WLY-4 | Martin Unit 8 Project Boundary                   |
| 19 | Document WLY-5 | Martin Unit 8 Typical Power Block Area           |
| 20 | Document WLY-6 | Martin Unit 8 Fact Sheet                         |
| 21 | Document WLY-7 | Overall Water Balance for the Martin Site        |
| 22 | Document WLY-8 | Martin Unit 8 / Manatee Unit 3 Expected          |
| 23 |                | Construction Schedule                            |



- 1 Document WLY-9 Martin Unit 8 / Manatee Unit 3 Construction Cost
- 2 Components
- 3 Document WLY-10 Manatee Plant Vicinity Map
- 4 Document WLY-11 Manatee Unit 3 Project Boundary
- 5 Document WLY-12 Manatee Unit 3 Typical Power Block Area
- 6 Document WLY-13 Manatee Unit 3 Fact Sheet
- 7 Document WLY-14 Overall Water Balance for the Manatee Site

8

9 **Q. Are you sponsoring any part of the Need Study for this proceeding?**

10 A. Yes. I sponsor Appendix L, and co-sponsor Sections III and VIII of the Need

11 Study.

12

13 **I. Overview of Combined Cycle Technology**

14

15 **A. Description of Technology**

16

17 **Q. Would you please describe the combined cycle technology that will be**

18 **used for the Martin and Manatee Projects?**

19 A. Referring to Document WLY-1, a combined cycle unit is a hybrid of

20 combustion turbines (CTs), heat recovery steam generators (HRSGs), and a

21 steam-driven turbine generator (STG). Each of the combustion turbines

22 compress outside air into a combustion area where fuel, typically natural gas

23 or light oil, is burned. The hot gases from the burning fuel air mixture drive a

1 turbine, which, in turn, directly rotates a generator to produce electricity. The  
2 exhaust gas produced by each turbine, which is on the order of 1,100°F, is  
3 passed through a HRSG, before exiting the stack at approximately 200°F. The  
4 energy extracted by the HRSG produces steam, which is used to drive a STG.  
5 The utilization of waste heat from the combustion turbines provides an overall  
6 plant efficiency that is much better than that of the CTs or the conventional  
7 STG alone.

8  
9 Each CT/HRSG combination is called a “train.” The number of CT/HRSG  
10 trains used establishes the general size of the STG. In the case of the  
11 proposed Martin Unit 8 and Manatee Unit 3, four CT/HRSG trains will be  
12 connected to one STG; hence the terminology “four on one” (4x1) combined  
13 cycle plant.

14  
15 **B. Operating Advantages**

16  
17 **Q. What level of operating efficiency is anticipated for the Martin and**  
18 **Manatee Projects?**

19 A. Each of the proposed FPL combined cycle units is based on the use of GE “F”  
20 Class advanced combustion turbines. The primary difference between these  
21 GE 7FA CTs and conventional CTs is their efficiency. This difference results  
22 from higher firing temperatures made possible by advances in design. FPL  
23 has selected designs based on advanced CTs because they are more

1 economical than conventional CTs at the capacity factors at which they are  
2 expected to operate on the FPL system.

3  
4 In general, combined cycle plants can be expected to achieve fuel conversion  
5 rates of less than 7,000 Btu/kWh, as opposed to values in the 10,000 Btu/kWh  
6 range for more conventional steam-electric generating units. This is a fuel  
7 efficiency improvement of about 30 percent. FPL anticipates that the new  
8 Martin and Manatee combined cycle units will achieve a full load base heat  
9 rate of 6,850 Btu/kWh (@ 75°F).

10  
11 **Q. Are there other operational advantages to combined cycle technology?**

12 A. Yes. Another advantage of the multi-train combined cycle arrangement is that  
13 it allows for greater flexibility in matching unit output to system operating  
14 characteristics over time. As designed, the proposed Martin Unit 8 and  
15 Manatee Unit 3 each can function as either a base load or intermediate unit as  
16 required by the Company's system.

17  
18 **C. FPL's History of Building and Operating Combined Cycle Plants**

19  
20 **Q. Does FPL have experience in building combined cycle plants?**

21 A. Yes, FPL has extensive experience in building combined cycle plants. FPL's  
22 first combined cycle plant (Putnam Units 1&2) went into service in 1976. As  
23 shown in Document WLY-2, FPL has already placed 4,717 MW (net summer)

1 of combined cycle capacity in service and the repowering of Sanford Unit 4 is  
2 scheduled to be complete by June 2003.

3

4 **Q. Please describe FPL's history of operating combined cycle plants.**

5 A. As I just mentioned, FPL has 4,717 MW (net summer) of combined-cycle  
6 equipment presently in-service, including 14 GE 7FA CTs. Our expertise with  
7 this equipment and our commitment to total operational quality enabled us to  
8 achieve an operating run of 203 consecutive days—a world record for F  
9 technology GE equipment at that time.

10

11 In addition to its combined cycle operating experience, FPL has extensive  
12 experience operating simple-cycle CTs, which comprise the “front end” of the  
13 combined cycle technology. FPL has operated eight GE 7FA CTs in simple-  
14 cycle mode at its Fort Myers and Martin plant sites in Florida. FPL also has  
15 been operating 48 smaller simple-cycle units for approximately 30 years.

16

17 **Q. Please characterize FPL's track record in building and operating  
18 combined cycle units.**

19 A. FPL has consistently completed all combined cycle construction projects in  
20 time to supply the needs of the customer. This is commendable, given the  
21 complexities that are inherent in the design and construction of the repowering  
22 projects that I just mentioned.

1 In meeting our obligation to serve, we have also demonstrated our ability to  
2 construct reliable and efficient plants. For example, in 1994 we began  
3 commercial operation of two new combined cycle units at our Martin plant  
4 and, just two years later, were awarded *Power* magazine's Power Plant of the  
5 Year Award for world-class performance in O&M and availability. In  
6 addition, this plant has excellent environmental characteristics.

7  
8 To ensure ongoing best-in-class performance in today's highly competitive  
9 electricity generating industry, FPL focuses on excellence in people,  
10 technology and business and operating processes.

11  
12 FPL promotes a shift team concept in its power plants that emphasizes  
13 empowerment, engagement and accountability, with an understanding that  
14 each employee has the necessary knowledge, skill and motivation to perform  
15 any required task. This multifunctional, team-driven and well-trained  
16 workforce is the key to our ability to consistently meet and often exceed plant  
17 performance objectives.

18  
19 With world-class operational skills upon which to draw, we maximize the  
20 value of our growing assets by utilizing the best practices that underlie FPL's  
21 industry-leading positions. Our fossil-fueled fleet reached an all-time high of  
22 90% availability in 2000 and 2001, ranking well above the 2000 industry  
23 average of 84% and placing FPL among the nation's best performers.

1       **Q.    Please describe how FPL monitors the operational performance of its**  
2       **power plants.**

3       A.    Technology is also helping us optimize plant operations, gain process  
4       efficiencies and leverage the deployment of technical skills as demand for  
5       services increases.  An example is our Fleet Performance and Diagnostics  
6       Center (FPDC) in Juno Beach, Florida.  The FPDC gives us the capability to  
7       monitor every fossil-fueled plant in the FPL system.  We can compare the  
8       performance of like components on similar generating units, determine how  
9       we can make improvements and prevent problems before they occur.  Live  
10      video links can be established between the FPDC and plant control rooms to  
11      immediately discuss, prevent and solve problems.  Last year, FPL was  
12      presented with an Industry Excellence Award from the Southeast Electric  
13      Exchange for the FPDC.  The proposed Martin Unit 8 and Manatee Unit 3  
14      combined cycle projects will be connected to the FPDC.

15  
16      **II.   Martin Combined Cycle Project**

17  
18      **A.   Site Description**

19  
20      **Q.    Please describe the existing facilities at the Martin Plant site.**

21      A.    The Martin Plant has reliably supplied electric power to FPL's customers  
22      since 1980, when Unit 1 began operation.  The Martin Plant site occupies

1 11,300 acres near Indiantown, Florida. A vicinity map of the Martin Plant site  
2 is presented on Document WLY-3.

3  
4 The generating capacity of the Martin Plant has increased over the years  
5 through the addition of new units to meet increasing demand for electricity.  
6 Generating units at the Martin Plant site (and their current net peak summer  
7 capacity) presently include: Units 1 (814 MW) and 2 (799 MW), which are  
8 residual oil/natural gas-fired steam units; Units 3 and 4 (natural gas-fired  
9 combined cycle units, with a peak summer capability of 467 MW and 468  
10 MW, respectively) and Units 8A and 8B (natural gas-fired/light oil, simple  
11 cycle combustion turbines, each with a peak summer capability of 159 MW).  
12 The Martin Plant site currently has a total summer net generating capability of  
13 approximately 2,846 MW. The site includes a 6,800-acre cooling pond that  
14 serves Units 1, 2, 3, and 4.

15  
16 **Q. Has the Martin Plant site previously been identified for unit expansion?**

17 A. Yes. The Martin Plant site has long been identified as a possible site for  
18 additional generating capacity. When site certification for Units 3 and 4 was  
19 issued in 1991, the Governor and Cabinet, acting as the Siting Board, also  
20 recognized the Martin Plant site's suitability for further capacity expansions.  
21 The Martin Plant site has been identified as a preferred location for additional  
22 generating capacity in each of FPL's Ten Year Power Plant Site Plans for the  
23 past decade.

1       **Q.     Please discuss the proposed location of Martin Unit 8 relative to the**  
2       **existing units on-site.**

3       A.     The project boundary for the Martin Unit 8 project is shown on Document  
4       WLY-4. The portion of the Martin Plant site that will be occupied by  
5       temporary and permanent project facilities comprises approximately 44 acres  
6       within the defined project area of approximately 110 acres. The entire project  
7       area is within the existing certified portion of the site. Existing Units 1, 2, 3,  
8       and 4 will remain in operation and will not be impacted by the project.

9  
10       The location of the new combined cycle Unit 8 at the existing Martin Plant  
11       site and the selection of the combined cycle technology will maximize the  
12       beneficial use of the site while minimizing environmental, land use, and cost  
13       impacts otherwise associated with development of a large power plant. The  
14       Project will utilize a number of existing facilities, while increasing the  
15       generating capacity of the site without increasing the overall size of the site.

16  
17       **B.     Martin Unit 8 Project**

18  
19       **Q.     Please describe the proposed Martin Unit 8 project in more detail.**

20       A.     The project involves converting the existing Units 8A and 8B CTs from  
21       simple cycle to combined cycle and the construction of two new CTs  
22       designated 8C and 8D. The unit's general arrangement resulting from this  
23       marriage of new and existing CTs is shown on Document WLY-5.



1 Unit 8 will be a 4x1 combined cycle unit consisting of four 159-MW GE "F"  
2 Class advanced CTs, with dry low-NO<sub>x</sub> combustors and four HRSGs, which  
3 will use the waste heat from the CTs to produce steam to be utilized in a new  
4 steam turbine generator. By utilizing the otherwise wasted heat from the CTs  
5 in four new HRSGs, the resulting combined cycle unit will be much more  
6 efficient than the existing Martin 8A & 8B simple cycle CTs.

7  
8 Each CT unit will utilize inlet air evaporative cooling. Direct inlet fogging  
9 systems achieve adiabatic cooling using water to form fine droplets (fog). The  
10 result of the fogging is a cooler, more moisture-laden air stream. This allows  
11 additional power to be produced more efficiently. For the GE Frame 7FA CT,  
12 an 8°F average decrease in temperature would result in a 3.0 percent increase  
13 in power and an associated 1.2 percent decrease in heat rate. Thus, while  
14 power increases, the production of power is more efficient with lower  
15 emissions per MWh generated.

16  
17 The inlet foggers would normally be utilized when the ambient air  
18 temperature is greater than 60°F. Since the average annual temperature for  
19 the Martin site is approximately 75°F, the output and heat rate benefits of  
20 fogger operation are included in the base rating of 984 MW (net summer) for  
21 Martin Unit 8.

22  
23 Duct burners are also proposed for each HRSG. The duct burners can be fired

1 during peak demand periods to add an additional 96 MW of capacity to the  
2 unit at an incremental heat rate of 8,770 Btu/kWh.

3  
4 An additional 27 MW of output can also be achieved by raising the fuel flow  
5 to the CT for “peak firing mode” operation. Peak firing reduces the heat rate  
6 of the entire unit and the expected incremental heat rate for peak firing is  
7 5,600 Btu/kWh. However, peak firing will shorten the normal replacement  
8 period for some CT components, so it will normally be reserved for peak need  
9 periods and not routinely dispatched ahead of duct firing - even though the  
10 incremental heat rate for this mode of operation is less than the incremental  
11 heat rate for all forms of fossil power generation.

12  
13 Martin Unit 8, with a summer generating capacity of approximately 1,107  
14 MW (net) from the base operation, duct burning, and peak firing capabilities  
15 described above, will be among the most efficient electric generators in  
16 Florida. It will result in a summer net increase of approximately 789 MW in  
17 the Martin Plant site’s capacity after accounting for the 318 MW already  
18 being provided by CT Units 8A and 8B. The expected operating  
19 characteristics of Martin Unit 8 are shown in Document WLY-6.

20  
21 **Q. Please describe the potential air emissions of the Martin Unit 8 project.**

22 A. Protecting the environment while providing safe, reliable and adequate power  
23 to customers is of great importance to FPL. FPL’s Martin Plant will continue

1 to comply with all applicable regulatory standards through construction and  
2 operation of Martin Unit 8.

3  
4 The project will have lower overall impacts than were previously reviewed  
5 and found acceptable in the 1991 “ultimate site capacity” certification for the  
6 Martin Plant site. The use of clean fuels and combustion controls will  
7 minimize air emissions from Martin Unit 8 and ensure compliance with  
8 applicable emission-limiting standards. Using clean fuels minimizes  
9 emissions of sulfur dioxide, particulate matter and other fuel-bound  
10 contaminants. Combustion controls similarly minimize the formation of  
11 nitrogen oxides (NO<sub>x</sub>) and the combustor design will similarly limit the  
12 formation of carbon monoxide and volatile organic compounds. When firing  
13 natural gas, NO<sub>x</sub> emissions will be controlled using dry low-NO<sub>x</sub> combustion  
14 technology and selective catalytic reduction (SCR), which will limit NO<sub>x</sub>  
15 emissions to 2.5 parts per million volume dry (ppmvd) (@ 15% O<sub>2</sub> on natural  
16 gas). Water injection and SCR will be used to reduce NO<sub>x</sub> emissions during  
17 CC operation when firing light oil. These design alternatives maximize  
18 control of air emissions while balancing economic, environmental, and energy  
19 impacts, consistent with regulatory requirements for emission rates reflecting  
20 use of the “best available control technology.” Taken together, the design of  
21 Martin Unit 8 will incorporate features that will make it one of the most  
22 efficient and clean power plants in Florida.

1       **C.     Fuel Types**

2

3       **Q.     What types of fuel will Martin Unit 8 be capable of using?**

4       A.     The project will be capable of using two fuel types: natural gas and light oil.  
5             The testimony of Mr. Gerard Yupp provides the details for the transportation  
6             alternatives to supply the proposed Martin Unit 8 with fuel.

7

8       **D.     Water Supply – Access and Availability**

9

10      **Q.     What are the water requirements for the Martin Unit 8 project and how**  
11      **will they be met?**

12      A.     The overall water balance for the Martin site is shown on Document WLY-7.  
13             Primary water uses for Martin Unit 8 will be for condenser cooling,  
14             combustion turbine inlet foggers, steam cycle makeup and service water.  
15             Water also will be used on a limited basis for NO<sub>x</sub> control when using light  
16             oil. Condenser cooling for the steam cycle portion of Unit 8 will be  
17             accomplished with water from the existing cooling pond. Service and process  
18             water for the project will come from the cooling pond. Make up water to the  
19             pond will continue to come from the St. Lucie Canal in accordance with the  
20             current South Florida Water Management District consumptive use allocation  
21             for the site.

1       **E.     Electric Transmission Interconnection Facilities**

2

3       **Q.     How will the Martin Unit 8 project be interconnected to FPL's**  
4       **transmission network?**

5       A.     The electricity generated by Martin Unit 8 will interconnect with FPL's  
6       existing transmission network at the Martin site's existing system substation.

7

8       **F.     Proposed Construction Schedule**

9

10      **Q.     What is the proposed construction schedule for the Martin Unit 8**  
11      **project?**

12      A.     A summary of construction milestone dates is shown on Document WLY-8.  
13      FPL will begin construction upon receipt of the necessary federal and state  
14      certifications and permits. The expected construction duration for the Martin  
15      Unit 8 project is 24 months, based on our experience constructing Martin  
16      Units 3&4 and the rate of progress for our current construction projects at our  
17      Fort Myers and Sanford plants. Therefore, with a planned in-service date of  
18      June 2005 to help meet FPL's load requirements, FPL anticipates that  
19      construction must commence on or before June 1, 2003.

20

21      **Q.     What is the current status of the certifications and permits required to**  
22      **begin construction of Martin Unit 8?**

1 A. As of July 10, 2002, the Martin 8 site certification application has been  
2 deemed sufficient by the Florida Department of Environmental Protection  
3 (FDEP). The state-mandated land use hearing for the project was held and the  
4 Administrative Law Judge has forwarded a favorable Recommended Order to  
5 the Governor and Cabinet for review and approval.

6

7 **G. Estimated Construction Costs**

8

9 **Q. What does FPL estimate that the Martin Unit 8 will cost?**

10 A. In the economic analysis, the expected installed cost for the Martin Unit 8 is  
11 \$439 million (2005 dollars), exclusive of transmission integration. This cost  
12 includes \$389 million for the power block, \$7 million for the transmission  
13 interconnection, and \$43 million in allowances for funds used during  
14 construction (AFUDC) to an in-service date of June 2005. The components of  
15 the total plant cost are shown in Document WLY-9.

16

17 **Q. Are these estimated costs for Martin Unit 8 consistent with the estimated  
18 costs in the 2002 Supplemental Request for Proposals (Supplemental  
19 RFP)?**

20 A. Yes, these plant costs are consistent with FPL's estimates in Table VI-1 of the  
21 Supplemental RFP.

1       **III. Manatee Combined Cycle Expansion Project**

2

3       **A. Site Description**

4

5       **Q. Please describe the existing facilities at the Manatee Plant site.**

6       A. As shown on Document WLY-10, the Manatee Plant is located in Manatee  
7       County, just east of Parrish, Florida. The plant was originally constructed in  
8       the mid-1970s, with the commercial in-service dates for Units 1 and 2 in  
9       October 1976 and December 1977, respectively.

10

11       The peak summer capacity (net) of the existing units are as follows:

- 12               • Unit 1 – 809 MW (peak summer capacity)  
13                       - Steam electric generating unit firing residual oil
- 14               • Unit 2 – 810 MW (peak summer capacity)  
15                       - Steam electric generating unit firing residual oil

16

17       **Q. Is the Manatee site suitable for the Manatee Unit 3 project?**

18       A. Yes. The location of the new combined cycle Unit 3 at the existing Manatee  
19       Plant site and the selection of the combined cycle technology will maximize  
20       the beneficial use of the site while minimizing environmental, land use, and  
21       cost impacts otherwise associated with development of a large power plant.  
22       The new CTs and associated HRSGs will be located in an area that has  
23       already been affected by existing uses at the plant. The project will utilize a

1 number of existing facilities, while increasing the generating capacity of the  
2 site without increasing the overall size of the site.

3  
4 **B. Manatee Unit 3 Project**

5  
6 **Q. Please describe the Manatee Unit 3 project in more detail.**

7 A. The project will be located west of the existing Units 1 and 2 on the existing  
8 9,500-acre Manatee Plant site. Document WLY-11 presents the boundary of  
9 the project area, which comprises approximately 73 acres. The new CTs and  
10 associated HRSGs will be located in an area that has already been affected by  
11 existing uses at the plant.

12  
13 The proposed Manatee Unit 3 will be a 4x1 combined cycle unit consisting of  
14 four 159-MW GE "F" Class advanced CTs, with dry low-NO<sub>x</sub> combustors and  
15 four HRSGs, which will use the waste heat from the CTs to produce steam to  
16 be used in a new steam turbine generator. The proposed power block  
17 arrangement is shown on Document WLY-12.

18  
19 Like Martin Unit 8, the inlets of each combustion turbine will be outfitted  
20 with an evaporative cooling (fogging) system. Based on the average annual  
21 temperature for the Manatee site, the output and heat rate benefits associated  
22 with fogger operation are included in the base rating of 984 MW (net summer)  
23 for Manatee Unit 3.



1 Duct burners are also proposed for each HRSG. The duct burners can be fired  
2 during peak demand periods to add an additional 96 MW of capacity to the  
3 base unit at an incremental heat rate of 8,770 Btu/kWh.

4  
5 An additional 27 MW can also be achieved by raising the fuel flow to the CT  
6 for “peak firing mode” operation. Since peak firing reduces the heat rate of the  
7 entire unit, the expected incremental heat rate for peak firing is 5,600  
8 Btu/kWh. However, peak firing will shorten the normal replacement period  
9 for some CT components, so it will normally be reserved for peak need  
10 periods and not routinely dispatched ahead of duct firing.

11  
12 Manatee Unit 3 will have a total peak summer generating capacity of  
13 1,107 MW (net) from the base operation, duct burning, and peak firing  
14 capabilities described above. The expected operating characteristics of  
15 Manatee Unit 3 are shown in Document WLY-13.

16  
17 **Q. Please describe the potential air emissions of the Manatee Unit 3 project.**

18 A. FPL’s Manatee Plant will continue to comply with all applicable regulatory  
19 standards through construction and operation of Manatee Unit 3.

20  
21 The use of natural gas and combustion controls will minimize air emissions  
22 and ensure compliance with applicable emission-limitation standards. Using  
23 natural gas minimizes emissions of sulfur dioxide, particulate matter and other

1 fuel-bound contaminants. Combustion controls similarly minimize the  
2 formation of NO<sub>x</sub> and the combustor design will similarly limit the formation  
3 of carbon monoxide and volatile organic compounds. NO<sub>x</sub> emissions will be  
4 controlled using dry low-NO<sub>x</sub> combustion technology and SCR, which will  
5 limit NO<sub>x</sub> emissions to 2.5 ppmvd (@ 15% O<sub>2</sub> on natural gas). The design of  
6 Manatee Unit 3 will incorporate features that will make it one of the most  
7 efficient and clean power plants in Florida.

8  
9 **C. Fuel Types**

10  
11 **Q. What types of fuel will Manatee Unit 3 be capable of using?**

12 A. The CTs and HRSG duct burners will be capable of using only natural gas.  
13 Please refer to the testimony of Mr. Gerard Yupp for discussion of the  
14 transportation alternatives to supply the proposed Martin Unit 8 with fuel.

15  
16 **D. Water Supply – Access and Availability**

17  
18 **Q. What are the water requirements for the Manatee Unit 8 project and how  
19 will they be met?**

20 A. The water supply for the Manatee project will be similar to that of the Martin  
21 project, in that water will be obtained from an existing 4,000-acre cooling  
22 pond. With make up water provided from the Little Manatee River, this  
23 cooling pond will continue to be the source of cooling, service and process

1 water for the Manatee Plant after the addition of Unit 3. Total site  
2 consumptive use will continue to be in accordance with the current Southwest  
3 Florida Water Management District water use agreement. The overall water  
4 balance for the Manatee Plant, including Unit 3, is shown in Document WLY-  
5 14.

6  
7 **E. Electric Transmission Interconnection Facilities**

8  
9 **Q. How will the Manatee Unit 3 project be interconnected to FPL's**  
10 **transmission network?**

11 A. The project will connect to the existing on-site system substation via a new tie  
12 line. The existing on-site system substation will be expanded to accommodate  
13 the new interconnection to FPL's electric transmission system.

14  
15 **F. Proposed Construction Schedule**

16  
17 **Q. What is the proposed construction schedule for the Manatee Unit 3**  
18 **project?**

19 A. Manatee Unit 3 will be a sister to Martin Unit 8, so the expected construction  
20 duration will also be 24 months. With a planned in-service date of June 2005  
21 to help meet FPL's load requirements, FPL anticipates that the Manatee Unit  
22 3 construction must commence on or before June 1, 2003. A summary of the  
23 construction milestone dates is shown on document WLY-8.

1       **Q.     What is the current status of the certifications and permits required to**  
2       **begin construction of Manatee Unit 3?**

3       A.     As of July 10, 2002, the Manatee Unit 3 site certification application has been  
4       deemed sufficient by the FDEP. Zoning and site plan approval requests have  
5       been filed with Manatee County in support of the state-mandated land use  
6       hearing. The Manatee County Planning Commission has recommended  
7       approval of the Rezoning, General Development Plan and Preliminary Site  
8       Plan.

9  
10      **G.     Estimated Construction Costs**

11  
12      **Q.     What does FPL estimate that Manatee Unit 3 will cost?**

13      A.     In the economic analysis, the expected installed cost for the proposed Manatee  
14      Unit 3 is \$551 million, exclusive of transmission integration. This cost  
15      includes \$482 million for the power block, \$10 million for the transmission  
16      interconnection, and \$59 million in allowances for funds used during  
17      construction (AFUDC) to an in-service date of June 2005. The components of  
18      the total plant cost are shown in Document WLY-9.

19  
20      **Q.     Are these estimated costs for the Manatee Unit 3 project consistent with**  
21      **the estimated costs in the 2002 Supplemental RFP?**

22      A.     Yes, these plant costs are consistent with FPL's estimates in Table VI-2 of the  
23      Supplemental RFP.

1       **IV.   Consequences of Delay**

2

3       **Q.   What consequences would be likely if the need determination for either**  
4       **project were delayed?**

5       A.   In order to achieve our reliability criteria for summer 2005, FPL has set an in-  
6       service date of June 2005 for both projects. Each project has a projected 24  
7       month construction schedule, which dictates that construction begin on or  
8       before June 1, 2003. Consistent with this schedule for commencing  
9       construction, FPL needs to receive a site certification for each project by the  
10      end of May 2003, with the air permit to be issued concurrently or shortly after  
11      site certification. This remains a realistic timetable for the site certification,  
12      but with less than one month between the expected date upon which all  
13      approvals would be received, and the actual date that construction must begin  
14      to support a June 2005 in-service date, it is imperative that the FDEP receive  
15      all agency reports (including the Commission's Need Determination) report in  
16      a timely matter. Based on FPL's experience with the FDEP site certification  
17      process, FPL asks the Commission to vote to issue affirmative Need  
18      Determinations by no later than November 19, 2002.

19

20      If the licensing of the project is delayed beyond June 1, 2003, FPL may not be  
21      able to meet its system reliability criteria in 2005. Also, the introduction of  
22      new low cost energy would be delayed to the detriment of FPL's customers.

1       **V. Conclusion**

2

3       **Q. What level of confidence does FPL have in the cost projections and**  
4       **construction schedules for the plants discussed herein?**

5       A. In establishing the construction schedule and capital cost estimates for these  
6       plants, FPL has drawn upon its design and construction experience in Florida.  
7       We are confident that our current design philosophy and construction  
8       processes will allow us to complete these power blocks and associated  
9       transmission interconnections on schedule and in accordance with the  
10       expected construction costs, which our analyses have shown to be the best  
11       alternatives for our customers.

12

13       **Q. Please summarize your testimony.**

14       A. FPL's Martin Unit 8 and Manatee Unit 3 projects will use highly efficient  
15       low-emission combined cycle technology, with which FPL has a great deal of  
16       experience building and operating. FPL is confident of the accuracy of our  
17       construction cost estimates and projected unit capabilities.

18

19       The Martin and Manatee sites are ideal locations for these projects because of  
20       the existing electric generating plant, gas transmission and electric  
21       transmission infrastructure, and minimal expected incremental environmental  
22       impacts compared to "greenfield" sites. There are no water supply, fuel


1 supply, transmission or other constraints that will interfere with FPL's ability  
2 to successfully construct and operate either facility.

3

4 **Q. Does this conclude your testimony?**

5 **A. Yes.**

TYPICAL 4X1 CC UNIT PROCESS DIAGRAM






**FPL OPERATIONAL COMBINED CYCLE POWER PLANTS**

Facility	Location	In-Service Year	Technology	Summer Capacity (MW)	Primary Fuel
Fort Myers Unit 2	FL	2002	6x2 combined cycle	1,473	Natural gas
Sanford Unit 5	FL	2002	4x1 combined cycle	957	Natural gas
Martin Unit 3	FL	1994	2x1 combined cycle	467	Natural gas
Martin Unit 4	FL	1994	2x1 combined cycle	468	Natural gas
Lauderdale Unit 4	FL	1993	2x1 combined cycle	425	Natural gas
Lauderdale Unit 5	FL	1993	2x1 combined cycle	429	Natural gas
Putnam Unit 1	FL	1976	2x1 combined cycle	249	Natural gas
Putnam Unit 2	FL	1976	2x1 combined cycle	249	Natural gas
<b>Total Combined Cycle Capacity - Summer (net) →</b>				<b>4,717</b>	


**FPL COMBINED CYCLE CONSTRUCTION PROJECTS IN PROGRESS**

Project	Technology	Summer Capacity (MW)	Primary Fuel
Sanford Unit 4 Repowering	4x1 combined cycle	957	Natural gas


MARTIN PLANT VICINITY MAP



**MARTIN UNIT 8 PROJECT BOUNDARY**



### MARTIN UNIT 8 TYPICAL POWER BLOCK AREA



**FPL**  
Martin Unit 8

## MARTIN UNIT 8 FACT SHEET

### Generation Technology - "Four on One" (4x1) Combined Cycle Configuration:

- Four (4) → GE 7FA Combustion Turbines w/ Inlet Foggers  
(Two currently on-site operating in simple-cycle mode)
- Four (4) → Heat Recovery Steam Generators with Duct Burners and Selective Catalytic Reduction System for NO<sub>x</sub> Control
- One (1) → Single-Reheat Steam Turbine

### Expected Plant Peak Capacity:

- Summer (95°F / 50% RH) 1,107 MW
- Winter (35°F / 60% RH) 1,197 MW

### Projected Unit Performance Data:

- Average Forced Outage Rate (EFOR) 1%
- Average Scheduled Maintenance Outages 1 wk/yr (2% POF)
- Average Equivalent Availability Factor (EAF) 97%
- Base Average Net Operating Heat Rate 6,850 Btu/kWh (HHV)  
@ 75°F / 60% RH
- Annual Fixed O&M – incremental (2001 dollars) \$1.87/kW-yr
- Variable O&M – excluding fuel (2001 dollars) \$0.037/MWh

### Fuel Type and Base Load Typical Usage @ 75°F:

- Primary Fuel Natural Gas
- Natural Gas Consumption 6,580,000 scf/hr
- Alternate Fuel Low Sulfur Light Oil
- Light Oil Consumption 60,000 gal/hr

### Expected Base Load Air Emissions Per Train @ 75°F: Natural Gas Light Oil

- |  |            |            |
|--|------------|------------|
| □ NO <sub>x</sub> ( @ 15% O <sub>2</sub> ) | 2.5 ppmvd  | 12 ppmvd   |
| □ CO                                       | 9 ppmvd    | 20 ppmvd   |
| □ PM <sub>10</sub>                         | 10.9 lb/hr | 36.2 lb/hr |
| □ SO <sub>2</sub>                          | 9.4 lb/hr  | 94.9 lb/hr |


### Water Balance:

- Total site consumptive use will continue to be within current SFWMD annual allocation
- Process wastewater recycled to cooling pond

### Linear Facilities:

- Two (2) FGT gas laterals currently supply Martin site; possibility of contracting with another transporter
- No light oil pipeline – light oil delivered to site by truck

**OVERALL WATER BALANCE FOR THE MARTIN SITE**



All Flows in gpm; Maximum Instantaneous Flows in Parentheses  
 Source: Black & Veatch, 2001; FPL, 2001; Foster Wheeler Environmental Corporation



**MARTIN UNIT 8 / MANATEE UNIT 3**

**EXPECTED CONSTRUCTION SCHEDULE**


	Begin	End
Initiate sequence of HRSG orders (LNTP)	Nov 02	Dec 02
Initiate sequence of combustion turbine orders (LNTP)	Nov 02	Dec 02
Issue LNTP for steam turbines		Nov 02
Receive approvals necessary to begin construction		May 03
Site Prep & Foundations	Jun 03	Jan 04
Balance of Plant	Aug 03	Dec 04
Erect HRSGs	Feb 04	
Erect CTs	Apr 04	
Erect steam turbines	Apr 04	
Start-Up	Jan 05	May 05
Commercial operation		Jun 05

**PLANT CONSTRUCTION COST COMPONENTS  
(2005 \$ MILLION)**


	<b>MARTIN</b>	<b>MANATEE</b>
Power Block	\$389	\$482
Transmission Interconnect	\$7	\$10
AFUDC (Excluding Transmission Integration)	\$43	\$59
Total Plant Cost (Excluding Transmission Integration)	\$439	\$551




MANATEE PLANT VICINITY MAP




### MANATEE UNIT 3 PROJECT BOUNDARY



Boundary of Manatee Expansion Project Area 

### MANATEE UNIT 3 TYPICAL POWER BLOCK AREA



**FPL**  
Manatee Unit 3



## MANATEE UNIT 3 FACT SHEET

### Generation Technology - "Four on One" (4x1) Combined Cycle Configuration:

- Four (4) → GE 7FA Combustion Turbines w/ Inlet Foggers
- Four (4) → Heat Recovery Steam Generators with Duct Burners and Selective Catalytic Reduction System for NO<sub>x</sub> Control
- One (1) → Single-Reheat Steam Turbine

### Expected Plant Peak Capacity:

- Summer (95°F / 50% RH) 1,107 MW
- Winter (35°F / 60% RH) 1,197 MW

### Projected Unit Performance Data:

- Average Forced Outage Rate (EFOR) 1%
- Average Scheduled Maintenance Outages 1 wk/yr (2% POF)
- Average Equivalent Availability Factor (EAF) 97%
- Base Average Net Operating Heat Rate 6,850 Btu/kWh (HHV)  
@ 75°F / 60% RH
- Annual Fixed O&M – incremental (2001 dollars) \$2.71/kW-yr
- Variable O&M – excluding fuel (2001 dollars) \$0.037/MWh

### Fuel Type and Base Load Typical Usage @ 75°F:

- Fuel Natural Gas
- Natural Gas Consumption 6,580,000 scf/hr

### Expected Base Load Air Emissions Per Train @ 75°F:

- NO<sub>x</sub> (@ 15% O<sub>2</sub>) 2.5 ppmvd
- CO 9 ppmvd
- PM<sub>10</sub> 10.9 lb/hr
- SO<sub>2</sub> 9.4 lb/hr


### Water Balance:

- Total site consumptive use will be within amounts currently allocated by SWFWMD
- Process wastewater recycled to cooling pond

### Linear Facilities:

- FPL has an agreement with Gulfstream Natural Gas Pipeline System (Gulfstream) to supply natural gas for the existing Manatee Plant Units 1 and 2, and a new lateral from the Gulfstream mainline into the Manatee site is planned for that purpose. Natural gas for Manatee Unit 3 may be supplied by this new lateral or from another gas supplier.

## OVERALL WATER BALANCE FOR THE MANATEE SITE



FPL Manatee Plant Water Management Plan

Source: Foster Wheeler, 2002.

