

STATE OF FLORIDA

COMMISSIONERS:

LILA A. JABER, CHAIRMAN  
J. TERRY DEASON  
BRAULIO L. BAEZ  
MICHAEL A. PALECKI  
RUDOLPH "RUDY" BRADLEY



OFFICE OF THE GENERAL COUNSEL  
HAROLD A. MCLEAN  
GENERAL COUNSEL  
(850) 413-6199

# Public Service Commission

August 23, 2002

Mr. Carroll Webb  
Joint Administrative Procedures Committee  
Room 120 Holland Building  
Tallahassee, FL 32399-1300

Dear Mr. Webb:

RE: Docket No. 000154-SU - Proposed Rule 25-30.432, F.A.C.,  
Flows to be Used for Wastewater Treatment Plant Used and  
Useful Calculations

Dear Mr. Webb:

The Commission has approved the adoption of Rule 25-30.432  
without changes.

We plan to file the rule for adoption on August 30, 2002.

Sincerely,


A handwritten signature in cursive script that reads "Christiana T. Moore".

Christiana T. Moore  
Senior Attorney

ADT30432.CTM

Enclosure

cc: Division of the Commission Clerk  
and Administrative Services



1        25-30.432 Wastewater Treatment Plant Used and Useful  
2 Calculations. The flow data to be used in the numerator of the  
3 equation for calculating the used and useful percentage of a  
4 wastewater treatment plant shall be the same period or basis  
5 (such as annual average daily flow, three-month average daily  
6 flow, maximum month average daily flow) as the period or basis  
7 stated for the permitted capacity on the most recent operating  
8 permit issued by the Florida Department of Environmental  
9 Protection (DEP). The DEP permitted capacity shall be used in  
10 the denominator of the equation. If there are differences  
11 between the capacities of the individual components of the  
12 wastewater treatment plant, the Commission may calculate a used  
13 and useful percentage for each individual component of the  
14 treatment plant using the actual capacity of the component in the  
15 denominator. In determining the used and useful amount, the  
16 Commission will also consider other factors such as the allowance  
17 for growth pursuant to section 367.081(2)(a)2., F.S.,  
18 infiltration and inflow, the extent to which the area served by  
19 the plant is built out, whether the permitted capacity differs  
20 from the design capacity, and whether flows have decreased due to  
21 conservation or a reduction in the number of customers. This  
22 rule does not apply to reuse projects pursuant to section  
23 367.0817(3), F.S., or investment for environmental compliance  
24 pursuant to 367.081(2)(a)2.c., F.S.

25 Specific Authority: 350.127(2), 367.121(1)(f), FS.

CODING: Words underlined are additions; words in ~~struck~~  
through type are deletions from existing law.

1 Law Implemented: 367.081(2), 367.0817(3), FS.

2 History: New\_\_\_\_\_.

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

CODING: Words underlined are additions; words in ~~struck through~~ type are deletions from existing law.