## STATE OF FLORIDA

Commissioners: Lila A. Jaber, Chairman J. Terry Deason Braulio L. Baez Rudolph "Rudy" Bradley Charles M. Davidson



TIMOTHY DEVLIN, DIRECTOR DIVISION OF ECONOMIC REGULATION (850)413-6900

## Hublic Service Commission

April 23, 2003

Mr. John L. O'Brien 32814 Crooked Oaks Lane, Lot K-45 Leesburg, FL 34748

Re: Docket No. 030236-WS - Application for Authority to Transfer the Facilities of Pennbrooke Utilities, Inc. and Certificate Nos. 466-W and 400-S in Lake County Florida to Utilities, Inc. of Pennbrooke.

Dear Mr. O'Brien:

We have received a response (copy attached) from Mr. Martin S. Friedman, attorney for Utilities, Inc. of Pennbrooke (Pennbrooke or utility), and we have spoken to Ms. Karen Milicic, inspector of the Pennbrooke's water facility for the Florida Department of Environmental Protection (DEP), at (407) 894-7555 Ext 2226. Mr. Friedman explained in his letter that utility hired the Florida Rural Water Association to do a flow test over a 24-hour period and concluded that the water pressure was satisfactory. Also, the utility has installed a new hydropneumatic tank at the water plant, increased the water flow rate and increased the water pressure by 5 pounds per square inch (psi). The utility believes that they are meeting all pressure and flow requirements, including fire flow.

Ms. Milicic has reviewed the DEP files to determine if they had received any low pressure complaints. Your complaint was the only one they have received regarding low pressure for Pennbrooke. No other complaints were on file. In addition, Ms. Milicic indicated during her last water plant inspection that the water pressure at the water treatment plant was sufficient and she had no reason to believe that the utility was providing less than the 20 psi as required by Rule 62-555.320(7), Florida Administrative Code. However, she suggested that if you believe you are receiving low water pressure to document the time of day and frequency, so that she can investigate the pressure concern. Her phone number is listed above.

80

**APR 28** 

386

Mr. John L. O'Brien Page 2 April 23, 2003

Again, thank you for your correspondence and I hope that this letter addresses your concerns. If you have any questions, please contact me at (850) 413-6999.

Sincerely,

Pulsod Dedoman

Richard P. Redemann, P.E. Utility Systems/Communications Engineer

 cc: Utilities, Inc. of Pennbrooke (Rasmussen, Flynn) Rose, Sundstrom & Bentley (Friedman) Pennbrooke Utilities, Inc. (Erickson) Florida Department of Environmental Protection (Milicic, Ansag) Division of Economic Regulation (Daniel, Johnson) Office of the General Counsel (Crosby) Division of the Commission Clerk & Administrative Services (Bayó)

C:\wp9\030236c2.rpr

DRIGII

## Rose. Sundstrom & Bentley, LLP

**2548 BLAIRSTONE PINES DRIVE** TALLAHASSEE, FLORIDA 32301

> (850) 877-6555 FAX (850) 656-4029 www.rsbattorneys.com

**REPLY TO ALTAMONTE SPRINGS** 

CENTRAL FLORIDA OFFICE 600 S. NORTH LAKE BLVD., SUITE 160 ALTAMONTE SPRINGS, FLORDA 32701 (407) 830-6331 Fax (407) 830-8522

MARTIN S. FRIEDMAN, P.A. VALERIE L. LORD, OF COUNSEL (LICENSED IN TEXAS ONLY)

April 18, 2003

Ms. Blanca Bayo **Commission Clerk and Administrative Services Director** Florida Public Service Commission 2540 Shumard Oak Boulevard Tallahassee, FL 32399

Docket No. 030236-WS; Utilities, Inc. of Pennbrooke's Application for Authority Re: to Transfer Facilities and Certificate Nos. 466-W and 400-S Our File No.: 30057.56

Dear Ms. Bayo:

The PSC Staff has asked that we file a response to the April 7, 2003, letter from John O'Brien to you in the above-referenced docket.

At the outset, I would point out that Mr. O'Brien states that he has suffered a low water pressure problem since as early as 1998. In the Utility's most recent Staff Assisted Rate Case, which concluded in Order No. PSC-01-1248-PAA-WS, the Commission addressed water pressure in its evaluation of quality of service. In doing so, the Commission stated as follows:

Our Staff engineers noted that the Utility's operator has the plant regulated to maintain average pressure of 55 PSI. Records on file at DEP do not indicate pressure problems and AUS contain no complaints of low pressure reported by customers. CAF CMP By all reports, it appears that the Utility currently supplies COM water above the 20 PSI minimum required by DEP. CTR ECR Mr. O'Brien has complained periodically to the Utility regarding his water GCL OPC pressure, and each time the pressure and flow were checked it has always been above MMS the minimum required by Code and is considered acceptable. The Utility even had the SEC Florida Rural Water Association do a flow test over a 24-hour period and concluded OTH

that the pressure was satisfactory.

CHRIS H. BENTLEY, P.A. ROBERT C. BRANNAN DAVID F. CHESTER F. MARSHALL DETERDING JOHN R. JENKINS, P.A. STEVEN T. MINDLIN, P.A. DAREN L. SHIPPY WILLIAM E. SUNDSTROM, P.A. DIANE D. TREMOR. P.A. JOHN L. WHARTON ROBERT M. C. ROSE, OF COUNSEL WAYNE L. SCHIEFELBEIN, OF COUNSEL

FPSC-COMMISSION CLERK

NT NUMBER - EATE

ε0

3604 APR21

Ms. Blanca Bayo April 18, 2003 Page 2

Mr. O'Brien lives on a cul-de-sac that is served by a 4" deadend water line. While his water pressure and flow does fluctuate depending upon the particular time of day, the pressure always remains above the minimum standard. The Utility has installed a new hydrotank at the water plant and increased the flow rate and pressure by 5 PSI coming out of the plant. Other residents on Mr. O'Brien's cul-de-sac have noticed an improvement, however, apparently, Mr. O'Brien is not satisfied.

The Utility meets all pressure and flow requirements, including those for fire flow. There is no further action which the Utility can take to appease Mr. O'Brien.

Very truly yours,

Endula

MARTIN S. FRIEDMAN For the Firm

MSF:dmp

cc: Mr. Arthur Erickson Mr. Steve Lubertozzi Mr. Don Rasmussen Mr. Patrick Flynn Ms. Alice Crosby Mr. Richard Redemann

ASO\Utilities\(56) Pennbrooke\\PSC Clerk 07.ltr