

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

In re: Fuel and Purchased Power)
Cost Recovery Clause with)
Generating Performance Incentive)
Factor)
_____)

050001EI

Docket No. 030001-EI

Filed: October 2, 2003

CONFIDENTIAL

DIRECT TESTIMONY

OF

WILLIAM M. ZAETZ

On Behalf of the Citizens of the State of Florida

Charles J. Beck
Interim Public Counsel

Office of Public Counsel
c/o the Florida Legislature
111 W. Madison Street
Room 812
Tallahassee, Florida 32399-1400

(850) 488-9330

Attorney for Florida's Citizens

PHS-10-05
DECLASSIFIED
CONFIDENTIAL

CONFIDENTIAL DN 09563-03
FILED BY OPC TO BE TREATED AS
CONFIDENTIAL PENDING RECEIPT OF
REQUEST FOR CONFIDENTIALITY FROM
COMPANY.

DOCUMENT NUMBER-DATE

09563 OCT-28

FPSC-COMMISSION CLEAR

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

**CONFIDENTIAL DIRECT TESTIMONY OF
WILLIAM M. ZAETZ
DOCKET NO. 030001-EI**

INTRODUCTION

Q. PLEASE STATE YOUR NAME, POSITION AND BUSINESS ADDRESS.

A. My name is William M. Zaetz. I am a Senior Consultant with the economic consulting firm of Snavely King Majoros O'Connor & Lee, Inc. ("Snavely King"). My business address is 1220 L Street, N.W., Suite 410, Washington, D.C. 20005.

Q. WHAT IS YOUR PROFESSIONAL BACKGROUND?

A. Prior to joining Snavely King in February of 2001, I was a boilermaker for 33 years with Union Local No. 193, headquartered in Baltimore, Maryland, rising eventually to the position of General Foreman. In the course of this career, I participated in or supervised the fabrication, installation, repair and dismantlement of boiler plant, fuel-handling equipment, and environmental abatement facilities in electric generating plants operated by both public utilities and private industrial and commercial enterprises. In the course of 180 separate projects, I participated in operations in most of the major power plants in Maryland, the District of Columbia, southern Delaware and northern Virginia.

DOCUMENT NUMBER-DATE
09563 OCT-28
FPSC-COMMISSION CLERK

1 After leaving the Boilermakers' Union, I worked as a consultant and expert
2 witness for the Department of Justice's Environmental Division in
3 connection with their Power Plant Initiative. My duties consisted of
4 analyzing and summarizing various "forced" and "scheduled" outage
5 reports and providing the attorneys with contact lists from my association
6 with the International Brotherhood of Boilermakers.

7

8 I joined Snavelly King in 2001. I have provided technical support and
9 advice in connection with that firm's analyses of steam generation facilities
10 and costs, principally in connection with depreciation proceedings.

11 **Q. WHAT IS YOUR EDUCATIONAL BACKGROUND?**

12 A. After resigning my commission from the U.S. Naval Academy in 1967, I
13 enrolled in the apprenticeship program of the International Brotherhood of
14 Boilermakers and also served in the Naval Reserves as a boilermaker. I
15 continued my education at Johns Hopkins University, Loyola College and
16 the University of Baltimore. In 1971, I received a Bachelor of Science
17 degree in Business Management from the University of Baltimore.

18 **Q. HAVE YOU ATTACHED A SUMMARY OF YOUR EXPERIENCE?**

19 A. Yes. Appendix A is a brief summary of my qualifications and experience.

20 **Q. FOR WHOM ARE YOU APPEARING IN THIS DOCKET?**

21 A. I am appearing on behalf of the Florida Office of Public Counsel ("OPC")

22 **Q. WHAT IS THE PURPOSE OF YOUR TESTIMONY?**

23 A. The OPC asked me to review and analyze Tampa Electric
24 Company's testimony, depositions and responses to data requests focusing
25 on the reason for the decision to retire Gannon units 1 through 4 earlier than

1 planned. In my testimony I will demonstrate that Tampa Electric's position
2 that the Gannon plant was closed in 2003 due to reliability and safety
3 reasons is not valid and not supported by factual evidence. I will
4 demonstrate that any of the perceived safety and reliability factors as stated
5 in witness Whale's testimony, (P-10, L 21-23) affecting Gannon were a
6 direct result of the Company's failure to maintain adequate preventative
7 maintenance.

8 **Q. ON WHAT INFORMATION IS YOUR TESTIMONY BASED?**

9 A. I will validate my findings by using 1) universally accepted "industry
10 standards" 2) my 33 years experience as a field construction boilermaker
11 and 3) Tampa Electric's testimony, depositions, interrogatories and
12 documents provided in the course of discovery.

13 **Q. FROM YOUR ANALYSIS OF THE DEPOSITIONS, DO YOU FEEL**
14 **THAT SAFETY OR RELIABILITY WAS A FACTOR IN THE**
15 **RETIREMENT DECISION?**

16 A. Absolutely not. I could relate to the verbiage used by plant general manager
17 Karen Sheffield when she stated: "Gannon was not very reliable. It was –
18 we had a lot of safety concerns, we had reliability concerns. It didn't make
19 any sense to us to spend a lot of money doing things to make it reliable
20 when we knew that the remaining life' whatever that might be – we
21 certainly knew it wasn't past December 31, 2004, so it just didn't make
22 good sense to us."

23

24 "We felt that those dollars could be spent in areas which would give us
25 better benefit for our dollars". (SHEFFIELD p.21 4-11) I was very
26 impressed with Ms. Sheffield's analysis of the labor costs and imaginative

1 contributions to cutting maintenance costs. I have to disagree, however,
2 that safety and reliability concerns led to the decision to retire the plants.

3 **Q. COULD A PLANT EVER BE RETIRED BECAUSE IT WAS**
4 **UNSAFE?**

5 A. I have never seen a plant retired because of safety issues. I've repaired
6 boilers after explosions. I've worked on older units that were full of
7 asbestos and had gas leaks that required you to wear protective gear as soon
8 as you enter the plant. In each case, the repair was made and the unit
9 returned to service. On page 22 of her deposition Karen Sheffield states:
10 "Our safety record was pretty good at both Gannon and Big Bend."

11 **Q. WHAT SAFETY CONCERNS DID YOUR RESEARCH REVEAL?**

12 A. I believe the biggest concern at Tampa Electric during this time frame was
13 budgetary. The Gannon Station safety budget went from \$86,200 in 2000
14 to \$355,160 in 2001 and \$336,320 in 2002. (Late filed Deposition exhibit
15 of Buddy Maye No. 2)

16 **Q. DO YOU KNOW WHAT CAUSED THIS INCREASE?**

17 A. Yes. Ms. Sheffield explains: "The Gannon units were not very reliable.
18 We were continually having forced outages due to many things. The ones
19 that stand out in my mind because they brought the units off quite often
20 were boiler leaks."

21 "We ran it seemed like all the time, continually, at reduced boiler header
22 pressures in order to keep the units on or to keep them from taking
23 themselves off. As far as safety is concerned, we had issues with casing
24 leaks. On several occasions we had carbon monoxide in the plant where
25 our employees worked and we had to shut down and take care of those
26 problems and bring them back up. And, you know, sometimes they would

1 reoccur and sometimes, you know, we would get the problem repaired and
2 move on. There were also issues with duct work lagging in the back end of
3 the plant that was loose.” (SHEFFIELD p. 39 3-17)

4 **Q. DOES HER STATEMENT SUGGEST A CAUSE AND EFFECT**
5 **SCENARIO?**

6 A. Yes it does. It also indicates that the carbon monoxide would be predictable
7 and that as an engineer, Ms. Sheffield followed the required precautions
8 (monitors, blood tests breathing equipment, etc.) that would prevent lost
9 time. She wanted to preserve that “pretty good safety record”.

10 **Q. WHAT IS THE BASIS FOR YOUR ASSUMPTION?**

11 A. The presence of carbon monoxide (CO) is an indication of incomplete
12 combustion. One of the reference books used for many years throughout
13 the industry is Babcock & Wilcox’s *STEAM*. On page 9-8 of the 40th
14 edition: “ For example, 1 lb. of carbon reacts with oxygen to produce about
15 14,100 BTU of heat. The reaction may occur in one step to form CO₂, or
16 under certain conditions, it may take two steps. In the multi-step process,
17 CO is first formed, producing only 3960 BTU per lb. of carbon. In the
18 second step, the CO joins with additional oxygen to form CO₂, releasing
19 10,140 BTU per pound of carbon. The total heat produced is again 14,100
20 BTU per pound of carbon.”

21 A few pages later in *STEAM* on page 9-18: “One of the most critical
22 parameters for attaining good combustion is excess air. Too little air can be
23 a source of excessive unburned combustibles and can be a safety hazard.”

24 As an engineer, Ms. Sheffield knew that by continually running the unit at
25 reduced head pressure, and not fixing the leaks that reduced the airflow, the
26 presence of carbon monoxide would have been inevitable. The timing of

1 this action would have been coincidental with the increase in the safety
2 budget.

3 **Q. WERE THE ISSUES YOU ARE DESCRIBING HERE STRICTLY**
4 **SAFETY ISSUES?**

5 A. There is no bright line between performance and safety. If you fail to
6 address obvious maintenance problems in a power plant you can quickly
7 create a safety problem as well as a reliability problem. However, until
8 Tampa Electric decided to move forward with the early retirement of
9 Gannon 1-4, there was no real indication that there were serious safety or
10 reliability issues affecting the plant.

11
12 Gannon was either safe or unsafe. As I stated earlier, I've never known a
13 plant to be shut down for safety reasons and the safety issue is always the
14 first consideration in an operational environment. However, if it was
15 determined at any point in time that the plant was unsafe, then Tampa
16 Electric was obligated to shut it down immediately. Whether you believe
17 that the company made a decision for early retirement in October or
18 February, if it was made because the plant was unsafe, then it should have
19 been shut down at that point. Instead, Gannon 1 and 2 were operated until
20 April and were restarted in May for a brief time.

21 **Q. BUT DIDN'T THE PLANT EXPERIENCE A FATAL ACCIDENT**
22 **DUE TO AN EXPLOSION PRIOR TO ITS EARLY SHUTDOWN?**

23 A. Yes. That's correct. On April 8, 1999, a worker at the Gannon Station
24 opened a cover on a generator that contained hydrogen, sparking an
25 explosion that could be heard 35 miles away. Three people died, and about
26 50 were injured in the blast. OSHA cited Tampa Electric for safety

1 violations and fined the company \$30,075. After this accident, the company
2 investigation revealed that it was a human error that caused the explosion.
3 In late 2000 the company introduced substantial new modifications into its
4 Hazardous Energy Control Program (Exhibit No.WMZ-2). Most
5 importantly, there does not appear to be any equipment factors relating to
6 the accident and, to my knowledge, no equipment was replaced as a result
7 of the new procedures. As you can see, safety is a huge issue in any steam
8 plant and if this plant was truly unsafe, then it should have been closed
9 immediately, without delay.

10
11 I have also reviewed the confidential documents furnished by Tampa
12 Electric, Bates Stamp 1428-2335 that contain all of the Gannon accident
13 reports since January 1, 2000. These records reveal the normal range of
14 incident and accident reports that are common for such a work environment,
15 including the ordinary sprains, contusions, etc that occur when employees
16 don't pay strict attention to what they are doing. The request for copies of
17 all OSHA violations at Gannon since January 1, 2000 reveals that there
18 were none. (Tampa Electric response to OPC's 2nd Request for Production
19 of Documents, No. 12.)

20
21 **Q. ARE THERE OTHER EXAMPLES THAT THE UNITS WERE**
22 **NEGLECTED?**

23 **A.** Yes. Karen Sheffield explains: "There was work that had not taken place
24 that was going to cause higher operating costs, bowl mill maintenance,
25 charging bowl mill maintenance, and burner maintenance." (SHEFFIELD
26 p.35 14-17) The mills she is referring to pulverize the coal for its optimum

1 combustion. The burners are self-explanatory. Again, these items affect
2 the total combustion and the amount of carbon monoxide that was escaping.

3 **Q. WOULDN'T REDUCED RELIABILITY BE A CAUSE TO RETIRE**
4 **THE UNITS?**

5 A. It probably would if all the preventative maintenance had been done and the
6 units were still failing. Tampa Electric repeatedly disregarded reliability as
7 an issue. When asked if he attempted to "factor in or quantify or address
8 considerations of safety, reliability and other operating considerations that
9 might preclude the units from running through the retirement date",
10 Financial Director Craig Cameron replied: "No. No. At this point what
11 we're doing is based on the consent decree that required the units to come
12 off at the end of 2004, we made an effort to establish what the O & M and
13 non-recoverable fuel would be as the units peeled off, but didn't consider to
14 do an analysis to try to build in the additional incremental impacts of safety
15 - performance, system demand."

16 Q. "Did you just assume that they would be run through that
17 September 2004 retirement date without considering anything
18 that could preclude them from running that long?"

19 A. "Yes." (CAMERON p. 31 17-25, p. 32 1-9)"

20 **Q. WHAT SHOULD HAVE BEEN DONE TO IMPROVE THE UNITS**
21 **RELIABILITY?**

22 A. Fix the tube leaks. There are various methods used, if the leak is small,
23 called a "weeper", pad welding can sometimes repair it. If the leak is larger
24 the repair might require the use of a "dutchman". When dutchmen are used,
25 the damaged portion of the tube is removed, and a new section of tube stock
26 is installed in its place. Sometimes the entire tube needs to be replaced. If

1 replaced. If the leaks were in a general area of the boiler (economizer,
2 superheaters, slope panels etc.), the entire section would be replaced during
3 the next scheduled outage.

4 If a contractor was brought in to fix the leaks, no matter how many,
5 when the repairs are made, the unit must pass the "hydrostatic" test that
6 requires the unit to hold one and one half times the operating pressure of
7 the unit. If this had done, the units would have been able to run at their
8 normal capacity. As previously stated by the TECO employees, they
9 weren't going to spend dollars on reliability issues.

10 **Q. DID THESE NEGLECTED UNITS STILL SATISFY THE**
11 **PERFORMANCE ISSUES RELATING TO THE RETIREMENT?**

12 **A.** There are four sources of data that stand out from a number of additional
13 indicators that demonstrate that despite the company's failure to spend
14 adequate maintenance dollars, its actual performance was not a valid reason
15 for the early shutdown. They are as follows:

16 1. The Gannon 2003 Business Plan (Exhibit No. WMZ-1), dated
17 November 15, 2002, shows that Gannon's unplanned outages declined in
18 2001 and again in 2002 from a high in year 2000 that was probably due to
19 the plant explosion. (Page 4, B.S. 1818)

20 2. The Net Capacity, described in this document as the Station maximum
21 dependable generation capabilities, shows that the projected "Net Capacity
22 at the beginning of 2003 is projected to be the same as last year and it is
23 1.1% below the 5 year average." (Page 6, B.S. 1820) Likewise the Net
24 Generation since 1998 in Megawat Hours (MWH) is 5599, 4963, 4355,
25 5085 and 4838. (Page 7, B.S. 1821)

1 3. The on-peak availability factor is basically flat since 1999, except for
2 year 2000, and the 2002 performance actually exceeded the 1999
3 performance (74.4% in 2002 versus 73.4% in 1999) (Page 9, B.S. 1823) It
4 should be noted that the Gannon performance during this time period was
5 achieved while the Gannon workforce was reduced from 287 to 235 in
6 2002, an 18% reduction (Page 20, B.S. 1834) Likewise, the company's
7 Capital investment shrank by 61% from 1997 until 2002. In fact, the total
8 capital investment in the plant during both 2001 and 2002 is less than the
9 company spent in 1997 (Page 24, B.S. 1838). So even though the company
10 was spending less money on the plant, and despite its age, its performance
11 was acceptable.

12
13 4. In reviewing the annual performance review of Plant Manager Maye, it
14 is clear that he was performing at or above most of his performance
15 objectives. In his deposition dated May 13, 2001, I noted the following
16 exchange between OPC and witness Maye, (Page 64, L9-17)

17 Q. "And so for all of our deferred maintenance and everything, the
18 Gannon units are trucking along pretty good, aren't they?"

19 A. "I..."

20 Q. "Would you agree with that?"

21 A. "Met expectations."

22
23 **Q. WHAT OTHER INDICATORS DID YOU OBSERVE SHOWING**
24 **THE PLANTS WERE OPERATING AS EXPECTED?**

25 A. The base case scenario as outlined on page 25, B.S. 1839, in KEY
26 STRATEGIES FOR 2003-GANNON WAS:

- 1 a. Shut down Unit 5 February, 2003
- 2 b. Shut down Units 1 and 2 on March 15, 2003
- 3 c. Run Units 3 and 4 until September 1, 2003 or until O & M
- 4 dollars are gone
- 5 d. Shut down Unit 6 September 1, 2003

6 Under the heading "Station Performance Issues" on page 28, B.S. 1842,
7 "Unit forced outage rates should not change from our current projections
8 since Units 3 and 4 will have spring outages and units 1 and 2 will be shut
9 down before the effects of not having their spring outages develop." It
10 appears that most of the goals for Gannon operations were either met or
11 exceeded based on the targets that were established for the plant.

12 **Q. TAMPA ELECTRIC WITNESS WHALE STATES IN HIS**
13 **TESTIMONY THAT IT WOULD TAKE \$57 MILLION TO KEEP**
14 **GANNON RUNNING. IS HIS TESTIMONY IN THIS REGARD**
15 **REALISTIC?**

16 **A.** Since there was no documentation provided in the testimony of Mr. Whale,
17 we are left only with the earlier documents prepared by Plant Manager
18 Maye for Mr. Whale that showed approximately \$53 million was needed to
19 achieve 85% availability at Gannon. One only needs to look at the Gannon
20 Business Plan to know that the plant has been operating over the past
21 several years between 60% and 75% availability. Even if a plant's
22 availability were less than what one would expect from a new plant, the
23 lower cost of generation could still make it attractive for continued use in
24 meeting the primary generation needs.

25 **Q. HOW WOULD THE EARLY SHUTDOWN OF GANNON REDUCE**
26 **THE OVERALL O&M EXPENSE FOR TAMPA ELECTRIC?**

1 A. Combined cycle gas generation is more costly than coal generation at the
2 present time because the fuel costs are at least twice the cost of coal
3 generation. However, in a state like Florida, where all of the fuel costs are
4 passed directly to the customers as a separate line item on their bill, these
5 higher fuel costs have nothing to do with the earnings of the company.
6 What does impact the company directly is the significant labor savings that
7 are achieved through gas generation as opposed to coal generation. These
8 labor savings will have the effect of improving Tampa Electric's earnings
9 while the customers pay significantly higher fuel costs. The actual amount
10 of the O&M savings is addressed in Mr. Majoros's testimony.

11 **Q. WHAT ARE YOUR CONCLUSIONS?**

12 A. The Company made a conscious decision to run the Gannon Station as long
13 as they could without spending any dollars to increase reliability or to make
14 them safer. The initial path was decided by the consent decree and each
15 decision thereafter was economic. Gannon's performance was predictable
16 and any side effects that resulted were dealt with by spending the least
17 amount of money possible.

18 **Q. DOES THIS CONCLUDE YOUR TESTIMONY?**

19 A. Yes it does.

20

Experience**Snavelly King Majoros O'Connor & Lee, Inc., Washington D.C.**

Senior Consultant (2000 to present)

Mr. Zaetz provides technical expertise in all of the firm's projects involving the engineering, costing, operation, valuation, depreciation and dismantlement of electric and gas facilities. Mr. Zaetz has assisted in several electric and gas depreciation studies.

Independent Consultant (2000-2001)

Mr. Zaetz provided consultation to the U.S. Department of Justice in connection with several units to enforce the nitrogen oxide ("NOX") abatement regulations of the Environmental Protection Agency. Mr. Zaetz reviewed engineering plans and work orders to determine the nature and objectives of modifications to the generation plants subject to the suit. He prepared summaries of his findings in anticipation of possible testimony before Federal Courts.

**Boilermaker Local 193
Severn, MD****General Foreman
Foreman (1973-2000)**

Mr. Zaetz supervised the fabrication, installation, repair and dismantlement of boiler plant, synthetic natural gas, fuel handling equipment, and environmental abatement facilities in electric generating plants operated by both public utilities and private industrial and commercial enterprises. In the course of 180 separate projects, Mr. Zaetz supervised operations in most of the major power plants throughout the Maryland, Northern Virginia and Southern Delaware area.

Shop Steward

Mr. Zaetz represented over 100 boilermakers in labor arbitrations, safety disputes and the implementation of Federal worker protection provisions.

Legislative Education Action Committee

Mr. Zaetz participated as committeeman and Chairman of the Education Committee in the Union's efforts to facilitate and enhance the technical training of its members.

Education

University of Baltimore: B.S. in Business Management

Boilermaker Apprentices Program

William M. Zaetz

Testimony

<u>Date</u>	<u>State</u>	<u>Docket</u>	<u>Utility</u>
2001	Georgia <u>1/</u>	14000-U	Georgia Power Company
2002	Florida <u>7/</u>	010949-EL	Gulf Power Company
Plant Tours			
<u>Date</u>	<u>State/Client Code</u>	<u>Docket</u>	<u>Utility</u>
2001	Kansas <u>2/ 3/ 4/</u>	01-WSRE-436-RTS	Kansas Power & Light
2001	Kansas <u>2/ 3/ 4/</u>	01-WSRE-436-RTS	Kansas Gas & Electric
2001	New Jersey <u>5/</u>	GR0105029	Public Service Electric & Gas
2001	Georgia <u>1/</u>	14000-U	Georgia Power Company
2001	Michigan <u>6/</u>	U-12999	Consumers Energy
2001	Florida <u>7/</u>	010949-EL	Gulf Power Company
2002	Nevada <u>8/</u>	01-11031	Sierra Pacific & Nevada Power
Clients			
<u>1/</u> Georgia Public Service Commission <u>2/</u> Kansas Citizens' Utility Rate Board <u>3/</u> Kansas Industrial Group <u>4/</u> City of Wichita <u>5/</u> New Jersey Rate Advocate <u>6/</u> Michigan Attorney General <u>7/</u> Florida Office of Public Counsel <u>8/</u> Nevada Bureau of Consumer Protection			

Experience**Snavely King Majoros O'Connor & Lee, Inc., Washington D.C.**

Senior Consultant (2000 to present)

Mr. Zaetz provides technical expertise in all of the firm's projects involving the engineering, costing, operation, valuation, depreciation and dismantlement of electric and gas facilities. Mr. Zaetz has assisted in several electric and gas depreciation studies.

Independent Consultant (2000-2001)

Mr. Zaetz provided consultation to the U.S. Department of Justice in connection with several units to enforce the nitrogen oxide ("NOX") abatement regulations of the Environmental Protection Agency. Mr. Zaetz reviewed engineering plans and work orders to determine the nature and objectives of modifications to the generation plants subject to the suit. He prepared summaries of his findings in anticipation of possible testimony before Federal Courts.

**Boilermaker Local 193
Severn, MD****General Foreman
Foreman (1973-2000)**

Mr. Zaetz supervised the fabrication, installation, repair and dismantlement of boiler plant, synthetic natural gas, fuel handling equipment, and environmental abatement facilities in electric generating plants operated by both public utilities and private industrial and commercial enterprises. In the course of 180 separate projects, Mr. Zaetz supervised operations in most of the major power plants throughout the Maryland, Northern Virginia and Southern Delaware area.

Shop Steward

Mr. Zaetz represented over 100 boilermakers in labor arbitrations, safety disputes and the implementation of Federal worker protection provisions.

Legislative Education Action Committee

Mr. Zaetz participated as committeeman and Chairman of the Education Committee in the Union's efforts to facilitate and enhance the technical training of its members.

Education

University of Baltimore: B.S. in Business Management

Boilermaker Apprenticeship Program

William M. Zaetz

Testimony

<u>Date</u>	<u>State</u>	<u>Docket</u>	<u>Utility</u>
2001	Georgia <u>1/</u>	14000-U	Georgia Power Company
2002	Florida <u>7/</u>	010949-EL	Gulf Power Company

Plant Tours

<u>Date</u>	<u>State/Client Code</u>	<u>Docket</u>	<u>Utility</u>
2001	Kansas <u>2/ 3/ 4/</u>	01-WSRE-436-RTS	Kansas Power & Light
2001	Kansas <u>2/ 3/ 4/</u>	01-WSRE-436-RTS	Kansas Gas & Electric
2001	New Jersey <u>5/</u>	GR0105029	Public Service Electric & Gas
2001	Georgia <u>1/</u>	14000-U	Georgia Power Company
2001	Michigan <u>6/</u>	U-12999	Consumers Energy
2001	Florida <u>7/</u>	010949-EL	Gulf Power Company
2002	Nevada <u>8/</u>	01-11031	Sierra Pacific & Nevada Power

Clients

- 1/ Georgia Public Service Commission
- 2/ Kansas Citizens' Utility Rate Board
- 3/ Kansas Industrial Group
- 4/ City of Wichita
- 5/ New Jersey Rate Advocate
- 6/ Michigan Attorney General
- 7/ Florida Office of Public Counsel
- 8/ Nevada Bureau of Consumer Protection

WILLIAM M. ZAETZ

INDEX OF EXHIBITS

EXHIBIT NO.

Gannon Station Business Plan	WMZ - 1
Hazardous Energy Control Program	WMZ - 2

DOCKET NO. 030001
EXHIBIT NO. WMZ-1
PAGES 1-45

THIS INFORMATION CLAIMED

CONFIDENTIAL


EXHIBIT NO. WMZ-1, PAGES 1-45

BY

TAMPA ELECTRIC

Gannon Station

2003 Business Plan



18345

November 15, 2002

Confidential

Table of Contents

1. Performance Expectations

EAF	1
EUOF	2
POF	3
Net Capacity	4
Net Generation	5
Consumption	6
OPA	7
OPA Weighting	8
Heat Rate & NOF	9

2. Financial Expectations

2003 Budget & Requirements	10
2003 O&M Budget Assumptions	11
2003 O&M Budget Requirements - Operations	12
2003 O&M Budget Requirements - Safety	13
2003 O&M Budget Requirements - Planned/Forced Outages	14
2003 O&M Budget Requirements - Non-Outage Maintenance	15
2003 O&M Budget Requirements - Non-Recoverable Fuel	16
Historical Trends - O&M	17
Workforce Trends	18
Historical Trends - NRF	19
Fuel Burn/Purchase Plan	20

3. Capital Budget

2003 Budget	21
Historical Trend	22

4. Key strategies 23-25

5. Risk Associated 26

6. 5 Year Plan 27


Appendix A - Performance Expectations 1-6

Appendix B - Labor detail 1

Appendix C - Subcontractor detail 1-2

Equivalent Availability Factor

The equivalent availability factor is based on period hours. Period hours are all of the hours in the year.



	<u>1998</u>	<u>1999</u>	<u>2000</u>	<u>2001</u>	<u>2002 (9+3)</u>	<u>2003 Bud</u>
Gannon	74.6%	69.4%	56.8%	67.7%	64.1%	67.6%
Bayside						87.9%
System	75.4%	74.2%	72.6%	73.5%	72.1%	71.6%


Analysis:

EAF is projected to be 3.5 percentage points better than last year and it is 1.1 percentage points better than the 5-year average. The EAF projection is increasing in 2003 due to the reduction/elimination in planned outages.

1817

Equivalent Unplanned Outage Factor

This factor is the percent of all forced, maintenance, and planned outages & derations divided by the period hours of the year.



	<u>1998</u>	<u>1999</u>	<u>2000</u>	<u>2001</u>	<u>2002 (9+3)</u>	<u>2003 Bud</u>
Gannon	18.5%	21.4%	35.6%	23.0%	22.5%	30.3%
Bayside						12.1%
System	17.1%	17.6%	21.2%	19.6%	17.0%	23.3%


Analysis:

EUOF is projected to be 7.8 percentage points higher than last year and it is 6.1 percentage points above the 5-year average. This projected increase in EUOF is due to decreasing O&M and capital budgets on our coal units.

1818

Planned Outage Factor

The planned outage factor is the percentage of planned outage hours divided by the period hours of the year.



	<u>1998</u>	<u>1999</u>	<u>2000</u>	<u>2001</u>	<u>2002 (9+3)</u>	<u>2003 Bud</u>
Gannon	7.0%	9.2%	7.6%	9.4%	13.4%	2.1%
Bayside						0.0%
System	7.5%	8.2%	6.2%	6.9%	10.9%	5.1%


Analysis:

POF is projected to be 11.3 percentage points lower than last year and it is 7.2 percentage points below the 5-year average. The reduction in planned outages is due to cost control and approaching shutdowns of the coal units.

1819

Net Capacity

Station maximum dependable generation capabilities minus station service load



	<u>1998</u>	<u>1999</u>	<u>2000</u>	<u>2001</u>	<u>2002 (9+3)</u>	<u>2003 Bud</u>
Gannon	1155	1126	1140	1122	1120	1120
Bayside						1732
System	3551	3244	3666	3624	3590	4154

Analysis:

Net Capacity at the beginning of 2003 is projected to be the same as last year and it is 1.1% below the 5-year average. By the end of 2003, Bayside units 1&2 will be commissioned and the station's capacity will be 1732MW, 55% more than Gannon's coal capacity at the start of 2003.

Capacity schedule: February loss of 218MW due to shutdown of Gannon 5

March loss of 212MW due to shutdown of Gannon 1&2

May gain of 748MW with Bayside 1 commissioning

September loss of 691MW due to shutdown of Gannon 3,4&6

December gain of 984MW with Bayside 2 commissioning.

1820

11/12/2002

Net Generation

MWh generated minus station service.



	<u>1998</u>	<u>1999</u>	<u>2000</u>	<u>2001</u>	<u>2002 (9+3)</u>	<u>2003 Bud</u>
Gannon	5599	4963	4355	5085	4838	2230
Bayside						2929
System	17174	15835	17283	16145	15938	16810

Analysis:


Gannon generation is projected to be 53.9% lower than last year and it is 56.6% lower than the 5-year average. This projected decrease in net generation is due to coal unit shutdowns for repowering and cost control.

1821

11/14/2002

Fuel Consumption

Tons of coal consumed.



	<u>1998</u>	<u>1999</u>	<u>2000</u>	<u>2001</u>	<u>2002 (9+3)</u>	<u>2003 Bud</u>
Gannon	2848	2637	2056	2615	2569	1158
System Coal	7893	7319	7550	7289	5511	6069


Analysis:

Generation is projected to be 53.9% lower than last year and it is 56.6% lower than the 5-year average. Reduced coal consumption reflects our coal unit shutdown strategy. The increase in natural gas is due to unit conversions.

1822

On-Peak Availability

The on-peak availability factor is based on peak hours instead of period hours. Peak hours occur when native load is greater than 2900 MW.




	<u>1998</u>	<u>1999</u>	<u>2000</u>	<u>2001</u>	<u>2002 (9+3)</u>	<u>2003 Bud</u>
Gannon	No data	73.5%	65.0%	71.4%	74.4%	71.1%
Bayside	No data					95.0%
System	No data	81.9%	79.1%	78.4%	73.0%	75.0%

Analysis:

OPA is projected to be 5 percentage points worse than last year but only 0.1 percentage points worse than the 4-year average. This projected drop in OPA is due to decreasing O&M and capital budgets on our coal units.

1823

On-Peak Weighting (1999-2002 through Sept.)




11/12/2002

Average Net Operating Heat Rate with Net Output Factor

The Average Net Operating Heat Rate is a measure of unit efficiency. It is calculated from fuel input in Btu divided by energy output in Kwh.

The Net Output Factor is the loading on the unit while the in operation.



	<u>1998</u>	<u>1999</u>	<u>2000</u>	<u>2001</u>	<u>2002 (9+3)</u>	<u>2003 Bud</u>
Gannon HR	11,125	11,704	11,206	11,302	11,800	11,802
Gannon NOF	75.6%	69.1%	71.6%	72.6%	68.8%	64.7%
Bayside HR						7,582
Bayside NOF						79.6%
System	10,561	10,705	10,511	10,800	11,079	10,395

Analysis:

Heat Rate is projected to be 2 Btu/Kwh worse than last year and it is 375 Btu/Kwh better than the 5-year average. The Heat Rate projection is based on the Net Output Factor %, or loading, on each unit.

1825

Gannon Station
2003 O&M Budget Requirements
(\$ x 1,000)

	<u>Labor / Fringe</u>	<u>Other Expense</u>	<u>2003 Budget</u>
Operations	3,588	4,260	7,848
Maintenance - Outage	1,472	2,229	3,701
Maintenance - Non-Outage	3,636	6,444	10,080
Inventory Write-off	0	2,000	2,000
O&M Only	<u>8,696</u>	<u>14,933</u>	<u>23,629</u>
Non-Recoverable Fuel	1,109	1,907	3,016
Total Gannon O & M	<u>9,805</u>	<u>16,840</u>	<u>26,645</u>

2003 O&M Budget Assumptions

Shut down Unit 5 February 2003.

Shut down Unit 1 and Unit 2 on March 15, 2003.

Run Unit 3 and Unit 4 until Sept. 1, 2003 or until O&M dollars are gone.

Shut down Unit 6 Sept. 1, 2003.

2003 estimate assumes Unit 3 2002 outage (\$250K) takes place.

OT at 15%.

3.5% Craft raises, 3% other.

36% fringe rate.

In operations need 10 BTO's and 13 AO's in March; 7 BTO's will work down(demoted) under current plan.

Assumes no red circles; considers demotions in budgets.

Includes inventory write-off \$2M.

No layoff dollars included. This is estimated at \$1.8M - \$3.0M(66 to 106 craft employees). Dollars are not included for the 6 employees who accepted retention packages.

Planned outages include a 28 day outage on Unit 4 starting February 1, and a 28 day outage on Unit 3 starting March 4.

Gannon Operations Budget
(\$ x 1,000)

<u>Resource</u>	<u>2003</u>	<u>Description</u>
	240	Safety Budget
03	351	Subcontractor services (KBR)
03	235	Misc subcontractor services
03	777	Water Expense
03	373	Chemical expense
03	500	Solid Material Disposal
06	378	Stores expense
03	450	Environmental costs
30	117	Temporary Help
58	43	Vehicles
60	647	Facility services.
	149	Misc plant expense
	<u>4,260</u>	<u>Total</u>

Safety Budget

(\$ x 1,000)

<u>Budget</u>	<u>Description</u>
\$ 75	IH Consultants, Dr. charges, Ergonomics, Drug testing, PFT Interpretations, Noise monitoring, Audiometric test follow ups, Chest x-rays.
70	Care team station nurse.
24	PPE, Spirometry Supply, Audiometric, Supplies, Fit Testing Supplies.
57	Luminometer, Safety rewards, prescriptions, safety glasses, 4-gas Air monitors, Pager, Cell phone, Thermometers for heat stress, Confined space rescue eqp.
2	Travel expense.
1	Miscellaneous expense.
10	Meals expense.
1	Personal auto reimbursement.
<u>\$ 240</u>	

1829

Gannon Station
2003 Outage Plan
(\$ x 1,000)

	<u>Planned Outage</u>	<u>Forced Outage</u>	<u>Total</u>
Unit #1 is planned to run until March 15, 2003.	0	125	125
Unit #2 is planned to run until March 15, 2003.	0	125	125
Unit #3 is planned to run until Sept. 1, 2003 or Fund depletion. A 28 day outage is planned to start March 4 - March 31.	500	125	625
Unit #4 is planned to run until Sept. 1, 2003 or Fund depletion. A 28 day outage is planned to start February 1 - February 28.	500	125	625
Unit #5 is planned to shut down February 1 2003. We plan forced outage dollars to maintain the unit and outage dollars for cleanup before turn over to Bayside.	210	100	310
Unit #6 is planned to shut down September 1 2003. We plan forced outage dollars to maintain the unit and outage dollars for cleanup before turn over to Bayside.	294	125	419
			<u>2,229</u>

Gannon Station
Non-Outage Maintenance Budget
(\$ x 1,000)

	<u>2003</u>	<u>Description</u>
03	772	KBR core plus indirects
03	154	KBR core and indirect OT(@ 20%)
03	469	EME core - Craft (20% o/t)
03	137	AVA core - Craft (20% o/t)
03	256	ESI core - Craft (20% o/t)
03	50	Seawall repair
03	50	Fire Protection(Industrial fire, Suncoast)
03	50	Sprayfield and Coalfield ditch maintenance
03	50	Elevator maintenance
03	150	Penn coal crusher maintenance
03	60	Slag handling/ Ash handling / Sootblowing maint.
03	85	Other (Gaffin,Blasters,S.E.,Southern Valve,etc.)
03	50	Diving services
06	1,765	Stores Issues
30	508	16 SUW (20% o/t) Jan - Sept. 1
30	66	PMI Electrical Engr for Jan - Sept. 1
30	180	PMI Electricians Jan - Dec
55	153	Off Road equipment
57	134	Coal Handling Equipment
58	74	Vehicles
03	48	Plant Lay up \$2K per month per unit.
59	33	Personnel Carriers
03	1,040	Dredge in front of 5 & 6 screen wells
67	110	Tool Repair
	<u>6,444</u>	Total

Gannon Station


2003 Non-Recoverable Fuel

(\$ x 1,000)


	<u>2003</u>	
03	1,112	TECO Stevedoring - unloading
00	130	supervisory payroll
70	47	supervisory fringe
01	685	operating payroll
71	246	operating fringe
03	621	KBR clean-up crew
03	50	Dust suppression
06	150	Consumables
10	130	fuel for coalfield equipment
58	10	vehicles
10	(50)	flyash sales
10	(115)	slag sales
	<u>3,016</u>	Total 2003 Budget

Gannon O & M Trend


(Excludes NR Fuel)



Gannon Workforce



Gannon Station Non-Recoverable Fuel



2003 BURN DATA

(KTONS)

ACTUAL vs BUDGET

CONFIDENTIAL

	<u>JAN</u>	<u>FEB</u>	<u>MAR</u>	<u>APR</u>	<u>MAY</u>	<u>JUN</u>	<u>JUL</u>	<u>AUG</u>	<u>SEP</u>	<u>OCT</u>	<u>NOV</u>	<u>DEC</u>	<u>TOTAL</u>
GANNON													
BUDGET	188.7	145.8	157.8	143.4	156.4	188.6	199.7	201.9	122.8	0.0	0.0	0.0	1,505.0
ACTUAL													

2003 Coal Purchases

(KTONS)

CONFIDENTIAL

2003 Purchases

	<u>JAN</u>	<u>FEB</u>	<u>MAR</u>	<u>APR</u>	<u>MAY</u>	<u>JUN</u>	<u>JUL</u>	<u>AUG</u>	<u>SEP</u>	<u>OCT</u>	<u>NOV</u>	<u>DEC</u>	<u>TOTAL</u>
Galatia	168.0	156.0	144.0	132.0	132.0	120.0	84.0	72.0	0.0	0.0	0.0	0.0	1,008.0
PRB - Gannon	0.0	0.0	45.0	45.0	60.0	60.0	60.0	45.0	0.0	0.0	0.0	0.0	315.0
W. Ky Standard - BB	203.8	203.8	203.8	203.8	203.8	203.8	187.1	187.1	0.0	0.0	0.0	0.0	1,596.8
Illinois 6 (BB4)	87.5	87.5	87.5	87.5	87.5	87.5	87.5	87.5	0.0	0.0	0.0	0.0	700.0
Total River	459.3	447.3	480.3	468.3	483.3	471.3	418.6	391.6	0.0	0.0	0.0	0.0	3,619.8
Pet Coke - Direct	25.0	20.0	15.0	15.0	15.0	15.0	15.0	15.0	0.0	0.0	0.0	0.0	135.0
Pet Coke thru TBT	25.0	30.0	25.0	25.0	25.0	25.0	25.0	30.0	0.0	0.0	0.0	0.0	210.0
Foreign LS - Polk	0.0	60.0	0.0	0.0	60.0	0.0	50.0	0.0	0.0	0.0	0.0	0.0	170.0
Foreign Low Sulfur-G	60.0	0.0	0.0	60.0	0.0	60.0	10.0	0.0	0.0	0.0	0.0	0.0	190.0
Gulf	569.3	557.3	520.3	568.3	583.3	571.3	518.6	436.6	0.0	0.0	0.0	0.0	705.0


Gannon Station Summary 2003 Capital Budget Requirements (\$ x 1,000)

	<u>2002 Budget</u>	<u>2003 Plan</u>	<u>Change</u>
Capital	3,500	2,300	(1,200)
<u>Major Drivers</u>			
Tools and test equipment		200	
Discharge bridge replacement		150	
Control Valve repl		50	
Green lip mussels(units 5 & 6)		250	
CWP motors (rotors) unit 6		250	
Indeterminates		<u>1,400</u>	
Total 2003 Capital		<u><u>2,300</u></u>	

Due to change in our plan not all capital dollars will be needed, there is a risk with Bayside spare parts roll over into 2003.

Capital History

1828



November 15, 2002, revised

CONFIDENTIAL
KEY STRATEGIES FOR 2003 – GANNON

Introduction

As a result of transitioning from Gannon Station to Bayside Power Station, employee headcount (at both Big Bend and Gannon Stations) is deliberately decreasing and our use of contracted and temporary labor continues to become more critical. We have the most difficulty when headcount falls below minimum operational levels in the operator classifications. We must deal with getting work done in other ways. This year, we have utilized production apprentices (an entry-level maintenance classification) and production workers (former TSS employees) in Plant and coalfield operations. We also currently have 3 temporary union electricians hired through PMI. These electricians function as crew members in the electric shop, working side by side with our own employees. Additionally, mechanical and electrical maintenance requires the rising use of contracted labor and special utility workers (temporary employees and permanent) as our employee headcount continues to decline; implementation of this strategy is well underway and we plan to continue. In the supervisor areas, we have two "borrowed supervisors" from the Construction Services group and three temporary engineers (one mechanical, one chemical and one electrical). Six supervisors have accepted retention packages containing an incentive not to retire until October 1, 2004 (+/- 3 months); this is so that we continue to operate and maintain Gannon and minimize an excess of supervisors when the Bayside transition is complete. We will remain flexible and have identified an individual plan to react to headcount reductions in each of our classifications.

Our Base Case (#9) O&M Scenario for Gannon has the following assumptions:

- shut down Unit 5 February, 2003
- shut down Units 1 and 2 on March 15, 2003
- run Units 3 and 4 until September 1, 2003 or until O&M dollars are gone
- shut down Unit 6 September 1, 2003

For 2003 budgeting, the following additional assumptions were made:

- Unit 6 2002 outage (\$1.6M O&M) takes place
- Unit 3 2002 outage (\$250K O&M) takes place
- overtime is held to 15%
- 3.5% craft salary increase, 3% supervisory and admin
- 36% fringe
- inventory write off of \$2M
- no red circles; the budget considers demotions in classifications

Plant Operations

- Will work 12 hour shifts 7 days a week through 9/1
- Will work 8 hour shifts 7 days a week 9/1 through 12/31
- Head count drops as Controls rooms become inactive.
- 1/1 through 3/15 requires 54 operators
- 3/15 through 9/1 requires 38 operators
- 9/1 through 12/31 requires 5 operators (fire watch)

Coal field Operations and Maintenance

- Will work two 8 hour shifts (0630-1430/1830-0230)
- 1/1 through 9/1 requires 19 operators
- No operators required after 9/1.

Maintenance

From January 2003 to March 15, 2003 we will have; 58 mechanical personnel and 28 maintenance support (WF, IC, Ele.). From March 16, 2003 to August 31, 2003 we will have; 49 mechanical maintenance personnel and 24 mechanical maintenance support. From September 1, 2003 to December 31, 2003 we will have; 7 mechanical maintenance personnel and 3 mechanical maintenance support. We will be cutting back on the contractor work force to match budget plan (KBR, EME). Gannon will look at placing contractors where we need them (Straight time, weekend, coal field maintenance, night shifts). As we cut back the TECO work force. The Impacts of these work force reductions will be as follows. With cutting back the contractor work force takes away from the scaffold building or multi-unit outages and quick turnovers. This will also effect the around the clock

coverage to turn over units including weekend. We will have to get the TEC craft retrained for scaffold building (2 tier etc). We will decrease the amount of planning and scheduling staff for the "01" side after March, 2003. We will continue to combine crews as we loose people.

Outage Schedule

Gannon's outage strategy since the Bayside decision has been to reduce capital improvements (unless the payback period is very short) and maintain acceptable, but decreasing unit availability by performing annual 4-week long O&M outages. The 4-week outages generally allow enough time to perform needed inspections and repairs on turbines and boilers. They also usually provide enough time to complete high priority backlog work. For 2003, Units 1 and 2 will not have a scheduled outage because both units will shut down March 15. Unit 5, is scheduled to come off in February for the Bayside tie in outage and has minimal plant maintenance work scheduled. Units 3 and 4 will have 4-week outages in early Spring with the intent that they can run until September with minimal forced outages competing for our plant O&M dollars. We plan to have an outage on our Unit 3 this fall so that we can improve availability for the winter run and minimize outage expenses in 2003.

2003 Outage Plan:

Unit 1 - no outage

Unit 2 - no outage

Unit 3 - 28 day spring outage, 3/4/03 - 3/31/03

Unit 4 - 28 day spring outage, 2/1/03 - 2/28/03

Unit 5 - 96 day Bayside tie in outage, 2/8/03 - 5/16/03

Unit 6 - 42 day Bayside outage, 9/1/03 - 12/22/03

The Total Funds Available in the Planned Outage "bucket" is \$1.5M.

Outage costs will be minimized by use of core employees where practical on their budgeted work schedules (straight time shifts with minimal overtime). Efforts to minimize overtime for everyone will be a key to meeting budget targets. As reflected in the above days of funding, O&M dollar allotments take into account that no non-critical path work will be performed on overtime (weekends).

Station Performance Issues

Unit forced outage rates should not change from our current projections since Units 3 and 4 will have spring outages and units 1 and 2 will be shut down before the effects of not having their spring outages develop.

Contingency Plan for Reducing O&M if Retail Sales are Below Plan

Consideration can be given to shutting down Units 3 and 4 earlier.

Other Considerations

There are no layoff dollars included in this budget. Attachment III details the ES personnel projections for March and September 2003. Also included in Attachment III, are the classifications, which will experience demotions to a lower classification and the % of employees in that classification that are affected. This budget assumes no red circles and considers top step wages for the classifications required. This budget also does not include dollars to settle or negotiate changes in the six retention contracts.

Gannon Station

Case 9 Staff Requirements

Attachment 1

CLASSIFICATION		Units 1-6	Units 3,4,6	FW/DEMO
		Head Count 01/01-3/15	Head Count 3/16-8/31	Head Count 9/1-12/31
Managers		2	2	0.5
Technical Staff		9	8	0
Superintendents		4	4	0
Supervisors		9	8	1
		24	22	1.5
Administrative		5	3	0
Watch Engineers	WE	10	6	0
Control Center Operators	CCO	12	9	0
Boiler Turbine Operators	BTO	18	10	5
Auxiliary Operators	AO	5	13	0
Auxiliary Operators OTHER	PA	4	0	0
Production Worker	PW	5	0	0
Total Operations		54	38	5
Maintenance				
Water & Fuels Analyst	WF	5	4	0
Instrument & Controls Analysts	CAP	11	8	1
Electricians	E	11	8	2
Production Apprentice	PA	0	4	0
Special Utility worker	SUW/PW	1	0	0
Tech OPS Support		28	24	3
Machinist Blader	MB	1	0	0
Machinist	MM	3	2	0
Maintenance Mechanics	M	37	30	3
Mechanic Certified Welders	MCW	17	17	4
Mechanical Maintenance		58	49	7
Total Maintenance		86	73	10
NON-RECOVERABLE FUEL				
Supv		1	1	0
Fuel Equipment Operators	FEO	11	11	0
Production Apprentice	PA	3	3	0
Fuel Handlers	FH	5	5	0
		20	20	0
Gannon payroll		189	156	17
		160	131	15

1843

Attachment 2

Jan-Mar 15 Mar 16 - Aug 31 Sept - Dec 31

Kellogg Brown & Root

Indirect Support Services

Asst, Proj Mgr.
Admin
Safety

NUMBER	NUMBER	NUMBER
1	1	0
1	1	0
1	1	0
3	3	0

Site Indirect

General Foreman
Supt
Planner
Tool Clerk
Total Daily Cost

1	1	0
1	1	0
1	1	0
1	1	0
4	4	0

CORE GROUP PERSONNEL

Crew Foreman
Lead man
Pressure Welders (Craft Validated)
Structural Welders (Craft Validated)
Structural Welders
Operator (Craft Validated)
Boiler Makers (Mechanical)
Civil (Carpenter, Scaffold) (Craft Validated)
Millwright (Craft Validated)
TOTAL DAILY COST

1	1	0
1	1	0
4	4	0
3	1	0
2	1	0
1	1	0
3	2	0
1	1	0
3	2	0
19	14	0

COAL CREW PERSONNEL

Lead man - Jack Watts
Structural Welders - Jose Ruiz
Millwright - Bert Frahs
Helper 1A
TOTAL DAILY COST

1	1	0
2	2	0
1	1	0
2	2	0
6	6	0

COAL FIELD CLEAN

Helper 1A
Helper 4C
Helper 5B
TOTAL DAILY COST

1	1	0
1	1	0
3	2	0
5	4	0

PLANT CLEAN

Helper 1A
Helper 4B
Helper 4C
Helper 5B
TOTAL DAILY COST

1	1	0
1	1	0
1	1	0
11	5	0
14	8	0

3 P.M.-11 P.M. PERSONNEL

Leadman, (Pressure Welder, Operator)
Pressure Welder
Millwright, Instrumentation
Helper 1A
TOTAL DAILY COST

1	1	0
1	1	0
1	1	0
3	3	0
6	6	0

1844

ES Personnel Projections (3/03)

09/24/2002(Case 9)

Classifications 01 + Supervisors 9/01/02	9/02 Total # of Employees by Classification	3/03 BB Needs/ BPS Needs/ Gannon Needs(5)	Total Projected Positions 3/03 by Classification	Other Needs	Projected Over or Under Staffed by Classification	Potential Demotions(D)/ Layoffs(L)	Comments
Watch Engineer	28	10/0/6	16		10	26-16=10(D)	38% demoted
Control Center Operator	17	14/0/9	23		-6	10+17-23=4(D)	23% demoted
Boiler Turbine Operator	51	34/4/10	48		3	4+51-48=7(D)	13% demoted
Auxiliary Operator	15	22/0/13	35		-20	7+15-35=-13	short - use PA/PW
Combined Cycle Spec (5)	23	0/23/0	23		0	0	NA
Fuel Equip Oper	30	20/0/11	31		-1	30-31=-1	short
Fuel Handler	9	7/0/5	12		-3	9-12=-3	short - use PA/PW
W&F Analyst	16	12/1/4	17		-1	16-17=-1	short
Controls Analyst	28	21/5/8	34		-6	28-34=-6	short - use contractors?
Electrician	22	20/0/8	28		-6	22-28=-6	short - use contractors?
MCW	45	33/2/17	52	3(1)	-7	45-52=-7	short - use contractors?
Maint Mech	91	72/0/25	97	12(1)	-6	91-97=-6	short - use contractors?
Production Apprentice	13	0/0/7	7		6	13-7=6	use as AO/FH
Production Worker (2)	14	0/0/0	0		14	14-0=14	use as AO/FH
Spec Utility Worker (2)	1	16/0/0	16	16(3)	-15	1-16=-15	Filled with demoted people?
Machinist/Mach Blader	10	8/0/2	10		0	10-10=0	NA
SPO/Supt Prods (6)	12	6/0/4	10		2	12-10=2	With retirements should be no impact.
Supt Maintenance	2	1/0/0	1		1	2-1=1	NA
Supt. Prod. ES (6)	45	21/7/9	37		8	45-37=8	With retirements may be no impact.
Total	470	317/42/138	497			21(D) 0(L)	

NOTES:

- 1) Replace 15 skilled contractors at BB when needed.
- 2) Transfer former TSSI employees (15) back to TSSI when no longer needed. May cause lay off at TSSI.
- 3) 16 SUW positions @ BB are currently filled by temps. Can replace with demoted TEC personnel when needed.
- 4) Normal Attrition is not factored into these numbers. Estimated to be 25 to 35 people between now and 3/03.
- 5) BPS people who have not moved are shown by skill vs CCS.
- 6) Have six people in the supervisory retention program that we have to deal with.
- 7) In Sept 03 Gannon needs go to 16.

**Gannon / Big Bend
Base Case (#9) Staffing Requirements**

Management	10/1 - 13/15		3/16 - 8/31		+/-	B&R	9/1 - 12/31		+/-	B&R	Comments
	GN	BB	GN	BB			GN	BB			
Management	2	7	2	7			0.5	7	0		
Technical Staff	9	16	8	16			0	16	+4		BB, MS, WJ and ZJ
Superintendents	4	6	4	6			0	6	+1		J Harker
Supervisors	8	23	7	23			1	23	+3		JJ, FF, TA; TT stays @ GN
Total	23	52	21	52	0	0	1.5	52	0	0	

Administrative	4	4	3	4	+1		0	4	+1		2 to Bayside, JC and BJ extra
-----------------------	----------	----------	----------	----------	-----------	--	----------	----------	-----------	--	-------------------------------

Operations											
Watch Engineer	10	16	6	10	+10	+10 we-cco	0	10	+6	6 we-cco	all at BB
Control Center Operator	12	5	9	14	-6	+4 cco-blo	0	14	+9	15 cco-blo	all at BB
Boiler/Turbine Operator	18	31	10	33	+7	+11 blo-ao	5	33	+5	20 blo-ao	8 at GN and 3 at BB
Auxiliary Operator	5	9	13	12	-11		0	22	+3	(+23 jr AOs)	23 AOs at risk
Production Apprentice	4	2	0	2	0		0	0	+2	(+2 PAs)	4 PAs to GN maint; 2 PAs @ risk
Production Worker	5	7	0	7	+5	(+5 PWs)	0	0	+7	(+7PWs)	5 PWs @ risk; 7 more PWs @ risk
Combustion Turbine BTO	0	2	0	2	0			2	0		
Total	54	72	38	80	+5		5	61	32		

Maintenance											
Water & Fuels	5	12	4	12	0		0	12	+4	(+4 W&F)	DB to Bayside; expect some attrition
Instrument & Controls	11	16	8	19	0		1	18	0		DL to Bayside
Electricians	11	10	8	13	0		2	18	+1	(+1 elect)	
Production Apprentice	0	1	0	1	0		0	0	+5	(+5 PA)	PAs from operations excess
Special Utility Workers	1	0	0	0	+1	(+1 SUW)	0	0	0		
Sub-Total	28	39	24	45	0		3	48			
Machinist Blader	1	3	0	4	0		0	4	0		
Machinist	3	3	2	4	0		0	4	0		
Maintenance Mechanics	37	54	30	61	0		3	61	+27	(+27 mech)	
Mechanic Certified Welder	17	28	17	28	0		4	28	+13	(+13 mcw)	
Garage Mechanic III	0	11	0	11	0		0	11	0		
Senior Parts Clerk	0	1	0	1	0		0	1	0		
Special Utility Worker	0	0	0	0	0		0	23	-23	(-23 suw)	These openings filled by seniority
Sub-Total	58	100	49	97	0	0	10	145	0	0	
Total Maintenance	86										

Non-Recoverable Fuel											
Supervisor	1	1	1	1	0		0	1	+1	+1 suprv	CN extra
Fuel Equipment Operator	11	19	11	19	0		0	20	+10	10 fe-fh	
Fuel Handler	5	4	5	4	0		0	12	-3	(+7 FH)	
Production Apprentice	3	3	3	3	0		0	0	+6	(+6 PA)	
Production Workers	0	2	0	2	0		0	0	+2	(+2 PW)	
TSS Mechanical	0	7	0	7	0		0	0	+7	(+7 tss mech)	teco to maintain coal field
TSS Electrical	0	4	0	4	0		0	0	+4	(+2 tss elect)	2 elect to dock; 2 @ risk
Sub-Total	20	40	20	40	0	0	0	33	0	0	

Note: Red indicates excess
Blue indicates shortage
[Scott to input]

4887

Risk Associated with this Plan

- * Unit shut downs must occur as planned (Base case).
 - Shut down Unit 5 February 2003.
 - Shut down Unit 1 and Unit 2 March 15, 2003.
 - Run Unit 3 and Unit 4 until Sept. 1, 2003 or until O&M dollars are gone.
 - Shut down Unit 6 Sept. 1, 2003.

- * A large equipment failure will result in the expenditure of O&M dollars which previously would be classified as capital.

- * Unplanned major O&M dollars may require premature unit shut downs.

- * Environmental remediation is not included in the plan.

- * The Gannon 6 explosion insurance default (\$1.8M) is not in the plan.

- * Lay-off dollars est. \$1.8M - \$3.0M (66 - 106 craft employees) are not included in the plan.

- * Dollars resulting from the resolution of the contract issues for the six supervisors who will have accepted retention packages are not in the plan.

5 Year Operations & Maintenance Forecast Gannon
(\$ x 1,000)

	<u>2003</u>	<u>2004</u>	<u>2005</u>	<u>2006</u>	<u>2007</u>
Inventory Write-off	2,000	3,300	0	0	0
Plant Operations	4,260	350	0	0	0
Outage Maintenance	2,229	0	0	0	0
Non-Outage Maintenance	6,444	2,700	1,500	1,500	1,500
Payroll	6,396	2,400	0	0	0
Fringe	2,300	0	0	0	0
Total O&M	23,629	8,750	1,500	1,500	1,500
TECO Stevedoring	1,112	0	0	0	0
Fuel Handling Exp - Gannon	1,984	0	0	0	0
Fuel Handling Exp - Other	10	0	0	0	0
Residuals Handling Exp	75	0	0	0	0
Residuals Revenue	(165)	0	0	0	0
Total N/R Fuel	3,016	0	0	0	0
	26,645	8,750	1,500	1,500	1,500

*Done A row
12 07
2004*

*Description
in dollars*

CONSUMPTION

Station / Unit	2003 Burn	7 Year Avg.	2003 Burn VS		2003 Burn VS		2002 (9+3)	2001	2000	1999	Historical Operatlon			
			7 Year Avg.		2002 (9+3)						1998	1997	1996	1995
Gannon 1	46.693	241.615	(194.922)	-80.7%	(202.981)	-81.3%	275.879	249.674	207.996	280.590	262.842	246.327	265.722	186.212
2	35.301	254.287	(218.986)	-86.1%	(218.446)	-86.1%	246.986	253.747	198.132	281.808	239.609	368.328	251.464	186.383
3	253.107	389.791	(136.684)	-35.1%	(143.575)	-36.2%	449.480	396.682	390.453	431.164	441.838	502.172	298.202	274.919
4	208.970	453.239	(244.269)	-53.9%	(210.621)	-50.2%	429.425	419.591	397.897	408.955	486.831	474.906	486.874	463.970
5	42.993	523.248	(480.255)	-91.8%	(372.658)	-89.7%	417.594	415.651	496.276	541.559	556.487	450.802	574.584	519.780
6	571.343	771.460	(200.117)	-25.9%	(308.283)	-35.0%	749.738	879.626	364.783	693.039	860.597	920.526	892.742	897.070
Coal Total	1,158.407	2,633.639	(1,475.232)	-56.0%	(1,456.564)	-55.7%	2,569.102	2,614.971	2,055.536	2,637.115	2,848.204	2,963.059	2,769.588	2,528.334

1859

SERVICE HOURS

Station / Unit	2003 Burn	7 Year Avg.	2003 Burn VS		2003 Burn VS		2002 (9+3)	2001	2000	1999	Historical Operation			
			7 Year Avg.		2002 (9+3)						1998	1997	1996	1995
Gannon 1	1,334	5,872	(4,539)	-77.3%	(5,454)	-80.4%	6,510	6,788	7,266	6,590	5,986	5,306	6,269	5,211
2	1,098	6,065	(4,968)	-81.9%	(4,912)	-81.7%	5,790	6,010	6,195	6,272	5,519	7,563	5,915	5,058
3	3,911	6,606	(2,695)	-40.8%	(2,533)	-39.3%	6,318	6,444	7,235	7,070	6,798	7,599	6,077	5,487
4	3,303	6,754	(3,451)	-51.1%	(2,551)	-43.6%	5,428	5,854	6,599	5,719	6,894	6,643	7,139	7,373
5	687	8,927	(6,240)	-90.1%	(5,243)	-88.4%	5,471	5,930	5,764	6,765	7,523	5,990	7,458	8,898
6	4,843	6,823	(1,980)	-29.0%	(2,462)	-33.7%	5,765	7,305	3,149	5,294	7,323	7,588	6,800	7,109
Coal Total	15,176	39,047	(23,871)	-61.1%	(23,154)	-60.4%	35,282	38,330	36,208	37,710	40,042	40,689	39,659	37,135

1854

GENERATION

Station / Unit	2003 Burn	7 Year Avg.	2003 Burn VS		2003 Burn VS		2002 (9+3)	2001	2000	1999	Historical Operation			1995
			7 Year Avg.		2002 (9+3)						1998	1997	1996	
Gannon 1	87.563	467.692	(380.129)	-81.3%	(407.586)	-82.3%	529.200	495.149	544.526	476.668	455.350	415.853	507.306	406.451
2	66.963	455.168	(388.205)	-85.3%	(345.384)	-83.8%	463.116	412.347	446.727	434.667	381.654	598.809	469.901	399.249
3	373.130	608.114	(232.984)	-38.4%	(249.105)	-40.0%	689.744	622.235	773.502	725.338	71.136	860.496	603.417	602.795
4	347.148	840.618	(493.470)	-58.7%	(295.780)	-46.0%	645.891	642.928	759.815	655.398	816.059	858.393	954.970	999.072
5	94.986	1,172.387	(1,077.401)	-91.9%	(804.923)	-89.4%	890.493	899.909	931.060	1,170.215	1,269.178	1,034.834	1,366.525	1,262.508
6	1,259.985	1,794.599	(534.614)	-29.8%	(752.934)	-37.4%	1,619.998	2,012.919	899.588	1,500.422	1,965.635	2,153.967	2,107.664	2,140.321
Coal Total	2,229.775	5,336.578	(3,106.803)	-58.2%	(2,855.712)	-56.2%	4,838.442	5,085.487	4,355.218	4,962.708	4,959.012	5,922.352	6,009.783	5,810.396

1852

EXHIBIT WMZ-1
Page 33 of 45

NET OUTPUT FACTOR

Station / Unit	2003 Burn	7 Year Avg.	2003 Burn VS		2003 Burn VS		2002 (9+3)	2001	2000	1999	Historical Operation			1995
			7 Year Avg.		2002 (9+3)						1998	1997	1996	
Gannon 1	57.6	68.1	(10.5)	-15.4%	(6.4)	-10.0%	72.4	64.0	65.7	73.1	67.3	66.6	68.0	65.6
2	62.2	69.2	(7.0)	-10.1%	(7.8)	-11.2%	82.3	70.0	77.5	78.8	65.2	68.6	66.9	66.3
3	61.5	69.3	(7.8)	-11.2%	(5.1)	-7.7%	74.8	66.6	71.3	70.3	67.9	73.1	64.1	70.9
4	66.1	69.1	(3.0)	-4.4%	(1.6)	-2.3%	75.0	67.7	70.2	65.9	68.0	69.3	70.8	71.7
5	59.6	76.2	(16.6)	-21.7%	(8.2)	-12.2%	71.0	67.8	68.2	73.0	73.0	75.3	79.8	79.7
6	66.4	76.6	(10.2)	-13.3%	(6.4)	-8.8%	76.3	72.8	74.8	74.2	71.2	75.3	82.2	80.0
Coal Total	64.7	71.4	(6.7)	-9.4%	(4.4)	-6.4%	75.6	69.1	71.6	72.6	68.8	71.4	72.0	72.4

4853

CAPACITY FACTOR

Station / Unit	2003 Burn	7 Year Avg.	2003 Burn VS		2003 Burn VS		2002 (9+3)	2001	2000	1999	Historical Operation			
			7 Year Avg.		2002 (9+3)						1998	1997	1996	1995
Gannon 1	35.1	45.8	(10.7)	-23.4%	(14.5)	-29.2%	53.0	49.6	54.4	55.0	46.0	40.3	48.7	39.0
2	7.8	48.0	(40.2)	-83.8%	(40.2)	-83.8%	54.0	48.0	54.7	56.4	41.1	59.2	45.1	38.3
3	27.5	52.3	(24.8)	-47.5%	(21.5)	-43.9%	53.0	49.0	58.7	56.8	52.7	63.4	44.4	44.4
4	24.9	53.4	(28.5)	-53.4%	(20.3)	-44.9%	46.4	45.2	52.7	43.0	53.5	52.5	57.7	60.3
5	4.7	60.3	(55.6)	-92.2%	(41.2)	-89.8%	46.8	45.9	44.7	56.4	62.7	51.5	68.0	62.8
6	36.7	59.7	(23.0)	-38.5%	(24.0)	-39.5%	49.1	60.7	26.8	44.8	59.5	65.2	63.8	65.0
Coal Total	23.9	53.3	(29.4)	-55.1%	(27.9)	-53.8%	49.6	51.8	43.5	52.1	52.6	55.4	54.6	51.6

1854

EXHIBIT WMZ-1
Page 40 of 45

HEAT RATE

Station / Unit	2003 Burn	7 Year Avg.	2003 Burn VS		2003 Burn VS		2002 (9+3)	2001	2000	1999	Historical Operation			1995
			7 Year Avg.		2002 (9+3)						1998	1997	1996	
Gannon 1	12,969	11,868	1,101	9.3%	1,253	10.7%	12,459	11,716	11,493	12,446	11,681	12,012	11,908	11,292
2	12,821	12,418	403	3.2%	386	3.1%	12,551	12,435	12,472	13,339	12,716	12,593	11,956	11,487
3	13,013	11,713	1,300	11.1%	805	6.6%	12,677	12,208	11,951	12,201	11,906	11,703	11,520	11,233
4	13,035	11,568	1,467	12.7%	686	5.6%	13,012	12,349	11,840	12,415	11,765	11,425	11,395	10,838
5	11,008	10,518	490	4.7%	245	2.3%	11,064	10,763	10,659	11,029	10,497	10,503	10,368	10,193
6	11,028	10,575	453	4.3%	433	4.1%	10,919	10,595	10,562	10,971	10,544	10,403	10,527	10,428
Coal Total	11,802	11,108	5,216	6.2%	500	4.4%	11,800	11,302	11,206	11,704	11,125	11,092	10,956	10,664

1875

EXHIBIT WAZ-1
Page 41 of 15

Gannon Station

Budget Requirements - Payroll Case 9

CLASSIFICATION	Units 1-6 Head Count 01/01-3/15	Units 3,4,6 Head Count 3/16-8/31	FW/DEMO Head Count 9/1-12/31	Hourly Rate	Annual ST Total	OT Rate	Annual OT Total	2003		2003		2003		
								Jan-Mar 15 Total	Fringe	Mar 16 - Aug 31 Total	Fringe	Sept - Dec 31 Total	Fringe	
Managers	2	2	0.5				128,000	45,360	292,100	105,156	198,000	71,280		
Technical Staff	9	8	0				151,200	54,432	294,400	105,984	-	-		
Superintendents	4	4	0				58,800	21,168	147,200	52,992	-	-		
Supervisors	9	8	1				141,750	51,030	294,400	105,984	28,400	9,504		
	24	22	1.5				477,750	171,990	1,028,100	370,116	224,400	80,784		
Administrative	5	3	0				47,250	17,010	82,800	29,808	59,400	19,602		
Watch Engineers	WE	10	8	0	28.3	123,477	15%	18,522	141,999	51,120	186,579	67,168	-	
Control Center Operators	CCO	12	9	0	26.1	136,774	15%	20,516	157,290	58,624	258,341	93,003	-	
Boiler Turbine Operators	BTO	18	10	5	24.7	194,577	15%	29,187	223,764	80,555	272,237	98,005	97,573	
Auxiliary Operators	AO	5	13	0	20.5	44,777	15%	6,717	51,494	18,538	293,196	105,551	-	
Auxiliary Operators OTHER	PA	4	0	0	20.5	35,822	15%	5,373	41,195	14,830	0	-	-	
Production Worker	PW	5	0	0	20.4	44,551	15%	6,683	51,234	18,444	0	-	-	
Total Operations		54	38	5		579,978		86,998	688,978	240,111	1,010,353	363,727	97,573	35,128
Maintenance														
Water & Fuels Analyst	WF	5	4	0	25.9	58,537	15%	8,481	65,018	23,408	113,908	41,007	-	
Instrument & Controls Analysts	CAP	11	8	1	26.9	129,356	15%	19,403	148,759	53,553	238,928	85,293	21,229	
Electricians	E	11	8	2	24.8	11,908	15%	1,788	13,692	4,929	218,701	78,732	39,192	
Production Apprentice	PA	0	4	0	20.7	0	15%	0	0	-	91,128	32,805	-	
Special Utility worker	SUW/PW	1	0	0	24.8	10,855	15%	1,628	12,483	4,494	0	-	-	
Tech OPS Support		28	24	3		208,654		31,298	239,952	86,383	660,661	237,838	60,421	
Machinist Blader	MB	1	0	0	25.9	11,307	15%	1,698	13,003	4,681	0	-	-	
Machinist	MM	3	2	0	25.7	33,651	15%	5,048	38,699	13,932	58,498	20,339	-	
Maintenance Mechanics	M	37	30	3	25.7	325,291	15%	48,794	374,085	134,871	564,979	203,392	60,749	
Mechanic Certified Welders	MCW	17	17	4	25.7	168,254	15%	25,238	193,492	69,657	367,236	132,205	80,898	
Mechanical Maintenance		58	49	7		538,503		80,776	619,279	222,940	988,713	355,937	141,747	
Total Maintenance		86	73	10		747,157		112,074	859,231	309,323	1,649,374	593,775	202,168	72,780
NON-RECOVERABLE FUEL														
Supv		1	1	0					0	0	130,000	46,800	-	
Fuel Equipment Operators	FEO	11	11	0	23.8	114,431	20%	22,888	137,317	49,434	288,184	103,746	-	
Production Apprentices	PA	3	3	0	20.4	28,731	20%	5,346	32,077	11,548	87,319	24,235	-	
Fuel Handlers	FH	5	5	0	19.7	42,968	20%	8,594	51,562	18,562	108,212	38,956	-	
		20	20	0		184,130		36,826	220,956	79,544	593,715	213,737	-	
Gannon payroll		189	156	17		1,511,265		235,898	1,526,207	549,435	2,659,727	957,502	299,741	107,907
									Payroll	Fringe	Payroll	Fringe	Payroll	Fringe
									2,051,207	738,435	3,770,627	1,357,428	583,541	208,293
									Payroll	Fringe				
									6,452,709	2,321,193		8,546,402		
									Bayside 6mth adj.	(167,279)	(60,220)			0
									New Total	6,285,430	2,260,973			

1856

Case 9 Jan - Mar, 16
Kelloug Brown & Root

Gannon Station Estimated Straight Time Hourly Cost				
Classification	Number	S.T. Billing Rate	No. of Hrs. Per Day	Daily Cost
Indirect Support Services				
Asst. Proj Mgr. - Joe Givens	1	57,962	4	231.93
Admin - Nancy Daniels	1	45.24	4	180.96
Safety - Danny Gelsinger	1	51,0016	4	204.01
	3		12	616.89
Site Indirect				
General Foreman Gerald Jones	1	35,4432	8	283.55
Supt - Roy Tillis	1	47,0808	8	378.65
Planner - Rick Bramel	1	34,8712	8	278.97
Tool Clerk - Doug Jones	1	26.78	8	214.24
Total Daily Cost	4		32	1,153.40

Classification	Number	S.T. Billing Rate	Total Cost Per (S.T. & Hour Day)	Daily Cost
CORE GROUP PERSONNEL				
Crew Foreman	1	32,4887	8	259.91
Lead man	1	29,2181	8	233.74
Pressure Welders (Craft Validated)	4	27.46	32	878.67
Structural Welders (Craft Validated)	3	27.46	16	439.34
Structural Welders	2	26.65	8	213.21
Operator (Craft Validated)	1	27.46	8	219.67
Boiler Makers (Mechanical)	3	26.65	24	619.63
Chf (Carpenter, Scaffold) (Craft Validated)	1	27.46	8	219.67
MWright (Craft Validated)	3	26.65	16	426.42
TOTAL DAILY COST	19		128	3,630.28
COAL CREW PERSONNEL				
Lead man - Jack Watts	1	29,2181	8	233.74
Structural Welders - Jose Ruiz	2	26,6513	8	213.21
MWright - Bert Frabs	1	27,4566	8	219.67
Helper 1A	2	23,1426	24	555.42
TOTAL DAILY COST	6		48	1,222.05
COAL FIELD CLEAN				
Helper 1A	1	23,1426	8	185.14
Helper 4C	1	16,0218	8	128.17
Helper 5B	3	14,9868	24	359.68
TOTAL DAILY COST	5		40	673.00
PLANT CLEAN				
Helper 1A	1	23,1426	8	185.14
Helper 4B	1	16,7049	16	267.28
Helper 4C	1	16,0218	8	128.17
Helper 5B	11	14,9868	64	959.16
TOTAL DAILY COST	14		96	1,539.75

Classification	Number	S.T. Billing Rate	No. of Hrs. Per Day	Daily Cost
3 P.M.-11 P.M. PERSONNEL				
Leadman (Pressure Welder Operator)	1	29,2181	8	233.74
Pressure Welder	1	26.65	8	213.21
MWright, Instrumentation	1	26.65	8	213.21
Helper 1A	3	23,1426	16	370.28
TOTAL DAILY COST	6		40	1,030.45
11 P.M.-7 A.M. PERSONNEL				
Leadman (Pressure Welder)	1	29,2181	8	233.74
MWright, Mechanics	2	26.65	8	213.21
Helper 1A	4	23,1426	16	370.28
TOTAL DAILY COST	7		32	817.24
Totals	61		428	10,543.03
Total Average Cost (Per Person Per Hour)	7.02	69 days		882,047
Total Average Cost (Per Person Per Day)	173.49	Man		355,061
		Coal Field		104,772
		Coal Field		122,224
				82,046.72

Classification	Number	S.T. Billing Rate	Total Cost (S.T. & Hour Day)	Daily Cost
AVALONITE PAINTING COMPANY				
PS (PAINT SUPERVISOR)	1	29.91	29.91	29.91
FOR (WORKING FOREMAN)	1	26.80	26.80	26.80
FOR (JOURNEYMAN)	1	24.62	24.62	24.62
TOTAL	3			81.33
			69 days	26.872

Classification	Number	S.T. Billing Rate	Total Cost (S.T. & Hour Day)	Daily Cost
ELECTRIC MACHINERY ENTERPRISES				
GEN FOREMAN	1	39.66	39.66	39.66
FOREMAN	1	33.72	33.72	33.72
LEAD MAN	1	32.04	32.04	32.04
TOTAL	3			105.42

Case 9 Mar 16 - Am. 31
Kelloug Brown & Root

Gannon Station Estimated Straight Time Hourly Cost				
Classification	Number	S.T. Billing Rate	No. of Hrs. Per Day	Daily Cost
Indirect Support Services				
Asst. Proj Mgr. - Joe Givens	1	57,962	4	231.93
Admin - Nancy Daniels	1	45.24	4	180.96
Safety - Danny Gelsinger	1	51,0016	4	204.01
	3		12	616.89
Site Indirect				
General Foreman Gerald Jones	1	35,4432	8	283.55
Supt - Roy Tillis	1	47,0808	8	378.65
Planner - Rick Bramel	1	34,8712	8	278.97
Tool Clerk - Doug Jones	1	26.78	8	214.24
Total Daily Cost	4		32	1,153.40

Classification	Number	S.T. Billing Rate	Total Cost Per (S.T. & Hour Day)	Daily Cost
CORE GROUP PERSONNEL				
Crew Foreman	1	32,4887	8	259.91
Lead man	1	29,2181	8	233.74
Pressure Welders (Craft Validated)	4	27.46	32	878.67
Structural Welders (Craft Validated)	1	27.46	16	439.34
Structural Welders	1	26.65	8	213.21
Operator (Craft Validated)	1	27.46	8	219.67
Boiler Makers (Mechanical)	2	26.65	24	619.63
Chf (Carpenter, Scaffold) (Craft Validated)	1	27.46	8	219.67
MWright (Craft Validated)	2	26.65	16	426.42
TOTAL DAILY COST	14		128	3,630.28
COAL CREW PERSONNEL				
Lead man - Jack Watts	1	29,2181	8	233.74
Structural Welders - Jose Ruiz	2	26,6513	8	213.21
MWright - Bert Frabs	1	27,4566	8	219.67
Helper 1A	2	23,1426	24	555.42
TOTAL DAILY COST	6		48	1,222.05
COAL FIELD CLEAN				
Helper 1A	1	23,1426	8	185.14
Helper 4C	1	16,0218	8	128.17
Helper 5B	2	14,9868	24	359.68
TOTAL DAILY COST	4		40	673.00
PLANT CLEAN				
Helper 1A	1	23,1426	8	185.14
Helper 4B	1	16,7049	16	267.28
Helper 4C	1	16,0218	8	128.17
Helper 5B	5	14,9868	64	959.16
TOTAL DAILY COST	8		96	1,539.75

Classification	Number	S.T. Billing Rate	No. of Hrs. Per Day	Daily Cost
3 P.M.-11 P.M. PERSONNEL				
Leadman (Pressure Welder Operator)	1	29,2181	8	233.74
Pressure Welder	1	26.65	8	213.21
MWright, Instrumentation	1	26.65	8	213.21
Helper 1A	3	23,1426	16	370.28
TOTAL DAILY COST	6		40	1,030.45
11 P.M.-7 A.M. PERSONNEL				
Leadman (Pressure Welder)	1	29,2181	8	233.74
MWright, Mechanics	2	26.65	8	213.21
Helper 1A	4	23,1426	16	370.28
TOTAL DAILY COST	7		32	817.24
Totals	49		428	10,543.03
Total Average Cost (Per Person Per Hour)	8.73	120 days		1,042,859
Total Average Cost (Per Person Per Day)	216.98	Man		635,061
		Coal Field		187,861
				218,937

Classification	Number	S.T. Billing Rate	Total Cost (S.T. & Hour Day)	Daily Cost
AVALONITE PAINTING COMPANY				
PS (PAINT SUPERVISOR)	1	29.91	29.91	29.91
FOR (WORKING FOREMAN)	1	26.80	26.80	26.80
FOR (JOURNEYMAN)	1	24.62	24.62	24.62
TOTAL	3			81.33
			69 days	26.872

Classification	Number	S.T. Billing Rate	Total Cost (S.T. & Hour Day)	Daily Cost
ELECTRIC MACHINERY ENTERPRISES				
GEN FOREMAN	1	39.66	39.66	39.66
FOREMAN	1	33.72	33.72	33.72
LEAD MAN	1	32.04	32.04	32.04
TOTAL	3			105.42

Case 9 Sept - Dec. 31
Kelloug Brown & Root

Gannon Station Estimated Straight Time Hourly Cost				
Classification	Number	S.T. Billing Rate	No. of Hrs. Per Day	Daily Cost
Indirect Support Services				
Asst. Proj Mgr. - Joe Givens	1	57,962	4	231.93
Admin - Nancy Daniels	1	45.24	4	180.96
Safety - Danny Gelsinger	1	51,0016	4	204.01
	3		12	616.89
Site Indirect				
General Foreman Gerald Jones	1	35,4432	8	283.55
Supt - Roy Tillis	1	47,0808	8	378.65
Planner - Rick Bramel	1	34,8712	8	278.97
Tool Clerk - Doug Jones	1	26.78	8	214.24
Total Daily Cost	4		32	1,153.40

Classification	Number	S.T. Billing Rate	Total Cost Per Hour	Daily Cost (S.T. & Hour Day)
CORE GROUP PERSONNEL				
Crew Foreman	1	32,4885	8	259.91
Lead man	1	29,21805	8	233.74
Pressure Welders (Craft Validated)	2	27.46	32	878.67
Structural Welders (Craft Validated)	1	27.46	16	439.34
Structural Welders	1	26.65	8	213.21
Operator (Craft Validated)	1	27.46	8	219.67
Boiler Makers (Mechanical)	1	26.65	24	619.63
Chf (Carpenter, Scaffold) (Craft Validated)	1	27.46	8	219.67
MWright (Craft Validated)	1	26.65	16	426.42
TOTAL DAILY COST	10		128	3,330.26
COAL CREW PERSONNEL				
Lead man - Jack Watts	1	29,21805	8	233.74
Structural Welders - Jose Ruiz	1	27,45655	8	213.21
MWright - Bert Frabs	1	27,45655	8	219.67
Helper 1A	1	23,1426	24	555.42
TOTAL DAILY COST	4		48	1,222.05
COAL FIELD CLEAN				
Helper 1A	1	23,1426	8	185.14
Helper 4C	1	16,0218	8	128.17
Helper 5B	1	14,9868	24	359.68
TOTAL DAILY COST	3		40	673.00
PLANT CLEAN				
Helper 1A	1	23,1426	8	185.14
Helper 4B	2	16,7049	16	267.28
Helper 4C	1	16,0218	8	128.17
Helper 5B	2	14,9868	64	959.16
TOTAL DAILY COST	6		96	1,539.75

Classification	Number	S.T. Billing Rate	No. of Hrs. Per Day	Daily Cost
3 P.M.-11 P.M. PERSONNEL				
Leadman (Pressure Welder Operator)	1	29,21805	8	233.74
Pressure Welder	1	26.65	8	213.21
MWright, Instrumentation	1	26.65	8	213.21
Helper 1A	3	23,1426	16	370.28
TOTAL DAILY COST	6		40	1,030.45
11 P.M.-7 A.M. PERSONNEL				
Leadman (Pressure Welder)	1	29,21805	8	233.74
MWright, Mechanics	2	26.65	8	213.21
Helper 1A	5	23,1426	16	370.28
TOTAL DAILY COST	8		32	817.24
Totals	41		428	10,543.03
Total Average Cost (Per Person Per Hour)	16.44	6 days		
Total Average Cost (Per Person Per Day)	254.12	Man		
		Coal Field		

Classification	Number	S.T. Billing Rate	Total Cost (S.T. & Hour Day)	Daily Cost
AVALONITE PAINTING COMPANY				
PS (PAINT SUPERVISOR)	1	29.91	29.91	29.91
FOR (WORKING FOREMAN)	1	26.80	26.80	26.80
FOR (JOURNEYMAN)	0	24.62	0.00	0.00
TOTAL	2			56.71
			69 days	26.872

Classification	Number	S.T. Billing Rate	Total Cost (S.T. & Hour Day)	Daily Cost
ELECTRIC MACHINERY ENTERPRISES				
GEN FOREMAN	1	39.66	39.66	39.66
FOREMAN	1	33.72	33.72	33.72
LEAD MAN	1	32.04	32.04	32.04
TOTAL	3			105.42

JOURNEYMAN	7	30.53	213.73	1,709.62
APPRENTICE A77	1	22.84	72.84	183.48
TOTAL	11			2,738.73

88 days 198,819

CLASSIFICATION	NUMBER	S.T. BALANCE		DAILY COST (S.T. 8 HOUR DAY)
		FOR ONE HOUR	PER HOUR	
INSUL F0RE A881-1	1	48 89673	48 89673	389.57
INSUL F0RE A907-4	1	48 9683	48 9683	375.75
INSUL MECH A905	1	40 79255	40 79255	322.34
SMTL F0RE S197	1	43 88	43 884	351.07
SMTL MECH S195	2	36 22	72 44	579.52
TECH. SUPPORT (4 hours)	0	24 45	24 45	-
TOTAL	6			2,018.26

81 days 111,864

Total Core cost per day As of 09/01/01 18,990.21
 Inflated by 3% for 2002 18,990.21
 Times 260 days = Core cost for 2002 4,157,453.33

1858

JOURNEYMAN	4	30.53	122.13	877.04
APPRENTICE A77	1	24.84	77.84	183.48
TOTAL	5			1,060.53

129 days 240,871

CLASSIFICATION	NUMBER	S.T. BALANCE		DAILY COST (S.T. 8 HOUR DAY)
		FOR ONE HOUR	PER HOUR	
INSUL F0RE A881-1	1	48 89673	48 89673	389.57
INSUL F0RE A907-4	1	48 9683	48 9683	375.75
INSUL MECH A905	1	40 79255	40 79255	322.34
SMTL F0RE S197	1	43 88	43 884	351.07
SMTL MECH S195	1	36 22	36 22	289.78
TECH. SUPPORT (4 hours)	0	24 45	24 45	-
TOTAL	5			1,728.43

129 days 297,419

JOURNEYMAN	1	30.53	30.53	244.78
APPRENTICE A77	1	22.84	22.84	183.48
TOTAL	2			1,371.18

8 days

CLASSIFICATION	NUMBER	S.T. BALANCE RATE		TOTAL COST PER HOUR	DAILY COST (S.T. 8 HOUR DAY)
		FOR ONE HOUR	PER HOUR		
INSUL F0RE A881-1	0	48 89673	0	0	375.75
INSUL F0RE A907-4	1	48 9683	48 9683	375.75	372.34
INSUL MECH A905	1	40 79255	40 79255	322.34	351.07
SMTL F0RE S197	1	43 88	43 884	351.07	289.78
SMTL MECH S195	1	36 22	36 22	289.78	-
TECH. SUPPORT (4 hours)	0	24 45	24 45	-	-
TOTAL	4				1,338.92

88 days 113,988

Gannon Coal Fired Operations Budget

EXHIBIT WMZ-1
Page 45 of 45


<u>Resource</u>	<u>Case 9 2003</u>	<u>Description</u>
03	75,000	Safety Budget (benefitting 931)
03	15,000	Welding Equip - make repairs to torches, regulators, etc
03	500,000	City of Tampa
03	70,000	Care Team - Station Nurse
03	110,000	Demineralizer Water Trailer
03	85,000	Hazardous/industrial waste
03	85,000	Waste & Trash disposal
03	500,000	Solid Material Disposal
03	12,000	Herbicides in ponds
03	167,000	RO System maint contract
03	30,000	Spectrum CEM Software
03	8,000	Spill Response Wildlife/Toxicity Testing
03	2,000	Toxicity Testing
03	13,000	NPDES Annual Fee
03	351,000	KBR core group plus (20% OT)
03	30,000	Land Water consulting fees
03	-	Land Compliance
07	57,000	Safety Budget (benefitting 931)
07	127,000	Betz Deaborn Boiler Chemicals
03	50,000	Green Mussels
07	27,000	Bulk Hydrogen
07	60,000	Lime Slurry
07	85,000	Liquid Caustic
07	18,000	Sulphuric Acid
07	56,000	Oil Products & Lubricants
07	13,000	Bottled Water
07	12,000	Office Supplies
07	500	Print Machine Supplies
07	1,500	Magazine subscriptions
07	2,000	Flowers
07	3,000	Computer Enhancements
07	62,000	Welding - purchase gases,oxygen etc.
06	24,000	Safety Budget (benefitting 931)
06	28,000	Hand Held Radios
06	378,000	Stores Issues
08	15,000	Telecom Business Lines
09	18,000	Travel - Gannon
09	-	Safety Budget (benefitting 931) - Travel
10	3,000	Safety Budget (benefitting 931) - Misc. costs
10	5,000	Travel - Gannon (Misc. costs)
10	300,000	DEP 'Air' Annual Oper. Fee
10	7,000	Staff & Misc meetings
10	10,000	Annual E-I Team Recognition
10	3,500	Employee Retirements
10	1,000	Professional Dues
15	4,000	Travel - Gannon (Food)
15	10,000	Safety Budget (benefitting 931) - Food
15	3,000	Employee Retirements
15	3,000	Annual E-I Team Recognition
15	4,000	Annual Employee Get-together
15	9,000	Plant Overtime Meals
30	117,000	Temporary Help
39	500	Safety Budget (benefitting 931) - Person. Auto Reimbur.
39	7,000	Personal Auto Reimbursement
58	43,000	Vehicles
60	640,000	Facility services.
	<u>4,260,000</u>	<u>Total</u>

1859

Hazardous Energy Control Program

Energy Supply Department

October 23, 2000



TAMPA ELECTRIC

Hazardous Energy Control Program					
Tampa Electric Company					
Energy Supply Department					
Creation Date:	01/18/2000	Last Modified:	10/30/2000	Expiration Date	01/18/2001
Document #:		Maintained by:	Nancy P. Hitchins	Approved by:	
Audience: All Plant Personnel					

Table of Contents

I.	BASIC REQUIREMENT	1
II.	SCOPE	1
III.	RESPONSIBILITY	1
IV.	HAZARDOUS ENERGY CONTROL APPLICATION	2
	A. Preparation for Shutdown	
	B. Shutdown	
	C. Isolation	
	D. Application of Tagout Devices (Individual or Group)	
	E. Stored/Hazardous Energy	
	F. Initial Verification/Test	
	G. Notification	
	H. Individual Verification	
	I. Release from Tagout	
	J. Committeeing a Tagout Device	
	K. Special Tagout Situations	
	L. Group Protection Procedures	
	M. Transition of Tagout at Shift Change	
V.	TRAINING	12
VI.	HAZARDOUS ENERGY CONTROL PROCEDURAL INSPECTIONS	13
VII.	OUTSIDE CONTRACTOR COMPLIANCE PROCEDURES	13
VIII.	EQUIPMENT DESIGN	15
IX.	DISCIPLINE FOR NON-COMPLIANCE	15

- APPENDIX A – DEFINITIONS
- APPENDIX B – HAZARDOUS ENERGY CONTROL PROCEDURE
- APPENDIX C – HAZARDOUS ENERGY CONTROL COMMITTEEING FORM
- APPENDIX D – TAGGING DEVICE REQUIREMENTS/ORDERING INFORMATION
- APPENDIX E – PERIODIC/ANNUAL INSPECTION FORM
- APPENDIX F – MASTER JOB TAG WORK PERMIT

I. BASIC REQUIREMENT

The Tampa Electric Company - Energy Supply Department - Hazardous Energy Control Program has been established, in accordance with OSHA Standards to prevent the unexpected release of potentially hazardous energy (e.g. electrical, hydraulic, thermal, chemical, pneumatic, potential, or radiation) during the maintenance and servicing of equipment. This Hazardous Energy Control Program consists of a comprehensive set of equipment-specific Hazardous Energy Control Procedures, employee training requirements, and guidelines for the periodic inspection of the Hazardous Energy Control procedures and program.

II. SCOPE

The Energy Supply Hazardous Control Program applies to the servicing and maintenance of equipment at all Tampa Electric Company facilities under the jurisdiction of the Energy Supply Department.

The Hazardous Energy Control Supervisor has tagout authority and control over the equipment in all generation stations.

The division of responsibility between the Energy Supply Department and the Energy Delivery Department will be the centerline of the unit transformers at the generation stations, unless otherwise indicated in specific tagout procedures or switching orders.

III. RESPONSIBILITY

- A. It is the responsibility of Energy Supply Management to approve, implement, monitor and enforce the Energy Supply Hazardous Energy Control Program. Joint responsibility for continuous improvement of the Program is shared between craft and management through a partnership dedicated to protection of workers and compliance with regulations.
- B. Each facility shall establish specific Hazardous Energy Control Procedures for the shutdown, isolation, tagout, verification and setup for return to service for the control of hazardous energy for each piece of equipment and/or system. An Authorized Employee shall review these procedures for accuracy at least annually, or, upon equipment changes/additions. Facility management is responsible for the development and maintenance of the HEC procedures.
- C. All employees are responsible for assuring that all applicable procedures and Safe Work Practices are followed in the control of hazardous energy.
- D. It is the responsibility of the Plant General Manager or Plant Manager to select competent and qualified employees to act as Hazardous Energy Control Supervisors. The Hazardous Energy Control Supervisor is the person under whose orders the Hazardous Energy Control Procedures are performed.
- E. It is the responsibility of the Hazardous Energy Control Supervisor to assure that competent and qualified employees are assigned to act as Hazardous Energy Control Operators. The Hazardous Energy Control Operator is the person performing the shutdown, isolation, tagout, verification and set-up for each piece of equipment and/or system, as directed by the Hazardous Energy Control

Supervisor. Coordination between Energy Supply and Energy Delivery:

1. When the Energy Supply Department requests clearance on a circuit or piece of equipment that is under the jurisdiction of the Energy Delivery Department, the switching and tagging shall be done under the orders of the System Dispatcher and shall follow Tampa Electric Company's Safe Work Practices, sections 218 and 522, which shall comply with OSHA standard 1910.269 paragraphs (l), (m), (n) and others that may be applicable.
 2. System Dispatchers shall be informed of all Hazardous Energy Control requests that will make generating equipment unavailable or that will curtail station capability.
 3. When the System Dispatcher requests a circuit or piece of equipment that is under the jurisdiction of the Energy Supply Department, the tagout shall be done under the orders of the Hazardous Energy Control Supervisor in accordance with Energy Supply's Hazardous Energy Control Program.
- F. Tampa Electric Company's Positive Discipline Program applies to any violation of the mandatory provisions of this Program.
- G. Departmental Safety Staff shall periodically monitor all areas for compliance with this program.
- H. Station management is responsible for coordinating work of outside contractors and will work jointly with the Hazardous Energy Control Supervisor in the implementation of the Hazardous Energy Control Program for outside contractors.

IV. HAZARDOUS ENERGY CONTROL APPLICATION and REMOVAL

Prior to performing servicing and/or maintenance on any system or equipment under the jurisdiction of Tampa Electric Company, Energy Supply Department, all elements of the Hazardous Energy Control Program must be satisfied.

A. Preparation for Shutdown

1. The Hazardous Energy Control supervisor, or designee, will validate the written tagging request.
2. The Hazardous Energy Control Supervisor and the Primary Authorized Employee will jointly determine the scope of tagging requirements.
3. Prior to beginning a Hazardous Energy Control Procedure, the Hazardous Energy Control Supervisor, or their qualified designee, shall verbally notify all affected personnel.

B. Shutdown

The HEC operator shall assure the state of shut down by utilizing the specific

HEC procedure.

The Hazardous Energy Control Operator shall turn OFF or shut down the equipment in an orderly manner, utilizing the specific Hazardous Energy Control Procedure..

C. Isolation

The Hazardous Energy Control Operator isolate the equipment/system from the energy source(s), as described in the Hazardous Energy Control Procedure. All energy isolating devices that are needed to control the energy to the machine or equipment shall be physically located and operated in such a manner as to isolate the machine or equipment from energy sources.

D. Application of Tagout Devices (Individual or Group)

1. Tagout Devices

NOTE: Tagout devices are essentially warning devices attached to energy isolating devices and do not provide physical restraint on those devices.

- a. Only approved tagout devices, including means of attachment, ordered through Tampa Electric Company Materials Management System, Appendix D, shall be used for the control of hazardous energy.
 - b. Tagout devices applied to energy isolating devices shall identify:
 1. the Hazardous Energy Control Operator applying it;
 2. the Master Tag number, and;
 3. a description of the Hazardous Energy Control device to which the tag is being attached.
- ~~2.~~ A Danger tag must be affixed to EACH energy isolating device by the Hazardous Energy Control Operator, as described in the Hazardous Energy Control Procedure, in the following manner.
3. Tagout devices will be securely affixed to each energy-isolating device so that they cannot be inadvertently or accidentally detached during use.
 - a. Tagout devices shall be attached in such a manner as will clearly indicate that the operation or movement of energy isolating devices from the "safe" or OFF position is prohibited.
 - b. Tagout devices shall be fastened at the same point at which a lock would be attached.
 - e. Where there is no point at which a lock may be fastened, additional hardware will be utilized to eliminated the likelihood of inadvertent energization, such as "clamshells", chains, and switch

covers.

- d. Tagout devices shall not be removed until they are properly signed off.
 - e. Tagout devices shall not be by-passed, ignored, or otherwise defeated.
4. Only the Hazardous Energy Control Operator, under the authority of the Hazardous Energy Control Supervisor, utilizing equipment/system specific procedures, may apply tags to equipment energy isolating devices.
5. If the Hazardous Energy Control Operator finds the procedure inadequate during the isolation of the system or equipment, the tagout is to cease.
- a. The Hazardous Energy Control Supervisor will be notified to inspect the system or equipment.
 - b. He/she will record any required changes to the Hazardous Energy Control Procedure, in writing, on the procedure form, and all authorized and affected employees shall be made aware of the changes.
 - c. A safety work order will be generated by the Hazardous Energy Control Supervisor to ensure that the changes, if permanent, are made to the master copy of the Hazardous Energy Control Procedure.
6. If the tagging request or list specifies that certain equipment not be tagged until a later time, those tags for the equipment shall be hung behind the Master Job Tag, on the Master Board, until the equipment is secured for tagging.

E. Stored/Hazardous Energy

- 1. Following the application of tags to energy isolating devices, all potentially hazardous stored or residual energy shall be relieved, disconnected, restrained, and otherwise rendered safe.
- 2. If there is a possibility of re-accumulation of stored energy to a hazardous level, verification of isolation shall be continued, by the Primary Authorized Employee or their designee, until the servicing or maintenance is completed, or until the possibility of accumulation no longer exists.

F. Initial Verification/Test

After application of tags, and prior to commencement of work, the Hazardous Energy Control Operator shall, according to the equipment specific procedures:

- 1. operate the equipment/process controls (push buttons, switches, etc.) to

verify that energy isolation has been accomplished,

2. and check the equipment/system by use of test instruments when appropriate, and visually inspect to verify that potentially hazardous energy isolation has been accomplished.

G. Notification

Upon successful isolation of the system, the Hazardous Energy Control Supervisor shall verbally communicate to the Primary Authorized Employee that isolation and tagout are complete, so that verification by the Primary Authorized Employee may begin. The Hazardous Energy Control Supervisor's initials on the Master Job Tag shall signify that verbal communication has taken place.

H. Individual Verification

Upon receiving notification from the Hazardous Energy Control Supervisor, each Primary Authorized Employee, upon verification of isolation, shall sign on to the Master Tag..

An Authorized Employee shall verify Hazardous Energy Control prior to signing on to the Master Job Tag.

NOTE: An individual's signature on and off the Master Job Tag or the Master Job Tag Work Permit represents the affixation and removal of a personal tagout device.

If the situation arises that a Primary Authorized Employee, who remains signed on to the Master Job Tag, finds themselves working alone on a later shift as an Authorized Employee, he/she will sign off the Master Job Tag, verify, and sign on to the Master Job Tag.

I. Release from Tagout

1. Prior to removing their personal tagout device (signing off), each Authorized Employee must ensure the equipment/system is completely reassembled and all tools/materials have been removed from and are clear of the machine/equipment.
2. Each tagout device shall be removed (signed off) by the Authorized Employee applying it (signed on) at the end of their shift.
 - a. No person may sign on or sign off for another person.
 - b. If the work is completed, and the Authorized Employee/contractor failed to sign off from their personal tagout device, the personal tagout devices may be removed by using the Committeeing procedure:
3. When working under Group Protection, the Primary Authorized Employee must ensure that the work is complete, all tools removed, and that each of their crew has signed off on the Master Job Tag Work Permit or Master

Job Tag.

4. The Hazardous Energy Control Operator shall be notified by the Hazardous Energy Control Supervisor when the work is complete and all personal tagout devices have been signed off.
5. Only after the Hazardous Energy Control Operator has verified, through a visual inspection, that the work area is clear of all personnel, and that nonessential items have been removed and components are operationally intact, may the Danger tags be removed from the equipment/system.
6. Prior to startup, all equipment guards shall be in place and properly adjusted.
7. The Hazardous Energy Control Operator shall verbally notify affected employees that the servicing and/or maintenance is complete, and the equipment/system is ready for use.

J. Committeeing a Tagout Device

1. The Hazardous Energy Control Supervisor must first verify that the employee who remains signed on to the tagout device is not at the facility.
2. All reasonable efforts to contact the employee shall be made in order for that person to sign off of the personal tagout device.
3. The Hazardous Energy Control Supervisor initiates the completion of the Committeeing Form, Appendix C.
4. Prior to removal of tags, the Hazardous Energy Control Supervisor shall:
 - a. obtain written consent from the facility Superintendent of Plant Operations, or equivalent; and
 - b. obtain written consent from the Production Supervisor, or equivalent; and
 - c. notify the Duty person/manager.

NOTE: At facilities where production supervisors do not exist, a competent representative of the craft performing work on the equipment/system will be identified.

5. MJTWP & Tagout Device(s) shall be signed by all Committee members.
6. If a system is tagged to a contractor employee, a competent representative of that organization must be contacted for consent.
7. The immediate supervisor of the employee shall be informed of the tag removal, and will inform and review the incident with the employee when that employee returns to work.

8. All committee tags go behind MJT;
9. The committeeing form, once completed, must be routed to the station general manager, and finally to the station safety coordinator.

K Special Situations

Whenever any changes take place during the control of hazardous energy sources, all Authorized Employees shall be verbally notified. The Master Job Tag Work Permit shall be signed off by each employee to indicate notification of the changes, and a new Master Job Tag Work Permit shall be issued prior to starting work.

1. Testing or positioning of machines

In situations where the energy isolating device(s) are tagged, and there is a need for testing or positioning of the equipment/system, the following sequence shall apply:

- a. The work area shall be inspected to ensure that nonessential items have been removed and that machine or equipment components are operationally intact.
- b. All affected and Authorized Employees shall be notified of the intended changes, and Authorized Employees shall be required to sign off of the Master Job Tag Work Permit. A new Master Job Tag Work Permit shall be issued, as required, indicating modifications, in writing, to the Hazardous Energy Control Procedure.
- c. The work area shall be checked to ensure that all employees have been safely positioned or removed.
- d. When the tagout device has been signed off by all primary authorized employees, the tags may be removed. Indicate reason for removal, in writing, on tag, and place behind the Master Job Tag.
- e. Proceed with testing.
- f. If equipment is re-tagged after testing, numbers for the new local tags shall correspond to the numbers on the removed tags. The word "reissue" will be written on the new local tag. When the 'new' tag is issued the tag that was signed & removed shall then be taken from behind the Master Job Tag and placed in the facility Hazardous Energy Control Tagging file.
- g. De-energize and re-tag energy isolating devices to continue work.
- h. Operate controls, switches, etc. to verify energy isolation as outlined in Section IV, A through H and L of the HEC Program.

2. Physical Removal of Isolation Equipment/Devices that are Tagged:

In situations where a device with a Danger tag must be removed for maintenance, the following provisions shall be made:

- a. Electrical Breakers: If a breaker must be removed that has an Electrical Danger Tag affixed to it:
 - i. Additional tagging shall be performed to isolate the device safely prior to removal.
 - ii. The tag on the breaker will then be signed off by all Primary Authorized Employees.
 - iii. The Primary Authorized Employee must reinspect for compliance with the plant's Energy Control Program and insure that other Authorized Employees are aware of their rights to reinspect the tagging procedure.
 - iv. All affected and Authorized Employees shall be notified of the intended changes, and Authorized Employees shall be required to sign off of the Master Job Tag Work Permit. A new Master Job Tag Work Permit shall be issued, as required, indicating modifications, in writing, to the Hazardous Energy Control Procedure.
 - v. Any tags removed will be placed behind the Master Job Tag.
 - vi. A new tag shall be re-issued, labeled "re-issue", and the same tag number.
- b. Valves: If a valve must be removed that has a Mechanical Danger Tag affixed to it.
 - i. Additional tagging shall be performed to isolate the device safely prior to removal.
 - ii. The tag on the valve will then be signed off by all Primary Authorized Employees.
 - iii. Any tags removed will be placed behind the Master Job Tag.
 - iv. the Primary Authorized Employee must reinspect for compliance with the plant's Energy Control Program and insure that other Authorized Employees are aware of their rights to reinspect the tagging procedure.

3. When troubleshooting or performing routine/repetitive servicing energized

equipment/systems during servicing/repairs, safety-related work practices shall be employed. The specific safety-related work practices shall be consistent with the nature and extent of the associated hazards.

4. Work on cord and plug connected electric equipment for which exposure to the hazards of unexpected energization or start up of the equipment is controlled by the unplugging of the equipment from the energy source and by the plug being under the exclusive control of the employee performing the servicing or maintenance.

L. Group Protection Procedures

1. The Hazardous Energy Control Supervisor has overall responsibility for the adherence to the Energy Supply Hazardous Energy Control Program. He/she will coordinate Group Protection procedures with the Production Supervisor or equivalent and/or the Primary Authorized Employee, who oversees each crew or group, to ensure continuity of protection.
2. The Master Job Tag will be used on ALL jobs.
3. Master Job Tags will be assigned a number by the Hazardous Energy Control Supervisor.
 - a. This Master Job Tag number will be written on all Energy Supply Department Electrical Danger or Mechanical Danger tags related to this job.
 - b. Each of these tags will be numbered in numerical order. The Master Job Tag number, the individual tag number, the equipment name, the energy isolating device to which it will be attached, and the name of the Hazardous Energy Control Operator applying the tag will be required on these related tags.
 - c. Master Job Tag boards will be located at designated areas within each station.
4. Utilization to the Master Job Tag/Master Job Tag Work Permit
 - a. A Master Job Tag Work Permit will be used as an extension of the Master Job Tag, when one or more employees are working under the jurisdiction of a Primary Authorized Employee.
 - b. Hazardous Energy Control Operators shall follow specific Hazardous Energy Control Procedures to shutdown, isolate and secure the system/equipment.
 - c. Upon completion of the shutdown, the Hazardous Energy Control Supervisor identifies the Production Supervisor and/or the Primary Authorized Employee and enters their name in the "tagged to" column of the Master Job Tag, indicating the equipment has been shutdown, isolated, and tagged as requested.

- d. The Hazardous Energy Control Supervisor will indicate that the equipment/system is in a "hold condition", being held by the Production Supervisor, or equivalent, by writing "Holder" in the sign on column of the Master Job Tag.
 - 1. The Production Supervisor, or equivalent, may, upon verification of hazardous energy isolating devices, sign on to the Master Job Tag.
 - 2. The Production Supervisor, or equivalent, may do equipment/system inspections as needed by signing on and signing off the Master Job Tag Work Permit, as an Authorized Employee, without signing on to the Master Job Tag. This allows the inspection without the Production Supervisor having to give up their "Holder" status on the Master Job Tag.
- e. Each Primary Authorized Employee shall verify that the hazardous energy controls are in place. Upon verification, he/she will sign on to the Master Job Tag.
- f. The Primary Authorized Employee shall then sign and date the Master Job Tag Work Permit, the group protection device for their crew.
- g. Each Authorized Employee is assured the right to verify that the hazardous energy has been effectively isolated and controlled prior to signing the Master Job Tag Work Permit.
- h. Further verification may be necessary as outlined in IV.E.2 "Stored/Hazardous Energy".
- i. Each employee working on the machine or equipment shall sign on and sign off the Master Job Tag Work Permit or related Master Job Tag.
- j. The Master Job Tag or Master Job Tag Work Permit shall clearly identify each employee who is being protected by it.
- k. Signature, date, and time for sign-in and sign-out are recorded and retained by the Primary Authorized Employee for that group on the Master Job Tag Work Permit.
- l. Upon completion of the Master Job Tag Work Permit, the Primary Authorized Employee will retain the Master Job Tag Work Permit in their respective shop.
- m. Prior to beginning work and every shift thereafter, upon verification of energy controls, each Primary Authorized Employee must initiate a new Master Job Tag Work Permit.
- n. Upon completion of job requirements, the Primary Authorized

Employee shall sign off the Master Job Tag, only after all Authorized Employees in their crew have signed off the Master Job Tag Work Permit.

- o. The Production Supervisor (Holder), or equivalent, shall return each completed Master Job Tag Work Permit to the Hazardous Energy Control Supervisor.
- p. The Master Job Tag Work Permits shall then be attached to the Master Job Tag and filed along with the Hazardous Energy Control Procedural forms and related tags.
- q. These documents shall be placed in the facility Hazardous Energy Control tagging file for a minimum of 30 days
- r. During the progress of work, the Primary Authorized Employee shall ensure the Master Job Tag Work Permit accurately represents exposed employees.

M. Transition of Tagout at Shift Change

If the tagout continues beyond the end of the shift:

- 1. The Primary Authorized Employee shall not sign off the Master Job Tag Work Permit until all Authorized Employees on the Master Job Tag Work Permit have signed off.
- 2. The Primary Authorized Employee shall not sign off the Master Job Tag until:
 - a. the Master Job Tag Work Permit has been signed off by all Authorized Employees and,
 - b. Protection is provided by another Primary Authorized Employee, or, another "Holder", as indicated in the "Tagged To" column, or, the work has been completed.
- 3. Each departing Authorized Employee shall sign off the Master Job Tag or Master Job Tag Work Permit at the end of each shift.
 - a. In the event an Authorized Employee does not sign off the Master Job Tag Work Permit, the procedures for committing shall be followed.
- 4. The "Holder" of a Master Job Tag (as outlined in section IV.L, Group Protection Procedures) and their designated Primary Authorized Employees are the only employees who do not have to sign off the Master Job Tag at the end of the shift.

V. TRAINING

Tampa Electric Company, Energy Supply Department, will implement a Hazardous Energy Control Training Program, which will include authorized, affected and other employees. Training shall be provided prior to assignment. Training may be classroom or on-the-job format.

- A. Authorized Employee training shall include:
 - 1. The purpose and use of the Hazardous Energy Control Program.
 - 2. The recognition of hazardous energy sources.
 - 3. The type and magnitude of the energy present or available in the workplace.
 - 4. The methods and means necessary for energy isolation and control.
 - 5. Means of verification of effective energy control and the purpose of the procedures to be used.
 - 6. The limitations of tags.
- B. Affected employee and other employee training shall include:
 - 1. The purpose and use of the Hazardous Energy Control Procedures.
 - 2. The prohibitions to attempt to re-start or re-energize any machines/equipment that are tagged out.
 - 3. The limitations of tags.
- C. Upon successful completion, a record of this training, including employee's name and date of training shall be maintained in a centralized recordkeeping system.
- D. Retraining shall take place annually, or, as needed, based upon equipment changes, employee transfer or employee performance.

VI. HAZARDOUS ENERGY CONTROL PROCEDURAL INSPECTIONS

- A. Hazardous Energy Control Procedures (Appendix B) will be stored in controlled files at each facility. Each of the facility's active Hazardous Energy Control Procedures shall be inspected at least annually to assure accuracy and effectiveness.
1. Periodic Procedural Inspections – Utilizing Appendix E, each Hazardous Energy Control Procedure, when used at least once a year, shall be inspected, at least annually, under the administration of the facility Safety Coordinator, by an Authorized Employee who is not using the procedure at the time, and shall include:
 - a. The equipment/system specific Hazardous Energy Control Procedure.
 - b. The employees involved in the inspection, and the date.
 - c. Whether the procedural steps are being followed.
 - d. A review between the inspector and each authorized and affected employee of that employee's responsibility under the Hazardous Energy Control Program.
 - e. Identification and corrective action taken on any deviations or inadequacies of the procedure to provide protection equivalent to lockout.
 - f. The Hazardous Energy Control Procedure Periodic/Annual Inspection Form will be kept on file by the facility Safety Coordinator.
 2. The facility Safety Coordinator will certify that the required inspections have been accomplished by reviewing and signing the Hazardous Energy Control Procedure Periodic/Annual Inspection Form, Appendix E.

VII. OUTSIDE CONTRACTOR COMPLIANCE PROCEDURES

A. General

1. Outside contractors are required to abide by all applicable OSHA Control of Hazardous Energy Standards as well as Tampa Electric Company, Energy Supply requirements.
2. Tampa Electric Company, Energy Supply, shall inform the contractor of the applicable hazardous energy sources, the type and magnitude of energy available, and the means and methods necessary for energy isolation and control.
3. Tampa Electric Company and outside contractors shall exchange information regarding the Energy Supply Hazardous Energy Control Program to be used by each employer's workers. Each employer shall ensure that their personnel understand and comply with restrictions and

prohibitions of the energy control program being used.

4. Outside contractors shall utilize their own "Hazardous Energy Control Program" for protection of their employees only after hazardous energy control on equipment/systems has been provided to them by Tampa Electric Company.

B. Implementation

1. At the request of the contractor's authorized representative, Tampa Electric Company, Energy Supply Department, shall implement appropriate Hazardous Energy Controls on machines and/or equipment utilizing specific Hazardous Energy Control Procedures.
 - a. Each contractor shall provide Tampa Electric Company, Energy Supply Department with a list of Primary Authorized Employees that may request equipment to be tagged for their organization. This list will be updated annually.
 - b. These authorized personnel must fully comprehend Tampa Electric Company, Energy Supply's, Hazardous Energy Control Program.
2. Upon shutdown, isolation, tagout, and verification that all energy sources are controlled, the Hazardous Energy Control Supervisor shall notify the contractor Primary Authorized Employee that isolation and tagout is complete.
3. The Contractor Primary Authorized Employee, upon verifying energy control, shall sign on to the Master Job Tag.
4. The contractor, upon signing the Master Job Tag, shall ensure individual protection of each of their Authorized Employees through the implementation of that organization's Hazardous Energy Control Program.

C. Coordination

1. The contractor shall monitor compliance of their employee.
2. The contractor shall provide all necessary lockout/tagout training and equipment (devices) necessary for the implementation of their own Hazardous Energy Control Program.

D. Termination of Tagout

1. Upon completion of their work, the Contractor Primary Authorized Employee shall inspect the area, verify that their servicing and/or maintenance is complete.
2. All affected employees in the area shall be notified by the Contractor Primary Authorized Employee of the intention to remove tagout devices.
3. All contractor lockout/tagout devices shall be removed by the Authorized Employees who affixed them.
4. Upon notification from the Contractor Primary Authorized Employee, the Tampa Electric Company Hazardous Energy Control Supervisor will inspect and verify that all contractor lockout/tagout devices have been properly removed from the machine or equipment prior to removal of the Company's tagout devices and subsequent return to service.

E. Removal of Tagout Device

In an emergency, or when the Contractor's Primary Authorized Employee is unavailable to sign off or remove lockout/tagout device(s), a committeeing procedure shall be used (refer to section IV. J. Committeeing a Tagout Device)

F. Discipline for Non-Compliance

Enforcement of the Hazardous Energy Control Program shall be in accordance with the contract and will be enforced up to and including immediate termination of the contract.

VIII. EQUIPMENT DESIGN

New machines/equipment or, existing equipment that is retrofitted, must be designed to accept a lockout device.

IX. DISCIPLINE FOR NON-COMPLIANCE

The following guidelines apply to ALL employees:

- A. Any employee who fails to follow this Hazardous Energy Control Program shall be subject to disciplinary action.
- B. Disciplinary actions shall be consistent with the Tampa Electric Company policies and shall follow Positive Discipline guidelines.

APPENDIX A

DEFINITIONS

Affected Employee – A person whose job requires them to operate or use a machine or equipment on which servicing or maintenance is being performed under tagout or whose job requires them to work in an area in which such servicing or maintenance is being performed.

Authorized Employee – A person who tags out machines or equipment to perform the servicing or maintenance on that machine or equipment. When working alone, an Authorized Employee shall coordinate with the Hazardous Energy Control Supervisor to ensure adherence with Energy Supply Hazardous Energy Control procedures. An Affected Employee becomes an Authorized Employee when that employee's duties include performing servicing or maintenance covered under this Program.

Competent Person – One who is capable of identifying existing and predictable hazards in the surroundings or working conditions which are hazardous or dangerous to employees, and who has authorization to take prompt corrective measures to eliminate them.

Energy Isolating Device – A physical device that prevents the transmission or release of energy, including: manually operated circuit breakers, disconnect switches, line valves, blocks, and any similar device with a visible indication of the position (on/off or open/closed) of the device. Push buttons, selector switches and other control circuit type devices are not energy isolating devices.

Group Tagout Device – Administrative device to account for each Authorized Employee protected from unexpected release of hazardous energy signified by affixing their name as their personal tagout device.

Group Protection – Methods and procedures designed to afford a crew or group of employees a level of protection equivalent to that provided by use of a personal tagout device.

Hazardous Energy Control Operator – Energy Supply qualified person responsible for the initial physical isolation and application of the Danger Tagout devices to the energy isolation devices.

Hazardous Energy Control Supervisor – Energy Supply employee with the overall responsibility and jurisdiction for the Tagout of equipment/systems. The person under whose orders Hazardous Energy Control is performed.

Hazardous Energy Source - Any source of electrical, mechanical, hydraulic, pneumatic, chemical, thermal, potential or other energy source that may pose a hazard to individuals.

Hold Condition – A condition in which equipment is isolated, tagged but not verified nor signed on. This condition requires signing off before the tag is removed. No work shall be done under this state.

Holder – The person for which a hold condition is established.

Primary Authorized Employee - An Authorized Employee who exercises overall job responsibility for a group or crew of Authorized Employees, and coordinates with the Hazardous Energy Control Supervisor to ensure adherence with Energy Supply's Hazardous Energy Control Procedures.

Qualified person - A person who is specially qualified to do a specific job because of education, training, and/or experience.

Servicing and/or Maintenance - Workplace activities such as constructing, installing, setting up, adjusting, inspecting, modifying, and maintaining and/or servicing machines or equipment. These activities include lubrication, cleaning, or unjamming of machines or equipment and making adjustments or tool changes, where the employee may be exposed to the unexpected energization or start-up of the equipment or release of hazardous energy.

Switch - A device for opening and closing or for changing the connection of a circuit. In this section, a switch is understood to be manually operable, unless otherwise stated.

Tag - An openly displayed card, ticket, plastic marker, etc. securely attached to something as a label to give information, warning or instruction. Accident prevention tags have standard signal works, symbols and colors to convey a danger, warning, caution or information.

Tag, Electrical Danger Tag - Tagout device used only on electrical Hazardous Energy Control devices, such as circuit breakers, motor starters, and disconnects.

Tag, Master Job Tag- Group/individual tagout device used as an administrative control and accountability device for group or individual protection. This device is controlled by the Hazardous Energy Control Supervisor, and is a personal tagout device if each employee personally signs on and signs off of it.

Tag, Master Job Tag Work Permit - Group tagout device used in conjunction with master job tag and is a personal tagout device as well as an administrative control and accountability device for Authorized Employees who sign on to it. It is administered by the Primary Authorized employee.

Tag, Mechanical Danger Tag: Tagout device used on mechanical Hazardous Energy Control devices, such as valves, valve wheels, levers, and all other operating mechanisms.

Tagout - The placement of a tagout device on an energy isolating device, in accordance with an established procedure, to indicate that the energy isolating device and the equipment being controlled shall not be operated until the tagout device is properly signed off and removed.

Tagout device - A prominent warning device, such as a tag and a means of attachment, which can be securely fastened to an energy-isolating device in accordance with an established procedure, to indicate that the energy isolating device and the equipment being controlled shall not be operated until the tagout device is properly signed off and removed.

Verification - A confirmation of the certainty that a system/equipment has been properly tagged out, and all energy sources have been controlled.

Verify - Proving something to be true and establishing the certainty of it. Also, to determine or

test the accuracy of a state or condition. This can range from a visual determination to a physical examination and inspection.

APPENDIX B

HAZARDOUS ENERGY CONTROL PROCEDURE

Microsoft Excel - HEDP_TEMPLATE

SWISS 12 50%

HAZARDOUS ENERGY CONTROL PROCEDURE

FILE NAME: BLANK
 BACKLINES: EXCOCK
 REVISION: 041 02/23/2008

MASTER TAG
1-435

BIG BEND 1A CONDENSER
DRAFT

PAGE 1 OF 1

PRIMARY AUTHORIZED EMPLOYE: JOE MECHANIC DATE/TIME NEEDED: 02/15/2008 15:00
 SUPERVISOR: NANCY FOREMAN REQUESTED BY: JOE SCHEDULAR
 WORK TO BE DONE: CLEAN CONDENSER TUBES (1-40154-1) APPROVED BY: BOB OPERATOR

ENERGY SOURCE/Requirements			
Electrical	Mag	Mechanical	Mag
YES	4160V	YES	15 PSI
Chemical	Mag	Other	Mag
NO			
Thermal	Mag	Pressure	Mag
YES	120F	NO	
Control Space Permitt. Permitted?		Hot Work Permitt. Permitted?	
YES		NO	

ACTIONS TAKEN PRIOR TO ISOLATION

TURN PUMP OFF, LEAVE CONTROL SWITCH IN OFF POSITION
 VERIFY PUMP HAS STOPPED ROTATION
 OPEN INLET AND OUTLET WATERBOX DRAINS

ELECTRICAL			
ENERGY SOURCE	LOCATION	ISOLATION METHOD	TEST/VERIFICATION METHOD
1A CIRCULATING WATER PUMP BREAKER	2ND FLOOR 4160V CUBICLE 113W	OPEN, RACK DOWN AND TAG	VISUALLY INSPECT AIR GAP, ATTEMPT START
1A CONDENSER DISCHARGE VALVE BREAKER	1ST FL MCC 171 CUBICLE 3D	OPEN, RACK OUT AND TAG	VISUALLY INSPECT AIR GAP
1A CATHODIC PROTECTION DISCONNECT	M SCREEN WELL ELECTRICAL BUILDING EAST WALL	RACK OUT AND TAG	VISUALLY INSPECT AIR GAP

MECHANICAL			
ENERGY SOURCE	LOCATION	ISOLATION METHOD	TEST/VERIFICATION METHOD

APPENDIX C

Energy Supply Department
Hazardous Energy Control Committeeing Form

Location : _____ Organization: _____

Hazardous Energy Control Supervisor: _____

Date _____ Time: _____ Master Job Tag #: _____

Identify the equipment to which the Tagout Device was attached: _____

Reason for Hazardous Energy Control Device removal: _____

Name indicated on Hazardous Energy Control Device _____

What attempt was made to contact the person who applied the Hazardous Energy Control Device? _____

Has equipment been checked by a competent representative of the department doing the work to verify equipment and energy sources are in useable condition? Yes No

Has immediate supervisor of employee been notified? Yes No

Signed: _____
SPO/Equivalent

Signed _____
Production Supervisor or Equivalent

Notification Signed _____
 Verbal Manager/Duty Person

___ Yes ___ No Authorized employee has been informed of tag removal prior to resuming work at the station

Time Date Signature, Authorized Employee

Time Date Supervisor/Designee

Time	Date	General Manager
------	------	-----------------

Route completed form to Facility Safety Coordinator.

APPENDIX D

Tagging Device Requirements/Ordering Information

Tagging Device Requirements

1. Tagging devices specify "DO NOT OPERATE".
2. Tagging devices are standard in size and able to withstand plant conditions.
3. Tagging device attachment means shall be of a non-reusable type, attachable by hand, self-locking; with a minimum breaking strength of no less than 50 pounds.
4. Tagging devices shall be constructed and printed so that exposure will not cause the tag to deteriorate or cause the tag message to become illegible. All information required on the tag shall be properly entered and legible so that exposure to the elements will not cause the message to deteriorate.

Ordering Information

<u>***DESCRIPTION***</u>	<u>STOCK NO</u>
TAG, ATTACHER -- check on	P/N AR-159 6013153
TAG, DANGER MASTER ORANGE 4 1/8 X 8	H-210 5858030
TAG, DANGER PRODUCTION ELECTRICAL WHITE LAMINATED	H222B 6013622
TAG, DANGER PRODUCTION ELECTRICAL WHITE PAPER	P/N H222 6013623
TAG, DANGER PRODUCTION MECHANICAL WHITE LAMINATED	H221B 6013624
TAG, DANGER PRODUCTION MECHANICAL WHITE PAPER	H221 6013625
MASTER JOB TAG WORK PERMIT	

APPENDIX E

Tampa Electric Company
Energy Supply
Hazardous Energy Control Procedure
Periodic/Annual Inspection Form

Facility: _____ Area: _____ Date: _____

Equipment/System: _____ Inspector: _____

Authorized Employees: _____

Affected Employees: _____

- a. Has every energy source been identified on the procedure? Yes ___ No ___
- b. Are all energy sources tagged? Yes ___ No ___
- c. Are all Authorized Employees protected from all energy sources by a personal tagout device? Yes ___ No ___
- d. Was equipment verified as having been tagged out effectively? Yes ___ No ___
- e. What date was the procedure last reviewed? _____
- f. Do procedures specify equipment with appropriate disconnects? Yes ___ No ___
- g. Are tags and devices available that are designated for tagout use only? Yes ___ No ___
- h. Do tags identify the person applying the tagout device? Yes ___ No ___
- i. Do the authorized and affected employees understand their responsibilities under the Hazardous Energy Control Program? Yes ___ No ___
- j. Are they following the specific Hazardous Energy Control Procedure? Yes ___ No ___
- k. Identification of any deviations or inadequacies of the procedure to provide protection equivalent to lockout?

l. Corrective actions taken:

Certification of Inspection by: _____ Date: _____

Facility Safety Coordinator

cc: Facility Safety Coordinator

APPENDIX F

Group Protection
Master Job Tag Work Permit

Master Job Tag # _____ Work Order # _____

Job Description _____

Energy Controls *Visually Inspected By:*

Print Name: Primary Authorized Employee

Signature of Primary Authorized Employee Date: _____ Time: _____

Authorized Employees: (My signature represents that I understand the purpose and use of the Tampa Electric, Energy Supply, Hazardous Energy Control Program; recognize the hazardous energy sources, type and magnitude of energy, and the methods and means necessary for energy isolation and control of these energy sources; the means of verification, the purpose of the specific procedure being used, and the limitations of tags.)

Name: [Print]	Sign On	Time	Sign Off	Time

Sign Off: Primary Authorized Employee Date _____ Time _____