

SCANNED

**BEFORE THE FLORIDA  
PUBLIC SERVICE COMMISSION**

**DOCKET NO. 040029-EG  
FLORIDA POWER & LIGHT COMPANY**

**IN RE: FLORIDA POWER & LIGHT COMPANY'S  
PETITION FOR APPROVAL OF  
NUMERIC CONSERVATION GOALS**

**DIRECT TESTIMONY & EXHIBIT OF:**

**STEVEN R. SIM**

DOCUMENT NUMBER-DATE

06196 JUN-18

FPSC-COMMISSION CLERK

1                   **BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION**

2                   **FLORIDA POWER & LIGHT COMPANY**

3                   **TESTIMONY OF STEVEN R. SIM**

4                   **DOCKET NO. 040029-EG**

5                   **JUNE 1, 2004**

6  
7           **Q.     Please state your name and business address.**

8           A.     My name is Steven R. Sim and my business address is 9250 West  
9                   Flagler Street, Miami, Florida 33174.

10  
11          **Q.     By whom are you employed and what position do you hold?**

12          A.     I am employed by Florida Power & Light Company (FPL) as a  
13                   Supervisor in the Resource Assessment & Planning Business Unit.

14  
15          **Q.     Please describe your duties and responsibilities in that position.**

16          A.     I supervise a group that is responsible for determining the magnitude  
17                   and timing of FPL's future resource needs, analyzing supply and  
18                   demand side management (DSM) options which could potentially meet  
19                   these future needs, and developing FPL's integrated resource plan (IRP)  
20                   with which FPL intends to meet these needs.

21  
22          **Q.     Please describe your education and professional experience.**

23          A.     I graduated from the University of Miami (Florida) with a Bachelor's

1 degree in Mathematics in 1973. I subsequently earned a Master's  
2 degree in Mathematics from the University of Miami (Florida) in 1975  
3 and a Doctorate in Environmental Science and Engineering from the  
4 University of California at Los Angeles (UCLA) in 1979.

5  
6 While completing my degree program at UCLA, I was also employed  
7 full-time as a Research Associate at the Florida Solar Energy Center  
8 during 1977-1979. My responsibilities at the Florida Solar Energy  
9 Center included an evaluation of Florida consumers' experiences with  
10 solar water heaters and an analysis of potential renewable resources  
11 including photovoltaics, biomass, wind power, etc., applicable in the  
12 southeastern United States.

13  
14 In 1979 I joined FPL, and from then until 1985, I worked first in the  
15 Marketing Department and then in the Energy Management Research  
16 Department. My responsibilities during this time included the  
17 development and monitoring of numerous DSM programs. In 1985 I  
18 began working in FPL's Load Management Department as Supervisor  
19 of Planning. My responsibilities there involved design of FPL's load  
20 management programs, cost-effectiveness analyses and monitoring of  
21 these programs, and the integration of these programs with FPL's  
22 capacity resource plans.

23

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23

In 1991 I joined my current department, then named the System Planning Department, as a Supervisor of Supply and Demand Analysis, where my responsibilities included the cost-effectiveness analyses of a variety of individual supply and DSM options. I assumed my present position in 1993.

**Q. What is the purpose of your testimony?**

A. The purpose of my testimony is to explain a number of the FPL system-related analyses that were conducted in determining the level of cost-effective DSM that FPL is now proposing as its DSM goals for 2005 through 2014.

**Q. How is your testimony structured?**

A. My testimony is presented in 4 parts. First, I briefly introduce FPL’s basic IRP approach to evaluating resource options such as DSM and discuss several key planning assumptions that were used in FPL’s IRP work during the first half of 2004 to determine the level of cost-effective DSM that FPL is now proposing as its new DSM Goals. In this section I introduce the “Supply Only” resource plan (i.e., a resource plan without incremental DSM beyond 2004) to which a resource plan containing incremental DSM will later be compared in the final determination of the cost-effectiveness of the incremental DSM. (Both the Supply Only resource plan, and the competing

1 resource plan that will contain incremental DSM, assume that the load  
2 reduction capability from all load management participants signed up  
3 through 2004 will continue. In addition, the load forecast used in  
4 creating these resource plans accounts for the impacts of all previously  
5 signed up conservation participants.)

6  
7 Second, I discuss the analyses performed to determine which individual  
8 DSM measures (or programs) were potentially cost-effective for FPL to  
9 implement. The cost-effectiveness screening of individual DSM  
10 options is addressed in this section. (Mr. Brandt's testimony also  
11 addresses portions of this work.) The analyses performed to evaluate  
12 the usable amount of incremental load control on FPL's system, and the  
13 results of those analyses, are also discussed.

14  
15 Third, I discuss the development of a "With DSM" resource plan that  
16 contains the potentially cost-effective amount of incremental DSM. The  
17 Supply Only and With DSM resource plans are then compared in order  
18 to determine whether the projected amount of incremental DSM is truly  
19 cost-effective.

20  
21 Fourth, the analyses conducted to determine FPL's proposed new DSM  
22 Goals are summarized.

23

1           **Q.    Are you sponsoring an exhibit?**

2           A.    Yes, the exhibit consists of the following 12 documents:

3                   Document No. SRS-1: Overview of FPL’s IRP Process

4                   Document No.SRS-2: FPL’s Resource Plan in its 2004 Ten-Year

5   Power Plant Site Plan (with current DSM

6   Goals)

7                   Document No.SRS-3: Projected FPL Resource Needs Without

8   Incremental DSM

9                   Document No. SRS-4: The Supply Only Resource Plan for 2005 -

10   2014

11                  Document No. SRS-5: Summary of Results of the Cost-Effectiveness

12   Screening

13                  Document No. SRS-6: Hypothetical Utility Peak Day Load Shape

14                  Document No. SRS-7: Representative Effect of Implementing 100

15   MW of Load Control on the Hypothetical

16   Utility Peak Day Load Shape

17                  Document No. SRS-8: Representative Effect of Implementing 200

18   MW of Load Control on the Hypothetical

19   Utility Peak Day Load Shape

20                  Document No. SRS-9: Calculation of System Average Levelized Rate

21   for the Supply Only Resource Plan

22                  Document No. SRS-10: Projected FPL Resource Needs If Needs Are

23   Met Solely by DSM

1 Document No. SRS-11: The With DSM Resource Plan for 2005 - 2014  
2 Document No. SRS-12: Calculation of System Average Levelized Rate  
3 for the With DSM Resource Plan  
4

5 **I. FPL's Planning Approach, Key Planning Assumptions, and the**  
6 **Development of the Supply Only Resource Plan**

7  
8 **Q. Please briefly describe FPL's approach to evaluating the role of**  
9 **DSM in meeting future resource needs.**

10 A. FPL utilized its basic IRP process to analyze what role DSM should  
11 play in its resource plan. This basic process has been well-documented  
12 in each of the last several Ten-Year Power Plant Site Plans (Site Plan)  
13 filed with the Florida Public Service Commission (Commission). A  
14 copy of the discussion of the IRP process that appeared in the 2004 Site  
15 Plan is presented in Document No. SRS-1, and FPL's resource plan  
16 that was presented in its 2004 Site Plan is shown in Document No.  
17 SRS-2. This resource plan incorporates FPL's current DSM Goals for  
18 the years 2000 through 2009 that were approved by the Commission in  
19 1999.

20  
21 FPL believes that an IRP approach is the best way to determine how  
22 much of any resource option, supply or DSM, should be included in  
23 FPL's resource plan, because it allows options to compete on an

1 equitable basis in economic analyses to earn a place in the resource  
2 plan.

3

4 **Q. Did the 2004 IRP work differ from FPL's IRP work conducted in**  
5 **previous years?**

6 A. Yes, but only in regard to two starting assumptions. The same basic  
7 IRP process has been used by FPL since late 1993 for all of FPL's  
8 resource planning work, including work performed for the previous two  
9 DSM Goals dockets. During the last few years, FPL's IRP work  
10 assumed that the level of DSM from 2000 through 2009 called for in  
11 FPL's current DSM goals was a "given" in the annual planning work.  
12 Thus, DSM did not have to compete for a place in the resource plan for  
13 all years through 2009, since DSM's role in the resource plan had been  
14 established in the previous Goals docket. However, since the purpose  
15 of this docket is to reset DSM goals for the years 2005 through 2014, it  
16 was not appropriate to continue to view predetermined DSM levels for  
17 the years 2005 through 2009, i.e., the remaining years covered by  
18 FPL's current DSM Goals, as a "given".

19

20 Consequently, one assumption of the IRP work performed in early  
21 2004 to address the cost-effective level of incremental DSM was that  
22 only currently planned DSM additions through 2004 were a given and  
23 that no incremental DSM would be viewed as a given beyond January



1 1, 2005. Therefore, DSM would have to compete to earn a role for  
2 2005 and beyond in FPL's resource plan.

3  
4 **Q. What was the other planning assumption that differed from those**  
5 **utilized in IRP work conducted in previous years?**

6 A. The other assumption involved near-term new generating units that  
7 were considered as "givens" in FPL's 2004 resource planning work for  
8 the DSM Goals docket. The generating units that were considered  
9 "givens" in the most recent resource planning work (and that are  
10 discussed in Document No. SRS-2) are the following:

- 11 - a new 1,107 MW (Summer) combined cycle (CC) unit,  
12 Manatee Unit No. 3, at FPL's existing Manatee plant site that  
13 will come in-service in June, 2005;
- 14 - the conversion of two combustion turbine (CT) units at FPL's  
15 existing Martin plant site into a 1,107 MW (Summer) four-CT  
16 based CC unit, Martin Unit No. 8, with the addition of two  
17 additional CT's, four heat recovery steam generators, and a  
18 steam boiler. The new CC unit will also come in-service in  
19 June, 2005; and,
- 20 - a new 1,144 MW (Summer) CC unit, Turkey Point Unit No.  
21 5, at FPL's existing Turkey Point plant site that is planned to  
22 come in-service in June, 2007.

1 FPL considered these generating units to be “givens” in its resource  
2 planning work to determine the cost-effective amount of incremental  
3 DSM. Both of the 2005 CC units are already under construction. The  
4 third generating unit, the proposed new 1,144 MW CC unit for 2007, is  
5 too large, and is planned to come in-service too early, to be avoided or  
6 deferred by incremental DSM starting in 2005.

7  
8 As stated above, the first two units considered as “givens”, Manatee  
9 Unit No. 3 and Martin Unit No. 8, are under construction. The  
10 Commission granted Determinations of Need for the two units, and  
11 both have received Site Certification Approval from the Florida  
12 Department of Environmental Protection (DEP) with concurrence by  
13 the Florida Electrical Power Plant Siting Board.

14  
15 In regard to the third unit mentioned above as a “given”, Turkey Point  
16 Unit No. 5, FPL filed a petition with the Commission on March 8, 2004  
17 for approval of a Determination of Need for this unit with the  
18 Commission, and the Commission has scheduled a hearing on the  
19 petition in early June 2004. FPL has also filed for Site Certification  
20 Approval with the DEP, and a decision on this filing is anticipated in  
21 early 2005.

22  
23

1           **Q.    What are the potential effects of the two planning assumptions**  
2           **discussed above on the role of DSM in FPL’s resource plan?**

3           A.    The effects of these two assumptions vary in terms of the magnitude  
4           and timing of DSM’s potential role in FPL’s resource plan. The first  
5           assumption – that incremental DSM from January 1, 2005 through  
6           2009 would be removed as a “given” from the resource planning work  
7           – increases FPL’s resource needs for all years starting in 2005 and  
8           moves those resource needs closer to the present. The effect of  
9           removing DSM previously projected (due to FPL’s current DSM  
10          Goals) to be added from 2005 through 2009 creates a “hole” in the  
11          resource plan in that time period. This affords the incremental DSM  
12          now being examined an opportunity to at least refill that hole and,  
13          perhaps, play an even greater role in those years.

14  
15          The second assumption – that three new CC units, each of  
16          approximately 1,100 MW of capacity, are planned to be added to FPL’s  
17          system, two in 2005 and one in 2007 – has the opposite effect. These  
18          additions lower FPL’s resource needs from 2005-on and decrease the  
19          opportunity for incremental DSM to earn a role in FPL’s resource plan.

20  
21          **Q.    Describe the development of the Supply Only Resource Plan.**

22          A.    FPL used the resource plan for 2004 through 2013 presented first in its  
23          2004 Site Plan, and again in Document No. SRS-2, as its “starting

1 point” plan. Then, two changes were made to this starting point plan.  
2 First, the incremental DSM included in the starting point plan from  
3 January 1, 2005 through 2009 was removed. This resulted in a total of  
4 approximately 385 MW (Summer, at the generator) of planned DSM  
5 demand reduction being removed. As previously mentioned, this both  
6 increased FPL’s resource needs and accelerated those needs.

7  
8 Second, the generating unit additions in the plan for 2008-on were  
9 removed. As previously discussed, the two new generating units for  
10 2005, and the new generating unit for 2007, remained in place.

11  
12 These two changes allowed FPL to project what its resource needs  
13 would then be for the 2005 through 2014 time period without these  
14 DSM and generating unit resources. Document No. SRS-3 shows those  
15 projected resource needs in terms of MW needed with the two changes  
16 discussed above. The calculations shown in this document assume that  
17 only supply options – purchases and/or new construction options –  
18 would be used to meet those projected resource needs.

19  
20 Using these supply resource need projections, a new Supply Only  
21 resource plan was developed that met the increased and accelerated  
22 needs. FPL used its Electric Generation Expansion Analysis System  
23 (EGEAS) model to develop this resource plan. The resulting Supply

1            Only resource plan is presented in Document No. SRS-4 along with the  
2            associated annual Summer reserve margin values. This resource plan  
3            meets FPL's dual reliability criteria of a minimum reserve margin of  
4            20% (with one year falling only slightly below this value) and a  
5            maximum annual Loss-of-Load-Probability (LOLP) value of 0.10.

6

7            **Q.    How does this Supply Only resource plan differ from the resource**  
8            **plan presented in FPL's 2004 Site Plan?**

9            A.    A comparison of Document Nos. SRS-2 and SRS-4 show that there are  
10           three basic differences. First, there is an increased resource need of  
11           approximately 170 MW in 2007 that is assumed to be met by a new  
12           one-year, 170 MW purchase for that year. Second, the two CT units  
13           previously shown to be added in 2008 have been increased to four CT  
14           units in that year. Third, the addition of 2 new CC units, one each in  
15           2011 and 2013, that was previously shown has been changed to three  
16           new CC units, one each in 2010, 2012, and 2014. These changes are  
17           needed to meet the greater and accelerated resource needs that are a  
18           result of removing the previously projected DSM additions for 2005  
19           through 2009.

20

21

22

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22

**Q. Why is the Supply Only resource plan needed to determine the cost-effective amount of incremental DSM?**

A. The Supply Only resource plan is used in three ways in this work. The first way it is used is in assisting to set assumptions for the cost-effectiveness screening of individual DSM measures to determine which DSM measures are potentially cost-effective. The second way it is used is in serving as the starting point in developing a With DSM resource plan once it is known which DSM measures are potentially cost-effective and the achievable potential of each measure. The third way in which this plan is used is in serving as a “standard” to which the With DSM resource plan is compared by analyzing the impact each plan has on FPL’s projected system average electric rates. If FPL’s projected system average electric rates are lower with the With DSM resource plan than with the Supply Only resource plan, then the amount of incremental DSM included in the With DSM resource plan is truly cost-effective.

1           **II. Cost-Effectiveness Screening of DSM Measures and the**  
2           **Determination of Usable Amounts of Incremental Load Control**

3  
4           **Q. What is the purpose of the cost-effectiveness screening of**  
5           **individual DSM measures?**

6           A. To construct a portfolio of DSM measures that includes all of the cost-  
7           effective DSM available to FPL to help it meet its resource needs in the  
8           2005 through 2014 time period, it is necessary to determine the  
9           following information for each DSM measure: (1) whether the measure  
10          is potentially cost-effective, and (2) the potential contribution of the  
11          measure over this time period. In performing the cost-effectiveness  
12          screening analyses, FPL uses both the Rate Impact Measure (RIM) test  
13          and the Participant test.

14  
15          The cost-effectiveness screening first allows FPL to determine whether  
16          the individual measures are potentially cost-effective. Measures that do  
17          not pass this screening are not considered further. For those measures  
18          that do pass this screening, FPL can then determine the maximum  
19          incentive payment level for the measure that allows the measure to  
20          remain cost-effective. This maximum payment level to potential  
21          customers is then used to determine the size of the potential market for  
22          the measure that is achievable over the 2005 through 2014 time period.

23

1           **Q.     Please describe the cost-effectiveness screening process.**

2           A.     FPL’s cost-effectiveness screening of individual DSM measures is  
3                 carried out in four steps that utilize the Commission’s approved cost-  
4                 effectiveness methodology.

5  
6                 In the first step, which is carried out by the Resource Assessment and  
7                 Planning Business Unit (RAP), a “stripped down” version of each  
8                 individual DSM measure is analyzed versus the likely type of supply  
9                 option the measure would have to displace to earn a role in the resource  
10                plan. (The likely type of supply option that was used in the screening  
11                analyses will be discussed later in my testimony.) This version of each  
12                DSM measure is considered “stripped down” because no cost  
13                information - no administrative costs or incentive payments - are  
14                included in this step of the analyses. The information supplied for the  
15                "stripped down" DSM measure includes all of the information needed  
16                to project the economic benefits of implementing the measure on FPL’s  
17                system (i.e., the kw and kwh reductions per participant). The intent of  
18                this analysis step is to determine whether a DSM measure is potentially  
19                cost-effective when all of the measure’s benefits are compared to only  
20                the revenue losses associated with the measure. Both the benefits and  
21                the revenue losses are determined on a long-term, net present value  
22                basis. DSM measures whose benefits do not exceed the revenue losses



1 are considered to have failed this first step of the screening and are not  
2 considered further.

3  
4 In the second step of the cost-effectiveness screening, the projected  
5 length of time that it takes a DSM option to “pay for itself,” assuming  
6 no incentive payment is made by FPL to the participant, is determined.  
7 This is a question of how long it takes for the savings in a participant’s  
8 bills to equal the participant’s out-of-pocket costs for acquiring the  
9 measure. If this “payback” period is two years or less, FPL views the  
10 measure as one that is sufficiently attractive to potential participants  
11 that FPL’s involvement in promoting the measure is not needed.  
12 Consequently, all measures that “survived” the first screening step, but  
13 which have a payback of two years or less, are not considered further.  
14 Mr. Brandt discusses this second step of the screening, which is carried  
15 out by the Product Management and Operations (PMO) Department, in  
16 more detail in his testimony.

17  
18 In the third step of the cost-effectiveness screening, administrative  
19 costs are added for each surviving DSM measure, and the measure’s  
20 cost-effectiveness is again determined by RAP. All DSM measures  
21 whose benefits do not exceed the sum of their administrative costs and  
22 revenue losses (but with no incentive payment yet assumed), are not  
23 considered further. The surviving DSM measures that pass this cost-

1 effectiveness screening step are then carried forward to evaluate what  
2 incentive payment is applicable for each measure.

3

4 **Q. What is the fourth and final step of the cost-effectiveness**  
5 **screening?**

6 A. For the measures that survive the third cost-effectiveness screening  
7 step; i.e., measures whose benefits exceed the sum of administrative  
8 costs and revenue losses, this “net benefits” calculation defines the  
9 amount of incentive payment FPL can offer and still have the measure  
10 remain cost-effective. In other words, FPL can offer an incentive up to  
11 the amount where the cost of the incentive equals the net benefits  
12 amount. This becomes the maximum possible incentive for that  
13 measure.

14

15 In the fourth and final step, FPL determines what incentive, up to the  
16 maximum incentive amount, FPL can offer so that the measure passes  
17 both the RIM test and the Participant test. If such an incentive amount  
18 can be determined, then the measure has survived all of the screening  
19 steps and is deemed to be potentially cost-effective. However, if there  
20 is no incentive level that will allow the measure to pass both the RIM  
21 and Participant tests, then the measure is dropped from further  
22 consideration.

23

1 PMO then uses the selected incentive level for each surviving measure  
2 to develop projections of how many participants (or how many kw) the  
3 market potentially could provide for each year in the 2005 through  
4 2014 time period. Mr. Brandt's testimony addresses this effort.

5

6 **Q. In the cost-effectiveness screening, how did FPL determine the**  
7 **“likely supply option” that DSM might displace?**

8 A. To perform the cost-effectiveness screening of DSM measures, it was  
9 necessary to first project the type of new generating units that would be  
10 added to FPL's system absent any incremental DSM and when those  
11 units would likely be added. The Supply Only resource plan shown in  
12 Document No. SRS-4 answers those two questions. This resource plan  
13 shows that the majority of the new generating options that FPL would  
14 add absent any incremental DSM after 2004 are CC units. Therefore, it  
15 was clear that incremental DSM would primarily be competing with  
16 CC capacity over the 2005 through 2014 time period.

17

18 When considering the size (approximately 1,100 MW) of the new CC  
19 units projected to be added, it was clear that if the potential achievable  
20 amount of cost-effective incremental DSM over the ten-year time  
21 period was similar to that determined during the last DSM Goals  
22 proceedings (approximately 765 MW Summer at the meter), then there  
23 would not be sufficient cost-effective DSM to avoid a generating unit

1 of this size. Consequently, the benefits of incremental DSM would be  
2 derived from deferring the addition of these units. Also, again assuming  
3 that the amount of potentially achievable cost-effective DSM was  
4 similar to this 700 MW-plus level, there would likely be more than one  
5 deferral of these large generating units over the ten-year time period as  
6 seen from a comparison of the differences in the 2010 through 2014 CC  
7 additions between Document Nos. SRS-2 and SRS-4.

8  
9 While the Commission's approved cost-effectiveness methodology can  
10 be used to determine the DSM benefits associated with deferring a  
11 single generating unit, it does not lend itself well to calculating the  
12 benefits of multiple unit deferrals. Therefore, in order to address the  
13 likely impact of incremental DSM from 2005 through 2014 for  
14 screening purposes, FPL chose to use an avoided unit approach that  
15 was representative of the expected multiple unit deferral pattern.

16  
17 In order to determine how a single avoided unit approach might best  
18 represent the expected multiple unit deferral pattern, FPL took the  
19 Supply Only resource plan and added 10 years of hypothetical DSM  
20 MW with the amount of DSM for each year of the 2005 through 2009  
21 time period matching the annual DSM additions in FPL's current DSM  
22 Goals for 2005 through 2009, then with a similar 5-year incremental  
23 DSM pattern being repeated for 2010 through 2014. The projected

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22

impact of this hypothetical amount of DSM on the Supply Only resource plan did result in a multiple unit deferral pattern. This deferral pattern appeared for many of the years from 2010 – on, which provided a reasonable approximation of having avoided a unit in 2010.

This observation, plus the fact that a 2010 avoided unit assumption would allow FPL to look at DSM costs over a 5-year signup period (2005 through 2009) covering half of the time period for which new DSM Goals are to be set, led FPL to use a 2010 avoided CC unit and the Commission’s approved cost-effectiveness methodology in order to perform the economic screening of individual DSM measures.

DSM measures that survived this screening work were deemed to be potentially cost-effective. Later in the analyses, FPL would again use its EGEAS model to create a “With DSM” resource plan that included potentially cost-effective DSM and that could be compared to the Supply Only resource plan. This approach allowed DSM to be compared from a resource plan perspective from which a determination can be made if the incremental DSM is truly cost-effective.

1           **Q.    What were the results of the cost-effectiveness screenings of the**  
2           **individual DSM measures?**

3           A.    FPL’s PMO department identified a total of 329 DSM measures for  
4           analysis. In examining these measures, it was determined that a number  
5           of them were “identical” in regard to their demand and energy  
6           reduction impacts, but different in their potential applications. For  
7           example, the same DSM measure may be applicable to both existing  
8           construction and to new construction. In other cases, the same measure  
9           may be applicable to existing construction or it could be evaluated as a  
10          Code Utility Evaluation (CUE) application. In either of these cases, the  
11          same measure was properly counted twice in the total count of 329  
12          DSM measures.

13  
14          However, in regard to the possible cost-effectiveness of these  
15          “identical” measures, since they possessed identical kw and kwh  
16          reduction characteristics, it was only necessary to evaluate one of the  
17          “identical” pair. Consequently, the list of 329 total measures was  
18          reduced to 224 DSM measures for the cost-effectiveness screening.

19  
20          Of these 224 DSM measures submitted for analysis, 162 measures, in  
21          their "stripped down" mode, were found to be cost-effective in the first  
22          step of the screening process. Consequently, 62 measures were

1 eliminated from further consideration at this point because their  
2 revenue losses exceeded their benefits.

3  
4 In the second step of the cost-effectiveness screening, 23 measures that  
5 had survived the first step of the screening were eliminated after it was  
6 determined that the payback period for the measure was two years or  
7 less. At this point, 139 surviving measures remained.

8  
9 The addition of administrative costs in the third step of the screening  
10 process eliminated another 29 measures. This resulted in 110 surviving  
11 measures for which the maximum incentive level was determined.

12  
13 In the fourth and final screening step, 56 additional measures were  
14 eliminated when incentive levels that allowed the measure to pass both  
15 the RIM and Participant tests could not be found for those measures.

16  
17 This left 54 DSM measures that survived the cost-effectiveness  
18 screening process. All but one of these 54 surviving measures were  
19 carried forward through the rest of the DSM Goals-setting analyses;  
20 one measure survived but the analyses had shown that only a \$1  
21 incentive payment was possible if the measure was to pass both the  
22 RIM and Participant tests. Since a \$1 incentive payment would allow  
23 virtually no market potential for this measure, the measure was dropped

1 from further consideration. The remaining 53 DSM measures were  
2 retained for the rest of the DSM Goals analyses. (Later, when FPL  
3 developed estimates of the achievable market potential for these  
4 remaining 53 measures, any “identical” measures associated with these  
5 53 measures were included in the development of the market potential  
6 estimates.) Mr. Brandt’s testimony also addresses these DSM screening  
7 analyses and provides more detail regarding both the participant pay  
8 back and incentive level determination steps.

9  
10 Document No. SRS-5 provides a summary view of the results of the  
11 cost-effectiveness screening steps of the individual DSM measures. Mr.  
12 Brandt’s testimony also discusses the DSM screening analyses and  
13 provides additional detail regarding the participant pay back and  
14 incentive level determination steps, plus provides detailed screening  
15 results for each of the individual measures evaluated.

16  
17 **Q. Did FPL perform additional analyses to determine the potential for**  
18 **DSM measures?**

19 A. Yes. FPL conducted analyses that were directed at evaluating the  
20 potential contribution of incremental load control capacity on FPL’s  
21 system. These analyses were a continuation of similar analyses FPL has  
22 conducted in the past. The objective of these analyses is to determine



1                   whether FPL is at, or near, what it terms a "physical limit" as to how  
2                   much load control is "usable" on its system.

3

4                   **Q.    Please explain this concept of a "physical limit" for load control on**  
5                   **a utility system.**

6                   A.    One way to demonstrate the concept is by visualizing the shape of a  
7                   utility's peak day load and how the implementation of load control  
8                   affects this load shape. To simplify matters, assume that a utility's peak  
9                   day load shape resembles a normal distribution curve with the peak  
10                  hour's load at the very top of the curve. Document No. SRS-6 presents  
11                  such a peak day load shape for a hypothetical utility.

12

13                  The objective of load control is to lower the peak load of the system  
14                  when load control is implemented. When it is implemented, load  
15                  control reduces the electrical load on the utility's system from the  
16                  participating customers' equipment. Then, when load control  
17                  implementation ends (or load control is "released"), the utility system  
18                  typically experiences some short-term "payback" as pent-up demand  
19                  for electricity from this equipment (particularly if the equipment is  
20                  controlled by a thermostat such as is the case with air conditioners and  
21                  water heaters) is now served.

22

1 To lower the system's peak load, a utility typically initiates load control  
2 prior to what its peak load hour would have been, and continues it for a  
3 time past what the peak load hour would have been, to ensure that the  
4 "payback" effect does not create a new, higher peak load. A result of  
5 load control's implementation is a "flattening" of the load shape for a  
6 period of time. An example of the effect of this typical implementation  
7 practice on a utility's peak day load shape is illustrated in Document  
8 No. SRS-7.

9  
10 In Document No. SRS-7, load control is implemented for a period of  
11 time (for example, 3 hours) to achieve a desired 100 MW load  
12 reduction. Note that it is necessary to implement load control for this  
13 period of time to ensure that the load does not rise above the "w/ load  
14 control" line during the 3 hours (i.e., to really achieve the 100 MW  
15 demand reduction). In other words, load control must be implemented  
16 for a time period stretching from the left-hand side of the load curve to  
17 the right-hand side (which is a time span of 3 hours in this example) to  
18 achieve the desired 100 MW demand reduction.

19  
20 The key point is that in order to achieve a given load reduction (i.e., a  
21 given drop down from the original peak hour load), it is necessary to  
22 implement and sustain load control for a specific number of hours

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23

(determined by the width across from the left-hand side of the load curve to the right-hand side).

Now assume the same utility wishes to implement load control to achieve double the demand reduction (200 MW). This means there is a greater drop down from the original peak hour load (from 100 MW to 200 MW), and a greater number of hours (i.e., the width across the load shape) for which the load control must be sustained (from 3 hours to 5 hours in this example). This is illustrated in Document No. SRS-8.

This brings us to the concept of a "physical limit" to how much load control makes sense for a utility system. Since load control must be sustained for a longer time period as the desired demand reduction gets greater, it is possible for the distance across the load shape simply to become too great a time period for the load control to be sustained. This is particularly true considering that most load control programs have tariff (or other) restrictions on the number of hours particular equipment can be controlled.

FPL considers the "physical limit" to load control on a utility system to be the point at which a desired increase in load reduction cannot be achieved due to the length of time the control must be sustained.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23

Note that this "limit" can be increased by either increasing the tariff limits of control time or by essentially operating load control in a "relay race" mode in which two participating customers now are required to sustain a duration of control longer than is possible with only one customer. For example, if it is necessary to sustain load control for 7 hours to achieve a desired reduction and the tariff limit control period is only 6 hours, it would be possible to have one participating customer "carry" the demand reduction for up to 6 hours and then have a second participating customer "carry" the demand reduction the rest of the time period until 7 hours are reached.

However, there are drawbacks to both of these "remedies". Participating customers will only remain on the program as long as control durations do not exceed a tolerance threshold. Thus, there are limitations to this "remedy" itself. Likewise, using two participants to achieve additional demand reduction when the previous level of reduction only required one participant means that the cost-effectiveness of this next reduction increment has been significantly reduced (i.e., approximately cut in half) since two participants must now be used to accomplish the demand reduction that could previously be achieved with the use of only one participant.

1           **Q.    Does the same physical limit to load control apply to every utility?**

2           A.    No.  Although FPL believes there is a physical limit as to how much  
3           load control is usable on each utility system, this limit will vary from  
4           one utility system to the next.  It is highly dependent upon peak day  
5           load shape.  For example, FPL's Summer peak day load shape typically  
6           shows many more hours of high load than does FPL's Winter peak day.  
7           The Summer peak day load shape is thus broader across than the  
8           Winter peak day load shape (which is characterized by a "spike-like"  
9           appearance).  All else equal, this means that FPL could utilize more  
10          MW of load control on a Winter peak day than on a Summer peak day  
11          simply because the demand reduction would have to be carried for  
12          fewer hours in Winter.  In other words, there is a higher physical limit to  
13          Winter load control than to Summer load control for FPL.

14

15          Therefore, the amount of usable load control can even vary seasonally  
16          for the same utility.  This physical limit of load control also varies from  
17          one utility to another depending upon the utilities' respective peak day  
18          load shapes, tariff restrictions on control duration, and the importance  
19          of Winter versus Summer peak loads in regard to resource planning.

20

21          **Q.    How does FPL analyze the physical limit of load control on its**  
22          **system?**

23          A.    The basic steps for FPL's analyses include the following:

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23

- 1) Develop a 15-minute interval projection of a future peak day load shape. For example, develop such a projection for an August, 2009 peak day.
- 2) Input assumptions for demand reduction and payback on a per participant basis for all of the types of equipment controlled by the load control programs. FPL includes projections for its residential, small commercial, and large Commercial/Industrial load control programs in these analyses.
- 3) Input the current tariff restrictions and current level of load control participants for each of these load control programs.
- 4) Using linear programming techniques, seek to utilize as much of the current load control as possible in order to minimize the future peak day's highest hourly load as much as possible.
- 5) If 100% of the current load control is utilized, and if the theoretically achievable peak load reduction is as projected (for example, if you utilize 100 load control participants who are each theoretically able to provide 1 kw of demand reduction, you would expect to get a 100 kw demand reduction), then add an additional amount of load control (for example, 10 additional participants) and check the projected theoretical reduction versus the linear programming result. (In our example, did  $100 + 10 = 110$  participants  $\times$  1 kw/participant yield 110 kw of reduction from the previous peak?)

1                   Once the point has been reached at which additional increments of  
2                   load control do not yield the projected theoretical results (for  
3                   example, 110 participants yielded less than the projected 110 kw of  
4                   reduction), then the physical limit of load control has been crossed.  
5                   The analysis then backtracks to find the last point at which one  
6                   additional projected increment of load control still yields one  
7                   additional increment in the linear programming analysis. This point  
8                   represents the physical limit for load control for a given year on the  
9                   utility system, and that amount of load control is the maximum  
10                  amount that is termed "usable" for the system for that year.

11

12               **Q.    What were the results of your analysis of load control for FPL's**  
13               **system?**

14               A.    Previous FPL analyses of the impact of load control programs on peak  
15               day load shape showed that the physical limit in regard to Summer  
16               peak was more restrictive than in regard to Winter peak. Consequently,  
17               FPL's 2004 analyses concentrated on the usable amount of load control  
18               "versus" FPL's projected Summer peak loads. The forecasted Summer  
19               peak day load shapes for 2009 and 2014 were used in the analyses.

20

21               The results of these analyses were that FPL could add up to another 150  
22               MW of usable residential and/or small business load control (since the  
23               primary characteristics of these two programs are similar) in the 2005

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22

through 2009 time frame, and another usable 60 MW in the 2010 through 2014 time frame, for a total usable incremental total of 210 MW over the 10-year period. Similar analyses showed that a much greater amount, approximately 600 MW over the 10-year period, of additional of large business load control (such as FPL’s CDR program) would be usable on FPL’s system. This greater amount of usable large business load control, compared to the amount of usable residential and/or small business load control, is due to the differences between the two types of programs in the payback of electrical demand when load control is released.

There is no immediate payback when control of large business customers’ load is released, since these customers’ typical electrical load is typically not driven by thermostatically-controlled equipment. In contrast, the electrical load of residential and/or small business customers typically drops off in the evening hours when load control is likely to be released and is typically driven by thermostatically-controlled equipment. Consequently, the payback of previously controlled load of residential and/or small business customers during these hours serves to increase their loads beyond what they would have been if load control had not been implemented.



1           The insight gained from these analyses of two types of load control  
2           programs with significant differences in payback characteristics is that,  
3           all else equal, a utility can use more of a load control program without  
4           payback than it can of a load control program with payback.

5

6           **Q.    What other insights into future load control at FPL were gained**  
7           **from the analyses?**

8           A.    In addition to the previously mentioned conclusion that, all else equal,  
9           “the smaller the payback, the greater amount of load control that is  
10          usable,” one other insight was gained: all else equal, the longer the  
11          control duration that is allowed by tariff (or tolerable by participants),  
12          the greater amount of load control that is usable. These results have  
13          been seen in previous FPL analyses and were again confirmed in this  
14          recent work.

15

16          **Q.    How did FPL utilize the results of these analyses in its 2004 IRP**  
17          **work?**

18          A.    The usable amount of load control that was determined for each of  
19          these two types of load control programs was first compared to the  
20          achievable market potential projections that were independently  
21          developed for the two programs. Then the lower of these two values,  
22          the incremental MW that are usable on FPL’s system or the achievable  
23          MW market potential that can be signed up, was used to develop an

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22

“achievable usable” level for the program (i.e., the “upper limit” for incremental signups). This lower value was then carried through the remainder of the analyses. (Mr. Brandt’s testimony addresses how the achievable market potential projections for the DSM options were developed.)

In the case of residential and/or small business load control, the usable amount of incremental load control (210 MW) is significantly less than the achievable market potential for such programs (that was conservatively estimated to be over 500 MW for the 10-year period). Consequently, the lower value – the usable amount of 210 MW – for these programs was used as the achievable usable value for the remainder to the analyses.

Just the opposite was the case for large business load control. The achievable market potential value of 70 MW over the 10-year period was significantly lower than the 600 MW usable amount. Therefore, the lower market potential value of 70 MW was used as the achievable usable value for large business load control for the remainder of the analyses.

1           **Q.    When the results of the market potential analyses for the non-load**  
2           **control measures were combined with these results of the usable**  
3           **projections for the load control programs, how much achievable**  
4           **usable DSM in total was projected?**

5           A.    FPL projects that approximately 886 MW (Summer) at the generator of  
6           DSM for the 2005 through 2014 time period are achievable and usable.  
7           These DSM MW are potentially cost-effective since each individual  
8           DSM measure represented in this total has passed the cost-effectiveness  
9           screening. In the next step of determining what FPL’s DSM Goals for  
10          2005 through 2014 should be, these potentially cost-effective DSM  
11          measures were then combined into a DSM portfolio that was tested  
12          against the Supply Only resource plan.

13  
14          **Q.    Before moving to this next step, please summarize the results of the**  
15          **work designed to determine the amount of achievable, usable, and**  
16          **potentially cost-effective DSM for the years 2005 through 2014.**

17          A.    This work can be summarized as follows:  
18                1) FPL analyzed 224 DSM measures (that actually represented 329  
19                measures as previously discussed), first without administrative  
20                costs or incentive payments, to determine which measures  
21                appeared to be potentially cost-effective versus CC capacity in  
22                the period beyond 2004. The 162 measures that survived this  
23                first screening were then evaluated to determine which ones had

1                   payback periods for the participants of two years or less. 23  
2                   additional measures were eliminated by this analysis leaving  
3                   139 surviving measures. The measures were then reevaluated  
4                   after administrative costs were added for each measure. 110  
5                   measures survived after this analysis and were carried forward  
6                   for further evaluation. The Commission's approved cost-  
7                   effectiveness methodology was utilized to perform these  
8                   evaluations that were based on the RIM and Participant tests.

9                   2) For each of these surviving 110 measures, FPL sought to  
10                  determine an incentive level that would allow the measure to  
11                  pass both the RIM and Participant tests. Such an incentive level  
12                  could be determined for 54 of these 110 measures, while 56  
13                  measures were eliminated in this final screening step. Then,  
14                  using the determined incentive level, an achievable market  
15                  potential value for each measure was then developed. In  
16                  determining the incentive levels for all measure, one measure  
17                  was dropped from further consideration when it was determined  
18                  that only a \$1 incentive could be paid for the measure and have  
19                  the measure pass both the RIM and Participant tests. Therefore,  
20                  53 DSM measures were carried forward for the remainder of the  
21                  DSM Goals analyses work.

22                  3) For the load control programs, an additional analysis was  
23                  performed to determine how much load control was usable on

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23

the FPL system. The results of these analyses were then compared with the achievable market potential results for load control to develop achievable usable values for the load control programs.

4) The end result of these efforts was a projection of approximately 886 MW (Summer) at the generator, of DSM that was achievable, usable, and potentially cost-effective for the 2005 through 2014 time period.

**III. Development of the With DSM Resource Plan and Comparison of the Supply Only and With DSM Resource Plans**

**Q. How did FPL evaluate whether this amount of achievable, usable, and potentially cost-effective DSM was truly cost-effective?**

A. The prior economic screening analyses determined which DSM measures were viewed as potentially cost-effective from the perspective of avoiding a single generating unit projected to come in-service in 2010. However, as previously discussed, the primary impact of adding DSM to the Supply Only resource plan will be to defer the in-service dates of a number of CC units. Therefore, to determine whether all or part of this DSM amount was truly cost-effective, it was necessary to analyze DSM from a resource plan perspective that accounts for the effects of multiple unit deferrals.

1 This approach allows two things to be determined. First, what would  
2 the implementation of this amount of DSM really accomplish in terms  
3 of displacing new generating units that otherwise would be built?  
4 Second, would this displacement of new units by DSM truly be cost-  
5 effective when comparing resource plans both with and without the  
6 incremental 886 MW of DSM?

7  
8 The resource plan without DSM has already been determined; it is the  
9 Supply Only resource plan presented in Document No. SRS-4. To  
10 fairly compare the economics of this Supply Only resource plan and a  
11 second resource plan that utilizes this incremental 886 MW of DSM, it  
12 is necessary to examine the impacts on system average electric rates of  
13 the two plans. FPL performs this comparison by calculating a levelized  
14 system average electric rate based on each plan. This calculation for the  
15 Supply Only resource plan was performed in EGEAS when EGEAS  
16 was used to develop this resource plan. A depiction of this calculation  
17 is presented in Document No. SRS-9.

18  
19 As shown in Document No. SRS-9, the levelized system average  
20 electric rate for the Supply Only resource plan is 8.7200 cents/kwh. If  
21 a resource plan which includes the incremental 886 MW of DSM can  
22 be constructed which results in a lower levelized system average

1 electric rate, then the inclusion of the incremental DSM is cost-  
2 effective.

3

4 **Q. How did FPL construct a resource plan with DSM?**

5 A. We began with the Supply Only resource plan shown in Document No.  
6 SRS-4 and the 10-year incremental DSM achievable potential level of  
7 886 MW. The objective was to construct a resource plan that included  
8 the incremental 886 MW of DSM and that had comparable reserve  
9 margins and LOLP values to that of the Supply Only resource plan.

10

11 FPL developed this With DSM resource plan using an approach that  
12 had four basic steps. The first step in this approach was to determine  
13 how much of the 886 MW of DSM could be implemented for each year  
14 of the 2005 through 2014 time period. Much of this work had been  
15 carried out in developing the overall achievable market potential values  
16 for conservation. These estimates were then combined with data from  
17 the analyses of the usable amounts of load control to develop overall  
18 annual estimates of achievable usable DSM.

19

20 The second step determined how many MW of DSM would be needed  
21 to avoid or defer the supply additions shown in the Supply Only  
22 resource plan. In making this determination, FPL started with  
23 Document No. SRS-3 that presented FPL's annual and cumulative

1 resource needs for 2005 through 2010 assuming that these resource  
2 needs would be met by supply options only.

3  
4 However, if these resources were to be supplied by DSM, the resource  
5 needs would be smaller due to the 20% reserve margin criterion that  
6 FPL uses. In other words, if FPL has load growth of 100 MW, then 120  
7 MW of either new generation and/or purchased power must be added to  
8 maintain the 20% reserve margin. Yet if FPL could meet this load  
9 growth by DSM, then only 100 MW of new DSM would be needed to  
10 maintain the 20% reserve margin.

11  
12 Therefore, the resource needs for 2005 through 2014 are smaller by  
13 20% if the needs can be met by DSM. Document No. SRS-10 presents  
14 FPL's resource needs for this time period if the needs could be met  
15 solely by DSM. Column (9) on this document is identical to Column  
16 (9) on Document No. SRS-3. Both of these Column (9)'s show what  
17 FPL's resource needs are if those needs are met solely by supply  
18 options. By comparison, Column (10) on Document No. SRS-10 shows  
19 what the reduced resource needs are if met solely by DSM.

20  
21 The third step of this approach was to use the DSM resource need  
22 values from Column (10) of Document No. SRS-10, plus the  
23 achievable usable levels for DSM, to set annual MW targets for DSM.



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22

Then, using linear programming techniques that solve the question of how to meet these annual DSM MW targets with the achievable usable amount of DSM in the most cost-effective way possible, a DSM portfolio is selected. This selection process determines which DSM measures are chosen and how much of each selected measure is chosen per year.

This DSM “portfolio” then forms the basis for constructing the With DSM resource plan. In the With DSM resource plan, the selected DSM measures - in the appropriate amount per year - are combined with needed supply options to ensure that FPL’s resource needs are met for all years in the 2005 through 2014 time period. That work was carried out again using FPL’s EGEAS model. Document No. SRS-11 presents the resulting With DSM resource plan and the annual Summer reserve margin values for this plan. By comparing the reserve margin values for the Supply Only resource plan (shown in Document No. SRS-4) and for this With DSM resource plan, it is evident that the two plans are comparable in regard to this reliability criterion. A comparison of annual LOLP projections for each resource plan also showed the two resource plans were comparable from that reliability perspective as well.

1           **Q.    How much incremental DSM is included in this With DSM**  
2                           **resource plan for the 2005 through 2014 time period?**

3           A.    All of the incremental total of 886 MW (Summer) at the generator of  
4                           DSM that was previously discussed are included in this plan.

5  
6           **Q.    How did this resource plan compare economically with the Supply**  
7                           **Only resource plan?**

8           A.    A levelized system average electric rate for the With DSM resource  
9                           plan was calculated in EGEAS in the development of the resource plan  
10                          so that it could be compared to the equivalent electric rate for the  
11                          Supply Only resource plan. Document No. SRS-12 presents a depiction  
12                          of the levelized system average electric rate calculation for the With  
13                          DSM resource plan. The resulting levelized system average electric rate  
14                          value for the With DSM resource plan is 8.7156 cents/kwh. This  
15                          electric rate is lower than the 8.7200 rate for the Supply Only resource  
16                          plan. Consequently, the DSM portfolio included in the With DSM  
17                          resource plan is both truly cost-effective and represents the maximum  
18                          amount of achievable, usable, and cost-effective DSM available to FPL  
19                          for the 2005 through 2014 time period.

20  
21  
22

1           **Q.    What else do you conclude from a comparison of the two resource**  
2           **plans?**

3           A.    The amount of DSM included in the With DSM resource plan should  
4           be set as FPL's new DSM Goals for the 2005 through 2014 time  
5           period. This amount is 886 MW (Summer) at the generator or an  
6           equivalent amount of 802 MW (Summer) at the meter.

7  
8           Although DSM values at the generator are typically used in resource  
9           planning work, DSM values at the meter are typically used when  
10          referring to DSM program implementation. Therefore, FPL will use the  
11          "at the meter" designation in referring to its proposed Summer MW  
12          DSM Goals amount of 802 MW. (The corresponding Winter MW and  
13          Energy total Goals values, plus the annual Goals values for Summer  
14          MW, Winter MW, and Energy, are presented and discussed in Mr.  
15          Brandt's testimony.)

16  
17          **IV.    Summary of Analyses**

18  
19          **Q.    How would you summarize the 2004 IRP analyses which were**  
20          **performed in order to develop the proposed DSM goals?**

21          A.    I would summarize the entire process and the results in general as  
22          follows:

- 1                                    1) FPL utilized its basic IRP process to determine how much DSM  
2                                    was cost-effective to add in the 2005 through 2014 time frame.  
3                                    This is the correct approach to take to make such a  
4                                    determination. Economic impacts were determined on a  
5                                    levelized system average electric rate basis that is the correct  
6                                    and equitable way to compare supply and DSM options that  
7                                    have different effects on a utility system.
- 8                                    2) FPL included the appropriate key assumptions in its analyses  
9                                    regarding supply options (i.e., Martin Unit No. 8, Manatee Unit  
10                                    No. 3, and Turkey Point Unit No. 5) to which FPL has either  
11                                    already committed or, due to the size (1,144 MW) and nearness  
12                                    of its planned in-service date (2007), incremental new DSM  
13                                    cannot reasonably avoid or defer.
- 14                                    3) The initial economic screening of DSM options was performed  
15                                    using an appropriate tool, the Commission's approved cost-  
16                                    effectiveness methodology, and an appropriate type of supply  
17                                    option (i.e., new CC capacity). This screening allowed FPL to  
18                                    determine optimal incentive payments and achievable market  
19                                    potential levels for each DSM measure that was shown to be  
20                                    potentially cost-effective in the cost-effectiveness screening.  
21                                    Additional analyses of load control programs further refined the  
22                                    achievable usable levels for these DSM options.

1                   4) Both the Supply Only and With DSM resource plans were  
2                   developed using the EGEAS model and were designed to  
3                   provide adequate system reliability. The two plans are  
4                   comparable in regard to system reliability criteria over the 10-  
5                   year period in question.

6                   5) Since the With DSM resource plan results in a lower system  
7                   average levelized rate, it is a more cost-effective resource plan.  
8                   Consequently, FPL proposes this amount of DSM, 802 MW  
9                   (Summer) at the meter (that corresponds to 886 Summer MW at  
10                  the generator) as its new DSM Goals for the 2005 through 2014  
11                  time frame.

12  
13                  **Q.     Does this conclude your testimony?**

14                  A.     Yes.

**Overview of FPL's IRP Process  
(An Excerpt from FPL's 2004 Site Plan)**

## **Projection of Incremental Resource Additions**

### **III.A FPL's Resource Planning:**

FPL developed an integrated resource planning (IRP) process in the early 1990's and has since utilized the process to determine when new resources are needed, what the magnitude of the needed resources are, and what type of resources should be considered. The projected timing and type of potential new power plants, the primary subject of this document, is determined as part of the IRP process work. This section discusses how FPL applied this process in its 2003 and early 2004 planning work.

#### **Four Fundamental Steps of FPL's Resource Planning:**

There are 4 fundamental "steps" to FPL's resource planning. These steps can be described as follows:


- Step 1: Determine the magnitude and timing of FPL's projected new resource needs;
- Step 2: Identify which resource options can meet the determined magnitude and timing of the specific resource needs;
- Step 3: Determine the economics for the total utility system with each of the competing options and resource plans; and,
- Step 4: Select a resource plan and make commitments, as required.

Figure III.A.1 graphically outlines the 4 steps.


# Overview of FPL's IRP Process

Fundamental  
 IRP Steps


(1) Determine the magnitude or timing of FPL new resource needs




(2) Identify competing resource options and resource plan which can meet the determine magnitude and timing of FPL resource needs



(3) Determine total system economics of competing options/ resource plan



(4) Finalize FPL's Integrated Resource Plan & commit to near-term options



Start  Completion

Timetable for Process

(Normal time period: approx. 6-7 months)

Figure III.A.1



## **Step 1: Determine the Magnitude and Timing of FPL's New Resource Needs:**

The first of these four resource planning steps – determining the magnitude and timing of FPL's projected resource needs – is essentially a determination of how many megawatts (MW) of load reduction, new capacity additions, or a combination of both load reduction and new capacity additions are expected to be needed. Also determined in this step is when the capacity is expected to be needed to meet FPL's planning criteria. This step is often referred to as a reliability assessment for the utility system.

Step 1 generally starts with an updated load forecast. Several databases are also updated in this first fundamental step, not only with the new information regarding forecasted loads, but also with other information which is used in many of the fundamental steps in resource planning. Examples of this new information include: delivered fuel price projections, current financial and economic assumptions, as well as power plant capability and reliability assumptions. During its recent IRP work, FPL made four key assumptions. These assumptions include near-term construction capacity additions through the summer of 2007, short-term firm capacity purchase additions through late spring of 2007, long-term DSM implementation through 2009, and the projected replacement of the Southern Company Unit Power Sales (UPS) contracts that end in May, 2010.

The first of these assumptions incorporates FPL's announced plans to add near-term capacity through various construction projects. These construction projects include the addition of a new combined cycle (CC) unit at Manatee, the conversion of two existing CT's at Martin into a new CC unit and a new CC unit at Turkey Point. The Manatee and Martin additions are under construction with a scheduled in-service date of June, 2005. These capacity additions were approved by the FPSC in November 2002 after comparing them to proposals that were received in response to Requests for Proposals (RFP's) that solicited alternatives for meeting FPL's 2005/2006 capacity needs. These capacity additions also received certification under the Florida Electrical Power Plant Siting Act (PPSA) in April, 2003. The new CC unit at FPL's Turkey Point site is scheduled for mid-2007. FPL selected this construction option after evaluating competing proposals provided in response to FPL's 2003 RFP. FPL recently (March 8, 2004) filed for a request for approval of a Determination of Need for this unit with the FPSC and also has pending an application for PPSA certification of this unit with a decision expected in the 1<sup>st</sup> Quarter of 2005.

The second of these assumptions involves short-term firm capacity purchase additions. These firm capacity purchases are provided by a combination of utility and independent power producers. The total capacity and duration of these purchases have changed somewhat from what was presented in the 2003 Site Plan and the annual total capacity values for these purchases are presented in Table I.D.1 as "Other Firm Capacity Purchases" up to mid-2007. These purchase amounts are included in FPL's resource planning work.

The third of these assumptions involves DSM. Since 1994, FPL's resource planning work has incorporated the DSM MW called for in FPL's approved DSM goals in its analyses. This was again the case in FPL's most recent planning work, as its approved DSM goals at the time this Site Plan was filed were included.

The fourth of these assumptions anticipates a replacement of the UPS purchases that are currently scheduled to end in May, 2010 with other purchases. These purchases are presented in Table I.D.1 as "Other Firm Capacity Purchases" for the years beyond mid-2010.

These assumptions and much of the other updated information are used in the first fundamental step: the determination of the magnitude and the timing of FPL's projected resource needs. This determination is accomplished by system reliability analyses which are typically based on the dual planning criteria of a minimum peak period reserve margin of 20% (FPL applies this to both summer and winter peaks) and a maximum loss-of-load probability (LOLP) of 0.1 day per year. Both of these criteria are commonly used throughout the utility industry.

Historically, both deterministic and probabilistic methodologies have been employed in system reliability analysis. The calculation of excess firm capacity at the time of annual system peaks (reserve margin) is the most common method, and this relatively simple deterministic calculation can be performed on a spreadsheet. The reserve margin calculation provides an indication of how much extra generation a system has above the forecasted peak load. A value of 20% is used as the reserve margin planning criteria to establish FPL's need. However, deterministic methods do not take into account probabilistic-related elements such as unit reliability and the value of being part of an interconnected system. Therefore, probabilistic methodologies have been used to provide additional information on the reliability of a generating system.

There are a number of probabilistic methods that are being used to perform system reliability analyses. Of these, the most widely used is loss-of-load probability or LOLP. Simply stated, LOLP is an index of how well a generating system may be able to meet its demand (i.e., a measure of how often load may exceed available resources). In contrast to reserve margin, the calculation of LOLP looks at the daily peak demands for each year, while taking into consideration such probabilistic events as the unavailability of individual generators due to scheduled maintenance or forced outages.

LOLP is expressed in units of the "number of times per year" that the system demand could not be served. The standard for LOLP accepted throughout the industry is a maximum of 0.1 day per year and FPL uses this LOLP standard. LOLP analyses require complex statistical calculations and are carried out using the Tie Line Assistance and Generation Reliability (TIGER) model.

The end result of the first fundamental step of resource planning is a forecast of the amount and timing of capacity resources needed to meet both the reserve margin and LOLP criteria for system reliability. This information is used in the second fundamental step: identifying resource options and resource plans that can meet the projected magnitude and timing of FPL's resource needs.

**Step 2: Identify Resource Options and Plans which can meet the Determined Magnitude and Timing of FPL's Resource Needs:**

The initial activities associated with this second fundamental step of resource planning generally proceed concurrently with the activities associated with Step 1. During Step 2, feasibility analyses of new capacity options are carried out to determine which new capacity options appear to be the most economic. These analyses also consider capacity size (MW), estimated development and construction schedules, and operating parameters and costs.

The individual new capacity options are then "packaged" into different resource plans which are designed to meet the system reliability criteria. In other words, resource plans are created by combining individual resource options so that the timing and magnitude of FPL's new projected resource needs are met and the planning criteria are satisfied. The creation of these competing resource plans is typically carried out using dynamic programming techniques with the objective of forming alternative resource plans within the constraints applied to the resource planning process. The constraints include

recognition of reserve margin criteria, feasible resource option performance characteristics, and construction or DSM implementation lead time. The development of these resource plans has been conducted using the EGEAS (Electric Generation Expansion Analysis System) computer model. When DSM options are being addressed, other computer models using both linear and non-linear programming techniques are used. For planning purposes, only FPL construction options were included in FPL's most recent planning analyses addressing FPL's 2008-2013 forecasted capacity needs.

At the conclusion of the second fundamental resource planning step, a number of different combinations of new resource options (i.e., resource plans) of a magnitude and timing necessary to meet FPL's resource needs were identified.

### **Step 3: Determining the Total System Economics:**

At the completion of fundamental steps 1 & 2, viable new resource options have been identified, and these resource options have been combined into a number of resource plans which meet the magnitude and timing of FPL's resource needs. The stage is set for comparing the system economics of these resource plans. The EGEAS model is employed to conduct the basic economic analyses of the resource plans.

The basic economic analysis of the competing resource plans focuses on total system economics. The standard basis for comparing the economics of competing resource plans is their relative impact on FPL's electricity rate levels, with the intent of minimizing FPL's levelized system average rate (i.e., a Rate Impact Measure or RIM methodology). However, in cases such as those existing for FPL's most recent planning work (wherein the DSM contribution was incorporated and the only competing options were new generating units) comparisons of competing resource plans' impacts on electricity rates and on system revenue requirements are equivalent. This basic economic analysis captures the capital and operating costs of new resource options as well as the impact these new resource options have on FPL's system fuel costs.

In addition, other system costs of these resource plans must be incorporated as needed into the economic analyses. These include transmission-related costs, such as integration and system losses; increased operating costs of existing generating units, and impacts on FPL's capital structure. These costs are evaluated separately and in addition to the system operating cost values developed in the EGEAS analysis to complete the system cost impact of each resource plan. FPL considered the results of all of the

economic analyses carried out in Step 3, before a determination of FPL's resource plan was made.

#### **Step 4: Finalizing FPL's Current Resource Plan**

The results of the work performed in the previous three fundamental steps are evaluated by FPL management and a decision is made establishing FPL's resource plan. The current resource plan is presented in the following section.

**FPL's Resource Plan in its 2004 Ten-Year Power Plant Site Plan  
 (with Current DSM Goals)**

<b>Year</b>	<b>Incremental DSM (MW) (1)</b>	<b>Incremental Generation Capacity (MW) (2)</b>	<b>Incremental New Purchases (MW) (3)</b>
2005	79	1,896	---
2006	78	---	---
2007	77	1,144	---
2008	78	324	---
2009	75	1,144	---
2010	25	---	931
2011	0	1,144	---
2012	0	---	---
2013	0	1,144	---

(1) DSM MW represent FPL's approved DSM Goals set in 1999 for the years 2005 through 2009 with MW values "at the generator". No DSM Goals were set for the 2010 - on time period. Values shown for 2005 through 2009 represent 12-month incremental values (September-to-August) and the 2010 value shown represents a 4-month incremental value (September-through-December) that captures the effects of DSM participants signed up in 2009 after August of that year.

(2) Generation MW additions, by year, are as follows:  
 2005: Manatee Unit No. 3 (1,107 MW) and Martin Unit No. 8 conversion (789 MW)  
 2006: none  
 2007: Turkey Point Unit No. 5 (1,144 MW)  
 2008: Midway CT Unit Nos. 1A and 1B (total MW = 324 MW)  
 2009: Corbett CC Unit No. 1 (1,144 MW)  
 2010: none  
 2011: Unsited CC Unit (1,144 MW)  
 2012: none  
 2013: Unsited CC Unit (1,144 MW)

(3) Values shown represent new purchases projected for the time period shown. The 2010 purchase of 931 MW is projected to replace FPL's current UPS contract with Southern Company that ends in May, 2010.

**Projected FPL Resource Needs Without Incremental DSM**

	(1)	(2)	(3) = (1) + (2)	(4)	(5)	(6) = (4) - (5)	(7) = (3) - (6)	(8) = (7) / (6)	(9) = ((6) * 1.20)-(3)
<b>August of the Year</b>	<b>Projections of FPL Unit Capability (MW) (1)</b>	<b>Projections of Firm Purchases (MW) (2)</b>	<b>Projection of Total Capacity (MW)</b>	<b>Peak Load Forecast (MW)</b>	<b>Summer DSM Forecast w/ no Signups after 2004 (MW)</b>	<b>Forecast of Firm Peak (MW)</b>	<b>Forecast of Summer Reserves (MW)</b>	<b>Forecast of Summer Res.Margins (%)</b>	<b>Supply Only MW Needed to Meet Reserve Margin (MW)</b>
2005	21,021	3,127	24,148	20,799	1,537	19,262	4,886	25.4%	(1,034)
2006	21,020	2,991	24,011	21,331	1,537	19,794	4,217	21.3%	(258)
2007	22,162	2,046	24,208	21,851	1,537	20,314	3,894	19.2%	169
2008	22,162	2,046	24,208	22,289	1,537	20,752	3,456	16.7%	694
2009	22,162	1,995	24,157	22,784	1,537	21,247	2,910	13.7%	1,339
2010	22,162	1,952	24,114	23,294	1,537	21,757	2,357	10.8%	1,994
2011	22,162	1,907	24,069	23,783	1,537	22,246	1,823	8.2%	2,626
2012	22,162	1,907	24,069	24,279	1,537	22,742	1,327	5.8%	3,221
2013	22,162	1,907	24,069	24,784	1,537	23,247	822	3.5%	3,827
2014	22,162	1,907	24,069	25,300	1,537	23,763	306	1.3%	4,447

(1) Projections include the contributions of Manatee Unit No. 3 and Martin Unit No. 8 Conversion in 2005, and Turkey Point Unit No. 5 in 2007

(2) Projections include approximately 470 MW of "put options" for June 2005 through May 2007 exercised in 2003 and 931 MW of new purchases in 2010 - on to replace the current UPS contract that ends in May 2010.

**The Supply Only Resource Plan for 2005 - 2014**

(Shown in Columns (3) - (5) Below)

	(1)	(2)	(3)	(4)	(5)	(6) = (1)+(2) +(3)+(4)+(5)	(7)	(8)	(9)	(10) = (7) - (8) - (9)	(11) = (6) - (10)	(12) = (11) / (10)
	Supply Additions						DSM Additions					
August of the Year	Projections of FPL Unit Capability (MW) (1)	Projections of Firm Purchases (MW) (2)	Cumulative New Purchases (MW)	Cumulative New CC Additions (MW) (3)	Cumulative New CT Additions (MW) (3)	Projection of Total Capacity (MW)	Peak Load Forecast (MW)	Summer DSM Forecast w/ no Signups after 2004 (MW) (4)	Cumulative Summer DSM Additions after 2004 (MW) (4)	Forecast of Firm Peak (MW)	Forecast of Summer Reserves (MW)	Forecast of Summer Res. Margins (%)
2005	21,021	3,127	0	0	0	24,148	20,799	1,537	0	19,262	4,886	25.4%
2006	21,020	2,991	0	0	0	24,011	21,331	1,537	0	19,794	4,217	21.3%
2007	22,162	2,046	170	0	0	24,378	21,851	1,537	0	20,314	4,064	20.0%
2008	22,162	2,046	0	0	648	24,856	22,289	1,537	0	20,752	4,104	19.8%
2009	22,162	1,995	0	1,144	648	25,949	22,784	1,537	0	21,247	4,702	22.1%
2010	22,162	1,952	0	2,288	648	27,050	23,294	1,537	0	21,757	5,293	24.3%
2011	22,162	1,907	0	2,288	648	27,005	23,783	1,537	0	22,246	4,759	21.4%
2012	22,162	1,907	0	3,432	648	28,149	24,279	1,537	0	22,742	5,407	23.8%
2013	22,162	1,907	0	3,432	648	28,149	24,784	1,537	0	23,247	4,902	21.1%
2014	22,162	1,907	0	4,576	648	29,293	25,300	1,537	0	23,763	5,530	23.3%

(1) Projections include the contributions of Manatee Unit No. 3 and Martin Unit No. 8 Conversion in 2005 and Turkey Point Unit No. 5 in 2007.

(2) Projections include approximately 470 MW of "put options" for June 2005 through May 2007 exercised in 2003 and 931 MW of new purchases in 2010 - on to replace the current UPS contract that ends in May 2010.

(3) A CC unit addition is assumed to add 1,144 MW (Summer) and a CT unit addition is assumed to add 162 MW (Summer).

(4) DSM MW shown are "at the generator" values for August of each year shown.



### Summary of Results of the Cost-Effectiveness Screening


**224** = Number of DSM measures submitted by PMO for cost-effectiveness screening after removing numerous "identical" measures in its comprehensive list of 329 DSM measures. In this list, an "identical" measure is the same measure, but counted once in reference to existing construction and counted a second time for either new construction or as a Code Utility Evaluation (CUE) measure. Only one of each "identical" measure was included in the screening analyses.

Cost-Effectiveness Screening Step No.	Description of Screening Step	Number of Measures at Start of Screening Step	RIM Test Only		Both RIM & Participant Tests		Payback > 2 Years		Number of Measures Passing Screening Step
			Pass	Fail	Pass	Fail	Pass	Fail	
1	With Revenue Losses only (No Administrative costs or Incentive Payments)	224	162	62	---	---	---	---	162
2	Payback to Participant Greater than 2 Years	162	---	---	---	---	139	23	139
3	With Administrative costs & Revenue Losses only (No Incentive Payments)	139	110	29	---	---	---	---	110
4	With Incentive Payments, Administrative costs, & Revenue Losses	110	---	---	54	56	---	---	54


Conclusion: **54** DSM measures of the 224 measures submitted by PMO for evaluation survived all of the cost-effectiveness screening steps.

**92** Total DSM measures survived the cost-effectiveness screening steps after accounting for the "identical" measures that correspond to some of these 54 surviving measures.


***Hypothetical Utility Peak Day Load Shape***



*Representative Effect of Implementing 100 MW of  
Load Control on the Hypothetical Utility Peak Day  
Load Shape*



***Representative Effect of Implementing 200 MW  
of Load Control on the Hypothetical  
Utility Peak Day Load Shape***



**Calculation of System Average Levelized Rate for the Supply Only Resource Plan**

	(1)	(2)	(3)	(4) = (2) / (3)	(5) = (4) * (1)	(6)	(7) = (6) * (1)
Year	Annual Discount Factor 7.93%	Annual Revenue [\$ 000]	Annual Energy Sales (@ Meter) [GWh]	Nominal Annual Rate [cents/kWh]	NPV Annual Rate [cents/kWh]	Nominal Levelized System Average Rate [cents/kWh]	NPV Levelized System Average Rate [cents/kWh]
2004	1.000	7,852,664	101,086	7.76830	7.76830	8.71998	8.71998
2005	0.927	7,836,725	103,939	7.53973	6.98576	8.71998	8.07929
2006	0.858	7,971,975	107,066	7.44585	6.39190	8.71998	7.48568
2007	0.795	8,115,604	109,369	7.42039	5.90201	8.71998	6.93568
2008	0.737	8,355,785	111,654	7.48364	5.51498	8.71998	6.42609
2009	0.683	8,753,228	113,706	7.69812	5.25623	8.71998	5.95394
2010	0.633	9,432,938	116,201	8.11778	5.13552	8.71998	5.51648
2011	0.586	9,734,224	118,530	8.21246	4.81369	8.71998	5.11117
2012	0.543	10,168,751	120,749	8.42140	4.57348	8.71998	4.73563
2013	0.503	10,464,969	123,110	8.50050	4.27725	8.71998	4.38769
2014	0.466	10,926,077	125,543	8.70306	4.05742	8.71998	4.06531
2015	0.432	11,326,681	127,917	8.85471	3.82482	8.71998	3.76662
2016	0.400	11,805,696	130,401	9.05338	3.62330	8.71998	3.48987
2017	0.371	12,166,703	132,856	9.15781	3.39581	8.71998	3.23346
2018	0.344	12,688,560	135,200	9.38503	3.22437	8.71998	2.99588
2019	0.318	13,280,904	137,641	9.64894	3.07148	8.71998	2.77576
2020	0.295	13,674,377	140,164	9.75598	2.87737	8.71998	2.57182
2021	0.273	14,327,527	142,550	10.05088	2.74655	8.71998	2.38286
2022	0.253	14,994,811	145,021	10.33975	2.61789	8.71998	2.20778
2023	0.235	15,687,098	147,644	10.62495	2.49244	8.71998	2.04557
2024	0.217	16,175,856	150,438	10.75251	2.33704	8.71998	1.89527
2025	0.201	16,995,390	153,243	11.09048	2.23339	8.71998	1.75602
2026	0.187	17,294,909	153,243	11.28594	2.10576	8.71998	1.62700
2027	0.173	17,691,359	153,243	11.54464	1.99577	8.71998	1.50746
2028	0.160	18,055,487	153,243	11.78226	1.88719	8.71998	1.39670
2029	0.148	18,487,185	153,243	12.06397	1.79034	8.71998	1.29408
2030	0.138	18,863,981	153,243	12.30985	1.69261	8.71998	1.19900
2031	0.127	19,337,816	153,243	12.61905	1.60764	8.71998	1.11090
2032	0.118	19,499,147	153,243	12.72433	1.50194	8.71998	1.02928

105.70226

105.70226

Levelized System Average Rate (2004 - 2032, 2004 cents/kWh) = **8.720**

**Projected FPL Resource Needs If Needs are Met Solely by DSM**

	(1)	(2)	(3) = (1) + (2)	(4)	(5)	(6) = (4) - (5)	(7) = (3) - (6)	(8) = (7) / (6)	(9) = ((6) * 1.20)-(3)	(10) = (9) / 1.20
<b>August of the Year</b>	<b>Projections of FPL Unit Capability (MW) (1)</b>	<b>Projections of Firm Purchases (MW) (2)</b>	<b>Projection of Total Capacity (MW)</b>	<b>Peak Load Forecast (MW)</b>	<b>Summer DSM Forecast w/ no Signups after 2004 (MW)</b>	<b>Forecast of Firm Peak (MW)</b>	<b>Forecast of Summer Reserves (MW)</b>	<b>Forecast of Summer Res.Margins (%)</b>	<b>Supply Only MW Needed to Meet Reserve Margin (MW)</b>	<b>DSM Only MW Needed to Meet Reserve Margin (MW)</b>
2005	21,021	3,127	24,148	20,799	1,537	19,262	4,886	25.4%	(1,034)	(861)
2006	21,020	2,991	24,011	21,331	1,537	19,794	4,217	21.3%	(258)	(215)
2007	22,162	2,046	24,208	21,851	1,537	20,314	3,894	19.2%	169	141
2008	22,162	2,046	24,208	22,289	1,537	20,752	3,456	16.7%	694	579
2009	22,162	1,995	24,157	22,784	1,537	21,247	2,910	13.7%	1,339	1,116
2010	22,162	1,952	24,114	23,294	1,537	21,757	2,357	10.8%	1,994	1,662
2011	22,162	1,907	24,069	23,783	1,537	22,246	1,823	8.2%	2,626	2,189
2012	22,162	1,907	24,069	24,279	1,537	22,742	1,327	5.8%	3,221	2,685
2013	22,162	1,907	24,069	24,784	1,537	23,247	822	3.5%	3,827	3,190
2014	22,162	1,907	24,069	25,300	1,537	23,763	306	1.3%	4,447	3,706

(1) Projections include the contributions of Manatee Unit No. 3 and Martin Unit No. 8 Conversion in 2005, Turkey Point Unit No. 5 in 2007

(2) Projections include approximately 470 MW of "put options" for June 2005 through May 2007 exercised in 2003 and 931 MW of new purchases in 2010 - on to replace the current UPS contract that ends in May 2010.

**FPL's With DSM Resource Plan for 2005 - 2014**  
(Shown in Columns (3) - (5) and (9) Below)

	(1)	(2)	(3)	(4)	(5)	(6) = (1)+(2) +(3)+(4)+(5)	(7)	(8)	(9)	(10) = (7) - (8) - (9)	(11) = (6) - (10)	(12) = (11) / (10)
			Supply Additions						DSM Additions			
August of the Year	Projections of FPL Unit Capability (MW) (1)	Projections of Firm Purchases (MW) (2)	Cumulative New Purchases (MW)	Cumulative New CC Additions (MW) (3)	Cumulative New CT Additions (MW) (3)	Projection of Total Capacity (MW)	Peak Load Forecast (MW)	Summer DSM Forecast w/ no Signups after 2004 (MW) (4)	Cumulative Summer DSM Additions after 2004 (MW) (4)	Forecast of Firm Peak (MW)	Forecast of Summer Reserves (MW)	Forecast of Summer Res.Margin: (%)
2005	21,021	3,127	0	0	0	24,148	20,799	1,537	55	19,207	4,941	25.7%
2006	21,020	2,991	0	0	0	24,011	21,331	1,537	132	19,662	4,349	22.1%
2007	22,162	2,046	0	0	0	24,208	21,851	1,537	208	20,106	4,102	20.4%
2008	22,162	2,046	0	0	324	24,532	22,289	1,537	290	20,462	4,070	19.9%
2009	22,162	1,995	0	1,144	324	25,625	22,784	1,537	376	20,871	4,754	22.8%
2010	22,162	1,952	0	1,144	324	25,582	23,294	1,537	465	21,292	4,290	20.1%
2011	22,162	1,907	0	2,288	324	26,681	23,783	1,537	557	21,689	4,992	23.0%
2012	22,162	1,907	0	2,288	324	26,681	24,279	1,537	652	22,090	4,591	20.8%
2013	22,162	1,907	0	3,432	324	27,825	24,784	1,537	750	22,497	5,328	23.7%
2014	22,162	1,907	0	3,432	324	27,825	25,300	1,537	852	22,911	4,914	21.4%

(1) Projections include the contributions of Manatee Unit No. 3 and Martin Unit No. 8 Conversion in 2005 and Turkey Point Unit No. 5 in 2007.

(2) Projections include approximately 470 MW of "put options" for June 2005 through May 2007 exercised in 2003 and 931 MW of new purchases in 2010 - on to replace the current UPS contract that ends in May 2010.

(3) A CC unit addition is assumed to add 1,144 MW (Summer) and a CT unit addition is assumed to add 162 MW (Summer).

(4) DSM MW shown are "at the generator" values for August of each year shown.

(5) The 852 MW of incremental DSM at the generator shown above for 2014 represents DSM signups through August 2014 only. When DSM signups for the remaining 4 months, September through December, of 2014 are included, the incremental DSM signups through the end of 2014 result in an incremental DSM total of 886 MW at the generator.

**Calculation of System Average Levelized Rate for the With DSM Resource Plan**

Year	[1] Annual Discount Factor 7.93%	[2] Annual Revenue Requirements [\$ 000]	[3] Annual Energy Sales (@ Meter) [GWh]	[4] = [2] / [3] Nominal Annual Rate [cents/kWh]	[5] = [1] * [4] NPV Annual Rate [cents/kWh]	[6] Nominal Levelized System Average Rate [cents/kWh]	[7] = [1] * [6] NPV Levelized System Average Rate [cents/kWh]
2004	1.000	7,852,664	101,086	7.76830	7.76830	8.7156	8.71559
2005	0.927	7,861,720	103,879	7.56815	7.01209	8.7156	8.07523
2006	0.858	7,987,383	106,896	7.47211	6.41444	8.7156	7.48191
2007	0.795	8,118,150	109,107	7.44054	5.91804	8.7156	6.93219
2008	0.737	8,330,343	111,301	7.48452	5.51563	8.7156	6.42286
2009	0.683	8,725,002	113,254	7.70392	5.26019	8.7156	5.95095
2010	0.633	9,262,572	115,648	8.00928	5.06688	8.7156	5.51371
2011	0.586	9,707,440	117,870	8.23572	4.82732	8.7156	5.10860
2012	0.543	9,991,685	119,979	8.32786	4.52268	8.7156	4.73325
2013	0.503	10,438,298	122,226	8.54016	4.29721	8.7156	4.38548
2014	0.466	10,737,959	124,544	8.62182	4.01955	8.7156	4.06327
2015	0.432	11,261,487	126,858	8.87724	3.83455	8.7156	3.76472
2016	0.400	11,582,519	129,342	8.95496	3.58391	8.7156	3.48812
2017	0.371	12,107,973	131,797	9.18684	3.40657	8.7156	3.23183
2018	0.344	12,460,636	134,142	9.28914	3.19143	8.7156	2.99438
2019	0.318	13,050,292	136,583	9.55484	3.04152	8.7156	2.77437
2020	0.295	13,656,004	139,105	9.81705	2.89538	8.7156	2.57053
2021	0.273	14,110,055	141,492	9.97233	2.72508	8.7156	2.38166
2022	0.253	14,783,416	143,962	10.26897	2.59997	8.7156	2.20667
2023	0.235	15,477,744	146,585	10.55889	2.47695	8.7156	2.04454
2024	0.217	16,191,261	149,379	10.83905	2.35585	8.7156	1.89432
2025	0.201	17,013,395	152,184	11.17949	2.25132	8.7156	1.75514
2026	0.187	17,309,553	152,184	11.37410	2.12221	8.7156	1.62618
2027	0.173	17,701,878	152,184	11.63189	2.01085	8.7156	1.50670
2028	0.160	18,062,660	152,184	11.86896	1.90108	8.7156	1.39600
2029	0.148	18,490,278	152,184	12.14995	1.80310	8.7156	1.29343
2030	0.138	18,834,975	152,184	12.37645	1.70176	8.7156	1.19840
2031	0.127	19,302,535	152,184	12.68368	1.61587	8.7156	1.11035
2032	0.118	19,460,325	152,184	12.78737	1.50939	8.7156	1.02876

105.64912

105.64912

Levelized System Average Rate (2004 - 2032, 2004 cents/kWh) = 3.7156