



ORIGINAL

JAMES A. MCGEE

ASSOCIATE GENERAL COUNSEL
PROGRESS ENERGY SERVICE CO., LLC

June 22, 2004

Ms. Blanca S. Bayó, Director
Division of the Commission Clerk
and Administrative Services
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

RECEIVED-FPSC
04 JUN 23 AM 10:16
COMMISSION
CLERK

Re: Docket No. 040001-EI

Dear Ms. Bayó:

Enclosed for filing in the subject docket on behalf of Progress Energy Florida, Inc., is an original and ten copies of its Performance Data Report for May 2004.

Please acknowledge your receipt of the above filing on the enclosed copy of this letter and return to the undersigned.

Very truly yours,

James A. McGee

JAM/at
CMP _____ Enclosure
COM 5
CTR _____ cc: Parties of record
ECR _____
GCL _____
OPC _____
MMS _____
RCA _____
SCR _____
SEC 1
OTH _____

100 Central Avenue (33701) • Post Office Box 14042 (33733) • St. Petersburg, Florida
Phone: 727.820.5184 • Fax: 727.820.5519 • Email: james.mcgee@pgnmail.com

DOCUMENT NUMBER-DATE

06898 JUN 23 3

FPSC-COMMISSION CLERK

Progress Energy Florida

CERTIFICATE OF SERVICE

Docket No. 040001-EI

I HEREBY CERTIFY that a true copy of Progress Energy Florida, Inc.'s Performance Data Report for the month of May 2004 has been furnished to the following individuals by regular US Mail this 22nd day of June 2004.

John Butler
Steel Hector & Davis
200 S. Biscayne Blvd.
Suite 4000
Miami, FL 33131

Robert Vandiver, Esquire
Office of the Public Counsel
111 West Madison Street
Room 812
Tallahassee, FL 32399-1400

Jeffrey A. Stone, Esquire
Russell A. Badders, Esquire
Beggs and Lane
P. O. Box 12950
Pensacola, FL 32576-2950

Joseph A. McGlothlin, Esquire
Vicki Gordon Kaufman, Esquire
McWhirter, Reeves, McGlothlin,
117 S. Gadsden Street
Tallahassee, FL 32301


Lee L. Willis, Esquire
James D. Beasley, Esquire
Ausley & McMullen
P. O. Box 391
Tallahassee, FL 32302

John McWhirter, Jr.
McWhirter, Reeves, McGlothlin,
400 North Tampa Street
Suite 2450
Tampa, FL 33601

Wm. Cochran Keating, IV
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, FL 32399-0850

Norman Horton, Jr., Esquire
Messer, Caparello & Self
P. O. Box 1876
Tallahassee, FL 32302

Ronald C. LeFace, Esquire
Seann M. Frazier, Esquire
Greenberg Traurig
101 East College Avenue
Tallahassee, FL 32301



Attorney

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2004

ANCLOTE 1	Jan-04	Feb-04	Mar-04	Apr-04	May-04	Jun-04	Jul-04	Aug-04	Sep-04	Oct-04	Nov-04	Dec-04	Jan - May Period
1. EAF	90.32	96.99	99.52	98.58	93.85								95.82
2. PH	744	696	744	719	744								3,647
3. SH	577.2	560.3	724.6	719.0	744.0								3,325.1
4. RSH	102.4	135.7	19.4	0.0	0.0								257.6
5. UH	64.4	0.0	0.0	0.0	0.0								64.4
6. POH	0.0	0.0	0.0	0.0	0.0								0.0
7. FOH	64.4	0.0	0.0	0.0	0.0								64.4
8. MOH	0.0	0.0	0.0	0.0	0.0								0.0
9. PFOH	23.1	13.2	0.0	49.6	85.8								171.7
10. LR PF (MW)	164.8	159.0	0.0	4.0	64.8								67.9
11. PMOH	0.0	52.4	11.2	30.7	108.9								203.2
12. LR PM (MW)	0.0	159.0	159.0	159.0	158.2								158.6
13. NSC (MW)	498	498	498	498	498								498
14. OPER MBTU	1,399,153	1,482,450	1,742,969	1,863,808	1,915,072								8,403,451
15. NET GEN (MWH)	138,668	147,363	179,497	184,737	189,583								839,848
16. ANOHR (BTU/KWH)	10,089.9	10,059.8	9,710.3	10,089.0	10,101.5								10,005.9
17. NOF (%)	48.24	52.81	49.74	51.59	51.17								50.72
18. NPC (MW)	498	498	498	498	498								498

ORIGINAL

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2004

ANCLOTE 2	Jan-04	Feb-04	Mar-04	Apr-04	May-04	Jun-04	Jul-04	Aug-04	Sep-04	Oct-04	Nov-04 ²⁾	Dec-04	Jan - May Period
1. EAF	98.69	97.77	97.01	67.62	82.88								88.82
2. PH	744	696	744	719	744								3,647
3. SH	663.1	696.0	744.0	503.0	658.4								3,264.4
4. RSH	81.0	0.0	0.0	0.0	0.0								81.0
5. UH	0.0	0.0	0.0	216.1	85.6								301.7
6. POH	0.0	0.0	0.0	216.1	85.6								301.7
7. FOH	0.0	0.0	0.0	0.0	0.0								0.0
8. MOH	0.0	0.0	0.0	0.0	0.0								0.0
9. PFOH	0.0	1.7	4.0	9.4	40.9								55.9
10. LR PF (MW)	0.0	15.1	156.1	305.9	255.1								249.4
11. PMOH	30.9	49.2	66.7	34.7	65.8								247.3
12. LR PM (MW)	156.0	156.0	156.0	156.0	156.0								156.0
13. NSC (MW)	495	495	495	495	495								495
14. OPER MBTU	1,363,547	1,801,870	1,911,438	1,229,320	1,701,438								8,007,613
15. NET GEN (MWH)	132,833	179,808	182,380	124,143	165,337								784,501
16. ANOHR (BTU/KWH)	10,265.1	10,021.1	10,480.5	9,902.5	10,290.7								10,207.3
17. NOF (%)	40.47	52.19	49.52	49.86	50.73								48.55
18. NPC (MW)	495	495	495	495	495								495

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2004

CRYSTAL RIVER 1	Jan-04	Feb-04	Mar-04	Apr-04	May-04	Jun-04	Jul-04	Aug-04	Sep-04	Oct-04	Nov-04 ^{2h}	Dec-04	Jan - May Period
1. EAF	97.71	89.10	16.05	29.22	80.02								62.30
2. PH	744	696	744	719	744								3,647
3. SH	744.0	627.4	119.4	210.1	604.7								2,305.5
4. RSH	0.0	0.0	0.0	0.0	0.0								0.0
5. UH	0.0	68.7	624.6	508.9	139.3								1,341.5
6. POH	0.0	0.0	624.6	506.1	0.0								1,130.7
7. FOH	0.0	68.7	0.0	2.9	76.1								147.6
8. MOH	0.0	0.0	0.0	0.0	63.3								63.3
9. PFOH	4.9	0.8	0.0	0.0	0.0								5.7
10. LR PF (MW)	66.0	74.9	0.0	0.0	0.0								67.3
11. PMOH	65.2	17.6	0.0	0.0	18.7								101.5
12. LR PM (MW)	93.8	152.4	0.0	0.0	189.0								121.5
13. NSC (MW)	379	379	379	379	379								379
14. OPER MBTU	2,089,953	2,058,497	365,503	586,007	1,767,680								6,867,640
15. NET GEN (MWH)	212,857	204,585	36,536	55,079	172,880								681,937
16. ANOHR (BTU/KWH)	9,818.6	10,061.8	10,003.9	10,639.4	10,224.9								10,070.8
17. NOF (%)	75.49	86.04	80.75	69.17	75.44								78.04
18. NPC (MW)	379	379	379	379	379								379

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 004

CRYSTAL RIVER 2	Jan-04	Feb-04	Mar-04	Apr-04	May-04	Jun-04	Jul-04	Aug-04	Sep-04	Oct-04	Nov-04	Dec-04	Jan - May Period
1. EAF	94.17	5.14	92.68	94.32	85.24								75.08
2. PH	744	696	744	719	744								3,647
3. SH	744.0	56.2	715.3	693.5	662.2								2,871.2
4. RSH	0.0	0.0	0.0	0.0	0.0								0.0
5. UH	0.0	639.8	28.7	25.5	81.8								775.8
6. POH	0.0	0.0	0.0	0.0	0.0								0.0
7. FOH	0.0	0.0	2.6	25.5	81.8								109.9
8. MOH	0.0	639.8	26.1	0.0	0.0								665.9
9. PFOH	40.5	49.9	29.7	4.4	20.3								144.9
10. LR PF (MW)	181.4	199.0	118.6	78.4	276.0								184.7
11. PMOH	54.0	0.0	73.0	58.5	28.8								214.3
12. LR PM (MW)	254.4	0.0	123.0	121.3	278.3								176.5
13. NSC (MW)	486	486	486	486	486								486
14. OPER MBTU	2,651,908	150,466	2,698,049	2,684,569	2,387,991								10,572,983
15. NET GEN (MWH)	266,641	13,730	280,206	274,571	241,666								1,076,814
16. ANOHR (BTU/KWH)	9,945.6	10,958.9	9,628.8	9,777.3	9,881.4								9,818.8
17. NOF (%)	73.74	50.27	80.61	81.47	75.09								77.17
18. NPC (MW)	486	486	486	486	486								486

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2004

CRYSTAL RIVER 3	Jan-04	Feb-04	Mar-04	Apr-04	May-04	Jun-04	Jul-04	Aug-04	Sep-04	Oct-04	Nov-04 ²⁾	Dec-04	Jan - May Period
1. EAF	100.00	100.00	87.74	100.00	100.00								97.50
2. PH	744	696	744	719	744								3,647
3. SH	744.0	696.0	672.3	719.0	744.0								3,575.3
4. RSH	0.0	0.0	0.0	0.0	0.0								0.0
5. UH	0.0	0.0	71.7	0.0	0.0								71.7
6. POH	0.0	0.0	0.0	0.0	0.0								0.0
7. FOH	0.0	0.0	35.1	0.0	0.0								35.1
8. MOH	0.0	0.0	36.5	0.0	0.0								36.5
9. PFOH	0.0	0.0	21.3	0.0	0.0								21.3
10. LR PF (MW)	0.0	0.0	353.0	0.0	0.0								353.0
11. PMOH	0.0	0.0	22.0	0.0	0.0								22.0
12. LR PM (MW)	0.0	0.0	341.9	0.0	0.0								341.9
13. NSC (MW)	769	769	769	769	769								769
14. OPER MBTU	5,984,903	5,599,017	5,284,304	5,783,843	5,985,047								28,637,114
15. NET GEN (MWH)	589,270	551,445	517,097	569,151	583,206								2,810,170
16. ANOHR (BTU/KWH)	10,156.5	10,153.3	10,219.2	10,162.2	10,262.3								10,190.5
17. NOF (%)	102.99	103.03	100.01	102.94	101.93								102.21
18. NPC (MW)	769	769	769	769	769								769

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 004

CRYSTAL RIVER 4	Jan-04	Feb-04	Mar-04	Apr-04	May-04	Jun-04	Jul-04	Aug-04	Sep-04	Oct-04	Nov-04	De -04	Jan - May Period
1. EAF	96.37	76.54	94.03	98.46	96.66								92.58
2. PH	744	696	744	719	744								3,647
3. SH	721.3	580.5	744.0	716.2	744.0								3,506.1
4. RSH	0.0	0.0	0.0	0.0	0.0								0.0
5. UH	22.7	115.5	0.0	2.8	0.0								140.9
6. POH	0.0	0.0	0.0	0.0	0.0								0.0
7. FOH	22.7	115.5	0.0	2.8	0.0								140.9
8. MOH	0.0	0.0	0.0	0.0	0.0								0.0
9. PFOH	5.2	7.5	321.3	116.1	17.9								467.8
10. LR PF (MW)	351.3	299.5	99.5	51.6	358.0								103.5
11. PMOH	12.8	285.8	0.0	0.0	27.7								326.3
12. LR PM (MW)	101.1	112.5	0.0	0.0	415.0								137.7
13. NSC (MW)	720	720	720	720	720								720
14. OPER MBTU	4,179,046	3,100,776	4,349,207	4,324,800	4,306,115								20,259,942
15. NET GEN (MWH)	450,351	322,485	459,633	455,925	448,574								2,136,958
16. ANOHR (BTU/KWH)	9,279.5	9,615.3	9,462.3	9,485.8	9,599.6								9,480.7
17. NOF (%)	86.71	77.16	85.80	88.41	83.74								84.65
18. NPC (MW)	720	720	720	720	720								720

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2004

CRYSTAL RIVER 5	Jan-04	Feb-04	Mar-04	Apr-04	May-04	Jun-04	Jul-04	Aug-04	Sep-04	Oct-04	Nov-04 ^{2*}	Dec-04	Jan - May Period
1. EAF	100.00	96.33	100.00	81.13	88.83								93.30
2. PH	744	696	744	719	744								3,647
3. SH	744.0	696.0	744.0	593.8	665.2								3,443.0
4. RSH	0.0	0.0	0.0	0.0	0.0								0.0
5. UH	0.0	0.0	0.0	125.2	78.8								204.0
6. POH	0.0	0.0	0.0	122.0	76.2								198.2
7. FOH	0.0	0.0	0.0	3.2	2.6								5.8
8. MOH	0.0	0.0	0.0	0.0	0.0								0.0
9. PFOH	0.0	11.0	0.0	0.0	8.0								19.0
10. LR PF (MW)	0.0	304.4	0.0	0.0	99.0								217.9
11. PMOH	0.0	144.3	0.0	75.6	11.3								231.2
12. LR PM (MW)	0.0	103.6	0.0	99.0	202.4								107.0
13. NSC (MW)	717	717	717	717	717								717
14. OPER MBTU	4,632,050	4,181,723	4,591,836	3,620,472	3,803,862								20,829,943
15. NET GEN (MWH)	492,117	437,398	489,122	384,853	396,107								2,199,597
16. ANOHR (BTU/KWH)	9,412.5	9,560.5	9,387.9	9,407.4	9,603.1								9,469.9
17. NOF (%)	92.25	87.65	91.69	90.39	83.05								89.10
18. NPC (MW)	717	717	717	717	717								717

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2004

HINES 1	Jan-04	Feb-04	Mar-04	Apr-04	May-04	Jun-04	Jul-04	Aug-04	Sep-04	Oct-04	Nov-04	Dec-04	Jan - May Period
1. EAF	100.00	100.00	83.60	34.09	82.61								80.11
2. PH	744	696	744	719	744								3,647
3. SH	744.0	696.0	622.0	480.3	744.0								3,286.3
4. RSH	0.0	0.0	0.0	0.0	0.0								0.0
5. UH	0.0	0.0	122.0	238.7	0.0								360.7
6. POH	0.0	0.0	122.0	238.7	0.0								360.7
7. FOH	0.0	0.0	0.0	0.0	0.0								0.0
8. MOH	0.0	0.0	0.0	0.0	0.0								0.0
9. PFOH	0.0	0.0	0.0	0.0	1.7								1.7
10. LR PF (MW)	0.0	0.0	0.0	0.0	293.9								293.9
11. PMOH	0.0	0.0	0.0	480.3	262.1								742.4
12. LR PM (MW)	0.0	0.0	0.0	236.0	236.0								236.0
13. NSC (MW)	482	482	482	482	482								482
14. OPER MBTU	1,653,792	1,796,347	1,783,285	726,204	1,643,294								7,602,923
15. NET GEN (MWH)	217,724	246,290	244,992	92,129	216,532								1,017,667
16. ANOHR (BTU/KWH)	7,595.8	7,293.6	7,279.0	7,882.5	7,589.1								7,470.9
17. NOF (%)	60.71	73.42	81.71	39.80	60.38								64.25
18. NPC (MW)	482	482	482	482	482								482

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 004

TIGER BAY	Jan-04	Feb-04	Mar-04	Apr-04	May-04	Jun-04	Jul-04	Aug-04	Sep-04	Oct-04	Nov-04	Dec-04	Jan - May Period
1. EAF	100.00	91.46	38.84	94.18	100.00								84.75
2. PH	744	696	44	719	744								3,647
3. SH	595.1	636.6	70.3	492.7	685.2								2,479.9
4. RSH	148.9	0.0	218.8	184.5	58.8								610.9
5. UH	0.0	59.4	455.0	41.8	0.0								556.2
6. POH	0.0	48.0	455.0	0.0	0.0								503.0
7. FOH	0.0	11.4	0.0	0.0	0.0								11.4
8. MOH	0.0	0.0	0.0	41.8	0.0								41.8
9. PFOH	0.0	0.0	0.0	0.0	0.0								0.0
10. LR PF (MW)	0.0	0.0	0.0	0.0	0.0								0.0
11. PMOH	0.0	0.0	0.0	0.0	0.0								0.0
12. LR PM (MW)	0.0	0.0	0.0	0.0	0.0								0.0
13. NSC (MW)	207	207	207	207	207								207
14. OPER MBTU	797,679	896,778	153,325	720,009	944,728								3,512,518
15. NET GEN (MWH)	98,830	117,429	11,615	90,929	122,847								441,650
16. ANOHR (BTU/KWH)	8,071.2	7,636.8	13,200.6	7,918.4	7,690.3								7,953.2
17. NOF (%)	80.23	89.11	79.87	89.16	86.61								86.04
18. NPC (MW)	207	207	207	207	207								207

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - MAY 2004

Date	Outage Type	Hours	MW Affected	Description
1/5/2004	PFO	20.90	158.0	CONDENSER TUBE LEAKS
1/13/2004	FFO	64.35	498.0	ECONOMIZER LEAKS
1/21/2004	PFO	2.23	227.9	FEEDWATER PUMP
2/2/2004	PFO	8.98	159.0	CONDENSER TUBE LEAKS
2/3/2004	PMO	6.63	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
2/4/2004	PMO	16.23	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
2/5/2004	PMO	11.07	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
2/14/2004	PFO	4.18	159.1	CONDENSER TUBE LEAKS
2/15/2004	PMO	6.88	159.0	CONDENSER TUBE FOULING TUBE SIDE
2/16/2004	PMO	4.58	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
2/17/2004	PMO	2.72	158.9	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
2/19/2004	PMO	4.32	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
3/2/2004	PMO	6.57	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
3/2/2004	PMO	4.58	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
4/6/2004	PFO	49.58	4.0	OTHER HIGH PRESSURE HEATER PROBLEMS
4/15/2004	PMO	26.20	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
4/23/2004	PMO	4.48	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
5/3/2004	PFO	65.83	4.0	OTHER HIGH PRESSURE HEATER PROBLEMS
5/4/2004	PMO	12.77	155.0	CONDENSER TUBE FOULING TUBE SIDE
5/5/2004	PMO	8.28	155.0	CONDENSER TUBE FOULING TUBE SIDE
5/6/2004	PMO	8.12	159.0	CONDENSER TUBE FOULING TUBE SIDE
5/11/2004	PMO	14.02	159.0	CONDENSER TUBE FOULING TUBE SIDE
5/13/2004	PMO	4.17	158.9	CONDENSER TUBE FOULING TUBE SIDE
5/13/2004	PMO	4.63	159.0	CONDENSER TUBE FOULING TUBE SIDE
5/16/2004	PMO	9.03	159.0	CONDENSER TUBE FOULING TUBE SIDE
5/17/2004	PMO	6.38	159.0	CONDENSER TUBE FOULING TUBE SIDE

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - MAY 2004

Date	Outage Type	Hours	MW Affected	Description
5/20/2004	PFO	17.32	304.0	OTHER OIL AND GAS FUEL SUPPLY PROBLEMS
5/22/2004	PFO	2.67	13.1	IGNITERS
5/23/2004	PMO	5.58	159.0	CONDENSER TUBE FOULING TUBE SIDE
5/24/2004	PMO	2.17	159.0	CONDENSER TUBE FOULING TUBE SIDE
5/24/2004	PMO	5.85	159.0	CONDENSER TUBE FOULING TUBE SIDE
5/27/2004	PMO	27.08	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
5/31/2004	PMO	7.68	159.0	CONDENSER TUBE FOULING TUBE SIDE

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - MAY 2004

Date	Outage Type	Hours	MW Affected	Description
1/13/2004	PMO	3.20	155.9	CONDENSER TUBE FOULING TUBE SIDE
1/14/2004	PMO	3.38	156.0	CONDENSER TUBE FOULING TUBE SIDE
1/18/2004	PMO	6.68	156.0	CONDENSER TUBE FOULING TUBE SIDE
1/19/2004	PMO	7.02	156.0	CONDENSER TUBE FOULING TUBE SIDE
1/20/2004	PMO	4.95	156.0	CONDENSER TUBE FOULING TUBE SIDE
1/21/2004	PMO	5.70	156.0	CONDENSER TUBE FOULING TUBE SIDE
2/15/2004	PMO	7.33	156.0	CONDENSER TUBE FOULING TUBE SIDE
2/16/2004	PMO	7.00	156.0	CONDENSER TUBE FOULING TUBE SIDE
2/18/2004	PFO	1.67	15.1	BOTTOM ASH HOPPERS (INCLUDING GATES)
2/22/2004	PMO	8.47	156.0	CONDENSER TUBE FOULING TUBE SIDE
2/23/2004	PMO	7.67	156.0	CONDENSER TUBE FOULING TUBE SIDE
2/24/2004	PMO	6.70	156.0	CONDENSER TUBE FOULING TUBE SIDE
2/25/2004	PMO	5.75	156.0	CONDENSER TUBE FOULING TUBE SIDE
2/26/2004	PMO	6.25	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/16/2004	PMO	2.62	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/16/2004	PMO	1.97	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/16/2004	PMO	1.98	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/16/2004	PMO	9.88	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/17/2004	PFO	3.98	156.0	FEEDWATER PUMP DRIVE - CONTROLS
3/17/2004	PMO	6.55	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/18/2004	PMO			CONDENSER TUBE FOULING TUBE SIDE
3/21/2004	PMO			CONDENSER TUBE FOULING TUBE SIDE
3/22/2004	PMO		156.0	CONDENSER TUBE FOULING TUBE SIDE
3/23/2004	PMO	6.33	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/24/2004	PMO	6.88	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/25/2004	PMO	7.62	156.0	CONDENSER TUBE FOULING TUBE SIDE

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - MAY 2004

Date	Outage Type	Hours	MW Affected	Description
4/6/2004	PFO	0.25	479.2	FUEL OIL PUMPS - GENERAL
4/6/2004	PFO	9.13	301.0	FUEL OIL PUMPS - GENERAL
4/11/2004	PMO	8.60	156.0	CONDENSER TUBE FOULING TUBE SIDE
4/12/2004	PMO	6.87	156.0	CONDENSER TUBE FOULING TUBE SIDE
4/13/2004	PMO	8.67	156.0	CONDENSER TUBE FOULING TUBE SIDE
4/14/2004	PMO	4.85	156.0	CONDENSER TUBE FOULING TUBE SIDE
4/15/2004	PMO	1.97	156.0	CONDENSER TUBE FOULING TUBE SIDE
4/16/2004	PMO	3.75	156.0	CONDENSER TUBE FOULING TUBE SIDE
4/21/2004	PO	216.05	495.0	MINOR BOILER OVERHAUL (LESS THAN 720 HOURS)
5/1/2004	PO	85.60	495.0	MINOR BOILER OVERHAUL (LESS THAN 720 HOURS)
5/9/2004	PMO	8.05	156.0	CONDENSER TUBE FOULING TUBE SIDE
5/10/2004	PFO	17.75	190.0	TURBINE CONTROL VALVES
5/11/2004	PMO	12.92	156.0	CONDENSER TUBE FOULING TUBE SIDE
5/12/2004	PMO	6.20	156.0	CONDENSER TUBE FOULING TUBE SIDE
5/12/2004	PMO	9.35	156.0	CONDENSER TUBE FOULING TUBE SIDE
5/17/2004	PMO	2.62	156.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
5/19/2004	PMO	6.08	156.0	CONDENSER TUBE FOULING TUBE SIDE
5/20/2004	PMO	7.67	156.0	CONDENSER TUBE FOULING TUBE SIDE
5/23/2004	PFO	19.75	350.0	BOILER CASING
5/26/2004	PMO	6.33	156.0	CONDENSER TUBE FOULING TUBE SIDE
5/29/2004	PFO	3.35	40.0	HIGH CIRCULATING WATER TEMPERATURE
5/30/2004	PMO	3.32	155.9	CONDENSER TUBE FOULING TUBE SIDE
5/30/2004	PMO	3.22	156.0	CONDENSER TUBE FOULING TUBE SIDE

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - MAY 2004

Date	Outage Type	Hours	MW Affected	Description
1/4/2004	PFO	4.93	66.0	PULVERIZER FEEDERS
1/4/2004	PMO	51.23	47.0	OTHER CIRCULATING WATER SYSTEM PROBLEMS
1/25/2004	PMO	14.00	265.0	COAL CONVEYERS AND FEEDERS
2/1/2004	PMO	5.65	75.0	PULVERIZER MILLS
2/9/2004	PMO	5.17	189.0	CONDENSER TUBE AND WATER BOX CLEANING
2/13/2004	FFO	68.65	379.0	FIRST REHEATER LEAKS
2/23/2004	PMO	6.77	189.0	CONDENSER TUBE AND WATER BOX CLEANING
2/27/2004	PFO	0.80	74.9	PULVERIZER COAL LEAK (PULVERIZERS ONLY)
3/5/2004	PO	1130.67	379.0	MAJOR TURBINE OVERHAUL (720 HOURS OR LONGER)
4/22/2004	FFO	1.35	379.0	FEEDWATER PUMP
4/23/2004	FFO	1.50	379.0	FEEDWATER PUMP
5/5/2004	FFO	23.30	379.0	TURBINE SUPERVISORY SYSTEM
5/12/2004	FFO	51.52	379.0	CONDENSER TUBE LEAKS
5/18/2004	PMO	7.23	189.0	CONDENSER TUBE AND WATER BOX CLEANING
5/19/2004	FFO	1.27	379.0	TURBINE HYDRAULIC SYSTEM PIPES AND VALVES
5/20/2004	PMO	11.47	189.0	CONDENSER TUBE AND WATER BOX CLEANING
5/22/2004	FMO	63.25	379.0	TURBINE MAIN STOP VALVES

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - MAY 2004

Crystal River 2				
Date	Outage Type	Hours	MW Affected	Description
1/6/2004	PMO	2.45	275.9	CONDENSER TUBE AND WATER BOX CLEANING
1/14/2004	PMO	28.50	252.0	AIR HEATER (HEAT PIPE, PLATE-TYPE)
1/15/2004	PMO	1.67	104.1	PULVERIZER MILLS
1/23/2004	PFO	7.50	104.0	PULVERIZER MILLS
1/23/2004	PMO	7.33	104.0	PULVERIZER MILLS
1/25/2004	PMO	14.00	352.0	COAL CONVEYERS AND FEEDERS
1/30/2004	PFO	82.90	199.0	BOILER RECIRCULATION VALVES
2/3/2004	FMO	639.80	486.0	BOILER RECIRCULATION VALVES
3/3/2004	PFO	9.25	180.0	OTHER FEEDWATER VALVES
3/7/2004	PMO	7.00	85.0	PULVERIZER MILLS
3/8/2004	PMO	7.00	85.0	PULVERIZER MILLS
3/9/2004	FFO	1.50	486.0	OTHER INSTRUMENT AIR PROBLEMS
3/10/2004	PMO	6.57	85.0	PULVERIZER MILLS
3/12/2004	PFO	1.17	85.0	IGNITERS
3/12/2004	PMO	6.08	85.0	PULVERIZER MILLS
3/15/2004	PMO	5.62	271.0	CONDENSER TUBE AND WATER BOX CLEANING
3/17/2004	PMO	4.80	257.0	CONDENSER TUBE AND WATER BOX CLEANING
3/18/2004	PMO	2.40	85.1	PULVERIZER FEEDERS
3/18/2004	PFO	1.05	85.2	PULVERIZER FEEDERS
3/18/2004	PMO	10.38	85.0	PULVERIZER MILLS
3/19/2004	FFO	1.12	486.0	FEEDWATER CONTROLS
3/19/2004	PMO	8.13	191.0	OTHER VOLTAGE CONDUCTORS AND BUSES
3/21/2004	PFO	1.92	129.0	480-VOLT TRANSFORMERS
3/25/2004	PFO	3.82	94.0	FOREIGN OBJECT IN MILL
3/26/2004	FMO	26.12	486.0	CIRCUIT BREAKERS
3/29/2004	PFO	12.50	85.0	OTHER PULVERIZER PROBLEMS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - MAY 2004

Date	Outage Type	Hours	MW Affected	Description
3/30/2004	PMO	4.90	94.0	OTHER PULVERIZER PROBLEMS
3/30/2004	PMO	4.50	85.0	OTHER PULVERIZER PROBLEMS
3/31/2004	PMO	2.92	85.0	OTHER PULVERIZER PROBLEMS
3/31/2004	PMO	2.72	85.0	OTHER PULVERIZER PROBLEMS
4/2/2004	PMO	32.12	104.0	PULVERIZER MILLS
4/4/2004	PFO	2.62	94.0	OTHER PULVERIZER PROBLEMS
4/4/2004	PMO	5.33	290.0	CONDENSER TUBE AND WATER BOX CLEANING
4/8/2004	PMO	4.10	85.0	OTHER PULVERIZER PROBLEMS
4/9/2004	PMO	4.67	85.0	OTHER PULVERIZER PROBLEMS
4/11/2004	PMO	4.75	104.0	OTHER PULVERIZER PROBLEMS
4/12/2004	PMO	4.83	143.0	CONDENSER TUBE AND WATER BOX CLEANING
4/13/2004	PMO	2.55	104.1	CIRCULATING WATER PUMPS
4/14/2004	PMO	0.18	93.0	CIRCULATING WATER PUMPS
4/14/2004	FFO	25.50	486.0	EMERGENCY GENERATOR TRIP DEVICES
4/30/2004	PFO	1.80	55.9	BOTTOM ASH SYSTEMS (WET OR DRY)
5/4/2004	PMO	4.58	295.0	CONDENSER TUBE AND WATER BOX CLEANING
5/4/2004	PMO	7.15	295.0	CONDENSER TUBE AND WATER BOX CLEANING
5/6/2004	PMO	5.92	271.0	CONDENSER TUBE AND WATER BOX CLEANING
5/17/2004	PFO	20.33	276.0	BOILER RECIRCULATION VALVES
5/20/2004	PMO	4.10	295.0	CONDENSER TUBE AND WATER BOX CLEANING
5/22/2004	FFO	81.77	486.0	FURNACE WALL LEAKS
5/31/2004	PMO	7.07	247.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS

PROGRESS ENERGY FLORIDA

Crystal River 3				
Date	Outage Type	Hours	MW Affected	Description
3/2/2004	PMO	6.77	400.0	REACTOR COOLANT/RECIRCULATING PUMP MOTORS
3/3/2004	FMO	36.53	769.0	REACTOR COOLANT/RECIRCULATING PUMP MOTORS
3/4/2004	PMO	15.27	316.0	REACTOR COOLANT/RECIRCULATING PUMP MOTORS
3/24/2004	FFO	35.13	769.0	REACTOR CONTROL SYSTEM/INTEGRATED CONTROL SYSTEM PROBLEMS
3/25/2004	PFO	21.30	353.0	REACTOR CONTROL SYSTEM/INTEGRATED CONTROL SYSTEM PROBLEMS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - MAY 2004

Date	Outage Type	Hours	MW Affected	Description
1/5/2004	PMO	5.50	101.1	PULVERIZER COAL LEAK (PULVERIZERS ONLY)
1/7/2004	FFO	22.67	720.0	PROCESS COMPUTER
1/10/2004	PMO	7.33	101.0	PULVERIZER COAL LEAK (PULVERIZERS ONLY)
1/21/2004	PFO	1.77	101.1	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
1/26/2004	PFO	3.38	482.1	AC INSTRUMENT POWER TRANSFORMERS
2/1/2004	FFO	1.88	720.0	FORCED DRAFT FAN DRIVES (OTHER THAN MOTOR)
2/10/2004	PMO	3.00	433.9	CEMS CERTIFICATION AND RECERTIFICATION
2/10/2004	PMO	1.50	243.8	CEMS CERTIFICATION AND RECERTIFICATION
2/11/2004	PMO	271.39	102.0	HEATER DRAIN PUMPS
2/12/2004	PMO	5.20	256.0	CEMS CERTIFICATION AND RECERTIFICATION
2/12/2004	PMO	4.75	309.1	CEMS CERTIFICATION AND RECERTIFICATION
2/17/2004	PFO	4.22	509.0	OTHER BOILER TUBE LEAKS
2/17/2004	FFO	87.58	720.0	OTHER BOILER TUBE LEAKS
2/21/2004	FFO	7.87	720.0	DESUPERHEATER/ATTEMPERATOR CONTROLS
2/21/2004	FFO	7.15	720.0	OPERATOR ERROR
2/22/2004	FFO	0.97	720.0	FEEDWATER REGULATING (BOILER LEVEL CONTROL) VALVE
2/23/2004	PFO	3.25	27.9	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
2/25/2004	FFO	8.67	720.0	OTHER EXCITER PROBLEMS
2/25/2004	FFO	1.38	720.0	OPERATOR ERROR
3/1/2004	PFO	15.00	125.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/2/2004	PFO	12.50	130.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/3/2004	PFO	18.83	120.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/4/2004	PFO	5.00	92.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/5/2004	PFO	18.08	139.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/6/2004	PFO	16.83	120.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/7/2004	PFO	14.25	87.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - MAY 2004

Date	Outage Type	Hours	MW Affected	Description
3/8/2004	PFO	40.33	111.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/11/2004	PFO	13.17	73.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/12/2004	PFO	18.33	125.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/13/2004	PFO	17.08	102.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/17/2004	PFO	15.00	111.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/18/2004	PFO	15.75	111.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/19/2004	PFO	3.92	30.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/20/2004	PFO	4.25	82.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/22/2004	PFO	52.42	92.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/25/2004	PFO	14.00	35.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/26/2004	PFO	5.83	39.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/29/2004	PFO	7.17	63.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/31/2004	PFO	7.75	54.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/31/2004	PFO	5.75	38.9	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/1/2004	PFO	13.00	101.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/1/2004	PFO	5.50	54.1	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/2/2004	PFO	19.00	54.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/3/2004	PFO	16.75	54.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/4/2004	PFO	13.50	35.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/5/2004	PFO	5.75	58.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/5/2004	PFO	12.50	25.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/6/2004	PFO	6.83	58.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/6/2004	PFO	11.00	35.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/7/2004	PFO	5.33	35.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/12/2004	PFO	1.13	101.0	OTHER PULVERIZER PROBLEMS
4/17/2004	PFO	5.80	43.9	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - MAY 2004

Date	Outage Type	Hours	MW Affected	Description
4/19/2004	FFO	2.77	720.0	PULVERIZER FEEDER MOTOR
5/17/2004	PMO	8.92	415.0	CONDENSER TUBE AND WATER BOX CLEANING
5/18/2004	PMO	10.25	415.0	CONDENSER TUBE AND WATER BOX CLEANING
5/19/2004	PFO	17.85	358.0	CONDENSER TUBE LEAKS
5/25/2004	PMO	8.50	415.0	CONDENSER TUBE AND WATER BOX CLEANING

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - MAY 2004

Date	Outage Type	Hours	MW Affected	Description
2/1/2004	PMO	141.33	98.0	PULVERIZER MILLS
2/23/2004	PFO	2.72	99.0	BURNER INSTRUMENTS AND CONTROLS (EXCEPT LIGHT-OFF)
2/24/2004	PMO	2.08	431.0	CEMS CERTIFICATION AND RECERTIFICATION
2/24/2004	PMO	0.83	241.0	CEMS CERTIFICATION AND RECERTIFICATION
2/24/2004	PFO	3.12	431.1	AIR HEATER FOULING (REGENERATIVE)
2/25/2004	PFO	5.15	335.9	AIR HEATER FOULING (REGENERATIVE)
4/22/2004	PMO	75.63	99.0	PULVERIZER OVERHAUL
4/25/2004	FFO	3.20	717.0	OTHER FEEDWATER VALVES
4/25/2004	PO	122.00	717.0	BOILER INSPECTIONS
5/1/2004	PO	76.20	717.0	BOILER INSPECTIONS
5/4/2004	FFO	1.32	717.0	OTHER FEEDWATER VALVES
5/4/2004	FFO	0.60	717.0	OTHER FEEDWATER VALVES
5/4/2004	FFO	0.65	717.0	OTHER FEEDWATER VALVES
5/13/2004	PFO	8.00	99.0	HEATER DRAIN PUMPS
5/26/2004	PMO	3.08	479.1	CONDENSER TUBE AND WATER BOX CLEANING
5/27/2004	PMO	8.25	99.0	PULVERIZER MILLS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - MAY 2004

Date	Outage Type	Hours	MW Affected	Description
3/26/2004	PO	360.68	482.0	MAJOR GAS TURBINE OVERHAUL
4/10/2004	PMO	742.38	236.0	MAJOR GAS TURBINE OVERHAUL
5/20/2004	PFO	1.08	327.1	TURBINE HYDRAULIC SYSTEM PIPES AND VALVES
5/21/2004	PFO	0.65	237.3	GT COOLING AND SEAL AIR SYSTEM

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - MAY 2004

Date	Outage Type	Hours	MW Affected	Description
2/27/2004	FFO	11.43	207.0	SOLID STATE EXCITER ELEMENT
2/28/2004	PO	503.00	207.0	GAS TURBINE HOT END INSPECTION
4/13/2004	FMO	41.83	207.0	MAIN STEAM RELIEF/SAFETY VALVES