

ORIGINAL

David B. Erwin
Attorney At Law

127 Riversink Road
Crawfordville, Florida 32327

Telephone 850.926.9331
Fax 850.926.8448
daveerwin@direcway.com

November 2, 2004

Blanca Bayo, Div. of the Commission Clerk
and Administrative Services
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

RECEIVED-TPSC
NOV - 2 PM 4: 31
COMMISSION
CLERK

In re: Application of Indiantown Company, Inc. for Increased
Water and Wastewater Rates in Martin County - Docket No. 040450-WS

Dear Ms. Bayo:

On October 18, 2004, Tim Devlin, Director of Economic Regulation, noted two deficiencies in the data filed by Indiantown Company, Inc., in its rate filing.

In order to obtain a filing date, the company herewith submits a response to the itemized deficiencies by filing a detailed map in compliance with Rule 25-30.440(1)(a), F. A. C., and the most recent DEP Community Public Water System Sanitary Survey, dated September 17, 2002, in compliance with Rule 25-30.440(5), F. A. C.

Please let us know if you have any further questions.

Sincerely,



David B. Erwin

CMP _____
COM _____
CTR _____
ECR map
GCL 1
OPC 1
MMS _____
RCA 1
SCR _____
SEC 1
OTH _____

DBE:jm

Copy: Trish Merchant
Bart Fletcher
Jeff Leslie
Jim Hewitt
Robert Nixon

DOCUMENT NUMBER-DATE
11808 NOV-2 04
FPSC-COMMISSION CLERK



State of Florida
 Department of Environmental Protection
 Southeast District
COMMUNITY PUBLIC WATER SYSTEM
SANITARY SURVEY - INSPECTION REPORT

Name INDIANTOWN County Martin PWS ID # 4430667
 Plant Location 15851 SW Farms Road Indiantown 34956 Phone 772.597.2121
 Owner Name Indiantown Company, Inc. Phone _____
 Owner Address P. O. Box 397 Indiantown 34956
 Contact Person James Hewitt jimh@itstelecom.net Title Superintendent Phone 772.597.2201
 Date 9/17/02 Last Inspection Date\Type 4/4/02 01 Photos Taken _____
 Inspected by: J. Toney Others present: Jim Hewitt
 Insp. Result: In w/D COMET: SITE ID PROJECT ID _____ Inspection type: **SS** 01 02 03

SERVICE AREA CHARACTERISTICS

Residents: _____ Total _____ Seasonal _____

Other licensed activities (List Agency and number)
042396-WC issued 11/5/99

Other DEP permitted facilities (Program \ permit#)

of Serv. Connects _____ (_____ ERCs)
 Population Served 5433 (_____ / ERC)
 Average Day (from MORs) _____ gpd
 Max. Day (from MORs) _____ 883 tgpd
 Max-day Design Capacity _____ 1,296 mgpd
 % of Design Capacity (from MORs) _____ 68
 Comments _____

OPERATION & MAINTENANCE

Certified Operator(s) \ Level-ID# \ Shift
James Hewitt B3821 :Lead Operator
Dean Smiley B5715 Earl Maine C4644
Ernie Watson C8649 Don Johnson B2816
 Plant Category/Class 3C
 Hrs/day: Required 6 Actual 8
 Days/wk: Required 5+2wev Actual 5+2 (4hr)
 weekend visits

RAW WATER SOURCES

GROUND SURFACE PURCHASED EMERGENCY
 # Wells: 8 Adequate Supply? _____
2,3, & 4 not used

TREATMENT PROCESSES\CHEMICALS IN USE

Ammoniation Fluoridation Chlorination _____
 Aeration Filtration Acrylamide \ Epichlorohydrin
 Coagulation Odor\Taste control Softening _____
 Stabilization Corrosion Control Membrane _____

Additional treatment needed:

FACILITY COMPLIANCE AREAS EVALUATED I - In Compliance; M - Marginal; O - Out of Compliance; R - Return to Compliance; N - Not evaluated		
<input type="checkbox"/> Raw Supply - Page _____	<input type="checkbox"/> Filtration\Softening - Page _____	<input type="checkbox"/> Distribution\CCCP - Page _____
<input type="checkbox"/> Disinfection - Page _____	<input type="checkbox"/> Storage - _____ -Page _____	<input type="checkbox"/> Operation\Maint. - Page _____
<input type="checkbox"/> Filtration - Page _____	<input type="checkbox"/> Emergency\Auxiliary - Page _____	<input type="checkbox"/> Records\Monitoring - Page _____
<input type="checkbox"/> Ion Exchange Page _____	<input type="checkbox"/> Other _____ -Page _____	<input type="checkbox"/> Other _____ -Page _____

RAW WATER SOURCE INVENTORY

Facility: Indiantown_____

PWS ID# 4430667

Date 9/17/02

GROUND WATER SOURCE Total Number of wells 8

WELL INVENTORY INFORMATION

Well Number \ Description	1/2/3	4/5/6	7/8
Well Location: Latitude	wells 2/3/4 not used	wells 1,5,6 operate together	wells 7,8 operate together
Well Location: Longitude (Method det.)			
Year Constructed	1989/1983/1987	1958/1974/1975	1990/1990
Permit # \ Agency			
Depth Drilled \ Drilling Method	135/130/120 rotary	115/125/125 driven	120/125 rotary
Inner Casing: Length \ Diameter \ Material			
Outer Casing: Length \ Diameter \ Material	85/105/85X8"	115(10)/125(8)/125(8)	70(16/8)/85(18/8)
Depth of Grout	85/0/85	0/0/0	70/85
Static Water Level	23/-19		16.8/13.1
Pumping Water Level			26.8/29.75
Design Well Yield			
Actual Yield (if different than rated capacity)			
PUMP	Type (lubrication)	sub	sub
	Manufacturer Name \ Model		
	Rated Capacity (gpm)	450/100/140	60/130/200
	Motor Horsepower \ Auxiliary power	20/10/7.5	5/7.5/7.5

INSPECTION RESULTS (check deficiencies for correction)

1	Satisfactory Well History	yes	yes	yes
2	Sufficient Distance from Sanitary Hazards	entire wellfield subject to	contamination from nearby	petroleum contamination sites
3	Site not subject to Inundation \ UDI	yes	yes	yes
4	Unused \ Unapproved well(s) abandoned	n/a	n/a	n/a
5	6' X 6' X 4" Concrete Pad (Centered)	generally yes but older wells	may have pads slightly	less than 6x6
6	Well casing \ seal: 12" above grade	yes	yes	yes
7	Satisfactory Sanitary Seal	yes	yes	yes
8	Pump Suction Line above grade \ protected	n/a	n/a	n/a
9	Pump Discharge: pressure gauge \ meter	yes	yes	yes
10	Discharge valves: check \ shutoff \ waste	yes	yes	yes
11	Sample Tap: pressurized \ representative	yes	yes	yes
12	Sample Tap: smooth-nosed \ down-facing	yes	yes	yes
13	Well Vent: <u>screened</u> \ downward facing	not downfacing	not downfacing	not downfacing
14	Provision for disinfection \ level measurement	yes	yes	yes
15	Satisfactory maintenance \ physical condition	yes	yes	yes
16	Adequate Protection from vandalism \ weather	yes	yes	yes
17	Adequate # wells \ auxiliary power provided	yes	yes	yes

DISINFECTION

Facility: Indiantown _____ PWS ID # 4430667 _____

CHLORINATION: Pre Post Hypo Gas Other: _____ Date 9/17/02 _____

Chemical Supplier: _____ Avg. amount of Cl₂ gas used _____

Certification: _____ Remote tap location _____

Cl Feed Rate _____ Capacity (gpd) _____ Injection Points _____

Model _____ Booster Pump Info _____

Chlorine Actuated by: _____ Chlorine Residuals: Plant _____ Remote _____

Reference YES NO N/A

	<input checked="" type="checkbox"/>			Chlorination exists and is operable
	<input checked="" type="checkbox"/>			Chlorine is dosed and proportional to flow
				Adequate chlorine residual (0.2 mg/L Free; 0.6 mg/L Total)
	<input checked="" type="checkbox"/>			A detention tank of adequate volume is provided [_____ gal.]
	<input checked="" type="checkbox"/>			Piping of the detention tank is adequate to prevent shortcircuiting
	<input checked="" type="checkbox"/>			Approved chemicals, coatings and hoses are in use
	<input checked="" type="checkbox"/>			A DPD method test kit is onsite

Gas Chlorination requirements

	<input checked="" type="checkbox"/>			Gas chlorine cylinders are properly secured/chained upright
	<input checked="" type="checkbox"/>			Scales for weighing chlorine consumption are provided
	<input checked="" type="checkbox"/>			Automatic switch-over for the gas cylinders is provided
	<input checked="" type="checkbox"/>			Required Dual Chlorination provided
	<input checked="" type="checkbox"/>			Standby chlorinators/booster pump exists for every 5 or fraction
	<input checked="" type="checkbox"/>			Wrench fitted to valve stem of cylinder in use
	<input checked="" type="checkbox"/>			Leak detection is provided for gas system (e.g. ammonia bottle)
	<input checked="" type="checkbox"/>			An audible alarm and warning light for loss of chlorination capability is provided
	<input checked="" type="checkbox"/>			Adequate cross ventilation (e.g. floor level fan)
	<input checked="" type="checkbox"/>			An adequate air-pack (SCBA)/emergency response contract is provided
	<input checked="" type="checkbox"/>			Chemical warning signs are posted
				Spare chlorinator parts are provided
	<input checked="" type="checkbox"/>			Chlorination housing/protection is adequate

Comments: _____

STORAGE FACILITIES

Facility: Indiantown _____ PWS ID # 4430667 _____

Date 9/17/02

(B) Bladder (C) Clearwell (D) Detention (E) Elevated (G) Ground (H) Hydropneumatic

Tank Type/Number	C	H	G	Settler		
Capacity (gal)	127,000	10,000	500,000	53,000		
Material						
Gravity Drain	N/A	Yes	Yes			
By-pass Piping	Yes	Yes	Yes			
Pressure Gauge	n/a	Yes	n/a			
PRV/ARV						
On/Off Pressure		60/80				
Level Indicator	Yes	Yes	Yes			
Protected Openings	Yes	n/a	Yes			
Access Padlocked						
Height to Bottom of Elevated Tank						
Height to Max. Water Level						
Physical Condition						
Age						
Last serviced (date)						

Comments: _____

HIGH SERVICE PUMPS

Pump Number	1/2/3	backwash	
Type			
Make			
Model			
Capacity (gpm)	900	1250	
Motor HP	50	75	
Date Installed			
Maintenance			

Comments: _____

AUXILIARY POWER SOURCE (serves over 350 people)

Yes None Not Required

Source / Capacity(kW) 250 + old 45 kw

Switchover: Automatic Manual

Standby Plan: No Yes _____

Logbook: No Yes 4 (hrs./month oper. under load)

What equipment does it operate?

Well pumps 1-4

High Service Pumps _____

Treatment Equipment _____

Other _____

Satisfy 1/2 max-day demand? Yes No Unk

Comments: In combination with storage generator operates 1 hr/ week under load

Reference YES NO N/A

		X	
		X	

A satisfactory air compressor (oil-free) is employed for pressure vessels

Satisfactory Float switches employed (Non-Mercury)

All inspection items above satisfactory (_____)

FILTRATION \ SOFTENING

Facility: Indiantown _____ PWS ID # 4430667 _____

Date 9/17/02 _____

FILTRATION 2 UNITS _____

DIMENSION _____

Type Sand Greensand Carbon Dual Media

Length of Filter Runs 48-72 hrs

Type of Filter Media sand

Is media visible? _____ Clean after BW? _____

Filter Rate 2 gpm/sf BW Rate ~25 gpm/sf

Filter Capacity 648,000 gpd each

Cracks/Cementation/Channeling _____

Effluent Stability _____ Algae Growth _____

Turbidity in clearwell? _____

Head Loss Gauge _____

Comments: _____

SOFTENING (Ca/Mg Hardness Removal)

Chemical Precipitation Process:

Chemicals Used _____

Nature of Floc _____

Sludge Blanket Appearance _____

Is settling OK? _____

Excessive carry-over? _____

Secondary Precipitation _____

Effluent Stability _____

Recarbonation Type _____

Sludge Recirculation Used _____

Comments: _____

ION Exchange Process: _____ UNITS _____ DIM.

Make _____ Model _____

Capacity _____

Grade of Salt for Regeneration _____

Backwash Effluent Destination _____

Comments: _____

REVERSE OSMOSIS (Dissolved Solids Removal)

Make _____ Pressure _____

No. of Modules _____ Permeate Cap. _____

Blend Rate (GPM) _____

Chemicals Used _____

Waste-to-product Ratio _____

Pre-treatment _____

Effluent Quality: TDS (mg/L) _____

Waste Disposal Site _____

IW Permit # & Expir. Date _____

Comments _____

Reference YES NO N/A

FILTRATION

<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Filters are operable
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Backwash is disposed of properly, at least 100' from wells
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Individual filters can be bypassed
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Sample taps are located at the filter influent and effluent lines
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Chlorine injection and the detention tank follow carbon filters
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Rate of flow controllers are provided on each filter
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Continuous monitoring turbidimeters are provided
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	All inspection items above satisfactory (_____)

SOFTENING

<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Spent brine/reject is disposed of properly, at least 100' from wells
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	A bypass with proportioning valve is provided for blending
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Sample taps are located at the softener influent & effluent
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Sample tap is provided for blended water.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Softeners have bypass piping
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Sludge disposal satisfactory [Location: _____]

All inspection items above satisfactory (_____)

OPERATION & MAINTENANCE

Facility: Indiantown _____ PWS ID # 4430667 _____

Date 9/17/02

Reference	YES	NO	N/A	
	X			Adequate operation and maintenance logbook maintained and secured
	X			Adequate operator coverage is logged [see cover page]
	X			Routine Maintenance, daily chemical usage recorded
	X			Calibration logbooks maintained for analytical equipment
	X			Monthly Operational Reports (MORs) satisfactory (see comments below)
	X			*Satisfactory Process performance records retained for treatment employed
	X			Abnormal Events properly recorded and reported for system (MORs, logbook, DEP)
	X			Plant is protected from weather, tampering & vandalism
	X			All electrical wiring is in proper conduit
	X			Finished sample tap is provided: 12" above ground, smooth-nosed & downfacing
	X			Has device to measure pumpage of finished water [timeclock / meter]
		X		Meter has bypass
	X			Meter is routinely calibrated [Last calibration Date: _____]
	X			A distribution system pressure gauge exists and is operable [Location: _____]
	X			Permit has plant rating [yes: _1.296 Mgalpd; no: file implies _____ gpd]
	X			MDF on MOR's is less than plant rating. [_____ Gpd for _____, 19__]

Comments: _____

***As certified on Part II of submitted Monthly Operating Reports: Process performance records shall be kept for the following treatment processes:**
Coagulation/flocculation records should include source water temperature, pH, turbidity, color, and alkalinity and process effluent pH and alkalinity in addition to chemical feed rates.
Sedimentation records should include process effluent turbidity and sludge volume produced.
Filtration records should include process effluent turbidity and color, number of filters in service, filtration rates, unit filter run volumes, head losses, length of filter runs, frequency of backwash, amount of backwash water used, duration of backwash, and backwash rates.
Lime-soda ash softening records should include source water and process effluent hardness in addition to records for coagulation/flocculation, sedimentation, and filtration.
Ion exchange softening records should include feed and bypass flows, blend rate, and salt and brine used.
Nanofiltration and reverse osmosis records should include feed, product, and brine flows; feed pressure, temperature, pH, conductivity, and turbidity; product pH and conductivity; and brine pH and conductivity.
Electrodialysis records should include polarity, feed temperature and total dissolved solids, product conductivity and total dissolved solids, dilute flow rate, brine make-up, pressures, and volts/amps.

DISTRIBUTION SYSTEM \ CROSS CONNECTION CONTROL PROGRAM

Reference	YES	NO	N/A	
	X			A cross connection control program is on file
	X			Required Backflow prevention devices present
	X			A Coliform Sampling plan is maintained
				A distribution flushing\maintenance program is
	X			An Asbestos Monitoring Plan has been submitted

Comments: _____

TREATMENT PROCESSES

Facility: Indiantown _____ PWS ID # 4430667

Date 9/17/02

AERATION (Natural/Forced Draft, Packed Tower)

Type CASCADE Capacity 900 gpm

Proper Maintenance/Screening _____

Comments: _____

OTHER TASTE/ODOR CONTROL PROCESSES

Explain: _____

AMMONIATION

Make _____ Capacity _____

Injection Points _____

Comments: _____

COAGULATION (Turbidity Removal)

Chemicals Used _____

Condition of Floc _____

Is settling OK? _____

Comments: _____

STABILIZATION

Effluent S.I. _____ Is pH control done? _____

Chemical Used _____

Injection Point _____

pH Range of Effluent _____

Comments: _____

FLUORIDATION

Chemical Used _____ Strength _____

Corrosion Noted _____ Plugging Noted _____

Feeder Make/Model _____

High Level Ventilation (acid) _____

Acid carboys/day tank vented outside _____

Designated Electrical Outlet (acid) _____

Analytical Testing Equipment _____

Anti-siphon Valves _____

Residual Range _____

Point of Application _____

Emergency Eyewash _____


Comments: _____

ADDITIVES/CHEMICALS

Meets NSF 60 & 61 _____

Chemical Inventory: Name \ Mfr. \ Cert. # \ Storage

Treatment schematic



RECORDS \ MONITORING

Facility: Indiantown _____ PWS ID # 4430667 _____

Date 9/17/02 _____

Reference	YES	NO	N/A	
	X			Records \ Reports are retained on premises for inspection
	X			Public Notice\Boil water advisory forms are retained on premises
	X			Adequate bacteriological monitoring is provided. [Qtr. , Mo., _____]
	X			Chemical monitoring is current. If no, check & indicate due date:
				<input type="checkbox"/> Nitrate\ Nitrite _____ <input type="checkbox"/> Primary Inorganics _____
				<input type="checkbox"/> Volatile Organics _____ <input type="checkbox"/> Turbidity _____
				<input type="checkbox"/> Pesticides\PCBs _____ <input type="checkbox"/> Secondaries _____
				<input type="checkbox"/> Radionuclides _____ <input type="checkbox"/> Unregulated Organics _____
				<input type="checkbox"/> Trihalomethanes _____ <input type="checkbox"/> Lead/Copper _____
				<input type="checkbox"/> Other _____
	X			No monitoring violations documented over the last 12 months [_____]
	X			System is in compliance with all MCL's [No: _____]
	X			Required analyses are reported in acceptable format [_____]
	X			WTP is permitted [HRS/DEP No: _____ , dated: _____] see comment
				System conforms with permit
	X			PWS has been updated per this inspection
	X			The system appears to be properly classified as a [NC , NTNC , C]

Comments: (include pertinent compliance history)

Permit includes:

**COMPLIANCE MONITORING
COMMUNITY PUBLIC WATER SYSTEMS**

CONTAMINANT	PWS Screen	# Samples Required	Sampling Location	C > 3300			C ≤ 3300		
				Frequency	Sample Date	Due Date	Frequency	Sample Date	Due Date
Microbiological (Bacte)	024	1	Each well	monthly			monthly		
		2	Distribution						
Volatile Organics	028	<i>(Note A)</i>	<i>(Note H)</i>	<i>(Notes A, 1)</i>			<i>(Notes A, 2)</i>		
Pesticides & PCBs	029	<i>(Notes B, E)</i>	<i>(Note H)</i>	3 years <i>(Note 1)</i>			3 years <i>(Note 2)</i>		
Nitrate & Nitrite (as N)	030	1	POE	annually			annually		
Inorganics	030	1	POE	3 years <i>(Note 1)</i>			3 years <i>(Note 2)</i>		
Asbestos	030	1 <i>(Note F)</i>	Distribution	9 years <i>(Note 7)</i>			9 years <i>(Note 8)</i>		
Secondaries	031	1	POE	3 years <i>(Note 1)</i>			3 years <i>(Note 2)</i>		
Radionuclides	033	<i>(Note C)</i>	POE	3 years <i>(Note 1)</i>			3 years <i>(Note 2)</i>		
Group I UOCs (OMIT)	035	<i>(Notes B, E, G)</i>	POE	<i>(Note 4)</i>			<i>(Note 5)</i>		
Group II UOCs (OMIT)	034	1 <i>(Notes E, G)</i>	POE	3 years <i>(Note 1)</i>			3 years <i>(Note 2)</i>		
Group III UOCs (OMIT)	036, 037	1 <i>(Note G)</i>	POE	<i>(Note 4)</i>			<i>(Note 5)</i>		
Lead and Copper	047	<i>(Note D)</i>	---	---			---		
TTHM (≥ 10,000 persons)	027	4/plant	Distribution	Quarterly			N/A	N/A	N/A

POE = Point of Entry (Samples shall be taken at each entry point to the distribution system that is representative of each source after treatment.)
See Page 5 for description of italicized notes.

NOTES:

SAMPLES REQUIRED/SAMPLING LOCATION:

Note A See Rule 62-550.515(1), F.A.C. Each system shall take four consecutive quarterly samples during its assigned year in the system's first compliance period. If no contaminant is detected, the system shall monitor annually during the next three-year compliance period. If still no contaminants are detected, systems shall take one sample during each subsequent three-year compliance period.

If the initial monitoring for contaminants listed in Rule 62-550.310(2)(b), F.A.C., was completed prior to December 31, 1992, then each system shall take one sample annually beginning January 1, 1993.

Note B 4 consecutive quarterly samples. Credit will be given for samples taken before January 1, 1993.

Note C See Rule 62-550.519, F.A.C. Compliance shall be based on the average of analyses of four consecutive quarterly samples. A maximum of two quarterly samples may be composited. Subsequent samples shall be collected once every three years.

Note D Contact the Southeast District's Drinking Water Program at (561) 681-6760 or contact the Florida Rural Water Association.

Note E Contact the Southeast District's Drinking Water Program at (561) 681-6760, to obtain an application for reduced monitoring.

Note F See Rule 62-550.511(4), F.A.C. A system without asbestos-containing components shall certify to the Department in writing, using DEP Form No. 62-555.910(10), that it is asbestos free. Certification shall satisfy subsections (1), (2), and (3) of the referenced rule, and shall be submitted each nine-year compliance cycle during the specified year the system is required to monitor.

Note G See Rule 62-550.521(4), F.A.C. Systems serving less than 150 service connections and serving fewer than 350 persons should notify the Department, by submitting DEP Form No. 62-555.910(11), that their system is available for testing. Normally, these small systems will not be required to monitor for UOCs. Do not send such samples to the Department unless required to do so by the Department.

Note H First quarter samples shall be representative of each well. Subsequent samples shall be taken at each entry point to the distribution system that is representative of each source after treatment.

FREQUENCY:

Note 1 First year of each three-year compliance period (calendar years 1993, 1996, 1999, etc.)

Note 2 Second year of each three-year compliance period (calendar years 1994, 1997, 2000, etc.)

Note 3 Third year of each three-year compliance period (calendar years 1995, 1998, 2001, etc.)

Note 4 First year of the first three-year compliance period (i.e. calendar year 1996)

Note 5 Second year of the first three-year compliance period (i.e. calendar year 1997)

Note 6 Third year of the first three-year compliance period (i.e. calendar year 1998)

Note 7 First year of each nine-year compliance cycle (calendar years 1993, 2002, etc.)

Note 8 Second year of each nine-year compliance cycle (calendar years 1994, 2003, etc.)

Note 9 Third year of each nine-year compliance cycle (calendar years 1995, 2004, etc.)

Facility: Indiantown _____ PWS ID #
4430667 _____

Date 9/17/02 _____

MONITORING VIOLATIONS	MCL VIOLATIONS

DEFICIENCIES:

1. Generator is run 1 hour per week, not 4 hours continuously as required. (will be corrected. See attached memo from Jim Hewitt.)
2. Algae growing in aerator. (scheduled maintenance will correct this.)
3. Hydro tank compressor oil needs to be changed to vegetable oil. (See memo from J. Hewitt)
4. Security of several wells is suspect due to remote isolated locations.

Inspector _____ Title ESII Date _____
Approved by _____ Title _____ Date _____