



JAMES A. MCGEE
ASSOCIATE GENERAL COUNSEL
PROGRESS ENERGY SERVICE CO., LLC

January 26, 2005

Ms. Blanca S. Bayó, Director
Division of the Commission Clerk
and Administrative Services
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Re: Docket No. 050001-EI

Dear Ms. Bayó:

Enclosed for filing in the subject docket on behalf of Progress Energy Florida, Inc., is an original and ten copies of its Performance Data Report for December 2004.

Please acknowledge your receipt of the above filing on the enclosed copy of this letter and return to the undersigned.

Very truly yours,

A handwritten signature in cursive script, appearing to read "James A. McGee".

James A. McGee

JAM/at
Enclosure

cc: Parties of record

Progress Energy Florida

CERTIFICATE OF SERVICE

Docket No. 050001-EI

I HEREBY CERTIFY that a true copy of Progress Energy Florida, Inc.'s Performance Data Report for the month of December 2004 has been furnished to the following individuals by regular US Mail this 26th day of January 2005.

John Butler
Steel Hector & Davis
200 S. Biscayne Blvd.
Suite 4000
Miami, FL 33131

Jeffrey A. Stone, Esquire
Russell A. Badders, Esquire
Beggs and Lane
P. O. Box 12950
Pensacola, FL 32576-2950

Lee L. Willis, Esquire
James D. Beasley, Esquire
Ausley & McMullen
P. O. Box 391
Tallahassee, FL 32302

Wm. Cochran Keating, IV
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, FL 32399-0850


Robert Vandiver, Esquire
Office of the Public Counsel
111 West Madison Street
Room 812
Tallahassee, FL 32399-1400

Joseph A. McGlothlin, Esquire
Vicki Gordon Kaufman, Esquire
McWhirter, Reeves, McGlothlin,
117 S. Gadsden Street
Tallahassee, FL 32301

John McWhirter, Jr.
McWhirter, Reeves, McGlothlin,
400 North Tampa Street
Suite 2450
Tampa, FL 33601

Norman Horton, Jr., Esquire
Messer, Caparello & Self
P. O. Box 1876
Tallahassee, FL 32302

Ronald C. LeFace, Esquire
Seann M. Frazier, Esquire
Greenberg Traurig
101 East College Avenue
Tallahassee, FL 32301



Attorney

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2004

ANCLOTE 1	Jan-04	Feb-04	Mar-04	Apr-04	May-04	Jun-04	Jul-04	Aug-04	Sep-04	Oct-04	Nov-04	Dec-04	Jan - Dec Period
1. EAF	90.32	96.99	99.52	98.58	93.85	93.85	98.01	98.43	94.48	88.46	99.36	99.57	95.94
2. PH	744	696	744	719	744	720	744	744	720	745	720	744	8,784
3. SH	577.2	560.3	724.6	719.0	744.0	714.1	744.0	741.5	697.4	678.0	720.0	688.4	8,308.5
4. RSH	102.4	135.7	19.4	0.0	0.0	0.0	0.0	1.9	0.0	0.0	0.0	55.6	315.0
5. UH	64.4	0.0	0.0	0.0	0.0	5.9	0.0	0.6	22.6	67.0	0.0	0.0	160.5
6. POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7. FOH	64.4	0.0	0.0	0.0	0.0	5.9	0.0	0.6	22.6	67.0	0.0	0.0	160.5
8. MOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
9. PFOH	23.1	13.2	0.0	49.6	85.8	0.0	10.2	30.6	15.1	9.8	108.0	400.4	745.7
10. LR PF (MW)	164.8	159.0	0.0	4.0	64.8	0.0	373.5	70.6	120.0	328.1	4.0	4.0	33.1
11. PMOH	0.0	52.4	11.2	30.7	108.9	124.0	22.4	20.8	32.1	36.0	11.7	0.0	450.2
12. LR PM (MW)	0.0	159.0	159.0	159.0	158.2	154.3	159.0	160.7	209.4	172.9	159.0	0.0	162.3
13. NSC (MW)	498	498	498	498	498	498	498	498	498	498	498	498	498
14. OPER MBTU	1,399,153	1,482,450	1,742,969	1,863,808	1,915,072	2,088,498	2,376,294	2,449,352	2,226,080	2,141,219	1,750,302	1,797,386	23,232,582
15. NET GEN (MWH)	138,668	147,363	179,497	184,737	189,583	212,089	237,666	243,531	228,439	220,212	174,002	182,104	2,337,891
16. ANOHR (BTU/KWH)	10,089.9	10,059.8	9,710.3	10,089.0	10,101.5	9,847.3	9,998.5	10,057.7	9,744.7	9,723.4	10,059.1	9,870.1	9,937.4
17. NOF (%)	48.24	52.81	49.74	51.59	51.17	59.64	64.15	65.95	65.78	65.22	48.53	53.12	56.50
18. NPC (MW)	498	498	498	498	498	498	498	498	498	498	498	498	498

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2004

ANCLOTE 2	Jan-04	Feb-04	Mar-04	Apr-04	May-04	Jun-04	Jul-04	Aug-04	Sep-04	Oct-04	Nov-04	Dec-04	Jan - Dec Period
1. EAF	98.69	97.77	97.01	67.62	82.88	94.69	95.02	94.71	89.67	93.50	51.34	97.64	88.47
2. PH	744	696	744	719	744	720	744	744	720	745	720	744	8,784
3. SH	663.1	696.0	744.0	503.0	658.4	720.0	744.0	701.2	703.1	745.0	232.5	345.5	7,455.7
4. RSH	81.0	0.0	0.0	0.0	0.0	0.0	0.0	42.8	0.0	0.0	142.9	398.5	665.2
5. UH	0.0	0.0	0.0	216.1	85.6	0.0	0.0	0.0	16.9	0.0	344.6	0.0	663.1
6. POH	0.0	0.0	0.0	216.1	85.6	0.0	0.0	0.0	0.0	0.0	344.6	0.0	646.2
7. FOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	16.9	0.0	0.0	0.0	16.9
8. MOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
9. PFOH	0.0	1.7	4.0	9.4	40.9	4.3	9.6	0.0	117.8	13.8	0.0	709.3	910.6
10. LR PF (MW)	0.0	15.1	156.1	305.9	255.1	270.2	393.7	0.0	135.9	222.2	0.0	12.1	51.1
11. PMOH	30.9	49.2	66.7	34.7	65.8	113.8	93.4	124.9	79.9	134.0	18.3	0.9	812.3
12. LR PM (MW)	156.0	156.0	156.0	156.0	156.0	156.0	156.0	156.0	156.0	156.0	156.0	146.3	156.0
13. NSC (MW)	495	495	495	495	495	495	495	495	495	495	495	495	495
14. OPER MBTU	1,363,547	1,801,870	1,911,438	1,229,320	1,701,438	2,324,451	2,522,089	2,459,458	2,309,517	2,510,434	718,485	890,076	21,742,123
15. NET GEN (MWH)	132,833	179,808	182,380	124,143	165,337	221,515	252,253	247,978	230,685	253,777	71,665	87,620	2,149,994
16. ANOHR (BTU/KWH)	10,265.1	10,021.1	10,480.5	9,902.5	10,290.7	10,493.4	9,998.3	9,918.0	10,011.6	9,892.3	10,025.6	10,158.4	10,112.6
17. NOF (%)	40.47	52.19	49.52	49.86	50.73	62.15	68.49	71.45	66.28	68.82	62.27	51.23	58.26
18. NPC (MW)	495	495	495	495	495	495	495	495	495	495	495	495	495

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2004

CRYSTAL RIVER 1	Jan-04	Feb-04	Mar-04	Apr-04	May-04	n-04	I-04	Aug-04	Sep-04	Oct-04	Nov-04	c-04	- Dec eriod
1. EAF	97.71	89.10	16.05	29.22	80.02	4.13	7.23	91.90	90.23	94.98	94.81	18.41	80.31
2. PH	744	696	744	719	744	720	744	744	720	745	720	744	8,784
3. SH	744.0	627.4	119.4	210.1	604.7	20.0	14.0	744.0	720.0	745.0	720.0	744.0	442.5
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5. UH	0.0	68.7	624.6	508.9	139.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	341.5
6. POH	0.0	0.0	624.6	506.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	130.7
7. FOH	0.0	68.7	0.0	2.9	76.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	147.6
8. MOH	0.0	0.0	0.0	0.0	63.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	63.3
9. PFOH	4.9	0.8	0.0	0.0	0.0	10.5	11.6	48.1	206.3	79.1	30.2	23.3	424.8
10. LR PF (MW)	66.0	74.9	0.0	0.0	0.0	55.8	1.6	171.7	106.6	106.0	143.3	28.7	118.6
11. PMOH	65.2	17.6	0.0	0.0	18.7	64.6	6.2	157.4	49.3	42.1	77.0	10.9	379.0
12. LR PM (MW)	93.8	152.4	0.0	0.0	189.0	87.4	19.3	92.5	94.7	137.9	127.8	36.2	98.8
13. NSC (MW)	379	379	379	379	379	379	379	379	379	379	379	379	379
14. OPER MBTU	2,089,953	2,058,497	365,503	586,007	1,767,680	916	361	2,194,744	1,906,888	2,115,164	2,021,953	762	3,428
15. NET GEN (MWH)	212,857	204,585	36,536	55,079	172,880	932	434	212,688	182,843	205,915	197,890	140	7,779
16. ANOHR (BTU/KWH)	9,818.6	10,061.8	10,003.9	10,639.4	10,224.9	36.3	3.5	10,319.1	10,429.1	10,272.0	10,217.6	63.0	233.7
17. NOF (%)	75.49	86.04	80.75	69.17	75.44	5.83	1.66	75.43	67.00	72.93	72.52	9.13	74.73
18. NPC (MW)	379	379	379	379	379	379	379	379	379	379	379	379	379

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2004

CRYSTAL RIVER 2	Jan-04	Feb-04	Ma -04	Apr-04	May-04	Ju -04	Jul-04	Aug-04	Sep-04	Oct-04	Nov-04	Dec-04	Jan - Dec Period
1 EAF	94.17	5.14	92.68	14.31	85.24	91.14	82.71	92.14	91.62	96.67	16.13	95.31	85.12
2 PH	44	696	44	719	44	21	44	44	21	44	721	44	8,784
3. SH	44.0	11.2	715.3	693.5	661.2	21.0	712.2	44.0	21.0	145.0	110.0	44.0	7,976.4
4 RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5. UH	0.0	639.8	28.7	25.5	81.8	0.0	31.8	0.0	0.0	0.0	0.0	0.0	807.6
6 POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7 FOH	0.0	0.0	2.6	25.5	81.8	0.0	31.8	0.0	0.0	0.0	0.0	0.0	141.7
8 MOH	0.0	639.8	11	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1659
9 PFOH	40.5	49.9	19.7	4.4	20.3	0.0	147.6	01.6	110.7	15.4	99.7	10.8	971.6
10. LR PF (MW)	181.4	199.0	18.6	78.4	71.0	0.0	31.3	40.8	110.2	110.0	57.1	143.1	75.5
11 PMOH	14.0	0.0	73.0	58.5	28.8	61.5	610.0	116.4	112.9	27.1	38.0	96.5	1607.7
12. LR PM (MW)	254.4	0.0	123.0	121.3	278.3	15.5	64.1	0.0	115.0	201.0	01.5	148.9	115.4
13 NSC (MW)	486	486	486	486	486	486	486	486	486	486	486	486	486
14. OPER MBTU	2,651,908	150,466	2,698,049	2,684,569	2,387,991	2,493,687	2,448,232	2,653,108	2,370,245	2,625,651	2,489,142	2,663,510	28,316,556
15. NET GEN (MWH)	266,641	13,730	280,206	274,571	241,666	253,802	244,649	264,481	237,440	266,567	255,942	273,011	2,872,706
16. ANOHR (BTU/KWH)	9,945.6	10,958.9	9,628.8	9,777.3	9,881.4	9,825.3	10,007.1	10,031.4	9,982.5	9,849.9	9,725.4	9,756.1	9,857.1
17 NOF (%)	73.74	50.27	80.61	81.47	5.09	2.53	70.68	3.15	67.86	73.62	73.14	5.50	74.11
18. NPC (MW)	486	486	486	486	486	486	486	486	486	486	486	486	486

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2004

	Jan-04	Feb-04	Mar-04	Apr-04	May-04	Jun-04	Jul-04	Aug-04	Sep-04	Oct-04	Nov-04	Dec-04	Jan-Dec Period
CRYSTAL RIVER 3													
1. EAF	100.00	110.00	87.74	110.00	110.00	99.98	100.00	99.93	81.47	81.28	100.00	99.57	95.85
2. PH	4	696	744	719	4	720	744	744	2	2	2	4	8,759
3. SH	4	696.0	672.3	719.0	4	720.0	4	4	592.7	592.7	700.0	4	8,432.6
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5. UH	0.0	0.0	71.7	0.0	0.0	0.0	0.0	0.0	27.4	27.4	0.0	0.0	27.4
6. POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7. FOH	0.0	0.0	35.1	0.0	0.0	0.0	0.0	0.0	127.4	127.4	0.0	0.0	289.8
8. MOH	0.0	0.0	35.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	36.5
9. PFOH	0.0	0.0	21.3	0.0	0.0	0.0	0.0	2.0	22.9	22.9	0.0	14.8	83.8
10. LR PF (MW)	0.0	0.0	353.0	0.0	0.0	0.0	0.0	96.8	150.0	151.0	0.0	40.0	233.5
11. PMOH	0.0	0.0	22.0	0.0	0.0	44.7	0.0	6.2	0.0	0.0	0.0	24.6	97.5
12. LR PM (MW)	0.0	0.0	119.0	0.0	0.0	2.0	0.0	37.0	0.0	0.0	0.0	1.0	99.9
13. NSC (MW)	1	1	1	1	6	6	769	769	1	6	169	1	1
14. OPER MBTU	5,984,903	5,589,017	5,284,304	5,783,843	5,985,047	5,791,003	5,985,006	5,975,730	4,708,864	5,906,294	5,791,161	5,949,536	68,744,708
15. NET GEN (MWH)	589,270	551,445	517,097	569,151	583,206	555,585	573,928	575,123	456,680	456,680	569,373	585,051	6,582,589
16. ANOHR (BTU/KWH)	10,156.5	10,153.3	10,219.2	10,162.2	10,262.3	10,423.3	10,428.1	10,390.4	10,311.1	12,933.1	10,171.1	10,159.3	10,443.4
17. NOF (%)	112.99	0.03	0.01	112.94	101.93	100.34	100.31	100.52	100.20	100.20	112.83	112.26	101.51
18. NPC (MW)	76	1	1	76	1	1	769	769	1	1	169	769	1

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2004

	CRYSTAL RIVER 4	Jan-04	Feb-04	Mar-04	Apr-04	May-04	Jun-04	Jul-04	Aug-04	Sep-04	Oct-04	Nov-04	Dec-04	Jan - Dec Period
1. EAF		96.37	76.54	94.03	98.46	96.66	98.21	95.66	95.13	91.13	83.78	72.59	91.50	90.92
2. PH		744	696	744	719	744	720	744	744	720	745	720	744	8,784
3. SH		721.3	580.5	744.0	716.2	744.0	714.0	737.5	727.1	699.7	687.7	584.5	684.1	8,340.5
4. RSH		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5. UH		22.7	115.5	0.0	2.8	0.0	6.0	6.6	16.9	20.3	57.3	135.5	59.9	443.5
6. POH		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7. FOH		22.7	115.5	0.0	2.8	0.0	6.0	6.6	16.9	20.3	0.0	0.0	0.0	190.8
8. MOH		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	57.3	135.5	59.9	252.7
9. PFOH		5.2	7.5	321.3	116.1	17.9	16.2	179.5	31.0	452.6	206.8	134.8	0.0	1,488.6
10. LR PF (MW)		351.3	299.5	99.5	51.6	358.0	272.8	103.3	98.4	67.0	151.2	90.6	0.0	99.6
11. PMOH		12.8	285.8	0.0	0.0	27.7	12.0	0.0	54.8	10.3	132.3	259.1	17.7	812.4
12. LR PM (MW)		101.1	112.5	0.0	0.0	415.0	44.0	0.0	198.0	102.0	109.3	124.8	136.4	131.2
13. NSC (MW)		720	720	720	720	720	720	720	720	720	720	720	720	720
14. OPER MBTU		4,179,046	3,100,776	4,349,207	4,324,800	4,306,115	4,379,964	4,534,700	4,092,251	3,596,466	3,022,010	2,969,831	4,322,755	47,177,918
15. NET GEN (MWH)		450,351	322,485	459,633	455,925	448,574	463,248	478,890	428,201	361,032	305,648	310,723	458,926	4,943,636
16. ANOHR (BTU/KWH)		9,279.5	9,615.3	9,462.3	9,485.8	9,599.6	9,454.9	9,469.2	9,556.8	9,961.6	9,887.2	9,557.8	9,419.3	9,543.2
17. NOF (%)		86.71	77.16	85.80	88.41	83.74	90.12	90.19	81.80	71.67	61.73	73.84	93.17	82.32
18. NPC (MW)		720	720	720	720	720	720	720	720	720	720	720	720	720

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR : 00:

	Jan-04	Feb-04	Mar-04	Apr-04	May-04	Jun-04	Jul-04	Aug-04	Sep-04	Oct-04	Nov-04	Dec-04	Jan - Dec Period
CRYSTAL RIVER 5													
1 EAF	110.0	16.33	10.0	81.13	88.83	99.83	97.97	99.56	90.2	93.14	96.5	89.12	14.41
2 PH	4	69	4	719	4	2	144	4	72	4	72	4	8,784
3 SH	4	69	4	59.8	66.2	2	73.3	4	67.2	145.0	2	72.1	8,491.6
4 RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5 UH	0.0	0.0	0.0	1.52	788	0.0	13.7	0.0	52.9	0.0	0.0	22.0	292.4
6 POH	0.0	0.0	0.0	1.20	16.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	188.2
7 FOH	0.0	0.0	0.0	3.2	2.6	0.0	13.7	0.0	52.9	0.0	0.0	12.0	34.2
8 MOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
9. PFOH	0.0	0	0.0	0.0	8.0	5.9	9.1	10.9	4.8	87.4	60.6	40.6	348.3
10 LR PF (MW)	0.0	0.4	0.0	0.0	99.0	113.8	11.8	215.2	115.5	4.6	51.9	28.5	162.2
PMOH	0.0	114.3	0.0	15.6	11.3	6.0	0.0	0.0	8.0	51.3	129.3	86.4	512.2
12. LR PM (MW)	0.0	113.6	0.0	10	20.4	41.0	0.0	0.0	40.8	297.7	3.9	35.7	167.6
13 NSC (MW)	717	717	717	717	717	717	717	717	717	717	717	717	717
14. OPER MBTU	4,632,050	4,181,723	4,591,836	3,620,472	3,803,862	4,489,029	4,615,667	4,340,796	3,575,260	3,553,528	4,190,077	4,210,730	49,805,030
15 NET GEN (MWH)	492,117	43,398	489.2	8,853	156.07	47,216	49,54	45,317	58,241	6,91	1,221	439,4	5,224,548
16. ANOHR (BTU/KWH)	9,412.5	9,560.5	9,387.9	9,407.4	9,603.1	9,426.5	9,409.3	9,512.7	9,980.0	9,791.2	9,496.5	9,581.1	9,532.9
17 NOF (%)	92.2	87.65	91.69	90.3	83.05	12.25	93.68	85.5	1.1	67.94	85.47	84.89	85.81
18 NPC (MW)	717	717	717	717	717	717	717	717	717	717	717	717	717

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2004

HINES 1	Jan -04	Feb-04	Mar-04	Ap -04	May-04	Jun-04	Jul-04	Aug-04	Sep-04	Oct-04	Nov-04	Dec-04	Jan - Dec Period
1. EAF	100.00	100.00	83.60	14.09	82.61	96.11	110.00	110.00	99.73	55.13	25.09	19.62	81.42
2. PH	744	696	4	719	4	2	744	744	72	4	72	744	8,784
3. SH	4	696.0	622.0	480.3	144.0	72	4	604.0	11.4	41.3	11.8	81.7	7,043.4
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	40.0	68.6	0.0	42.9	55.3	506.9
5. UH	0.0	0.0	2	238.7	0.0	0.0	0.0	0.0	0.0	33.8	539.3	0.0	1,233.8
6. POH	0.0	0.0	2	231.7	0.0	0.0	0.0	0.0	0.0	333.8	539.3	0.0	1,233.8
7. FOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
8. MOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
9. PFOH	0.0	0.0	0.0	0.0	1.7	48.9	0.0	0.0	2.8	1.5	0.0	12.4	67.3
10. LR PF (MW)	0.0	0.0	0.0	0.0	2939	276.0	0.0	0.0	15.7	8.6	0.0	110.4	246.4
11. PMOH	0.0	0.0	0.0	480.3	162.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	742.4
12. LR PM (MW)	0.0	0.0	0.0	3	23	0.0	0.0	0.0	0.0	0.0	0.0	0.0	236.0
13. NSC (MW)	482	482	482	482	482	482	482	482	482	482	482	482	482
14. OPER MBTU	1,653,792	1,796,347	1,783,285	726,204	1,643,294	1,887,801	1,666,488	1,501,431	1,595,144	1,162,657	49,999	1,441,031	16,907,473
15. NET GEN (MWH)	217,724	246,290	244,992	92,29	216,532	256,631	232,251	179,217	209,292	164,161	4,620	194,355	2,258,194
16. ANOHR (BTU/KWH)	7,595.8	7,293.6	7,279.0	7,882.5	7,589.1	7,356.1	7,175.4	8,377.7	7,621.6	7,082.4	10,822.4	7,414.4	7,487.2
17. NOF (%)	60.71	73.42	81.71	39.80	60.38	13.95	14.76	61.56	16.66	82.82	25.35	68.50	16.52
18. NPC (MW)	482	482	482	482	482	482	482	482	482	482	482	482	482

PROGRESS ENERGY FLORIDA
 ACTUAL UNIT PERFORMANCE DATA -- YEAR 2004

TIGER BAY	Jan-04	Feb-04	Ma -04	Apr-04	May-04	Ju -04	Jul-04	Aug-04	Sep-04	Oct-04	N v-04	D c-04	Jan - Dec Period
1 EAF	110.0	91.46	38.84	14.18	110.0	98.59	110.00	61.9	19.09	88.88	110.0	110.00	89.31
2 PH	4	69	4	719	74	20	4	4	2	74	2	4	8.784
3 SH	59.1	63.6	10.3	492.7	685.2	109.9	4.0	460.8	618.3	162.2	8.4	7.0	6.077.4
4. RSH	148.9	0.0	218.8	184.5	58.8	0.0	0.0	0.0	95.1	0.0	43.7	627.0	1,767.7
5. UH	0.0	59.4	45.0	41.8	0.0	10.2	0.0	283.2	6.6	82.8	0.0	0.0	138.9
6 POH	0.0	48.0	45.0	0.0	0.0	0.0	0.0	0.0	0.0	82.8	0.0	0.0	58.8
7 FOH	0.0	11.4	0.0	0.0	0.0	10.2	0.0	283.2	6.6	0.0	0.0	0.0	31.3
8 MOH	0.0	0.0	0.0	41.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	41.8
9. PFOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10. LR PF (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11 PMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12 LR PM (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
13 NSC (MW)	107	0	0	0	207	207	0	0	0	0	207	107	207
14. OPER MBTU	797,679	896,780	1,332	72,107	4,715	998,031	992,858	78,7	976,47	1,079,801	45,5	22,717	9,025,648
15. NET GEN (MWH)	98.8	117.429	615	10,929	12,847	17,47	142,44	86,82	118,0	13,83	51,299	22,20	1.1 3,679
16 ANOHR (BTU/KWH)	8,071.2	7,636.8	13,200.6	7,918.3	7,690.3	7,829.2	6,970.3	8,969.2	8,213.0	8,719.5	8,918.8	10,385.0	8,114.4
17 NOF (%)	80.23	11	9.87	89.16	86.61	86.7	12.49	91.02	12.2	90.3	16.85	91.3	88.53
18 NPC (MW)	207	207	07	107	207	207	07	107	07	07	07	207	107

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Date	Outage Type	Hours	MW Affected	Description
1/5/2004	PFO	20.90	158.0	CONDENSER TUBE LEAKS
1/13/2004	FFO	64.35	498.0	ECONOMIZER LEAKS
1/21/2004	PFO	2.23	227.9	FEEDWATER PUMP
2/2/2004	PFO	8.98	159.0	CONDENSER TUBE LEAKS
2/3/2004	PMO	6.63	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
2/4/2004	PMO	16.23	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
2/5/2004	PMO	11.07	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
2/14/2004	PFO	4.18	159.1	CONDENSER TUBE LEAKS
2/15/2004	PMO	6.88	159.0	CONDENSER TUBE FOULING TUBE SIDE
2/16/2004	PMO	4.58	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
2/17/2004	PMO	7.72	158.9	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
2/19/2004	PMO	4.32	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
3/2/2004	PMO	6.57	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
3/2/2004	PMO	4.58	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
4/6/2004	PFO	49.58	4.0	OTHER HIGH PRESSURE HEATER PROBLEMS
4/15/2004	PMO	26.20	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
4/23/2004	PMO	4.48	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
5/3/2004	PFO	65.83	4.0	OTHER HIGH PRESSURE HEATER PROBLEMS
5/4/2004	PMO	12.77	155.0	CONDENSER TUBE FOULING TUBE SIDE
5/5/2004	PMO	8.28	155.0	CONDENSER TUBE FOULING TUBE SIDE
5/6/2004	PMO	8.12	159.0	CONDENSER TUBE FOULING TUBE SIDE
5/11/2004	PMO	14.02	159.0	CONDENSER TUBE FOULING TUBE SIDE
5/13/2004	PMO	4.17	158.9	CONDENSER TUBE FOULING TUBE SIDE
5/13/2004	PMO	4.63	159.0	CONDENSER TUBE FOULING TUBE SIDE
5/16/2004	PMO	9.03	159.0	CONDENSER TUBE FOULING TUBE SIDE
5/17/2004	PMO	6.38	159.0	CONDENSER TUBE FOULING TUBE SIDE

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Anclote 1				
Date	Outage Type	Hours	MW Affected	Description
5/20/2004	PFO	17.32	304.0	OTHER OIL AND GAS FUEL SUPPLY PROBLEMS
5/22/2004	PFO	2.67	13.1	IGNITERS
5/23/2004	PMO	5.58	159.0	CONDENSER TUBE FOULING TUBE SIDE
5/24/2004	PMO	2.17	159.0	CONDENSER TUBE FOULING TUBE SIDE
5/24/2004	PMO	5.85	159.0	CONDENSER TUBE FOULING TUBE SIDE
5/27/2004	PMO	27.08	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
5/31/2004	PMO	7.68	159.0	CONDENSER TUBE FOULING TUBE SIDE
6/3/2004	PMO	6.33	159.0	CONDENSER TUBE FOULING TUBE SIDE
6/4/2004	PMO	2.02	159.0	CONDENSER TUBE FOULING TUBE SIDE
6/6/2004	PMO	6.58	159.0	CONDENSER TUBE FOULING TUBE SIDE
6/7/2004	PMO	2.35	158.9	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
6/8/2004	FFO	5.88	498.0	GENERATOR VOLTAGE CONTROL
6/8/2004	PMO	6.60	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
6/10/2004	PMO	6.30	159.0	CONDENSER TUBE FOULING TUBE SIDE
6/13/2004	PMO	8.77	159.0	CONDENSER TUBE FOULING TUBE SIDE
6/14/2004	PMO	6.73	159.0	CONDENSER TUBE FOULING TUBE SIDE
6/16/2004	PMO	3.12	159.0	CONDENSER TUBE FOULING TUBE SIDE
6/18/2004	PMO	5.53	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
6/21/2004	PMO	5.75	159.0	CONDENSER TUBE FOULING TUBE SIDE
6/22/2004	PMO	3.00	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
6/22/2004	PMO	8.23	159.0	CONDENSER TUBE FOULING TUBE SIDE
6/22/2004	PMO	11.07	96.0	AIR HEATER FOULING (REGENERATIVE)
6/23/2004	PMO	6.38	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
6/23/2004	PMO	9.63	96.0	AIR HEATER FOULING (REGENERATIVE)
6/27/2004	PMO	2.78	420.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/28/2004	PMO	4.75	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Anclote 1				
Date	Outage Type	Hours	MW Affected	Description
6/29/2004	PMO	6.00	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
6/29/2004	PMO	5.25	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
7/2/2004	PMO	5.23	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
7/4/2004	PFO	1.75	159.1	FEEDWATER PUMP DRIVE - CONTROLS
7/10/2004	PFO	4.50	421.0	OTHER COOLING TOWER PROBLEMS
7/11/2004	PFO	3.92	415.0	OTHER COOLING TOWER PROBLEMS
7/21/2004	PMO	2.57	159.1	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
7/21/2004	PMO	7.47	159.0	CONDENSER TUBE FOULING TUBE SIDE
7/23/2004	PMO	3.38	159.0	CONDENSER TUBE FOULING TUBE SIDE
7/29/2004	PMO	3.77	159.0	CONDENSER TUBE FOULING TUBE SIDE
8/19/2004	PFO	3.00	264.9	FEEDWATER PUMP DRIVE - CONTROLS
8/19/2004	PFO	0.25	13.9	TRAVELING SCREENS
8/19/2004	PMO	6.97	159.0	CONDENSER TUBE FOULING TUBE SIDE
8/20/2004	PFO	1.00	264.9	FEEDWATER PUMP DRIVE - CONTROLS
8/20/2004	PFO	5.73	23.0	CONDENSER TUBE FOULING TUBE SIDE
8/21/2004	PFO	0.25	17.9	CONDENSER TUBE FOULING TUBE SIDE
8/22/2004	PFO	4.18	52.0	CONDENSER TUBE FOULING TUBE SIDE
8/23/2004	FFO	0.63	498.0	OTHER BOILER RECIRCULATION PROBLEMS
8/23/2004	PFO	5.38	33.0	CONDENSER TUBE FOULING TUBE SIDE
8/23/2004	PMO	5.62	159.0	CONDENSER TUBE FOULING TUBE SIDE
8/24/2004	PFO	0.25	328.7	OTHER BOILER RECIRCULATION PROBLEMS
8/24/2004	PFO	5.72	52.0	CONDENSER TUBE FOULING TUBE SIDE
8/25/2004	PFO	4.80	38.0	CONDENSER TUBE FOULING TUBE SIDE
8/25/2004	PMO	7.85	159.0	CONDENSER TUBE FOULING TUBE SIDE
8/31/2004	PMO	8.37	255.0	AIR HEATER FOULING (REGENERATIVE)
9/1/2004	PMO	8.83	255.0	AIR HEATER FOULING (REGENERATIVE)

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Date	Outage Type	Hours	MW Affected	Description
9/15/2004	PMO	2.90	159.0	CONDENSER TUBE FOULING TUBE SIDE
9/16/2004	PMO	5.52	159.0	CONDENSER TUBE FOULING TUBE SIDE
9/24/2004	PMO	6.82	159.0	CONDENSER TUBE FOULING TUBE SIDE
9/26/2004	FFO	5.33	498.0	OTHER AIR SUPPLY PROBLEMS
9/26/2004	PFO	12.93	81.0	CONDENSATE BOOSTER PUMP MOTOR - VARIABLE SPEED
9/28/2004	FFO	9.58	498.0	HURRICANE RELATED - GRASS ATTACK
9/29/2004	FFO	7.72	498.0	HURRICANE RELATED - GRASS ATTACK
9/30/2004	PFO	2.17	353.0	HURRICANE RELATED - GRASS ATTACK
10/1/2004	PFO	2.92	353.1	HURRICANE RELATED - GRASS ATTACK
10/2/2004	PFO	2.67	401.1	HURRICANE RELATED - GRASS ATTACK
10/3/2004	PFO	2.00	353.1	HURRICANE RELATED - GRASS ATTACK
10/4/2004	PFO	0.82	304.2	HURRICANE RELATED - GRASS ATTACK
10/10/2004	PFO	0.65	120.3	HURRICANE RELATED - GRASS ATTACK
10/14/2004	PMO	2.12	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
10/14/2004	PMO	1.93	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
10/14/2004	PMO	0.78	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
10/14/2004	PMO	6.37	159.0	CONDENSER TUBE FOULING TUBE SIDE
10/15/2004	FFO	67.00	498.0	FURNACE WALL LEAKS
10/18/2004	PMO	6.10	159.0	CONDENSER TUBE FOULING TUBE SIDE
10/20/2004	PMO	4.65	226.0	FEEDWATER PUMP DRIVE - STEAM TURBINE
10/20/2004	PMO	5.25	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
10/21/2004	PFO	0.75	110.2	TRAVELING SCREEN FOULING
10/27/2004	PMO	2.83	226.1	FEEDWATER PUMP DRIVE - STEAM TURBINE
10/28/2004	PMO	5.98	159.0	CONDENSER TUBE FOULING TUBE SIDE
11/5/2004	PMO	11.67	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
11/26/2004	PFO	508.38	4.0	OTHER FEEDWATER VALVES

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Date	Outage Type	Hours	MW Affected	Description
1/13/2004	PMO	3.20	155.9	CONDENSER TUBE FOULING TUBE SIDE
1/14/2004	PMO	3.38	156.0	CONDENSER TUBE FOULING TUBE SIDE
1/18/2004	PMO	6.68	156.0	CONDENSER TUBE FOULING TUBE SIDE
1/19/2004	PMO	7.02	156.0	CONDENSER TUBE FOULING TUBE SIDE
1/20/2004	PMO	4.95	156.0	CONDENSER TUBE FOULING TUBE SIDE
1/21/2004	PMO	5.70	156.0	CONDENSER TUBE FOULING TUBE SIDE
2/15/2004	PMO	7.33	156.0	CONDENSER TUBE FOULING TUBE SIDE
2/16/2004	PMO	7.00	156.0	CONDENSER TUBE FOULING TUBE SIDE
2/18/2004	PFO	1.67	15.1	BOTTOM ASH HOPPERS (INCLUDING GATES)
2/22/2004	PMO	8.47	156.0	CONDENSER TUBE FOULING TUBE SIDE
2/23/2004	PMO	7.67	156.0	CONDENSER TUBE FOULING TUBE SIDE
2/24/2004	PMO	6.70	156.0	CONDENSER TUBE FOULING TUBE SIDE
2/25/2004	PMO	5.75	156.0	CONDENSER TUBE FOULING TUBE SIDE
2/26/2004	PMO	6.25	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/16/2004	PMO	2.62	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/16/2004	PMO	1.97	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/16/2004	PMO	1.98	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/16/2004	PMO	9.88	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/17/2004	PFO	3.98	156.0	FEEDWATER PUMP DRIVE - CONTROLS
3/17/2004	PMO	6.55	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/18/2004	PMO	6.17	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/21/2004	PMO	8.20	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/22/2004	PMO	8.50	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/23/2004	PMO	6.33	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/24/2004	PMO	6.88	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/25/2004	PMO	7.62	156.0	CONDENSER TUBE FOULING TUBE SIDE

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Date	Outage Type	Hours	MW Affected	Description
4/6/2004	PFO	0.25	479.2	FUEL OIL PUMPS - GENERAL
4/6/2004	PFO	9.13	301.0	FUEL OIL PUMPS - GENERAL
4/11/2004	PMO	8.60	156.0	CONDENSER TUBE FOULING TUBE SIDE
4/12/2004	PMO	6.87	156.0	CONDENSER TUBE FOULING TUBE SIDE
4/13/2004	PMO	8.67	156.0	CONDENSER TUBE FOULING TUBE SIDE
4/14/2004	PMO	4.85	156.0	CONDENSER TUBE FOULING TUBE SIDE
4/15/2004	PMO	1.97	156.0	CONDENSER TUBE FOULING TUBE SIDE
4/16/2004	PMO	3.75	156.0	CONDENSER TUBE FOULING TUBE SIDE
4/21/2004	PO	216.05	495.0	MINOR BOILER OVERHAUL (LESS THAN 720 HOURS)
5/1/2004	PO	85.60	495.0	MINOR BOILER OVERHAUL (LESS THAN 720 HOURS)
5/9/2004	PMO	8.05	156.0	CONDENSER TUBE FOULING TUBE SIDE
5/10/2004	PFO	17.75	190.0	TURBINE CONTROL VALVES
5/11/2004	PMO	12.92	156.0	CONDENSER TUBE FOULING TUBE SIDE
5/12/2004	PMO	6.20	156.0	CONDENSER TUBE FOULING TUBE SIDE
5/12/2004	PMO	9.35	156.0	CONDENSER TUBE FOULING TUBE SIDE
5/17/2004	PMO	2.62	156.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
5/19/2004	PMO	6.08	156.0	CONDENSER TUBE FOULING TUBE SIDE
5/20/2004	PMO	7.67	156.0	CONDENSER TUBE FOULING TUBE SIDE
5/23/2004	PFO	19.75	350.0	BOILER CASING
5/26/2004	PMO	6.33	156.0	CONDENSER TUBE FOULING TUBE SIDE
5/29/2004	PFO	3.35	40.0	HIGH CIRCULATING WATER TEMPERATURE
5/30/2004	PMO	3.32	155.9	CONDENSER TUBE FOULING TUBE SIDE
5/30/2004	PMO	3.22	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/1/2004	PMO	4.58	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/1/2004	PMO	5.83	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/2/2004	PMO	1.30	156.1	CONDENSER TUBE FOULING TUBE SIDE

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Date	Outage Type	Hours	MW Affected	Description
6/2/2004	PMO	6.20	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/7/2004	PMO	8.18	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/9/2004	PMO	8.30	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/11/2004	PMO	3.87	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/15/2004	PMO	7.57	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/16/2004	PMO	8.20	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/17/2004	PMO	7.40	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/20/2004	PFO	1.50	25.1	BOTTOM ASH HOPPERS (INCLUDING GATES)
6/20/2004	PMO	7.23	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/22/2004	PMO	5.93	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/23/2004	PMO	5.70	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/24/2004	PMO	5.10	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/24/2004	PMO	6.07	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/27/2004	PFO	2.78	402.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/27/2004	PMO	6.43	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/28/2004	PMO	2.48	156.1	CONDENSER TUBE FOULING TUBE SIDE
6/29/2004	PMO	1.33	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/29/2004	PMO	2.22	156.1	CONDENSER TUBE FOULING TUBE SIDE
6/29/2004	PMO	2.33	155.9	CONDENSER TUBE FOULING TUBE SIDE
6/29/2004	PMO	6.20	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/30/2004	PMO	5.08	156.0	CONDENSER TUBE FOULING TUBE SIDE
7/1/2004	PMO	1.63	156.1	CONDENSER TUBE FOULING TUBE SIDE
7/1/2004	PMO	2.08	155.9	CONDENSER TUBE FOULING TUBE SIDE
7/2/2004	PMO	2.75	156.1	CONDENSER TUBE FOULING TUBE SIDE
7/6/2004	PMO	5.93	156.0	CONDENSER TUBE FOULING TUBE SIDE
7/6/2004	PMO	1.48	155.9	CONDENSER TUBE FOULING TUBE SIDE

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Date	Outage Type	Hours	MW Affected	Description
7/7/2004	PMO	6.38	156.0	CONDENSER TUBE FOULING TUBE SIDE
7/7/2004	PMO	11.00	156.0	CONDENSER TUBE FOULING TUBE SIDE
7/8/2004	PMO	5.72	156.0	CONDENSER TUBE FOULING TUBE SIDE
7/10/2004	PFO	5.00	418.0	OTHER COOLING TOWER PROBLEMS
7/11/2004	PFO	3.92	412.0	OTHER COOLING TOWER PROBLEMS
7/11/2004	PMO	4.88	156.0	CONDENSER TUBE FOULING TUBE SIDE
7/13/2004	PMO	7.07	156.0	CONDENSER TUBE FOULING TUBE SIDE
7/15/2004	PMO	4.80	156.0	CONDENSER TUBE FOULING TUBE SIDE
7/20/2004	PFO	0.70	120.2	TRAVELING SCREENS
7/20/2004	PMO	5.55	156.0	CONDENSER TUBE FOULING TUBE SIDE
7/20/2004	PMO	7.92	156.0	CONDENSER TUBE FOULING TUBE SIDE
7/22/2004	PMO	4.78	156.0	CONDENSER TUBE FOULING TUBE SIDE
7/25/2004	PMO	6.07	156.0	CONDENSER TUBE FOULING TUBE SIDE
7/27/2004	PMO	6.15	156.0	CONDENSER TUBE FOULING TUBE SIDE
7/28/2004	PMO	5.40	156.0	CONDENSER TUBE FOULING TUBE SIDE
8/1/2004	PMO	5.50	156.0	CONDENSER TUBE FOULING TUBE SIDE
8/2/2004	PMO	5.55	156.0	CONDENSER TUBE FOULING TUBE SIDE
8/3/2004	PMO	7.33	156.0	CONDENSER TUBE FOULING TUBE SIDE
8/4/2004	PMO	6.23	156.0	CONDENSER TUBE FOULING TUBE SIDE
8/8/2004	PMO	7.00	156.0	CONDENSER TUBE FOULING TUBE SIDE
8/9/2004	PMO	7.07	156.0	CONDENSER TUBE FOULING TUBE SIDE
8/10/2004	PMO	7.03	156.0	CONDENSER TUBE FOULING TUBE SIDE
8/11/2004	PMO	7.85	156.0	CONDENSER TUBE FOULING TUBE SIDE
8/15/2004	PMO	7.75	156.0	CONDENSER TUBE FOULING TUBE SIDE
8/16/2004	PMO	7.53	156.0	CONDENSER TUBE FOULING TUBE SIDE
8/17/2004	PMO	8.78	156.0	CONDENSER TUBE FOULING TUBE SIDE

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Anclote 2				
Date	Outage Type	Hours	MW Affected	Description
8/18/2004	PMO	5.92	156.0	CONDENSER TUBE FOULING TUBE SIDE
8/19/2004	PMO	5.80	156.0	CONDENSER TUBE FOULING TUBE SIDE
8/22/2004	PMO	6.95	156.0	CONDENSER TUBE FOULING TUBE SIDE
8/23/2004	PMO	8.18	156.0	CONDENSER TUBE FOULING TUBE SIDE
8/24/2004	PMO	6.00	156.0	CONDENSER TUBE FOULING TUBE SIDE
8/25/2004	PMO	6.07	156.0	CONDENSER TUBE FOULING TUBE SIDE
8/30/2004	PMO	7.58	156.0	CONDENSER TUBE FOULING TUBE SIDE
8/31/2004	PMO	6.23	156.0	CONDENSER TUBE FOULING TUBE SIDE
9/1/2004	PMO	6.48	156.0	CONDENSER TUBE FOULING TUBE SIDE
9/2/2004	PMO	7.07	156.0	CONDENSER TUBE FOULING TUBE SIDE
9/7/2004	PFO	11.25	252.0	OTHER FORCED DRAFT FAN PROBLEMS
9/7/2004	PFO	16.58	252.0	OTHER FORCED DRAFT FAN PROBLEMS
9/8/2004	PFO	14.90	252.0	OTHER FORCED DRAFT FAN PROBLEMS
9/8/2004	PMO	6.53	156.0	CONDENSER TUBE FOULING TUBE SIDE
9/9/2004	PFO	8.83	96.0	OTHER FORCED DRAFT FAN PROBLEMS
9/9/2004	PMO	6.15	156.0	CONDENSER TUBE FOULING TUBE SIDE
9/12/2004	PMO	7.63	156.0	CONDENSER TUBE FOULING TUBE SIDE
9/14/2004	PFO	7.35	49.0	OTHER FORCED DRAFT FAN PROBLEMS
9/14/2004	PMO	5.75	156.0	CONDENSER TUBE FOULING TUBE SIDE
9/15/2004	PFO	1.20	49.1	OTHER FORCED DRAFT FAN PROBLEMS
9/15/2004	PFO	3.25	49.0	OTHER FORCED DRAFT FAN PROBLEMS
9/15/2004	PMO	1.95	156.1	CONDENSER TUBE FOULING TUBE SIDE
9/15/2004	PMO	6.73	156.0	CONDENSER TUBE FOULING TUBE SIDE
9/16/2004	PFO	1.88	48.9	OTHER FORCED DRAFT FAN PROBLEMS
9/16/2004	PFO	3.90	49.0	OTHER FORCED DRAFT FAN PROBLEMS
9/17/2004	PFO	0.97	49.1	OTHER FORCED DRAFT FAN PROBLEMS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Date	Outage Type	Hours	MW Affected	Description
9/17/2004	PFO	7.88	49.0	OTHER FORCED DRAFT FAN PROBLEMS
9/19/2004	PMO	6.50	156.0	CONDENSER TUBE FOULING TUBE SIDE
9/20/2004	PFO	6.45	49.0	OTHER FORCED DRAFT FAN PROBLEMS
9/21/2004	PMO	6.30	156.0	CONDENSER TUBE FOULING TUBE SIDE
9/22/2004	PFO	10.00	49.0	OTHER FORCED DRAFT FAN PROBLEMS
9/22/2004	PMO	7.45	156.0	CONDENSER TUBE FOULING TUBE SIDE
9/24/2004	PFO	4.70	49.0	OTHER FORCED DRAFT FAN PROBLEMS
9/25/2004	PFO	14.83	49.0	OTHER FORCED DRAFT FAN PROBLEMS
9/27/2004	PMO	5.85	156.0	CONDENSER TUBE FOULING TUBE SIDE
9/28/2004	FFO	16.87	495.0	HURRICANE RELATED - GRASS ATTACK
9/29/2004	PFO	1.67	350.1	HURRICANE RELATED - GRASS ATTACK
9/30/2004	PFO	2.17	349.9	HURRICANE RELATED - GRASS ATTACK
10/1/2004	PFO	2.92	345.0	HURRICANE RELATED - GRASS ATTACK
10/2/2004	PFO	2.67	350.0	HURRICANE RELATED - GRASS ATTACK
10/2/2004	PFO	3.80	34.0	HURRICANE RELATED - LOST CIRCULATORS
10/3/2004	PFO	2.00	350.0	HURRICANE RELATED - GRASS ATTACK
10/3/2004	PMO	6.53	156.0	CONDENSER TUBE FOULING TUBE SIDE
10/4/2004	PMO	7.70	156.0	CONDENSER TUBE FOULING TUBE SIDE
10/5/2004	PMO	7.45	156.0	CONDENSER TUBE FOULING TUBE SIDE
10/6/2004	PMO	3.40	156.1	CONDENSER TUBE FOULING TUBE SIDE
10/7/2004	PMO	7.90	156.0	CONDENSER TUBE FOULING TUBE SIDE
10/10/2004	PMO	6.17	156.0	CONDENSER TUBE FOULING TUBE SIDE
10/11/2004	PMO	7.02	156.0	CONDENSER TUBE FOULING TUBE SIDE
10/12/2004	PMO	7.23	156.0	CONDENSER TUBE FOULING TUBE SIDE
10/13/2004	PFO	1.55	124.9	FUEL OIL PUMPS - GENERAL
10/13/2004	PMO	6.48	156.0	CONDENSER TUBE FOULING TUBE SIDE

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Date	Outage Type	Hours	MW Affected	Description
10/14/2004	PMO	5.83	156.0	CONDENSER TUBE FOULING TUBE SIDE
10/17/2004	PMO	7.38	156.0	CONDENSER TUBE FOULING TUBE SIDE
10/19/2004	PMO	6.13	156.0	CONDENSER TUBE FOULING TUBE SIDE
10/20/2004	PMO	4.48	156.0	CONDENSER TUBE FOULING TUBE SIDE
10/20/2004	PMO	7.57	156.0	CONDENSER TUBE FOULING TUBE SIDE
10/21/2004	PFO	0.83	117.1	TRAVELING SCREEN FOULING
10/21/2004	PMO	7.40	156.0	CONDENSER TUBE FOULING TUBE SIDE
10/24/2004	PMO	6.58	156.0	CONDENSER TUBE FOULING TUBE SIDE
10/25/2004	PMO	8.07	156.0	CONDENSER TUBE FOULING TUBE SIDE
10/26/2004	PMO	4.63	156.0	CONDENSER TUBE FOULING TUBE SIDE
10/27/2004	PMO	7.97	156.0	CONDENSER TUBE FOULING TUBE SIDE
10/28/2004	PMO	8.03	156.0	CONDENSER TUBE FOULING TUBE SIDE
11/1/2004	PMO	8.03	156.0	CONDENSER TUBE FOULING TUBE SIDE
11/2/2004	PMO	6.17	156.0	CONDENSER TUBE FOULING TUBE SIDE
11/4/2004	PMO	4.10	156.0	CONDENSER TUBE FOULING TUBE SIDE
11/5/2004	PO	344.58	495.0	MINOR BOILER OVERHAUL (LESS THAN 720 HOURS)
11/26/2004	PFO	812.02	10.0	HIGH PRESSURE HEATER TUBE LEAKS
12/10/2004	PMO	0.88	145.8	CONDENSER TUBE FOULING TUBE SIDE
12/13/2004	PFO	5.25	291.0	TRAVELING SCREENS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Date	Outage Type	Hours	MW Affected	Description
1/4/2004	PFO	4.93	66.0	PULVERIZER FEEDERS
1/4/2004	PMO	51.23	47.0	OTHER CIRCULATING WATER SYSTEM PROBLEMS
1/25/2004	PMO	14.00	265.0	COAL CONVEYERS AND FEEDERS
2/1/2004	PMO	5.65	75.0	PULVERIZER MILLS
2/9/2004	PMO	5.17	189.0	CONDENSER TUBE AND WATER BOX CLEANING
2/13/2004	FFO	68.65	379.0	FIRST REHEATER LEAKS
2/23/2004	PMO	6.77	189.0	CONDENSER TUBE AND WATER BOX CLEANING
2/27/2004	PFO	0.80	74.9	PULVERIZER COAL LEAK (PULVERIZERS ONLY)
3/5/2004	PO	1130.67	379.0	MAJOR TURBINE OVERHAUL (720 HOURS OR LONGER)
4/22/2004	FFO	1.35	379.0	FEEDWATER PUMP
4/23/2004	FFO	1.50	379.0	FEEDWATER PUMP
5/5/2004	FFO	23.30	379.0	TURBINE SUPERVISORY SYSTEM
5/12/2004	FFO	51.52	379.0	CONDENSER TUBE LEAKS
5/18/2004	PMO	7.23	189.0	CONDENSER TUBE AND WATER BOX CLEANING
5/19/2004	FFO	1.27	379.0	TURBINE HYDRAULIC SYSTEM PIPES AND VALVES
5/20/2004	PMO	11.47	189.0	CONDENSER TUBE AND WATER BOX CLEANING
5/22/2004	FMO	63.25	379.0	TURBINE MAIN STOP VALVES
6/2/2004	PFO	2.25	94.0	BOTTOM ASH SYSTEMS (WET OR DRY)
6/9/2004	PMO	5.23	189.0	CONDENSER TUBE AND WATER BOX CLEANING
6/12/2004	PMO	7.98	32.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/13/2004	PMO	8.33	32.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/14/2004	PMO	4.73	189.0	CONDENSER TUBE AND WATER BOX CLEANING
6/14/2004	PMO	6.73	84.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/15/2004	PMO	5.97	94.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/16/2004	PMO	54.25	75.0	OTHER PULVERIZER PROBLEMS
6/19/2004	PMO	9.32	70.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Date	Outage Type	Hours	MW Affected	Description
6/20/2004	PMO	6.83	113.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/21/2004	PMO	11.93	46.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/22/2004	PMO	5.58	170.0	CONDENSER TUBE AND WATER BOX CLEANING
6/24/2004	PMO	8.25	94.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/25/2004	PMO	14.52	94.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/26/2004	PMO	13.58	122.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/29/2004	PMO	1.38	46.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/30/2004	PFO	7.08	189.0	CONDENSER TUBE LEAKS
6/30/2004	PFO	1.18	75.0	OTHER PULVERIZER PROBLEMS
7/1/2004	PMO	7.18	75.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/2/2004	PMO	11.25	70.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/4/2004	PMO	9.15	94.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/5/2004	PMO	11.57	60.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/5/2004	PMO	8.67	189.0	FEEDWATER PUMP
7/6/2004	PMO	13.67	98.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/7/2004	PMO	14.40	160.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/7/2004	PMO	8.42	94.0	BOTTOM ASH CLINKER GRINDERS
7/8/2004	PMO	12.00	103.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/9/2004	PMO	18.25	94.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/10/2004	PMO	16.10	94.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/11/2004	PMO	15.08	132.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/11/2004	PMO	7.63	57.0	CONDENSER TUBE AND WATER BOX CLEANING
7/12/2004	PMO	18.00	151.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/13/2004	PFO	1.65	189.0	CONDENSER TUBE LEAKS
7/13/2004	PMO	13.50	122.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/14/2004	PMO	9.68	46.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Crystal River 1				
Date	Outage Type	Hours	MW Affected	Description
7/14/2004	PMO	7.88	189.0	CONDENSER TUBE AND WATER BOX CLEANING
7/15/2004	PMO	8.83	42.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/16/2004	PMO	9.00	75.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/17/2004	PMO	4.70	46.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/19/2004	PFO	7.37	76.0	OTHER PULVERIZER PROBLEMS
7/19/2004	PMO	6.58	114.0	CONDENSER TUBE AND WATER BOX CLEANING
7/19/2004	PMO	49.67	75.0	OTHER PULVERIZER PROBLEMS
7/23/2004	PMO	18.20	28.0	BOTTOM ASH SYSTEMS (WET OR DRY)
7/25/2004	PMO	5.70	75.0	PULVERIZER FEEDERS
7/26/2004	PFO	7.78	189.0	CONDENSER TUBE LEAKS
7/26/2004	PMO	6.45	114.0	CONDENSER TUBE AND WATER BOX CLEANING
7/26/2004	PMO	7.53	75.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/26/2004	PMO	6.00	75.0	PULVERIZER FEEDERS
7/27/2004	PMO	6.58	95.0	FEEDWATER PUMP/DRIVE LUBE OIL SYSTEM
7/27/2004	PMO	10.50	70.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/28/2004	PMO	5.00	75.0	PULVERIZER FEEDERS
7/29/2004	PFO	4.75	13.0	HEATER LEVEL CONTROL
7/29/2004	PMO	9.33	43.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/30/2004	PMO	12.72	46.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/31/2004	PMO	7.00	46.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
8/1/2004	PMO	5.78	70.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
8/2/2004	PMO	3.50	18.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
8/3/2004	PMO	6.20	23.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
8/3/2004	PMO	6.92	189.0	CONDENSER TUBE AND WATER BOX CLEANING
8/9/2004	PMO	8.37	189.0	CONDENSER TUBE AND WATER BOX CLEANING
3/12/2004	PFO	3.17	75.0	PULVERIZER EXHAUSTER FAN (FOR INDIRECT FIRING)

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Crystal River 1				
Date	Outage Type	Hours	MW Affected	Description
8/12/2004	PMO	7.33	189.0	CONDENSER TUBE AND WATER BOX CLEANING
8/16/2004	PMO	8.50	170.0	CONDENSER TUBE AND WATER BOX CLEANING
8/17/2004	PFO	6.60	75.0	OTHER PULVERIZER PROBLEMS
8/19/2004	PMO	5.33	46.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
8/20/2004	PFO	21.28	236.0	INDUCED DRAFT FAN SPEED CHANGER
8/20/2004	PMO	12.52	70.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
8/23/2004	PMO	6.72	189.0	CONDENSER TUBE AND WATER BOX CLEANING
8/24/2004	PMO	34.03	9.0	BOILER RECIRCULATION PUMPS
8/25/2004	PMO	1.92	28.1	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
8/25/2004	PMO	8.37	189.0	CONDENSER TUBE AND WATER BOX CLEANING
8/26/2004	PMO	6.98	46.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
8/27/2004	PFO	3.17	75.0	PULVERIZER FEEDERS
8/28/2004	PFO	6.00	132.0	BUNKER FLOW PROBLEMS
8/29/2004	PFO	4.67	265.0	BUNKER FLOW PROBLEMS
8/29/2004	PFO	3.25	75.0	IGNITERS
8/29/2004	PMO	6.03	94.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
8/30/2004	PMO	7.35	170.0	CONDENSER TUBE AND WATER BOX CLEANING
8/30/2004	PMO	7.72	94.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
8/31/2004	PMO	13.83	75.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
9/1/2004	PMO	7.93	70.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
9/2/2004	PMO	13.17	46.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
9/6/2004	PFO	52.75	113.0	HURRICANE RELATED - WET COAL
9/8/2004	PFO	79.98	46.0	HURRICANE RELATED - WET COAL
9/13/2004	PMO	3.85	46.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
9/15/2004	PFO	1.95	47.0	BAGHOUSE SYSTEMS, GENERAL
9/15/2004	PFO	8.00	94.0	BOTTOM ASH CLINKER GRINDERS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Date	Outage Type	Hours	MW Affected	Description
9/15/2004	PFO	11.98	265.0	BOTTOM ASH CLINKER GRINDERS
9/16/2004	PFO	11.98	94.0	BOTTOM ASH CLINKER GRINDERS
9/16/2004	PFO	11.98	265.0	BOTTOM ASH CLINKER GRINDERS
9/17/2004	PFO	12.90	94.0	BOTTOM ASH CLINKER GRINDERS
9/21/2004	PMO	7.58	265.0	COAL CONVEYERS AND FEEDERS
9/22/2004	PMO	6.25	94.0	COAL CONVEYERS AND FEEDERS
9/23/2004	PFO	5.48	265.0	COAL CONVEYERS AND FEEDERS
9/29/2004	PFO	0.97	119.1	OTHER PULVERIZER PROBLEMS
9/29/2004	PMO	10.55	70.0	TRAVELING SCREEN FOULING
9/30/2004	PFO	8.27	151.0	OTHER FEEDWATER PUMP PROBLEMS
10/1/2004	PFO	8.78	151.0	OTHER FEEDWATER PUMP PROBLEMS
10/3/2004	PFO	11.35	103.0	PULVERIZER FEEDERS
10/3/2004	PFO	26.33	103.0	IGNITERS
10/4/2004	PMO	0.90	75.8	FORCED DRAFT FANS
10/4/2004	PMO	3.68	86.0	CONDENSER TUBE AND WATER BOX CLEANING
10/4/2004	PMO	2.50	86.0	CONDENSER TUBE AND WATER BOX CLEANING
10/8/2004	PFO	5.63	189.0	ELECTROSTATIC PRECIPITATOR PROBLEMS
10/11/2004	PFO	1.73	75.0	PULVERIZER FEEDERS
10/12/2004	PMO	7.97	189.0	CONDENSER TUBE AND WATER BOX CLEANING
10/13/2004	PMO	10.20	151.0	FEEDWATER PUMP
10/14/2004	PMO	9.00	75.0	PULVERIZER FEEDERS
10/25/2004	PMO	7.83	189.0	CONDENSER TUBE AND WATER BOX CLEANING
10/27/2004	PFO	8.10	75.0	OTHER PULVERIZER PROBLEMS
10/27/2004	PFO	8.68	75.0	OTHER PULVERIZER PROBLEMS
10/28/2004	PFO	8.50	85.0	OTHER PULVERIZER PROBLEMS
11/1/2004	PFO	2.85	265.0	BAGHOUSE SYSTEMS, GENERAL

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Date	Outage Type	Hours	MW Affected	Description
11/1/2004	PFO	6.85	141.0	BAGHOUSE SYSTEMS, GENERAL
11/1/2004	PMO	12.38	75.0	PULVERIZER FEEDERS
11/3/2004	PMO	5.72	189.0	CONDENSER TUBE AND WATER BOX CLEANING
11/4/2004	PMO	10.95	75.0	PULVERIZER MILLS
11/7/2004	PMO	15.17	255.0	AIR HEATER (REGENERATIVE)
11/8/2004	PMO	11.17	75.0	PULVERIZER MILLS
11/11/2004	PMO	11.17	75.0	PULVERIZER MILLS
11/12/2004	PFO	3.33	161.0	INDUCED DRAFT FAN LUBRICATION SYSTEMS
11/12/2004	PFO	11.15	94.0	CONDENSER TUBE LEAKS
11/13/2004	PFO	5.98	170.0	CONDENSER TUBE LEAKS
11/23/2004	PMO	5.95	189.0	CONDENSER TUBE AND WATER BOX CLEANING
11/23/2004	PMO	4.45	75.0	PULVERIZER FEEDERS
12/2/2004	PFO	4.28	70.0	DESUPERHEATER/ATTEMPERATOR VALVES
12/3/2004	PFO	6.85	94.0	BOILER RECIRCULATION VALVES
12/8/2004	PFO	6.18	265.0	COAL CONVEYERS AND FEEDERS
12/13/2004	PMO	5.83	189.0	CONDENSER TUBE AND WATER BOX CLEANING
12/14/2004	PFO	1.50	141.0	ASH HANDLING SYSTEM AND HOPPERS
12/14/2004	PFO	2.35	46.0	ASH HANDLING SYSTEM AND HOPPERS
12/21/2004	PMO	5.03	75.0	CONDENSER TUBE AND WATER BOX CLEANING
12/28/2004	PFO	2.13	46.0	BAGHOUSE SYSTEMS, GENERAL

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Date	Outage Type	Hours	MW Affected	Description
1/6/2004	PMO	2.45	275.9	CONDENSER TUBE AND WATER BOX CLEANING
1/14/2004	PMO	28.50	252.0	AIR HEATER (HEAT PIPE,PLATE-TYPE)
1/15/2004	PMO	1.67	104.1	PULVERIZER MILLS
1/23/2004	PFO	7.50	104.0	PULVERIZER MILLS
1/23/2004	PMO	7.33	104.0	PULVERIZER MILLS
1/25/2004	PMO	14.00	352.0	COAL CONVEYERS AND FEEDERS
1/30/2004	PFO	82.90	199.0	BOILER RECIRCULATION VALVES
2/3/2004	FMO	639.80	486.0	BOILER RECIRCULATION VALVES
3/3/2004	PFO	9.25	180.0	OTHER FEEDWATER VALVES
3/7/2004	PMO	7.00	85.0	PULVERIZER MILLS
3/8/2004	PMO	7.00	85.0	PULVERIZER MILLS
3/9/2004	FFO	1.50	486.0	OTHER INSTRUMENT AIR PROBLEMS
3/10/2004	PMO	6.57	85.0	PULVERIZER MILLS
3/12/2004	PFO	1.17	85.0	IGNITERS
3/12/2004	PMO	6.08	85.0	PULVERIZER MILLS
3/15/2004	PMO	5.62	271.0	CONDENSER TUBE AND WATER BOX CLEANING
3/17/2004	PMO	4.80	257.0	CONDENSER TUBE AND WATER BOX CLEANING
3/18/2004	PMO	2.40	85.1	PULVERIZER FEEDERS
3/18/2004	PFO	1.05	85.2	PULVERIZER FEEDERS
3/18/2004	PMO	10.38	85.0	PULVERIZER MILLS
3/19/2004	FFO	1.12	486.0	FEEDWATER CONTROLS
3/19/2004	PMO	8.13	191.0	OTHER VOLTAGE CONDUCTORS AND BUSES
3/21/2004	PFO	1.92	129.0	480-VOLT TRANSFORMERS
3/25/2004	PFO	3.82	94.0	FOREIGN OBJECT IN MILL
3/26/2004	FMO	26.12	486.0	CIRCUIT BREAKERS
3/29/2004	PFO	12.50	85.0	OTHER PULVERIZER PROBLEMS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Date	Outage Type	Hours	MW Affected	Description
3/30/2004	PMO	4.90	94.0	OTHER PULVERIZER PROBLEMS
3/30/2004	PMO	4.50	85.0	OTHER PULVERIZER PROBLEMS
3/31/2004	PMO	2.92	85.0	OTHER PULVERIZER PROBLEMS
3/31/2004	PMO	2.72	85.0	OTHER PULVERIZER PROBLEMS
4/2/2004	PMO	32.12	104.0	PULVERIZER MILLS
4/4/2004	PFO	2.62	94.0	OTHER PULVERIZER PROBLEMS
4/4/2004	PMO	5.33	290.0	CONDENSER TUBE AND WATER BOX CLEANING
4/8/2004	PMO	4.10	85.0	OTHER PULVERIZER PROBLEMS
4/9/2004	PMO	4.67	85.0	OTHER PULVERIZER PROBLEMS
4/11/2004	PMO	4.75	104.0	OTHER PULVERIZER PROBLEMS
4/12/2004	PMO	4.83	143.0	CONDENSER TUBE AND WATER BOX CLEANING
4/13/2004	PMO	2.55	104.1	CIRCULATING WATER PUMPS
4/14/2004	PMO	0.18	93.0	CIRCULATING WATER PUMPS
4/14/2004	FFO	25.50	486.0	EMERGENCY GENERATOR TRIP DEVICES
4/30/2004	PFO	1.80	55.9	BOTTOM ASH SYSTEMS (WET OR DRY)
5/4/2004	PMO	4.58	295.0	CONDENSER TUBE AND WATER BOX CLEANING
5/4/2004	PMO	7.15	295.0	CONDENSER TUBE AND WATER BOX CLEANING
5/6/2004	PMO	5.92	271.0	CONDENSER TUBE AND WATER BOX CLEANING
5/17/2004	PFO	20.33	276.0	BOILER RECIRCULATION VALVES
5/20/2004	PMO	4.10	295.0	CONDENSER TUBE AND WATER BOX CLEANING
5/22/2004	FFO	81.77	486.0	FURNACE WALL LEAKS
5/31/2004	PMO	7.07	247.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/2/2004	PMO	3.58	42.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/2/2004	PMO	10.00	295.0	CONDENSER TUBE AND WATER BOX CLEANING
6/3/2004	PMO	2.50	56.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/6/2004	PMO	5.82	295.0	CONDENSER TUBE AND WATER BOX CLEANING

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Crystal River 2				
Date	Outage Type	Hours	MW Affected	Description
6/7/2004	PMO	5.90	295.0	CONDENSER TUBE AND WATER BOX CLEANING
6/9/2004	PMO	2.00	85.1	PULVERIZER FEEDERS
6/9/2004	PMO	3.75	276.0	CONDENSER TUBE AND WATER BOX CLEANING
6/11/2004	PMO	4.65	295.0	CONDENSER TUBE AND WATER BOX CLEANING
6/12/2004	PMO	5.97	37.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/13/2004	PMO	8.33	51.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/14/2004	PMO	6.63	80.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/15/2004	PMO	6.05	56.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/16/2004	PMO	4.45	352.0	CONDENSER TUBE AND WATER BOX CLEANING
6/19/2004	PMO	9.28	70.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/20/2004	PMO	6.83	123.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/21/2004	PMO	11.93	66.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/21/2004	PMO	5.23	210.0	CONDENSER TUBE AND WATER BOX CLEANING
6/24/2004	PMO	4.50	191.1	CONDENSER TUBE AND WATER BOX CLEANING
6/21/2004	PMO	59.55	85.0	OTHER PULVERIZER PROBLEMS
6/24/2004	PMO	8.25	71.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/25/2004	PMO	15.18	71.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/26/2004	PMO	14.00	176.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/22/2004	PMO	158.12	33.0	HEATER DRAIN PUMPS
7/1/2004	PMO	2.67	33.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/1/2004	PMO	2.62	24.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/1/2004	PMO	355.97	33.0	HEATER DRAIN PUMPS
7/2/2004	PMO	11.25	71.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/3/2004	FFO	19.78	486.0	SWITCHYARD SYSTEM PROTECTION DEVICES
7/4/2004	PMO	9.15	62.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/5/2004	PMO	11.57	38.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Crystal River 2				
Date	Outage Type	Hours	MW Affected	Description
7/6/2004	PMO	5.88	262.0	CONDENSER TUBE AND WATER BOX CLEANING
7/7/2004	PMO	14.57	166.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/8/2004	PMO	6.50	243.0	CONDENSER TUBE AND WATER BOX CLEANING
7/8/2004	PMO	11.53	71.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/9/2004	PMO	18.25	71.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/10/2004	PMO	15.82	71.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/11/2004	PMO	10.25	128.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/12/2004	PMO	18.00	147.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/13/2004	PMO	16.00	61.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/13/2004	PMO	5.78	243.0	CONDENSER TUBE AND WATER BOX CLEANING
7/14/2004	PMO	9.35	24.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/15/2004	PFO	2.92	109.0	TRAVELING SCREEN FOULING
7/15/2004	PMO	5.40	156.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/16/2004	PMO	9.00	52.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/17/2004	PMO	2.58	56.1	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/18/2004	PFO	1.70	275.9	TRAVELING SCREEN FOULING
7/18/2004	PFO	1.87	123.1	OTHER PULVERIZER PROBLEMS
7/18/2004	PFO	5.40	28.0	OTHER PULVERIZER PROBLEMS
7/19/2004	PMO	6.62	295.0	CONDENSER TUBE AND WATER BOX CLEANING
7/22/2004	PFO	219.45	18.0	OTHER HIGH PRESSURE HEATER PROBLEMS
7/22/2004	PMO	2.75	247.1	CIRCULATING WATER PUMPS
7/22/2004	PMO	2.92	295.1	CONDENSER TUBE AND WATER BOX CLEANING
7/23/2004	FFO	12.05	486.0	BOTTOM ASH SYSTEMS (WET OR DRY)
7/23/2004	PFO	16.23	162.0	BOTTOM ASH SYSTEMS (WET OR DRY)
7/23/2004	PMO	4.42	277.1	CONDENSER TUBE AND WATER BOX CLEANING
7/26/2004	PMO	7.52	39.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Crystal River 2				
Date	Outage Type	Hours	MW Affected	Description
7/27/2004	PMO	10.50	39.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/29/2004	PMO	9.33	62.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/30/2004	PMO	5.28	277.0	CONDENSER TUBE AND WATER BOX CLEANING
7/30/2004	PMO	11.50	62.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
7/31/2004	PMO	7.00	57.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
8/1/2004	PFO	12.98	18.0	HIGH PRESSURE HEATER TUBE LEAKS
8/1/2004	PFO	272.33	38.0	HIGH PRESSURE HEATER TUBE LEAKS
8/1/2004	PMO	5.60	80.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
8/2/2004	PMO	2.33	112.9	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
8/3/2004	PMO	5.40	33.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
8/8/2004	PMO	71.98	113.0	OTHER FEEDWATER VALVES
8/18/2004	PMO	7.08	276.0	CONDENSER TUBE AND WATER BOX CLEANING
8/19/2004	PMO	5.42	56.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
8/20/2004	PMO	12.52	80.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
8/25/2004	PMO	1.92	46.9	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
8/26/2004	PMO	6.98	52.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
8/27/2004	PFO	11.23	85.0	PULVERIZER FEEDERS
8/28/2004	PFO	6.00	132.0	BUNKER FLOW PROBLEMS
8/29/2004	PMO	5.33	80.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
8/30/2004	PMO	2.45	56.9	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
8/31/2004	PMO	5.50	295.0	CONDENSER TUBE AND WATER BOX CLEANING
8/31/2004	PMO	13.83	85.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
9/1/2004	PMO	7.30	80.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
9/1/2004	PMO	6.07	295.0	CONDENSER TUBE AND WATER BOX CLEANING
9/2/2004	PMO	12.83	56.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
9/2/2004	PMO	5.50	85.0	PULVERIZER FEEDERS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Crystal River 2				
Date	Outage Type	Hours	MW Affected	Description
9/3/2004	PFO	1.65	123.1	PULVERIZER FEEDERS
9/3/2004	PFO	0.82	95.8	PULVERIZER FEEDERS
9/6/2004	PFO	66.37	142.0	HURRICANE RELATED - WET COAL
9/9/2004	PFO	66.38	37.0	HURRICANE RELATED - WET COAL
9/21/2004	PMO	7.58	248.0	COAL CONVEYERS AND FEEDERS
9/21/2004	PMO	30.25	104.0	COAL CONVEYERS AND FEEDERS
9/23/2004	PFO	5.48	352.0	COAL CONVEYERS AND FEEDERS
9/26/2004	PMO	6.05	276.0	CONDENSER TUBE AND WATER BOX CLEANING
9/27/2004	PMO	7.03	85.0	PULVERIZER MILLS
9/29/2004	PMO	10.55	80.0	TRAVELING SCREEN FOULING
9/29/2004	PMO	9.75	257.0	INDUCED DRAFT FAN SPEED CHANGER
9/29/2004	PMO	9.97	104.0	PULVERIZER FEEDERS
10/5/2004	PMO	6.00	295.0	CONDENSER TUBE AND WATER BOX CLEANING
10/7/2004	PFO	13.30	37.0	ELECTROSTATIC PRECIPITATOR PROBLEMS
10/7/2004	PFO	12.12	295.0	ELECTROSTATIC PRECIPITATOR PROBLEMS
10/18/2004	PMO	5.90	295.0	CONDENSER TUBE AND WATER BOX CLEANING
10/24/2004	PMO	7.25	295.0	CONDENSER TUBE AND WATER BOX CLEANING
10/28/2004	PMO	7.97	295.0	CONDENSER TUBE AND WATER BOX CLEANING
11/1/2004	PFO	3.75	352.0	BAGHOUSE SYSTEMS, GENERAL
11/1/2004	PFO	5.95	161.0	BAGHOUSE SYSTEMS, GENERAL
11/2/2004	PMO	6.13	295.0	CONDENSER TUBE AND WATER BOX CLEANING
11/2/2004	PMO	6.50	104.0	CIRCULATING WATER PUMPS
11/16/2004	PMO	8.00	85.0	PULVERIZER FEEDERS
11/22/2004	PMO	6.13	257.0	CONDENSER TUBE AND WATER BOX CLEANING
11/26/2004	PFO	59.73	38.0	OTHER CIRCULATING WATER SYSTEM PROBLEMS
11/28/2004	PMO	11.27	276.0	OTHER CIRCULATING WATER SYSTEM PROBLEMS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Date	Outage Type	Hours	MW Affected	Description
11/29/2004	PFO	30.30	38.0	OTHER CIRCULATING WATER SYSTEM PROBLEMS
12/1/2004	PMO	19.83	199.0	OTHER CIRCULATING WATER SYSTEM PROBLEMS
12/1/2004	PMO	5.50	85.0	PULVERIZER FEEDERS
12/3/2004	PMO	17.07	220.0	BOILER RECIRCULATION PUMPS
12/8/2004	PFO	6.18	352.0	COAL CONVEYERS AND FEEDERS
12/14/2004	PMO	4.67	295.0	CONDENSER TUBE AND WATER BOX CLEANING
12/16/2004	PFO	2.45	123.0	IGNITERS
12/27/2004	PMO	18.33	85.0	PULVERIZER MILLS
12/28/2004	PFO	2.13	66.1	BAGHOUSE SYSTEMS, GENERAL
12/28/2004	PMO	11.75	85.0	PULVERIZER MILLS
12/29/2004	PMO	5.83	191.0	CONDENSER TUBE AND WATER BOX CLEANING
12/29/2004	PMO	13.50	85.0	PULVERIZER MILLS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Crystal River 3				
Date	Outage Type	Hours	MW Affected	Description
3/2/2004	PMO	6.77	400.0	REACTOR COOLANT/RECIRCULATING PUMP MOTORS
3/3/2004	FMO	36.53	769.0	REACTOR COOLANT/RECIRCULATING PUMP MOTORS
3/4/2004	PMO	15.27	316.0	REACTOR COOLANT/RECIRCULATING PUMP MOTORS
3/24/2004	FFO	35.13	769.0	REACTOR CONTROL SYSTEM/INTEGRATED CONTROL SYSTEM PROBLEMS
3/25/2004	PFO	21.30	353.0	REACTOR CONTROL SYSTEM/INTEGRATED CONTROL SYSTEM PROBLEMS
6/9/2004	PMO	44.70	2.0	REACTOR CONTROL SYSTEM/INTEGRATED CONTROL SYSTEM PROBLEMS
8/9/2004	PFO	1.97	97.0	FEEDWATER PUMP DRIVE - CONTROLS
8/9/2004	PMO	3.25	45.9	TURBINE MAIN STOP VALVE TESTING
8/9/2004	PMO	0.95	46.1	FEEDWATER PUMP DRIVE - CONTROLS
8/9/2004	PMO	1.97	18.0	TURBINE MAIN STOP VALVE TESTING
9/6/2004	FFO	127.35	769.0	HURRICANE RELATED - FLASHOVER OF A SWITCHYARD BREAKER
9/11/2004	PFO	22.85	251.0	HURRICANE RELATED
10/10/2004	PMO	89.37	107.0	CONDENSER TUBE AND WATER BOX CLEANING
10/13/2004	PMO	9.02	76.0	CIRCULATING WATER PUMP MOTORS
12/28/2004	PFO	14.78	40.0	OTHER CIRCULATING WATER SYSTEM PROBLEMS
12/30/2004	PMO	24.62	77.0	OTHER CIRCULATING WATER SYSTEM PROBLEMS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Date	Outage Type	Hours	MW Affected	Description
1/5/2004	PMO	5.50	101.1	PULVERIZER COAL LEAK (PULVERIZERS ONLY)
1/7/2004	FFO	22.67	720.0	PROCESS COMPUTER
1/10/2004	PMO	7.33	101.0	PULVERIZER COAL LEAK (PULVERIZERS ONLY)
1/21/2004	PFO	1.77	101.1	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
1/26/2004	PFO	3.38	482.1	AC INSTRUMENT POWER TRANSFORMERS
2/1/2004	FFO	1.88	720.0	FORCED DRAFT FAN DRIVES (OTHER THAN MOTOR)
2/10/2004	PMO	3.00	433.9	CEMS CERTIFICATION AND RECERTIFICATION
2/10/2004	PMO	1.50	243.8	CEMS CERTIFICATION AND RECERTIFICATION
2/11/2004	PMO	271.39	102.0	HEATER DRAIN PUMPS
2/12/2004	PMO	5.20	256.0	CEMS CERTIFICATION AND RECERTIFICATION
2/12/2004	PMO	4.75	309.1	CEMS CERTIFICATION AND RECERTIFICATION
2/17/2004	PFO	4.22	509.0	OTHER BOILER TUBE LEAKS
2/17/2004	FFO	87.58	720.0	OTHER BOILER TUBE LEAKS
2/21/2004	FFO	7.87	720.0	DESUPERHEATER/ATTEMPERATOR CONTROLS
2/21/2004	FFO	7.15	720.0	OPERATOR ERROR
2/22/2004	FFO	0.97	720.0	FEEDWATER REGULATING (BOILER LEVEL CONTROL) VALVE
2/23/2004	PFO	3.25	27.9	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
2/25/2004	FFO	8.67	720.0	OTHER EXCITER PROBLEMS
2/25/2004	FFO	1.38	720.0	OPERATOR ERROR
3/1/2004	PFO	15.00	125.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/2/2004	PFO	12.50	130.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/3/2004	PFO	18.83	120.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/4/2004	PFO	5.00	92.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/5/2004	PFO	18.08	139.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/6/2004	PFO	16.83	120.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/7/2004	PFO	14.25	87.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Crystal River 4				
Date	Outage Type	Hours	MW Affected	Description
3/8/2004	PFO	40.33	111.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/11/2004	PFO	13.17	73.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/12/2004	PFO	18.33	125.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/13/2004	PFO	17.08	102.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/17/2004	PFO	15.00	111.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/18/2004	PFO	15.75	111.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/19/2004	PFO	3.92	30.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/20/2004	PFO	4.25	82.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/22/2004	PFO	52.42	92.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/25/2004	PFO	14.00	35.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/26/2004	PFO	5.83	39.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/29/2004	PFO	7.17	63.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/31/2004	PFO	7.75	54.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/31/2004	PFO	5.75	38.9	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/1/2004	PFO	13.00	101.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/1/2004	PFO	5.50	54.1	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/2/2004	PFO	19.00	54.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/3/2004	PFO	16.75	54.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/4/2004	PFO	13.50	35.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/5/2004	PFO	5.75	58.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/5/2004	PFO	12.50	25.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/6/2004	PFO	6.83	58.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/6/2004	PFO	11.00	35.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/7/2004	PFO	5.33	35.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/12/2004	PFO	1.13	101.0	OTHER PULVERIZER PROBLEMS
4/17/2004	PFO	5.80	43.9	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Date	Outage Type	Hours	MW Affected	Description
4/19/2004	FFO	2.77	720.0	PULVERIZER FEEDER MOTOR
5/17/2004	PMO	8.92	415.0	CONDENSER TUBE AND WATER BOX CLEANING
5/18/2004	PMO	10.25	415.0	CONDENSER TUBE AND WATER BOX CLEANING
5/19/2004	PFO	17.85	358.0	CONDENSER TUBE LEAKS
5/25/2004	PMO	8.50	415.0	CONDENSER TUBE AND WATER BOX CLEANING
6/3/2004	FFO	6.03	720.0	FEEDWATER VALVES (NOT FEEDWATER REGULATING VALVE)
6/3/2004	PFO	9.23	449.0	FEEDWATER VALVES (NOT FEEDWATER REGULATING VALVE)
6/15/2004	PMO	12.00	44.0	CEMS CERTIFICATION AND RECERTIFICATION
6/17/2004	PFO	1.68	110.8	OTHER PULVERIZER PROBLEMS
6/30/2004	PFO	5.23	14.0	OTHER FUEL QUALITY PROBLEMS
7/5/2004	PFO	1.92	54.1	BOTTOM ASH PYRITE HOPPER (PULVERIZER REJECT) SYSTEM
7/7/2004	FFO	3.95	720.0	480-VOLT CIRCUIT BREAKERS
7/8/2004	FFO	2.60	720.0	OTHER FEEDWATER VALVES
7/20/2004	PFO	2.20	101.1	OTHER FUEL QUALITY PROBLEMS
7/22/2004	PFO	167.87	101.0	PULVERIZER MILLS
7/24/2004	PFO	7.50	167.0	PULVERIZER MILLS
8/1/2004	PFO	0.92	101.3	OTHER PULVERIZER PROBLEMS
8/3/2004	PMO	22.05	101.0	OTHER PULVERIZER PROBLEMS
8/10/2004	PMO	3.92	243.9	BOTTOM ASH SYSTEMS (WET OR DRY)
8/12/2004	PMO	5.33	149.0	BOTTOM ASH SYSTEMS (WET OR DRY)
8/19/2004	PFO	8.37	30.0	PULVERIZER REDUCED CAPACITY DUE TO WEAR
8/24/2004	PFO	5.77	25.0	PULVERIZER REDUCED CAPACITY DUE TO WEAR
8/25/2004	PFO	2.28	100.9	OTHER FUEL QUALITY PROBLEMS
8/26/2004	PFO	4.23	387.0	COAL CONVEYERS AND FEEDERS
8/26/2004	PFO	2.27	101.0	COAL CONVEYERS AND FEEDERS
8/26/2004	PFO	0.67	101.5	PULVERIZER FEEDERS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Date	Outage Type	Hours	MW Affected	Description
3/26/2004	PMO	2.08	119.9	HEATER DRAIN PUMPS
3/27/2004	PMO	8.58	434.0	FEEDWATER PIPING
3/28/2004	FFO	5.92	720.0	OPERATOR ERROR
3/28/2004	FFO	11.02	720.0	FEEDWATER PIPING
3/28/2004	PMO	4.80	434.0	FEEDWATER PIPING
3/29/2004	PFO	4.50	73.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/30/2004	PFO	2.00	34.9	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/31/2004	PMO	8.00	101.0	PULVERIZER MILLS
9/1/2004	PFO	5.27	73.0	HURRICANE RELATED - HIGH OPACITY
9/1/2004	PFO	7.37	20.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
9/1/2004	PMO	4.60	102.1	PULVERIZER MILLS
9/2/2004	PFO	7.25	73.0	HURRICANE RELATED - HIGH OPACITY
9/3/2004	PMO	5.68	102.0	PULVERIZER FEEDERS
9/6/2004	FFO	20.33	720.0	HURRICANE RELATED - PT FAILURE
9/7/2004	PFO	71.00	244.0	HURRICANE RELATED - WET COAL
3/10/2004	PFO	249.42	25.0	OTHER FORCED DRAFT FAN PROBLEMS
3/13/2004	PFO	9.50	77.0	HURRICANE RELATED - HIGH OPACITY
3/14/2004	PFO	44.00	57.0	HURRICANE RELATED - HIGH OPACITY
3/16/2004	PFO	43.50	33.0	HURRICANE RELATED - HIGH OPACITY
3/18/2004	PFO	15.25	67.0	HURRICANE RELATED - HIGH OPACITY
10/5/2004	PFO	1.43	25.1	HURRICANE RELATED - HIGH OPACITY
0/14/2004	PFO	110.00	68.0	HIGH PRESSURE HEATER TUBE LEAKS
0/19/2004	FMO	57.33	720.0	HIGH PRESSURE HEATER TUBE LEAKS
0/21/2004	PFO	17.67	549.0	CONDENSER TUBE LEAKS
0/22/2004	PFO	18.00	263.0	HURRICANE RELATED - HIGH OPACITY
0/23/2004	PFO	11.88	339.0	HURRICANE RELATED - HIGH OPACITY

PROGRESS ENERGY FLORIDA

Date	Outage Type	Hours	MW Affected	Description
10/24/2004	PFO	9.75	244.0	HURRICANE RELATED - HIGH OPACITY
10/24/2004	PMO	114.25	101.0	PULVERIZER MILLS
10/25/2004	PFO	8.67	24.0	HURRICANE RELATED - HIGH OPACITY
10/26/2004	PFO	5.42	162.0	TRIP OF 407 PULVERIZER MOTOR
10/27/2004	PMO	6.00	162.0	COAL CONVEYERS AND FEEDERS
10/28/2004	PMO	6.00	162.0	COAL CONVEYERS AND FEEDERS
10/29/2004	PFO	8.67	29.0	HURRICANE RELATED - HIGH OPACITY
10/29/2004	PMO	6.00	162.0	COAL CONVEYERS AND FEEDERS
10/30/2004	PFO	6.25	63.0	HURRICANE RELATED - HIGH OPACITY
10/31/2004	PFO	9.08	130.0	HURRICANE RELATED - HIGH OPACITY
11/1/2004	PFO	11.92	106.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
11/2/2004	PFO	16.33	102.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
11/3/2004	PFO	16.42	96.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
11/4/2004	PFO	12.17	96.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
11/5/2004	PFO	13.75	125.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
11/6/2004	PFO	10.17	149.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
11/7/2004	PFO	10.92	149.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
11/7/2004	PMO	221.22	102.0	PULVERIZER MILLS
11/8/2004	PFO	5.58	94.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
11/8/2004	PMO	6.00	161.0	COAL CONVEYERS AND FEEDERS
11/9/2004	PFO	9.17	47.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
11/9/2004	PMO	6.00	161.0	COAL CONVEYERS AND FEEDERS
11/10/2004	PFO	5.87	71.1	COAL CONVEYERS AND FEEDERS
11/10/2004	PFO	6.13	23.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
11/11/2004	PFO	15.42	4.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
11/17/2004	FMO	135.52	720.0	ELECTROSTATIC PRECIPITATOR FOULING

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Date	Outage Type	Hours	MW Affected	Description
11/23/2004	PFO	0.92	102.1	OTHER PULVERIZER PROBLEMS
11/23/2004	PMO	6.00	340.0	OTHER CIRCULATING WATER SYSTEM PROBLEMS
11/24/2004	PMO	19.87	292.0	OTHER CIRCULATING WATER SYSTEM PROBLEMS
12/17/2004	PMO	5.25	100.9	PULVERIZER COAL LEAK (PULVERIZERS ONLY)
12/21/2004	PMO	1.45	100.8	PULVERIZER COAL LEAK (PULVERIZERS ONLY)
12/22/2004	PMO	11.00	158.0	OTHER CIRCULATING WATER SYSTEM PROBLEMS
12/26/2004	FMO	59.87	720.0	OTHER BOILER TUBE LEAKS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Date	Outage Type	Hours	MW Affected	Description
2/1/2004	PMO	141.33	98.0	PULVERIZER MILLS
2/23/2004	PFO	2.72	99.0	BURNER INSTRUMENTS AND CONTROLS (EXCEPT LIGHT-OFF)
2/24/2004	PMO	2.08	431.0	CEMS CERTIFICATION AND RECERTIFICATION
2/24/2004	PMO	0.83	241.0	CEMS CERTIFICATION AND RECERTIFICATION
2/24/2004	PFO	3.12	431.1	AIR HEATER FOULING (REGENERATIVE)
2/25/2004	PFO	5.15	335.9	AIR HEATER FOULING (REGENERATIVE)
4/22/2004	PMO	75.63	99.0	PULVERIZER OVERHAUL
4/25/2004	FFO	3.20	717.0	OTHER FEEDWATER VALVES
4/25/2004	PO	122.00	717.0	BOILER INSPECTIONS
5/1/2004	PO	76.20	717.0	BOILER INSPECTIONS
5/4/2004	FFO	1.32	717.0	OTHER FEEDWATER VALVES
5/4/2004	FFO	0.60	717.0	OTHER FEEDWATER VALVES
5/4/2004	FFO	0.65	717.0	OTHER FEEDWATER VALVES
5/13/2004	PFO	8.00	99.0	HEATER DRAIN PUMPS
5/26/2004	PMO	3.08	479.1	CONDENSER TUBE AND WATER BOX CLEANING
5/27/2004	PMO	8.25	99.0	PULVERIZER MILLS
6/14/2004	PFO	4.33	99.0	HEATER DRAIN PUMPS
6/16/2004	PMO	6.00	41.0	CEMS CERTIFICATION AND RECERTIFICATION
6/17/2004	PFO	1.57	117.1	OTHER PULVERIZER PROBLEMS
7/1/2004	PFO	1.50	98.0	FORCED DRAFT FAN CONTROLS
7/2/2004	FFO	9.92	717.0	AIR HEATER (REGENERATIVE)
7/2/2004	FFO	1.15	717.0	OTHER FEEDWATER VALVES
7/18/2004	PFO	2.97	98.1	OTHER FUEL QUALITY PROBLEMS
7/18/2004	PFO	2.35	125.1	OTHER FUEL QUALITY PROBLEMS
7/19/2004	PFO	2.30	125.0	OTHER FUEL QUALITY PROBLEMS
7/25/2004	FFO	2.60	717.0	AIR SUPPLY DAMPERS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Date	Outage Type	Hours	MW Affected	Description
8/17/2004	PFO	1.50	98.0	PULVERIZER FEEDERS
8/18/2004	PFO	2.93	122.0	PULVERIZER FEEDERS
8/26/2004	PFO	4.23	384.0	COAL CONVEYERS AND FEEDERS
8/26/2004	PFO	2.27	98.0	COAL CONVEYERS AND FEEDERS
9/3/2004	PFO	2.25	99.1	OTHER FUEL QUALITY PROBLEMS
9/6/2004	FFO	48.42	717.0	HURRICANE RELATED
9/8/2004	PFO	36.07	193.0	HURRICANE RELATED - WET COAL
9/13/2004	PFO	9.00	79.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
9/14/2004	PFO	46.00	70.0	HURRICANE RELATED - HIGH OPACITY
9/15/2004	PFO	1.75	209.0	OTHER FUEL QUALITY PROBLEMS
9/15/2004	PMO	2.00	76.0	OTHER COOLING TOWER PROBLEMS
9/15/2004	PMO	6.00	29.0	OTHER PULVERIZER PROBLEMS
9/18/2004	PFO	19.72	32.0	HURRICANE RELATED - HIGH OPACITY
9/24/2004	FFO	4.43	717.0	AIR SUPPLY DAMPERS
10/3/2004	PMO	24.00	403.0	OTHER FEEDWATER VALVES
10/4/2004	PFO	43.03	403.0	OTHER FEEDWATER VALVES
10/6/2004	PFO	33.80	99.0	PULVERIZER MILLS
10/20/2004	PFO	0.67	60.2	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
10/22/2004	PFO	5.03	51.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
10/27/2004	PMO	6.00	260.0	COAL CONVEYERS AND FEEDERS
10/28/2004	PMO	6.00	260.0	COAL CONVEYERS AND FEEDERS
10/29/2004	PMO	6.00	260.0	COAL CONVEYERS AND FEEDERS
10/30/2004	PFO	4.83	79.1	PULVERIZER FEEDERS
10/31/2004	PMO	9.25	98.0	PULVERIZER MILLS
11/1/2004	PMO	117.33	99.0	PULVERIZER MILLS
11/8/2004	PFO	2.50	312.9	CONDENSER TUBE LEAKS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Date	Outage Type	Hours	MW Affected	Description
11/8/2004	PFO	2.25	65.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
11/8/2004	PMO	6.00	260.0	COAL CONVEYERS AND FEEDERS
11/9/2004	PMO	6.00	260.0	COAL CONVEYERS AND FEEDERS
11/10/2004	PFO	12.42	22.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
11/11/2004	PFO	3.52	59.9	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
11/12/2004	PFO	1.50	108.0	CONDENSER TUBE LEAKS
11/12/2004	PFO	11.03	51.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
11/13/2004	PFO	11.00	22.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
11/14/2004	PFO	9.08	17.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
11/17/2004	PFO	1.80	170.1	DESUPERHEATER/ATTEMPERATOR CONTROLS
11/29/2004	PFO	5.50	55.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
12/2/2004	PFO	0.83	289.2	CONDENSER TUBE LEAKS
12/2/2004	PMO	20.83	536.0	CONDENSER TUBE LEAKS
12/4/2004	PFO	1.00	78.9	AIR HEATER (REGENERATIVE)
12/5/2004	PFO	3.00	289.0	CONDENSER TUBE LEAKS
12/5/2004	PFO	11.33	146.0	CONDENSER TUBE LEAKS
12/5/2004	PMO	16.67	536.0	CONDENSER TUBE LEAKS
12/8/2004	PFO	4.00	193.1	CONDENSER TUBE LEAKS
12/8/2004	PMO	5.33	536.0	CONDENSER TUBE LEAKS
12/9/2004	PFO	8.42	312.0	CIRCULATING WATER VALVES
12/9/2004	PMO	7.50	536.0	CONDENSER TUBE LEAKS
12/10/2004	FFO	3.78	717.0	AIR SUPPLY DAMPERS
12/10/2004	PFO	11.33	479.0	PRIMARY AIR FAN DRIVES
12/13/2004	FFO	1.37	717.0	AIR SUPPLY DAMPERS
12/13/2004	PMO	33.22	98.0	HEATER DRAIN PUMPS
12/14/2004	PFO	0.67	117.2	HEATER DRAIN PUMPS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Date	Outage Type	Hours	MW Affected	Description
12/15/2004	FFO	16.80	717.0	GENERATOR LIQUID COOLING SYSTEM
12/21/2004	PMO	2.88	116.9	HEATER DRAIN PUMPS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

lines 1				
Date	Outage Type	Hours	MW Affected	Description
3/26/2004	PO	360.68	482.0	MAJOR GAS TURBINE OVERHAUL
4/10/2004	PMO	742.38	236.0	MAJOR GAS TURBINE OVERHAUL
5/20/2004	PFO	1.08	327.1	TURBINE HYDRAULIC SYSTEM PIPES AND VALVES
5/21/2004	PFO	0.65	237.3	GT COOLING AND SEAL AIR SYSTEM
6/18/2004	PFO	5.2	276.0	GT FUEL PIPING AND VALVES
6/19/2004	PFO	8.48	276.0	GT FUEL PIPING AND VALVES
6/20/2004	PFO	35.25	276.0	GT FUEL PIPING AND VALVES
9/22/2004	PFO	2.77	336.0	BOILER SAFETY VALVE TEST
0/16/2004	PFO	1.47	186.0	TURBINE LUBE OIL PUMPS
0/18/2004	PO	873.07	482.0	MAJOR GAS TURBINE OVERHAUL
12/9/2004	PFO	12	106.0	GT VIBRATION IN UNIT NOT ATTRIBUTABLE TO BEARINGS OR OTHER COMPONENTS
2/14/2004	PFO	0.43	231.5	OPERATOR ERROR

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - DECEMBER 2004

Date	Outage Type	Hours	MW Affected	Description
2/27/2004	FFO	11.43	207.0	SOLID STATE EXCITER ELEMENT
2/28/2004	PO	503.00	207.0	GAS TURBINE HOT END INSPECTION
4/13/2004	FMO	41.83	207.0	MAIN STEAM RELIEF/SAFETY VALVES
6/1/2004	FFO	10.15	207.0	GT COOLING AND SEAL AIR SYSTEM
8/13/2004	FFO	283.17	207.0	HURRICANE RELATED - COOLING TOWER DAMAGE
9/10/2004	FFO	6.55	207.0	OPERATOR ERROR
10/3/2004	PO	82.82	207.0	GT COOLING AND SEAL AIR SYSTEM