

05000

E.B. Docket No. 04-381

Before The FEDERAL COMMUNICATIONS COMMISSION Washington, D.C. 20554

FLORIDA CABLE TELECOMMUNICATIONS ASSOCIATION, INC., COX COMMUNICATIONS GULF COAST, L.L.C., et. al.

Complainants,

v.

GULF POWER COMPANY,

Respondent.

To: Office of the Secretary

Attn.: The Honorable Richard L. Sippel Chief Administrative Law Judge

SUPPLEMENT TO GULF POWER'S MOTION FOR EXTENSION OF TIME

Gulf Power Company ("Gulf Power") supplements its March 23, 2005 Motion For Extension Of Time as follows:

1. The March 23, 2005 Motion For Extension Of Time included, as Exhibit A, the

executed Statement of Work between Gulf Power and Osmose Utilities Services, Inc.

("Osmose").

 CMP
 ______2.
 Since March 23, 2005, the appendices to the Statement of Work have been

 COM
 ______2.
 Since March 23, 2005, the appendices to the Statement of Work have been

 CTR
 ______revised by Gulf Power and Osmose.

 ECR
 _______3.
 The appendices attached hereto as Exhibit A should replaced the appendices in

 GCL
 3.
 The appendices attached hereto as Exhibit A should replaced the appendices in

OPC the previously transmitted Statement of Work (pp. 16-20).

- MMS_____
- RCA

SCR

SEC

OTH 761969.1

DOCUMENT NUMBER-DATE 03137 NAR 31 8 FPSC-COMMISSION CLEFT Respectfully submitted,

J. Russell Campbell Eric B. Langley Jennifer M. Buettner **BALCH & BINGHAM LLP** 1710 Sixth Avenue North Birmingham, Alabama 35203-2015 Telephone: (205) 251-8100 Facsimile: (205) 226-8798

Ralph A. Peterson BEGGS & LANE, LLP P.O. Box 12950 Pensacola, Florida 32591-2950 Telephone: (850) 432-2451 Facsimile: (850) 469-3331

Counsel for Respondent

CERTIFICATE OF SERVICE

I hereby certify that a copy of the foregoing Supplement To Gulf Power's Motion For Extension Of Time has been served upon the following by Electronic Mail and by United States Mail on this the 2947 day of March, 2005:

| Federal Communications Commission 445 12th Street, S.W. Washington, D.C. 20554 Via E-mail |
|---|
| Marlene H. Dortch, Secretary Federal Communications Commission Office of the Secretary 445 12th Street, SW Washington, D.C. 20554 |
| David H. Solomon Federal Communications Commission 445 12th Street, S.W. Washington, D.C. 20554 |
| Federal Energy Regulatory Commission Docket Room 1A-209 888 First Street, NE Washington, D.C. 20426 |
| |
| |

OF COU

Usmose Utilities Services

Proprietary and Confidential

Appendix A

Objects/Attributes/Attribute Values to be Inventoried

| OBJECT | ATTRIBUTE | ATTRIBUTE VALUE |
|-----------------------------|--|--|
| 'ole | ID Number Generated by FastGate (with TLN map number p | |
| | GPS Location | X,Y |
| | Date/time of Inspection | String |
| | Pole class | Enumerated list (actual or estimated) |
| | Pole height | Enumerated list (actual or estimated) |
| | Pole type | Enumerated list |
| | Crowded pole | Y/N |
| | Measurements (crowded poles only): From ground to secondary (pole) From ground to neutral(pole) From ground to span guy (pole) From ground to secondary (mid-span) From ground to neutral (mid-span) From ground to transformer can From ground to street light drip loop | Integers |
| From ground to top of riser | | |
| | Image1 file name (crowded poles only) mage2 file name (crowded poles only, f necessary) | String String |
| Attachment | Dwner | Enumerated list |
| | Гуре | Enumerated list: CATV, phone, government, etc. |
| | Crowded attachment | Enumerated list: No Less than 52" power/attachment separation Less than 24" street light drip loop/attachment separation Less than 42" transformer/attachment separation |
| | NESC Violation | Multi-select list: None Less than 40" secondary/communication separation Less than 40" neutral/communication separation Less than 40" span guy/communication separation Less than 40" riser/communication separation Less than 4" mid-span vertical spacing between attachments Less than 30" transformer/attachment separation Less than 12" street light drip loop/attachment separation Less than 12" between attachments on pole Less than 30" mid-span power/attachment separation Less than 30" mid-span power/attachment separation Less than 30" mid-span power/attachment separation Less than 30" clearance over DOT roadway Less than 3' clearance over structure Less than 15'5" clearance over roadway |

Proprietary and Confidential

| | | Less than 9.5' clearance to pedestrian accessible area |
|--|---|--|
| | | Less than 4' anchor separation between down guys |
| | | Attacher's vertical ground not bonded to Gulf Power ground |
| | Number of main line cable attachments | Integer |
| | Height of main line cable attachment(s) (crowded only) | Integer(s) |
| | Mid-span height of main line cable(s) (crowded only) | Integer(s) |
| | Number of service drop attachments | Integer |
| | Height of service drop attachment(s) (crowded only) | Integer(s) |
| | Mid-span height of service drop(s) (crowded only) | Integer(s) |
| | Number of amplifier attachments | Integer |
| | Height of amplifier attachment(s) (crowded only) | Integer(s) |
| | Number of riser attachments | Integer |
| | Height of riser attachment(s) (crowded only) | Integer(s) |
| | Number of pedestal attachments | Integer |
| | Number of termination box attachments | Integer |
| | Height of termination box attachment(s) (crowded only) | Integer(s) |
| ······································ | Number of crossarm attachments | Integer |
| | Height of crossarm attachment(s) (crowded only) | Integer(s) |
| | Number of extension arm attachments | Integer |
| | Height of extension arm attachment(s) (crowded only) | Integer(s) |
| | Over-lashing | Y/N |
| | Number of overlashed cables | Integer |

Usmose Utilities Services

Proprietary and Confidential

Appendix B

ESRI Shapefile Deliverable Format

| OBJECT | ATTRIBUTE | COMMENTS |
|---------------------------------------|---|----------------------------------|
| Pole | ID number | |
| | GPS Location | |
| | Date/time of inspection | |
| | Pole class | |
| | Pole height | |
| | Pole type | |
| | County name | Derived from Gulf Power landbase |
| | Crowded pole | Y/N |
| | Measurements (crowded poles only): From ground to secondary (pole) From ground to neutral (pole) From ground to span guy (pole) From ground to secondary (mid-span) | |
| Attachment | From ground to neutral (mid-span) From ground to transformer can From ground to street light drip loop From ground to top of riser Pole ID number | |
| Attachment | Owner | ····· |
| | Туре | |
| | Less than 52" power/communication separation | Y/N |
| | Less than 22" power/communication separation | Y/N Y/N |
| · · · · · · · · · · · · · · · · · · · | Less than 24 succer light drip toop/attachment separation | Y/N |
| | Less than 42° transformer/attachment separation | Y/N |
| | Less than 40° secondary/communication separation | Y/N |
| | Less than 40° heutral/communication separation | Y/N |
| | Less than 40° span guy/communication separation | Y/N |
| | - | Y/N |
| | Less than 12" street light drip loop/attachment separation Less than 30" transformer/attachment separation | Y/N |
| | Less than 12" between attachments | Y/N |
| | | |
| | Less than 4" mid-span vertical spacing between attachments | Y/N V/N |
| | Less than 30" mid-span power/attachment separation | Y/N NAL |
| | Less than 18' clearance over DOT roadway | Y/N |
| | Less than 15'5" clearance over roadway | Y/N |
| | Less than 9.5' clearance to pedestrian accessible area | Y/N |
| | Less than 3' clearance over structure | Y/N |
| | Less than 4' anchor separation between down guys | Y/N |

.

.

Proprietary and Confidential

| | Attacher's vertical ground not bonded to Gulf Power ground | Y/N |
|---------|--|---|
| | Number of main line cable attachments | |
| | Height of main line cable attachment(s) | (crowded only) |
| | Mid-span height of main line cable(s) | (crowded only) |
| | Number of service drop attachments | |
| | Height of service drop attachment(s) | (crowded only) |
| | Mid-span height of service drop(s) | (crowded only) |
| | Number of amplifier attachments | |
| | Height of amplifier attachment(s) | (crowded only) |
| <u></u> | Number of riser attachments | ······································ |
| | Height of riser attachment(s) | (crowded only) |
| | Number of pedestal attachments | |
| | Number of termination box attachments | |
| | Height of termination box attachment(s) | (crowded only) |
| | Number of crossarm attachments | |
| | Height of crossarm attachment(s) | (crowded only) |
| | Number of extension arm attachments |] ··· ··· ··· ··· ··· ··· ··· ··· ··· · |
| <u></u> | Height of extension arm attachment(s) | (crowded only) |
| | Over-lashing | Y/N |
| | Number of overlashed cables | |

Usmose Utilities Services

•

4

Proprietary and Confidential

Appendix C

Access Deliverable Format

| TABLE NAME | COLUMN NAME | COMMENTS |
|------------|---|----------|
| Pole | ID Number | |
| | GPS Location | |
| | Date/time of Inspection | |
| | Pole class | |
| | Pole height | |
| | Pole type | |
| | Measurements: From ground to secondary (pole) From ground to neutral (pole) From ground to span guy (pole) From ground to secondary (mid-span) From ground to neutral (mid-span) From ground to transformer can From ground to street light drip loop From ground to top of riser Image1 file name | |
| | Image2 file name | |
| Attachment | Pole ID number | - |
| | Owner | |
| | Туре | |
| | Less than 52" power/communication separation | Y/N |
| | Less than 24" street light drip loop/attachment separation | Y/N |
| | Less than 42" transformer/attachment separation | Y/N |
| | Less than 40" secondary/communication separation | Y/N |
| | Less than 40" neutral/communication separation | Y/N |
| | Less than 40" span guy/communication separation | Y/N |
| | Less than 40" riser/communication separation | Y/N |
| | Less than 12" street light drip loop/attachment separation | Y/N |
| | Less than 30" transformer/attachment separation | Y/N |
| | Less than 12" between attachments | Y/N |
| | Less than 4" mid-span vertical spacing between attachments | Y/N |
| | Less than 30" mid-span power/attachment separation | Y/N |
| | Less than 18' clearance over DOT roadway | Y/N |
| | Less than 15'5" clearance over roadway | Y/N |
| | Less than 9.5' clearance to pedestrian accessible area | Y/N |
| | Less than 3' clearance over structure | Y/N |
| | Less than 4' anchor separation between down guys | Y/N |

.

Proprietary and Confidential

| Attacher's ve | rtical ground not bonded to Gulf Power ground | Y/N |
|---------------|---|--------------|
| Number of m | ain line cable attachments | |
| Height of ma | in line cable attachment(s) | (if present) |
| Mid-span hei | ght of main line cable(s) | (if present) |
| Number of se | ervice drop attachments | |
| Height of ser | vice drop attachment(s) | (if present) |
| Mid-span hei | ght of service drop(s) | (if present) |
| Number of a | mplifier attachments | |
| Height of am | plifier attachment(s) | (if present) |
| Number of ri | ser attachments | |
| Height of ris | er attachment(s) | (if present) |
| Number of p | edestal attachments | |
| Number of te | ermination box attachments | |
| Height of ter | mination box attachment(s) | (if present) |
| Number of c | prossarm attachments | |
| Height of cro | ossarm attachment(s) | (if present) |
| Number of e | extension arm attachments | |
| Height of ex | tension arm attachment(s) | (if present) |
| Over-lashing | g | |
| Number of c | overlashed cables | |
| | | |