

Susan D. Ritenour
Secretary and Treasurer
and Regulatory Manager

One Energy Place
Pensacola, Florida 32520-0781

Tel 850.444.6231
Fax 850.444.6026
SDRITENO@southernco.com



March 31, 2005

Ms. Blanca S. Bayo, Director
Division of the Commission Clerk and Administrative Services
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee FL 32399-0870

Dear Ms. Bayo:

Enclosed for official filing in Docket No. 050001-EI are an original and ten copies of the following:

1. Prepared direct testimony and exhibit of L. S. Noack concerning the Generating Performance Incentive Factor Results for 2004.

Sincerely,

A handwritten signature in cursive script that reads "Susan D. Ritenour". The signature is written in black ink on a light-colored background.

db

Enclosures

cc: Beggs and Lane
Jeffrey A. Stone, Esquire

DOCUMENT NUMBER-DATE

03207 APR -1 '05

FPSC-COMMISSION

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

IN RE: Fuel and Purchased Power Cost)
Recovery Clause with Generating)
Performance Incentive Factor)

Docket No. 050001-EI

Certificate of Service

I HEREBY CERTIFY that a true copy of the foregoing was furnished by hand delivery or the U. S. Mail this 31st day of March 2005 on the following:

Robert Vandiver, Esquire
Patricia Ann Christensen, Esquire
Office of Public Counsel
111 W. Madison St., Suite 812
Tallahassee FL 32399-1400

James McGee, Esquire
Progress Energy Service Co., LLC
P. O. Box 14042
St. Petersburg FL 33733-4042

John T. Butler, Esquire
Steel, Hector & Davis LLP
200 S. Biscayne Blvd, Ste 4000
Miami FL 33131-2398

Norman H. Horton, Jr., Esquire
Messer, Caparello & Self, P.A.
P. O. Box 1876
Tallahassee FL 32302-1876

Jon C. Moyle, Jr., Esquire
The Perkins House
118 N. Gadsden Street
Tallahassee, FL 32301

Gary V. Perko, Esquire
Hopping Green & Sams, P.A.
P.O. Box 6526
Tallahassee, FL 32314


Timothy J. Perry, Esq.
McWhirter Reeves
117 S. Gadsden Street
Tallahassee FL 32301

Lee L. Willis, Esquire
James D. Beasley, Esquire
Ausley & McMullen
P. O. Box 391
Tallahassee FL 32302

John W. McWhirter, Jr., Esq.
McWhirter Reeves
400 N Tampa St Suite 2450
Tampa FL 33602

Adrienne Vining, Esquire
FL Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee FL 32399-0863

Robert Scheffel Wright, Esquire
John Thomas LaVia, III, Esquire
310 West College Avenue
Tallahassee, FL 32301



JEFFREY A. STONE
Florida Bar No. 325953
RUSSELL A. BADDERS
Florida Bar No. 0007455
STEVEN R. GRIFFIN
Florida Bar No. 0627569
BEGGS & LANE
P. O. Box 12950
Pensacola FL 32591-2950
(850) 432-2451
Attorneys for Gulf Power Company

GULF POWER COMPANY
TESTIMONY AND EXHIBITS OF
L. S. NOACK

GENERATING PERFORMANCE INCENTIVE FACTOR

RESULTS FOR

JANUARY 2004 - DECEMBER 2004

Before

THE FLORIDA PUBLIC SERVICE COMMISSION

DOCKET NO. 050001-EI



1 GULF POWER COMPANY
2 Before the Florida Public Service Commission
3 Direct Testimony and Exhibit of
4 L. S. Noack
5 Docket No. 050001-EI
6 Date of Filing April 1, 2005

7 Q. Please state your name, address, and occupation.

8 A. My name is Lonzelle S. Noack. My business address is
9 One Energy Place, Pensacola, Florida 32520-0335. My
10 current job position is Power Generation Specialist,
11 Senior for Gulf Power Company.

12 Q. Please describe your educational and business
13 background.

14 A. I received my Bachelor of Science degree in
15 Environmental Engineering from the University of
16 Florida in 1995 and received my Master of Business
17 Administration degree from the University of West
18 Florida in 2000. I joined Gulf Power in 1995 as an
19 Environmental Engineer and served in that role with
20 increasing levels of responsibility for over six years.
21 Major responsibilities included coordination of federal
22 and state air-related compliance testing for all Gulf
23 Power generating units, management of the Continuous
24 Emission Monitoring (CEM) System program at each of the
25 Company's generating facilities, and coordination of

1 the Company's air compliance reporting to state and
2 federal regulatory agencies. I was also responsible
3 for serving as Gulf's Environmental Subject Matter
4 Expert on Company and system-wide compliance teams. As
5 previously mentioned in my testimony, my current job
6 position is Power Generation Specialist, Senior at Gulf
7 Power Company. In this position, I am responsible for
8 preparing all GPIF filings as well as other generating
9 plant reliability and heat rate performance reporting.
10

11 Q. What is the purpose of your testimony in this
12 proceeding?

13 A. The purpose of my testimony is to present GPIF results
14 for Gulf Power Company for the period of January 1,
15 2004, through December 31, 2004.
16

17 Q. Have you prepared an exhibit that contains information
18 to which you will refer in your testimony?

19 A. Yes. I have prepared an exhibit consisting of five
20 schedules.
21

22 Q. Was this exhibit prepared by you or under your
23 direction and supervision?

24 A. Yes. It was.
25

1 Counsel: We ask that Ms. Noack's exhibit,
2 consisting of five schedules, be marked for
3 identification as Exhibit__ (LSN-1).
4

5 Q. Are there any issues related to the GPIF targets for
6 this period that were filed with the Commission on
7 September 12, 2003, in Docket No. 030001-EI that may
8 affect the validity of those targets for this period?

9 A. Yes. Plant Daniel Units 1 and 2, which had been
10 burning a high-Btu bituminous coal for several years,
11 switched to a blend of approximately 60% high-Btu
12 bituminous coal and 40% low-Btu sub-bituminous coal in
13 March of 2004. This change in fuel mix was due to
14 economic conditions and results in lower costs to
15 customers than if the units continued burning the high-
16 Btu coal only. However, this change in fuel also
17 results in an increase in the heat rates of these units
18 above the targets set for this period. This increase
19 is not an indication of a change in unit efficiency but
20 is more a reflection of the change in heat content and
21 properties of the new fuel mix being burned.

22 Because the heat rate targets for this period were
23 set according to the GPIF implementation manual, which
24 required the targets to be set based on the historical
25 high-Btu coal burn for Daniel Units 1 and 2, the heat

1 rate targets for this period are only valid for these
2 units when burning high-Btu coal. Consequently, there
3 is no reasonable way to determine what portion of the
4 actual unit heat rates are due to unit performance and
5 what portion is due to the lower-Btu fuel mix. The
6 GPIF process was not established to reward or penalize
7 units for fuel switching; therefore, the heat rate
8 targets set for this period for Daniel Units 1 and 2
9 are not applicable during the months when the units
10 burned the low-Btu fuel mix.

11
12 Q. Please describe how this change in fuel mix is being
13 addressed in this filing.

14 A. In accordance with past Commission Orders, including
15 Commission Order PSC-04-1276-FOF-EI, Plant Daniel Units
16 1 and 2 are excluded from the GPIF heat rate
17 calculations for the months when the low-Btu fuel mix
18 was burned. This was accomplished by setting the
19 units' ANOHRs (Average Net Operating Heat Rates) equal
20 to their respective target ANOHRs at Actual Conditions
21 as indicated on lines 2 and 4 of pages 16 and 17 of
22 Schedule 3 for each month beginning with March through
23 December 2004. This results in producing neither a
24 reward nor a penalty for ANOHR for these two units for
25 these months when the units were burning the low-Btu

1 fuel mix.

2 It should be noted that, if adequate data is
3 available, the Btu/lb independent variable that was
4 stipulated and approved in Commission Order PSC-99-
5 2512-FOF-EI will be added to the target heat rate
6 equations for Daniel Units 1 and 2 beginning with the
7 2006 GPIF Target Filing that will be submitted in the
8 fall of 2005. This process should account for the
9 change in fuel mix for these units at that time.

10

11 Q. Is there any other information that has been supplied
12 to the Commission pertaining to this GPIF period that
13 requires amendment?

14 A. Yes. Some corrections have been made to the actual
15 unit performance data, which was submitted monthly to
16 the Commission during this time period. These
17 corrections are based on discoveries made during the
18 final data review to ensure the accuracy of the
19 information reported in this filing. The actual unit
20 performance data tables on pages 16 through 31 of
21 Schedule 5 of Exhibit_(LSN-1) incorporate these
22 changes. The data contained in these tables is the
23 data upon which the GPIF calculations were made.

24

25 Q. Would you now review the Company's equivalent

1 availability results for the period?

2 A. Actual equivalent availability and adjusted actual
3 equivalent availability figures for each of the
4 Company's GPIF units are shown on page 15 of
5 Schedule 5. Pages 3 through 10 of Schedule 2 contain
6 the calculations for the adjusted actual equivalent
7 availabilities.

8 A calculation of GPIF availability points based on
9 these availabilities and the targets established by
10 Commission Order PSC-03-1461-FOF-EI is on page 11 of
11 Schedule 2. The results are: Crist 4, +10.00 points;
12 Crist 5, +10.00 points; Crist 6, -10.00 points; Crist
13 7, 0.00 points; Smith 1, +10.00 points; Smith 2, +10.00
14 points; Daniel 1, +7.50 points; and Daniel 2, +10.00
15 points.

16
17 Q. What were the heat rate results for the period?

18 A. The detailed calculations of the actual average net
19 operating heat rates for the Company's GPIF units are
20 on pages 2 through 9 of Schedule 3.

21 As was done for the prior GPIF periods, and as
22 indicated on pages 10 through 17 of Schedule 3, the
23 target equations were used to adjust actual results to
24 the target bases. These equations, submitted in
25 September 2003, are shown on page 20 of Schedule 3.

1 As calculated on page 21 of Schedule 3, the
2 adjusted actual average net operating heat rates
3 correspond to the following GPIF unit heat rate points:
4 -0.72 for Crist 4, -3.79 for Crist 5, +9.75 for Crist
5 6, 0.00 for Crist 7, 0.00 for Smith 1, -6.99 for Smith
6 2, -0.13 for Daniel 1, and 0.00 for Daniel 2.

7
8 Q. What number of Company points was achieved during the
9 period, and what reward or penalty is indicated by
10 these points according to the GPIF procedure?

11 A. Using the unit equivalent availability and heat rate
12 points previously mentioned, along with the appropriate
13 weighting factors, the number of Company points
14 achieved is +1.91, as indicated on page 2 of Schedule
15 4. This calculated to a reward in the amount of
16 \$441,988.

17
18 Q. Would you please summarize your testimony?

19 A. Yes. In view of the adjusted actual equivalent
20 availabilities, as shown on page 11 of Schedule 2, and
21 the adjusted actual average net operating heat rates
22 achieved, as shown on page 21 of Schedule 3, evidencing
23 the Company's performance for the period, Gulf
24 calculates a reward in the amount of \$441,988 as
25 provided for by the GPIF plan.

1

2 Q. Does this conclude your testimony?

3 A. Yes.

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

Florida Public Service Commission
Docket No. 050001-EI
Gulf Power Company
Witness: L. S. Noack
Exhibit No. _____ (LSN-1)

EXHIBIT TO THE TESTIMONY OF

L. S. NOACK

IN FPSC DOCKET 050001-EI

I. CORRECTIONS TO REPORTED DATA FOR THE JANUARY 2004 - DECEMBER 2004 PERIOD

Additions and Corrections to Outages Previously Reported
for the January 2004 - December 2004 Period

| <u>Date</u> | <u>Unit</u> | <u>Change</u> | <u>Outage Type</u> | <u>Hours</u> | <u>MW</u> | <u>Description</u> |
|-------------|-------------|---------------|------------------------|--------------|-----------|-----------------------|
| 04/07/04 | Smith 1 | Event Type | FMO | 94.0 | 162.0 | Change to PO |
| 04/26/04 | Daniel 1 | Event Type | PO | 74.8 | 514.0 | Change to FMO |
| 05/04/04 | Daniel 1 | MW Affected | PFO | 3.3 | 132.6 | Change 132.6 to 132.7 |

II. CALCULATIONS OF EQUIVALENT AVAILABILITY POINTS

Comparison of Forecast and Actual Planned Outages
for January 2004 - December 2004

| <u>Unit</u> | <u>Note</u> | <u>Forecast Planned Outage Schedule</u> | <u>Forecast Hours*</u> | <u>Actual Planned Outage Schedule</u> | <u>Actual Hours*</u> |
|-------------|-------------|---|----------------------------|---|--------------------------|
| Crist 6 | 1 | 01/31/04 - 02/22/04 | 552.0 | 01/01/04 - 01/24/04 | 571.2 |
| Crist 7 | 2 | 02/28/04 - 05/16/04 | 1896.0 | 02/01/04 - 04/22/04 | 1925.6 |
| Smith 1 | 3 | 02/21/04 - 03/21/04 | 720.0 | 04/07/04 - 04/11/04 | 94.0 |
| Smith 1 | 4 | - | - | 11/05/04 - 11/20/04 | 353.1 |
| Smith 2 | 5 | 03/27/04 - 04/25/04 | 720.0 | 04/02/04 - 04/17/04 | 340.7 |
| Daniel 1 | 6 | 01/17/04 - 01/30/04 | 336.0 | 03/05/04 - 03/19/04 | 317.2 |
| Daniel 1 | 7 | 10/09/04 - 12/24/04 | 1848.0 | 10/02/04 - 11/21/04 | 1176.8 |
| Daniel 2 | 8 | 01/10/04 - 02/22/04 | 1056.0 | 01/08/04 - 01/14/04 | 164.3 |

* Planned outage hours in the January 2004 - December 2004 period only.

- Notes:
1. The outage date was changed subsequent to the target filing, and it proceeded as scheduled.
 2. The outage date was changed subsequent to the target filing, and it proceeded as scheduled.
 3. The outage date was changed subsequent to the target filing.
 4. The outage date was added subsequent to the target filing
 5. The outage date was changed subsequent to the target filing, and it proceeded as scheduled with all work completed ahead of schedule.
 6. The outage date was changed subsequent to the target filing, and it proceeded as scheduled.
 7. The outage date was changed subsequent to the target filing, and it proceeded as scheduled with all work completed ahead of schedule.
 8. The outage date was changed subsequent to the target filing.

Calculation of Actual Equivalent Availability
for January 2004 - December 2004
Based on Target Planned Outage Hours
Crist 4

Results of Operations

| | Jan / Jul | Feb / Aug | Mar / Sep | Apr / Oct | May / Nov | Jun / Dec | Total |
|------|----------------|----------------|----------------|----------------|----------------|----------------|--------|
| FOH | 0.0 0.0 | 0.0 0.0 | 0.0 63.8 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 63.8 |
| EFOH | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 |
| MOH | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 27.1 40.7 | 67.8 |
| EMOH | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 |
| PH | 744.0 744.0 | 696.0 744.0 | 744.0 720.0 | 719.0 745.0 | 744.0 720.0 | 720.0 744.0 | 8784.0 |
| POH | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 |
| RSH | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 |

$$1. \text{ EUOR} = \frac{(\text{FOH} + \text{EFOH} + \text{MOH} + \text{EMOH})}{(\text{PH} - \text{POH} - \text{RSH})} = \frac{(63.8 + 0.0 + 67.8 + 0.0)}{(8784.0 - 0.0 - 0.0)}$$

$$\text{EUOR} = 0.0150$$

$$2. \text{ EA} = \left[1 - \frac{(\text{POH}^* + \text{EUOR} (\text{PH} - \text{POH}^* - \text{RSH}^*))}{\text{PH}} \right] \times 100$$

$$\text{Target POH}^* = 0.0$$

$$\text{Target RSH}^* = 0.0$$

$$\text{EA} = \left[1 - \frac{(0.0 + 0.0150 (8784.0 - 0.0 - 0.0))}{8784.0} \right] \times 100 = 98.5 \%$$

Note: Please refer to page 12 of this schedule for an explanation of symbols.

Calculation of Actual Equivalent Availability
for January 2004 - December 2004
Based on Target Planned Outage Hours
Crist 5

Results of Operations

| | Jan / Jul | Feb / Aug | Mar / Sep | Apr / Oct | May / Nov | Jun / Dec | Total |
|------|----------------|----------------|----------------|----------------|----------------|----------------|--------|
| FOH | 0.0 0.0 | 0.0 0.0 | 0.0 55.2 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 55.2 |
| EFOH | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 1.4 | 1.4 |
| MOH | 0.0 0.0 | 26.1 27.6 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 53.7 |
| EMOH | 0.0 0.0 | 5.4 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 5.4 |
| PH | 744.0 744.0 | 696.0 744.0 | 744.0 720.0 | 719.0 745.0 | 744.0 720.0 | 720.0 744.0 | 8784.0 |
| POH | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 |
| RSH | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 |

$$1. \text{ EUOR} = \frac{(\text{FOH} + \text{EFOH} + \text{MOH} + \text{EMOH})}{(\text{PH} - \text{POH} - \text{RSH})} = \frac{(55.2 + 1.4 + 53.7 + 5.4)}{(8784.0 - 0.0 - 0.0)}$$

$$\text{EUOR} = 0.0132$$

$$2. \text{ EA} = \left[1 - \frac{(\text{POH}^* + \text{EUOR} (\text{PH} - \text{POH}^* - \text{RSH}^*))}{\text{PH}} \right] \times 100$$

$$\text{Target POH}^* = 0.0$$

$$\text{Target RSH}^* = 0.0$$

$$\text{EA} = \left[1 - \frac{(0.0 + 0.0132 (8784.0 - 0.0 - 0.0))}{8784.0} \right] \times 100 = 98.7 \%$$

Note: Please refer to page 12 of this schedule for an explanation of symbols.

Calculation of Actual Equivalent Availability
for January 2004 - December 2004
Based on Target Planned Outage Hours
Crist 6

| Results of Operations | | | | | | | |
|-----------------------|----------------|----------------|----------------|----------------|----------------|----------------|--------|
| | Jan / Jul | Feb / Aug | Mar / Sep | Apr / Oct | May / Nov | Jun / Dec | Total |
| FOH | 167.6 47.8 | 4.8 8.6 | 18.2 52.4 | 0.0 73.5 | 30.8 32.2 | 68.7 0.0 | 504.6 |
| EFOH | 0.0 0.4 | 0.0 0.0 | 0.0 0.0 | 0.0 2.5 | 0.0 25.9 | 0.0 0.0 | 28.8 |
| MOH | 0.0 0.0 | 24.0 0.0 | 0.0 99.9 | 547.8 0.0 | 0.0 0.0 | 0.0 318.3 | 990.0 |
| EMOH | 0.0 8.4 | 0.0 8.5 | 0.0 57.6 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 74.5 |
| PH | 744.0 744.0 | 696.0 744.0 | 744.0 720.0 | 719.0 745.0 | 744.0 720.0 | 720.0 744.0 | 8784.0 |
| POH | 571.2 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 571.2 |
| RSH | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 |

$$1. \text{ EUOR} = \frac{(\text{FOH} + \text{EFOH} + \text{MOH} + \text{EMOH})}{(\text{PH} - \text{POH} - \text{RSH})} = \frac{(504.6 + 28.8 + 990.0 + 74.5)}{(8784.0 - 571.2 - 0.0)}$$

$$\text{EUOR} = 0.1946$$

$$2. \text{ EA} = \left[1 - \frac{(\text{POH}^* + \text{EUOR} (\text{PH} - \text{POH}^* - \text{RSH}^*))}{\text{PH}} \right] \times 100$$

$$\text{Target POH}^* = 552.0$$

$$\text{Target RSH}^* = 0.0$$

$$\text{EA} = \left[1 - \frac{(552.0 + 0.1946 (8784.0 - 552.0 - 0.0))}{8784.0} \right] \times 100 = 75.5 \%$$

Note: Please refer to page 12 of this schedule for an explanation of symbols.

Calculation of Actual Equivalent Availability
for January 2004 - December 2004
Based on Target Planned Outage Hours
Crist 7

Results of Operations

| | Jan / Jul | Feb / Aug | Mar / Sep | Apr / Oct | May / Nov | Jun / Dec | Total |
|------|----------------|----------------|----------------|----------------|----------------|----------------|--------|
| FOH | 0.0 4.4 | 0.0 6.7 | 0.0 52.4 | 129.8 0.0 | 0.0 0.0 | 0.0 0.0 | 193.3 |
| EFOH | 0.0 0.8 | 0.0 74.9 | 0.0 0.0 | 1.9 0.7 | 0.3 0.3 | 6.0 0.0 | 84.9 |
| MOH | 0.0 57.0 | 0.0 22.0 | 0.0 189.3 | 0.0 0.0 | 46.3 25.8 | 82.1 0.0 | 422.5 |
| EMOH | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 18.9 | 10.2 0.0 | 0.0 0.0 | 29.1 |
| PH | 744.0 744.0 | 696.0 744.0 | 744.0 720.0 | 719.0 745.0 | 744.0 720.0 | 720.0 744.0 | 8784.0 |
| POH | 0.0 0.0 | 673.9 0.0 | 744.0 0.0 | 507.7 0.0 | 0.0 0.0 | 0.0 0.0 | 1925.6 |
| RSH | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 |

$$1. \text{ EUOR} = \frac{(\text{FOH} + \text{EFOH} + \text{MOH} + \text{EMOH})}{(\text{PH} - \text{POH} - \text{RSH})} = \frac{(193.3 + 84.9 + 422.5 + 29.1)}{(8784.0 - 1925.6 - 0.0)}$$

EUOR = 0.1064

$$2. \text{ EA} = \left[1 - \frac{(\text{POH}^* + \text{EUOR} (\text{PH} - \text{POH}^* - \text{RSH}^*))}{\text{PH}} \right] \times 100$$

Target POH* = 1896.0

Target RSH* = 0.0

$$\text{EA} = \left[1 - \frac{(1896.0 + 0.1064 (8784.0 - 1896.0 - 0.0))}{8784.0} \right] \times 100 = 70.1 \%$$

Note: Please refer to page 12 of this schedule for an explanation of symbols

Calculation of Actual Equivalent Availability
for January 2004 - December 2004
Based on Target Planned Outage Hours
Smith 1

Results of Operations

| | Jan / Jul | Feb / Aug | Mar / Sep | Apr / Oct | May / Nov | Jun / Dec | Total |
|------|----------------|----------------|----------------|----------------|----------------|----------------|--------|
| FOH | 0.0 0.0 | 0.0 0.0 | 0.0 2.2 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 2.2 |
| EFOH | 1.7 0.0 | 0.5 0.3 | 0.0 0.0 | 0.0 0.4 | 0.5 0.0 | 0.4 10.6 | 14.4 |
| MOH | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 |
| EMOH | 0.0 0.0 | 0.0 1.1 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 1.1 |
| PH | 744.0 744.0 | 696.0 744.0 | 744.0 720.0 | 719.0 745.0 | 744.0 720.0 | 720.0 744.0 | 8784.0 |
| POH | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 94.0 0.0 | 0.0 353.1 | 0.0 0.0 | 447.1 |
| RSH | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 |

$$1. \text{ EUOR} = \frac{(\text{FOH} + \text{EFOH} + \text{MOH} + \text{EMOH})}{(\text{PH} - \text{POH} - \text{RSH})} = \frac{(2.2 + 14.4 + 0.0 + 1.1)}{(8784.0 - 447.1 - 0.0)}$$

$$\text{EUOR} = 0.0021$$

$$2. \text{ EA} = \left[1 - \frac{(\text{POH}^* + \text{EUOR} (\text{PH} - \text{POH}^* - \text{RSH}^*))}{\text{PH}} \right] \times 100$$

$$\text{Target POH}^* = 720.0$$

$$\text{Target RSH}^* = 0.0$$

$$\text{EA} = \left[1 - \frac{(720.0 + 0.0021 (8784.0 - 720.0 - 0.0))}{8784.0} \right] \times 100 = 91.6 \%$$

Note: Please refer to page 12 of this schedule for an explanation of symbols.

Calculation of Actual Equivalent Availability
for January 2004 - December 2004
Based on Target Planned Outage Hours
Smith 2

Results of Operations

| | Jan / Jul | Feb / Aug | Mar / Sep | Apr / Oct | May / Nov | Jun / Dec | Total |
|------|----------------|----------------|----------------|----------------|----------------|----------------|--------|
| FOH | 0.0 0.0 | 38.0 0.0 | 24.5 0.0 | 0.0 0.0 | 0.0 29.1 | 0.0 0.0 | 91.6 |
| EFOH | 0.2 0.2 | 2.2 1.2 | 0.9 1.3 | 0.0 0.8 | 0.0 0.3 | 0.0 0.0 | 7.1 |
| MOH | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 31.3 0.0 | 0.0 0.0 | 31.3 |
| EMOH | 0.0 0.0 | 1.7 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 1.7 |
| PH | 744.0 744.0 | 696.0 744.0 | 744.0 720.0 | 719.0 745.0 | 744.0 720.0 | 720.0 744.0 | 8784.0 |
| POH | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 340.7 0.0 | 0.0 0.0 | 0.0 0.0 | 340.7 |
| RSH | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 |

$$1. \text{ EUOR} = \frac{(\text{FOH} + \text{EFOH} + \text{MOH} + \text{EMOH})}{(\text{PH} - \text{POH} - \text{RSH})} = \frac{(91.6 + 7.1 + 31.3 + 1.7)}{(8784.0 - 340.7 - 0.0)}$$

$$\text{EUOR} = 0.0156$$

$$2. \text{ EA} = \left[1 - \frac{(\text{POH}^* + \text{EUOR} (\text{PH} - \text{POH}^* - \text{RSH}^*))}{\text{PH}} \right] \times 100$$

$$\text{Target POH}^* = 720.0$$

$$\text{Target RSH}^* = 0.0$$

$$\text{EA} = \left[1 - \frac{(720.0 + 0.0156 (8784.0 - 720.0 - 0.0))}{8784.0} \right] \times 100 = 90.4 \%$$

Note: Please refer to page 12 of this schedule for an explanation of symbols.

Calculation of Actual Equivalent Availability
for January 2004 - December 2004
Based on Target Planned Outage Hours
Daniel 1

Results of Operations

| | Jan / Jul | Feb / Aug | Mar / Sep | Apr / Oct | May / Nov | Jun / Dec | Total |
|------|----------------|----------------|----------------|----------------|----------------|----------------|--------|
| FOH | 0.0 0.0 | 4.3 0.0 | 0.0 0.0 | 24.3 0.0 | 0.0 0.0 | 24.7 0.0 | 53.3 |
| EFOH | 0.4 1.2 | 0.3 33.5 | 0.8 0.5 | 5.1 0.0 | 0.9 0.0 | 0.1 1.3 | 44.1 |
| MOH | 0.0 32.1 | 0.0 0.0 | 0.0 0.0 | 74.8 0.0 | 33.6 0.0 | 66.9 106.2 | 313.6 |
| EMOH | 0.0 0.0 | 0.0 0.0 | 0.0 3.7 | 3.8 0.0 | 0.0 1.5 | 0.0 0.6 | 9.6 |
| PH | 744.0 744.0 | 696.0 744.0 | 744.0 720.0 | 719.0 745.0 | 744.0 720.0 | 720.0 744.0 | 8784.0 |
| POH | 0.0 0.0 | 0.0 0.0 | 317.2 0.0 | 0.0 720.6 | 0.0 456.2 | 0.0 0.0 | 1494.0 |
| RSH | 0.0 0.0 | 0.0 0.0 | 0.0 11.9 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 11.9 |

$$1. \text{ EUOR} = \frac{(\text{FOH} + \text{EFOH} + \text{MOH} + \text{EMOH})}{(\text{PH} - \text{POH} - \text{RSH})} = \frac{(53.3 + 44.1 + 313.6 + 9.6)}{(8784.0 - 1494.0 - 11.9)}$$

$$\text{EUOR} = 0.0578$$

$$2. \text{ EA} = \left[1 - \frac{(\text{POH}^* + \text{EUOR} (\text{PH} - \text{POH}^* - \text{RSH}^*))}{\text{PH}} \right] \times 100$$

$$\text{Target POH}^* = 2184.0$$

$$\text{Target RSH}^* = 0.0$$

$$\text{EA} = \left[1 - \frac{(2184.0 + 0.0578 (8784.0 - 2184.0 - 0.0))}{8784.0} \right] \times 100 = 70.8 \%$$

Note: Please refer to page 12 of this schedule for an explanation of symbols.

Calculation of Actual Equivalent Availability
for January 2004 - December 2004
Based on Target Planned Outage Hours
Daniel 2

Results of Operations

| | Jan / Jul | Feb / Aug | Mar / Sep | Apr / Oct | May / Nov | Jun / Dec | Total |
|------|----------------|----------------|----------------|----------------|----------------|----------------|--------|
| FOH | 25.0 0.0 | 1.4 43.3 | 0.0 0.0 | 0.0 24.8 | 0.0 0.0 | 0.0 0.0 | 94.5 |
| EFOH | 1.4 3.3 | 1.5 3.2 | 0.0 1.2 | 1.3 33.3 | 0.3 6.4 | 0.2 1.3 | 53.4 |
| MOH | 28.8 0.0 | 0.0 31.5 | 42.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 102.3 |
| EMOH | 0.0 0.0 | 1.8 0.0 | 0.3 0.0 | 0.0 2.6 | 2.0 3.0 | 0.0 0.1 | 9.8 |
| PH | 744.0 744.0 | 696.0 744.0 | 744.0 720.0 | 719.0 745.0 | 744.0 720.0 | 720.0 744.0 | 8784.0 |
| POH | 164.3 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 164.3 |
| RSH | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 |

$$1. \text{ EUOR} = \frac{(\text{FOH} + \text{EFOH} + \text{MOH} + \text{EMOH})}{(\text{PH} - \text{POH} - \text{RSH})} = \frac{(94.5 + 53.4 + 102.3 + 9.8)}{(8784.0 - 164.3 - 0.0)}$$

$$\text{EUOR} = 0.0302$$

$$2. \text{ EA} = \left[1 - \frac{(\text{POH}^* + \text{EUOR} (\text{PH} - \text{POH}^* - \text{RSH}^*))}{\text{PH}} \right] \times 100$$

$$\text{Target POH}^* = 1056.0$$

$$\text{Target RSH}^* = 0.0$$

$$\text{EA} = \left[1 - \frac{(1056.0 + 0.0302 (8784.0 - 1056.0 - 0.0))}{8784.0} \right] \times 100 = 85.3 \%$$

Note: Please refer to page 12 of this schedule for an explanation of symbols

Calculation of Equivalent Availability Points
for January 2004 - December 2004

| (1) Unit | (2) Equivalent Availability Target* | (3) Actual Equivalent Availability Adjusted to Target Planned Outage Basis** | (4) Minimum or Maximum Attainable Equivalent Availability* | (5) Availability Points*** |
|-------------|--|--|---|----------------------------------|
| Crist 4 | 97.9 | 98.5 | 98.5 | 10.00 |
| Crist 5 | 96.8 | 98.7 | 97.7 | 10.00 |
| Crist 6 | 86.7 | 75.5 | 83.6 | -10.00 |
| Crist 7 | 70.1 | 70.1 | 66.3 | 0.00 |
| Smith 1 | 90.1 | 91.6 | 90.6 | 10.00 |
| Smith 2 | 82.8 | 90.4 | 85.5 | 10.00 |
| Daniel 1 | 69.6 | 70.8 | 71.2 | 7.50 |
| Daniel 2 | 81.1 | 85.3 | 83.2 | 10.00 |

* As appropriate from page 5, Schedule 3 of Exhibit to L. S. Noack's September 12, 2003 GPIF testimony in Docket 030001-EI.

** Refer to pages 3 through 10 of this schedule for calculations.

*** If (3) > (2)

$$\text{Availability Points} = \frac{(3) - (2)}{(4) - (2)} \times 10$$

If (3) < (2)

$$\text{Availability Points} = \frac{(3) - (2)}{(4) - (2)} \times -10$$

Summary of Equivalent Availability Symbols

EA - Equivalent Availability
POH - Planned Outage Hours
EUOR - Equivalent Unplanned Outage Rate
PH - Period Hours
FOH - Forced Outage Hours
EFOH - Equivalent Forced Outage Hours
MOH - Maintenance Outage Hours
EMOH - Equivalent Maintenance Outage Hours
RSH - Reserve Shutdown Hours

III. CALCULATION OF GPIF UNIT HEAT RATE POINTS

Calculation of Average Net Operating Heat Rate Points
for January 2004 - December 2004

Crist 4

| | Jan / Jul | Feb / Aug | Mar / Sep | Apr / Oct | May / Nov | Jun / Dec | Total |
|---------------------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|-----------|
| Pounds Coal (000's) | 44320.5 45913.2 | 44201.1 46331.9 | 47879.4 38361.4 | 45107.0 46640.0 | 42729.1 45836.9 | 41866.3 41699.2 | 530886.0 |
| BTU/Lb* | 11728.6 11539.4 | 11643.9 11634.8 | 11873.3 11552.1 | 11950.9 11707.9 | 11903.7 11491.9 | 11470.4 11498.2 | 11669.6 |
| Coal, MMBTU | 519817.4 529810.8 | 514673.2 539062.4 | 568486.5 443154.7 | 539069.2 546056.5 | 508634.4 526753.1 | 480223.2 479465.7 | 6195207.1 |
| Oil, MMBTU | 1034.3 761.2 | 917.2 1123.1 | 401.0 1311.7 | 1186.1 1920.0 | 689.0 996.1 | 982.7 1048.9 | 12371.3 |
| Gas, MMBTU | 0.0 0.0 | 0.0 0.0 | 0.0 1068.0 | 0.0 10286.0 | 2081.0 156.0 | 655.0 82.0 | 14328.0 |
| Startup, MMBTU ** | 0.0 0.0 | 0.0 0.0 | 0.0 -400.0 | 0.0 0.0 | 0.0 0.0 | -400.0 -400.0 | -1200.0 |
| Total Fuel Consumption, MMBTU | 520851.7 530572.0 | 515590.4 540185.5 | 568887.5 445134.4 | 540255.3 558262.5 | 511404.4 527905.2 | 481460.9 480196.6 | 6220706.4 |
| Net MWH Generation*** | 49849 49709 | 49777 50779 | 55002 41712 | 51719 52657 | 48540 49209 | 45249 45870 | 590072 |
| Average Net Operating Heat Rate | 10449 10674 | 10358 10638 | 10343 10672 | 10446 10602 | 10536 10728 | 10640 10469 | 10542 |

* Weighted average of daily as-burned BTU/Lb values.
** Based on number of unit starts after unit off-line 24 hours or more.
*** Not reduced by off-line station service.

Calculation of Average Net Operating Heat Rate Points
for January 2004 - December 2004

Crist 5

| | Jan / Jul | Feb / Aug | Mar / Sep | Apr / Oct | May / Nov | Jun / Dec | Total |
|---------------------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|-----------|
| Pounds Coal (000's) | 43546.3 45467.1 | 40421.3 45008.7 | 48017.5 39241.7 | 45291.1 48855.9 | 43483.1 45266.2 | 44015.7 44026.5 | 532641.1 |
| BTU/Lb* | 11735.4 11561.3 | 11637.6 11633.1 | 11880.1 11572.3 | 11951.0 11627.9 | 11892.9 11515.9 | 11533.3 11541.0 | 11675.4 |
| Coal, MMBTU | 511033.2 525658.8 | 470406.9 523590.7 | 570452.7 454116.7 | 541273.9 568091.5 | 517140.2 521281.0 | 507646.3 508109.8 | 6218801.7 |
| Oil, MMBTU | 597.3 322.0 | 920.6 729.5 | 462.7 863.9 | 1158.0 1056.8 | 197.9 697.8 | 383.8 654.9 | 8045.2 |
| Gas, MMBTU | 29.0 0.0 | 13209.0 408.0 | 0.0 1037.0 | 0.0 4012.0 | 0.0 148.0 | 0.0 4557.0 | 23400.0 |
| Startup, MMBTU ** | 0.0 0.0 | -400.0 -400.0 | 0.0 -400.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | -1200.0 |
| Total Fuel Consumption, MMBTU | 511659.5 525980.8 | 484136.5 524328.2 | 570915.4 455617.6 | 542431.9 573160.3 | 517338.1 522126.8 | 508030.1 513321.7 | 6249046.9 |
| Net MWH Generation*** | 49022 49266 | 46011 49679 | 55051 42018 | 51691 52737 | 48611 48318 | 47805 47695 | 587904 |
| Average Net Operating Heat Rate | 10437 10676 | 10522 10554 | 10371 10843 | 10494 10868 | 10642 10806 | 10627 10763 | 10629 |

* Weighted average of daily as-burned BTU/Lb values.

** Based on number of unit starts after unit off-line 24 hours or more.

*** Not reduced by off-line station service.

Calculation of Average Net Operating Heat Rate Points
for January 2004 - December 2004

Crist 6

| | Jan / Jul | Feb / Aug | Mar / Sep | Apr / Oct | May / Nov | Jun / Dec | Total |
|---------------------------------|----------------------|------------------------|------------------------|-----------------------|------------------------|------------------------|------------|
| Pounds Coal (000's) | 4533.4 154521.7 | 151210.0 174724.9 | 164904.7 114277.7 | 36076.0 164307.2 | 154490.0 159637.4 | 144766.2 104634.3 | 1528083.5 |
| BTU/Lb* | 11992.7 11570.9 | 11720.4 11679.9 | 11907.3 11630.4 | 11958.1 11705.9 | 11714.6 11481.1 | 11408.2 11477.5 | 11647.2 |
| Coal, MMBTU | 54367.7 1787955.1 | 1772241.7 2040769.4 | 1963569.7 1329095.4 | 431400.4 1923363.7 | 1809788.6 1832813.0 | 1651521.8 1200940.2 | 17797826.7 |
| Oil, MMBTU | 222.3 113.5 | 211.7 283.9 | 433.4 78.7 | 82.8 511.7 | 138.4 181.4 | 281.1 109.6 | 2648.5 |
| Gas, MMBTU | 6290.0 2070.0 | 3186.0 1676.0 | 3173.0 2283.0 | 4720.0 2025.0 | 0.0 2388.0 | 4648.0 4697.0 | 37156.0 |
| Startup, MMBTU ** | -4040.0 -4040.0 | 0.0 0.0 | 0.0 -4040.0 | -4040.0 -4040.0 | -4040.0 -8080.0 | -8080.0 -4040.0 | -44440.0 |
| Total Fuel Consumption, MMBTU | 56840.0 1786098.6 | 1775639.4 2042729.3 | 1967176.1 1327417.1 | 432163.2 1921860.4 | 1805887.0 1827302.4 | 1648370.9 1201706.8 | 17793191.2 |
| Net MWH Generation*** | 336 171620 | 185634 194961 | 200102 126804 | 42588 189204 | 169810 179756 | 161977 116738 | 1739530 |
| Average Net Operating Heat Rate | 169167 10407 | 9565 10478 | 9831 10468 | 10148 10158 | 10635 10165 | 10177 10294 | 10229 |

* Weighted average of daily as-burned BTU/Lb values.
** Based on number of unit starts after unit off-line 24 hours or more.
*** Not reduced by off-line station service.

Calculation of Average Net Operating Heat Rate Points
for January 2004 - December 2004

Crist 7

| | Jan / Jul | Feb / Aug | Mar / Sep | Apr / Oct | May / Nov | Jun / Dec | Total |
|---------------------------------|------------------------|----------------------|------------------|-----------------------|------------------------|------------------------|------------|
| Pounds Coal (000's) | 273438.4 243112.7 | 8278.9 248782.4 | 0.0 166035.8 | 31099.2 285400.3 | 236437.2 272604.5 | 217360.3 294106.7 | 2276656.4 |
| BTU/Lb* | 11733.9 11583.5 | 11797.0 11642.7 | 0.0 11690.0 | 11989.8 11773.0 | 11883.4 11466.8 | 11524.0 11448.1 | 11639.9 |
| Coal, MMBTU | 3208498.8 2816096.0 | 97666.2 2896498.8 | 0.0 1940958.5 | 372873.2 3360017.7 | 2809677.8 3125901.3 | 2504860.1 3366962.9 | 26500011.3 |
| Oil, MMBTU | 602.6 1216.2 | 83.5 1150.9 | 0.0 633.1 | 3525.4 275.4 | 836.4 291.0 | 1267.8 204.4 | 10086.7 |
| Gas, MMBTU | 0.0 4407.0 | 37.0 3038.0 | 0.0 6048.0 | 11441.0 0.0 | 0.0 1354.0 | 3276.0 0.0 | 29601.0 |
| Startup, MMBTU ** | 0.0 -4512.0 | 0.0 0.0 | 0.0 -2256.0 | -4512.0 0.0 | -2256.0 -2256.0 | -4512.0 0.0 | -20304.0 |
| Total Fuel Consumption, MMBTU | 3209101.4 2817207.2 | 97786.7 2900687.7 | 0.0 1945383.6 | 383327.6 3360293.1 | 2808258.2 3125290.3 | 2504891.9 3367167.3 | 26519395.0 |
| Net MWH Generation*** | 314192 271888 | 9866 275001 | 0 185784 | 35457 322899 | 268569 303761 | 242071 329080 | 2558568 |
| Average Net Operating Heat Rate | 10214 10362 | 9911 10548 | --- 10471 | 10811 10407 | 10456 10289 | 10348 10232 | 10365 |

* Weighted average of daily as-burned BTU/Lb values.

** Based on number of unit starts after unit off-line 24 hours or more.

*** Not reduced by off-line station service.

Calculation of Average Net Operating Heat Rate Points
for January 2004 - December 2004

Smith 1

| | Jan / Jul | Feb / Aug | Mar / Sep | Apr / Oct | May / Nov | Jun / Dec | Total |
|---------------------------------|------------------------|------------------------|-----------------------|-----------------------|----------------------|-----------------------|------------|
| Pounds Coal (000's) | 85999.4 83599.2 | 89325.2 89940.3 | 97794.7 79881.5 | 78482.8 94025.4 | 84664.7 45498.1 | 82631.3 95428.3 | 1007270.9 |
| BTU/Lb* | 11802.8 11974.3 | 11877.0 11924.7 | 11929.8 11861.9 | 11949.4 11924.6 | 11619.7 11849.3 | 11836.2 11818.2 | 11865.2 |
| Coal, MMBTU | 1015033.7 1001041.9 | 1060915.4 1072511.1 | 1166671.2 947546.4 | 937822.4 1121215.3 | 983778.4 539120.6 | 978040.6 1127790.7 | 11951487.7 |
| Oil, MMBTU | 168.0 192.6 | 364.0 229.1 | 239.3 855.2 | 1327.8 497.7 | 82.5 1635.4 | 216.5 435.0 | 6243.1 |
| Gas, MMBTU | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 |
| Startup, MMBTU ** | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | -964.0 0.0 | 0.0 -964.0 | 0.0 0.0 | -1928.0 |
| Total Fuel Consumption, MMBTU | 1015201.7 1001234.5 | 1061279.4 1072740.2 | 1166910.5 948401.6 | 938186.2 1121713.0 | 983860.9 539792.0 | 978257.1 1128225.7 | 11955802.8 |
| Net MWH Generation*** | 99035 98792 | 102586 106626 | 114343 92429 | 91949 112690 | 96175 52754 | 95364 109214 | 1171957 |
| Average Net Operating Heat Rate | 10251 10135 | 10345 10061 | 10205 10261 | 10203 9954 | 10230 10232 | 10258 10330 | 10202 |

* Weighted average of daily as-burned BTU/Lb values.
** Based on number of unit starts after unit off-line 24 hours or more.
*** Not reduced by off-line station service.

Calculation of Average Net Operating Heat Rate Points
for January 2004 - December 2004

Smith 2

| | Jan / Jul | Feb / Aug | Mar / Sep | Apr / Oct | May / Nov | Jun / Dec | Total |
|---------------------------------|------------------------|------------------------|------------------------|-----------------------|------------------------|------------------------|------------|
| Pounds Coal (000's) | 97556.1 96836.3 | 94961.4 106289.9 | 103558.2 93096.1 | 54798.0 113219.9 | 91210.1 104357.9 | 93379.6 112138.9 | 1161402.4 |
| BTU/Lb* | 11798.9 11930.4 | 11886.5 11876.0 | 11903.8 11727.1 | 11924.7 11861.1 | 11603.3 11831.5 | 11805.2 11809.6 | 11828.8 |
| Coal, MMBTU | 1151054.7 1155295.8 | 1128758.7 1262298.9 | 1232736.1 1091747.3 | 653449.7 1342912.6 | 1058338.2 1234710.5 | 1102364.9 1324315.6 | 13737983.0 |
| Oil, MMBTU | 239.2 168.2 | 1848.6 329.0 | 1332.0 800.9 | 1585.8 390.5 | 1300.2 1480.4 | 241.1 338.5 | 10054.4 |
| Gas, MMBTU | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 |
| Startup, MMBTU ** | 0.0 0.0 | -1190.0 0.0 | -1190.0 0.0 | -1190.0 0.0 | -1190.0 -1190.0 | 0.0 0.0 | -5950.0 |
| Total Fuel Consumption, MMBTU | 1151293.9 1155464.0 | 1129417.3 1262627.9 | 1232878.1 1092548.2 | 653845.5 1343303.1 | 1058448.4 1235000.9 | 1102606.0 1324654.1 | 13742087.4 |
| Net MWH Generation*** | 113613 111088 | 110797 120774 | 124970 104190 | 61809 129215 | 102145 117212 | 106089 125512 | 1327414 |
| Average Net Operating Heat Rate | 10133 10401 | 10194 10454 | 9865 10486 | 10578 10396 | 10362 10536 | 10393 10554 | 10353 |

* Weighted average of daily as-burned BTU/Lb values.
** Based on number of unit starts after unit off-line 24 hours or more
*** Not reduced by off-line station service.

Calculation of Average Net Operating Heat Rate Points
for January 2004 - December 2004

Daniel 1

| | Jan / Jul | Feb / Aug | Mar / Sep | Apr / Oct | May / Nov | Jun / Dec | Total |
|-------------------------------------|------------------------|------------------------|------------------------|----------------------|-----------------------|------------------------|------------|
| Pounds Coal (000's) | 321038.0 329628.0 | 291472.0 320240.0 | 176466.0 299708.0 | 263136.0 6418.0 | 285218.0 80948.0 | 272218.0 285734.0 | 2932224.0 |
| BTU/Lb* | 11651.8 10683.9 | 11668.8 10588.6 | 11648.6 10651.1 | 11344.7 10933.4 | 10974.2 11322.0 | 11071.8 10664.6 | 11071.9 |
| Coal, MMBTU | 3740670.6 3521712.6 | 3401128.5 3390893.3 | 2055581.8 3192219.9 | 2985199.0 70170.6 | 3130039.4 916493.3 | 3013943.3 3047238.8 | 32465291.1 |
| Oil, MMBTU | 0.0 3173.5 | 1404.4 2.8 | 4687.5 7360.9 | 8804.2 201.3 | 2311.2 15082.8 | 9474.8 9182.1 | 61685.5 |
| Gas, MMBTU | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 |
| Startup, MMBTU ** | 0.0 -2388.7 | 0.0 0.0 | -2388.7 0.0 | -2388.7 0.0 | -2388.7 -4777.4 | -4777.4 -4777.4 | -23887.0 |
| Total Fuel Consumption, MMBTU | 3740670.6 3522497.4 | 3402532.9 3390896.1 | 2057880.6 3199580.8 | 2991614.5 70371.9 | 3129961.9 926798.7 | 3018640.7 3051643.5 | 32503089.6 |
| Net MWH Generation*** | 363598 345675 | 336226 339849 | 203907 303265 | 289817 10767 | 298651 86661 | 290363 300905 | 3169684 |
| Average Net Operating Heat Rate**** | 10288 10195 | 10120 10194 | 9926 10037 | 9957 9926 | 9893 10178 | 9957 9919 | 10066 |

* Weighted average of daily as-burned BTU/Lb values.
** Based on number of unit starts after unit off-line 24 hours or more.
*** Not reduced by off-line station service.
**** Mar - Dec values are set equal to targets at actual conditions for Daniel 1.

Calculation of Average Net Operating Heat Rate Points
for January 2004 - December 2004

Daniel 2

| | <u>Jan / Jul</u> | <u>Feb / Aug</u> | <u>Mar / Sep</u> | <u>Apr / Oct</u> | <u>May / Nov</u> | <u>Jun / Dec</u> | <u>Total</u> |
|-------------------------------------|------------------------|------------------------|------------------------|------------------------|------------------------|------------------------|--------------|
| Pounds Coal (000's) | 198270.0 319342.0 | 280076.0 287438.0 | 287116.0 290262.0 | 303922.0 326852.0 | 283738.0 309098.0 | 294128.0 342886.0 | 3523128.0 |
| BTU/Lb* | 11661.1 11031.1 | 11667.4 10561.5 | 11570.7 10675.1 | 11189.6 10454.4 | 11291.9 11213.7 | 11264.8 10502.7 | 11058.7 |
| Coal, MMBTU | 2312046.3 3522693.5 | 3267758.7 3035776.4 | 3322133.1 3098575.9 | 3400765.6 3417041.5 | 3203941.1 3466132.2 | 3313293.1 3601228.8 | 38961386.2 |
| Oil, MMBTU | 7952.2 3867.1 | 2551.2 6857.7 | 2854.7 439.5 | 47.8 14512.8 | 24.9 1521.9 | 8.9 0.0 | 40638.7 |
| Gas, MMBTU | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 0.0 | 0.0 |
| Startup, MMBTU ** | -4777.4 0.0 | -2388.7 -4777.4 | -2388.7 0.0 | 0.0 -2388.7 | 0.0 0.0 | 0.0 0.0 | -16720.9 |
| Total Fuel Consumption, MMBTU | 2315221.1 3526560.6 | 3267921.2 3037856.7 | 3322599.1 3099015.4 | 3400813.4 3429165.6 | 3203966.0 3467654.1 | 3313302.0 3601228.8 | 38985304.0 |
| Net MWH Generation*** | 243582 346502 | 342971 313796 | 338437 310867 | 346245 334758 | 324431 343589 | 332493 359939 | 3937610 |
| Average Net Operating Heat Rate**** | 9505 9924 | 9528 9916 | 9700 10020 | 9884 9926 | 10007 9709 | 9934 9878 | 9833 |

- * Weighted average of daily as-burned BTU/Lb values.
- ** Based on number of unit starts after unit off-line 24 hours or more.
- *** Not reduced by off-line station service.
- **** Mar - Dec values are set equal to targets at actual conditions for Daniel 2

Calculation of Average Net Operating Heat Rate
for January 2004 - December 2004
Adjusted to Target Basis Using Heat Rate
Equations Filed September 12, 2003

Crist 4

| | Jan/Jul | Feb/Aug | Mar/Sep | Apr/Oct | May/Nov | Jun/Dec | Jan - Dec |
|--|----------------|----------------|----------------|----------------|----------------|----------------|-----------|
| 1. Target Heat Rate* | 10385 10357 | 10382 10356 | 10518 10364 | 10407 10436 | 10538 10096 | 10382 10423 | |
| 2. Target Heat Rate at Actual Conditions** | 10472 10510 | 10355 10436 | 10532 10616 | 10434 10414 | 10549 10144 | 10518 10457 | |
| 3. Adjustment to Actual Heat Rate (1-2)*** | -87 -153 | 27 -80 | -14 -252 | -27 22 | -11 -48 | -136 -34 | |
| 4. Actual Heat Rate (Page 2 of Sched. 3) | 10449 10674 | 10358 10638 | 10343 10672 | 10446 10602 | 10536 10728 | 10640 10469 | |
| 5. Adjusted Actual Heat Rate (4+3) | 10362 10521 | 10385 10558 | 10329 10420 | 10419 10624 | 10525 10680 | 10504 10435 | |
| 6. Net MWH Generation | 49849 49709 | 49777 50779 | 55002 41712 | 51719 52657 | 48540 49209 | 45249 45870 | |
| 7. Adjusted Actual Heat Rate for January 2004 - December 2004 = $(\Sigma(5*6) / \Sigma 6)$ | | | | | | | 10480 |

* From pages 20 & 21, Schedule 3 of Exhibit to L. S. Noack's September 12, 2003 GPIF testimony in Docket 030001-EI.

** Based on target heat rate equation from page 2, Schedule 1 of above mentioned filing using actual rather than forecast variable values. The equations are also shown for convenience on page 20 of this Schedule.

*** If (1=0) and (6>0), then (3) is calculated by subtracting (2) from the unit's Actual Average Net Operating Heat Rate Target found on page 21 of this Schedule.

Calculation of Average Net Operating Heat Rate
for January 2004 - December 2004
Adjusted to Target Basis Using Heat Rate
Equations Filed September 12, 2003

Crist 5

| | Jan/Jul | Feb/Aug | Mar/Sep | Apr/Oct | May/Nov | Jun/Dec | Jan - Dec |
|--|----------------|----------------|----------------|----------------|----------------|----------------|-----------|
| 1. Target Heat Rate* | 10238 10133 | 10234 10120 | 10224 10185 | 10303 10190 | 10538 10025 | 10224 10391 | |
| 2. Target Heat Rate at Actual Conditions** | 10595 10559 | 10541 10429 | 10255 10699 | 10330 10207 | 10591 10228 | 10556 10720 | |
| 3. Adjustment to Actual Heat Rate (1-2)*** | -357 -426 | -307 -309 | -31 -514 | -27 -17 | -53 -203 | -332 -329 | |
| 4. Actual Heat Rate (Page 3 of Sched. 3) | 10437 10676 | 10522 10554 | 10371 10843 | 10494 10868 | 10642 10806 | 10627 10763 | |
| 5. Adjusted Actual Heat Rate (4+3) | 10080 10250 | 10215 10245 | 10340 10329 | 10467 10851 | 10589 10603 | 10295 10434 | |
| 6. Net MWH Generation | 49022 49266 | 46011 49679 | 55051 42018 | 51691 52737 | 48611 48318 | 47805 47695 | |
| 7. Adjusted Actual Heat Rate for January 2004 - December 2004 =(Σ(5*6)/Σ6) | | | | | | | 10395 |

* From pages 22 & 23, Schedule 3 of Exhibit to L. S. Noack's September 12, 2003 GPIF testimony in Docket 030001-EI.

** Based on target heat rate equation from page 2, Schedule 1 of above mentioned filing using actual rather than forecast variable values. The equations are also shown for convenience on page 20 of this Schedule.

*** If (1=0) and (6>0), then (3) is calculated by subtracting (2) from the unit's Actual Average Net Operating Heat Rate Target found on page 21 of this Schedule.

Calculation of Average Net Operating Heat Rate
for January 2004 - December 2004
Adjusted to Target Basis Using Heat Rate
Equations Filed September 12, 2003

Crist 6

| | Jan/Jul | Feb/Aug | Mar/Sep | Apr/Oct | May/Nov | Jun/Dec | Jan - Dec |
|--|-----------------|------------------|------------------|-----------------|------------------|------------------|-----------|
| 1. Target Heat Rate* | 10484 10491 | 10483 10593 | 10638 10490 | 10484 10481 | 10370 10482 | 10486 10482 | |
| 2. Target Heat Rate at Actual Conditions** | 18492 10550 | 10441 10607 | 10588 10654 | 10758 10471 | 10411 10555 | 10576 10490 | |
| 3. Adjustment to Actual Heat Rate (1-2)*** | -8008 -59 | 42 -14 | 50 -164 | -274 10 | -41 -73 | -90 -8 | |
| 4. Actual Heat Rate (Page 4 of Sched. 3) | 169167 10407 | 9565 10478 | 9831 10468 | 10148 10158 | 10635 10165 | 10177 10294 | |
| 5. Adjusted Actual Heat Rate (4+3) | 161159 10348 | 9607 10464 | 9881 10304 | 9874 10168 | 10594 10092 | 10087 10286 | |
| 6. Net MWH Generation | 336 171620 | 185634 194961 | 200102 126804 | 42588 189204 | 169810 179756 | 161977 116738 | |
| 7. Adjusted Actual Heat Rate for January 2004 - December 2004 = $(\Sigma(5*6) / \Sigma 6)$ | | | | | | | 10192 |

* From pages 24 & 25, Schedule 3 of Exhibit to L. S. Noack's September 12, 2003 GPIF testimony in Docket 030001-EI.

** Based on target heat rate equation from page 2, Schedule 1 of above mentioned filing using actual rather than forecast variable values. The equations are also shown for convenience on page 20 of this Schedule.

*** If (1=0) and (6>0), then (3) is calculated by subtracting (2) from the unit's Actual Average Net Operating Heat Rate Target found on page 21 of this Schedule.

Calculation of Average Net Operating Heat Rate
for January 2004 - December 2004
Adjusted to Target Basis Using Heat Rate
Equations Filed September 12, 2003

Crist 7

| | Jan/Jul | Feb/Aug | Mar/Sep | Apr/Oct | May/Nov | Jun/Dec | Jan - Dec |
|--|------------------|----------------|-------------|-----------------|------------------|------------------|-----------|
| 1. Target Heat Rate* | 10124 10364 | 10129 10287 | 0 10312 | 0 10129 | 10177 10260 | 10254 10126 | |
| 2. Target Heat Rate at Actual Conditions** | 10215 10554 | 10171 10501 | 0 10520 | 10191 10194 | 10296 10333 | 10471 10178 | |
| 3. Adjustment to Actual Heat Rate (1-2)*** | -91 -190 | -42 -214 | 0 -208 | 32 -65 | -119 -73 | -217 -52 | |
| 4. Actual Heat Rate (Page 5 of Sched. 3) | 10214 10362 | 9912 10548 | 0 10471 | 10811 10407 | 10456 10289 | 10348 10232 | |
| 5. Adjusted Actual Heat Rate (4+3) | 10123 10172 | 9870 10334 | 0 10263 | 10843 10342 | 10337 10216 | 10131 10180 | |
| 6. Net MWH Generation | 314192 271888 | 9866 275001 | 0 185784 | 35457 322899 | 268569 303761 | 242071 329080 | |
| 7. Adjusted Actual Heat Rate for January 2004 - December 2004 = $(\Sigma(5*6) / \Sigma 6)$ | | | | | | | 10239 |

* From pages 26 & 27, Schedule 3 of Exhibit to L. S. Noack's September 12, 2003 GPIF testimony in Docket 030001-EI.

** Based on target heat rate equation from page 2, Schedule 1 of above mentioned filing using actual rather than forecast variable values. The equations are also shown for convenience on page 20 of this Schedule.

*** If (1=0) and (6>0), then (3) is calculated by subtracting (2) from the unit's Actual Average Net Operating Heat Rate Target found on page 21 of this Schedule.

Calculation of Average Net Operating Heat Rate
for January 2004 - December 2004
Adjusted to Target Basis Using Heat Rate
Equations Filed September 12, 2003

Smith 1

| | Jan/Jul | Feb/Aug | Mar/Sep | Apr/Oct | May/Nov | Jun/Dec | Jan - Dec |
|--|----------------|------------------|-----------------|-----------------|----------------|-----------------|-----------|
| 1. Target Heat Rate* | 9970 10100 | 9943 10104 | 10112 10102 | 10252 10144 | 10230 10137 | 10118 10134 | |
| 2. Target Heat Rate at Actual Conditions** | 10075 10249 | 9980 10187 | 10135 10275 | 10290 10146 | 10271 10185 | 10251 10169 | |
| 3. Adjustment to Actual Heat Rate (1-2)*** | -105 -149 | -37 -83 | -23 -173 | -38 -2 | -41 -48 | -133 -35 | |
| 4. Actual Heat Rate (Page 6 of Sched. 3) | 10251 10135 | 10345 10061 | 10205 10261 | 10203 9954 | 10230 10232 | 10258 10330 | |
| 5. Adjusted Actual Heat Rate (4+3) | 10146 9986 | 10308 9978 | 10182 10088 | 10165 9952 | 10189 10184 | 10125 10295 | |
| 6. Net MWH Generation | 99035 98792 | 102586 106626 | 114343 92429 | 91949 112690 | 96175 52754 | 95364 109214 | |
| 7. Adjusted Actual Heat Rate for January 2004 - December 2004 = $(\Sigma(5*6) / \Sigma 6)$ | | | | | | | 10131 |

* From pages 28 & 29 , Schedule 3 of Exhibit to L. S. Noack's September 12, 2003 GPIF testimony in Docket 030001-EI.

** Based on target heat rate equation from page 2, Schedule 1 of above mentioned filing using actual rather than forecast variable values. The equations are also shown for convenience on page 20 of this Schedule.

*** If (1=0) and (6>0), then (3) is calculated by subtracting (2) from the unit's Actual Average Net Operating Heat Rate Target found on page 21 of this Schedule.

Calculation of Average Net Operating Heat Rate
for January 2004 - December 2004
Adjusted to Target Basis Using Heat Rate
Equations Filed September 12, 2003

Smith 2

| | Jan/Jul | Feb/Aug | Mar/Sep | Apr/Oct | May/Nov | Jun/Dec | Jan - Dec |
|--|------------------|------------------|------------------|-----------------|------------------|------------------|-----------|
| 1. Target Heat Rate* | 9841 10180 | 9819 10138 | 9813 10033 | 10088 10085 | 10091 10071 | 10052 10071 | |
| 2. Target Heat Rate at Actual Conditions** | 9949 10408 | 9862 10268 | 9848 10254 | 10143 10094 | 10150 10112 | 10237 10116 | |
| 3. Adjustment to Actual Heat Rate (1-2)*** | -108 -228 | -43 -130 | -35 -221 | -55 -9 | -59 -41 | -185 -45 | |
| 4. Actual Heat Rate (Page 7 of Sched. 3) | 10133 10401 | 10194 10454 | 9865 10486 | 10578 10396 | 10362 10536 | 10393 10554 | |
| 5. Adjusted Actual Heat Rate (4+3) | 10025 10173 | 10151 10324 | 9830 10265 | 10523 10387 | 10303 10495 | 10208 10509 | |
| 6. Net MWH Generation | 113613 111088 | 110797 120774 | 124970 104190 | 61809 129215 | 102145 117212 | 106089 125512 | |
| 7. Adjusted Actual Heat Rate for January 2004 - December 2004 =($\Sigma(5*6)$)/ $\Sigma 6$) | | | | | | | 10257 |

* From pages 30 & 31, Schedule 3 of Exhibit to L. S. Noack's September 12, 2003 GPIF testimony in Docket 030001-EI.

** Based on target heat rate equation from page 2, Schedule 1 of above mentioned filing using actual rather than forecast variable values. The equations are also shown for convenience on page 20 of this Schedule.

*** If (1=0) and (6>0), then (3) is calculated by subtracting (2) from the unit's Actual Average Net Operating Heat Rate Target found on page 21 of this Schedule.

Calculation of Average Net Operating Heat Rate
for January 2004 - December 2004
Adjusted to Target Basis Using Heat Rate
Equations Filed September 12, 2003

Daniel 1

| | Jan/Jul | Feb/Aug | Mar/Sep | Apr/Oct | May/Nov | Jun/Dec | Jan - Dec |
|---|------------------|------------------|------------------|-----------------|-----------------|------------------|-----------|
| 1. Target Heat Rate* | 9984 10175 | 9943 10054 | 9925 9902 | 9989 10008 | 10008 0 | 9943 10026 | |
| 2. Target Heat Rate at Actual Conditions** | 9870 10195 | 9887 10194 | 9926 10037 | 9957 9926 | 9893 10178 | 9957 9919 | |
| 3. Adjustment to Actual Heat Rate (1-2)*** | 114 -20 | 56 -140 | -1 -135 | 32 82 | 115 -184 | -14 107 | |
| 4. Actual Heat Rate**** (Page 8 of Sched. 3) | 10288 10195 | 10120 10194 | 9926 10037 | 9957 9926 | 9893 10178 | 9957 9919 | |
| 5. Adjusted Actual Heat Rate (4+3) | 10402 10175 | 10176 10054 | 9925 9902 | 9989 10008 | 10008 9994 | 9943 10026 | |
| 6. Net MWH Generation | 363598 345675 | 336226 339849 | 203907 303265 | 289817 10767 | 298651 86661 | 290363 300905 | |
| 7. Adjusted Actual Heat Rate for January 2004 - December 2004 =($\Sigma(5*6) / \Sigma 6$) | | | | | | | 10072 |

* From pages 32 & 33, Schedule 3 of Exhibit to L. S. Noack's September 12, 2003 GPIF testimony in Docket 030001-EI.

** Based on target heat rate equation from page 2, Schedule 1 of above mentioned filing using actual rather than forecast variable values. The equations are also shown for convenience on page 20 of this Schedule.

*** If (1=0) and (6>0), then (3) is calculated by subtracting (2) from the unit's Actual Average Net Operating Heat Rate Target found on page 21 of this Schedule.

****Mar - Dec values are set equal to targets at actual conditions for Daniel 1.

Calculation of Average Net Operating Heat Rate
for January 2004 - December 2004
Adjusted to Target Basis Using Heat Rate
Equations Filed September 12, 2003

Daniel 2

| | Jan/Jul | Feb/Aug | Mar/Sep | Apr/Oct | May/Nov | Jun/Dec | Jan - Dec |
|---|------------------|------------------|------------------|------------------|------------------|------------------|-----------|
| 1. Target Heat Rate* | 9653 9815 | 9687 9820 | 9660 9817 | 9876 9894 | 10072 9702 | 9847 9871 | |
| 2. Target Heat Rate at Actual Conditions** | 9675 9924 | 9678 9916 | 9700 10020 | 9884 9926 | 10007 9709 | 9934 9878 | |
| 3. Adjustment to Actual Heat Rate (1-2)*** | -22 -109 | 9 -96 | -40 -203 | -8 -32 | 65 -7 | -87 -7 | |
| 4. Actual Heat Rate**** (Page 9 of Sched. 3) | 9505 9924 | 9528 9916 | 9700 10020 | 9884 9926 | 10007 9709 | 9934 9878 | |
| 5. Adjusted Actual Heat Rate (4+3) | 9483 9815 | 9537 9820 | 9660 9817 | 9876 9894 | 10072 9702 | 9847 9871 | |
| 6. Net MWH Generation | 243582 346502 | 342971 313796 | 338437 310867 | 346245 334758 | 324431 343589 | 332493 359939 | |
| 7. Adjusted Actual Heat Rate for January 2004 - December 2004 =($\Sigma(5*6) / \Sigma 6$) | | | | | | | 9789 |

* From pages 34 & 35, Schedule 3 of Exhibit to L. S. Noack's September 12, 2003 GPIF testimony in Docket 030001-EI.

** Based on target heat rate equation from page 2, Schedule 1 of above mentioned filing using actual rather than forecast variable values. The equations are also shown for convenience on page 20 of this Schedule.

*** If (1=0) and (6>0), then (3) is calculated by subtracting (2) from the unit's Actual Average Net Operating Heat Rate Target found on page 21 of this Schedule.

****Mar - Dec values are set equal to targets at actual conditions for Daniel 2.

Actual Values of
Target Heat Rate Equation Parameters
for January 2004 - December 2004

| | Jan/Jul | Feb/Aug | Mar/Sep | Apr/Oct | May/Nov | Jun/Dec |
|-----------|----------|----------|----------|----------|----------|----------|
| Crist 4 | | | | | | |
| +3 | | | | | | |
| AKW * 10 | 67.0 | 71.5 | 73.9 | 71.9 | 65.2 | 65.3 |
| | 66.8 | 68.3 | 63.6 | 70.7 | 68.3 | 65.2 |
| +6 | | | | | | |
| LSRF * 10 | 4632.9 | 5182.7 | 5528.5 | 5277.8 | 4424.9 | 4423.8 |
| | 4624.1 | 4791.4 | 4237.6 | 5104.8 | 4813.7 | 4381.6 |
| Crist 5 | | | | | | |
| +3 | | | | | | |
| AKW * 10 | 65.9 | 68.7 | 74.0 | 71.9 | 65.3 | 66.4 |
| | 66.2 | 69.3 | 63.2 | 70.8 | 67.1 | 64.1 |
| +6 | | | | | | |
| LSRF * 10 | 4502.2 | 4802.7 | 5538.0 | 5274.4 | 4449.4 | 4577.6 |
| | 4556.9 | 4948.2 | 4177.1 | 5118.5 | 4647.2 | 4244.2 |
| Crist 6 | | | | | | |
| +3 | | | | | | |
| AKW * 10 | 64.6 | 278.2 | 275.7 | 248.8 | 238.1 | 248.7 |
| | 246.5 | 265.1 | 223.4 | 281.8 | 261.3 | 274.2 |
| +6 | | | | | | |
| LSRF * 10 | 3496.6 | 79537.5 | 78142.2 | 69425.2 | 61689.0 | 67129.9 |
| | 65746.1 | 73940.7 | 55761.7 | 81673.3 | 72946.2 | 78295.6 |
| Crist 7 | | | | | | |
| +3 | | | | | | |
| AKW * 10 | 422.3 | 446.4 | 0.0 | 435.1 | 384.9 | 379.5 |
| | 398.3 | 384.5 | 388.4 | 433.4 | 437.6 | 442.3 |
| +6 | | | | | | |
| LSRF * 10 | 186771.1 | 207340.7 | 0.0 | 126623.9 | 161545.7 | 157667.3 |
| | 170794.4 | 158850.1 | 164260.8 | 195376.9 | 200544.8 | 200937.2 |
| Smith 1 | | | | | | |
| +3 | | | | | | |
| AKW * 10 | 133.1 | 147.4 | 153.7 | 147.1 | 129.3 | 132.5 |
| | 132.8 | 143.3 | 128.8 | 151.3 | 143.8 | 146.8 |
| +6 | | | | | | |
| LSRF * 10 | 18974.8 | 22355.7 | 24110.3 | 22482.4 | 18323.6 | 19079.6 |
| | 19239.6 | 21621.7 | 18305.3 | 23492.4 | 21658.5 | 22370.8 |
| Smith 2 | | | | | | |
| +3 | | | | | | |
| AKW * 10 | 152.7 | 168.4 | 173.7 | 163.4 | 143.3 | 147.3 |
| | 149.3 | 162.3 | 144.7 | 173.4 | 169.7 | 168.7 |
| +6 | | | | | | |
| LSRF * 10 | 24858.0 | 29178.0 | 30877.6 | 28226.9 | 22873.9 | 23982.6 |
| | 24637.2 | 27836.2 | 23495.3 | 30856.0 | 29786.0 | 29395.1 |

Actual Values of
 Target Heat Rate Equation Parameters
 for January 2004 - December 2004

| | Jan/Jul | Feb/Aug | Mar/Sep | Apr/Oct | May/Nov | Jun/Dec |
|-----------|----------|----------|----------|----------|----------|----------|
| Daniel 1 | | | | | | |
| +3 | | | | | | |
| AKW * 10 | 488.7 | 486.1 | 477.8 | 467.5 | 420.4 | 462.1 |
| | 485.6 | 456.8 | 428.3 | 441.3 | 328.5 | 471.8 |
| +6 | | | | | | |
| LSRF * 10 | 244843.7 | 242265.7 | 235109.7 | 227201.2 | 194781.3 | 223879.8 |
| | 240891.3 | 217037.5 | 199433.6 | 212699.7 | 134290.3 | 231775.1 |
| Daniel 2 | | | | | | |
| +3 | | | | | | |
| AKW * 10 | 463.2 | 493.8 | 482.1 | 481.6 | 436.1 | 461.8 |
| | 465.7 | 468.9 | 431.8 | 464.8 | 477.2 | 483.8 |
| +6 | | | | | | |
| LSRF * 10 | 226114.7 | 247007.7 | 237783.9 | 237108.6 | 203034.5 | 221969.7 |
| | 224469.7 | 229440.9 | 201449.8 | 231511.8 | 234309.9 | 238620.1 |

Target Heat Rate Equations

Crist 4 ANOHR = $10^6 / AKW * [617.42 + 9.96 * MAR - 23.05 * NOV]$
 $- 8329 + 0.13863 * LSRF / AKW$

Crist 5 ANOHR = $10^6 / AKW * [-136.85 - 13.15 * OCT - 21.65 * NOV]$
 $+ 18,611 - 0.08694 * LSRF / AKW$

Crist 6 ANOHR = $10^6 / AKW * [1069.69 + 44.52 * MAR - 33.07 * MAY + 30.91 * AUG]$
 $+ 844 + 0.02012 * LSRF / AKW$

Crist 7 ANOHR = $10^6 / AKW * [349.83 - 96.07 * MAR + 61.52 * JUN + 115.03 * JUL + 78.38 * AUG + 90.36 * SEP + 64.01 * NOV]$
 $+ 9,387$

Smith 1 ANOHR = $10^6 / AKW * [111.12 - 22.83 * JAN - 27.46 * FEB + 17.98 * APR]$
 $+ 9,412$

Smith 2 ANOHR = $10^6 / AKW * [139.59 - 38.77 * JAN - 43.18 * FEB - 42.50 * MAR - 16.17 * MAY + 27.46 * JUL + 19.26 * AUG]$
 $+ 9,289$

Daniel 1 ANOHR = $10^6 / AKW * [-528.45 - 59.78 * MAY + 139.64 * JUL + 75.47 * AUG]$
 $+ 15,490 - 0.00906 * LSRF / AKW$

Daniel 2 ANOHR = $10^6 / AKW * [571.00 - 118.56 * JAN - 87.31 * FEB - 88.00 * MAR - 88.36 * NOV]$
 $+ 8,698$

Where:

| | |
|-------|---|
| ANOHR | Average Net Operating Heat Rate, BTU/KWH |
| AKW | Average Kilowatt Load, KW |
| LSRF | Load Square Range Factor, KW ² |
| JAN | January, 0 if not January, 1 if January |
| FEB | February, 0 if not February, 1 if February |
| MAR | March, 0 if not March, 1 if March |
| APR | April, 0 if not April, 1 if April |
| MAY | May, 0 if not May, 1 if May |
| JUN | June, 0 if not June, 1 if June |
| JUL | July, 0 if not July, 1 if July |
| AUG | August, 0 if not August, 1 if August |
| SEP | September, 0 if not September, 1 if September |
| OCT | October, 0 if not October, 1 if October |
| NOV | November, 0 if not November, 1 if November |

Calculation of Heat Rate Points
for January 2004 - December 2004

| (1) Unit | (2) Average Net Operating Heat Rate Target* | (3) Net Operating Heat Rate Adjusted to Target Basis** | (4) Minimum Attainable Heat Rate* | (5) Heat Rate Points*** |
|-------------|--|---|--|-------------------------------|
| Crist 4 | 10388 | 10480 | 10076 | -0.72 |
| Crist 5 | 10232 | 10395 | 9925 | -3.79 |
| Crist 6 | 10501 | 10192 | 10186 | 9.75 |
| Crist 7 | 10223 | 10239 | 9916 | 0.00 |
| Smith 1 | 10114 | 10131 | 9811 | 0.00 |
| Smith 2 | 10024 | 10257 | 9723 | -6.99 |
| Daniel 1 | 9994 | 10072 | 9694 | -0.13 |
| Daniel 2 | 9828 | 9789 | 9533 | 0.00 |

* From page 5, Schedule 3 of Exhibit to L. S. Noack's
September 12, 2003 GPIF testimony in Docket 030001-EI

** Refer to pages 10 through 17 of this Schedule for calculation.

*** If [(2) - 75] <= (3) <= [(2) + 75] then points = 0

If [(2) - (3) - 75] > 0 then points = $\frac{(2) - (3) - 75}{(2) - (4) - 75} * 10$

If [(2) - (3) + 75] < 0 then points = $\frac{(2) - (3) + 75}{(2) - (4) - 75} * 10$

Florida Public Service Commission
Docket No. 050001-EI
Gulf Power Company
Witness: L. S. Noack
Exhibit No. ____ (LSN-1)
Schedule 4
Page 1 of 2

IV. CALCULATION OF COMPANY GPIF POINTS AND REWARD/PENALTY

Calculation of Heat Rate Points

GPIF Points and Reward or Penalty

for January 2004 - December 2004

| Unit | Availability Points | Availability* Weighting Factor | Heat Rate Points | Heat Rate* Weighting Factor |
|----------|------------------------|-----------------------------------|---------------------|--------------------------------|
| Crist 4 | 10.00 | 0.001 | -0.72 | 0.040 |
| Crist 5 | 10.00 | 0.002 | -3.79 | 0.038 |
| Crist 6 | -10.00 | 0.015 | 9.75 | 0.154 |
| Crist 7 | 0.00 | 0.084 | 0.00 | 0.191 |
| Smith 1 | 10.00 | 0.006 | 0.00 | 0.080 |
| Smith 2 | 10.00 | 0.024 | -6.99 | 0.079 |
| Daniel 1 | 7.50 | 0.053 | -0.13 | 0.075 |
| Daniel 2 | 10.00 | 0.057 | 0.00 | 0.100 |

$$\begin{aligned}
\text{Company GPIF Points} = & + 10.00 * 0.001 - 0.72 * 0.040 \\
& + 10.00 * 0.002 - 3.79 * 0.038 \\
& - 10.00 * 0.015 + 9.75 * 0.154 \\
& + 0.00 * 0.084 + 0.00 * 0.191 \\
& + 10.00 * 0.006 + 0.00 * 0.080 \\
& + 10.00 * 0.024 - 6.99 * 0.079 \\
& + 7.50 * 0.053 - 0.13 * 0.075 \\
& + 10.00 * 0.057 + 0.00 * 0.100 \\
= & 1.91
\end{aligned}$$

$$\begin{aligned}
\text{Company reward/penalty} = & 1.91 \text{ points} * \$231407 \text{ per point} \\
= & \$441,988
\end{aligned}$$

* From page 5, Schedule 3 of Exhibit to L. S. Noack's
September 12, 2003 GPIF testimony in Docket 030001-EI

Florida Public Service Commission
Docket No. 050001-EI
Gulf Power Company
Witness: L. S. Noack
Exhibit No. ____ (LSN-1)
Schedule 5
Page 1 of 32

V. GPIF MINIMUM FILING REQUIREMENTS FOR THE JANUARY 2004 - DECEMBER 2004 PERIOD

| CONTENTS | SCHEDULE 5 |
|--|-------------|
| | <u>PAGE</u> |
| GPIF Reward/Penalty Table (Actual) | 3 |
| GPIF Calculation of Maximum Allowed Incentive Dollars (Actual) | 4 |
| Calculation of System Actual GPIF Points | 5 |
| Generating Performance Incentive Points Table | 6 - 13 |
| GPIF Unit Performance Summary | 14 |
| Actual Unit Performance Data | 15 |
| Historic Unit Performance Data | 16 - 31 |
| Planned Outage Schedules (Actual) | 32 |

Generating Performance Incentive Factor

Actual Reward/Penalty Table

Gulf Power Company

Period of: January 2004 - December 2004

| Generating Performance Incentive Factor Points | Fuel Saving/Loss (\$000) | Generating Performance Incentive Factor (\$000) |
|--|---------------------------------------|---|
| | Maximum Attainable Fuel Savings | Maximum Incentive Dollars Allowed by Commission During Period (Reward) |
| + 10 | 5678 | 2314 |
| + 9 | 5110 | 2083 |
| + 8 | 4542 | 1851 |
| + 7 | 3975 | 1620 |
| + 6 | 3407 | 1388 |
| + 5 | 2839 | 1157 |
| + 4 | 2271 | 926 |
| + 3 | 1703 | 694 |
| + 2 | 1136 | 463 |
| + 1 | 568 | 231 |
| 0 | 0 | 0 |
| - 1 | -638 | -231 |
| - 2 | -1275 | -463 |
| - 3 | -1913 | -694 |
| - 4 | -2551 | -926 |
| - 5 | -3189 | -1157 |
| - 6 | -3826 | -1388 |
| - 7 | -4464 | -1620 |
| - 8 | -5102 | -1851 |
| - 9 | -5739 | -2083 |
| - 10 | -6377 | -2314 |
| | Minimum Attainable Fuel Loss | Maximum Incentive Dollars Allowed by Commission During Period (Penalty) |

Issued by: S. N. Story

Page 3 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

Generating Performance Incentive Factor
Calculation of Maximum Allowed Incentive Dollars

Actual

Gulf Power Company

Period of: January 2004 - December 2004

| | | |
|---------|--|----------------|
| Line 1 | Beginning of Period Balance of Common Equity | \$561,357,935 |
| | End of Month Balance of Common Equity: | |
| Line 2 | Month of Jan '04 | \$594,083,709 |
| Line 3 | Month of Feb '04 | \$583,098,084 |
| Line 4 | Month of Mar '04 | \$587,546,853 |
| Line 5 | Month of Apr '04 | \$572,021,569 |
| Line 6 | Month of May '04 | \$580,696,217 |
| Line 7 | Month of Jun '04 | \$589,219,105 |
| Line 8 | Month of Jul '04 | \$585,443,104 |
| Line 9 | Month of Aug '04 | \$596,481,686 |
| Line 10 | Month of Sep '04 | \$605,017,259 |
| Line 11 | Month of Oct '04 | \$592,392,397 |
| Line 12 | Month of Nov '04 | \$594,051,062 |
| Line 13 | Month of Dec '04 | \$593,193,746 |
| Line 14 | Average Common Equity for the Period (sum of line 1 through line 13 divided by 13) | \$587,277,133 |
| Line 15 | 25 Basis Points | 0.0025 |
| Line 16 | Revenue Expansion Factor | 61.3808% |
| Line 17 | Maximum Allowed Incentive Dollars (line 14 multiplied by line 15 divided by line 16 multiplied by 1.0) | \$2,391,943 |
| Line 18 | Jurisdictional Sales (KWH) | 11,046,409,000 |
| Line 19 | Total Territorial Sales (KWH) | 11,418,120,000 |
| Line 20 | Jurisdictional Separation Factor (line 18 divided by line 19) | 96.7446% |
| Line 21 | Maximum Allowed Jurisdictional Incentive Dollars (line 17 multiplied by line 20) | \$2,314,074 |

Issued by: S. N. Story

Page 4 of 32
Schedule 5

Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

Calculation of System Actual GPIF Points

Gulf Power Company

Period of: January 2004 - December 2004

| Plant & Unit | Performance Indicator (EAF or ANOHR) | Weighting Factor | Unit Points | Weighted Unit Points |
|-----------------------|--|---------------------|----------------|----------------------------|
| Crist 4 | EAF1 | 0.1% | 10.00 | 0.010 |
| Crist 4 | ANOHR1 | 4.0% | -0.72 | -0.029 |
| Crist 5 | EAF2 | 0.2% | 10.00 | 0.020 |
| Crist 5 | ANOHR2 | 3.8% | -3.79 | -0.144 |
| Crist 6 | EAF3 | 1.5% | -10.00 | -0.150 |
| Crist 6 | ANOHR3 | 15.4% | 9.75 | 1.502 |
| Crist 7 | EAF4 | 8.4% | 0.00 | 0.000 |
| Crist 7 | ANOHR4 | 19.1% | 0.00 | 0.000 |
| Smith 1 | EAF5 | 0.6% | 10.00 | 0.060 |
| Smith 1 | ANOHR5 | 8.0% | 0.00 | 0.000 |
| Smith 2 | EAF6 | 2.4% | 10.00 | 0.240 |
| Smith 2 | ANOHR6 | 7.9% | -6.99 | -0.552 |
| Daniel 1 | EAF7 | 5.3% | 7.50 | 0.398 |
| Daniel 1 | ANOHR7 | 7.5% | -0.13 | -0.010 |
| Daniel 2 | EAF8 | 5.7% | 10.00 | 0.570 |
| Daniel 2 | ANOHR8 | 10.0% | 0.00 | 0.000 |
| Gulf Power GPIF Total | | 99.9% | | 1.91 |

Issued by: S. N. Story

Page 5 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

Generating Performance Incentive Points Table

Gulf Power Company

Period of: January 2004 - December 2004

Crist 4

| Equivalent Availability Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Equivalent Availability | Average Heat Rate Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Heat Rate |
|--------------------------------------|-------------------------------------|--|--------------------------------|-------------------------------------|---------------------------------|
| + 10 | 8 | 98.50 | + 10 | 229 | 10,076 |
| + 9 | 7 | 98.44 | + 9 | 206 | 10,100 |
| + 8 | 6 | 98.38 | + 8 | 183 | 10,123 |
| + 7 | 6 | 98.32 | + 7 | 160 | 10,147 |
| + 6 | 5 | 98.26 | + 6 | 137 | 10,171 |
| + 5 | 4 | 98.20 | + 5 | 115 | 10,195 |
| + 4 | 3 | 98.14 | + 4 | 92 | 10,218 |
| + 3 | 2 | 98.08 | + 3 | 69 | 10,242 |
| + 2 | 2 | 98.02 | + 2 | 46 | 10,266 |
| + 1 | 1 | 97.96 | + 1 | 23 | 10,289 |
| 0 | 0 | 97.90 | 0 | 0 | 10,313 |
| | | | | 0 | 10,388 |
| | | | | 0 | 10,463 |
| - 1 | (1) | 97.80 | - 1 | (23) | 10,487 |
| - 2 | (2) | 97.70 | - 2 | (46) | 10,510 |
| - 3 | (3) | 97.60 | - 3 | (69) | 10,534 |
| - 4 | (4) | 97.50 | - 4 | (92) | 10,558 |
| - 5 | (5) | 97.40 | - 5 | (115) | 10,582 |
| - 6 | (5) | 97.30 | - 6 | (137) | 10,605 |
| - 7 | (6) | 97.20 | - 7 | (160) | 10,629 |
| - 8 | (7) | 97.10 | - 8 | (183) | 10,653 |
| - 9 | (8) | 97.00 | - 9 | (206) | 10,676 |
| - 10 | (9) | 96.90 | - 10 | (229) | 10,700 |
| Weighting Factor: | | 0.001 | Weighting Factor: | | 0.040 |

Issued by: S. N. Story

Page 6 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

Generating Performance Incentive Points Table

Gulf Power Company

Period of: January 2004 - December 2004

Crist 6

| Equivalent Availability Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Equivalent Availability | Average Heat Rate Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Heat Rate |
|--------------------------------------|-------------------------------------|--|--------------------------------|-------------------------------------|---------------------------------|
| + 10 | 84 | 88.80 | + 10 | 876 | 10,186 |
| + 9 | 76 | 88.59 | + 9 | 788 | 10,210 |
| + 8 | 67 | 88.38 | + 8 | 701 | 10,234 |
| + 7 | 59 | 88.17 | + 7 | 613 | 10,258 |
| + 6 | 50 | 87.96 | + 6 | 526 | 10,282 |
| + 5 | 42 | 87.75 | + 5 | 438 | 10,306 |
| + 4 | 34 | 87.54 | + 4 | 350 | 10,330 |
| + 3 | 25 | 87.33 | + 3 | 263 | 10,354 |
| + 2 | 17 | 87.12 | + 2 | 175 | 10,378 |
| + 1 | 8 | 86.91 | + 1 | 88 | 10,402 |
| 0 | 0 | 86.70 | 0 | 0 | 10,426 |
| | | | | 0 | 10,501 |
| | | | | 0 | 10,576 |
| - 1 | (15) | 86.39 | - 1 | (88) | 10,600 |
| - 2 | (29) | 86.08 | - 2 | (175) | 10,624 |
| - 3 | (44) | 85.77 | - 3 | (263) | 10,648 |
| - 4 | (59) | 85.46 | - 4 | (350) | 10,672 |
| - 5 | (74) | 85.15 | - 5 | (438) | 10,696 |
| - 6 | (88) | 84.84 | - 6 | (526) | 10,720 |
| - 7 | (103) | 84.53 | - 7 | (613) | 10,744 |
| - 8 | (118) | 84.22 | - 8 | (701) | 10,768 |
| - 9 | (132) | 83.91 | - 9 | (788) | 10,792 |
| | (147) | 83.60 | | (876) | 10,816 |
| Weighting Factor: | | 0.015 | Weighting Factor: | | 0.154 |

Issued by: S. N. Story

Page 8 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

Generating Performance Incentive Points Table

Gulf Power Company

Period of: January 2004 - December 2004

Crist 7

| Equivalent Availability Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Equivalent Availability | Average Heat Rate Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Heat Rate |
|--------------------------------------|-------------------------------------|--|--------------------------------|-------------------------------------|---------------------------------|
| + 10 | 477 | 72.60 | + 10 | 1,086 | 9,916 |
| + 9 | 429 | 72.35 | + 9 | 977 | 9,939 |
| + 8 | 382 | 72.10 | + 8 | 869 | 9,962 |
| + 7 | 334 | 71.85 | + 7 | 760 | 9,986 |
| + 6 | 286 | 71.60 | + 6 | 652 | 10,009 |
| + 5 | 239 | 71.35 | + 5 | 543 | 10,032 |
| + 4 | 191 | 71.10 | + 4 | 434 | 10,055 |
| + 3 | 143 | 70.85 | + 3 | 326 | 10,078 |
| + 2 | 95 | 70.60 | + 2 | 217 | 10,102 |
| + 1 | 48 | 70.35 | + 1 | 109 | 10,125 |
| 0 | 0 | 70.10 | 0 | 0 | 10,148 |
| | | | | 0 | 10,223 |
| | | | | 0 | 10,298 |
| - 1 | (63) | 69.72 | - 1 | (109) | 10,321 |
| - 2 | (127) | 69.34 | - 2 | (217) | 10,344 |
| - 3 | (190) | 68.96 | - 3 | (326) | 10,368 |
| - 4 | (254) | 68.58 | - 4 | (434) | 10,391 |
| - 5 | (317) | 68.20 | - 5 | (543) | 10,414 |
| - 6 | (380) | 67.82 | - 6 | (652) | 10,437 |
| - 7 | (444) | 67.44 | - 7 | (760) | 10,460 |
| - 8 | (507) | 67.06 | - 8 | (869) | 10,484 |
| - 9 | (571) | 66.68 | - 9 | (977) | 10,507 |
| - 10 | (634) | 66.30 | - 10 | (1,086) | 10,530 |
| Weighting Factor: | | 0.084 | Weighting Factor: | | 0.191 |

Issued by: S. N. Story

Page 9 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

Generating Performance Incentive Points Table

Gulf Power Company

Period of: January 2004 - December 2004

Smith 1

| Equivalent Availability Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Equivalent Availability | Average Heat Rate Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Heat Rate |
|--------------------------------------|-------------------------------------|--|--------------------------------|-------------------------------------|---------------------------------|
| + 10 | 32 | 90.60 | + 10 | 454 | 9,811 |
| + 9 | 29 | 90.55 | + 9 | 409 | 9,834 |
| + 8 | 26 | 90.50 | + 8 | 363 | 9,857 |
| + 7 | 22 | 90.45 | + 7 | 318 | 9,879 |
| + 6 | 19 | 90.40 | + 6 | 272 | 9,902 |
| + 5 | 16 | 90.35 | + 5 | 227 | 9,925 |
| + 4 | 13 | 90.30 | + 4 | 182 | 9,948 |
| + 3 | 10 | 90.25 | + 3 | 136 | 9,971 |
| + 2 | 6 | 90.20 | + 2 | 91 | 9,993 |
| + 1 | 3 | 90.15 | + 1 | 45 | 10,016 |
| 0 | 0 | 90.10 | 0 | 0 | 10,039 |
| | | | | 0 | 10,114 |
| | | | | 0 | 10,189 |
| - 1 | (3) | 90.02 | - 1 | (45) | 10,212 |
| - 2 | (6) | 89.94 | - 2 | (91) | 10,235 |
| - 3 | (10) | 89.86 | - 3 | (136) | 10,257 |
| - 4 | (13) | 89.78 | - 4 | (182) | 10,280 |
| - 5 | (16) | 89.70 | - 5 | (227) | 10,303 |
| - 6 | (19) | 89.62 | - 6 | (272) | 10,326 |
| - 7 | (22) | 89.54 | - 7 | (318) | 10,349 |
| - 8 | (26) | 89.46 | - 8 | (363) | 10,371 |
| - 9 | (29) | 89.38 | - 9 | (409) | 10,394 |
| - 10 | (32) | 89.30 | - 10 | (454) | 10,417 |
| Weighting Factor: | | 0.006 | Weighting Factor: | | 0.080 |

Issued by: S. N. Story

Page 10 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

Generating Performance Incentive Points Table

Gulf Power Company

Period of: January 2004 - December 2004

Smith 2

| Equivalent Availability Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Equivalent Availability | Average Heat Rate Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Heat Rate |
|--------------------------------------|-------------------------------------|--|--------------------------------|-------------------------------------|---------------------------------|
| + 10 | 134 | 85.50 | + 10 | 449 | 9,723 |
| + 9 | 121 | 85.23 | + 9 | 404 | 9,746 |
| + 8 | 107 | 84.96 | + 8 | 359 | 9,768 |
| + 7 | 94 | 84.69 | + 7 | 314 | 9,791 |
| + 6 | 80 | 84.42 | + 6 | 269 | 9,813 |
| + 5 | 67 | 84.15 | + 5 | 225 | 9,836 |
| + 4 | 54 | 83.88 | + 4 | 180 | 9,859 |
| + 3 | 40 | 83.61 | + 3 | 135 | 9,881 |
| + 2 | 27 | 83.34 | + 2 | 90 | 9,904 |
| + 1 | 13 | 83.07 | + 1 | 45 | 9,926 |
| 0 | 0 | 82.80 | 0 | 0 | 9,949 |
| | | | | 0 | 10,024 |
| | | | | 0 | 10,099 |
| - 1 | (23) | 82.40 | - 1 | (45) | 10,122 |
| - 2 | (45) | 82.00 | - 2 | (90) | 10,144 |
| - 3 | (68) | 81.60 | - 3 | (135) | 10,167 |
| - 4 | (91) | 81.20 | - 4 | (180) | 10,189 |
| - 5 | (114) | 80.80 | - 5 | (225) | 10,212 |
| - 6 | (136) | 80.40 | - 6 | (269) | 10,235 |
| - 7 | (159) | 80.00 | - 7 | (314) | 10,257 |
| - 8 | (182) | 79.60 | - 8 | (359) | 10,280 |
| - 9 | (204) | 79.20 | - 9 | (404) | 10,302 |
| - 10 | (227) | 78.80 | - 10 | (449) | 10,325 |
| Weighting Factor: | | 0.024 | Weighting Factor: | | 0.079 |

Issued by: S. N. Story

Page 11 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

Generating Performance Incentive Points Table

Gulf Power Company

Period of: January 2004 - December 2004

Daniel 1

| Equivalent Availability Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Equivalent Availability | Average Heat Rate Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Heat Rate |
|--------------------------------------|-------------------------------------|--|--------------------------------|-------------------------------------|---------------------------------|
| + 10 | 299 | 71.20 | + 10 | 428 | 9,694 |
| + 9 | 269 | 71.04 | + 9 | 385 | 9,717 |
| + 8 | 239 | 70.88 | + 8 | 342 | 9,739 |
| + 7 | 209 | 70.72 | + 7 | 300 | 9,762 |
| + 6 | 179 | 70.56 | + 6 | 257 | 9,784 |
| + 5 | 150 | 70.40 | + 5 | 214 | 9,807 |
| + 4 | 120 | 70.24 | + 4 | 171 | 9,829 |
| + 3 | 90 | 70.08 | + 3 | 128 | 9,852 |
| + 2 | 60 | 69.92 | + 2 | 86 | 9,874 |
| + 1 | 30 | 69.76 | + 1 | 43 | 9,897 |
| 0 | 0 | 69.60 | 0 | 0 | 9,919 |
| | | | | 0 | 9,994 |
| | | | | 0 | 10,069 |
| - 1 | (45) | 69.34 | - 1 | (43) | 10,092 |
| - 2 | (91) | 69.08 | - 2 | (86) | 10,114 |
| - 3 | (136) | 68.82 | - 3 | (128) | 10,137 |
| - 4 | (181) | 68.56 | - 4 | (171) | 10,159 |
| - 5 | (227) | 68.30 | - 5 | (214) | 10,182 |
| - 6 | (272) | 68.04 | - 6 | (257) | 10,204 |
| - 7 | (317) | 67.78 | - 7 | (300) | 10,227 |
| - 8 | (362) | 67.52 | - 8 | (342) | 10,249 |
| - 9 | (408) | 67.26 | - 9 | (385) | 10,272 |
| - 10 | (453) | 67.00 | - 10 | (428) | 10,294 |
| Weighting Factor: | | 0.053 | Weighting Factor: | | 0.075 |

Issued by: S. N. Story

Page 12 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

Generating Performance Incentive Points Table

Gulf Power Company

Period of: January 2004 - December 2004

Daniel 2

| Equivalent Availability Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Equivalent Availability | Average Heat Rate Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Heat Rate |
|--------------------------------------|-------------------------------------|--|--------------------------------|-------------------------------------|---------------------------------|
| + 10 | 324 | 83.20 | + 10 | 568 | 9,533 |
| + 9 | 292 | 82.99 | + 9 | 511 | 9,555 |
| + 8 | 259 | 82.78 | + 8 | 454 | 9,577 |
| + 7 | 227 | 82.57 | + 7 | 398 | 9,599 |
| + 6 | 194 | 82.36 | + 6 | 341 | 9,621 |
| + 5 | 162 | 82.15 | + 5 | 284 | 9,643 |
| + 4 | 130 | 81.94 | + 4 | 227 | 9,665 |
| + 3 | 97 | 81.73 | + 3 | 170 | 9,687 |
| + 2 | 65 | 81.52 | + 2 | 114 | 9,709 |
| + 1 | 32 | 81.31 | + 1 | 57 | 9,731 |
| 0 | 0 | 81.10 | 0 | 0 | 9,753 |
| - 1 | (55) | 80.79 | - 1 | (57) | 9,828 |
| - 2 | (110) | 80.48 | - 2 | (114) | 9,903 |
| - 3 | (165) | 80.17 | - 3 | (170) | 9,925 |
| - 4 | (220) | 79.86 | - 4 | (227) | 9,947 |
| - 5 | (275) | 79.55 | - 5 | (284) | 9,969 |
| - 6 | (330) | 79.24 | - 6 | (341) | 9,991 |
| - 7 | (385) | 78.93 | - 7 | (398) | 10,013 |
| - 8 | (440) | 78.62 | - 8 | (454) | 10,035 |
| - 9 | (495) | 78.31 | - 9 | (511) | 10,057 |
| - 10 | (550) | 78.00 | - 10 | (568) | 10,079 |
| Weighting Factor: | | 0.057 | Weighting Factor: | | 0.100 |

Issued by: S. N. Story

Page 13 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

GPIF Unit Performance Summary

Gulf Power Company

Period of: January 2004 - December 2004

| Plant & Unit | Weighting Factor % | EAF Target % | EAF Range | | Max Fuel Savings (\$000) | Max Fuel Loss (\$000) | EAF Adjusted Actual % | Actual Fuel Savings/ Loss (\$000) |
|--------------|--------------------|--------------|-----------|-------|--------------------------|-----------------------|-----------------------|-----------------------------------|
| | | | Max % | Min % | | | | |
| Crist 4 | 0.1 | 97.9 | 98.5 | 96.9 | 8.0 | (\$9) | 98.5 | \$8 |
| Crist 5 | 0.2 | 96.8 | 97.7 | 95.3 | 14.0 | (\$19) | 98.7 | \$14 |
| Crist 6 | 1.5 | 86.7 | 88.8 | 83.6 | 84.0 | (\$147) | 75.5 | (\$147) |
| Crist 7 | 8.4 | 70.1 | 72.6 | 66.3 | 477.0 | (\$634) | 70.1 | \$0 |
| Smith 1 | 0.6 | 90.1 | 90.6 | 89.3 | 32.0 | (\$32) | 91.6 | \$32 |
| Smith 2 | 2.4 | 82.8 | 85.5 | 78.8 | 134.0 | (\$227) | 90.4 | \$134 |
| Daniel 1 | 5.3 | 69.6 | 71.2 | 67.0 | 299.0 | (\$453) | 70.8 | \$224 |
| Daniel 2 | 5.7 | 81.1 | 83.2 | 78.0 | 324.0 | (\$550) | 85.3 | \$324 |
| Total: | 24.2 | | | | | | | |

| Plant & Unit | Weighting Factor % | ANOHR Target BTU/KWH | ANOHR Target NOF | ANOHR Range | | Max Fuel Savings (\$000) | Max Fuel Loss (\$000) | ANOHR Adjusted Actual BTU/KWH | Actual Fuel Savings/ Loss (\$000) |
|--------------|--------------------|----------------------|------------------|-------------|-------------|--------------------------|-----------------------|-------------------------------|-----------------------------------|
| | | | | Max BTU/KWH | Min BTU/KWH | | | | |
| Crist 4 | 4.0 | 10,388 | 93.9 | 10,700 | 10,076 | \$229 | (\$229) | 10,480 | (\$16) |
| Crist 5 | 3.8 | 10,232 | 92.1 | 10,539 | 9,925 | \$216 | (\$216) | 10,395 | (\$82) |
| Crist 6 | 15.4 | 10,501 | 96.5 | 10,816 | 10,186 | \$876 | (\$876) | 10,192 | \$854 |
| Crist 7 | 19.1 | 10,223 | 99.1 | 10,530 | 9,916 | \$1,086 | (\$1,086) | 10,239 | \$0 |
| Smith 1 | 8.0 | 10,114 | 95.7 | 10,417 | 9,811 | \$454 | (\$454) | 10,131 | \$0 |
| Smith 2 | 7.9 | 10,024 | 95.2 | 10,325 | 9,723 | \$449 | (\$449) | 10,257 | (\$314) |
| Daniel 1 | 7.5 | 9,994 | 94.3 | 10,294 | 9,694 | \$428 | (\$428) | 10,072 | (\$6) |
| Daniel 2 | 10.0 | 9,828 | 94.7 | 10,123 | 9,533 | \$568 | (\$568) | 9,789 | \$0 |
| Total: | 75.7 | | | | | | | | |

Issued by: S. N. Story

Page 14 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

Actual Unit Performance Data

Gulf Power Company

Period of: January 2004 - December 2004

| Plant & Unit | Actual EAF % | Adjustments* to EAF % | Adjusted Actual % |
|--------------------|--------------------|-----------------------------|-------------------------|
| Crist 4 | 98.5 | 0.0 | 98.5 |
| Crist 5 | 98.7 | 0.0 | 98.7 |
| Crist 6 | 75.3 | 0.2 | 75.5 |
| Crist 7 | 69.8 | 0.3 | 70.1 |
| Smith 1 | 94.7 | -3.1 | 91.6 |
| Smith 2 | 94.6 | -4.2 | 90.4 |
| Daniel 1 | 78.2 | -7.4 | 70.8 |
| Daniel 2 | 95.2 | -9.9 | 85.3 |

| Plant & Unit | Actual ANOHR BTU/KWH | Adjustments** to ANOHR BTU/KWH | ANOHR Adjusted Actual BTU/KWH |
|--------------------|----------------------------|--------------------------------------|--|
| Crist 4 | 10,542 | -62 | 10,480 |
| Crist 5 | 10,629 | -234 | 10,395 |
| Crist 6 | 10,229 | -37 | 10,192 |
| Crist 7 | 10,365 | -126 | 10,239 |
| Smith 1 | 10,202 | -71 | 10,131 |
| Smith 2 | 10,353 | -96 | 10,257 |
| Daniel 1 | 10,066 | 6 | 10,072 |
| Daniel 2 | 9,833 | -44 | 9,789 |

* Refer to pages 3 through 10, Schedule 2.

** Refer to pages 10 through 17, Schedule 3.

Issued by: S. N. Story

Page 15 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

| CRIST 4 | Jan '04 | Feb '04 | Mar '04 | Apr '04 | May '04 | Jun '04 | |
|--------------------|--|---------|---------|---------|---------|---------|--|
| 1. EAF (%) | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 96.2 | |
| PH | 744.0 | 696.0 | 744.0 | 719.0 | 744.0 | 720.0 | |
| SH | 744.0 | 696.0 | 744.0 | 719.0 | 744.0 | 692.9 | |
| RSH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| UH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 27.1 | |
| POH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| FOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| MOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 27.1 | |
| PFOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| LR pf (MW) | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| PMOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| LR pm (MW) | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| NSC (MW) | 78.0 | 78.0 | 78.0 | 78.0 | 78.0 | 78.0 | |
| Oper MBtu | 520852 | 515590 | 568887 | 540255 | 511404 | 481461 | |
| Net Gen (MWH) | 49849 | 49777 | 55002 | 51719 | 48540 | 45249 | |
| ANOHR (Btu/KWH) | 10449 | 10358 | 10343 | 10446 | 10536 | 10640 | |
| NOF % | 85.9 | 91.7 | 94.8 | 92.2 | 83.6 | 83.7 | |
| NPC (MW) | 78.0 | 78.0 | 78.0 | 78.0 | 78.0 | 78.0 | |
| 19. ANOHR Equation | $10^6 / AKW * [617.42 + 9.96 * MAR - 23.05 * NOV]$ $-8329 + 0.13863 * LSRF / AKW$ | | | | | | |

Issued by: S. N. Story

Page 16 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

Calculation of Average Net Operating Heat Rate
for January 2004 - December 2004
Adjusted to Target Basis Using Heat Rate
Equations Filed September 12, 2003

Daniel 2

| | Jan/Jul | Feb/Aug | Mar/Sep | Apr/Oct | May/Nov | Jun/Dec | Jan - Dec |
|--|------------------|------------------|------------------|------------------|------------------|------------------|-----------|
| 1. Target Heat Rate* | 9653 9815 | 9687 9820 | 9660 9817 | 9876 9894 | 10072 9702 | 9847 9871 | |
| 2. Target Heat Rate at Actual Conditions** | 9675 9924 | 9678 9916 | 9700 10020 | 9884 9926 | 10007 9709 | 9934 9878 | |
| 3. Adjustment to Actual Heat Rate (1-2)*** | -22 -109 | 9 -96 | -40 -203 | -8 -32 | 65 -7 | -87 -7 | |
| 4. Actual Heat Rate**** (Page 9 of Sched. 3) | 9505 9924 | 9528 9916 | 9700 10020 | 9884 9926 | 10007 9709 | 9934 9878 | |
| 5. Adjusted Actual Heat Rate (4+3) | 9483 9815 | 9537 9820 | 9660 9817 | 9876 9894 | 10072 9702 | 9847 9871 | |
| 6. Net MWH Generation | 243582 346502 | 342971 313796 | 338437 310867 | 346245 334758 | 324431 343589 | 332493 359939 | |
| 7. Adjusted Actual Heat Rate for January 2004 - December 2004 =(Σ(5*6)/Σ6) | | | | | | | 9789 |

* From pages 34 & 35, Schedule 3 of Exhibit to L. S. Noack's September 12, 2003 GPIF testimony in Docket 030001-EI.

** Based on target heat rate equation from page 2, Schedule 1 of above mentioned filing using actual rather than forecast variable values. The equations are also shown for convenience on page 20 of this Schedule.

*** If (1=0) and (6>0), then (3) is calculated by subtracting (2) from the unit's Actual Average Net Operating Heat Rate Target found on page 21 of this Schedule.

****Mar - Dec values are set equal to targets at actual conditions for Daniel 2

Actual Values of
 Target Heat Rate Equation Parameters
 for January 2004 - December 2004

| | Jan/Jul | Feb/Aug | Mar/Sep | Apr/Oct | May/Nov | Jun/Dec |
|----------------|----------|----------|----------|----------|----------|----------|
| Crist 4 | | | | | | |
| | +3 | | | | | |
| AKW * 10 | 67.0 | 71.5 | 73.9 | 71.9 | 65.2 | 65.3 |
| | 66.8 | 68.3 | 63.6 | 70.7 | 68.3 | 65.2 |
| | +6 | | | | | |
| LSRF * 10 | 4632.9 | 5182.7 | 5528.5 | 5277.8 | 4424.9 | 4423.8 |
| | 4624.1 | 4791.4 | 4237.6 | 5104.8 | 4813.7 | 4381.6 |
| Crist 5 | | | | | | |
| | +3 | | | | | |
| AKW * 10 | 65.9 | 68.7 | 74.0 | 71.9 | 65.3 | 66.4 |
| | 66.2 | 69.3 | 63.2 | 70.8 | 67.1 | 64.1 |
| | +6 | | | | | |
| LSRF * 10 | 4502.2 | 4802.7 | 5538.0 | 5274.4 | 4449.4 | 4577.6 |
| | 4556.9 | 4948.2 | 4177.1 | 5118.5 | 4647.2 | 4244.2 |
| Crist 6 | | | | | | |
| | +3 | | | | | |
| AKW * 10 | 64.6 | 278.2 | 275.7 | 248.8 | 238.1 | 248.7 |
| | 246.5 | 265.1 | 223.4 | 281.8 | 261.3 | 274.2 |
| | +6 | | | | | |
| LSRF * 10 | 3496.6 | 79537.5 | 78142.2 | 69425.2 | 61689.0 | 67129.9 |
| | 65746.1 | 73940.7 | 55761.7 | 81673.3 | 72946.2 | 78295.6 |
| Crist 7 | | | | | | |
| | +3 | | | | | |
| AKW * 10 | 422.3 | 446.4 | 0.0 | 435.1 | 384.9 | 379.5 |
| | 398.3 | 384.5 | 388.4 | 433.4 | 437.6 | 442.3 |
| | +6 | | | | | |
| LSRF * 10 | 186771.1 | 207340.7 | 0.0 | 126623.9 | 161545.7 | 157667.3 |
| | 170794.4 | 158850.1 | 164260.8 | 195376.9 | 200544.8 | 200937.2 |
| Smith 1 | | | | | | |
| | +3 | | | | | |
| AKW * 10 | 133.1 | 147.4 | 153.7 | 147.1 | 129.3 | 132.5 |
| | 132.8 | 143.3 | 128.8 | 151.3 | 143.8 | 146.8 |
| | +6 | | | | | |
| LSRF * 10 | 18974.8 | 22355.7 | 24110.3 | 22482.4 | 18323.6 | 19079.6 |
| | 19239.6 | 21621.7 | 18305.3 | 23492.4 | 21658.5 | 22370.8 |
| Smith 2 | | | | | | |
| | +3 | | | | | |
| AKW * 10 | 152.7 | 168.4 | 173.7 | 163.4 | 143.3 | 147.3 |
| | 149.3 | 162.3 | 144.7 | 173.4 | 169.7 | 168.7 |
| | +6 | | | | | |
| LSRF * 10 | 24858.0 | 29178.0 | 30877.6 | 28226.9 | 22873.9 | 23982.6 |
| | 24637.2 | 27836.2 | 23495.3 | 30856.0 | 29786.0 | 29395.1 |

Actual Values of
Target Heat Rate Equation Parameters
for January 2004 - December 2004

| | Jan/Jul | Feb/Aug | Mar/Sep | Apr/Oct | May/Nov | Jun/Dec |
|-----------|----------|----------|----------|----------|----------|----------|
| Daniel 1 | | | | | | |
| +3 | | | | | | |
| AKW * 10 | 488.7 | 486.1 | 477.8 | 467.5 | 420.4 | 462.1 |
| | 485.6 | 456.8 | 428.3 | 441.3 | 328.5 | 471.8 |
| +6 | | | | | | |
| LSRF * 10 | 244843.7 | 242265.7 | 235109.7 | 227201.2 | 194781.3 | 223879.8 |
| | 240891.3 | 217037.5 | 199433.6 | 212699.7 | 134290.3 | 231775.1 |
| Daniel 2 | | | | | | |
| +3 | | | | | | |
| AKW * 10 | 463.2 | 493.8 | 482.1 | 481.6 | 436.1 | 461.8 |
| | 465.7 | 468.9 | 431.8 | 464.8 | 477.2 | 483.8 |
| +6 | | | | | | |
| LSRF * 10 | 226114.7 | 247007.7 | 237783.9 | 237108.6 | 203034.5 | 221969.7 |
| | 224469.7 | 229440.9 | 201449.8 | 231511.8 | 234309.9 | 238620.1 |

Target Heat Rate Equations

Crist 4 ANOHR = $10^6 / AKW * [617.42 + 9.96 * MAR - 23.05 * NOV]$
 $- 8329 + 0.13863 * LSRF / AKW$

Crist 5 ANOHR = $10^6 / AKW * [-136.85 - 13.15 * OCT - 21.65 * NOV]$
 $+ 18,611 - 0.08694 * LSRF / AKW$

Crist 6 ANOHR = $10^6 / AKW * [1069.69 + 44.52 * MAR - 33.07 * MAY + 30.91 * AUG]$
 $+ 844 + 0.02012 * LSRF / AKW$

Crist 7 ANOHR = $10^6 / AKW * [349.83 - 96.07 * MAR + 61.52 * JUN + 115.03 * JUL + 78.38 * AUG + 90.36 * SEP + 64.01 * NOV]$
 $+ 9,387$

Smith 1 ANOHR = $10^6 / AKW * [111.12 - 22.83 * JAN - 27.46 * FEB + 17.98 * APR]$
 $+ 9,412$

Smith 2 ANOHR = $10^6 / AKW * [139.59 - 38.77 * JAN - 43.18 * FEB - 42.50 * MAR - 16.17 * MAY + 27.46 * JUL + 19.26 * AUG]$
 $+ 9,289$

Daniel 1 ANOHR = $10^6 / AKW * [-528.45 - 59.78 * MAY + 139.64 * JUL + 75.47 * AUG]$
 $+ 15.490 - 0.00906 * LSRF / AKW$

Daniel 2 ANOHR = $10^6 / AKW * [571.00 - 118.56 * JAN - 87.31 * FEB - 88.00 * MAR - 88.36 * NOV]$
 $+ 8,698$

Where:

| | |
|-------|---|
| ANOHR | Average Net Operating Heat Rate, BTU/KWH |
| AKW | Average Kilowatt Load, KW |
| LSRF | Load Square Range Factor, KW ² |
| JAN | January, 0 if not January, 1 if January |
| FEB | February, 0 if not February, 1 if February |
| MAR | March, 0 if not March, 1 if March |
| APR | April, 0 if not April, 1 if April |
| MAY | May, 0 if not May, 1 if May |
| JUN | June, 0 if not June, 1 if June |
| JUL | July, 0 if not July, 1 if July |
| AUG | August, 0 if not August, 1 if August |
| SEP | September, 0 if not September, 1 if September |
| OCT | October, 0 if not October, 1 if October |
| NOV | November, 0 if not November, 1 if November |

Calculation of Heat Rate Points
for January 2004 - December 2004

| (1) | (2) | (3) | (4) | (5) |
|----------|---|--|-------------------------------------|------------------------|
| Unit | Average Net Operating Heat Rate Target* | Net Operating Heat Rate Adjusted to Target Basis** | Minimum Attainable Heat Rate* | Heat Rate Points*** |
| Crist 4 | 10388 | 10480 | 10076 | -0.72 |
| Crist 5 | 10232 | 10395 | 9925 | -3.79 |
| Crist 6 | 10501 | 10192 | 10186 | 9.75 |
| Crist 7 | 10223 | 10239 | 9916 | 0.00 |
| Smith 1 | 10114 | 10131 | 9811 | 0.00 |
| Smith 2 | 10024 | 10257 | 9723 | -6.99 |
| Daniel 1 | 9994 | 10072 | 9694 | -0.13 |
| Daniel 2 | 9828 | 9789 | 9533 | 0.00 |

* From page 5, Schedule 3 of Exhibit to L. S. Noack's
September 12, 2003 GPIF testimony in Docket 030001-EI.

** Refer to pages 10 through 17 of this Schedule for calculation.

*** If [(2) - 75] <= (3) <= [(2) + 75] then points = 0

If [(2) - (3) - 75] > 0 then points = $\frac{(2) - (3) - 75}{(2) - (4) - 75} * 10$

If [(2) - (3) + 75] < 0 then points = $\frac{(2) - (3) + 75}{(2) - (4) - 75} * 10$

Florida Public Service Commission
Docket No. 050001-EI
Gulf Power Company
Witness: L. S. Noack
Exhibit No. ____ (LSN-1)
Schedule 4
Page 1 of 2

IV. CALCULATION OF COMPANY GPIF POINTS AND REWARD/PENALTY

Calculation of Heat Rate Points
GPIF Points and Reward or Penalty
for January 2004 - December 2004

| Unit | Availability Points | Availability* Weighting Factor | Heat Rate Points | Heat Rate* Weighting Factor |
|----------|------------------------|-----------------------------------|---------------------|--------------------------------|
| Crist 4 | 10.00 | 0.001 | -0.72 | 0.040 |
| Crist 5 | 10.00 | 0.002 | -3.79 | 0.038 |
| Crist 6 | -10.00 | 0.015 | 9.75 | 0.154 |
| Crist 7 | 0.00 | 0.084 | 0.00 | 0.191 |
| Smith 1 | 10.00 | 0.006 | 0.00 | 0.080 |
| Smith 2 | 10.00 | 0.024 | -6.99 | 0.079 |
| Daniel 1 | 7.50 | 0.053 | -0.13 | 0.075 |
| Daniel 2 | 10.00 | 0.057 | 0.00 | 0.100 |

$$\begin{aligned}
\text{Company GPIF Points} = & + 10.00 * 0.001 - 0.72 * 0.040 \\
& + 10.00 * 0.002 - 3.79 * 0.038 \\
& - 10.00 * 0.015 + 9.75 * 0.154 \\
& + 0.00 * 0.084 + 0.00 * 0.191 \\
& + 10.00 * 0.006 + 0.00 * 0.080 \\
& + 10.00 * 0.024 - 6.99 * 0.079 \\
& + 7.50 * 0.053 - 0.13 * 0.075 \\
& + 10.00 * 0.057 + 0.00 * 0.100 \\
= & 1.91
\end{aligned}$$

$$\begin{aligned}
\text{Company reward/penalty} = & 1.91 \text{ points} * \$231407 \text{ per point} \\
= & \$441,988
\end{aligned}$$

* From page 5, Schedule 3 of Exhibit to L. S. Noack's
September 12, 2003 GPIF testimony in Docket 030001-EI

V. GPIF MINIMUM FILING REQUIREMENTS FOR THE JANUARY 2004 - DECEMBER 2004 PERIOD

| CONTENTS | SCHEDULE 5 <u>PAGE</u> |
|--|---------------------------|
| GPIF Reward/Penalty Table (Actual) | 3 |
| GPIF Calculation of Maximum Allowed Incentive Dollars (Actual) | 4 |
| Calculation of System Actual GPIF Points | 5 |
| Generating Performance Incentive Points Table | 6 - 13 |
| GPIF Unit Performance Summary | 14 |
| Actual Unit Performance Data | 15 |
| Historic Unit Performance Data | 16 - 31 |
| Planned Outage Schedules (Actual) | 32 |

Generating Performance Incentive Factor

Actual Reward/Penalty Table

Gulf Power Company

Period of: January 2004 - December 2004

| Generating Performance Incentive Factor Points | Fuel Saving/Loss (\$000) | Generating Performance Incentive Factor (\$000) |
|--|---------------------------------------|---|
| | Maximum Attainable Fuel Savings | Maximum Incentive Dollars Allowed by Commission During Period (Reward) |
| + 10 | 5678 | 2314 |
| + 9 | 5110 | 2083 |
| + 8 | 4542 | 1851 |
| + 7 | 3975 | 1620 |
| + 6 | 3407 | 1388 |
| + 5 | 2839 | 1157 |
| + 4 | 2271 | 926 |
| + 3 | 1703 | 694 |
| + 2 | 1136 | 463 |
| + 1 | 568 | 231 |
| 0 | 0 | 0 |
| - 1 | -638 | -231 |
| - 2 | -1275 | -463 |
| - 3 | -1913 | -694 |
| - 4 | -2551 | -926 |
| - 5 | -3189 | -1157 |
| - 6 | -3826 | -1388 |
| - 7 | -4464 | -1620 |
| - 8 | -5102 | -1851 |
| - 9 | -5739 | -2083 |
| - 10 | -6377 | -2314 |
| | Minimum Attainable Fuel Loss | Maximum Incentive Dollars Allowed by Commission During Period (Penalty) |

Issued by: S. N. Story

Page 3 of 32
Schedule 5

Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

Generating Performance Incentive Factor
Calculation of Maximum Allowed Incentive Dollars

Actual

Gulf Power Company

Period of: January 2004 - December 2004

| | | |
|---------|--|----------------|
| Line 1 | Beginning of Period Balance of Common Equity | \$561,357,935 |
| | End of Month Balance of Common Equity: | |
| Line 2 | Month of Jan '04 | \$594,083,709 |
| Line 3 | Month of Feb '04 | \$583,098,084 |
| Line 4 | Month of Mar '04 | \$587,546,853 |
| Line 5 | Month of Apr '04 | \$572,021,569 |
| Line 6 | Month of May '04 | \$580,696,217 |
| Line 7 | Month of Jun '04 | \$589,219,105 |
| Line 8 | Month of Jul '04 | \$585,443,104 |
| Line 9 | Month of Aug '04 | \$596,481,686 |
| Line 10 | Month of Sep '04 | \$605,017,259 |
| Line 11 | Month of Oct '04 | \$592,392,397 |
| Line 12 | Month of Nov '04 | \$594,051,062 |
| Line 13 | Month of Dec '04 | \$593,193,746 |
| Line 14 | Average Common Equity for the Period (sum of line 1 through line 13 divided by 13) | \$587,277,133 |
| Line 15 | 25 Basis Points | 0.0025 |
| Line 16 | Revenue Expansion Factor | 61.3808% |
| Line 17 | Maximum Allowed Incentive Dollars (line 14 multiplied by line 15 divided by line 16 multiplied by 1.0) | \$2,391,943 |
| Line 18 | Jurisdictional Sales (KWH) | 11,046,409,000 |
| Line 19 | Total Territorial Sales (KWH) | 11,418,120,000 |
| Line 20 | Jurisdictional Separation Factor (line 18 divided by line 19) | 96.7446% |
| Line 21 | Maximum Allowed Jurisdictional Incentive Dollars (line 17 multiplied by line 20) | \$2,314,074 |

Issued by: S. N. Story

Page 4 of 32
Schedule 5

Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

Calculation of System Actual GPIF Points

Gulf Power Company

Period of: January 2004 - December 2004

| Plant & Unit | Performance Indicator (EAF or ANOHR) | Weighting Factor | Unit Points | Weighted Unit Points |
|-----------------------|--|---------------------|----------------|----------------------------|
| Crist 4 | EAF1 | 0.1% | 10.00 | 0.010 |
| Crist 4 | ANOHR1 | 4.0% | -0.72 | -0.029 |
| Crist 5 | EAF2 | 0.2% | 10.00 | 0.020 |
| Crist 5 | ANOHR2 | 3.8% | -3.79 | -0.144 |
| Crist 6 | EAF3 | 1.5% | -10.00 | -0.150 |
| Crist 6 | ANOHR3 | 15.4% | 9.75 | 1.502 |
| Crist 7 | EAF4 | 8.4% | 0.00 | 0.000 |
| Crist 7 | ANOHR4 | 19.1% | 0.00 | 0.000 |
| Smith 1 | EAF5 | 0.6% | 10.00 | 0.060 |
| Smith 1 | ANOHR5 | 8.0% | 0.00 | 0.000 |
| Smith 2 | EAF6 | 2.4% | 10.00 | 0.240 |
| Smith 2 | ANOHR6 | 7.9% | -6.99 | -0.552 |
| Daniel 1 | EAF7 | 5.3% | 7.50 | 0.398 |
| Daniel 1 | ANOHR7 | 7.5% | -0.13 | -0.010 |
| Daniel 2 | EAF8 | 5.7% | 10.00 | 0.570 |
| Daniel 2 | ANOHR8 | 10.0% | 0.00 | 0.000 |
| Gulf Power GPIF Total | | 99.9% | | 1.91 |

Issued by: S. N. Story

Page 5 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

Generating Performance Incentive Points Table

Gulf Power Company

Period of: January 2004 - December 2004

Crist 4

| Equivalent Availability Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Equivalent Availability | Average Heat Rate Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Heat Rate |
|--------------------------------------|-------------------------------------|--|--------------------------------|-------------------------------------|---------------------------------|
| + 10 | 8 | 98.50 | + 10 | 229 | 10,076 |
| + 9 | 7 | 98.44 | + 9 | 206 | 10,100 |
| + 8 | 6 | 98.38 | + 8 | 183 | 10,123 |
| + 7 | 6 | 98.32 | + 7 | 160 | 10,147 |
| + 6 | 5 | 98.26 | + 6 | 137 | 10,171 |
| + 5 | 4 | 98.20 | + 5 | 115 | 10,195 |
| + 4 | 3 | 98.14 | + 4 | 92 | 10,218 |
| + 3 | 2 | 98.08 | + 3 | 69 | 10,242 |
| + 2 | 2 | 98.02 | + 2 | 46 | 10,266 |
| + 1 | 1 | 97.96 | + 1 | 23 | 10,289 |
| 0 | 0 | 97.90 | 0 | 0 | 10,313 |
| | | | | 0 | 10,388 |
| | | | | 0 | 10,463 |
| - 1 | (1) | 97.80 | - 1 | (23) | 10,487 |
| - 2 | (2) | 97.70 | - 2 | (46) | 10,510 |
| - 3 | (3) | 97.60 | - 3 | (69) | 10,534 |
| - 4 | (4) | 97.50 | - 4 | (92) | 10,558 |
| - 5 | (5) | 97.40 | - 5 | (115) | 10,582 |
| - 6 | (5) | 97.30 | - 6 | (137) | 10,605 |
| - 7 | (6) | 97.20 | - 7 | (160) | 10,629 |
| - 8 | (7) | 97.10 | - 8 | (183) | 10,653 |
| - 9 | (8) | 97.00 | - 9 | (206) | 10,676 |
| - 10 | (9) | 96.90 | - 10 | (229) | 10,700 |

Weighting Factor: 0.001

Weighting Factor: 0.040

Issued by: S. N. Story

Page 6 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

Generating Performance Incentive Points Table

Gulf Power Company

Period of: January 2004 - December 2004

Crist 5

| Equivalent Availability Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Equivalent Availability | Average Heat Rate Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Heat Rate |
|--------------------------------------|-------------------------------------|--|--------------------------------|-------------------------------------|---------------------------------|
| + 10 | 14 | 97.70 | + 10 | 216 | 9,925 |
| + 9 | 13 | 97.61 | + 9 | 194 | 9,948 |
| + 8 | 11 | 97.52 | + 8 | 173 | 9,971 |
| + 7 | 10 | 97.43 | + 7 | 151 | 9,995 |
| + 6 | 8 | 97.34 | + 6 | 130 | 10,018 |
| + 5 | 7 | 97.25 | + 5 | 108 | 10,041 |
| + 4 | 6 | 97.16 | + 4 | 86 | 10,064 |
| + 3 | 4 | 97.07 | + 3 | 65 | 10,087 |
| + 2 | 3 | 96.98 | + 2 | 43 | 10,111 |
| + 1 | 1 | 96.89 | + 1 | 22 | 10,134 |
| 0 | 0 | 96.80 | 0 | 0 | 10,157 |
| | | | | 0 | 10,232 |
| | | | | 0 | 10,307 |
| - 1 | (2) | 96.65 | - 1 | (22) | 10,330 |
| - 2 | (4) | 96.50 | - 2 | (43) | 10,353 |
| - 3 | (6) | 96.35 | - 3 | (65) | 10,377 |
| - 4 | (8) | 96.20 | - 4 | (86) | 10,400 |
| - 5 | (10) | 96.05 | - 5 | (108) | 10,423 |
| - 6 | (11) | 95.90 | - 6 | (130) | 10,446 |
| - 7 | (13) | 95.75 | - 7 | (151) | 10,469 |
| - 8 | (15) | 95.60 | - 8 | (173) | 10,493 |
| - 9 | (17) | 95.45 | - 9 | (194) | 10,516 |
| - 10 | (19) | 95.30 | - 10 | (216) | 10,539 |
| Weighting Factor: | | 0.002 | Weighting Factor: | | 0.038 |

Issued by: S. N. Story

Page 7 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

Generating Performance Incentive Points Table

Gulf Power Company

Period of: January 2004 - December 2004

Crist 6

| Equivalent Availability Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Equivalent Availability | Average Heat Rate Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Heat Rate |
|--------------------------------------|-------------------------------------|--|--------------------------------|-------------------------------------|---------------------------------|
| + 10 | 84 | 88.80 | + 10 | 876 | 10,186 |
| + 9 | 76 | 88.59 | + 9 | 788 | 10,210 |
| + 8 | 67 | 88.38 | + 8 | 701 | 10,234 |
| + 7 | 59 | 88.17 | + 7 | 613 | 10,258 |
| + 6 | 50 | 87.96 | + 6 | 526 | 10,282 |
| + 5 | 42 | 87.75 | + 5 | 438 | 10,306 |
| + 4 | 34 | 87.54 | + 4 | 350 | 10,330 |
| + 3 | 25 | 87.33 | + 3 | 263 | 10,354 |
| + 2 | 17 | 87.12 | + 2 | 175 | 10,378 |
| + 1 | 8 | 86.91 | + 1 | 88 | 10,402 |
| 0 | 0 | 86.70 | 0 | 0 | 10,426 |
| | | | | 0 | 10,501 |
| | | | | 0 | 10,576 |
| - 1 | (15) | 86.39 | - 1 | (88) | 10,600 |
| - 2 | (29) | 86.08 | - 2 | (175) | 10,624 |
| - 3 | (44) | 85.77 | - 3 | (263) | 10,648 |
| - 4 | (59) | 85.46 | - 4 | (350) | 10,672 |
| - 5 | (74) | 85.15 | - 5 | (438) | 10,696 |
| - 6 | (88) | 84.84 | - 6 | (526) | 10,720 |
| - 7 | (103) | 84.53 | - 7 | (613) | 10,744 |
| - 8 | (118) | 84.22 | - 8 | (701) | 10,768 |
| - 9 | (132) | 83.91 | - 9 | (788) | 10,792 |
| - 10 | (147) | 83.60 | - 10 | (876) | 10,816 |
| Weighting Factor: | | 0.015 | Weighting Factor: | | 0.154 |

Issued by: S. N. Story

Page 8 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

Generating Performance Incentive Points Table

Gulf Power Company

Period of: January 2004 - December 2004

Crist 7

| Equivalent Availability Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Equivalent Availability | Average Heat Rate Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Heat Rate |
|--------------------------------------|-------------------------------------|--|--------------------------------|-------------------------------------|---------------------------------|
| + 10 | 477 | 72.60 | + 10 | 1,086 | 9,916 |
| + 9 | 429 | 72.35 | + 9 | 977 | 9,939 |
| + 8 | 382 | 72.10 | + 8 | 869 | 9,962 |
| + 7 | 334 | 71.85 | + 7 | 760 | 9,986 |
| + 6 | 286 | 71.60 | + 6 | 652 | 10,009 |
| + 5 | 239 | 71.35 | + 5 | 543 | 10,032 |
| + 4 | 191 | 71.10 | + 4 | 434 | 10,055 |
| + 3 | 143 | 70.85 | + 3 | 326 | 10,078 |
| + 2 | 95 | 70.60 | + 2 | 217 | 10,102 |
| + 1 | 48 | 70.35 | + 1 | 109 | 10,125 |
| | | | | 0 | 10,148 |
| 0 | 0 | 70.10 | 0 | 0 | 10,223 |
| | | | | 0 | 10,298 |
| - 1 | (63) | 69.72 | - 1 | (109) | 10,321 |
| - 2 | (127) | 69.34 | - 2 | (217) | 10,344 |
| - 3 | (190) | 68.96 | - 3 | (326) | 10,368 |
| - 4 | (254) | 68.58 | - 4 | (434) | 10,391 |
| - 5 | (317) | 68.20 | - 5 | (543) | 10,414 |
| - 6 | (380) | 67.82 | - 6 | (652) | 10,437 |
| - 7 | (444) | 67.44 | - 7 | (760) | 10,460 |
| - 8 | (507) | 67.06 | - 8 | (869) | 10,484 |
| - 9 | (571) | 66.68 | - 9 | (977) | 10,507 |
| - 10 | (634) | 66.30 | - 10 | (1,086) | 10,530 |
| Weighting Factor: | | 0.084 | Weighting Factor: | | 0.191 |

Issued by: S. N. Story

Page 9 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

Generating Performance Incentive Points Table

Gulf Power Company

Period of: January 2004 - December 2004

Smith 1

| Equivalent Availability Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Equivalent Availability | Average Heat Rate Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Heat Rate |
|--------------------------------------|-------------------------------------|--|--------------------------------|-------------------------------------|---------------------------------|
| + 10 | 32 | 90.60 | + 10 | 454 | 9,811 |
| + 9 | 29 | 90.55 | + 9 | 409 | 9,834 |
| + 8 | 26 | 90.50 | + 8 | 363 | 9,857 |
| + 7 | 22 | 90.45 | + 7 | 318 | 9,879 |
| + 6 | 19 | 90.40 | + 6 | 272 | 9,902 |
| + 5 | 16 | 90.35 | + 5 | 227 | 9,925 |
| + 4 | 13 | 90.30 | + 4 | 182 | 9,948 |
| + 3 | 10 | 90.25 | + 3 | 136 | 9,971 |
| + 2 | 6 | 90.20 | + 2 | 91 | 9,993 |
| + 1 | 3 | 90.15 | + 1 | 45 | 10,016 |
| 0 | 0 | 90.10 | 0 | 0 | 10,039 |
| | | | | 0 | 10,114 |
| | | | | 0 | 10,189 |
| - 1 | (3) | 90.02 | - 1 | (45) | 10,212 |
| - 2 | (6) | 89.94 | - 2 | (91) | 10,235 |
| - 3 | (10) | 89.86 | - 3 | (136) | 10,257 |
| - 4 | (13) | 89.78 | - 4 | (182) | 10,280 |
| - 5 | (16) | 89.70 | - 5 | (227) | 10,303 |
| - 6 | (19) | 89.62 | - 6 | (272) | 10,326 |
| - 7 | (22) | 89.54 | - 7 | (318) | 10,349 |
| - 8 | (26) | 89.46 | - 8 | (363) | 10,371 |
| - 9 | (29) | 89.38 | - 9 | (409) | 10,394 |
| - 10 | (32) | 89.30 | - 10 | (454) | 10,417 |
| Weighting Factor: | | 0.006 | Weighting Factor: | | 0.080 |

Issued by: S. N. Story

Page 10 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

Generating Performance Incentive Points Table

Gulf Power Company

Period of: January 2004 - December 2004

Smith 2

| Equivalent Availability Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Equivalent Availability | Average Heat Rate Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Heat Rate |
|--------------------------------------|-------------------------------------|--|--------------------------------|-------------------------------------|---------------------------------|
| + 10 | 134 | 85.50 | + 10 | 449 | 9,723 |
| + 9 | 121 | 85.23 | + 9 | 404 | 9,746 |
| + 8 | 107 | 84.96 | + 8 | 359 | 9,768 |
| + 7 | 94 | 84.69 | + 7 | 314 | 9,791 |
| + 6 | 80 | 84.42 | + 6 | 269 | 9,813 |
| + 5 | 67 | 84.15 | + 5 | 225 | 9,836 |
| + 4 | 54 | 83.88 | + 4 | 180 | 9,859 |
| + 3 | 40 | 83.61 | + 3 | 135 | 9,881 |
| + 2 | 27 | 83.34 | + 2 | 90 | 9,904 |
| + 1 | 13 | 83.07 | + 1 | 45 | 9,926 |
| 0 | 0 | 82.80 | 0 | 0 | 9,949 |
| | | | | 0 | 10,024 |
| | | | | 0 | 10,099 |
| - 1 | (23) | 82.40 | - 1 | (45) | 10,122 |
| - 2 | (45) | 82.00 | - 2 | (90) | 10,144 |
| - 3 | (68) | 81.60 | - 3 | (135) | 10,167 |
| - 4 | (91) | 81.20 | - 4 | (180) | 10,189 |
| - 5 | (114) | 80.80 | - 5 | (225) | 10,212 |
| - 6 | (136) | 80.40 | - 6 | (269) | 10,235 |
| - 7 | (159) | 80.00 | - 7 | (314) | 10,257 |
| - 8 | (182) | 79.60 | - 8 | (359) | 10,280 |
| - 9 | (204) | 79.20 | - 9 | (404) | 10,302 |
| - 10 | (227) | 78.80 | - 10 | (449) | 10,325 |
| Weighting Factor: | | 0.024 | Weighting Factor: | | 0.079 |

Issued by: S. N. Story

Page 11 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

Generating Performance Incentive Points Table

Gulf Power Company

Period of: January 2004 - December 2004

Daniel 1

| Equivalent Availability Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Equivalent Availability | Average Heat Rate Points | Fuel Savings/ Loss (\$000) | Adjusted Actual Heat Rate |
|--------------------------------------|-------------------------------------|--|--------------------------------|-------------------------------------|---------------------------------|
| + 10 | 299 | 71.20 | + 10 | 428 | 9,694 |
| + 9 | 269 | 71.04 | + 9 | 385 | 9,717 |
| + 8 | 239 | 70.88 | + 8 | 342 | 9,739 |
| + 7 | 209 | 70.72 | + 7 | 300 | 9,762 |
| + 6 | 179 | 70.56 | + 6 | 257 | 9,784 |
| + 5 | 150 | 70.40 | + 5 | 214 | 9,807 |
| + 4 | 120 | 70.24 | + 4 | 171 | 9,829 |
| + 3 | 90 | 70.08 | + 3 | 128 | 9,852 |
| + 2 | 60 | 69.92 | + 2 | 86 | 9,874 |
| + 1 | 30 | 69.76 | + 1 | 43 | 9,897 |
| 0 | 0 | 69.60 | 0 | 0 | 9,919 |
| | | | | 0 | 9,994 |
| | | | | 0 | 10,069 |
| - 1 | (45) | 69.34 | - 1 | (43) | 10,092 |
| - 2 | (91) | 69.08 | - 2 | (86) | 10,114 |
| - 3 | (136) | 68.82 | - 3 | (128) | 10,137 |
| - 4 | (181) | 68.56 | - 4 | (171) | 10,159 |
| - 5 | (227) | 68.30 | - 5 | (214) | 10,182 |
| - 6 | (272) | 68.04 | - 6 | (257) | 10,204 |
| - 7 | (317) | 67.78 | - 7 | (300) | 10,227 |
| - 8 | (362) | 67.52 | - 8 | (342) | 10,249 |
| - 9 | (408) | 67.26 | - 9 | (385) | 10,272 |
| - 10 | (453) | 67.00 | - 10 | (428) | 10,294 |
| Weighting Factor: | | 0.053 | Weighting Factor: | | 0.075 |

Issued by: S. N. Story

Page 12 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

Generating Performance Incentive Points Table

Gulf Power Company

Period of: January 2004 - December 2004

Daniel 2

| Equivalent Availability Points | Fuel Savings/Loss (\$000) | Adjusted Actual Equivalent Availability | Average Heat Rate Points | Fuel Savings/Loss (\$000) | Adjusted Actual Heat Rate |
|--------------------------------|---------------------------|---|--------------------------|---------------------------|---------------------------|
| + 10 | 324 | 83.20 | + 10 | 568 | 9,533 |
| + 9 | 292 | 82.99 | + 9 | 511 | 9,555 |
| + 8 | 259 | 82.78 | + 8 | 454 | 9,577 |
| + 7 | 227 | 82.57 | + 7 | 398 | 9,599 |
| + 6 | 194 | 82.36 | + 6 | 341 | 9,621 |
| + 5 | 162 | 82.15 | + 5 | 284 | 9,643 |
| + 4 | 130 | 81.94 | + 4 | 227 | 9,665 |
| + 3 | 97 | 81.73 | + 3 | 170 | 9,687 |
| + 2 | 65 | 81.52 | + 2 | 114 | 9,709 |
| + 1 | 32 | 81.31 | + 1 | 57 | 9,731 |
| 0 | 0 | 81.10 | 0 | 0 | 9,753 |
| | | | | 0 | 9,828 |
| | | | | 0 | 9,903 |
| - 1 | (55) | 80.79 | - 1 | (57) | 9,925 |
| - 2 | (110) | 80.48 | - 2 | (114) | 9,947 |
| - 3 | (165) | 80.17 | - 3 | (170) | 9,969 |
| - 4 | (220) | 79.86 | - 4 | (227) | 9,991 |
| - 5 | (275) | 79.55 | - 5 | (284) | 10,013 |
| - 6 | (330) | 79.24 | - 6 | (341) | 10,035 |
| - 7 | (385) | 78.93 | - 7 | (398) | 10,057 |
| - 8 | (440) | 78.62 | - 8 | (454) | 10,079 |
| - 9 | (495) | 78.31 | - 9 | (511) | 10,101 |
| - 10 | (550) | 78.00 | - 10 | (568) | 10,123 |
| Weighting Factor: | | 0.057 | Weighting Factor: | | 0.100 |

Issued by: S. N. Story

Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

GPIF Unit Performance Summary

Gulf Power Company

Period of: January 2004 - December 2004

| Plant & Unit | Weighting Factor % | EAF Target % | EAF Range | | Max Fuel Savings (\$000) | Max Fuel Loss (\$000) | EAF Adjusted Actual % | Actual Fuel Savings/ Loss (\$000) |
|--------------------|--------------------------|--------------------|-----------|----------|-----------------------------------|--------------------------------|--------------------------------|---|
| | | | Max % | Min % | | | | |
| Crist 4 | 0.1 | 97.9 | 98.5 | 96.9 | 8.0 | (\$9) | 98.5 | \$8 |
| Crist 5 | 0.2 | 96.8 | 97.7 | 95.3 | 14.0 | (\$19) | 98.7 | \$14 |
| Crist 6 | 1.5 | 86.7 | 88.8 | 83.6 | 84.0 | (\$147) | 75.5 | (\$147) |
| Crist 7 | 8.4 | 70.1 | 72.6 | 66.3 | 477.0 | (\$634) | 70.1 | \$0 |
| Smith 1 | 0.6 | 90.1 | 90.6 | 89.3 | 32.0 | (\$32) | 91.6 | \$32 |
| Smith 2 | 2.4 | 82.8 | 85.5 | 78.8 | 134.0 | (\$227) | 90.4 | \$134 |
| Daniel 1 | 5.3 | 69.6 | 71.2 | 67.0 | 299.0 | (\$453) | 70.8 | \$224 |
| Daniel 2 | 5.7 | 81.1 | 83.2 | 78.0 | 324.0 | (\$550) | 85.3 | \$324 |
| Total: | 24.2 | | | | | | | |

| Plant & Unit | Weighting Factor % | ANOHR Target BTU/KWH | Target NOF | ANOHR Range | | Max Fuel Savings (\$000) | Max Fuel Loss (\$000) | ANOHR Adjusted Actual BTU/KWH | Actual Fuel Savings/ Loss (\$000) |
|--------------------|--------------------------|----------------------------|---------------|----------------|----------------|-----------------------------------|--------------------------------|--|---|
| | | | | Max BTU/KWH | Min BTU/KWH | | | | |
| Crist 4 | 4.0 | 10,388 | 93.9 | 10,700 | 10,076 | \$229 | (\$229) | 10,480 | (\$16) |
| Crist 5 | 3.8 | 10,232 | 92.1 | 10,539 | 9,925 | \$216 | (\$216) | 10,395 | (\$82) |
| Crist 6 | 15.4 | 10,501 | 96.5 | 10,816 | 10,186 | \$876 | (\$876) | 10,192 | \$854 |
| Crist 7 | 19.1 | 10,223 | 99.1 | 10,530 | 9,916 | \$1,086 | (\$1,086) | 10,239 | \$0 |
| Smith 1 | 8.0 | 10,114 | 95.7 | 10,417 | 9,811 | \$454 | (\$454) | 10,131 | \$0 |
| Smith 2 | 7.9 | 10,024 | 95.2 | 10,325 | 9,723 | \$449 | (\$449) | 10,257 | (\$314) |
| Daniel 1 | 7.5 | 9,994 | 94.3 | 10,294 | 9,694 | \$428 | (\$428) | 10,072 | (\$6) |
| Daniel 2 | 10.0 | 9,828 | 94.7 | 10,123 | 9,533 | \$568 | (\$568) | 9,789 | \$0 |
| Total: | 75.7 | | | | | | | | |

Issued by: S. N. Story

Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

Actual Unit Performance Data

Gulf Power Company

Period of: January 2004 - December 2004

| Plant & | Actual EAF | Adjustments* to EAF | Adjusted Actual |
|------------|---------------|------------------------|--------------------|
| Crist 4 | 98.5 | 0.0 | 98.5 |
| Crist 5 | 98.7 | 0.0 | 98.7 |
| Crist 6 | 75.3 | 0.2 | 75.5 |
| Crist 7 | 69.8 | 0.3 | 70.1 |
| Smith 1 | 94.7 | -3.1 | 91.6 |
| Smith 2 | 94.6 | -4.2 | 90.4 |
| Daniel 1 | 78.2 | -7.4 | 70.8 |
| Daniel 2 | 95.2 | -9.9 | 85.3 |

| Plant & Unit | Actual ANOHR BTU/KWH | Adjustments** to ANOHR BTU/KWH | ANOHR Adjusted Actual BTU/KWH |
|--------------------|----------------------------|--------------------------------------|--|
| Crist 4 | 10,542 | -62 | 10,480 |
| Crist 5 | 10,629 | -234 | 10,395 |
| Crist 6 | 10,229 | -37 | 10,192 |
| Crist 7 | 10,365 | -126 | 10,239 |
| Smith 1 | 10,202 | -71 | 10,131 |
| Smith 2 | 10,353 | 96 | 10,257 |
| Daniel 1 | 10,066 | 6 | 10,072 |
| Daniel 2 | 9,833 | 44 | 9,789 |

* Refer to pages 3 through 10, Schedule 2.

** Refer to pages 10 through 17, Schedule 3

Issued by: S. N. Story

Page 15 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

| CRIST 4 | Jan '04 | Feb '04 | Mar '04 | Apr '04 | May '04 | Jun '04 | |
|---------------------|--|---------|---------|---------|---------|---------|--|
| 1. EAF (%) | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 96.2 | |
| 2. PH | 744.0 | 696.0 | 744.0 | 719.0 | 744.0 | 720.0 | |
| 3. SH | 744.0 | 696.0 | 744.0 | 719.0 | 744.0 | 692.9 | |
| 4. RSH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 5. UH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 27.1 | |
| 6. POH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 7. FOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 8. MOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 27.1 | |
| 9. PFOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 10. LR pf (MW) | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 11. PMOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 12. LR pm (MW) | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 13. NSC (MW) | 78.0 | 78.0 | 78.0 | 78.0 | 78.0 | 78.0 | |
| 14. Oper MBtu | 520852 | 515590 | 568887 | 540255 | 511404 | 481461 | |
| 15. Net Gen (MWH) | 49849 | 49777 | 55002 | 51719 | 48540 | 45249 | |
| 16. ANOHR (Btu/KWH) | 10449 | 10358 | 10343 | 10446 | 10536 | 10640 | |
| 17. NOF % | 85.9 | 91.7 | 94.8 | 92.2 | 83.6 | 83.7 | |
| 18. NPC (MW) | 78.0 | 78.0 | 78.0 | 78.0 | 78.0 | 78.0 | |
| 19. ANOHR Equation | $10^6 / AKW * [617.42 + 9.96 * MAR - 23.05 * NOV]$ $-8329 + 0.13863 * LSRF / AKW$ | | | | | | |

Issued by: S. N. Story

Page 16 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

| CRIST 4 | Jul '04 | Aug '04 | Sep '04 | Oct '04 | Nov '04 | Dec '04 | Total |
|---------------------|--|---------|---------|---------|---------|---------|---------|
| 1. EAF (%) | 100.0 | 100.0 | 91.1 | 100.0 | 100.0 | 94.5 | 98.5 |
| 2. PH | 744.0 | 744.0 | 720.0 | 745.0 | 720.0 | 744.0 | 8784.0 |
| 3. SH | 744.0 | 744.0 | 656.2 | 745.0 | 720.0 | 703.3 | 8652.4 |
| 4. RSH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 5. UH | 0.0 | 0.0 | 63.8 | 0.0 | 0.0 | 40.7 | 131.6 |
| 6. POH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 7. FOH | 0.0 | 0.0 | 63.8 | 0.0 | 0.0 | 0.0 | 63.8 |
| 8. MOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 40.7 | 67.8 |
| 9. PFOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 10. LR pf (MW) | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 11. PMOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 12. LR pm (MW) | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 13. NSC (MW) | | | | | | | |
| 14. Oper MBtu | 530572 | 540186 | 445134 | 558262 | 527905 | 480197 | 6220705 |
| 15. Net Gen (MWH) | 49709 | 50779 | 41712 | 52657 | 49209 | 45870 | 590072 |
| 16. ANOHR (Btu/KWH) | 10674 | 10638 | 10672 | 10602 | 10728 | 10469 | 10542 |
| 17. NOF % | 85.7 | 87.5 | 81.5 | 90.6 | 87.6 | 83.6 | 87.4 |
| 18. NPC (MW) | 78.0 | 78.0 | 78.0 | 78.0 | 78.0 | 78.0 | 78.0 |
| 19. ANOHR Equation | $10^6 / AKW * [617.42 + 9.96 * MAR - 23.05 * NOV]$ $-8329 + 0.13863 * LSRF / AKW$ | | | | | | |

Issued by: S. N. Story

Page 17 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

| CRIST 5 | Jan '04 | Feb '04 | Mar '04 | Apr '04 | May '04 | Jun '04 | |
|---------------------|---|---------|---------|---------|---------|---------|--|
| 1. EAF (%) | 100.0 | 95.5 | 100.0 | 100.0 | 100.0 | 100.0 | |
| 2. PH | 744.0 | 696.0 | 744.0 | 719.0 | 744.0 | 720.0 | |
| 3. SH | 744.0 | 669.9 | 744.0 | 719.0 | 744.0 | 720.0 | |
| 4. RSH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 5. UH | 0.0 | 26.1 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 6. POH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 7. FOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 8. MOH | 0.0 | 26.1 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 9. PFOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 10. LR pf (MW) | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 11. PMOH | 0.0 | 33.3 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 12. LR pm (MW) | 0.0 | 13.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 13. NSC (MW) | 80.0 | 80.0 | 80.0 | 80.0 | 80.0 | 80.0 | |
| 14. Oper MBtu | 511660 | 484136 | 570915 | 542432 | 517338 | 508030 | |
| 15. Net Gen (MWH) | 49022 | 46011 | 55051 | 51691 | 48611 | 47805 | |
| 16. ANOHR (Btu/KWH) | 10437 | 10522 | 10371 | 10494 | 10642 | 10627 | |
| 17. NOF % | 82.4 | 85.9 | 92.5 | 89.9 | 81.7 | 83.0 | |
| 18. NPC (MW) | 80.0 | 80.0 | 80.0 | 80.0 | 80.0 | 80.0 | |
| 19. ANOHR Equation | $10^6 / AKW * [-136.85 - 13.15 * OCT - 21.65 * NOV]$ $+ 18.611 - 0.08694 * LSRF / AKW$ | | | | | | |

Issued by: S. N. Story

Page 18 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

| | CRIST 5 | Jul '04 | Aug '04 | Sep '04 | Oct '04 | Nov '04 | Dec '04 | Total |
|-----|-----------------|---|---------|---------|---------|---------|---------|---------|
| 1 | EAF (%) | 100.0 | 96.3 | 92.3 | 100.0 | 100.0 | 99.8 | 98.7 |
| 2. | PH | 744.0 | 744.0 | 720.0 | 745.0 | 720.0 | 744.0 | 8784.0 |
| 3. | SH | 744.0 | 716.4 | 664.8 | 745.0 | 720.0 | 744.0 | 8675.1 |
| 4. | RSH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 5. | UH | 0.0 | 27.6 | 55.2 | 0.0 | 0.0 | 0.0 | 108.9 |
| 6. | POH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 7. | FOH | 0.0 | 0.0 | 55.2 | 0.0 | 0.0 | 0.0 | 55.2 |
| 8. | MOH | 0.0 | 27.6 | 0.0 | 0.0 | 0.0 | 0.0 | 53.7 |
| 9. | PFOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 3.2 | 3.2 |
| 10. | LR pf (MW) | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 35.0 | 35.0 |
| 11. | PMOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 33.3 |
| 12. | LR pm (MW) | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 13.0 |
| 13. | NSC (MW) | 80.0 | 80.0 | 80.0 | 80.0 | 80.0 | 80.0 | 80.0 |
| | Oper MBtu | 525981 | 524328 | 455618 | 573160 | 522127 | 513322 | 6249047 |
| | Net Gen (MWH) | 49266 | 49679 | 42018 | 52737 | 48318 | 47695 | 587904 |
| | ANOHR (Btu/KWH) | 10676 | 10554 | 10843 | 10868 | 10806 | 10763 | 10629 |
| | NOF % | 82.8 | 86.7 | 79.0 | 88.5 | 83.9 | 80.1 | 84.7 |
| | NPC (MW) | 80.0 | 80.0 | 80.0 | 80.0 | 80.0 | 80.0 | 80.0 |
| 19. | ANOHR Equation | 10% / AKW * [-136.85 - 13.15 * OCT - 21.65 * NOV] + 18,611 - 0.08694 * LSRF / AKW | | | | | | |

Issued by: S. N. Story

Page 19 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

ACTUAL UNIT PERFORMANCE DATA
GULF POWER COMPANY

| CRIST 6 | Jan '04 | Feb '04 | Mar '04 | Apr '04 | May '04 | Jun '04 | |
|---------------------|--|---------|---------|---------|---------|---------|--|
| 1. EAF (%) | 0.7 | 95.9 | 97.6 | 23.8 | 95.9 | 90.5 | |
| 2. PH | 744.0 | 696.0 | 744.0 | 719.0 | 744.0 | 720.0 | |
| 3. SH | 5.2 | 667.2 | 725.8 | 171.2 | 713.2 | 651.3 | |
| 4. RSH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 5. UH | 738.8 | 28.8 | 18.2 | 547.8 | 30.8 | 68.7 | |
| 6. POH | 571.2 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 7. FOH | 167.6 | 4.8 | 18.2 | 0.0 | 30.8 | 68.7 | |
| 8. MOH | 0.0 | 24.0 | 0.0 | 547.8 | 0.0 | 0.0 | |
| 9. PFOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 10. LR pf (MW) | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 11. PMOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 12. LR pm (MW) | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 13. NSC (MW) | 302.0 | 302.0 | 302.0 | 302.0 | 302.0 | 302.0 | |
| 14. Oper MBtu | 56840 | 1775639 | 1967176 | 432163 | 1805887 | 1648371 | |
| 15. Net Gen (MWH) | 336 | 185634 | 200102 | 42588 | 169810 | 161977 | |
| 16. ANOHR (Btu/KWH) | 169167 | 9565 | 9831 | 10148 | 10635 | 10177 | |
| 17. NOF % | 21.4 | 92.1 | 91.3 | 82.4 | 78.8 | 82.4 | |
| 18. NPC (MW) | 302.0 | 302.0 | 302.0 | 302.0 | 302.0 | 302.0 | |
| 19. ANOHR Equation | $10^6 / AKW * [1069.69 + 44.52 * MAR - 33.07 * MAY + 30.91 * AUG]$ $+ 844 + 0.02012 * LSRF / AKW$ | | | | | | |

Issued by: S. N. Story

Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

| | CRIST 6 | Jul '04 | Aug '04 | Sep '04 | Oct '04 | Nov '04 | Dec '04 | Total |
|-----|-----------------|--|---------|---------|---------|---------|---------|----------|
| 1. | EAF (%) | 92.4 | 97.7 | 70.8 | 89.8 | 91.9 | 57.2 | 75.3 |
| 2. | PH | 744.0 | 744.0 | 720.0 | 745.0 | 720.0 | 744.0 | 8784.0 |
| 3. | SH | 696.2 | 735.4 | 567.7 | 671.5 | 687.8 | 425.7 | 6718.2 |
| 4. | RSH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 5. | UH | 47.8 | 8.6 | 152.3 | 73.5 | 32.2 | 318.3 | 2065.8 |
| 6. | POH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 571.2 |
| 7. | FOH | 47.8 | 8.6 | 52.4 | 73.5 | 32.2 | 0.0 | 504.6 |
| 8. | MOH | 0.0 | 0.0 | 99.9 | 0.0 | 0.0 | 318.3 | 990.0 |
| 9. | PFOH | 2.9 | 0.0 | 0.0 | 2.6 | 36.5 | 0.0 | 42.0 |
| 10. | LR pf (MW) | 38.0 | 0.0 | 0.0 | 292.0 | 214.0 | 0.0 | 206.7 |
| 11. | PMOH | 15.6 | 15.3 | 98.9 | 0.0 | 0.0 | 0.0 | 129.8 |
| 12. | LR pm (MW) | 162.0 | 167.5 | 176.0 | 0.0 | 0.0 | 0.0 | 173.3 |
| 13. | NSC (MW) | 302.0 | 302.0 | 302.0 | 302.0 | 302.0 | 302.0 | 302.0 |
| 14. | Oper MBtu | 1786099 | 2042729 | 1327417 | 1921860 | 1827302 | 1201707 | 17793190 |
| 15. | Net Gen (MWH) | 171620 | 194961 | 126804 | 189204 | 179756 | 116738 | 1739530 |
| 16. | ANOHR (Btu/KWH) | 10407 | 10478 | 10468 | 10158 | 10165 | 10294 | 10229 |
| 17. | NOF % | 81.6 | 87.8 | 74.0 | 93.3 | 86.5 | 90.8 | 85.7 |
| 18. | NPC (MW) | 302.0 | 302.0 | 302.0 | 302.0 | 302.0 | 302.0 | 302.0 |
| 19. | ANOHR Equation | $10^6 / \text{AKW} * [1069.69 + 44.52 * \text{MAR} - 33.07 * \text{MAY} + 30.91 * \text{AUG}]$ $+ 844 + 0.02012 * \text{LSRF} / \text{AKW}$ | | | | | | |

Issued by: S. N. Story

Page 21 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

PERIOD OF: January 2004 - December 2004

| CRIST 7 | Jan '04 | Feb '04 | Mar '04 | Apr '04 | May '04 | Jun '04 | |
|--------------------|--|---------|---------|---------|---------|---------|--|
| 1. EAF (%) | 100.0 | 3.2 | 0.0 | 11.1 | 92.4 | 87.8 | |
| PH | 744.0 | 696.0 | 744.0 | 719.0 | 744.0 | 720.0 | |
| SH | 744.0 | 22.1 | 0.0 | 81.5 | 697.7 | 637.9 | |
| RSH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| UH | 0.0 | 673.9 | 744.0 | 637.5 | 46.3 | 82.1 | |
| POH | 0.0 | 673.9 | 744.0 | 507.7 | 0.0 | 0.0 | |
| FOH | 0.0 | 0.0 | 0.0 | 129.8 | 0.0 | 0.0 | |
| MOH | 0.0 | 0.0 | 0.0 | 0.0 | 46.3 | 82.1 | |
| PFOH | 0.0 | 0.0 | 0.0 | 2.8 | 2.6 | 13.9 | |
| LR pf (MW) | 0.0 | 0.0 | 0.0 | 317.0 | 51.0 | 205.5 | |
| PMOH | 0.0 | 0.0 | 0.0 | 0.0 | 17.5 | 0.0 | |
| LR pm (MW) | 0.0 | 0.0 | 0.0 | 0.0 | 278.0 | 0.0 | |
| NSC (MW) | 477.0 | 477.0 | 477.0 | 477.0 | 477.0 | 477.0 | |
| Oper MBtu | 3209101 | 97787 | 0 | 383328 | 2808258 | 2504892 | |
| Net Gen (MWH) | 314192 | 9866 | 0 | 35457 | 268569 | 242071 | |
| ANOHR (Btu/KWH) | 10214 | 9912 | 0 | 10811 | 10456 | 10348 | |
| NOF % | 88.5 | 93.6 | 0.0 | 91.2 | 80.7 | 79.6 | |
| NPC (MW) | 477.0 | 477.0 | 477.0 | 477.0 | 477.0 | 477.0 | |
| 19. ANOHR Equation | 10 ⁶ / AKW * [349.83 - 96.07 * MAR + 61.52 * JUN + 115.03 * JUL + 78.38 * AUG + 90.36 * SEP + 64.01 * NOV] + 9,387 | | | | | | |

Issued by: S. N. Story

Filed: April 01, 2005

Suspended:

Effective: April 01, 2005

Docket No.: 050001-EI

Order No.:

ACTUAL UNIT PERFORMANCE DATA

| CRIST 7 | Jul '04 | Aug '04 | Sep '04 | Oct '04 | Nov '04 | Dec '04 | Total |
|---------------------|---|---------|---------|---------|---------|---------|----------|
| 1. EAF (%) | 91.6 | 86.1 | 66.4 | 97.4 | 96.4 | 100.0 | 69.8 |
| 2. PH | 744.0 | 744.0 | 720.0 | 745.0 | 720.0 | 744.0 | 8784.0 |
| 3. SH | 682.6 | 715.3 | 478.3 | 745.0 | 694.2 | 744.0 | 6242.6 |
| 4. RSH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 5. UH | 61.4 | 28.7 | 241.7 | 0.0 | 25.8 | 0.0 | 2541.4 |
| 6. POH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1925.6 |
| 7. FOH | 4.4 | 6.7 | 52.4 | 0.0 | 0.0 | 0.0 | 193.3 |
| 8. MOH | 57.0 | 22.0 | 189.3 | 0.0 | 25.8 | 0.0 | 422.5 |
| 9. PFOH | 9.6 | 213.3 | 0.0 | 16.0 | 3.0 | 0.0 | 261.2 |
| 10. LR pf (MW) | 41.7 | 167.5 | 0.0 | 21.5 | 51.0 | 0.0 | 155.1 |
| 11. PMOH | 0.0 | 0.0 | 0.0 | 66.2 | 0.0 | 0.0 | 83.7 |
| 12. LR pm (MW) | 0.0 | 0.0 | 0.0 | 136.0 | 0.0 | 0.0 | 165.7 |
| 13. NSC (MW) | 477.0 | 477.0 | 477.0 | 477.0 | 477.0 | 477.0 | 477.0 |
| 14. Oper MBtu | 2817207 | 2900688 | 1945384 | 3360293 | 3125290 | 3367167 | 26519395 |
| 15. Net Gen (MWH) | 271888 | 275001 | 185784 | 322899 | 303761 | 329080 | 2558568 |
| 16. ANOHR (Btu/KWH) | 10362 | 10548 | 10471 | 10407 | 10289 | 10232 | 10365 |
| 17. NOF % | 83.5 | 80.6 | 81.4 | 90.9 | 91.7 | 92.7 | 85.9 |
| 18. NPC (MW) | 477.0 | 477.0 | 477.0 | 477.0 | 477.0 | 477.0 | 477.0 |
| 19. ANOHR Equation | $10^6 / AKW * [349.83 - 96.07 * MAR + 61.52 * JUN + 115.03 * JUL + 78.38 * AUG + 90.36 * SEP + 64.01 * NOV]$ + 9.387 | | | | | | |

Issued by: S. N. Story

Page 23 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

| | SMITH 1 | Jan '04 | Feb '04 | Mar '04 | Apr '04 | May '04 | Jun '04 | |
|-----|-----------------|---|---------|---------|---------|---------|---------|--|
| 1. | EAF (%) | 99.8 | 99.9 | 100.0 | 86.9 | 99.9 | 100.0 | |
| 2. | PH | 744.0 | 696.0 | 744.0 | 719.0 | 744.0 | 720.0 | |
| 3. | SH | 744.0 | 696.0 | 744.0 | 625.0 | 744.0 | 720.0 | |
| 4. | RSH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 5. | UH | 0.0 | 0.0 | 0.0 | 94.0 | 0.0 | 0.0 | |
| 6. | POH | 0.0 | 0.0 | 0.0 | 94.0 | 0.0 | 0.0 | |
| 7. | FOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 8. | MOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 9. | PFOH | 1.9 | 20.6 | 0.0 | 0.0 | 1.7 | 1.8 | |
| 10. | LR pf (MW) | 142.0 | 3.7 | 0.0 | 0.0 | 47.0 | 32.0 | |
| 11. | PMOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 12. | LR pm (MW) | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 13. | NSC (MW) | 162.0 | 162.0 | 162.0 | 162.0 | 162.0 | 162.0 | |
| 14. | Oper MBtu | 1015202 | 1061279 | 1166910 | 938186 | 983861 | 978257 | |
| 15. | Net Gen (MWH) | 99035 | 102586 | 114343 | 91949 | 96175 | 95364 | |
| 16. | ANOHR (Btu/KWH) | 10251 | 10345 | 10205 | 10203 | 10230 | 10258 | |
| 17. | NOF % | 82.2 | 91.0 | 94.9 | 90.8 | 79.8 | 81.8 | |
| 18. | NPC (MW) | 162.0 | 162.0 | 162.0 | 162.0 | 162.0 | 162.0 | |
| 19. | ANOHR Equation | 10*6 / AKW * [111.12 - 22.83 * JAN - 27.46 * FEB + 17.98 * APR] | | | | | | |
| | | + 9,412 | | | | | | |

Issued by: S. N. Story

Page 24 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

PERIOD OF: January 2004 - December 2004

| | | | | | | | | | |
|-----|-----------------|---|---------|--------|---------|--------|---------|----------|--|
| 1. | | | | | | | | | |
| 2. | PH | 744.0 | 744.0 | 720.0 | 745.0 | 720.0 | 744.0 | 8784.0 | |
| 3. | SH | 744.0 | 744.0 | 717.8 | 745.0 | 366.9 | 744.0 | 8334.7 | |
| 4. | RSH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 5. | UH | 0.0 | 0.0 | 2.2 | 0.0 | 353.1 | 0.0 | 449.3 | |
| 6. | POH | 0.0 | 0.0 | 0.0 | 0.0 | 353.1 | 0.0 | 447.1 | |
| 7. | FOH | 0.0 | 0.0 | 2.2 | 0.0 | 0.0 | 0.0 | 2.2 | |
| 8. | MOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 9. | PFOH | 0.0 | 1.1 | 0.0 | 1.3 | 0.0 | 18.4 | 46.8 | |
| 10. | LR pf (MW) | 0.0 | 42.0 | 0.0 | 52.9 | 0.0 | 93.1 | 49.4 | |
| 11. | PMOH | 0.0 | 4.1 | 0.0 | 0.0 | 0.0 | 0.0 | 4.1 | |
| 12. | LR pm (MW) | 0.0 | 42.0 | 0.0 | 0.0 | 0.0 | 0.0 | 42.0 | |
| 13. | NSC (MW) | 162.0 | 162.0 | 162.0 | 162.0 | 162.0 | 162.0 | 162.0 | |
| 14. | Oper MBtu | 1001235 | 1072740 | 948402 | 1121713 | 539792 | 1128226 | 11955803 | |
| 15. | Net Gen (MWH) | 98792 | 106626 | 92429 | 112690 | 52754 | 109214 | 1171957 | |
| 16. | ANOHR (Btu/KWH) | 10135 | 10061 | 10261 | 9954 | 10232 | 10330 | 10202 | |
| 17. | NOF % | 82.0 | 88.5 | 79.5 | 93.4 | 88.8 | 90.6 | 86.8 | |
| 18. | NPC (MW) | 162.0 | 162.0 | 162.0 | 162.0 | 162.0 | 162.0 | 162.0 | |
| 19. | ANOHR Equation | 10^6 / AKW * [111.12 - 22.83 * JAN - 27.46 * FEB + 17.98 * APR] | | | | | | | |
| | | + 9,412 | | | | | | | |

Issued by: S. N. Story

Page 25 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

| SMITH 2 | Jan '04 | Feb '04 | Mar '04 | Apr '04 | May '04 | Jun '04 | |
|---------------------|--|---------|---------|---------|---------|---------|--|
| 1. EAF (%) | 100.0 | 94.0 | 96.6 | 52.6 | 95.8 | 100.0 | |
| PH | 744.0 | 696.0 | 744.0 | 719.0 | 744.0 | 720.0 | |
| SH | 744.0 | 658.0 | 719.5 | 378.3 | 712.7 | 720.0 | |
| RSH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| UH | 0.0 | 38.0 | 24.5 | 340.7 | 31.3 | 0.0 | |
| POH | 0.0 | 0.0 | 0.0 | 340.7 | 0.0 | 0.0 | |
| FOH | 0.0 | 38.0 | 24.5 | 0.0 | 0.0 | 0.0 | |
| MOH | 0.0 | 0.0 | 0.0 | 0.0 | 31.3 | 0.0 | |
| PFOH | 4.7 | 53.4 | 3.3 | 0.0 | 0.0 | 0.0 | |
| LR pf (MW) | 9.0 | 7.7 | 49.0 | 0.0 | 0.0 | 0.0 | |
| PMOH | 0.0 | 11.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| LR pm (MW) | 0.0 | 29.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 14. Oper MBtu | 1151294 | 1129417 | 1232878 | 653845 | 1058448 | 1102606 | |
| 15. Net Gen (MWH) | 113613 | 110797 | 124970 | 61809 | 102145 | 106089 | |
| 16. ANOHR (Btu/KWH) | 10133 | 10194 | 9865 | 10578 | 10362 | 10393 | |
| 17. NOF % | 80.8 | 89.1 | 91.9 | 86.4 | 75.8 | 78.0 | |
| 18. NPC (MW) | 189.0 | 189.0 | 189.0 | 189.0 | 189.0 | 189.0 | |
| 19. ANOHR Equation | $10^6 / AKW * [139.59 - 38.77 * JAN - 43.18 * FEB - 42.50 * MAR - 16.17 * MAY + 27.46 * JUL + 19.26 * AUG]$ + 9,289 | | | | | | |

Issued by: S. N. Story

Page 26 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

| SMITH 2 | Jul '04 | Aug '04 | Sep '04 | Oct '04 | Nov '04 | Dec '04 | Total |
|--------------------|--|---------|---------|---------|---------|---------|----------|
| 1. EAF (%) | 100.0 | 99.8 | 99.8 | 99.9 | 95.9 | 100.0 | 94.6 |
| PH | 744.0 | 744.0 | 720.0 | 745.0 | 720.0 | 744.0 | 8784.0 |
| SH | 744.0 | 744.0 | 720.0 | 745.0 | 690.9 | 744.0 | 8320.4 |
| RSH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| UH | 0.0 | 0.0 | 0.0 | 0.0 | 29.1 | 0.0 | 463.6 |
| POH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 340.7 |
| FOH | 0.0 | 0.0 | 0.0 | 0.0 | 29.1 | 0.0 | 91.6 |
| MOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 31.3 |
| PFOH | 0.2 | 1.3 | 1.3 | 13.0 | 0.3 | 0.0 | 77.5 |
| LR pf (MW) | 182.0 | 172.0 | 185.0 | 11.6 | 175.0 | 0.0 | 17.0 |
| PMOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 11.0 |
| LR pm (MW) | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 29.0 |
| NSC (MW) | 189.0 | 189.0 | 189.0 | 189.0 | 189.0 | 189.0 | 189.0 |
| Oper MBtu | 1155464 | 1262628 | 1092548 | 1343303 | 1235001 | 1324654 | 13742086 |
| Net Gen (MWH) | 111088 | 120774 | 104190 | 129215 | 117212 | 125512 | 1327414 |
| ANOHR (Btu/KWH) | 10401 | 10454 | 10486 | 10396 | 10536 | 10554 | 10353 |
| NOF % | 79.0 | 85.9 | 76.6 | 91.8 | 89.8 | 89.3 | 84.4 |
| NPC (MW) | 189.0 | 189.0 | 189.0 | 189.0 | 189.0 | 189.0 | 189.0 |
| 19. ANOHR Equation | $10^6 / AKW * [139.59 - 38.77 * JAN - 43.18 * FEB - 42.50 * MAR - 16.17 * MAY + 27.46 * JUL + 19.26 * AUG]$ + 9,289 | | | | | | |

Issued by: S. N. Story

Page 27 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

| | DANIEL 1 | Jan '04 | Feb '04 | Mar '04 | Apr '04 | May '04 | Jun '04 | |
|-----|-----------------|--|---------|---------|---------|---------|---------|--|
| 1. | EAF (%) | 99.9 | 99.3 | 57.3 | 85.0 | 95.4 | 87.3 | |
| 2. | PH | 744.0 | 696.0 | 744.0 | 719.0 | 744.0 | 720.0 | |
| 3. | SH | 744.0 | 691.7 | 426.8 | 619.9 | 710.4 | 628.4 | |
| 4. | RSH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 5. | UH | 0.0 | 4.3 | 317.2 | 99.1 | 33.6 | 91.6 | |
| 6. | POH | 0.0 | 0.0 | 317.2 | 0.0 | 0.0 | 0.0 | |
| 7. | FOH | 0.0 | 4.3 | 0.0 | 24.3 | 0.0 | 24.7 | |
| 8. | MOH | 0.0 | 0.0 | 0.0 | 74.8 | 33.6 | 66.9 | |
| 9. | PFOH | 3.1 | 0.3 | 2.9 | 17.0 | 3.3 | 0.3 | |
| 10. | LR pf (MW) | 64.0 | 511.0 | 140.0 | 155.0 | 132.7 | 94.0 | |
| 11. | PMOH | 0.0 | 0.0 | 0.0 | 10.7 | 0.0 | 0.0 | |
| 12. | LR pm (MW) | 0.0 | 0.0 | 0.0 | 184.7 | 0.0 | 0.0 | |
| 13. | NSC (MW) | 514.0 | 514.0 | 514.0 | 514.0 | 514.0 | 514.0 | |
| 14. | Oper MBtu | 3740671 | 3402533 | 2057881 | 2991614 | 3129962 | 3018641 | |
| 15. | Net Gen (MWH) | 363598 | 336226 | 203907 | 289817 | 298651 | 290363 | |
| 16. | ANOHR (Btu/KWH) | 10288 | 10120 | 9926 | 9957 | 9893 | 9957 | |
| 17. | NOF % | 95.1 | 94.6 | 92.9 | 91.0 | 81.8 | 89.9 | |
| 18. | NPC (MW) | 514.0 | 514.0 | 514.0 | 514.0 | 514.0 | 514.0 | |
| 19. | ANOHR Equation | $10^6 / AKW * [-528.45 - 59.78 * MAY + 139.64 * JUL + 75.47 * AUG]$ $+ 15,490 - 0.00906 * LSRF / AKW$ | | | | | | |

Issued by: S. N. Story

Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

| | DANIEL 1 | Jul '04 | Aug '04 | Sep '04 | Oct '04 | Nov '04 | Dec '04 | Total |
|-----|-----------------|--|---------|---------|---------|---------|---------|----------|
| 1. | EAF (%) | 95.5 | 95.5 | 99.4 | 3.3 | 36.4 | 85.5 | 78.2 |
| 2. | PH | 744.0 | 744.0 | 720.0 | 745.0 | 720.0 | 744.0 | 8784.0 |
| 3. | SH | 711.9 | 744.0 | 708.1 | 24.4 | 263.8 | 637.8 | 6911.2 |
| 4. | RSH | 0.0 | 0.0 | 11.9 | 0.0 | 0.0 | 0.0 | 11.9 |
| 5. | UH | 32.1 | 0.0 | 0.0 | 720.6 | 456.2 | 106.2 | 1860.9 |
| 6. | POH | 0.0 | 0.0 | 0.0 | 720.6 | 456.2 | 0.0 | 1494.0 |
| 7. | FOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 53.3 |
| 8. | MOH | 32.1 | 0.0 | 0.0 | 0.0 | 0.0 | 106.2 | 313.6 |
| 9. | PFOH | 4.0 | 103.6 | 4.4 | 0.0 | 0.0 | 7.3 | 146.2 |
| 10. | LR pf (MW) | 154.0 | 166.0 | 59.4 | 0.0 | 0.0 | 92.2 | 154.6 |
| 11. | PMOH | 0.0 | 0.0 | 11.2 | 0.0 | 1.5 | 2.5 | 25.9 |
| 12. | LR pm (MW) | 0.0 | 0.0 | 168.4 | 0.0 | 511.0 | 119.0 | 190.2 |
| 13. | NSC (MW) | 514.0 | 514.0 | 514.0 | 514.0 | 514.0 | 514.0 | 514.0 |
| 14. | Oper MBtu | 3522497 | 3390896 | 3199581 | 70372 | 926799 | 3051644 | 32503092 |
| 15. | Net Gen (MWH) | 345675 | 339849 | 303265 | 10767 | 86661 | 300905 | 3169684 |
| 16. | ANOHR (Btu/KWH) | 10195 | 10194 | 10037 | 9926 | 10178 | 9919 | 10066 |
| 17. | NOF % | 94.5 | 88.9 | 83.3 | 85.9 | 63.9 | 91.8 | 89.2 |
| 18. | NPC (MW) | 514.0 | 514.0 | 514.0 | 514.0 | 514.0 | 514.0 | 514.0 |
| 19. | ANOHR Equation | $10^6 / AKW * [-528.45 - 59.78 * MAY + 139.64 * JUL + 75.47 * AUG]$ $+ 15,490 - 0.00906 * LSRF / AKW$ | | | | | | |

Issued by: S. N. Story

Page 29 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

PERIOD OF: January 2004 - December 2004

| DANIEL 2 | Jan '04 | Feb '04 | Mar '04 | Apr '04 | May '04 | Jun '04 | |
|---------------------|---|---------|---------|---------|---------|---------|--|
| 1. EAF (%) | 70.5 | 99.3 | 94.3 | 99.8 | 99.7 | 100.0 | |
| 2. PH | 744.0 | 696.0 | 744.0 | 719.0 | 744.0 | 720.0 | |
| 3. SH | 525.9 | 694.6 | 702.0 | 719.0 | 744.0 | 720.0 | |
| 4. RSH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 5. UH | 218.1 | 1.4 | 42.0 | 0.0 | 0.0 | 0.0 | |
| 6. POH | 164.3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 7. FOH | 25.0 | 1.4 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 8. MOH | 28.8 | 0.0 | 42.0 | 0.0 | 0.0 | 0.0 | |
| 9. PFOH | 8.0 | 11.6 | 0.8 | 13.4 | 11.7 | 1.8 | |
| 10. LR pf (MW) | 84.5 | 64.9 | 25.6 | 50.3 | 13.4 | 60.0 | |
| 11. PMOH | 0.0 | 4.8 | 4.0 | 0.0 | 5.9 | 0.0 | |
| 12. LR pm (MW) | 0.0 | 187.9 | 37.7 | 0.0 | 170.0 | 0.0 | |
| 13. NSC (MW) | 500.0 | 500.0 | 500.0 | 500.0 | 500.0 | 500.0 | |
| 14. Oper MBtu | 2315221 | 3267921 | 3322599 | 3400813 | 3203966 | 3313302 | |
| 15. Net Gen (MWH) | 243582 | 342971 | 338437 | 346245 | 324431 | 332493 | |
| 16. ANOHR (Btu/KWH) | 9505 | 9528 | 9700 | 9884 | 10007 | 9934 | |
| 17. NOF % | 92.6 | 98.8 | 96.4 | 96.3 | 87.2 | 92.4 | |
| 18. NPC (MW) | 500.0 | 500.0 | 500.0 | 500.0 | 500.0 | 500.0 | |
| 19. ANOHR Equation | $10^6 / AKW * [571.00 - 118.56 * JAN - 87.31 * FEB - 88.00 * MAR - 88.36 * NOV]$ + 8.698 | | | | | | |

Issued by: S. N. Story

Page 30 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

| DANIEL 2 | Jul '04 | Aug '04 | Sep '04 | Oct '04 | Nov '04 | Dec '04 | Total |
|--------------------|---|---------|---------|---------|---------|---------|----------|
| 1. EAF (%) | 99.6 | 89.5 | 99.8 | 91.8 | 98.7 | 99.8 | 95.2 |
| PH | 744.0 | 744.0 | 720.0 | 745.0 | 720.0 | 744.0 | 8784.0 |
| SH | 744.0 | 669.2 | 720.0 | 720.2 | 720.0 | 744.0 | 8422.9 |
| RSH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| UH | 0.0 | 74.8 | 0.0 | 24.8 | 0.0 | 0.0 | 361.1 |
| POH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 164.3 |
| FOH | 0.0 | 43.3 | 0.0 | 24.8 | 0.0 | 0.0 | 94.5 |
| MOH | 0.0 | 31.5 | 0.0 | 0.0 | 0.0 | 0.0 | 102.3 |
| PFOH | 30.2 | 12.6 | 8.0 | 40.3 | 13.3 | 14.4 | 166.1 |
| LR pf (MW) | 55.3 | 128.3 | 76.3 | 413.0 | 240.7 | 44.6 | 161.2 |
| PMOH | 0.0 | 0.0 | 0.0 | 13.2 | 28.4 | 0.5 | 56.8 |
| LR pm (MW) | 0.0 | 0.0 | 0.0 | 100.0 | 53.6 | 72.0 | 86.9 |
| NSC (MW) | 500.0 | 500.0 | 500.0 | 500.0 | 500.0 | 500.0 | 500.0 |
| Oper MBtu | 3526561 | 3037857 | 3099015 | 3429166 | 3467654 | 3601229 | 38985304 |
| Net Gen (MWH) | 346502 | 313796 | 310867 | 334758 | 343589 | 359939 | 3937610 |
| ANOHR (Btu/KWH) | 9924 | 9916 | 10020 | 9926 | 9709 | 9878 | 9833 |
| NOF % | 93.1 | 93.8 | 86.4 | 93.0 | 95.4 | 96.8 | 93.5 |
| NPC (MW) | 500.0 | 500.0 | 500.0 | 500.0 | 500.0 | 500.0 | 500.0 |
| 19. ANOHR Equation | $10^6 / AKW * [571.00 - 118.56 * JAN - 87.31 * FEB - 88.00 * MAR - 88.36 * NOV]$ + 8,698 | | | | | | |

Issued by: S. N. Story

Page 31 of 32
Schedule 5Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

Planned Outage Schedules (Actual)

Period of: January 2004 - December 2004

Critical path bar charts of actual work activity performed during major planned outages are not shown here since corresponding bar charts of forecast work activity were not provided earlier in conformance with agreement with Staff to avoid the premature production of charts prior to their normal course of development. Forecast and actual critical path bar charts are developed for each planned outage and, per agreement with Staff, these charts will be provided on request.

Issued by: S. N. Story

Page 32 of 32
Schedule 5


Filed: April 01, 2005
Suspended:
Effective: April 01, 2005
Docket No.: 050001-EI
Order No.:

AFFIDAVIT

STATE OF FLORIDA)
)
COUNTY OF ESCAMBIA)

Docket No. 050001-EI

Before me, the undersigned authority, personally appeared Lonzelle S. Noack, who being first duly sworn, deposes, and says that she is the Power Generation Specialist, Senior for Gulf Power Company, a Maine corporation, and that the foregoing is true and correct to the best of her knowledge, information, and belief. She is personally known to me.



Lonzelle S. Noack
Power Generation Specialist, Senior

Sworn to and subscribed before me this 30th day of March, 2004.





Notary Public, State of Florida at Large

Commission Number: #DD 303630

Commission Expires: Mar. 25, 2008