

FPL REPORTED FOLLOWING BUILDSMART HOMES
 IN ZIPCODE 34275 See response to interrogatory #8 at page:

Dockets 04-0029-EG & 04-0660-EG

~~DSB~~ Page 1 of 5
 Exhibit 1

	2001	2002	2003	2004	2005 to date		
GOLD	NONE	NONE	2	3	1	6	1.32%
SILVER	NONE	1	93	103	66	262	57.46%
BRONZE	NONE	NONE	35	75	78	188	41.23%
TOTAL		1	130	181	145	456	100.00%
C+ SAMPLE							
GOLD	0	0	0	0	0	0	0.00%
SILVER	0	0	0	0	0	0	0.00%
BRONZE	0	0	2	2	2	6	4.51%
FAILS duct, passes 10%			5	9	3	17	12.78%
FAILED 10%		0	14	58	38	110	82.71%
TOTAL	0	0	21	69	43	133	100.00%
						29%	

17.29%

DOCUMENT NUMBER-DATE

08322 AUG 30 12

FPSC-COMMISSION CLERK

Tested Build Smart Community* [ALL DATA AS-BUILT]
 Sorted by year; then e-ratio; ducts

Dockets 04-0029-EG & 04-0660-EG

Page 2&2A of 5

Exhibit 1

YEAR	Home Identifier	Address*	Build Smart Medallion*	Date processed	E-Ratio As-Built	HERS Score	Sq Ft of living area	CFM25 TOTAL	Qn of TOTAL	AHU Rated Air Flow	Duct Leak Total %	CFM25 OUT	Duct Leak Out %	Qn of OUT
GOLD MEDALLION HOMES: 0.7 E-RATIO OR LOWER														
NONE														
SILVER MEDALLION HOMES: 0.71 TO 0.80 E-RATIO														
NONE														
BRONZE MEDALLION HOMES: 0.81-0.90 E-RATIO														
2003														
2004	116	WCI-34275		12/16/2003 14:23	0.89	85.1	1482	131	0.088	1200	10.92%	53	4.42%	0.035762
2005	108	WCI-34275		11/21/2003 15:24	0.90	85.3	3085	204	0.066	2200	9.27%	105	4.77%	0.034038
PASSES E-RATIO BUT FAILS DUCT STANDARDS														
2006	101	WCI-34275		11/21/2003 15:28	0.90	85	1482	140	0.094	1000	14.00%	50.5	5.05%	0.034076
2006	89	WCI-34275		11/21/2003 15:19	0.89	85.2	1994	163	0.082	1200	13.58%	64	5.33%	0.032096
2007	60	WCI-34275		11/21/2003 15:28	0.89	84.8	1994	202	0.101	1200	16.83%	79.5	6.63%	0.03987
2008	59	WCI-34275		11/21/2003 15:26	0.90	85.1	1994	154.5	0.077	1200	12.88%	81.5	6.79%	0.040873
2009	36	WCI-34275		11/21/2003 15:26	0.90	84.8	1994	174	0.087	1200	14.50%	98	8.17%	0.049147
2004														
2005	134	WCI-34275		9/15/2004 10:18	0.89	86.5	1994	140	0.070	1200	11.67%	31	2.58%	0.015547
2005	127	WCI-34275		6/9/2004 11:29	0.89	85.5	2889	299	0.103	2600	11.50%	99.25	3.82%	0.034354
PASSES E-RATIO BUT FAILS DUCT STANDARDS														
2006	84	WCI-34275		10/14/2004 14:05	0.89	84.5	1994	222	0.111	1200	18.50%	67	5.58%	0.033601
2007	79	WCI-34275		9/15/2004 10:18	0.89	86.2	1994	110	0.055	1200	9.17%	70	5.83%	0.035105
2008	77	WCI-34275		7/13/2004 7:27	0.90	85.1	1482	125	0.084	1000	12.50%	59	5.90%	0.039811
2009	70	WCI-34275		6/9/2004 11:33	0.89	84.9	1994	177	0.089	1400	12.64%	88.5	6.32%	0.044383
2010	65	WCI-34275		9/15/2004 10:19	0.90	85	1482	137	0.092	1000	13.70%	65	6.50%	0.04386
2011	49	WCI-34275		8/30/2004 10:22	0.89	85.1	1994	168.5	0.084	1200	13.88%	90.5	7.54%	0.045386
2012	29	WCI-34275		10/14/2004 14:06	0.90	83.7	1351	150.5	0.111	1200	12.54%	103.5	8.63%	0.07661
2013	11	WCI-34275		10/14/2004 14:05	0.90	85.2	1482	116.5	0.079	1000	11.65%	109.5	10.95%	0.073887
2014	3	WCI-34275		8/30/2004 10:54	0.90	82	1351	244	0.181	1000	24.40%	161.5	16.15%	0.119541
2005														
2006	110	WCI-34275		7/28/2005 14:37	0.89	85.4	3085	282	0.091	2200	12.82%	103.5	4.70%	0.033549
2007	106	WCI-34275		7/28/2005 14:37	0.90	84.7	1082	126	0.116	1000	12.60%	48	4.80%	0.044362
PASSES E-RATIO BUT FAILS DUCT STANDARDS														
2007	68	WCI-34275		3/7/2005 15:56	0.89	84.8	1994	198	0.099	1400	14.14%	89	6.36%	0.044634
2008	32	WCI-34275		5/18/2005 12:21	0.90	85	1482	133	0.090	1000	13.30%	83.5	8.35%	0.056343
2009	23	WCI-34275		5/18/2005 12:21	0.90	84.8	1482	146	0.099	1000	14.60%	94	9.40%	0.063428
HOMES THAT FAIL TO MEET BUILSMART TECHNICAL STANDARDS														
2003														
1	94	WCI-34275		11/21/2003 15:19	0.92	84.7	1482	139	0.093	1000	13.80%	52	5.20%	0.035088
2	4	WCI-34275		11/21/2003 15:20	0.95	81.6	1478	271	0.183	1000	27.10%	148.5	14.85%	0.100474
3	128	WCI-34275		11/21/2003 15:22	0.96	83.6	1082	84.5	0.078	1000	8.45%	38	3.80%	0.03512
4	103	WCI-34275		11/21/2003 15:22			1994	157	0.079	1200	13.08%	59	4.92%	0.029589
5	115	WCI-34275		11/21/2003 15:22	0.98	83.1	1994	169.5	0.085	1200	14.13%	53.5	4.46%	0.02683
6	107	WCI-34275		11/21/2003 15:23	0.97	82.9	1482	120	0.081	1000	12.00%	48	4.80%	0.032389
7	78	WCI-34275		11/21/2003 15:24	0.95	83.3	1478	160	0.108	1000	16.00%	58.5	5.85%	0.039581
8	113	WCI-34275		11/21/2003 15:27	0.96	85.1	1082	213	0.197	1000	21.30%	45	4.50%	0.04159
9	45	WCI-34275		11/21/2003 15:27	0.91	83.4	1351	162	0.120	1000	16.20%	76	7.60%	0.056255
10	46	WCI-34275		11/21/2003 15:27	0.92	84.3	1482	163.5	0.110	1000	16.35%	76	7.60%	0.051282
11	16	WCI-34275		12/16/2003 14:23	0.92	83.4	1478	186	0.126	1200	15.50%	124	10.33%	0.083897
12	96	WCI-34275		12/16/2003 14:23	0.97	84.1	1082	117	0.108	1200	9.75%	62	5.17%	0.057301
13	130	WCI-34275		12/16/2003 14:24	0.98	84.4	1082	76	0.070	1200	6.33%	41	3.42%	0.037893
14	87	WCI-34275		12/16/2003 14:24	0.95	84.4	1663	154	0.093	1200	12.83%	65	5.42%	0.039086
2004														
15	27	WCI-34275		1/9/2004 9:52	0.95	83	1478	181	0.122	1000	18.10%	88	8.80%	0.05954
16	123	WCI-34275		1/9/2004 9:52	0.96	83.4	1691	101	0.060	1200	8.42%	51	4.25%	0.03016
17	55	WCI-34275		1/9/2004 9:52	0.92	83.9	1478	150.5	0.102	1000	15.05%	71.5	7.15%	0.048376
18	52	WCI-34275		1/9/2004 9:52	0.97	84.1	1663	157	0.094	1000	15.70%	73	7.30%	0.043897
19	21	WCI-34275		1/9/2004 9:52	0.95	84.1	1663	178	0.107	1000	17.80%	96	9.60%	0.057727
20	81	WCI-34275		1/9/2004 9:53	0.97	83.5	1269	135.5	0.107	1000	13.55%	57	5.70%	0.044917
21	57	WCI-34275		1/9/2004 9:53	0.97	83.4	1269	141.5	0.112	1000	14.15%	69.5	6.95%	0.054768
22	37	WCI-34275		1/9/2004 9:53	1.05	82.8	1691	150	0.089	1200	12.50%	98	8.17%	0.057954
23	122	WCI-34275		1/9/2004 9:53	1.02	84.6	1082	103.5	0.096	1000	10.35%	43	4.30%	0.039741
24	124	WCI-34275		1/9/2004 9:53	1.05	84.1	1269	122	0.096	1000	12.20%	41	4.10%	0.032309
25	85	WCI-34275		1/9/2004 9:53	0.95	83.7	1478	129	0.087	1200	10.75%	67	5.58%	0.045332
26	121	WCI-34275		2/23/2004 11:23	1.05	81.8	1691	117	0.069	1200	9.75%	52	4.33%	0.030751
27	120	WCI-34275		2/23/2004 11:23	0.92	86.1	1691	225	0.133	1200	18.75%	52	4.33%	0.030751
28	104	WCI-34275		2/23/2004 11:24	0.92	84.8	1482	112	0.076	1000	11.20%	49	4.90%	0.033063
29	42	WCI-34275		2/23/2004 11:25	0.98	82.5	2556	379	0.148	2000	18.95%	158	7.90%	0.061815
30	98	WCI-34275		2/23/2004 11:48	1.00	83.9	1691	143	0.085	1200	11.92%	61.5	5.13%	0.036369
31	40	WCI-34275		6/9/2004 11:30	0.96	83.1	2556	363.5	0.142	2000	18.18%	159	7.95%	0.062207
32	99	WCI-34275		6/9/2004 11:30	0.96	85.4	3085	219	0.071	2200	9.95%	112.5	5.11%	0.036467
33	75	WCI-34275		6/9/2004 11:31	0.96	82.2	2889	457.5	0.158	2600	17.60%	156.5	6.02%	0.054171
34	53	WCI-34275		6/9/2004 11:31	0.96	83.4	2556	326	0.128	2000	16.30%	145	7.25%	0.056729
35	82	WCI-34275		6/9/2004 11:32	1.05	82.9	1691	148.5	0.088	1000	14.85%	56.5	5.65%	0.033412
36	95	WCI-34275		6/9/2004 11:33	1.01	82.9	1269	142	0.112	1200	11.83%	62	5.17%	0.048857
37	33	WCI-34275		7/13/2004 7:20	0.93	83.4	2195	295.5	0.135	1600	18.47%	133.5	8.34%	0.06082
38	41	WCI-34275		7/13/2004 7:25	0.94	81.7	2195	432	0.197	1600	27.00%	127	7.94%	0.057859
39	51	WCI-34275		7/13/2004 7:26	0.96	83.4	2556	244	0.095	1600	15.25%	118	7.38%	0.046166
40	8	WCI-34275		7/13/2004 7:27	1.05	82.5	1691	178	0.105	1000	17.80%	119	11.90%	0.070373
41	64	WCI-34275		7/13/2004 7:27	0.91	84.7	1482	139.5	0.094	1000	13.95%	65.5	6.55%	0.044197
42	92	WCI-34275		7/13/2004 9:05	0.98	83.6	1269	117	0.092	1000	11.70%	52.5	5.25%	0.041371
43	97	WCI-34275		7/13/2004 9:05	0.96	83.9	1269	130.5	0.103	1000	13.05%	51.5	5.15%	0.040583
44	73	WCI-34275		7/13/2004 9:05	0.92	84.7	1482	136	0.092	1000	13.60%	61	6.10%	0.041161

BOOK 07-00291
 DB 2A of 5
 EX 1)

45	131	WCI-34275	7/13/2004 9:05	0.96	84.8	1691	111	0.066	1200	9.25%	41	3.42%	0.024246
46	111	WCI-34275	7/15/2004 15:35	0.97	84.1	1691	96	0.057	1000	9.60%	47	4.70%	0.027794
47	117	WCI-34275	8/30/2004 10:20	0.92	84.8	1691	129	0.076	1200	10.75%	53	4.42%	0.031342
48	14	WCI-34275	8/30/2004 10:20	0.97	82.9	2889	381	0.132	2000	19.05%	212.5	10.63%	0.073565
49	50	WCI-34275	8/30/2004 10:20	0.98	83.4	2889	288.5	0.100	2000	14.43%	149.5	7.48%	0.051748
50	112	WCI-34275	8/30/2004 10:21	1.00	85.1	2889	173.75	0.060	2400	7.24%	110	4.58%	0.038075
51	20	WCI-34275	8/30/2004 10:21	0.96	83.7	2889	293	0.101	2000	14.65%	192	9.60%	0.066459
52	9	WCI-34275	8/30/2004 10:21	0.92	83	1478	212.5	0.144	1200	17.71%	134	11.17%	0.090663
53	34	WCI-34275	8/30/2004 10:21	0.98	83.7	2889	259.5	0.090	2000	12.98%	166.5	8.33%	0.057632
54	35	WCI-34275	8/30/2004 10:21	0.95	84.4	1663	152	0.091	1200	12.67%	98	8.17%	0.05893
55	13	WCI-34275	8/30/2004 10:21	0.95	83.7	1663	208.5	0.125	1000	20.85%	107	10.70%	0.064342
56	118	WCI-34275	8/30/2004 10:22	0.98	84.4	3282	284	0.087	3000	9.47%	132.34	4.41%	0.040323
57	24	WCI-34275	8/30/2004 10:22	0.95	84.1	1663	178	0.107	1000	17.80%	93.5	9.35%	0.056224
58	105	WCI-34275	8/30/2004 10:54	0.92	85.1	1994	192	0.096	1400	13.71%	68	4.88%	0.034102
59	74	WCI-34275	8/30/2004 10:54	0.93	84.7	1663	159.5	0.096	1200	13.29%	73	6.08%	0.043897
60	86	WCI-34275	9/15/2004 10:17	0.92	85.1	1994	130.5	0.065	1200	10.88%	65	5.42%	0.032598
61	69	WCI-34275	9/15/2004 10:17	0.94	84.8	1663	133.5	0.080	1200	11.13%	76	6.33%	0.045701
62	17	WCI-34275	9/15/2004 10:17	0.92	83	1478	213.5	0.144	1200	17.79%	120	10.00%	0.081191
63	119	WCI-34275	10/14/2004 14:04	1.01	84.4	3085	195	0.063	2200	8.86%	97	4.41%	0.031442
64	43	WCI-34275	10/14/2004 14:04	0.97	83.4	2556	304	0.119	2000	15.20%	154.5	7.73%	0.060446
65	90	WCI-34275	12/22/2004 14:17	0.99	84.8	1691	117	0.069	1200	9.75%	64	5.33%	0.037847
66	31	WCI-34275	12/22/2004 14:18	0.98	83.4	2889	290	0.100	2000	14.50%	167.5	8.38%	0.057979
67	80	WCI-34275	12/22/2004 14:18	0.92	85.2	1478	98	0.066	1000	9.80%	57	5.70%	0.038566
68	109	WCI-34275	12/22/2004 14:18	0.93	86	1994	141.5	0.071	1200	11.79%	57	4.75%	0.028586
69	6	WCI-34275	12/22/2004 14:18	0.95	83.8	1663	200	0.120	1000	20.00%	137	13.70%	0.082381
70	10	WCI-34275	12/22/2004 14:19	0.93	84.7	1663	157	0.094	1000	15.70%	111	11.10%	0.066747
71	44	WCI-34275	12/22/2004 14:19	0.92	83.9	1478	151.5	0.103	1000	15.15%	76	7.60%	0.051421
72	61	WCI-34275	12/22/2004 14:19	0.97	83.8	2889	262.5	0.091	2000	13.13%	132.5	6.63%	0.045864
2005													
73	76	WCI-34275	3/7/2005 15:56	0.99	83.3	1691	132	0.078	1200	11.00%	72	6.00%	0.042578
74	58	WCI-34275	3/7/2005 15:56	0.96	83.2	1082	116	0.107	1000	11.60%	69	6.90%	0.063771
75	100	WCI-34275	3/7/2005 15:56	0.96	84.6	1082	94	0.087	1000	9.40%	51	5.10%	0.047135
76	102	WCI-34275	3/7/2005 15:56	0.95	85.7	1691	117.5	0.069	1200	9.79%	60	5.00%	0.035482
77	5	WCI-34275	3/7/2005 15:56	0.95	83.7	1663	207.5	0.125	1000	20.75%	144	14.40%	0.08959
78	25	WCI-34275	3/7/2005 15:56	0.95	83.5	1663	210	0.126	1000	21.00%	92	9.20%	0.055322
79	19	WCI-34275	3/7/2005 15:56	0.91	83.4	1351	159	0.118	1200	13.25%	118.5	9.88%	0.087713
80	12	WCI-34275	3/7/2005 15:56	0.93	84.4	1663	180	0.108	1200	15.00%	129	10.75%	0.077571
81	133	WCI-34275	3/7/2005 15:56	0.97	84.2	1994	109	0.055	1400	7.79%	38	2.71%	0.019057
82	126	WCI-34275	3/7/2005 15:56	1.02	84.3	1994	136.5	0.068	1200	11.38%	46	3.83%	0.023069
83	47	WCI-34275	3/7/2005 15:56	0.95	83.8	1663	187	0.112	1000	18.70%	75.5	7.55%	0.0454
84	66	WCI-34275	4/28/2005 8:01	0.98	84	2889	215.5	0.075	2000	10.78%	129	6.45%	0.044652
85	67	WCI-34275	4/28/2005 8:01	0.98	84.7	2889	191	0.066	2000	9.55%	128.5	6.43%	0.044479
86	83	WCI-34275	4/28/2005 8:02	1.01	84.1	1269	83	0.065	1000	8.30%	56.5	5.65%	0.044523
87	88-see72	WCI-34275	4/28/2005 8:02 ne address	0.98	83.9	1269	71.5	0.056	1000	7.15%	54	5.40%	0.042553
88	72	WCI-34275	4/28/2005 8:03	0.98	84.7	1082	98.5	0.091	1000	9.85%	61.5	6.15%	0.056839
89	56	WCI-34275	4/28/2005 8:05	0.96	83.8	2556	281	0.110	2000	14.05%	142.5	7.13%	0.055751
90	39	WCI-34275	5/18/2005 12:21	0.98	83.7	1269	116	0.091	1000	11.60%	80	8.00%	0.063042
91	54	WCI-34275	5/18/2005 12:22	0.98	83.7	1269	110	0.087	1000	11.00%	72	7.20%	0.056738
92	30	WCI-34275	5/18/2005 12:22	0.98	83.5	1269	125.5	0.099	1000	12.55%	86	8.60%	0.06777
93	48	WCI-34275	5/18/2005 12:22	0.96	83.5	1082	105.5	0.098	1000	10.55%	75.5	7.55%	0.069778
93	63	WCI-34275	6/29/2005 13:56	0.91	85.2	1482	108	0.073	1000	10.80%	66	6.60%	0.044534
94	26	WCI-34275	6/29/2005 14:05	0.96	83.6	2556	305	0.119	2000	15.25%	180	9.00%	0.070423
95	18	WCI-34275	6/29/2005 14:05	0.97	83.5	2556	398.5	0.156	2000	19.93%	198.5	9.93%	0.07766
96	15	WCI-34275	7/27/2005 10:58	0.97	83.5	2556	336	0.131	2000	16.80%	209.5	10.48%	0.081964
97	1	WCI-34275	7/27/2005 10:58	0.95	78.2	1663	386.5	0.232	1200	32.21%	234.5	19.54%	0.14101
98	2	WCI-34275	7/27/2005 10:58	0.94	84	1663	402.5	0.242	1200	33.54%	224	18.67%	0.134696
99	38	WCI-34275	7/27/2005 10:58	0.95	83.1	1478	301	0.204	1200	25.08%	96.5	8.04%	0.065291
100	62	WCI-34275	7/27/2005 10:58	1.01	84.1	1269	99	0.078	1000	9.90%	66	6.60%	0.052009
101	125	WCI-34275	7/27/2005 14:32	0.97	83.7	1691	140.5	0.083	2000	7.03%	77.5	3.88%	0.045831
102	129	WCI-34275	7/27/2005 14:32	0.96	84.8	1269	147.5	0.116	2000	7.38%	73.5	3.68%	0.05792
103	71	WCI-34275	7/28/2005 14:37	0.97	83.2	1269	213.5	0.168	1000	21.35%	61.5	6.15%	0.048463
104	7	WCI-34275	7/28/2005 14:37	0.92	83.7	1478	326	0.221	1200	27.17%	143.5	11.96%	0.097091
105	93	WCI-34275	7/28/2005 14:38	1.05	82	1691	223.5	0.132	1400	15.96%	73	5.21%	0.04317
106	91	WCI-34275	7/28/2005 14:38	0.98	83	1269	201	0.158	1400	14.36%	74	5.29%	0.058314
107	114	WCI-34275	7/28/2005 14:38	0.96	81.1	1269	152	0.120	1400	10.86%	62.5	4.46%	0.049251
108	28	WCI-34275	7/28/2005 14:38	1.02	83.4	1691	144	0.085	1200	12.00%	104	8.67%	0.061502
109	132	WCI-34275	7/28/2005 14:39	1.00	85.2	2889	202	0.070	2006	10.07%	68	3.39%	0.023538
110	22	WCI-34275		0.94	84.9	1663	130	0.078	1200	10.83%	113	9.42%	0.067949

*WCI community at zipcode 34275 that is a designated BuildSmart community with 456 certified homes (GOLD-6 (1.3%); SILVER-262 (57.5%); and BRONZE-188 (41.2%))

**Residential New Construction
 BuildSmart™
 Trade Ally Program Standards**

Effective: June 1, 2000

Florida Power & Light Company

Residential New Construction BuildSmart™

Trade Ally Program Standards

TECHNICAL SPECIFICATIONS OF ELIGIBILITY

- Air distribution system must meet the following criteria:

Sealing of the ducted air distribution system may have a maximum cfm leakage of five percent (5%) of the air-conditioned square footage of the home at the final inspection and three percent (3%) at the mid-point inspection. State of Florida Energy Code approved closure systems must be used for all duct system connections.

Tested Build Smart Community* [ALL DATA AS-BUILT]

Sorted by as-built e-ratio

RANK BY AS-BUILT E-RATIO	Home Identifier	Address*	Build Smart Medallion*	Date processed	E-Ratio As-Built	HERS Score	Sq Ft of living area	CFM25 TOTAL	Qn of TOTAL	AHU Rated Air Flow	Duct Leak Total %	CFM25 OUT	Duct Leak Out %	Qn of OUT
GOLD MEDALLION HOMES: 0.7 E-RATIO OR LOWER														
NONE														
SILVER MEDALLION HOMES: 0.71 TO 0.80 E-RATIO														
NONE														
BRONZE MEDALLION HOMES: 0.81-0.90 E-RATIO														
1	134	WCI-34275		9/15/2004 10:18	0.89	86.5	1994	140	0.070	1200	11.67%	31	2.58%	0.015547
2	127	WCI-34275		6/9/2004 11:29	0.89	85.5	2889	299	0.103	2600	11.50%	99.25	3.82%	0.034354
3	116	WCI-34275		12/16/2003 14:23	0.89	85.1	1482	131	0.088	1200	10.92%	53	4.42%	0.035762
4	110	WCI-34275		7/28/2005 14:37	0.89	85.4	3085	282	0.091	2200	12.82%	103.5	4.70%	0.033549
5	108	WCI-34275		11/21/2003 15:24	0.90	85.3	3085	204	0.066	2200	9.27%	105	4.77%	0.034036
6	106	WCI-34275		7/28/2005 14:37	0.90	84.7	1082	126	0.116	1000	12.60%	48	4.80%	0.044362
PASSES 10% TEST BUT FAILS DUCT STANDARDS														
7	101	WCI-34275		11/21/2003 15:28	0.90	85	1482	140	0.094	1000	14.00%	50.5	5.05%	0.034076
8	89	WCI-34275		11/21/2003 15:19	0.89	85.2	1994	163	0.082	1200	13.58%	64	5.33%	0.032096
9	84	WCI-34275		10/14/2004 14:05	0.89	84.5	1994	222	0.111	1200	18.50%	67	5.58%	0.033601
10	79	WCI-34275		9/15/2004 10:18	0.89	86.2	1994	110	0.055	1200	9.17%	70	5.83%	0.035105
11	77	WCI-34275		7/13/2004 7:27	0.90	85.1	1482	125	0.084	1000	12.50%	59	5.90%	0.039811
12	70	WCI-34275		6/9/2004 11:33	0.89	84.9	1994	177	0.089	1400	12.64%	88.5	6.32%	0.044383
13	68	WCI-34275		3/7/2005 15:56	0.89	84.8	1994	198	0.099	1400	14.14%	89	6.36%	0.044634
14	65	WCI-34275		9/15/2004 10:19	0.90	85	1482	137	0.092	1000	13.70%	65	6.50%	0.04386
15	60	WCI-34275		11/21/2003 15:28	0.89	84.8	1994	202	0.101	1200	16.83%	79.5	6.63%	0.03987
16	59	WCI-34275		11/21/2003 15:26	0.90	85.1	1994	154.5	0.077	1200	12.88%	81.5	6.79%	0.040873
17	49	WCI-34275		8/30/2004 10:22	0.89	85.1	1994	166.5	0.084	1200	13.88%	90.5	7.54%	0.045386
18	36	WCI-34275		11/21/2003 15:26	0.90	84.8	1994	174	0.087	1200	14.50%	98	8.17%	0.049147
19	32	WCI-34275		5/18/2005 12:21	0.90	85	1482	133	0.090	1000	13.30%	83.5	8.35%	0.056343
20	29	WCI-34275		10/14/2004 14:06	0.90	83.7	1351	150.5	0.111	1200	12.54%	103.5	8.63%	0.07661
21	23	WCI-34275		5/18/2005 12:21	0.90	84.8	1482	146	0.099	1000	14.60%	94	9.40%	0.063428
22	11	WCI-34275		10/14/2004 14:05	0.90	85.2	1482	116.5	0.079	1000	11.65%	109.5	10.95%	0.073887
23	3	WCI-34275		8/30/2004 10:54	0.90	82	1351	244	0.181	1000	24.40%	161.5	16.15%	0.119541
FAILS TO MEET BOTH BUILDSMART 10% and DUCT STANDARDS														
24	19	WCI-34275		3/7/2005 15:56	0.91	83.4	1351	159	0.118	1200	13.25%	118.5	9.88%	0.087713
25	45	WCI-34275		11/21/2003 15:27	0.91	83.4	1351	162	0.120	1000	16.20%	76	7.60%	0.056255
26	63	WCI-34275		6/29/2005 13:56	0.91	85.2	1482	108	0.073	1000	10.80%	66	6.60%	0.044534
27	64	WCI-34275		7/13/2004 7:27	0.91	84.7	1482	139.5	0.094	1000	13.95%	65.5	6.55%	0.044197
28	7	WCI-34275		7/28/2005 14:37	0.92	83.7	1478	326	0.221	1200	27.17%	143.5	11.96%	0.097091
29	9	WCI-34275		8/30/2004 10:21	0.92	83	1478	212.5	0.144	1200	17.71%	134	11.17%	0.090663
30	16	WCI-34275		12/16/2003 14:23	0.92	83.4	1478	186	0.126	1200	15.50%	124	10.33%	0.083897
31	17	WCI-34275		9/15/2004 10:17	0.92	83	1478	213.5	0.144	1200	17.79%	120	10.00%	0.081191
32	44	WCI-34275		12/22/2004 14:19	0.92	83.9	1478	151.5	0.103	1000	15.15%	76	7.60%	0.051421
33	46	WCI-34275		11/21/2003 15:27	0.92	84.3	1482	163.5	0.110	1000	16.35%	76	7.60%	0.051282
34	55	WCI-34275		1/9/2004 9:52	0.92	83.9	1478	150.5	0.102	1000	15.05%	71.5	7.15%	0.048376
35	73	WCI-34275		7/13/2004 9:05	0.92	84.7	1482	136	0.092	1000	13.60%	61	6.10%	0.041161
36	80	WCI-34275		12/22/2004 14:18	0.92	85.2	1478	98	0.066	1000	9.80%	57	5.70%	0.038566
37	86	WCI-34275		9/15/2004 10:17	0.92	85.1	1994	130.5	0.065	1200	10.88%	65	5.42%	0.032598
38	94	WCI-34275		11/21/2003 15:19	0.92	84.7	1482	138	0.093	1000	13.80%	52	5.20%	0.035088
39	104	WCI-34275		2/23/2004 11:24	0.92	84.8	1482	112	0.076	1000	11.20%	49	4.90%	0.033053
40	105	WCI-34275		8/30/2004 10:54	0.92	85.1	1994	192	0.096	1400	13.71%	68	4.86%	0.034102
41	117	WCI-34275		8/30/2004 10:20	0.92	84.8	1691	129	0.076	1200	10.75%	53	4.42%	0.031342
42	120	WCI-34275		2/23/2004 11:23	0.92	86.1	1691	225	0.133	1200	18.75%	52	4.33%	0.030751
43	10	WCI-34275		12/22/2004 14:19	0.93	84.7	1663	157	0.094	1000	15.70%	111	11.10%	0.066747
44	12	WCI-34275		3/7/2005 15:56	0.93	84.4	1663	180	0.108	1200	15.00%	129	10.75%	0.077571
45	33	WCI-34275		7/13/2004 7:20	0.93	83.4	2195	295.5	0.135	1600	18.47%	133.5	8.34%	0.06082
46	74	WCI-34275		8/30/2004 10:54	0.93	84.7	1663	159.5	0.096	1200	13.29%	73	6.08%	0.043897
47	109	WCI-34275		12/22/2004 14:18	0.93	86	1994	141.5	0.071	1200	11.79%	57	4.75%	0.028586
48	2	WCI-34275		7/27/2005 10:58	0.94	84	1663	402.5	0.242	1200	33.54%	224	18.67%	0.134696
49	22	WCI-34275		7/27/2005 10:58	0.94	84.9	1663	130	0.078	1200	10.83%	113	9.42%	0.067949
50	41	WCI-34275		7/13/2004 7:25	0.94	81.7	2195	432	0.197	1600	27.00%	127	7.94%	0.057859
51	69	WCI-34275		9/15/2004 10:17	0.94	84.8	1663	133.5	0.080	1200	11.13%	76	6.33%	0.045701
52	1	WCI-34275		7/27/2005 10:58	0.95	78.2	1663	386.5	0.232	1200	32.21%	234.5	19.54%	0.14101
53	4	WCI-34275		11/21/2003 15:20	0.95	81.6	1478	271	0.183	1000	27.10%	148.5	14.85%	0.100474
54	5	WCI-34275		3/7/2005 15:56	0.95	83.7	1663	207.5	0.125	1000	20.75%	144	14.40%	0.08659
55	6	WCI-34275		12/22/2004 14:18	0.95	83.8	1663	200	0.120	1000	20.00%	137	13.70%	0.082381
56	13	WCI-34275		8/30/2004 10:21	0.95	83.7	1663	208.5	0.125	1000	20.85%	107	10.70%	0.064342
57	21	WCI-34275		1/9/2004 9:52	0.95	84.1	1663	178	0.107	1000	17.80%	96	9.60%	0.057727
58	24	WCI-34275		8/30/2004 10:22	0.95	84.1	1663	178	0.107	1000	17.80%	93.5	9.35%	0.056224
59	25	WCI-34275		3/7/2005 15:56	0.95	83.5	1663	210	0.126	1000	21.00%	92	9.20%	0.055322
60	27	WCI-34275		1/9/2004 9:52	0.95	83	1478	181	0.122	1000	18.10%	88	8.80%	0.05954
61	35	WCI-34275		8/30/2004 10:21	0.95	84.4	1663	152	0.091	1200	12.67%	98	8.17%	0.05893
62	38	WCI-34275		7/27/2005 10:58	0.95	83.1	1478	301	0.204	1200	25.08%	96.5	8.04%	0.065291
63	47	WCI-34275		3/7/2005 15:56	0.95	83.8	1663	187	0.112	1000	18.70%	75.5	7.55%	0.0454
64	78	WCI-34275		11/21/2003 15:24	0.95	83.3	1478	160	0.108	1000	16.00%	58.5	5.85%	0.039581
65	85	WCI-34275		1/9/2004 9:53	0.95	83.7	1478	129	0.087	1200	10.75%	67	5.58%	0.045332
66	87	WCI-34275		12/16/2003 14:24	0.95	84.4	1663	154	0.093	1200	12.83%	65	5.42%	0.039086
67	102	WCI-34275		3/7/2005 15:56	0.95	85.7	1691	117.5	0.069	1200	9.79%	60	5.00%	0.035482
68	20	WCI-34275		8/30/2004 10:21	0.96	83.7	2889	293	0.101	2000	14.65%	192	9.60%	0.066459
69	26	WCI-34275		6/29/2005 14:05	0.96	83.6	2556	305	0.119	2000	15.25%	180	9.00%	0.070423
70	40	WCI-34275		6/9/2004 11:30	0.96	83.1	2556	363.5	0.142	2000	18.18%	159	7.95%	0.062207

OS 3A 025

75	58	WCI-34275	3/7/2005 15:56	0.96	83.2	1082	116	0.107	1000	11.60%	69	6.90%	0.063771
76	75	WCI-34275	6/9/2004 11:31	0.96	82.2	2889	457.5	0.158	2600	17.60%	156.5	6.02%	0.054171
77	97	WCI-34275	7/13/2004 9:05	0.96	83.9	1269	130.5	0.103	1000	13.05%	51.5	5.15%	0.040583
78	99	WCI-34275	6/9/2004 11:30	0.96	85.4	3085	219	0.071	2200	9.95%	112.5	5.11%	0.036467
79	100	WCI-34275	3/7/2005 15:56	0.96	84.6	1082	94	0.087	1000	9.40%	51	5.10%	0.047135
80	113	WCI-34275	11/21/2003 15:27	0.96	85.1	1082	213	0.197	1000	21.30%	45	4.50%	0.04159
81	114	WCI-34275	7/28/2005 14:38	0.96	81.1	1269	152	0.120	1400	10.86%	62.5	4.46%	0.049251
82	123	WCI-34275	1/9/2004 9:52	0.96	83.4	1691	101	0.060	1200	8.42%	51	4.25%	0.03016
83	128	WCI-34275	11/21/2003 15:22	0.96	83.6	1082	84.5	0.078	1000	8.45%	38	3.80%	0.03512
84	129	WCI-34275	7/27/2005 14:32	0.96	84.8	1269	147.5	0.116	2000	7.38%	73.5	3.68%	0.05792
85	131	WCI-34275	7/13/2004 9:05	0.96	84.8	1691	111	0.066	1200	9.25%	41	3.42%	0.024246
86	14	WCI-34275	8/30/2004 10:20	0.97	82.9	2889	381	0.132	2000	19.05%	212.5	10.63%	0.073555
87	15	WCI-34275	7/27/2005 10:58	0.97	83.5	2556	336	0.131	2000	16.80%	209.5	10.48%	0.081964
88	18	WCI-34275	6/29/2005 14:05	0.97	83.5	2556	398.5	0.156	2000	19.93%	198.5	9.93%	0.07766
89	43	WCI-34275	10/14/2004 14:04	0.97	83.4	2556	304	0.119	2000	15.20%	154.5	7.73%	0.060446
90	52	WCI-34275	1/9/2004 9:52	0.97	84.1	1663	157	0.094	1000	15.70%	73	7.30%	0.043897
91	57	WCI-34275	1/9/2004 9:53	0.97	83.4	1269	141.5	0.112	1000	14.15%	69.5	6.95%	0.054768
92	61	WCI-34275	12/22/2004 14:19	0.97	83.8	2889	262.5	0.091	2000	13.13%	132.5	6.63%	0.045864
93	71	WCI-34275	7/28/2005 14:37	0.97	83.2	1269	213.5	0.168	1000	21.35%	61.5	6.15%	0.048463
94	81	WCI-34275	1/9/2004 9:53	0.97	83.5	1269	135.5	0.107	1000	13.55%	57	5.70%	0.044917
95	96	WCI-34275	12/16/2003 14:23	0.97	84.1	1082	117	0.108	1200	9.75%	62	5.17%	0.057301
96	107	WCI-34275	11/21/2003 15:23	0.97	82.9	1482	120	0.081	1000	12.00%	48	4.80%	0.032389
97	111	WCI-34275	7/15/2004 15:35	0.97	84.1	1691	96	0.057	1000	9.60%	47	4.70%	0.027794
98	125	WCI-34275	7/27/2005 14:32	0.97	83.7	1691	140.5	0.083	2000	7.03%	77.5	3.88%	0.045831
99	133	WCI-34275	3/7/2005 15:56	0.97	84.2	1994	109	0.055	1400	7.79%	38	2.71%	0.019057
100	30	WCI-34275	5/18/2005 12:22	0.98	83.5	1269	125.5	0.099	1000	12.55%	86	8.60%	0.06777
101	31	WCI-34275	12/22/2004 14:18	0.98	83.4	2889	290	0.100	2000	14.50%	167.5	8.38%	0.057979
102	34	WCI-34275	8/30/2004 10:21	0.98	83.7	2889	259.5	0.090	2000	12.98%	166.5	8.33%	0.057632
103	39	WCI-34275	5/18/2005 12:21	0.98	83.7	1269	116	0.091	1000	11.60%	80	8.00%	0.063042
104	42	WCI-34275	2/23/2004 11:25	0.98	82.5	2556	379	0.148	2000	18.95%	158	7.90%	0.061815
105	50	WCI-34275	8/30/2004 10:20	0.98	83.4	2889	288.5	0.100	2000	14.43%	149.5	7.48%	0.051748
106	54	WCI-34275	5/18/2005 12:22	0.98	83.7	1269	110	0.087	1000	11.00%	72	7.20%	0.056738
107	66	WCI-34275	4/28/2005 8:01	0.98	84	2889	215.5	0.075	2000	10.78%	129	6.45%	0.044652
108	67	WCI-34275	4/28/2005 8:01	0.98	84.7	2889	191	0.066	2000	9.55%	128.5	6.43%	0.044479
109	72	WCI-34275	4/28/2005 8:03	0.98	84.7	1082	98.5	0.091	1000	9.85%	61.5	6.15%	0.056839
110	91	WCI-34275	7/28/2005 14:38	0.98	83	1269	201	0.158	1400	14.36%	74	5.29%	0.058314
111	92	WCI-34275	7/13/2004 9:05	0.98	83.6	1269	117	0.092	1000	11.70%	52.5	5.25%	0.041371
112	115	WCI-34275	11/21/2003 15:22	0.98	83.1	1994	169.5	0.085	1200	14.13%	53.5	4.46%	0.02683
113	118	WCI-34275	8/30/2004 10:22	0.98	84.4	3282	284	0.087	3000	9.47%	132.34	4.41%	0.040323
114	130	WCI-34275	12/16/2003 14:24	0.98	84.4	1082	76	0.070	1200	6.33%	41	3.42%	0.037893
115	76	WCI-34275	3/7/2005 15:56	0.99	83.3	1691	132	0.078	1200	11.00%	72	6.00%	0.042578
116	90	WCI-34275	12/22/2004 14:17	0.99	84.8	1691	117	0.069	1200	9.75%	64	5.33%	0.037847
117	98	WCI-34275	2/23/2004 11:48	1.00	83.9	1691	143	0.085	1200	11.92%	61.5	5.13%	0.036369
118	112	WCI-34275	8/30/2004 10:21	1.00	85.1	2889	173.75	0.060	2400	7.24%	110	4.58%	0.038075
119	132	WCI-34275	7/28/2005 14:39	1.00	85.2	2889	202	0.070	2006	10.07%	68	3.39%	0.023538
120	62	WCI-34275	7/27/2005 10:58	1.01	84.1	1269	99	0.078	1000	9.90%	66	6.60%	0.052009
121	83	WCI-34275	4/28/2005 8:02	1.01	84.1	1269	83	0.065	1000	8.30%	56.5	5.65%	0.044523
122	95	WCI-34275	6/9/2004 11:33	1.01	82.9	1269	142	0.112	1200	11.83%	62	5.17%	0.048857
123	119	WCI-34275	10/14/2004 14:04	1.01	84.4	3085	195	0.063	2200	8.86%	97	4.41%	0.031442
124	28	WCI-34275	7/28/2005 14:38	1.02	83.4	1691	144	0.085	1200	12.00%	104	8.67%	0.061502
125	122	WCI-34275	1/9/2004 9:53	1.02	84.6	1082	103.5	0.096	1000	10.35%	43	4.30%	0.039741
126	126	WCI-34275	3/7/2005 15:56	1.02	84.3	1994	136.5	0.068	1200	11.38%	46	3.83%	0.023069
127	8	WCI-34275	7/13/2004 7:27	1.05	82.5	1691	178	0.105	1000	17.80%	119	11.90%	0.070373
128	37	WCI-34275	1/9/2004 9:53	1.05	82.8	1691	150	0.089	1200	12.50%	98	8.17%	0.057954
129	82	WCI-34275	6/9/2004 11:32	1.05	82.9	1691	148.5	0.088	1000	14.85%	56.5	5.65%	0.033412
130	93	WCI-34275	7/28/2005 14:38	1.05	82	1691	223.5	0.132	1400	15.96%	73	5.21%	0.04317
131	121	WCI-34275	2/23/2004 11:23	1.05	81.8	1691	117	0.069	1200	9.75%	52	4.33%	0.030751
132	124	WCI-34275	1/9/2004 9:53	1.05	84.1	1269	122	0.096	1000	12.20%	41	4.10%	0.032309
133	88-see72	WCI-34275	4/28/2005 8:02 ne address	83.9	1269	71.5	0.056	1000	7.15%	54	5.40%	0.042553	
134	103	WCI-34275	11/21/2003 15:22		1994	157	0.079	1200	13.08%	59	4.92%	0.029589	

*WCI community at zipcode 34275 that is a designated BuildSmart community with 456 certified homes (GOLD-6 (1.3%); SILVER-262 (57.5%); and BRONZE-188 (41.2%))

**Residential New Construction
BuildSmart™
Trade Ally Program Standards**

Effective: June 1, 2000
Florida Power & Light Company
Residential New Construction BuildSmart™
Trade Ally Program Standards

TECHNICAL SPECIFICATIONS OF ELIGIBILITY

- Air distribution system must meet the following criteria:
Sealing of the ducted air distribution system may have a maximum cfm leakage of five percent (5%) of the air-conditioned square footage of the home at the final inspection and three percent (3%) at the mid-point inspection. State of Florida Energy Code approved closure systems must be used for all duct system connections.

Sorted by HERS scores

RANK BY

Exhibit 1

HERS Score	Home Identifier	Address*	Build Smart Medallion*	Date processed	E-Ratio As-Built	HERS Score	Sq Ft of living area	CFM25 TOTAL	Qn of TOTAL	AHU Rated Air Flow	Duct Leak Total %	CFM25 OUT	Duct Leak Out %	Qn of OUT
------------	-----------------	----------	------------------------	----------------	------------------	------------	----------------------	-------------	-------------	--------------------	-------------------	-----------	-----------------	-----------

GOLD MEDALLION HOMES: 0.7 E-RATIO OR LOWER

NONE

SILVER MEDALLION HOMES: 0.71 TO 0.80 E-RATIO

NONE

BRONZE MEDALLION HOMES: 0.81-0.90 E-RATIO

ENERGY STAR HOME® QUALIFIED

1	134	WCI-34275		9/15/2004 10:18	0.89	86.5	1994	140	0.070	1200	11.67%	31	2.58%	0.015547
2	79	WCI-34275		9/15/2004 10:18	0.89	86.2	1994	110	0.055	1200	9.17%	70	5.83%	0.035105
3	120	WCI-34275		2/23/2004 11:23	0.92	86.1	1691	225	0.133	1200	18.75%	52	4.33%	0.030751
4	109	WCI-34275		12/22/2004 14:18	0.93	86	1994	141.5	0.071	1200	11.79%	57	4.75%	0.028586

GREEN BUILDING STANDARD ELIGIBLE

1	127	WCI-34275		6/9/2004 11:29	0.89	85.5	2889	299	0.103	2600	11.50%	99.25	3.82%	0.034354
2	110	WCI-34275		7/28/2005 14:37	0.89	85.4	3085	282	0.091	2200	12.82%	103.5	4.70%	0.033549
3	89	WCI-34275		11/21/2003 15:19	0.89	85.2	1994	163	0.082	1200	13.58%	64	5.33%	0.032096
4	49	WCI-34275		8/30/2004 10:22	0.89	85.1	1994	166.5	0.084	1200	13.88%	90.5	7.54%	0.045386
5	116	WCI-34275		12/16/2003 14:23	0.89	85.1	1482	131	0.088	1200	10.92%	53	4.42%	0.035762
6	70	WCI-34275		6/9/2004 11:33	0.89	84.9	1994	177	0.089	1400	12.64%	88.5	6.32%	0.044383
7	60	WCI-34275		11/21/2003 15:28	0.89	84.8	1994	202	0.101	1200	16.83%	79.5	6.63%	0.03987
8	68	WCI-34275		3/7/2005 15:56	0.89	84.8	1994	198	0.099	1400	14.14%	89	6.36%	0.044634
9	84	WCI-34275		10/14/2004 14:05	0.89	84.5	1994	222	0.111	1200	18.50%	67	5.58%	0.033601
10	108	WCI-34275		11/21/2003 15:24	0.90	85.3	3085	204	0.066	2200	9.27%	105	4.77%	0.034036
11	11	WCI-34275		10/14/2004 14:05	0.90	85.2	1482	116.5	0.079	1000	11.65%	109.5	10.95%	0.073887
12	59	WCI-34275		11/21/2003 15:26	0.90	85.1	1994	154.5	0.077	1200	12.88%	81.5	6.79%	0.040873
13	77	WCI-34275		7/13/2004 7:27	0.90	85.1	1482	125	0.084	1000	12.50%	59	5.90%	0.039811
14	32	WCI-34275		5/18/2005 12:21	0.90	85	1482	133	0.090	1000	13.30%	83.5	8.35%	0.056343
15	65	WCI-34275		9/15/2004 10:19	0.90	85	1482	137	0.092	1000	13.70%	65	6.50%	0.04386
16	101	WCI-34275		11/21/2003 15:28	0.90	85	1482	140	0.094	1000	14.00%	50.5	5.05%	0.034076
17	23	WCI-34275		5/18/2005 12:21	0.90	84.8	1482	146	0.099	1000	14.60%	94	9.40%	0.063428
18	36	WCI-34275		11/21/2003 15:26	0.90	84.8	1994	174	0.087	1200	14.50%	98	8.17%	0.049147
19	106	WCI-34275		7/28/2005 14:37	0.90	84.7	1082	126	0.116	1000	12.60%	48	4.80%	0.044362
20	29	WCI-34275		10/14/2004 14:06	0.90	83.7	1351	150.5	0.111	1200	12.54%	103.5	8.63%	0.07661
21	3	WCI-34275		8/30/2004 10:54	0.90	82	1351	244	0.181	1000	24.40%	161.5	16.15%	0.119541
22	63	WCI-34275		6/29/2005 13:56	0.91	85.2	1482	108	0.073	1000	10.80%	66	6.60%	0.044534
23	64	WCI-34275		7/13/2004 7:27	0.91	84.7	1482	139.5	0.094	1000	13.95%	65.5	6.55%	0.044197
24	19	WCI-34275		3/7/2005 15:56	0.91	83.4	1351	159	0.118	1200	13.25%	118.5	9.88%	0.087713
25	45	WCI-34275		11/21/2003 15:27	0.91	83.4	1351	162	0.120	1000	16.20%	76	7.60%	0.056255
26	80	WCI-34275		12/22/2004 14:18	0.92	85.2	1478	98	0.066	1000	9.80%	57	5.70%	0.038566
27	86	WCI-34275		9/15/2004 10:17	0.92	85.1	1994	130.5	0.065	1200	10.88%	65	5.42%	0.032598
28	105	WCI-34275		8/30/2004 10:54	0.92	85.1	1994	192	0.096	1400	13.71%	68	4.86%	0.034102
29	104	WCI-34275		2/23/2004 11:24	0.92	84.8	1482	112	0.076	1000	11.20%	49	4.90%	0.033063
30	117	WCI-34275		8/30/2004 10:20	0.92	84.8	1691	129	0.076	1200	10.75%	53	4.42%	0.031342
31	73	WCI-34275		7/13/2004 9:05	0.92	84.7	1482	136	0.092	1000	13.60%	61	6.10%	0.041161
32	94	WCI-34275		11/21/2003 15:19	0.92	84.7	1482	138	0.093	1000	13.80%	52	5.20%	0.035088
33	46	WCI-34275		11/21/2003 15:27	0.92	84.3	1482	163.5	0.110	1000	16.35%	76	7.60%	0.051282
34	44	WCI-34275		12/22/2004 14:19	0.92	83.9	1478	151.5	0.103	1000	15.15%	76	7.60%	0.051421
35	55	WCI-34275		1/9/2004 9:52	0.92	83.9	1478	150.5	0.102	1000	15.05%	71.5	7.15%	0.048376
36	7	WCI-34275		7/28/2005 14:37	0.92	83.7	1478	326	0.221	1200	27.17%	143.5	11.96%	0.097091
37	16	WCI-34275		12/16/2003 14:23	0.92	83.4	1478	186	0.126	1200	15.50%	124	10.33%	0.083897
38	9	WCI-34275		8/30/2004 10:21	0.92	83	1478	212.5	0.144	1200	17.71%	134	11.17%	0.090663
39	17	WCI-34275		9/15/2004 10:17	0.92	83	1478	213.5	0.144	1200	17.79%	120	10.00%	0.081191
40	10	WCI-34275		12/22/2004 14:19	0.93	84.7	1663	157	0.094	1000	15.70%	111	11.10%	0.066747
41	74	WCI-34275		8/30/2004 10:54	0.93	84.7	1663	159.5	0.096	1200	13.29%	73	6.08%	0.043897
42	12	WCI-34275		3/7/2005 15:56	0.93	84.4	1663	180	0.108	1200	15.00%	129	10.75%	0.077571
43	33	WCI-34275		7/13/2004 7:20	0.93	83.4	2195	295.5	0.135	1600	18.47%	133.5	8.34%	0.06082
44	22	WCI-34275			0.94	84.9	1663	130	0.078	1200	10.83%	113	9.42%	0.067949
45	69	WCI-34275		9/15/2004 10:17	0.94	84.8	1663	133.5	0.080	1200	11.13%	76	6.33%	0.045701
46	2	WCI-34275		7/27/2005 10:58	0.94	84	1663	402.5	0.242	1200	33.54%	224	18.67%	0.134696
46	102	WCI-34275		3/7/2005 15:56	0.95	85.7	1691	117.5	0.069	1200	9.79%	60	5.00%	0.035482
47	35	WCI-34275		8/30/2004 10:21	0.95	84.4	1663	152	0.091	1200	12.67%	98	8.17%	0.05893
48	87	WCI-34275		12/16/2003 14:24	0.95	84.4	1663	154	0.093	1200	12.83%	65	5.42%	0.039086
49	21	WCI-34275		1/9/2004 9:52	0.95	84.1	1663	178	0.107	1000	17.80%	96	9.60%	0.057727
50	24	WCI-34275		8/30/2004 10:22	0.95	84.1	1663	178	0.107	1000	17.80%	93.5	9.35%	0.056224
51	6	WCI-34275		12/22/2004 14:18	0.95	83.8	1663	200	0.120	1000	20.00%	137	13.70%	0.082381
52	47	WCI-34275		3/7/2005 15:56	0.95	83.8	1663	187	0.112	1000	18.70%	75.5	7.55%	0.0454
53	5	WCI-34275		3/7/2005 15:56	0.95	83.7	1663	207.5	0.125	1000	20.75%	144	14.40%	0.08659
54	13	WCI-34275		8/30/2004 10:21	0.95	83.7	1663	208.5	0.125	1000	20.85%	107	10.70%	0.064342
55	85	WCI-34275		1/9/2004 9:53	0.95	83.7	1478	129	0.087	1200	10.75%	67	5.58%	0.045332
56	25	WCI-34275		3/7/2005 15:56	0.95	83.5	1663	210	0.126	1000	21.00%	92	9.20%	0.055322
57	78	WCI-34275		11/21/2003 15:24	0.95	83.3	1478	160	0.108	1000	16.00%	58.5	5.85%	0.039581
58	38	WCI-34275		7/27/2005 10:58	0.95	83.1	1478	301	0.204	1200	25.08%	96.5	8.04%	0.065291
59	27	WCI-34275		1/9/2004 9:52	0.95	83	1478	181	0.122	1000	18.10%	88	8.80%	0.05954
60	99	WCI-34275		6/9/2004 11:30	0.96	85.4	3085	219	0.071	2200	9.95%	112.5	5.11%	0.036467
61	113	WCI-34275		11/21/2003 15:27	0.96	85.1	1082	213	0.197	1000	21.30%	45	4.50%	0.04159
62	129	WCI-34275		7/27/2005 14:32	0.96	84.8	1269	147.5	0.116	2000	7.38%	73.5	3.68%	0.05792
63	131	WCI-34275		7/13/2004 9:05	0.96	84.8	1691	111	0.066	1200	9.25%	41	3.42%	0.024246

09-0027-kt
 DS-P: tAOKS
 EX 1/18/11

64	100	WCI-34275	3/7/2005 15:56	0.96	84.6	1082	94	0.087	1000	9.40%	51	5.10%	0.047135
65	97	WCI-34275	7/13/2004 9:05	0.96	83.9	1269	130.5	0.103	1000	13.05%	51.5	5.15%	0.040583
66	56	WCI-34275	4/28/2005 8:05	0.96	83.8	2556	281	0.110	2000	14.05%	142.5	7.13%	0.055751
67	20	WCI-34275	8/30/2004 10:21	0.96	83.7	2889	293	0.101	2000	14.65%	192	9.60%	0.066459
68	26	WCI-34275	6/29/2005 14:05	0.96	83.6	2556	305	0.119	2000	15.25%	180	9.00%	0.070423
69	128	WCI-34275	11/21/2003 15:22	0.96	83.6	1082	84.5	0.078	1000	8.45%	38	3.80%	0.03512
70	48	WCI-34275	5/18/2005 12:22	0.96	83.5	1082	105.5	0.098	1000	10.55%	75.5	7.55%	0.069778
71	51	WCI-34275	7/13/2004 7:26	0.96	83.4	2556	244	0.095	1600	15.25%	118	7.38%	0.046166
72	53	WCI-34275	6/9/2004 11:31	0.96	83.4	2556	326	0.128	2000	16.30%	145	7.25%	0.056729
73	123	WCI-34275	1/9/2004 9:52	0.96	83.4	1691	101	0.060	1200	8.42%	51	4.25%	0.03016
74	58	WCI-34275	3/7/2005 15:56	0.96	83.2	1082	116	0.107	1000	11.60%	69	6.90%	0.063771
75	40	WCI-34275	6/9/2004 11:30	0.96	83.1	2556	363.5	0.142	2000	18.18%	159	7.95%	0.062207
76	75	WCI-34275	6/9/2004 11:31	0.96	82.2	2889	457.5	0.158	2600	17.60%	156.5	6.02%	0.054171
77	133	WCI-34275	3/7/2005 15:56	0.97	84.2	1994	109	0.055	1400	7.79%	38	2.71%	0.019057
78	52	WCI-34275	1/9/2004 9:52	0.97	84.1	1663	157	0.094	1000	15.70%	73	7.30%	0.043897
79	96	WCI-34275	12/16/2003 14:23	0.97	84.1	1082	117	0.108	1200	9.75%	62	5.17%	0.057301
80	111	WCI-34275	7/15/2004 15:35	0.97	84.1	1691	96	0.057	1000	9.60%	47	4.70%	0.027794
81	61	WCI-34275	12/22/2004 14:19	0.97	83.8	2889	262.5	0.091	2000	13.13%	132.5	6.63%	0.045864
82	125	WCI-34275	7/27/2005 14:32	0.97	83.7	1691	140.5	0.083	2000	7.03%	77.5	3.88%	0.045831
83	15	WCI-34275	7/27/2005 10:58	0.97	83.5	2556	336	0.131	2000	16.80%	209.5	10.48%	0.081964
84	18	WCI-34275	6/29/2005 14:05	0.97	83.5	2556	398.5	0.156	2000	19.93%	198.5	9.93%	0.07766
85	81	WCI-34275	1/9/2004 9:53	0.97	83.5	1269	135.5	0.107	1000	13.55%	57	5.70%	0.044917
86	43	WCI-34275	10/14/2004 14:04	0.97	83.4	2556	304	0.119	2000	15.20%	154.5	7.73%	0.060446
87	57	WCI-34275	1/9/2004 9:53	0.97	83.4	1269	141.5	0.112	1000	14.15%	69.5	6.95%	0.054768
88	71	WCI-34275	7/28/2005 14:37	0.97	83.2	1269	213.5	0.168	1000	21.35%	61.5	6.15%	0.048463
89	14	WCI-34275	8/30/2004 10:20	0.97	82.9	2889	381	0.132	2000	19.05%	212.5	10.63%	0.073555
90	107	WCI-34275	11/21/2003 15:23	0.97	82.9	1482	120	0.081	1000	12.00%	48	4.80%	0.032389
91	67	WCI-34275	4/28/2005 8:01	0.98	84.7	2889	191	0.066	2000	9.55%	128.5	6.43%	0.044479
92	72	WCI-34275	4/28/2005 8:03	0.98	84.7	1082	98.5	0.091	1000	9.85%	61.5	6.15%	0.056839
93	118	WCI-34275	8/30/2004 10:22	0.98	84.4	3282	284	0.087	3000	9.47%	132.34	4.41%	0.040323
94	130	WCI-34275	12/16/2003 14:24	0.98	84.4	1082	76	0.070	1200	6.33%	41	3.42%	0.037893
95	66	WCI-34275	4/28/2005 8:01	0.98	84	2889	215.5	0.075	2000	10.78%	129	6.45%	0.044652
96	34	WCI-34275	8/30/2004 10:21	0.98	83.7	2889	259.5	0.090	2000	12.98%	166.5	8.33%	0.057632
97	39	WCI-34275	5/18/2005 12:21	0.98	83.7	1269	116	0.091	1000	11.60%	80	8.00%	0.063042
98	54	WCI-34275	5/18/2005 12:22	0.98	83.7	1269	110	0.087	1000	11.00%	72	7.20%	0.056738
99	92	WCI-34275	7/13/2004 9:05	0.98	83.6	1269	117	0.092	1000	11.70%	52.5	5.25%	0.041371
100	30	WCI-34275	5/18/2005 12:22	0.98	83.5	1269	125.5	0.099	1000	12.55%	86	8.60%	0.06777
101	31	WCI-34275	12/22/2004 14:18	0.98	83.4	2889	290	0.100	2000	14.50%	167.5	8.38%	0.057979
102	50	WCI-34275	8/30/2004 10:20	0.98	83.4	2889	288.5	0.100	2000	14.43%	149.5	7.48%	0.051748
103	115	WCI-34275	11/21/2003 15:22	0.98	83.1	1994	169.5	0.085	1200	14.13%	53.5	4.46%	0.02683
104	91	WCI-34275	7/28/2005 14:38	0.98	83	1269	201	0.158	1400	14.36%	74	5.29%	0.058314
105	42	WCI-34275	2/23/2004 11:25	0.98	82.5	2556	379	0.148	2000	18.95%	158	7.90%	0.061815
106	90	WCI-34275	12/22/2004 14:17	0.99	84.8	1691	117	0.069	1200	9.75%	64	5.33%	0.037847
107	76	WCI-34275	3/7/2005 15:56	0.99	83.3	1691	132	0.078	1200	11.00%	72	6.00%	0.042578
108	132	WCI-34275	7/28/2005 14:39	1.00	85.2	2889	202	0.070	2000	10.07%	68	3.39%	0.023538
109	112	WCI-34275	8/30/2004 10:21	1.00	85.1	2889	173.75	0.060	2400	7.24%	110	4.58%	0.038075
110	98	WCI-34275	2/23/2004 11:48	1.00	83.9	1691	143	0.085	1200	11.92%	61.5	5.13%	0.036369
NOT ELIGIBLE FOR EITHER ENERGY STAR OR GREEN BUILDING CERTIFICATION													
111	119	WCI-34275	10/14/2004 14:04	1.01	84.4	3085	195	0.063	2200	8.86%	97	4.41%	0.031442
112	62	WCI-34275	7/27/2005 10:58	1.01	84.1	1269	99	0.078	1000	9.90%	66	6.60%	0.052009
113	83	WCI-34275	4/28/2005 8:02	1.01	84.1	1269	83	0.065	1000	8.30%	56.5	5.65%	0.044523
114	95	WCI-34275	6/9/2004 11:33	1.01	82.9	1269	142	0.112	1200	11.83%	62	5.17%	0.048857
115	122	WCI-34275	1/9/2004 9:53	1.02	84.6	1082	103.5	0.096	1000	10.35%	43	4.30%	0.039741
116	126	WCI-34275	3/7/2005 15:56	1.02	84.3	1994	136.5	0.068	1200	11.38%	46	3.83%	0.023069
117	28	WCI-34275	7/28/2005 14:38	1.02	83.4	1691	144	0.085	1200	12.00%	104	8.67%	0.061502
118	124	WCI-34275	1/9/2004 9:53	1.05	84.1	1269	122	0.096	1000	12.20%	41	4.10%	0.032309
119	82	WCI-34275	6/9/2004 11:32	1.05	82.9	1691	148.5	0.088	1000	14.85%	56.5	5.65%	0.033412
120	37	WCI-34275	1/9/2004 9:53	1.05	82.8	1691	150	0.089	1200	12.50%	98	8.17%	0.057954
121	8	WCI-34275	7/13/2004 7:27	1.05	82.5	1691	178	0.105	1000	17.80%	119	11.90%	0.070373
122	93	WCI-34275	7/28/2005 14:38	1.05	82	1691	223.5	0.132	1400	15.96%	73	5.21%	0.04317
123	88-see72	WCI-34275	4/28/2005 8:02	1.05	83.9	1269	71.5	0.056	1000	7.15%	54	5.40%	0.042553
124	121	WCI-34275	2/23/2004 11:23	1.05	81.8	1691	117	0.069	1200	9.75%	52	4.33%	0.030751
125	41	WCI-34275	7/13/2004 7:25	0.94	81.7	2195	432	0.197	1600	27.00%	127	7.94%	0.057859
126	4	WCI-34275	11/21/2003 15:20	0.95	81.6	1478	271	0.183	1000	27.10%	148.5	14.85%	0.100474
127	114	WCI-34275	7/28/2005 14:38	0.96	81.1	1269	152	0.120	1400	10.86%	62.5	4.46%	0.049251
128	1	WCI-34275	7/27/2005 10:58	0.95	78.2	1663	386.5	0.232	1200	32.21%	234.5	19.54%	0.14101
129	103	WCI-34275	11/21/2003 15:22			1994	157	0.079	1200	13.08%	59	4.92%	0.029589

*WCI community at zipcode 34275 that is a designated BuildSmart community with 456 certified homes (GOLD-6 (1.3%); SILVER-262 (57.5%); and BRONZE-188 (41.2%))

Residential New Construction
BuildSmart™
Trade Ally Program Standards

Effective: June 1, 2000
 Florida Power & Light Company
 Residential New Construction BuildSmart™
 Trade Ally Program Standards

TECHNICAL SPECIFICATIONS OF ELIGIBILITY

- Air distribution system must meet the following criteria:
 Sealing of the ducted air distribution system may have a maximum cfm leakage of five percent (5%) of the air-conditioned square footage of the home at the final inspection and three percent (3%) at the mid-point inspection. State of Florida Energy Code approved closure systems must be used for all duct system connections.

Tested Build Smart Community* [ALL DATA AS-BUILT]

Dockets 04-0029-EG & 04-0660-EG

Sorted by Duct leakage

JSR-Page 5&5A of 5

RANK BY

DUCT Home Build Smart Date processed E-Ratio HERS Sq Ft of CFM25 Qn of AHU Rated Duct Leak CFM25 Duct Leak Qn of
LEAKAGE Identifier Address* Medallion* As-Built Score living area TOTAL TOTAL Air Flow Total % OUT Out % OUT
GOLD MEDALLION HOMES: 0.7 E-RATIO OR LOWER
NONE
SILVER MEDALLION HOMES: 0.71 to 0.80 E-RATIO
NONE
BRONZE MEDALLION HOMES: 0.81-0.90 E-RATIO

RANK BY	DUCT Identifier	Home Address*	Build Smart Medallion*	Date processed	E-Ratio As-Built	HERS Score	Sq Ft of living area	CFM25 TOTAL	Qn of TOTAL	AHU Rated Air Flow	Duct Leak Total %	CFM25 OUT	Duct Leak Out %	Qn of OUT	
	FOLLOWING MEET BUILDSMART TECHNICAL STANDARDS*** and WOULD BE ELIGIBLE FOR FLORIDA CODE CREDIT FOR "TIGHT DUCTS" UNDER NEW STAND														
1	134	WCI-34275		9/15/2004 10:18	0.89	88.5	1994	140	0.070	1200	11.67%	31	2.58%	0.015547	
	FOLLOWING MEET BUILDSMART TECHNICAL STANDARDS*** and WOULD BE ELIGIBLE FOR FLORIDA CODE CREDIT FOR "TIGHT DUCTS" UNTIL NEW STAND														
2	127	WCI-34275		6/9/2004 11:29	0.89	85.5	2889	299	0.103	2600	11.50%	99.25	3.82%	0.034354	
3	116	WCI-34275		12/16/2003 14:23	0.89	85.1	1482	131	0.088	1200	10.92%	53	4.42%	0.035762	
4	110	WCI-34275		7/28/2005 14:37	0.89	85.4	3085	282	0.091	2200	12.82%	103.5	4.70%	0.033549	
5	108	WCI-34275		11/21/2003 15:24	0.90	85.3	3085	204	0.086	2200	9.27%	105	4.77%	0.034036	
6	106	WCI-34275		7/28/2005 14:37	0.90	84.7	1082	126	0.116	1000	12.60%	48	4.80%	0.044362	
	FOLLOWING FAIL BUILDSMART TECHNICAL STANDARDS*** but WOULD BE ELIGIBLE FOR FLORIDA CODE CREDIT FOR "TIGHT DUCTS" UNDER NEW STAND														
7	109	WCI-34275		12/22/2004 14:18	0.93	86	1994	141.5	0.071	1200	11.79%	57	4.75%	0.028586	
8	131	WCI-34275		7/13/2004 9:05	0.96	84.8	1691	111	0.066	1200	9.25%	41	3.42%	0.024246	
9	133	WCI-34275		3/7/2005 15:56	0.97	84.2	1994	109	0.055	1400	7.79%	38	2.71%	0.019057	
10	111	WCI-34275		7/15/2004 15:35	0.97	84.1	1691	96	0.057	1000	9.60%	47	4.70%	0.027794	
11	115	WCI-34275		11/21/2003 15:22	0.98	83.1	1994	169.5	0.085	1200	14.13%	53.5	4.46%	0.02683	
12	132	WCI-34275		7/28/2005 14:39	1.00	85.2	2889	202	0.070	2006	10.07%	68	3.39%	0.023538	
13	103	WCI-34275		11/21/2003 15:22			1994	157	0.079	1200	13.08%	59	4.92%	0.029589	
	FOLLOWING DO NOT MEET BUILDSMART TECHNICAL STANDARDS*** NOR BE ELIGIBLE FOR FLORIDA CODE CREDIT FOR "TIGHT DUCTS"														
14	101	WCI-34275		11/21/2003 15:28	0.90	85	1482	140	0.094	1000	14.00%	50.5	5.05%	0.034076	
15	89	WCI-34275		11/21/2003 15:19	0.89	85.2	1994	163	0.082	1200	13.58%	64	5.33%	0.032096	
16	84	WCI-34275		10/14/2004 14:05	0.89	84.5	1994	222	0.111	1200	18.50%	67	5.58%	0.033601	
17	79	WCI-34275		9/15/2004 10:18	0.89	86.2	1994	110	0.055	1200	9.17%	70	5.83%	0.035105	
18	77	WCI-34275		7/13/2004 7:27	0.90	85.1	1482	125	0.084	1000	12.50%	59	5.90%	0.039811	
19	70	WCI-34275		6/9/2004 11:33	0.89	84.9	1994	177	0.089	1400	12.64%	88.5	6.32%	0.044383	
20	68	WCI-34275		3/7/2005 15:56	0.89	84.8	1994	198	0.099	1400	14.14%	89	6.36%	0.044634	
21	65	WCI-34275		9/15/2004 10:19	0.90	85	1482	137	0.092	1000	13.70%	65	6.50%	0.04388	
22	60	WCI-34275		11/21/2003 15:28	0.89	84.8	1994	202	0.101	1200	16.83%	79.5	6.63%	0.03987	
23	59	WCI-34275		11/21/2003 15:28	0.90	85.1	1994	154.5	0.077	1200	12.88%	81.5	6.79%	0.040873	
24	49	WCI-34275		8/30/2004 10:22	0.89	85.1	1994	166.5	0.084	1200	13.88%	90.5	7.54%	0.045386	
25	36	WCI-34275		11/21/2003 15:26	0.90	84.8	1994	174	0.087	1200	14.50%	98	8.17%	0.049147	
26	32	WCI-34275		5/18/2005 12:21	0.90	85	1482	133	0.090	1000	13.30%	83.5	8.35%	0.056343	
27	29	WCI-34275		10/14/2004 14:06	0.90	83.7	1351	150.5	0.111	1200	12.54%	103.5	8.63%	0.07661	
28	23	WCI-34275		5/18/2005 12:21	0.90	84.8	1482	146	0.099	1000	14.60%	94	9.40%	0.063428	
29	11	WCI-34275		10/14/2004 14:05	0.90	85.2	1482	116.5	0.079	1000	11.65%	108.5	10.95%	0.073887	
30	3	WCI-34275		8/30/2004 10:54	0.90	82	1351	244	0.181	1000	24.40%	161.5	16.15%	0.119541	
31	64	WCI-34275		7/13/2004 7:27	0.91	84.7	1482	139.5	0.094	1000	13.95%	65.5	6.55%	0.044197	
32	63	WCI-34275		6/29/2005 13:56	0.91	85.2	1482	108	0.073	1000	10.80%	66	6.60%	0.044534	
33	45	WCI-34275		11/21/2003 15:27	0.91	83.4	1351	162	0.120	1000	16.20%	76	7.60%	0.056255	
34	19	WCI-34275		3/7/2005 15:56	0.91	84.4	1351	159	0.118	1200	13.25%	118.5	9.88%	0.087713	
35	120	WCI-34275		2/23/2004 11:23	0.92	86.1	1691	225	0.133	1200	18.75%	52	4.33%	0.030751	
36	117	WCI-34275		8/30/2004 10:20	0.92	84.8	1691	129	0.076	1200	10.75%	53	4.42%	0.031342	
37	105	WCI-34275		8/30/2004 10:54	0.92	85.1	1994	192	0.096	1400	13.71%	68	4.86%	0.034102	
38	104	WCI-34275		2/23/2004 11:24	0.92	84.8	1482	112	0.076	1000	11.20%	49	4.90%	0.033063	
39	94	WCI-34275		11/21/2003 15:19	0.92	84.7	1482	138	0.093	1000	13.80%	52	5.20%	0.035088	
40	86	WCI-34275		9/15/2004 10:17	0.92	85.1	1994	130.5	0.085	1200	10.88%	65	5.42%	0.032598	
41	80	WCI-34275		12/22/2004 14:18	0.92	85.2	1478	98	0.086	1000	9.80%	57	5.70%	0.038566	
42	73	WCI-34275		7/13/2004 9:05	0.92	84.7	1482	136	0.092	1000	13.60%	61	6.10%	0.041161	
43	55	WCI-34275		1/9/2004 9:52	0.92	83.9	1478	150.5	0.102	1000	15.05%	71.5	7.15%	0.048376	
44	44	WCI-34275		12/22/2004 14:19	0.92	83.9	1478	151.5	0.103	1000	15.15%	76	7.60%	0.051421	
45	46	WCI-34275		11/21/2003 15:27	0.92	84.3	1482	163.5	0.110	1000	16.35%	76	7.60%	0.051282	
46	17	WCI-34275		9/15/2004 10:17	0.92	83	1478	213.5	0.144	1200	17.79%	120	10.00%	0.081191	
47	16	WCI-34275		12/16/2003 14:23	0.92	83.4	1478	186	0.126	1200	15.50%	124	10.33%	0.083897	
48	9	WCI-34275		8/30/2004 10:21	0.92	83	1478	212.5	0.144	1200	17.71%	134	11.17%	0.090663	
49	7	WCI-34275		7/28/2005 14:37	0.92	83.7	1478	326	0.221	1200	27.17%	143.5	11.96%	0.097091	
50	74	WCI-34275		8/30/2004 10:54	0.93	84.7	1663	159.5	0.096	1200	13.29%	73	6.08%	0.043897	
51	33	WCI-34275		7/13/2004 7:20	0.93	84.4	2195	295.5	0.135	1600	18.47%	133.5	8.34%	0.06082	
52	12	WCI-34275		3/7/2005 15:56	0.93	84.4	1663	180	0.108	1200	15.00%	129	10.75%	0.077571	
53	10	WCI-34275		12/22/2004 14:19	0.93	84.7	1663	157	0.094	1000	15.70%	111	11.10%	0.066747	
54	69	WCI-34275		9/15/2004 10:17	0.94	84.8	1663	133.5	0.080	1200	11.13%	76	6.33%	0.045701	
55	41	WCI-34275		7/13/2004 7:25	0.94	81.7	2195	432	0.197	1600	27.00%	127	7.94%	0.057859	
56	22	WCI-34275			0.94	84.9	1663	130	0.078	1200	10.83%	113	9.42%	0.067949	
57	2	WCI-34275		7/27/2005 10:58	0.94	84	1663	402.5	0.242	1200	33.54%	224	18.67%	0.134696	
58	102	WCI-34275		3/7/2005 15:56	0.95	85.7	1691	117.5	0.089	1200	9.79%	60	5.00%	0.035482	
59	87	WCI-34275		12/16/2003 14:24	0.95	84.4	1663	154	0.093	1200	12.83%	65	5.42%	0.039086	
60	85	WCI-34275		1/9/2004 9:53	0.95	83.7	1478	129	0.087	1200	10.75%	67	5.58%	0.045332	
61	78	WCI-34275		11/21/2003 15:24	0.95	83.3	1478	160	0.108	1000	16.00%	58.5	5.85%	0.039581	
62	47	WCI-34275		3/7/2005 15:56	0.95	83.8	1663	187	0.112	1000	18.70%	75.5	7.55%	0.0454	
63	38	WCI-34275		7/27/2005 10:58	0.95	83.1	1478	301	0.204	1200	25.08%	96.5	8.04%	0.065291	
64	35	WCI-34275		8/30/2004 10:21	0.95	84.4	1663	152	0.091	1200	12.67%	98	8.17%	0.05893	
65	27	WCI-34275		1/9/2004 9:52	0.95	83	1478	181	0.122	1000	18.10%	88	8.80%	0.05954	
66	25	WCI-34275		3/7/2005 15:56	0.95	83.5	1663	210	0.126	1000	21.00%	92	9.20%	0.055322	
67	24	WCI-34275		8/30/2004 10:22	0.95	84.1	1663	178	0.107	1000	17.80%	93.5	9.35%	0.056224	
68	21	WCI-34275		1/9/2004 9:52	0.95	84.1	1663	178	0.107	1000	17.80%	96	9.60%	0.057727	
69	13	WCI-34275		8/30/2004 10:21	0.95	83.7	1663	208.5	0.125	1000	20.85%	107	10.70%	0.064342	
70	6	WCI-34275													

04-025-86
 D.S. PSC-65B
 2-17-05

89	20	WCI-34275	8/30/2004 10:21	0.96	83.7	2889	293	0.101	2000	14.65%	192	9.60%	0.066459
90	125	WCI-34275	7/27/2005 14:32	0.97	83.7	1691	140.5	0.083	2000	7.03%	77.5	3.88%	0.045831
91	107	WCI-34275	11/21/2003 15:23	0.97	82.9	1482	120	0.081	1000	12.00%	48	4.80%	0.032389
92	81	WCI-34275	1/9/2004 9:53	0.97	83.5	1269	135.5	0.107	1000	13.55%	57	5.70%	0.044917
93	71	WCI-34275	7/28/2005 14:37	0.97	83.2	1269	213.5	0.166	1000	21.35%	61.5	6.15%	0.048463
94	61	WCI-34275	12/22/2004 14:19	0.97	83.8	2889	262.5	0.091	2000	13.13%	132.5	6.63%	0.045864
95	52	WCI-34275	1/9/2004 9:52	0.97	84.1	1663	157	0.094	1000	15.70%	73	7.30%	0.043897
96	96	WCI-34275	12/16/2003 14:23	0.97	84.1	1082	117	0.108	1200	9.75%	62	5.17%	0.057301
97	57	WCI-34275	1/9/2004 9:53	0.97	83.4	1269	141.5	0.112	1000	14.15%	69.5	6.95%	0.054768
98	43	WCI-34275	10/14/2004 14:04	0.97	83.4	2556	304	0.119	2000	15.20%	154.5	7.73%	0.060446
99	18	WCI-34275	6/29/2005 14:05	0.97	83.5	2556	398.5	0.156	2000	19.93%	198.5	9.93%	0.07766
100	15	WCI-34275	7/27/2005 10:58	0.97	83.5	2556	336	0.131	2000	16.80%	209.5	10.48%	0.081964
101	14	WCI-34275	8/30/2004 10:20	0.97	82.9	2889	381	0.132	2000	19.05%	212.5	10.63%	0.073555
101	130	WCI-34275	12/16/2003 14:24	0.96	84.4	1082	76	0.070	1200	6.33%	41	3.42%	0.037893
102	118	WCI-34275	8/30/2004 10:22	0.98	84.4	3282	284	0.087	3000	9.47%	132.34	4.41%	0.040323
103	92	WCI-34275	7/13/2004 9:05	0.98	83.6	1269	117	0.092	1000	11.70%	52.5	5.25%	0.041371
104	67	WCI-34275	4/28/2005 8:01	0.98	84.7	2889	191	0.066	2000	9.55%	128.5	6.43%	0.044479
105	66	WCI-34275	4/28/2005 8:01	0.98	84	2889	215.5	0.075	2000	10.78%	129	6.45%	0.044652
106	91	WCI-34275	7/28/2005 14:38	0.98	83	1269	201	0.158	1400	14.36%	74	5.29%	0.058314
107	72	WCI-34275	4/28/2005 8:03	0.98	84.7	1082	98.5	0.091	1000	9.85%	61.5	6.15%	0.056839
108	54	WCI-34275	5/18/2005 12:22	0.98	83.7	1269	110	0.087	1000	11.00%	72	7.20%	0.056738
109	50	WCI-34275	8/30/2004 10:20	0.98	83.4	2889	288.5	0.100	2000	14.43%	149.5	7.48%	0.051748
110	42	WCI-34275	2/23/2004 11:25	0.98	82.5	2556	379	0.148	2000	18.95%	158	7.90%	0.061815
111	39	WCI-34275	5/18/2005 12:21	0.98	83.7	1269	116	0.091	1000	11.60%	80	8.00%	0.063042
112	34	WCI-34275	8/30/2004 10:21	0.98	83.7	2889	259.5	0.090	2000	12.98%	166.5	8.33%	0.057632
113	31	WCI-34275	12/22/2004 14:18	0.98	83.4	2889	290	0.100	2000	14.50%	167.5	8.38%	0.057979
114	30	WCI-34275	5/18/2005 12:22	0.98	83.5	1269	125.5	0.099	1000	12.55%	86	8.60%	0.06777
115	90	WCI-34275	12/22/2004 14:17	0.99	84.8	1691	117	0.069	1200	9.75%	64	5.33%	0.037847
116	76	WCI-34275	3/7/2005 15:56	0.99	83.3	1691	132	0.078	1200	11.00%	72	6.00%	0.042578
117	112	WCI-34275	8/30/2004 10:21	1.00	85.1	2889	173.75	0.060	2400	7.24%	110	4.58%	0.038075
118	98	WCI-34275	2/23/2004 11:48	1.00	83.9	1691	143	0.085	1200	11.92%	61.5	5.13%	0.036369
FOLLOWING FAIL FLORIDA CODE													
119	126	WCI-34275	3/7/2005 15:56	1.02	84.3	1994	136.5	0.068	1200	11.38%	46	3.83%	0.023069
120	119	WCI-34275	10/14/2004 14:04	1.01	84.4	3085	195	0.063	2200	8.86%	97	4.41%	0.031442
121	95	WCI-34275	6/9/2004 11:33	1.01	82.9	1269	142	0.112	1200	11.83%	62	5.17%	0.048857
122	83	WCI-34275	4/28/2005 8:02	1.01	84.1	1269	83	0.065	1000	8.30%	56.5	5.65%	0.044523
123	62	WCI-34275	7/27/2005 10:58	1.01	84.1	1269	99	0.078	1000	9.90%	66	6.60%	0.052009
124	122	WCI-34275	1/9/2004 9:53	1.02	84.6	1082	103.5	0.096	1000	10.35%	43	4.30%	0.039741
125	28	WCI-34275	7/28/2005 14:38	1.02	83.4	1691	144	0.085	1200	12.00%	104	8.67%	0.061502
126	124	WCI-34275	1/9/2004 9:53	1.05	84.1	1269	122	0.098	1000	12.20%	41	4.10%	0.032309
127	121	WCI-34275	2/23/2004 11:23	1.05	81.8	1691	117	0.069	1200	9.75%	52	4.33%	0.030751
128	93	WCI-34275	7/28/2005 14:38	1.05	82	1691	223.5	0.132	1400	15.96%	73	5.21%	0.04317
129	82	WCI-34275	6/9/2004 11:32	1.05	82.9	1691	148.5	0.088	1000	14.85%	56.5	5.65%	0.033412
130	37	WCI-34275	1/9/2004 9:53	1.05	82.8	1691	150	0.089	1200	12.50%	96	8.17%	0.057954
131	8	WCI-34275	7/13/2004 7:27	1.05	82.5	1691	178	0.105	1000	17.80%	119	11.90%	0.070373
DUPLICATE?													
132	88-see72	WCI-34275	4/28/2005 8:02 ne address	83.9		1269	71.5	0.058	1000	7.15%	54	5.40%	0.042553

*WCI community at zipcode 34275 that is a designated BuildSmart community with 456 certified homes (GOLD-6 (1.3%); SILVER-262 (57.5%); and BRONZE-188 (41.2%))

***leakage to outdoors not greater than 3 cfm per 100 sq.ft. AND (emphasis added) total leakage not greater than 9 cfm per 100 sq.ft. of conditioned floor area at a pressure differential of 25 Pascal across the entire system." MEANS Qn total should not exceed .09 and Qn out should not exceed .03

**Residential New Construction
 BuildSmart™
 Trade Ally Program Standards**
 Effective: June 1, 2000
 Florida Power & Light Company
 Residential New Construction BuildSmart™
 Trade Ally Program Standards

TECHNICAL SPECIFICATIONS OF ELIGIBILITY
 ***Air distribution system must meet the following criteria:
 Sealing of the ducted air distribution system may have a maximum cfm leakage of five percent (5%) of the air-conditioned square footage of the home at the final inspection and three percent (3%) at the mid-point inspection. State of Florida Energy Code approved closure systems must be used for all duct system connections.