

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

IN RE: Application of  
SANLANDO UTILITIES  
CORPORATION for amendment  
of water and wastewater certificates  
in Seminole County, Florida


---

Docket No. 040384-WS

NOTICE OF SERVICE

SANLANDO UTILITIES CORPORATION , by and through the undersigned counsel,  
gives notice that it has served its answers to Staff's Second Set of Interrogatories (Nos. 11-  
13) on March 1, 2006.

ROSE, SUNDSTROM & BENTLEY, LLP  
Sanlando Center  
2180 W. State Road 434, Suite 2118  
Longwood, Florida 32779  
Telephone: (407) 830-6331  
Facsimile: (407) 830 8255



---

Martin S. Friedman  
Valerie L. Lord

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

IN RE: Application of  
SANLANDO UTILITIES  
CORPORATION for amendment  
of water and wastewater certificates  
in Seminole County, Florida

---

Docket No. 040384-WS

**SANLANDO UTILITIES CORPORATION'S ANSWERS TO  
STAFF'S SECOND SET OF INTERROGATORIES (NOS. 11-13)**

SANLANDO UTILITIES CORPORATION (*Applicant*), by and through its undersigned attorneys, files the following answers to Staff's Second Set of Interrogatories (Nos. 11-13):

11. Please review the following data from PCF-4 with respect to the number of ERCs, and affirm whether the number of existing ERCs and permitted capacities are correct for customers to be served in the proposed area. Please provide the number of ERCs and existing maximum flows, and describe the basis for maximum flows. Please update the information through December 31, 2005.

ANSWER: Please refer to table on following page.

In addition, the maximum flow is based on a review of the historical daily flow data for each water and wastewater facility.

	Water System	Wastewater System
Capacity of Existing Lines	21,240 SFEs	13,000 SFEs
Permitted Capacity of Treatment Facilities		
Des Pinar	5.364 mgd	.500 mgd
Knollwood	.576 mgd	N/A
Wekiva Hunt Club	8.928 mgd	2.9 mgd
Permitted Design Capacity of Reuse System		2.603 mgd
	Water System	Wastewater System
Current Number of ERCs served		
Des Pinar	Not available <sup>1</sup> .	Not available <sup>1</sup> .
Knollwood	Not available <sup>1</sup> .	Not available <sup>1</sup> .
Total Customers	13,172 SFEs	12,271 SFEs
Reuse System		5
Maximum Flows		
Des Pinar	5.317 mgd	0.532 mgd

---

<sup>1</sup>Note that Sanlando does not calculate ERCs per plant.

Knollwood	0.558 mgd	N/A
Wekiva Hunt Club	8.3587 mgd	3.259 mgd
Reuse System		2.564 mgd

12. Please describe whether the Des Pinar, Knollwood and Wekiva Hunt Club water systems are interconnected.

ANSWER: The Wekiva Hunt Club and Des Pinar water plants are interconnected at three locations in the distribution system. The Knollwood and Des Pinar water plants are interconnected at one location.

13. Please describe whether the Des Pinar and Wekiva Hunt Club wastewater systems are interconnected.

ANSWER: The Wekiva Hunt Club and Des Pinar collection systems are interconnected on the west and east side of The Springs subdivision.

AFFIDAVIT

STATE OF FLORIDA)

COUNTY OF SEMNOLE

I hereby certify that on this 1<sup>ST</sup> day of MARCH, 2006, before me, an officer duly authorized in the State and County aforesaid to take acknowledgments, personally appeared PATRICK C. FLYNN, who is personally known to me, and he/she acknowledged before me that he/she provided the answers to interrogatory number(s) 11-13 from STAFF'S SECOND SET OF INTERROGATORIES TO SANLANDO UTILITIES CORPORATION (NOS. 11-13) in Docket No. 040384-WS, and that the responses are true and correct based on his/her personal knowledge.

In Witness Whereof, I have hereunto set my hand and seal in the State and County aforesaid as of this 1<sup>ST</sup> day of MARCH, 2006.

Leah N. Wright  
Notary Public  
State of Florida, at Large

My Commission Expires:

LEAH N. WRIGHT  
NOTARY PUBLIC - STATE OF FLORIDA  
COMMISSION # DD168777  
EXPIRES 12/2/2006  
BONDED THRU 1-888-NOTARY1

CERTIFICATE OF SERVICE  
DOCKET NO. 040384-WS

I HEREBY CERTIFY that a true and correct copy of the foregoing Sanlando Utilities Corporation's Answers to Staff's Second Set of Interrogatories (Nos. 11-13) has been furnished by U.S. Mail to the following parties on this 1<sup>st</sup> day of March, 2006:


Jennifer Brubaker, Esq.  
Office of General Counsel  
Florida Public Service Commission  
Capitol Circle Office Center  
2540 Shumard Oak Blvd.  
Tallahassee Florida 32399-0850

Richard S. Taylor, Esq.  
531 Dog Track Road  
Longwood, Florida, 32752-1117

Susan E. Dietrich, Esq.  
Assistant County Attorney  
Seminole County Services Building  
1101 East First Street  
Sanford, FL 32771-1468

Respectfully submitted this 1<sup>st</sup> day of  
March, 2006.

ROSE, SUNDSTROM & BENTLEY, LLP  
2180 W. State Road 434, Suite 2118  
Longwood, Florida 32779  
Telephone: (407) 830-6331  
Facsimile: (407) 830 8255

  
MARTIN S. FRIEDMAN  
VALERIE L. LORD  
For the Firm