

AUSLEY & MCMULLEN

ATTORNEYS AND COUNSELORS AT LAW

227 SOUTH CALHOUN STREET
P.O. BOX 391 (ZIP 32302)
TALLAHASSEE, FLORIDA 32301
(850) 224-9115 FAX (850) 222-7560

April 3, 2006

HAND DELIVERED

Ms. Blanca S. Bayo, Director
Division of Commission Clerk
and Administrative Services
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, FL 32399-0850

Re: Fuel and Purchased Power Cost Recovery Clause with Generating
Performance Incentive Factor; FPSC Docket No. 060001-EI

Dear Ms. Bayo:


Enclosed for filing in the above docket on behalf of Tampa Electric Company are the original and fifteen (15) copies of each of the following:

1. Prepared Direct Testimony and Exhibit WAS-1 of William A. Smotherman regarding Generating Performance Incentive Factor True-Up for the period January 2005 through December 2005. 02971-06
2. Prepared Direct Testimony and Exhibit JTW-1 of Joann T. Wehle regarding Tampa Electric company's risk management and hedging activities for the period January 2005 through December 2005. 02972-06

Please acknowledge receipt and filing of the above by stamping the duplicate copy of this letter and returning same to this writer.

Thank you for your assistance in connection with this matter.

Sincerely,



James D. Beasley

JDB/pp
Enclosures

cc: All parties of record (w/encls.)

DOCUMENT NUMBER - DATE

02971 APR-3 06

FPSC-COMMISSION CLERK

CERTIFICATE OF SERVICE

I HEREBY CERTIFY that a true and correct copy of the foregoing Testimony and Exhibits of William A. Smotherman and Joann T. Wehle has been furnished by U. S. Mail or hand delivery (*) on this 3rd day of April 2006 to the following:

Ms. Jennifer Rodan*
Staff Attorney
Office of General Counsel
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, FL 32399-0863

Mr. John T. Burnett
Associate General Counsel
Progress Energy Service Co., LLC
Post Office Box 14042
St. Petersburg, FL 33733-4042

Mr. Paul Lewis, Jr.
106 East College Avenue
Suite 800
Tallahassee, FL 32301-7740

Mr. Timothy J. Perry
McWhirter, Reeves & Davidson, P.A.
117 S. Gadsden Street
Tallahassee, FL 32301

Mr. John W. McWhirter, Jr.
McWhirter, Reeves & Davidson, P.A.
400 North Tampa Street, Suite 2450
Tampa, FL 33601-5126

Ms. Patricia A. Christensen
Associate Public Counsel
Office of Public Counsel
111 West Madison Street – Room 812
Tallahassee, FL 32399-1400

Mr. Norman Horton
Messer Caparello & Self
Post Office Box 1876
Tallahassee, FL 32302

Ms. Cheryl Martin
Florida Public Utilities Company
P. O. Box 3395
West Palm Beach, FL 33402-3395

Mr. John T. Butler
Squire, Sanders & Dempsey, L.L.P.
200 South Biscayne Boulevard, Suite 4000
Miami, FL 33131-2398

Mr. William Walker, III
Florida Power & Light Company
215 South Monroe Street, Suite 810
Tallahassee, FL 32301-1859

Mr. R. Wade Litchfield
Associate General Counsel
Florida Power & Light Company
700 Universe Blvd.
Juno Beach, FL 33408-0420

Ms. Susan Ritenour
Secretary and Treasurer
Gulf Power Company
One Energy Place
Pensacola, FL 32520-0780

Mr. Jeffrey A. Stone
Mr. Russell A. Badders
Beggs & Lane
Post Office Box 12950
Pensacola, FL 32591-2950


Mr. Jon C. Moyle, Jr.
Moyle, Flanigan, Katz, Raymond &
Sheehan, P.A.
118 N. Gadsden Street
Tallahassee, FL 32301

Mr. Robert Scheffel Wright
Mr. John T. LaVia, III
Young van Assenderp, P.A.
225 South Adams Street, Suite 200
Tallahassee, FL 32301

Mr. Mark Hoffman
Legal Department
CSX Transportation
500 Water Street, 14th Floor
Jacksonville, FL 32202

Karen S. White, Lt Col, USAF
Damund E. Williams, Capt., USAF
AFLSA/JACL-ULT
139 Barnes Drive, Suite 1
Tyndall Air Force Base, FL 32403-5319

Mr. Michael B. Twomey
Post Office Box 5256
Tallahassee, FL 32314-5256


ATTORNEY



BEFORE THE
FLORIDA PUBLIC SERVICE COMMISSION

DOCKET NO. 060001-EI
IN RE: FUEL & PURCHASED POWER COST RECOVERY
AND
CAPACITY COST RECOVERY

GENERATING PERFORMANCE INCENTIVE FACTOR
TRUE-UP
JANUARY 2005 THROUGH DECEMBER 2005

TESTIMONY AND EXHIBIT
OF
WILLIAM A. SMOTHERMAN

DOCUMENT NUMBER DATE

02971 APR-3 8

FPSC-COMMISSION CLERK

1 **BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION**

2 **PREPARED DIRECT TESTIMONY**

3 **OF**

4 **WILLIAM A. SMOTHERMAN**

5
6 **Q.** Please state your name, business address, occupation and
7 employer.

8
9 **A.** My name is William A. Smotherman. My business address is
10 702 N. Franklin Street, Tampa, Florida 33602. I am
11 employed by Tampa Electric Company ("Tampa Electric" or
12 "company") as Director of the Resource Planning
13 Department.

14
15 **Q.** Please provide a brief outline of your educational
16 background and business experience.

17
18 **A.** I received a Bachelor of Electrical Engineering degree
19 in 1986 from the University of South Florida. In May
20 1986, I joined Tampa Electric as an associate engineer,
21 and I have worked in the areas of system planning,
22 commercial/ industrial account management and wholesale
23 power marketing. In February 2001, I was promoted to
24 Director, Resource Planning. My present
25 responsibilities include the areas of system

1 reliability, generation expansion and system fuel and
2 purchased power forecasting and related economic
3 analyses.

4
5 **Q.** What is the purpose of your testimony?
6

7 **A.** My testimony presents Tampa Electric's actual performance
8 results from unit equivalent availability and station
9 heat rate used to determine the GPIF for the period
10 January 2005 through December 2005. I will also compare
11 these results to the targets established prior to the
12 beginning of the period.
13

14 **Q.** Have you prepared an exhibit to support your testimony?
15

16 **A.** Yes, Exhibit No. _____ (WAS-1), consisting of two
17 documents, was prepared under my direction and
18 supervision. Document No. 1, entitled "Tampa Electric
19 Company, Generating Performance Incentive Factor, January
20 2005 - December 2005, True-up" is consistent with the
21 GPIF Implementation Manual previously approved by the
22 Commission. In addition, Document No. 2 provides the
23 company's Actual Unit Performance Data for the 2005
24 period.
25

1 Q. Which generating units on Tampa Electric's system are
2 included in the determination of the GPIF?

3

4 A. Five of the company's units are included. They are Big
5 Bend Station Units 1, 2, 3, and 4 and Polk Station Unit
6 1.

7

8 Q. Have you calculated the results of Tampa Electric's
9 performance under the GPIF during the January 2005
10 through December 2005 period?

11

12 A. Yes, I have. This is shown on Document No. 1, page 4 of
13 26. Based upon -0.182 GPIF points, the result is a
14 penalty amount of \$99,791 for the period.

15

16 Q. Please proceed with your review of the actual results for
17 the January 2005 through December 2005 period.

18

19 A. On Document No. 1, page 3 of 26, the actual average
20 common equity for the period is shown on line 14 as
21 \$1,394,720,154. This produces the maximum penalty or
22 reward amount of \$5,479,030 as shown on line 21.

23

24 Q. Will you please explain how you arrived at the actual
25 equivalent availability results for the five units

1 included within the GPIF?

2
3 **A.** Yes. Operating data on each of the units is filed
4 monthly with the Commission on the Actual Unit
5 Performance Data form. Additionally, outage information
6 is reported to the Commission on a monthly basis. A
7 summary of this data for the 12 months provides the basis
8 for the GPIF.

9
10 **Q.** Are the equivalent availability results shown on Document
11 No. 1, page 6 of 26, column 2, directly applicable to the
12 GPIF table?

13
14 **A.** No. Adjustments to equivalent availability may be
15 required as noted in section 4.3.3 of the GPIF Manual.
16 The actual equivalent availability including the required
17 adjustment is shown on Document No. 1, page 6 of 26. The
18 necessary adjustments as prescribed in the GPIF Manual
19 are further defined by a letter dated October 23, 1981,
20 from Mr. J. H. Hoffsis of the Commission's Staff. The
21 adjustments for each unit are as follows:

22
23 **Big Bend Unit No. 1**

24 On this unit, 1344.0 planned outage hours were originally
25 scheduled for 2005. Actual outage activities required

1 754.6 planned outage hours. Consequently, the actual
2 equivalent availability of 61.0% is adjusted to 56.6% as
3 shown on Document No. 1, page 7 of 26.
4

5 **Big Bend Unit No. 2**

6 On this unit, 336.0 planned outage hours were originally
7 scheduled for 2005. Actual outage activities required
8 1399.5 planned outage hours. Consequently, the actual
9 equivalent availability of 64.8% is adjusted to 74.2% as
10 shown on Document No. 1, page 8 of 26.
11

12 **Big Bend Unit No. 3**

13 On this unit, 336.0 planned outage hours were originally
14 scheduled for 2005. Actual outage activities required
15 617.9 planned outage hours. Consequently, the actual
16 equivalent availability of 51.5% is adjusted to 53.4% as
17 shown on Document No. 1, page 9 of 26.
18

19 **Big Bend Unit No. 4**

20 On this unit, 336.0 planned outage hours were originally
21 scheduled for 2005. Actual outage activities required
22 683.8 planned outage hours. Consequently, the actual
23 equivalent availability of 70.7% is adjusted to 73.8% as
24 shown on Document No. 1, page 10 of 26.
25

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

Polk Unit No. 1

On this unit, 330.5 planned outage hours were originally scheduled for 2005. Actual outage activities required 0 planned outage hours. Consequently, the actual equivalent availability of 68.5% is adjusted to 65.9%, as shown on Document No. 1, page 11 of 26.

Q. How did you arrive at the applicable equivalent availability points for each unit?

A. The final adjusted equivalent availabilities for each unit are shown on Document No. 1, page 6 of 26, column 4. This number is entered into the respective Generating Performance Incentive Point ("GPIP") table for each particular unit on pages 20 of 26 through 24 of 26. Page 4 of 26 summarizes the equivalent availability points to be awarded or penalized.

Q. Will you please explain the heat rate results relative to the GPIF?

A. The actual heat rate and adjusted actual heat rate for Big Bend Units 1, 2, 3, and 4 and Polk Unit 1 are shown on Document No. 1, page 6 of 26. The adjustment was developed based on the guidelines of section 4.3.16 of

1 the GPIF Manual. This procedure is further defined by a
2 letter dated October 23, 1981, from Mr. J.H. Hoffsis of
3 the FPSC Staff. The final adjusted actual heat rates are
4 also shown on page 5 of 26. The heat rate value is
5 entered into the respective GPIF table for the particular
6 unit, shown on pages 20 of 26 through 24 of 26. Page 4
7 of 26 summarizes the weighted heat rate and equivalent
8 availability points to be awarded.

9
10 **Q.** What is the overall GPIF for Tampa Electric for the
11 January 2005 through December 2005 period?

12
13 **A.** This is shown on Document No. 1, page 26 of 26.
14 Essentially, the weighting factors shown on page 4 of 26,
15 column 3, plus the equivalent availability points and the
16 heat rate points shown on page 4 of 26, column 4, are
17 substituted within the equation. The resulting value,
18 -0.182, is then entered into the GPIF table on page 2 of
19 26. Using linear interpolation, the penalty amount is
20 \$99,791.

21
22 **Q.** Does this conclude your testimony?

23
24 **A.** Yes, it does.
25

DOCKET NO. 060001-EI
GPIF 2005 TRUE-UP
EXHIBIT WAS-1

TAMPA ELECTRIC COMPANY

GENERATING PERFORMANCE INCENTIVE FACTOR

JANUARY 2005 - DECEMBER 2005

GENERATING PERFORMANCE INCENTIVE FACTOR

INDEX

DOCUMENT NO.	TITLE	BATES PAGE NO.
1	GPIF Schedules	10
2	Actual Unit Performance Data	37

DOCKET NO. 060001-EI
GPIF 2005 TRUE-UP SCHEDULES
EXHIBIT WAS-1, DOCUMENT 1

EXHIBIT TO THE TESTIMONY OF
William A. Smotherman

DOCKET NO. 060001-EI

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE FACTOR
JANUARY 2005 - DECEMBER 2005
TRUE-UP

DOCUMENT NO. 1


GPIF SCHEDULES

**TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE FACTOR
JANUARY 2005 - DECEMBER 2005
TRUE-UP**

<u>SCHEDULE</u>	<u>PAGE</u>
GPIF REWARD / PENALTY TABLE - ACTUAL	2
GPIF CALCULATION OF MAXIMUM ALLOWED INCENTIVE DOLLARS	3
CALCULATIONS OF SYSTEM GPIF POINTS - ACTUAL	4
GPIF TARGET AND RANGE SUMMARY	5
UNIT PERFORMANCE DATA - ACTUAL	6
ADJUSTMENTS TO PERFORMANCE	7 - 11
ADJUSTMENTS TO HEAT RATE	12 - 16
PLANNED OUTAGE SCHEDULE - ACTUAL	17
CRITICAL PATH METHOD DIAGRAMS	18 - 19
GENERATING PERFORMANCE INCENTIVE POINTS TABLES	204 - 24
COMPARISON OF GPIF TARGETS VS ACTUAL PERFORMANCE	25
GENERATING PERFORMANCE INCENTIVE POINTS CALCULATION	26

TAMPA ELECTRIC COMPANY
 GENERATING PERFORMANCE INCENTIVE FACTOR
 REWARD / PENALTY TABLE - ACTUAL
 JANUARY 2005 - DECEMBER 2005

GENERATING PERFORMANCE INCENTIVE POINTS (GPIP)	FUEL SAVINGS / (LOSS) (\$000)	GENERATING PERFORMANCE INCENTIVE FACTOR (\$000)
+10	35,060.9	5,479.0
+9	31,554.8	4,931.1
+8	28,048.7	4,383.2
+7	24,542.6	3,835.3
+6	21,036.5	3,287.4
+5	17,530.4	2,739.5
+4	14,024.3	2,191.6
+3	10,518.3	1,643.7
+2	7,012.2	1,095.8
+1	3,506.1	547.9
0	0.0	0.0
-1	(6,036.0)	(547.9)
-2	(12,072.0)	(1,095.8)
-3	(18,108.0)	(1,643.7)
-4	(24,144.0)	(2,191.6)
-5	(30,180.0)	(2,739.5)
-6	(36,216.0)	(3,287.4)
-7	(42,252.0)	(3,835.3)
-8	(48,288.0)	(4,383.2)
-9	(54,324.0)	(4,931.1)
-10	(60,360.0)	(5,479.0)



**TAMPA ELECTRIC COMPANY
 GENERATING PERFORMANCE INCENTIVE FACTOR
 CALCULATION OF MAXIMUM ALLOWED INCENTIVE DOLLARS - ACTUAL
 JANUARY 2005 - DECEMBER 2005**

Line 1	Beginning of period balance of common equity:		\$	1,394,835,000
	End of month common equity:			
Line 2	Month of January	2005	\$	1,368,206,000
Line 3	Month of February	2005	\$	1,373,211,000
Line 4	Month of March	2005	\$	1,383,071,000
Line 5	Month of April	2005	\$	1,373,463,000
Line 6	Month of May	2005	\$	1,389,222,000
Line 7	Month of June	2005	\$	1,406,893,000
Line 8	Month of July	2005	\$	1,398,273,000
Line 9	Month of August	2005	\$	1,423,286,000
Line 10	Month of September	2005	\$	1,438,565,000
Line 11	Month of October	2005	\$	1,387,120,000
Line 12	Month of November	2005	\$	1,398,153,000
Line 13	Month of December	2005	\$	1,397,064,000
Line 14	(Summation of line 1 through line 13 divided by 13)		\$	1,394,720,154
Line 15	25 Basis points			0.0025
Line 16	Revenue Expansion Factor			61.38%
Line 17	Maximum Allowed Incentive Dollars (line 14 times line 15 divided by line 16)		\$	5,680,607
Line 18	Jurisdictional Sales			18,901,894 MWH
Line 19	Total Sales			19,597,306 MWH
Line 20	Jurisdictional Separation Factor (line 18 divided by line 19)			96.45%
Line 21	Maximum Allowed Jurisdictional Incentive Dollars (line 17 times line 20)		\$	5,479,030

TAMPA ELECTRIC COMPANY
 CALCULATION OF SYSTEM GPIF POINTS - ACTUAL
 JANUARY 2005 - DECEMBER 2005

<u>PLANT / UNIT</u>	<u>12 MONTH ADJ. ACTUAL PERFORMANCE</u>		<u>WEIGHTING FACTOR %</u>	<u>UNIT POINTS</u>	<u>WEIGHTED UNIT POINTS</u>
BIG BEND 1	56.6%	EAF	15.68%	5.537	0.868
BIG BEND 2	74.2%	EAF	17.44%	10.000	1.744
BIG BEND 3	53.4%	EAF	18.30%	-4.893	-0.895
BIG BEND 4	73.8%	EAF	11.68%	-6.624	-0.774
POLK 1	65.9%	EAF	5.44%	-10.000	-0.544
BIG BEND 1	10964	ANOHR	5.27%	-0.795	-0.042
BIG BEND 2	10610	ANOHR	4.72%	0.000	0.000
BIG BEND 3	10767	ANOHR	7.40%	-0.504	-0.037
BIG BEND 4	10690	ANOHR	7.74%	-6.486	-0.502
POLK 1	10331	ANOHR	<u>6.34%</u>	0.000	<u>0.000</u>
			100.00%		-0.182

GPIF REWARD	\$ (99,791)
--------------------	--------------------

TAMPA ELECTRIC COMPANY
 GPIF TARGET AND RANGE SUMMARY

EQUIVALENT AVAILABILITY (%)

<u>PLANT / UNIT</u>	<u>WEIGHTING FACTOR (%)</u>	<u>EAFF TARGET (%)</u>	<u>EAFF MAX. (%)</u>	<u>RANGE MIN. (%)</u>	<u>MAX. FUEL SAVINGS (\$000)</u>	<u>MAX. FUEL LOSS (\$000)</u>	<u>EAFF ADJUSTED ACTUAL (%)</u>	<u>ACTUAL FUEL SAVINGS/ LOSS (\$000)</u>
BIG BEND 1	15.68%	52.6	59.8	38.3	5,498.6	(12,805.0)	56.6%	3,044.4
BIG BEND 2	17.44%	61.6	68.7	47.5	6,112.9	(12,376.3)	74.2%	6,112.9
BIG BEND 3	18.30%	60.6	67.9	45.9	6,414.7	(13,384.7)	53.4%	(6,549.1)
BIG BEND 4	11.68%	78.7	82.4	71.3	4,096.8	(6,982.3)	73.8%	(4,625.0)
POLK 1	<u>5.44%</u>	79.8	83.2	72.8	<u>1,906.3</u>	<u>(3,780.1)</u>	65.9%	(3,780.1)
GPIF SYSTEM	68.54%				24,029.3	(49,328.4)		

AVERAGE NET OPERATING HEAT RATE (Btu/kwh)

<u>PLANT / UNIT</u>	<u>WEIGHTING FACTOR (%)</u>	<u>ANOHR (Btu/kwh)</u>	<u>TARGET NOF (%)</u>	<u>ANOHR TARGET RANGE</u>		<u>MAX. FUEL SAVINGS (\$000)</u>	<u>MAX. FUEL LOSS (\$000)</u>	<u>ACTUAL ADJUSTED ANOHR</u>	<u>ACTUAL FUEL SAVINGS/ LOSS (\$000)</u>
				<u>MIN.</u>	<u>MAX.</u>				
BIG BEND 1	5.27%	10,853	76.8	10,324	11,382	1,848.1	(1,848.1)	10,964	(146.9)
BIG BEND 2	4.72%	10,672	77.2	10,251	11,093	1,656.1	(1,656.1)	10,610	0.0
BIG BEND 3	7.40%	10,663	72.0	10,006	11,319	2,593.2	(2,593.2)	10,767	(130.8)
BIG BEND 4	7.74%	10,350	85.7	9,868	10,833	2,712.8	(2,712.8)	10,690	(1,759.5)
POLK 1	<u>6.34%</u>	10,342	89.1	9,624	11,060	<u>2,221.4</u>	<u>(2,221.4)</u>	10,331	0.0
GPIF SYSTEM	31.46%					11,031.6	(11,031.6)		

**TAMPA ELECTRIC COMPANY
 UNIT PERFORMANCE DATA - ACTUAL
 JANUARY 2005 - DECEMBER 2005**

<u>PLANT / UNIT</u>	<u>ACTUAL EAF (%)</u>	<u>ADJUSTMENTS (1) TO EAF (%)</u>	<u>EAF ADJUSTED ACTUAL (%)</u>
BIG BEND 1	61.0	-4.4	56.6
BIG BEND 2	64.8	9.4	74.2
BIG BEND 3	51.5	1.9	53.4
BIG BEND 4	70.7	3.1	73.8
POLK 1	68.5	-2.6	65.9

<u>PLANT / UNIT</u>	<u>ACTUAL ANOHR (Btu/kwh)</u>	<u>ADJUSTMENTS (2) TO ANOHR (Btu/kwh)</u>	<u>ANOHR ADJUSTED ACTUAL (Btu/kwh)</u>
BIG BEND 1	11072	-108	10964
BIG BEND 2	10598	12	10610
BIG BEND 3	10948	-181	10767
BIG BEND 4	10826	-136	10690
POLK 1	10442	-111	10331

(1) Documentation of adjustments to Actual EAF on pages 7 - 13

(2) Documentation of adjustments to Actual ANOHR on pages 14 - 20

TAMPA ELECTRIC COMPANY
 ADJUSTMENTS TO PERFORMANCE
 BIG BEND UNIT NO. 1
 JANUARY 2005 - DECEMBER 2005

WEIGHTING FACTOR = 15.68%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
PH	8760.0	8760.0	8760.0
EAFF	52.6	61.0	56.6
POH	1344.0	754.6	1344.0
FOH + EFOH	2001.3	2252.9	2087.0
MOH + EMOH	804.3	407.6	377.6
POF	15.3	8.6	15.3
EFOF	22.8	25.7	23.8
EMOF	9.2	4.7	4.3
	5.537	EQUIVALENT AVAILABILITY POINTS	

ADJUSTMENTS TO ACTUAL EAF FOR COMPARISON

$$\frac{PH - POH_{TARGET}}{PH - POH_{ACTUAL}} \times (FOH + EFOH + MOH + EMOH) = EUOH_{ADJUSTED}$$

$$\frac{8760 - 1344}{8760 - 754.6} \times (2252.9 + 407.6) = 2464.6$$

$$100 - POF_{TARGET} - \frac{EUOH_{ADJUSTED}}{PH} \times 100 = EAF_{ADJUSTED}$$

$$100 - 15.3 - \frac{2464.6}{8760.0} \times 100 = 56.6$$

PH = PERIOD HOURS
 EAF = EQUIVALENT AVAILABILITY FACTOR
 POH = PLANNED OUTAGE HOURS
 FOH = FORCED OUTAGE HOURS
 EFOH = EQUIVALENT FORCED OUTAGE HOURS
 MOH = MAINTENANCE OUTAGE HOURS
 EMOH = EQUIVALENT MAINTENANCE OUTAGE HOURS
 POF = PLANNED OUTAGE FACTOR
 EFOF = EQUIVALENT FORCED OUTAGE FACTOR
 EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR

TAMPA ELECTRIC COMPANY
 ADJUSTMENTS TO PERFORMANCE
 BIG BEND UNIT NO. 2
 JANUARY 2005 - DECEMBER 2005

WEIGHTING FACTOR = 17.44%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
PH	8760.0	8760.0	8760.0
EAF	61.6	64.8	74.2
POH	336.0	1399.5	336.0
FOH + EFOH	2170.9	1431.4	1638.2
MOH + EMOH	853.0	249.4	285.4
POF	3.8	16.0	3.8
EFOF	24.8	16.3	18.7
EMOF	9.7	2.8	3.3
	10.000	EQUIVALENT AVAILABILITY POINTS	

ADJUSTMENTS TO ACTUAL EAF FOR COMPARISON

$$\frac{PH - POH_{TARGET}}{PH - POH_{ACTUAL}} \times (FOH + EFOH + MOH + EMOH) = EUOH_{ADJUSTED}$$

$$\frac{8760 - 336}{8760 - 1399.5} \times (1431.4 + 249.4) = 1923.7$$

$$100 - POF_{TARGET} - \frac{EUOH_{ADJUSTED}}{PH} \times 100 = EAF_{ADJUSTED}$$

$$100 - 3.8 - \frac{1923.7}{8760.0} \times 100 = 74.2$$

PH = PERIOD HOURS
 EAF = EQUIVALENT AVAILABILITY FACTOR
 POH = PLANNED OUTAGE HOURS
 FOH = FORCED OUTAGE HOURS
 EFOH = EQUIVALENT FORCED OUTAGE HOURS
 MOH = MAINTENANCE OUTAGE HOURS
 EMOH = EQUIVALENT MAINTENANCE OUTAGE HOURS
 POF = PLANNED OUTAGE FACTOR
 EFOF = EQUIVALENT FORCED OUTAGE FACTOR
 EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR

TAMPA ELECTRIC COMPANY
 ADJUSTMENTS TO PERFORMANCE
 BIG BEND UNIT NO. 3
 JANUARY 2005 - DECEMBER 2005

WEIGHTING FACTOR = 18.30%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
PH	8760.0	8760.0	8760.0
EAF	60.6	51.5	53.4
POH	336.0	617.9	336.0
FOH + EFOH	2147.6	3167.7	3277.4
MOH + EMOH	971.6	460.2	476.1
POF	3.8	7.1	3.8
EFOF	24.5	36.2	37.4
EMOF	11.1	5.3	5.4
	-4.893	EQUIVALENT AVAILABILITY POINTS	

ADJUSTMENTS TO ACTUAL EAF FOR COMPARISON

$$\frac{PH - POH_{TARGET}}{PH - POH_{ACTUAL}} \times (FOH + EFOH + MOH + EMOH) = EUOH_{ADJUSTED}$$

$$\frac{8760 - 336}{8760 - 617.9} \times (3167.7 + 460.2) = 3753.5$$

$$100 - POF_{TARGET} - \frac{EUOH_{ADJUSTED}}{PH} \times 100 = EAF_{ADJUSTED}$$

$$100 - 3.8 - \frac{3753.5}{8760.0} \times 100 = 53.4$$

PH = PERIOD HOURS
 EAF = EQUIVALENT AVAILABILITY FACTOR
 POH = PLANNED OUTAGE HOURS
 FOH = FORCED OUTAGE HOURS
 EFOH = EQUIVALENT FORCED OUTAGE HOURS
 MOH = MAINTENANCE OUTAGE HOURS
 EMOH = EQUIVALENT MAINTENANCE OUTAGE HOURS
 POF = PLANNED OUTAGE FACTOR
 EFOF = EQUIVALENT FORCED OUTAGE FACTOR
 EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR

TAMPA ELECTRIC COMPANY
 ADJUSTMENTS TO PERFORMANCE
 BIG BEND UNIT NO. 4
 JANUARY 2005 - DECEMBER 2005

WEIGHTING FACTOR = 11.68%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
PH	8760.0	8760.0	8760.0
EAFF	78.7	70.7	73.8
POH	336.0	683.8	336.0
FOH + EFOH	994.1	1539.6	1605.9
MOH + EMOH	537.1	344.0	358.8
POF	3.8	7.8	3.8
EFOF	11.3	17.6	18.3
EMOF	6.1	3.9	4.1
	-6.624	EQUIVALENT AVAILABILITY POINTS	

ADJUSTMENTS TO ACTUAL EAF FOR COMPARISON

$$\frac{PH - POH_{TARGET}}{PH - POH_{ACTUAL}} \times (FOH + EFOH + MOH + EMOH) = EUOH_{ADJUSTED}$$

$$\frac{8760 - 336}{8760 - 683.8} \times (1539.6 + 344) = 1964.7$$

$$100 - POF_{TARGET} - \frac{EUOH_{ADJUSTED}}{PH} \times 100 = EAF_{ADJUSTED}$$

$$100 - 3.8 - \frac{1964.7}{8760.0} \times 100 = 73.8$$

PH = PERIOD HOURS
 EAF = EQUIVALENT AVAILABILITY FACTOR
 POH = PLANNED OUTAGE HOURS
 FOH = FORCED OUTAGE HOURS
 EFOH = EQUIVALENT FORCED OUTAGE HOURS
 MOH = MAINTENANCE OUTAGE HOURS
 EMOH = EQUIVALENT MAINTENANCE OUTAGE HOURS
 POF = PLANNED OUTAGE FACTOR
 EFOF = EQUIVALENT FORCED OUTAGE FACTOR
 EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR

TAMPA ELECTRIC COMPANY
 ADJUSTMENTS TO PERFORMANCE
 POLK UNIT NO. 1
 JANUARY 2005 - DECEMBER 2005

WEIGHTING FACTOR = 5.44%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
PH	8760.0	8760.0	8760.0
EAF	79.8	68.5	65.9
POH	330.5	0.0	330.5
FOH + EFOH	276.6	2594.9	2497.0
MOH + EMOH	1165.9	167.6	161.3
POF	3.8	0.0	3.8
EFOF	3.2	29.6	28.5
EMOF	13.3	1.9	1.8
	-10.000	EQUIVALENT AVAILABILITY POINTS	

ADJUSTMENTS TO ACTUAL EAF FOR COMPARISON

$$\frac{PH - POH_{TARGET}}{PH - POH_{ACTUAL}} \times (FOH + EFOH + MOH + EMOH) = EUOH_{ADJUSTED}$$

$$\frac{8760 - 330}{8760 - 0} \times (2594.9 + 167.6) = 2658.3$$

$$100 - POF_{TARGET} - \frac{EUOH_{ADJUSTED}}{PH} \times 100 = EAF_{ADJUSTED}$$

$$100 - 3.8 - \frac{2658.3}{8760.0} \times 100 = 65.9$$

PH = PERIOD HOURS
 EAF = EQUIVALENT AVAILABILITY FACTOR
 POH = PLANNED OUTAGE HOURS
 FOH = FORCED OUTAGE HOURS
 EFOH = EQUIVALENT FORCED OUTAGE HOURS
 MOH = MAINTENANCE OUTAGE HOURS
 EMOH = EQUIVALENT MAINTENANCE OUTAGE HOURS
 POF = PLANNED OUTAGE FACTOR
 EFOF = EQUIVALENT FORCED OUTAGE FACTOR
 EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR

**TAMPA ELECTRIC COMPANY
 ADJUSTMENTS TO HEAT RATE
 BIG BEND UNIT NO. 1
 JANUARY 2005 - DECEMBER 2005**

WEIGHTING FACTOR = 5.27%

	12 MONTH TARGET	12 MONTH ACTUAL PERFORMANCE
ANOHR (Btu/kwh)	10853	11072
NET GENERATION (GWH)	1622.8	2022.1
OPERATING BTU (10 ⁹)	17612	22390.0
NET OUTPUT FACTOR	76.8	71.1

-0.795 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

CURRENT EQUATION: $\text{NOF} * (-18.92) + 12305.63 = \text{ANOHR}$

$$71.1 * (-18.92) + 12305.63 = 10960$$

$$11072 \quad - \quad 10960 \quad = \quad 112$$

$$10853 \quad + \quad 112 \quad = \quad 10964 \quad \leftarrow \text{ADJUSTED ACTUAL HEAT RATE AT TARGET NOF}$$

ANOHR = AVERAGE NET OPERATING HEAT RATE

NOF = NET OPERATING FACTOR

TAMPA ELECTRIC COMPANY
 ADJUSTMENTS TO HEAT RATE
 BIG BEND UNIT NO. 2
 JANUARY 2005 - DECEMBER 2005

WEIGHTING FACTOR = 4.72%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	10672	10598
NET GENERATION (GWH)	1799.5	2068.3
OPERATING BTU (10 ⁹)	19205	21919.2
NET OUTPUT FACTOR	77.2	78.3

0.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

CURRENT EQUATION: $NOF * (-10.94) + 11516.07 = ANOHR$

$$78.3 * (-10.94) + 11516.07 = 10660$$

$$10598 - 10660 = -62$$

$$10672 + -62 = 10610 \leftarrow \text{ADJUSTED ACTUAL HEAT RATE AT TARGET NOF}$$

ANOHR = AVERAGE NET OPERATING HEAT RATE
 NOF = NET OPERATING FACTOR

**TAMPA ELECTRIC COMPANY
 ADJUSTMENTS TO HEAT RATE
 BIG BEND UNIT NO. 3
 JANUARY 2005 - DECEMBER 2005**

WEIGHTING FACTOR = 7.40%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	10663	10948
NET GENERATION (GWH)	1873.2	1792.2
OPERATING BTU (10 ⁹)	19973	19621.7
NET OUTPUT FACTOR	72.0	65.7

-0.504 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

CURRENT EQUATION: $\text{NOF} * (-28.86) + 12739.98 = \text{ANOHR}$

$$65.7 * (-28.86) + 12739.98 = 10844$$

$$10948 - 10844 = 104$$

$$10663 + 104 = 10767 \leftarrow \text{ADJUSTED ACTUAL HEAT RATE AT TARGET NOF}$$

ANOHR = AVERAGE NET OPERATING HEAT RATE

NOF = NET OPERATING FACTOR

**TAMPA ELECTRIC COMPANY
 ADJUSTMENTS TO HEAT RATE
 BIG BEND UNIT NO. 4
 JANUARY 2005 - DECEMBER 2005**

WEIGHTING FACTOR = 7.74%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	10350	10826
NET GENERATION (GWH)	2691.3	2550.7
OPERATING BTU (10 ⁹)	27857	27613.3
NET OUTPUT FACTOR	85.7	82.3

-6.486 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

CURRENT EQUATION: $NOF * (-40.19) + 13794.47 = ANOHR$

$82.3 * (-40.19) + 13794.47 = 10487$

$10826 - 10487 = 339$

$10350 + 339 = 10690$ ← ADJUSTED ACTUAL HEAT RATE AT TARGET NOF

ANOHR = AVERAGE NET OPERATING HEAT RATE

NOF = NET OPERATING FACTOR

TAMPA ELECTRIC COMPANY
 ADJUSTMENTS TO HEAT RATE
 POLK UNIT NO. 1
 JANUARY 2005 - DECEMBER 2005

WEIGHTING FACTOR = 6.34%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	10342	10442
NET GENERATION (GWH)	1519.1	1273.7
OPERATING BTU (10 ⁹)	15711	13300.7
NET OUTPUT FACTOR	89.1	87.6

0.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

CURRENT EQUATION: $\text{NOF} * (-73.22) + 16866.46 = \text{ANOHR}$

$$87.6 * (-73.22) + 16866.46 = 10453$$

$$10442 - 10453 = -11$$

$$10342 + -11 = 10331 \leftarrow \text{ADJUSTED ACTUAL HEAT RATE AT TARGET NOF}$$


ANOHR = AVERAGE NET OPERATING HEAT RATE
 NOF = NET OPERATING FACTOR

TAMPA ELECTRIC COMPANY
 PLANNED OUTAGE SCHEDULE (ACTUAL)
 GPIF UNITS
 JANUARY 2005 - DECEMBER 2005

PLANT / UNIT	PLANNED OUTAGE DATES	OUTAGE DESCRIPTION
BIG BEND 1	Nov 23 - Dec 24	Floor tube replacement, weld overlay of floor tubes and wall tubes, floor refractory, precipitator inspection and maintenance, air preheater maintenance, sootblower inspection and maintenance Secondary Air Damper Drive Modification/Upgrade A & B Slag Tank Neck, Weir Box, and Overflow Line replacements Safety Valve Drain and Scupper replacement Screen well Dredging B Condensate Pump Element Replacement Coal Air Flow Balancing A & C Coal Plug Valve rebuilds FGD 1 & 2 Tower Oxidation Air Header replacement A1 Oxidation Blower Element replacement Misc. repairs and clean up
BIG BEND 2	Oct 01 - Nov 28	Condenser tubebundle removal and replacement, continuous condenser cleaning system installation, boiler inspection, tube weld overlay, steam turbine inspection and maintenance, turbine valve inspection and maintenance, slag tank neck inspection and maintenance, precipitator inspection and maintenance, exhaust duct inspection and maintenance, air preheater maintenance, sootblower inspection and maintenance, burner front removal and replacement, high energy piping inspection
+ BIG BEND 3	Apr 01 - Apr 26	Wall tube weld overlay, precipitator inspection and maintenance, sootblower inspection and maintenance, Condenser Tubesheet Coating repairs, A Coarse Mesh Screen rebuild, Hot Gas Duct Expansion Joint replacement, Burner Ignitor replacement (18 ignitors), Coal Blast Gate replacements (A2, C1, & C2), WDPF Weststation replacement, Salt Water Header Piping replacement, High Pressure Piping Inspections, Extensive Coal Leak/Gas Leak repairs
+ BIG BEND 4	Feb 12 - Mar 12	Wall tube overlay, (cast waterwall)tube panel replacement, Lower Waterfall Ring Header repairs, Boiler Nose Arch Door replacement, MCC 4B1 & 4B2 replacement, Finishing Superheater Tube Samples, New ID/FD/PA Fan Vibration Monitoring Systems, High Pressure Piping Inspections, #3 Stack work (Bands), Extensive FGD Work: A Tower Bowl Return Line C Tower Vortex Breaker Quencher Blow Down Line Mods (all 4 towers) Duct Work repairs


+ CPM for units with less than or equal to 4 weeks are not included.

**TAMPA ELECTRIC COMPANY
CRITICAL PATH METHOD DIAGRAMS
GPIF UNITS > FOUR WEEKS
JANUARY 2005 - DECEMBER 2005**



TAMPA ELECTRIC COMPANY
BIG BEND UNIT NUMBER 1
PLANNED OUTAGE 2005

TAMPA ELECTRIC COMPANY
CRITICAL PATH METHOD DIAGRAMS
GPIF UNITS > FOUR WEEKS
JANUARY 2005 - DECEMBER 2005



TAMPA ELECTRIC COMPANY
BIG BEND UNIT NUMBER 2
PLANNED OUTAGE 2005

TAMPA ELECTRIC COMPANY
 GENERATING PERFORMANCE INCENTIVE POINTS TABLE

BIG BEND 1

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	5,498.6	59.8	+10	1,848.1	10,324
+9	4,948.7	59.1	+9	1,663.3	10,369
+8	4,398.9	58.4	+8	1,478.5	10,415
+7	3,849.0	57.6	+7	1,293.6	10,460
+6	3,299.2	56.9	+6	1,108.8	10,506
+5	2,749.3	56.2	+5	924.0	10,551
+4	2,199.4	55.5	+4	739.2	10,596
+3	1,649.6	54.8	+3	554.4	10,642
+2	1,099.7	54.1	+2	369.6	10,687
+1	549.9	53.3	+1	184.8	10,733
0	0.0	52.6	0	0.0	10,778
-1	(1,280.5)	51.2	-1	(184.8)	10,853
-2	(2,561.0)	49.8	-2	(369.6)	10,928
-3	(3,841.5)	48.3	-3	(554.4)	10,973
-4	(5,122.0)	46.9	-4	(739.2)	11,019
-5	(6,402.5)	45.5	-5	(924.0)	11,064
-6	(7,683.0)	44.0	-6	(1,108.8)	11,109
-7	(8,963.5)	42.6	-7	(1,293.6)	11,155
-8	(10,244.0)	41.2	-8	(1,478.5)	11,200
-9	(11,524.5)	39.7	-9	(1,663.3)	11,246
-10	(12,805.0)	38.3	-10	(1,848.1)	11,291
					11,336
					11,382

Weighting Factor =

15.68%

Weighting Factor =

5.27%

TAMPA ELECTRIC COMPANY
 GENERATING PERFORMANCE INCENTIVE POINTS TABLE

BIG BEND 2

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	6,112.9	68.7	+10	1,656.1	10,251
+9	5,501.6	68.0	+9	1,490.5	10,286
+8	4,890.3	67.3	+8	1,324.9	10,320
+7	4,279.0	66.6	+7	1,159.2	10,355
+6	3,667.7	65.9	+6	993.6	10,389
+5	3,056.5	65.2	+5	828.0	10,424
+4	2,445.2	64.5	+4	662.4	10,459
+3	1,833.9	63.8	+3	496.8	10,493
+2	1,222.6	63.1	+2	331.2	10,528
+1	611.3	62.4	+1	165.6	10,562
0	0.0	61.6	0	0.0	10,597
-1	(1,237.6)	60.2	-1	(165.6)	10,672
-2	(2,475.3)	58.8	-2	(331.2)	10,747
-3	(3,712.9)	57.4	-3	(496.8)	10,782
-4	(4,950.5)	56.0	-4	(662.4)	10,816
-5	(6,188.2)	54.5	-5	(828.0)	10,851
-6	(7,425.8)	53.1	-6	(993.6)	10,886
-7	(8,663.4)	51.7	-7	(1,159.2)	10,920
-8	(9,901.0)	50.3	-8	(1,324.9)	10,955
-9	(11,138.7)	48.9	-9	(1,490.5)	10,989
-10	(12,376.3)	47.5	-10	(1,656.1)	11,024

Weighting Factor =

17.44%

Weighting Factor =

4.72%

TAMPA ELECTRIC COMPANY
 GENERATING PERFORMANCE INCENTIVE POINTS TABLE

BIG BEND 3

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	6,414.7	67.9	+10	2,593.2	10,006
+9	5,773.2	67.2	+9	2,333.9	10,064
+8	5,131.8	66.4	+8	2,074.6	10,122
+7	4,490.3	65.7	+7	1,815.3	10,181
+6	3,848.8	65.0	+6	1,555.9	10,239
+5	3,207.3	64.2	+5	1,296.6	10,297
+4	2,565.9	63.5	+4	1,037.3	10,355
+3	1,924.4	62.8	+3	778.0	10,413
+2	1,282.9	62.0	+2	518.6	10,471
+1	641.5	61.3	+1	259.3	10,530
0	0.0	60.6	0	0.0	10,588
-1	(1,338.5)	59.1	-1	(259.3)	10,663
-2	(2,676.9)	57.6	-2	(518.6)	10,738
-3	(4,015.4)	56.2	-3	(778.0)	10,796
-4	(5,353.9)	54.7	-4	(1,037.3)	10,854
-5	(6,692.4)	53.2	-5	(1,296.6)	10,912
-6	(8,030.8)	51.8	-6	(1,555.9)	10,970
-7	(9,369.3)	50.3	-7	(1,815.3)	11,028
-8	(10,707.8)	48.9	-8	(2,074.6)	11,087
-9	(12,046.2)	47.4	-9	(2,333.9)	11,145
-10	(13,384.7)	45.9	-10	(2,593.2)	11,203
					11,261
					11,319

AHR POINTS
-0.504

Adjusted ANOHR
10767

EAF POINTS
4.893

Adjusted EAF
53.4

Weighting Factor =

18.30%

Weighting Factor =

7.40%

TAMPA ELECTRIC COMPANY
 GENERATING PERFORMANCE INCENTIVE POINTS TABLE

BIG BEND 4

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	4,096.8	82.4	+10	2,712.8	9,868
+9	3,687.1	82.0	+9	2,441.6	9,908
+8	3,277.4	81.7	+8	2,170.3	9,949
+7	2,867.8	81.3	+7	1,899.0	9,990
+6	2,458.1	80.9	+6	1,627.7	10,031
+5	2,048.4	80.5	+5	1,356.4	10,071
+4	1,638.7	80.2	+4	1,085.1	10,112
+3	1,229.0	79.8	+3	813.9	10,153
+2	819.4	79.4	+2	542.6	10,194
+1	409.7	79.1	+1	271.3	10,235
0	0.0	78.7	0	0.0	10,275
					10,350
					10,425
-1	(698.2)	77.9	-1	(271.3)	10,466
-2	(1,396.5)	77.2	-2	(542.6)	10,507
-3	(2,094.7)	76.5	-3	(813.9)	10,548
-4	(2,792.9)	75.7	-4	(1,085.1)	10,589
-5	(3,491.2)	75.0	-5	(1,356.4)	10,629
-6	(4,189.4)	74.3	-6	(1,627.7)	10,670
-7	(4,887.6)	73.5	-7	(1,899.0)	10,711
-8	(5,585.8)	72.8	-8	(2,170.3)	10,752
-9	(6,284.1)	72.0	-9	(2,441.6)	10,793
-10	(6,982.3)	71.3	-10	(2,712.8)	10,833

Weighting Factor =

11.68%

Weighting Factor =

7.74%

TAMPA ELECTRIC COMPANY
 GENERATING PERFORMANCE INCENTIVE POINTS TABLE

POLK 1

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	1,906.3	83.2	+10	2,221.4	9,624
+9	1,715.7	82.9	+9	1,999.2	9,688
+8	1,525.0	82.5	+8	1,777.1	9,753
+7	1,334.4	82.2	+7	1,555.0	9,817
+6	1,143.8	81.9	+6	1,332.8	9,881
+5	953.1	81.5	+5	1,110.7	9,945
+4	762.5	81.2	+4	888.5	10,010
+3	571.9	80.8	+3	666.4	10,074
+2	381.3	80.5	+2	444.3	10,138
+1	190.6	80.1	+1	222.1	10,203
					10,267
0	0.0	79.8	0	0.0	10,342
					10,417
-1	(378.0)	79.1	-1	(222.1)	10,481
-2	(756.0)	78.4	-2	(444.3)	10,546
-3	(1,134.0)	77.7	-3	(666.4)	10,610
-4	(1,512.0)	77.0	-4	(888.5)	10,674
-5	(1,890.0)	76.3	-5	(1,110.7)	10,739
-6	(2,268.1)	75.6	-6	(1,332.8)	10,803
-7	(2,646.1)	74.9	-7	(1,555.0)	10,867
-8	(3,024.1)	74.2	-8	(1,777.1)	10,931
-9	(3,402.1)	73.5	-9	(1,999.2)	10,996
-10	(3,780.1)	72.8	-10	(2,221.4)	11,060

← EAF POINTS
-10.000

Weighting Factor =

Adjusted EAF
65.9 →

5.44%

← AHR POINTS
0.000

Weighting Factor =

Adjusted ANGHR
10331 →

6.34%

**TAMPA ELECTRIC COMPANY
 COMPARISON OF GPIF TARGETS VS ACTUAL PERFORMANCE**

EQUIVALENT AVAILABILITY (%)

<u>PLANT / UNIT</u>	<u>TARGET WEIGHTING FACTOR (%)</u>	<u>NORMALIZED WEIGHTING FACTOR</u>	<u>TARGET PERIOD JAN 05 - DEC 05</u>			<u>ACTUAL PERFORMANCE JAN 05 - DEC 05</u>		
			<u>POF</u>	<u>EUOF</u>	<u>EUOR</u>	<u>POF</u>	<u>EUOF</u>	<u>EUOR</u>
BIG BEND 1	15.68%	22.9%	15.3	32.0	37.8	8.6	30.4	33.2
BIG BEND 2	17.44%	25.4%	3.8	34.5	35.9	16.0	19.2	22.8
BIG BEND 3	18.30%	26.7%	3.8	35.6	37.0	7.1	41.4	44.6
BIG BEND 4	11.68%	17.0%	3.8	17.5	18.2	7.8	21.5	23.3
POLK 1	<u>5.44%</u>	<u>7.9%</u>	<u>3.8</u>	<u>16.5</u>	<u>17.1</u>	<u>0.0</u>	<u>31.5</u>	<u>31.5</u>
GPIF SYSTEM	68.54%	100.0%	6.5	29.9	32.1	9.2	29.1	31.8
GPIF SYSTEM WEIGHTED EQUIVALENT AVAILABILITY (%)			<u>63.6</u>			<u>61.7</u>		
			<u>3 PERIOD AVERAGE</u>			<u>3 PERIOD AVERAGE</u>		
			<u>POF</u>	<u>EUOF</u>	<u>EUOR</u>	<u>EAF</u>		
			5.8	28.4	29.5	65.8		

AVERAGE NET OPERATING HEAT RATE (Btu/kwh)

<u>PLANT / UNIT</u>	<u>TARGET WEIGHTING FACTOR (%)</u>	<u>NORMALIZED WEIGHTING FACTOR</u>	<u>TARGET</u>	<u>ADJUSTED</u>
			<u>HEAT RATE JAN 05 - DEC 05</u>	<u>ACTUAL HEAT RATE JAN 05 - DEC 05</u>
BIG BEND 1	5.27%	16.8%	10,853	10,964
BIG BEND 2	4.72%	15.0%	10,672	10,610
BIG BEND 3	7.40%	23.5%	10,663	10,767
BIG BEND 4	7.74%	24.6%	10,350	10,690
POLK 1	<u>6.34%</u>	<u>20.1%</u>	<u>10,342</u>	<u>10,331</u>
GPIF SYSTEM	31.46%	100.0%		
GPIF SYSTEM WEIGHTED AVERAGE HEAT RATE (Btu/kwh)			<u>10,555</u>	<u>10,670</u>

**TAMPA ELECTRIC COMPANY
 GENERATING PERFORMANCE INCENTIVE POINTS CALCULATION
 JANUARY 2005 - DECEMBER 2005**

Points are calculated according to the formula:

$$GPIP = \sum_{i=1}^n [a_i(EAP_i) + e_i(AHRP_i)]$$

Where:

GPIP = Generating performance incentive points

a_i = Percentage of total system fuel cost reduction attributed to maximum reasonably attainable equivalent availability of unit i during the period

e_i = Percentage of total system fuel cost reduction attributed to minimum reasonably attainable average heat rate of unit i during the period

EAP_i = Equivalent availability points awarded/deducted for unit i

AHRP_i = Average heat rate points awarded/deducted for unit i

Weighting factors and point values are listed on page 4.

<i>GPIP</i> =	15.68%	*	(BB 1 EAP) +	17.44%	*	(BB 2 EAP) +	18.30%	*	(BB 3 EAP)
	+ 11.68%	*	(BB 4 EAP) +						
	+ 5.44%	*	(PK 1 EAP) +	5.27%	*	(BB 1 AHRP) +	4.72%	*	(BB 2 AHRP)
	+ 7.40%	*	(BB 3 AHRP) +	7.74%	*	(BB 4 AHRP) +			
				+ 6.34%	*	(PK 1 AHRP)			

<i>GPIP</i> =	15.68%	*	5.537	+	17.44%	*	10.000	+	18.30%	*	-4.893
	+ 11.68%	*	-6.624	+				+			
	+ 5.44%	*	-10.000	+	5.27%	*	-0.795	+	4.72%	*	0.000
	+ 7.40%	*	-0.504	+	7.74%	*	-6.486	+			
				+	6.34%	*	0.000				

<i>GPIP</i> =	0.868	+	1.744	+	-	0.895
	+ -0.774	+	0.000	+		0.000
	+ -0.544	+	-0.042	+		0.000
	+ -0.037	+	-0.502	+		0.000
	+ 0.000	+	0.000			

GPIP = -0.182 POINTS

REWARD/PENALTY dollar amounts of the Generating Performance Incentive Factor (GPIF) are determined directly from the table for the corresponding Generating Performance Points (GPIP) on page 2.

GPIF REWARD = (\$99,791)

DOCKET NO. 060001-EI
GPIF 2005 ACTUAL UNIT
PERFORMANCE DATA
EXHIBIT WAS-1, DOCUMENT 2

EXHIBIT TO THE TESTIMONY OF

William A. Smotherman

DOCKET NO. 060001-EI

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE FACTOR
JANUARY 2005 - DECEMBER 2005
TRUE-UP

DOCUMENT NO. 2

ACTUAL UNIT PERFORMANCE DATA

ORIGINAL SHEET NO. 8.401.05A
TAMPA ELECTRIC COMPANY

ACTUAL UNIT PERFORMANCE DATA

JANUARY 2005 - DECEMBER 2005

DOCKET NO. 060001-EI
GPIF 2005 ACTUAL UNIT PERFORMANCE DATA
EXHIBIT WAS-1, DOC. 2, PAGE 1 OF 5

'PLANT/UNIT	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	PERIOD
	JAN 05	FEB 05	MAR 05	APR 05	MAY 05	JUN 05	JUL 05	AUG 05	SEP 05	OCT 05	NOV 05	DEC 05	2005
BIG BEND 1													
1. EAF (%)	80.2	93.8	60.0	71.1	74.2	58.2	69.6	67.7	71.5	46.1	32.5	9.6	61.0
2. PH	744.0	672.0	744.0	719.0	744.0	720.0	744.0	744.0	720.0	745.0	720.0	744.0	8760
3. SH	630.2	652.9	554.9	553.7	616.5	524.3	744.0	694.1	720.0	530.6	356.5	137.9	6715.5
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5. UH	113.8	19.2	189.1	165.3	127.5	195.8	0.0	49.9	0.0	214.4	363.5	606.1	2044.5
6. POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	183.0	571.6	754.6
7. FOH	0.0	19.2	189.1	0.0	127.5	154.7	0.0	49.9	0.0	214.4	95.8	34.5	885.1
8. MOH	113.8	0.0	0.0	165.3	0.0	41.1	0.0	0.0	0.0	0.0	84.7	0.0	404.8
9. PFOH	126.1	80.8	223.4	117.7	205.5	457.1	1170.9	1106.3	1112.3	724.5	380.1	154.6	5859.3
10. LR PF (MW)	113.1	120.9	207.6	152.8	132.0	96.9	81.4	72.4	77.7	108.8	132.3	183.4	98.8
11. PMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	8.9	0.0	8.9
12. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	132.8	0.0	132.8
13. NSC (MW)	428.0	428.0	428.0	421.0	421.0	421.0	421.0	421.0	421.0	421.0	421.0	428.0	423
14. OPR BTU(GBTU)	2313.3	2454.5	1774.4	2049.2	2115.3	1754.3	2460.3	2253.7	2329.7	1526.2	1047.9	311.4	22389.9576
15. NET GEN (MWH)	216779.0	229701.0	161731.0	191365.0	191681.0	156049.0	211812.5	198707.5	207632.0	137384.2	93255.0	26048.0	2022145
16. ANOHR (BTU/KWH)	10671.1	10685.4	10971.2	10708.1	11035.3	11241.7	11615.2	11341.7	11220.4	11109.3	11237.1	11954.0	11072
17. NOF (%)	80.4	82.2	68.1	82.1	73.9	70.7	67.6	68.0	68.5	61.5	62.1	44.1	71.1
18. NPC (MW)	428.0	428.0	428.0	421.0	421.0	421.0	421.0	421.0	421.0	421.0	421.0	428.0	423
19. ANOHR EQUATION	ANOHR = NOF (-18.920) + 12305.628												

ACTUAL UNIT PERFORMANCE DATA

JANUARY 2005 - DECEMBER 2005

PLANT/UNIT	MONTH OF:												PERIOD			
	JAN 05	FEB 05	MAR 05	APR 05	MAY 05	JUN 05	JUL 05	AUG 05	SEP 05	OCT 05	NOV 05	DEC 05				
BIG BEND 2																2005
1. EAF (%)	72.5	70.8	91.5	84.1	72.9	83.7	79.3	78.6	68.3	0.0	0.2	75.7				64.8
2. PH	744.0	672.0	744.0	719.0	744.0	720.0	744.0	744.0	720.0	745.0	720.0	744.0				8760
3. SH	600.8	485.9	744.0	674.6	566.5	675.7	741.7	718.1	690.7	0.0	5.9	652.8				6556.6
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				0.0
5. UH	143.2	186.1	0.0	44.5	177.5	44.3	2.4	25.9	29.3	745.0	714.1	91.2				2203.4
6. POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.2	745.0	653.4	0.0				1399.5
7. FOH	72.4	11.3	0.0	44.5	177.5	44.3	2.4	25.9	28.1	0.0	60.7	91.2				558.3
8. MOH	70.8	174.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				245.6
9. PFOH	181.6	24.2	312.7	376.3	109.2	253.4	461.7	837.9	1020.9	0.0	5.9	240.9				3824.7
10. LR PF (MW)	140.1	173.7	84.6	73.4	88.1	114.2	130.0	63.1	77.2	0.0	312.0	148.3				91.9
11. PMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6.7				6.7
12. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	234.0				234.0
13. NSC (MW)	416.0	416.0	416.0	396.0	396.0	396.0	396.0	396.0	396.0	396.0	396.0	416.0				403
14. OPR BTU(GBTU)	1994.4	1798.4	2573.4	2377.4	2054.7	2321.0	2386.9	2305.3	1970.8	0.0	2.1	2134.8				21919.2345
15. NET GEN (MWH)	191179.0	177021.0	247360.0	219276.0	197205.0	218171.0	218114.3	214768.9	182647.0	0.0	197.0	202367.0				2068306
16. ANOHR (BTU/KWH)	10432.3	10159.4	10403.4	10841.9	10419.3	10638.5	10943.5	10733.6	10790.2	0.0	10586.3	10549.2				10598
17. NOF (%)	76.5	87.6	79.9	82.1	87.9	81.5	74.3	75.5	66.8	0.0	8.4	74.5				78.3
18. NPC (MW)	416.0	416.0	416.0	396.0	396.0	396.0	396.0	396.0	396.0	396.0	396.0	416.0				403
19. ANOHR EQUATION	ANOHR = NOF(-10.937) + 11516.070															

ORIGINAL SHEET NO. 8.401.05A
 TAMPA ELECTRIC COMPANY

ACTUAL UNIT PERFORMANCE DATA

JANUARY 2005 - DECEMBER 2005

PLANT/UNIT	MONTH OF:												PERIOD			
	JAN 05	FEB 05	MAR 05	APR 05	MAY 05	JUN 05	JUL 05	AUG 05	SEP 05	OCT 05	NOV 05	DEC 05				
BIG BEND 3																2005
1. EAF (%)	65.1	69.8	38.3	1.2	44.2	72.0	71.6	65.2	48.7	54.0	52.1	36.4	51.5			
2. PH	744.0	672.0	744.0	719.0	744.0	720.0	744.0	744.0	720.0	745.0	720.0	744.0	876.0			
3. SH	597.2	672.0	432.3	22.9	453.4	720.0	744.0	653.0	494.8	670.6	577.4	356.8	6394.4			
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
5. UH	146.8	0.0	311.8	696.1	290.6	0.0	0.0	91.0	225.2	74.4	142.6	387.3	2365.6			
6. POH	0.0	0.0	0.0	617.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	617.9			
7. FOH	0.0	0.0	208.3	78.2	290.6	0.0	0.0	91.0	225.2	74.4	100.6	227.5	1295.7			
8. MOH	146.8	0.0	103.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	42.0	159.7	452.0			
9. PFOH	640.7	1203.6	610.4	19.6	428.2	867.4	1030.2	1041.5	292.2	690.0	963.3	391.6	8178.6			
10. LR PF (MW)	76.3	73.1	104.4	303.4	122.9	98.2	86.7	68.2	208.4	162.1	86.7	94.9	97.6			
11. PMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	7.3	10.7	0.0	18.0			
12. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	207.8	187.9	0.0	196.0			
13. NSC (MW)	433.0	433.0	433.0	423.0	423.0	423.0	423.0	423.0	423.0	423.0	423.0	433.0	426			
14. OPR BTU(GBTU)	2093.9	2114.7	1229.4	34.9	1405.6	2343.9	2403.1	2111.2	1370.7	1812.5	1598.9	1102.7	19621.6707			
15. NET GEN (MWH)	194992.0	191483.0	113965.0	2330.0	129422.0	214041.0	217932.3	195577.5	121937.0	167108.8	143407.0	100054.0	1792250			
16. ANOHR BTU/KWH	10738.5	11043.8	10787.7	14996.9	10860.8	10950.9	11026.9	10794.7	11241.2	10846.3	11149.4	11020.8	10948			
17. NOF (%)	75.4	65.8	60.9	24.0	67.5	70.3	69.2	70.8	58.3	58.9	58.7	64.8	65.7			
18. NPC (MW)	433.0	433.0	433.0	423.0	423.0	423.0	423.0	423.0	423.0	423.0	423.0	433.0	426			
19. ANOHR EQUATION	ANOHR = NOF(-28.859) + 12739.979															

ORIGINAL SHEET NO. 8.401.05A
TAMPA ELECTRIC COMPANY

ACTUAL UNIT PERFORMANCE DATA

JANUARY 2005 - DECEMBER 2005

PLANT/UNIT	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	PERIOD
	JAN 05	FEB 05	MAR 05	APR 05	MAY 05	JUN 05	JUL 05	AUG 05	SEP 05	OCT 05	NOV 05	DEC 05	2005
1. EAF (%)	72.4	18.1	43.5	97.5	97.1	89.9	69.9	54.8	89.2	68.1	66.7	78.2	70.7
2. PH	744.0	672.0	744.0	719.0	744.0	720.0	744.0	744.0	720.0	745.0	720.0	744.0	8760
3. SH	737.8	208.5	349.5	709.3	744.0	674.5	564.2	450.4	695.4	600.1	492.7	590.1	6816.4
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5. UH	6.2	463.6	394.5	9.7	0.0	45.5	179.8	293.6	24.7	144.9	227.3	154.0	1943.6
6. POH	0.0	411.3	272.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	683.8
7. FOH	0.0	52.3	122.0	9.7	0.0	45.5	179.8	293.6	24.7	0.0	196.3	0.0	923.9
8. MOH	6.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	144.9	31.0	154.0	336.0
9. PFOH	750.8	209.0	87.5	14.3	95.5	94.4	166.2	176.3	231.6	338.7	52.3	26.7	2243.3
10. LR PF (MW)	121.9	191.1	135.8	253.2	102.7	130.2	120.5	108.8	103.5	116.4	86.7	140.1	124.8
11. PMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	8.9	5.3	0.0	14.2
12. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	277.2	226.0	0.0	258.1
13. NSC (MW)	460.0	460.0	460.0	452.0	452.0	452.0	452.0	452.0	452.0	452.0	452.0	460.0	455
14. OPR BTU(GBTU)	2401.3	539.0	1401.2	3229.2	3258.4	2812.4	2384.6	1796.2	2762.5	2344.3	2135.5	2548.8	27613.3268
15. NET GEN (MWH)	223629.0	50753.0	139162.0	309225.0	305406.0	258579.0	210959.3	153916.1	256485.0	214711.0	194747.0	233136.0	2550708
16. ANOHR BTU/KWH	10737.7	10619.6	10069.1	10442.8	10669.1	10876.3	11303.5	11670.3	10770.7	10918.2	10965.5	10932.7	10826
17. NOF (%)	65.9	52.9	86.6	96.5	90.8	84.8	82.7	75.6	81.6	79.2	87.4	85.9	82.3
18. NPC (MW)	460.0	460.0	460.0	452.0	452.0	452.0	452.0	452.0	452.0	452.0	452.0	460.0	455
19. ANOHR EQUATION	ANOHR = NOF(-40.192) + 13794.468												

41

ORIGINAL SHEET NO. 8.401.05A
TAMPA ELECTRIC COMPANY
ACTUAL UNIT PERFORMANCE DATA
JANUARY 2005 - DECEMBER 2005

DOCKET NO. 060001-EI
GPIF 2005 ACTUAL UNIT PERFORMANCE DATA
EXHIBIT WAS-1, DOC. 2, PAGE 5 OF 5

PLANT/UNIT	MONTH OF:												PERIOD					
	JAN 05	FEB 05	MAR 05	APR 05	MAY 05	JUN 05	JUL 02	AUG 05	SEP 05	OCT 05	NOV 05	DEC 05						
POLK 1																	2005	
1. EAF (%)	54.3	0.0	0.0	8.6	93.6	93.5	91.8	96.2	96.7	99.2	99.1	82.5					68.5	
2. PH	744.0	672.0	744.0	719.0	744.0	720.0	744.0	744.0	720.0	745.0	720.0	744.0					8760	
3. SH	130.7	0.0	0.0	67.0	732.4	716.8	677.3	702.1	707.1	693.2	666.1	571.9					5664.6	
4. RSH	290.9	0.0	0.0	0.0	31.5	0.0	59.4	39.8	0.0	50.7	59.2	41.9					573.5	
5. UH	322.4	672.0	744.0	652.0	19.0	3.1	31.3	2.1	12.9	1.1	4.8	130.2					2594.9	
6. POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0					0.0	
7. FOH	322.4	672.0	744.0	632.3	19.0	3.1	14.0	2.1	12.9	1.1	4.8	0.0					2427.7	
8. MOH	0.0	0.0	0.0	19.7	0.0	0.0	17.3	0.0	0.0	0.0	0.0	130.2					167.2	
9. PFOH	306.9	0.0	0.0	63.2	725.0	775.3	701.9	552.7	92.5	38.6	12.5	0.0					3268.6	
10. LR PF (MW)	15.0	0.0	0.0	18.2	10.0	14.4	10.9	12.2	30.0	30.0	30.0	0.0					13.1	
11. PMOH	0.0	0.0	0.0	3.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0					3.9	
12. LR PM (MW)	0.0	0.0	0.0	30.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0					30.0	
13. NSC (MW) **	260.0	260.0	260.0	255.0	255.0	255.0	255.0	255.0	255.0	255.0	255.0	260.0					257	
14. OPR BTU(GBTU)	294.6	0.0	0.0	125.9	1659.3	1649.1	1530.9	1664.6	1617.9	1671.2	1676.2	1410.9					13300.6844	
15. NET GEN (MWH)	24143.0	-1884.0	-4046.0	2018.0	158626.0	161718.0	146197.0	159770.0	160932.0	166238.0	161055.0	138940.0					1273707	
16. ANOHR BTU/KWH	12202.4	0.0	0.0	62380.7	10460.6	10197.6	10471.6	10418.9	10053.2	10053.3	10407.6	10154.5					10442	
17. NOF (%)	71.1	0.0	0.0	11.8	84.9	88.5	84.7	89.2	89.3	94.0	94.8	93.4					87.6	
18. NPC (MW) **	260.0	260.0	260.0	255.0	255.0	255.0	255.0	255.0	255.0	255.0	255.0	260.0					257	
19. ANOHR EQUATION																		

ANOHR = NOF(-73.216) + 16866.459