

MEMORANDUM

April 18, 2006

US APR 18 PM 12: 38

COMMISSION CLERK

TO:	DIVISION OF THE COMMISSION CLERK AND ADMINISTRATIVE SERVICES
FROM:	OFFICE OF THE GENERAL COUNSEL (BRUBAKER)
RE:	DOCKET NO. 040384-WS – APPLICATION FOR AMENDMENT TO CERTIFICATES 247-W AND 189-S IN SEMINOLE COUNTY BY SANLANDO UTILITIES CORPORATION.

Attached is a letter dated March 23, 3006 to Jennifer Brubaker, Esquire from Valerie L. Lord of Rose, Sundstrom & Bentley, LLP. Please file in the above-referenced docket.

DATE DOCUMENT SENT TO CCA 418/06

JSB/pz Attachment

CIVIP	
COM	
CTR	
ECR	
GCL	
OPC	
RCA	
SCR	
SGA	
SEC	
отн	

DOCUMENT NUMBER-DATE

03390 APR 188

LAW OFFICES

Rose, Sundstrom & Bentley, LLP

2548 BLAIRSTONE PINES DRIVE TALLAHASSEE, FLORIDA 32301

FREDERICK L. ASCHAUER, JR. CHRIS H. BENTLEY, P.A. ROBERT C. BRANNAN DAVID F. CHESTER F. MARSHALL DETERDING JOHN R. JENKINS, P.A. STEVEN T. MINDLIN, P.A. CHASITY H. O'STEEN DAREN L. SHIPPY WILLIAM E. SUNDSTROM, P.A. DIANE D. TREMOR, P.A. JOHN L. WHARTON ROBERT M. C. ROSE, OF COUNSEL

WAYNE L. SCHIEFELBEIN, OF COUNSEL

(850) 877-6555 FAX (850) 656-4029 www.rsbattornevs.com

REPLY TO CENTRAL FLORIDA OFFICE

CENTRAL FLORIDA OFFICE Sanlando Center 2180 W. STATE ROAD 434, SUITE 2118 LONGWOOD, FLORIDA 32779 (407) 830-6331

FAX (407) 830-8522

VALERIE L. LORD

BRIAN J. STREET

MARTIN S. FRIEDMAN, P.A.

March 23, 2006

VIA FACSIMILE AND U.S. MAIL

Jennifer Brubaker, Esq. Office of General Counsel Florida Public Service Commission 2540 Shumard Oak Boulevard Tallahassee, FL 32399

Re: Docket No. 040384-WS; Application of Sanlando Utilities Corp. for an Amendment

of Water and Wastewater Certificates in Seminole County, Florida

Our File No.: 30057.61

Dear Jennifer:

Per your request, we provide the following explanation of the differences between the testimony of Mr. Gary Miller of the Florida Department of Environmental Protection (DEP) and Sanlando Utilities Corp. relating to Sanlando's water treatment plants (WTP) and wastewater treatment plants (WWTP):

Des Pinar: The Des Pinar WTP was originally rated at 5.364 mgd. About eighteen (18) months ago, Sanlando asked the DEP to re-rate the WTP to increase its permitted capacity to 6.261 mgd. After a careful review, the DEP re-rated the Des Pinar WTP at 5.040 mgd.

The permitted capacity of the Des Pinar WWTP is .500 mgd, which is consistent with Mr. Miller's testimony.

Knollwood: The permitted capacity of the Knollwood WTP is .576 mgd, which is consistent with Mr. Miller's testimony.

There is no WWTP at Knollwood.

Wekiva Hunt Club: The Wekiva Hunt Club WTP was originally rated at 8.928 mgd. About eighteen (18) months ago, Sanlando asked the DEP to re-rate the Wekive Hunt Club WTP to increase its permitted capacity to 11.088 mgd. After careful review, the DEP re-rated this WTP, increasing its permitted capacity to 11.088 mgd.

Jennifer Brubaker, Esquire Florida Public Service Commission March 23, 2006 Page 2

The permitted capacity of the Wekiva Hunt Club WWTP is currently 2.900 mgd. The design capacity of the plant is 4.500 mgd. The average annual daily flow is 2.152 mgd, which is within its permitted capacity. After a six-day period of heavy rainfall, the plant recorded 3.259 as a maximum day flow (not an average) on its DMRs. The spike was the result of an anomalous event. On the average, the WWTP has not exceeded its permitted capacity.

Should you have any questions regarding this matter, please do not hesitate to give me a call.

Very truly yours,

VALERIE L. LORD

VLL/tlc

cc: Mr. Steven M. Lubertozzi

Mr. Patrick C. Flynn

ROSE, SUNDSTROM & BENTLEY, LLP

SANLANDO CENTER
2180 W. STATE ROAD 434, SUITE 2118
LONGWOOD, FL 32779

Jennifer Brubaker, Esq.
Office of General Counsel
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, FL 32399

32399+7019-40 C001

ADDITION OF THE PARTY OF THE PA