

# ORIGINAL

FLORIDA PUBLIC SERVICE COMMISSION

OFFICE OF THE GENERAL COUNSEL

DOCKET NO. 060512-EU

RULE NO:    RULE TITLE:

25-6.0343    Municipal Electric Utility and Rural Electric Cooperative Reporting  
Requirements

## NOTICE OF CHANGE

Notice is hereby given that the following changes have been made to the proposed rule in accordance with subparagraph 120.54(3)(d)1., F.S., published in Volume 32, No. 27, July 7, 2006, issue of the Florida Administrative Weekly:

The rule text proposed July 7, 2006 has been substantially changed, and the new rule shall read:

25-6.0343 Municipal Electric Utility and Rural Electric Cooperative Reporting Requirements

(1) Application and Scope. The purpose of this rule is to define certain reporting requirements by municipal electric utilities and rural electric cooperatives providing distribution service to end-use customers in Florida.

(2) The reports required by subsections (3), (4), and (5) of this rule shall be filed with the

Director of the Division of Economic Regulation by March 1 of each year for the preceding calendar year.

(3) Standards of Construction. Each municipal electric utility and rural electric cooperative shall report the extent to which its construction standards, policies, practices, and procedures are designed to address the ability of transmission and distribution facilities to

VP \_\_\_\_\_  
OM \_\_\_\_\_  
TR \_\_\_\_\_  
CR \_\_\_\_\_  
CL \_\_\_\_\_  
PC \_\_\_\_\_  
DA \_\_\_\_\_  
DR \_\_\_\_\_  
GA \_\_\_\_\_  
EC   1    
TH \_\_\_\_\_

DOCUMENT NUMBER-DATE

09426 OCT 11 g

mitigate damage caused by extreme weather. Each utility report shall, at a minimum, address the extent to which its construction standards, policies, guidelines, practices, and procedures:

(a) Comply, at a minimum, with the National Electrical Safety Code (ANSI C-2) [NESC]. For electrical facilities constructed on or after February 1, 2007, the 2007 NESC shall apply. Electrical facilities constructed prior to February 1, 2007, shall be governed by the edition of the NESC in effect at the time of the facility's initial construction. A copy of the 2007 NESC, ISBN number 0-7381-4893-8, may be obtained from the Institute of Electric and Electronic Engineers, Inc. (IEEE).

(b) Are guided by the extreme wind loading standards specified by Figure 250-2(d) of the 2002 edition of the NESC for:

1. new construction;
2. major planned work, including expansion, rebuild, or relocation of existing facilities, assigned on or after the effective date of this rule; and
3. targeted critical infrastructure facilities and major thoroughfares taking into account political and geographical boundaries and other applicable operational considerations.

(c) Address the effects of flooding and storm surges on underground distribution facilities and supporting overhead facilities.

(d) Provide for placement of new and replacement distribution facilities so as to facilitate safe and efficient access for installation and maintenance.

(e) Include written safety, pole reliability, pole loading capacity, and engineering standards and procedures for attachments by others to the utility's electric transmission and distribution poles.

(4) Facility Inspections. Each municipal electric utility and rural electric cooperative shall report, at a minimum, the following information pertaining to its transmission and distribution facilities:

(a) A description of the utility's policies, guidelines, practices, and procedures for inspecting transmission and distribution lines, poles, and structures including, but not limited to, pole inspection cycles and pole selection process.

(b) The number and percentage of transmission and distribution inspections planned and completed.

(c) The number and percentage of transmission poles and structures and distribution poles failing inspection and the reason for the failure.

(d) The number and percentage of transmission poles and structures and distribution poles, by pole type and class of structure, replaced or for which remediation was taken after inspection, including a description of the remediation taken.

(5) Vegetation Management. Each municipal electric utility and rural electric cooperative shall report, at a minimum, the following information pertaining to the utility's vegetation management efforts:

(a) A description of the utility's policies, guidelines, practices, and procedures for vegetation management, including programs addressing appropriate planting, landscaping, and problem tree removal practices for vegetation management outside of road right-of-ways or easements, and an explanation as to why the utility believes its vegetation management practices are sufficient.

(b) The quantity, level, and scope of vegetation management planned and completed for transmission and distribution facilities.

Specific Authority: 350.127(2), 366.05(1) FS.

Law Implemented: 366.04(2)(f), 366.04(6) FS.

History New \_\_\_\_\_.

I:\FAW-notices\060512eu.doc

Submit FAW Notices

Step 5:

Acknowledgement of Submittal

The Administrative Code and Weekly Unit has received your notice for publication in the FAW.

A confirmation number has been provided below which may be used to reference this submittal in any communications with the Unit. Use the your browser *'Print'* button or the *'Print this Acknowledgement'* button at the bottom of this page to generate a receipt for your records. A record of this transmittal will be maintained for approximately 30 days and may be accessed from the 'Submittal Listing' item in the FAW Online menu on the left of this page.

Confirmation No

Notice1992

Submitted On	10/11/2006 11:07:38 AM
FAW Pub Date	10/20/2006
Volume/Number	32/42
Notice Section	Notice of Change/Withdrawal
Payment Method	Purchase Order
PO #	600057
Department	Public Service Commission
Division	
Organization	
SAMAS Account	
Billing Address	2540 Shumard Oak Blvd. Tallahassee, FL 32399-0850
Contact	Rose Thompson/Hong Wang 850-413-6770/413-6762 rthompso@psc.state.fl.us/hwang@psc.state.fl.us
Submitted File	I:\FAW-notices\060512eu.doc
Notice Text	
Comments	

[Print this Acknowledgement](#)