

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

**In Re: Petition on behalf of Citizens of
the State of Florida to require
Progress Energy Florida, Inc. to
refund to customers \$143 million**

DOCKET NO. 060658

Submitted for filing: January 16, 2007

**DIRECT TESTIMONY
OF JON FRANKE
ON BEHALF OF
PROGRESS ENERGY FLORIDA**

**R. ALEXANDER GLENN
JOHN BURNETT
PROGRESS ENERGY SERVICE
COMPANY, LLC
P.O. Box 14042
St. Petersburg, Florida 33733
Telephone: (727) 820-5180
Facsimile: (727) 820-5519**

**JAMES MICHAEL WALLS
Florida Bar No. 706272
DIANNE M. TRIPLETT
Florida Bar No. 0872431
CARLTON FIELDS, P.A.
Post Office Box 3239
Tampa, FL 33601
Telephone: (813) 223-7000
Telecopier: (813) 229-4133**

DOCUMENT NUMBER-DATE

00434 JAN 16 5

FPSC-COMMISSION CLERK

**IN RE: PETITION ON BEHALF OF CITIZENS OF THE
STATE OF FLORIDA TO REQUIRE PROGRESS ENERGY
FLORIDA, INC. TO REFUND CUSTOMERS \$143 MILLION**

FPSC DOCKET NO. 060658

DIRECT TESTIMONY OF

JON FRANKE

1

2

I. INTRODUCTION AND QUALIFICATIONS

3

4 **Q. Please state your name and business address.**

5 **A.** My name is Jon Franke. My business address is 15760 W. Powerline St., Crystal
6 River, FL 34442.

7

8 **Q. By whom are you employed and in what capacity?**

9 **A.** I am employed by Progress Energy Florida, Inc. ("PEF" or the "Company") in the
10 Nuclear Generation Group and serve as Plant General Manager at Crystal River Unit
11 3 ("CR3"), PEF's nuclear plant.

12

13 **Q. What do you do?**

14 **A.** As Plant General Manager I am responsible for the safe operation of the nuclear
15 generating station. The Operations, Maintenance, Scheduling, Radiation Protection
16 and Chemistry units report to me. Through my management team I have about 300
17 employees that perform the daily work required to operate the station.

18

1 **Q. What is the purpose of your testimony?**

2 **A.** My testimony will explain the impact of bringing Powder River Basin ("PRB") coal
3 to the Crystal River site with respect to PEF's nuclear unit, Crystal River 3 ("CR3").
4 Such a change in coal selection represents a significant challenge to my facility.
5 There are major nuclear plant concerns that must be addressed before PRB coal could
6 even be considered for wide-scale use at the Crystal River Energy Complex. My
7 testimony will discuss those concerns and explain what would be required before any
8 significant amount of PRB coal could be allowed at the Crystal River site.

9

10 **Q. Please describe your education background and professional experience.**

11 **A.** I have a Bachelor's degree in Mechanical Engineering from the United States Naval
12 Academy at Annapolis. I have a graduate degree in the same field from the
13 University of Maryland and a Masters of Business Administration from the
14 University of North Carolina at Wilmington.

15 I have over 20 years of experience in nuclear operations. I received training
16 by the US Navy as a nuclear officer and oversaw the operation and maintenance of a
17 nuclear aircraft carrier propulsion plant during my service. Following my service in
18 the Navy I was hired by Carolina Power and Light and have been with the company
19 through the formation of Progress Energy. My early assignments involved
20 engineering and operations, including oversight of the daily operation of the
21 Brunswick nuclear plant as a Nuclear Regulatory Commission ("NRC") licensed
22 Senior Reactor Operator. I was the Engineering Manager of that station for three
23 years prior to assignment to my present job, approximately five years ago.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

Q. Are you sponsoring any exhibits with your testimony?

A. Yes, I am sponsoring the following exhibits that were prepared by me or prepared under my direction.

- Exhibit No. __ (JF-1), which is an aerial photograph of the Crystal River site;
- Exhibit No. __ (JF-2), which is a composite exhibit of pictures of the barge unloader, which were taken from various places at CR3;
- Exhibit No. __ (JF-3), which is a composite exhibit of pictures of various points along the conveyor belt that would transport PRB coal, which were taken from CR3;
- Exhibit No. __ (JF-4), which is a picture taken of CR3 from the tripper floor at CR4;
- Exhibit No. __ (JF-5), which is a picture taken of CR3 from a conveyor belt that would transport the PRB coal;
- Exhibit No. __ (JF-6), which is a diagram of the transmission lines that provide power to the CR3 nuclear unit;
- Exhibit No. __ (JF-7), which is a composite exhibit of pictures of transmission lines at Crystal River as they cross over the conveyor belts;
- Exhibit No. __ (JF-8), which is an analysis of the steps taken to evaluate a proposed change at a nuclear facility;
- Exhibit No. __ (JF-9), which is a list of the risks that would require analysis pursuant to the CR3 operating license before significant quantities of PRB coal could be brought onto the Crystal River site.

1 These exhibits are true and correct.

2

3 **Q. Please summarize your testimony.**

4 **A.** The use of significant quantities of PRB coal at the Crystal River Energy Complex
5 may cause a reduction in the safety margin at the nuclear plant which would need to
6 be evaluated by the Company. The characteristics of PRB coal are vastly different
7 from the bituminous coal currently handled, burned and stored at the Crystal River
8 Energy Complex. The risk of spontaneous combustion, as well as the increased
9 production of flammable PRB dust, present additional hazards and risks that may not
10 have been previously analyzed in PEF's original nuclear operating license.

11 As the nuclear plant general manager, I believe that the use of significant
12 quantities of PRB coal is not prudent in the vicinity of a nuclear plant. Frankly, I
13 would not want this volatile PRB coal in the vicinity of the CR3 nuclear unit on a
14 long-term basis. I have had my licensing group contact every nuclear plant that is
15 sited with a coal facility. No similar condition, i.e. having PRB coal on-site with a
16 nuclear facility, exists or has been evaluated.

17 If PRB coal was to be used at the Crystal River site on a long-term basis, the
18 NRC would oblige the Company to evaluate whether this change in coal would result
19 in more than a minimal increase in risk. This evaluation is rigorous and will likely
20 require months of engineering analysis and study. The unique nature of the situation,
21 because to my knowledge no other nuclear unit has ever evaluated the risks of PRB
22 coal near the unit, means that this analysis will be that much more time-consuming
23 and difficult. After the evaluation, if the Company finds that, even with mitigation

1 strategies, the use of PRB coal would cause a more than minimal increase in risk to
2 plant safety under 10 C.F.R. 50.59, then the Company would have to submit a license
3 amendment request to the NRC. At this point, because PEF has not completed the
4 extensive evaluation, I cannot say whether a license amendment application and
5 formal NRC approval would be required. Whether formally or informally, I would
6 expect the NRC would want to review this change, along with PEF's proposed
7 solutions.

8 What is clear is that this sort of risk has not been analyzed before by the NRC,
9 and there is no certainty in how the NRC will react to it. Before PEF could bring the
10 PRB coal onto the site, it would have to make any required modifications and
11 upgrades identified by the engineering reviews to ensure the change can be
12 implemented safely.

13 **II. GENERAL OVERVIEW OF CRYSTAL RIVER 3 NUCLEAR UNIT**

14

15
16 **Q. Please describe the Crystal River Site.**

17 **A.** The Crystal River complex is a 4,700 acre site located in Citrus County, Florida that
18 contains four coal-fired generating units, one nuclear generating unit, and related
19 support facilities, such as fuel transportation and storage facilities.

20
21 **Q. Please describe the Crystal River 3 ("CR3") nuclear unit.**

22 **A.** CR3 is a B&W pressurized water reactor that includes a Primary and Secondary
23 System. It currently produces approximately 838 MWe of electricity. CR3 came
24 online in early 1977. The unit generates power onto the 500 kV grid and receives

1 power from two independent 230 kV lines that come into a switchyard located just
2 north of the CR3 Reactor Building. That switchyard, in turn, is supplied by several
3 230 KV transmission lines.

4 The major physical difference between CR3 and other steam electric plants is
5 the equipment used to create the steam. Rather than having a simple oil or coal
6 boiler, CR3 uses a nuclear reactor and support systems to create heat to produce that
7 steam. Those components are housed primarily in the Reactor Building and
8 Auxiliary Building.

9
10 **Q. Please describe the CR3 nuclear unit, as well as its source of offsite power, in
11 relation to the other units and equipment located at the Crystal River site.**

12 **A.** The CR3 nuclear unit is located east of two of the coal-burning units, Crystal River
13 Units 1 and 2 ("CR1" and "CR2," respectively). The three units share a common set
14 of intake and discharge canals. That common intake canal acts as the northern
15 boundary of the south coal yard and the coal receiving area. Barges use that intake to
16 transport coal to the station.

17 CR3's Reactor Building is approximately 1,140 feet from the barge unloader,
18 where OPC alleges that PEF should be offloading 100% PRB coal. The coal pile at
19 which PEF would have to temporarily store PRB coal during offloading is located
20 just south of the barge unloader, about 1,520 feet from the CR3 Reactor Building.
21 This coal yard is approximately 1,900 feet from CR3's switchyard. At the closest
22 point, the conveyor belts that transport the coal from the barge unloader to the north
23 coal yard are located as close as 620 feet from the CR3 Reactor Building. The coal

1 pile used to store the coal for use in Crystal River Units 4 and 5 ("CR4" and "CR5,"
2 respectively) lies 3,000 feet to the northeast of CR3 and approximately 1,500 feet
3 from the switchyard. This coal yard is also where PEF would have to blend the 100%
4 PRB coal with bituminous coal, as alleged by OPC in its Petition.

5 The railcar coal unloader is approximately 950 feet to the southeast of the
6 CR3 Reactor Building. CR4 and CR5, at which OPC contends PEF should have been
7 burning a blend of 50/50 PRB coal, are located 3,450 feet from the CR3 Reactor
8 Building. Therefore, the nuclear plant would be virtually surrounded on three sides
9 by this volatile PRB coal. These distances and the layout of the Crystal River site are
10 reflected in Exhibit No. __ (JF-1).

11 To further illustrate, attached as composite Exhibit No. __ (JF-2) are pictures
12 of the barge unloader, which were taken from various places at CR3. Attached as
13 composite Exhibit No. __ (JF-3) are pictures of various points along the conveyor belt
14 that would transport PRB coal, again taken from CR3. Exhibit No. __ (JF-4) is a
15 picture taken of CR3 from the tripper floor at CR4. Exhibit No. __ (JF-5) is a picture
16 taken of CR3 from a conveyor belt that would transport the PRB coal.

17 Regarding the location of the 500 kV and 230 kV lines that supply power to
18 the CR3 switchyard, these lines run east from the CR3 unit and switchyard and cross
19 directly over the conveyor belts that transport coal to the north coal yard. These lines
20 are only about 20 to 25 feet in the air above these conveyor belts. The northernmost
21 transmission line, a 230kV line, runs only about 100 feet to the south of the north coal
22 yard. A diagram of these transmission lines is shown in my attached Exhibit No. __

1 (JF-6). Composite Exhibit No. __ (JF-7) shows some of these transmission lines as
2 they cross over the conveyor belts.

3
4 **Q. Is there an agency that regulates nuclear plants like CR3?**

5 **A.** Yes, the federal NRC regulates and licenses nuclear units. NRC enforces strict safety
6 regulations for the operation of nuclear units.

7
8 **Q. Please explain the NRC's licensing process, including how and when an
9 operating license must be modified.**

10 **A.** When applying to receive an initial operator's license, the applicant must present
11 detailed information about the unit, including an analysis of certain types of risks that
12 may affect the unit's safe performance. Included within that analysis is a description
13 of the design basis of the plant and how the plant will respond to and handle each
14 challenge to safe plant operation. The details of plant design, construction, operation,
15 geography, location, geology, environmental hazards and many other factors must
16 meet strict requirements.

17 Important to this analysis is the requirement that the nuclear operator, or
18 licensee, must understand any risks to nuclear plant safety such as those risks
19 imposed by nearby activities. This can include risks created by neighboring industrial
20 facilities or the plant's proximity to natural hazards. After thorough review of the
21 design basis and the various risks that could affect the plant, an operating license is
22 issued. The license includes specifications and requirements that are specific to the
23 nuclear plant. When a change to either the nuclear plant or the plant's surrounding

1 environment is contemplated, the plant operator must evaluate whether the change is
2 something that will affect the safety of the plant.

3 If the plant operator finds that the change may increase the probability of a
4 potential risk, or that the change may increase the severity of a risk, then the operator
5 must engage in a rigorous analysis under 10 CFR 50.59. Subsection (c)(2) of this
6 regulation states that “a licensee shall obtain a license amendment . . . prior to
7 implementing a proposed change, test, or experiment if the change, test, or
8 experiment would: (i) Result in more than a minimal increase in the frequency of
9 occurrence of an accident previously evaluated in the final safety analysis report (as
10 updated); (ii) Result in more than a minimal increase in the likelihood of occurrence
11 of a malfunction [of equipment important to safety as it had previously been reviewed
12 by NRC]; or (iii) Result in more than a minimal increase in the consequences of an
13 accident previously evaluated in the final safety analysis report (as updated).”

14 After the licensee completes this detailed engineering analysis, it must decide
15 whether the proposed change can be mitigated such that there will be no more than a
16 minimal increase in the likelihood or severity of an accident or malfunction. If it
17 finds that it passes the test set forth in 10 C.F.R. 50.59, the licensee does not need to
18 seek a license amendment from NRC.

19 If, however, the licensee concludes that the change would result in more than
20 a minimal increase, then the licensee must submit a license amendment application to
21 NRC pursuant to 10 CFR 50.90. As part of the application, the licensee must identify
22 the proposed change and present all proposed modifications to the plant that are
23 necessary to show no undue risk will be presented to the plant and the plant operator

1 will be subject to lengthy review by the NRC staff prior to the plant being able to
2 implement that change to the facility as described in its license.

3
4 **Q. Is CR3 subject to these licensing requirements?**

5 **A.** Yes, CR3 is licensed and regulated by NRC. PEF's CR3 operating license was issued
6 by the NRC on December 3, 1976.

7
8 **Q. Please briefly explain the nature of PEF's requirements pursuant to its
9 operating license.**

10 **A.** There are strict regulations that control the manner in which we maintain, modify, test
11 and operate the nuclear plant. Incorporated into our license are commitments to
12 industry standards and specific federal regulations. In addition to the CFR
13 regulations, the NRC imposes requirements on operating plants as needed through a
14 variety of mechanisms (Bulletins, Generic Letters, and NUREGS). Other operational
15 conditions can be imposed on operators such as those that occurred after the Three
16 Mile Island event, and more recently, the security upgrades that were required
17 following the terrorist activities of 9/11. Many of these requirements are detailed
18 within our Technical Specifications regarding the areas of safety limits, limiting
19 conditions for operation, surveillance requirements, design features, and
20 administrative controls. A part of our licensing basis is the Updated Final Safety
21 Analysis Report (UFSAR) which provides detailed information about the plant
22 design, environment, staffing, surrounding community, and proximate land use, in
23 addition to other details. The original version of the document was the Final Safety

1 Analysis Report, FSAR, which was used extensively by the NRC to justify granting
2 our existing license. This document is required to be maintained as various changes
3 to the facility are implemented.

4 The license basis of the plant covers virtually all aspects of what my staff does
5 on a daily basis. To ensure that the safety systems are working correctly, the
6 technical specifications include hundreds of various surveillance tests that PEF must
7 perform, at various frequencies, at CR3. Many of my employees' normal work day
8 involves the performance of these surveillances. The training of my employees, the
9 educational and experience levels they have, the calibration of instruments, the
10 monitoring of plant equipment, the material used in specific components, the quality
11 standards used in their manufacture, the tests used to validate their construction, the
12 procedures used to repair and operate that equipment and many other things are
13 detailed in CR3's license basis.

14
15 **Q. Can you provide some examples of these regulations and specifications?**

16 **A.** Yes. As required in the regulatory response to Three Mile Island, one NUREG
17 requires nuclear unit licensees to "ensure that control room operators will be
18 adequately protected against the effects of accidental release of toxic and radioactive
19 gases and that the nuclear power plant can be safely operated or shut down under
20 design basis accident conditions." In other words, to safely operate CR3, there must
21 be no hazardous conditions that will cause the evacuation of the operators in the
22 control unit. CR3 must have operators in its control room or special remote operating
23 locations in the plant at all times.

1 To comply with this requirement, PEF must, for example, ensure that the CR3
2 control room has an adequate emergency zone with critical files and a washroom,
3 self-contained breathing apparatus, and is sufficiently shielded from radiation and
4 toxic gases infiltrating into the room. Under this regulation, fires are considered to be
5 a hazard from which the operators must be protected. It is important to note that my
6 operators cannot simply shutdown the unit during a fire and evacuate the plant. They
7 must remain on station or retire to a remote operating station in a separate fire zone.
8 Should a large fire emerge in the vicinity of the plant, the ventilation system for the
9 control building must protect them from the fumes for the expected duration of the
10 fire.

11 Another important area of regulation is the availability of offsite power to the
12 nuclear unit. The offsite power system of a nuclear power plant provides the
13 preferred source of electrical power to all the station auxiliaries. Loss of the offsite
14 source results in a plant upset condition and the start of the backup power sources.
15 Power can be lost by things like smoke and dust interfering with the transmission
16 lines or the switchyard. If offsite power is lost, there is a large amount of equipment
17 which must function to mitigate such an event. The NRC imposes requirements as to
18 that back-up equipment, to ensure that the nuclear unit can be safely operated even
19 when its offsite power source is interrupted. There are also several requirements
20 designed to prevent the loss of the offsite power, including maintenance of the power
21 lines and other offsite equipment.

22 The NRC also regulates each nuclear unit's safety or protection systems.
23 Section 50.55a, "Codes and Standards" of 10 C.F.R. Part 50 requires that protection

1 * systems at nuclear units must meet the standards set forth either in IEEE Std. 279-
2 1971, "Criteria for Protection Systems for Nuclear Power Generating Stations," or
3 IEEE Std. 603-1991, "Criteria for Safety Systems for Nuclear Power Generating
4 Stations." Both standards basically define a safety or protection system as a system
5 that is designed to detect conditions at the plant that could cause safety issues or
6 concerns with the operation of the plant.

7 These standards also require that the safety or protection system must perform
8 even in the presence of a single failure within the system. In other words, the safety
9 or protection system must operate even if any one part of it has failed. In addition
10 certain features must be designed so that no single failure could cause inadvertent
11 operation of the safety system. To comply with this requirement, plants employ a
12 redundant safety system, where two trains of the same safety system operate
13 simultaneously to ensure that at least one will function at all times.

14 To maintain the integrity of these systems, plants must prevent common mode
15 failures from occurring. A "common mode failure" is a condition or hazard that
16 affects both trains of systems such that neither of the systems functions to notify the
17 plant of a safety issue. For example, if the two trains of a safety system are located in
18 the same room, the plant must take care to ensure that that room will not be flooded,
19 because this would subject both trains to the same environmental threat. Problems
20 with the operation of one component are reviewed to ensure that similar components
21 on the other train do not present the same problem. Excessive dust must be evaluated
22 against this criteria.

23

1 **Q. Are there any other ways that the NRC communicates with PEF, as an operator**
2 **of CR3?**

3 **A.** Yes, the NRC regularly issues Information Notices to all holders of operating licenses
4 for nuclear power reactors. These notices alert the operators of recent events at other
5 nuclear plants that have resulted in various issues with plant safety or operation.
6 Although the notices are not legal requirements, the holders of the operating licenses
7 are expected to review the information in the notices and determine whether the
8 lessons in the notices apply to their own plants.

9
10 **Q. Can you provide examples of these information notices?**

11 **A.** Yes, on October 20, 1985, the NRC issued Information Notice 93-85 to provide
12 details concerning safety related relays that failed to operate properly due to dirt
13 intrusion into electrical contacts. In another Information Notice, IN – 2002-34, dated
14 November 25, 2002, the NRC noted where the accumulation of dirt and dust within
15 the grease of safety related breaker auxiliary contacts lead to the failure of emergency
16 diesel output breakers at another nuclear plant. In Information Notice 98-64 the NRC
17 noted examples of electrical bus bar failures, including those in which dirt had
18 contributed to the failure of safety related electrical components leading to bus bar
19 explosions.

20
21 **Q. How would you characterize the operating requirements imposed by the NRC**
22 **on PEF's operation of CR3?**

1 A. The NRC's regulation of all nuclear units, including CR3, is very extensive. NRC's
2 main focus is on operating safety of the nuclear units. The NRC consistently works
3 to evaluate all nuclear units to anticipate most problems that could arise and then find
4 a way to limit the risks of those problems. As time passes, and incidents occur at
5 nuclear facilities, the NRC notifies all operators of nuclear units to evaluate whether
6 that particular incident could be prevented at other facilities. I literally have a library
7 room full of binders and bound copies of the various regulations, interpretations of
8 regulations, and industry standards with which I am committed to comply. My
9 licensing supervisor has estimated there are over 600,000 pages of regulatory
10 guidance which apply to the operation and maintenance of the station. Each engineer
11 is required to demonstrate a basic understanding of the regulatory structure before
12 they are allowed to work without direct supervision. I have a group of six licensing
13 engineers whose only function is to review and prepare regulatory correspondence
14 and support NRC inspection functions.

15
16 **III. SPECIFIC CONCERNS WITH HANDLING AND BURNING PRB COAL AT**
17 **CRYSTAL RIVER**

18
19 **Q. Are you generally aware of the characteristics of handling and burning PRB**
20 **coal?**

21 A. Yes, I have been informed that the chemical composition of the PRB coal that OPC
22 proposes PEF should have been burning in its CR4 and CR5 units, unlike the
23 bituminous coal currently used in those units, can cause the PRB coal to

1 spontaneously combust. There is also increased dustiness with PRB coal, and that
2 dust can catch on fire as well. The volatility of the PRB coal is explained in more
3 detail in the testimony of Rod Hatt.

4 5 **Spontaneous Combustibility**

6 **Q. Taking first the spontaneous combustion characteristic, what concerns, if any,**
7 **do you have regarding handling and storing PRB coal on the same site as the**
8 **CR3 nuclear unit?**

9 **A.** I am very concerned about the risk that piles of PRB coal could go up in flames so
10 close to CR3. The PRB coal would be stored and transported quite close to CR3, at
11 times coming as close as 620 feet. Clearly, the storage of PRB coal significantly
12 increases the chances of coal fires in the vicinity of the nuclear plant. My concerns
13 in addressing that increased plant risk are primarily in three areas. The first area is in
14 the ability to protect the nuclear operators who cannot evacuate during a large fire.
15 The second concern is what effect a coal fire might have on the equipment required to
16 operate the plant safely. Lastly, I am concerned by the possibility that this flammable
17 and potentially explosive coal pile might provide an opportunity to an adversary
18 terrorist group which would challenge our nuclear security.

19 With regard to the ability to protect the operators, this represents an
20 unanalyzed challenge to the control room ventilation system. That system is placed
21 in recirculation, passing the air through charcoal filtration trains in the unlikely event
22 of a release of significant amounts of radiation. The ventilation system must also

1 ensure that the control room staff is protected from potential airborne hazards, such as
2 toxic smoke from burning coal.

3 With regard to the performance of plant equipment, there are numerous
4 concerns. There is operating experience from another facility, where a local grass fire
5 lead to the loss of off site power due to the smoke affecting the plant switchyard. The
6 effect on the switchyard can be especially great when fighting the fire. There have
7 been many examples where fires in the area surrounding nuclear plants have caused a
8 loss of off site power to the facilities. The conveyor belts that will transport PRB coal
9 to CR4 and CR5 are also quite close to the power lines that supply CR3 with its
10 offsite power. Bringing large quantities of PRB coal onto the site would threaten to
11 interrupt CR3's offsite power in the event of a fire in the arriving barge or on the coal
12 pile to the south of the switchyard, or while being conveyed to the north plant as it
13 passes underneath the transmission line.

14 To make matters worse, the plant depends on emergency diesel generators in
15 the event of a loss of off site power. Significant amounts of smoke coming from a
16 coal pile fire would represent a challenge to the operation of those diesels. They are
17 located on the south east side of the reactor building, only a few hundred yards from
18 where the coal would be stored. Should significant amounts of smoke envelope the
19 diesel building, I would be unable to ensure that the diesels would operate at capacity.
20 Their operating margin is relatively small and any reduction in their ability to produce
21 sufficient power in the event of a loss of offsite power would represent a significant
22 challenge to any review by the Company.

1 Vol. 4. Within that document, the accumulation of dirt and dust within breaker
2 components was cited as one of the most significant contributors to breaker failure.

3 With the introduction of large amounts of powdered coal dust, maintenance
4 costs associated with keeping the nuclear unit clean will increase. As part of the
5 design of nuclear plants certain safety features must utilize redundant trains to ensure
6 the failure of one train does not prevent the successful mitigation of a plant event. In
7 this case, however, all trains of every safety system would be subject to the same
8 challenge. That challenge would be the introduction of large amounts of fine coal
9 dust in the air surrounding the components. This represents a potential common
10 mode failure for a wide array of electrical components. In other words, the potential
11 for a common mode failure would have to be evaluated to determine the effect on the
12 safety system trains. Dust problems like this have been the subject of several
13 information notices, as explained above on page 14.

14 Another potential risk posed by the increased PRB dust is that it is flammable.
15 The PRB dust could settle in the cable trays at CR3, which may increase the risk of a
16 fire in those cable trays. Cable trays hold the power cables and logic circuitry for
17 safety and non-safety components necessary for plant operation. A cable tray fire is
18 extremely dangerous to the safe operation of the plant. A fire in the cable tray could
19 cause extensive damage to the plant.

20
21 **Q. Have any other nuclear plants violated NRC regulations for allowing a common**
22 **mode failure?**

1 A. Yes, in one example, at the Fermi 2 nuclear plant operated by Detroit Edison, the
2 utility failed to recognize the potential for ice to cause a common mode failure of
3 critical cooling water pumps. The utility was found to be in violation of NRC
4 regulations. There are other examples of such common mode failures resulting in
5 NRC violations.

6

7 **Steps to Evaluate Bringing PRB Coal to Crystal River on Long-Term Basis**

8

9 **Q. What steps would PEF have to take to analyze this proposed change, to bring**
10 **significant amounts of PRB coal onto the Crystal River site on a long-term**
11 **basis?**

12 A. A summary of the steps taken by a nuclear plant licensee prior to making a change at
13 the plant can be found in Exhibit No. ___ (JF-8) to my testimony. Each of these steps
14 is discussed in detail below.

15

16 *Step 1: Does the proposed change require a 50.59 analysis?*

17 **Q. What is the first step in the analysis of the proposed change?**

18 A. Any change to the nuclear plant has to be fully evaluated for its potential impact on
19 safety. As part of that review, The Company must consider whether bringing the
20 PRB coal onsite for long-term use is something that needs to be analyzed pursuant to
21 10 C.F.R. 50.59. To decide this question, PEF must decide whether there is a chance
22 that the proposed change will affect any of the safety systems at the plant, or will
23 affect the likelihood or frequency of an accident occurring at the plant. Given the

1 type of hazards presented by PRB coal, the spontaneous combustibility and the
2 increased dustiness, it is my opinion that a 50.59 analysis would be required.

3
4 *Step 2: If a 50.59 analysis is necessary, what does such an evaluation involve?*

5 **Q. Please explain the next step in the process.**

6 **A.** The second step required to analyze a change, if the first step shows that it is
7 necessary, is the 50.59 evaluation. Such an evaluation would be difficult and time
8 consuming. The possible effects of the PRB coal on plant conditions would have to
9 be evaluated and a determination made if this change represented a condition which
10 would represent an “un-reviewed safety question.” In other words, the Company
11 must determine whether the 10 C.F.R. 50.59 test would be met or not. If it was not
12 met, meaning that the proposed use of PRB coal represented more than a minimal
13 increase in risk, then submittal to the NRC would be required. There are at least three
14 areas I believe would have to be analyzed: 1) a potential increase in the likelihood of
15 a loss of offsite power in combination with a potential degradation of the emergency
16 diesels; 2) an additional hazard to control room habitability; and 3) the potential for a
17 common mode failure to critical electrical components.

18
19 **Q. Taking each of these concerns in turn, please explain the risks that fire and
20 smoke would have to CR3’s offsite power.**

21 **A.** As explained above, the CR3 nuclear unit is supplied with offsite power by various
22 transmission lines that connect to the CR3 switchyard. It is important to mention that
23 the reliability of off-site power is one of the most important factors to nuclear safety.

1 The first risk is that all four of these lines cross over the conveyor belts that would
2 transport the PRB coal to the north coal yard. In addition, one of the 230 kV lines
3 comes within about a 100 feet of the north coal yard itself, where OPC alleges that
4 PEF should blend the PRB coal. If a coal fire were to break out in these locations, the
5 resultant fire and smoke could affect the lines and interfere with the supply of power
6 to the CR3 unit.

7 Perhaps the most significant threat to offsite power would be a coal fire that
8 would carry smoke and soot into the switchyard. Industry experience shows that even
9 small fires represent challenges to switchyard components. There are physical
10 connections in the switchyard which act as large scale switches carrying the 230 KV
11 and 500 KV loads. Soot and smoke could cause arc events in a switchyard which
12 could in turn cause the switches to open in a faulted condition. This would result in a
13 loss of offsite power. A similar situation occurred at the Diablo Canyon nuclear
14 power plant when a grass fire erupted near the unit. The dust from that fire caused a
15 loss in offsite power to the plant. The Institute of Nuclear Power Operations, INPO,
16 reported in October of 1982 that there had been six documented forest fires in the
17 preceding 10 years that had resulted in a loss of off site power to the industry. Since
18 that time plants have taken the precaution of preventing and eliminating fire hazards
19 in the vicinity of their offsite power supplies. Undergrowth is controlled near lines
20 and transmission corridors are maintained to significantly reduce the chances of a
21 fire. Bringing PRB coal onto the site would increase the risk of fire and be a
22 hindrance to these efforts to reduce the risk of forest fires interfering with the offsite
23 power supply.

1 In addition, discussed above, this hazard might also challenge the on site
2 emergency diesels. This fact makes this change significantly more complex and
3 risky.

4
5 **Q. How serious is a loss of offsite power to a nuclear facility?**

6 **A.** Losing offsite power is probably one of the worst occurrences that could happen at
7 the unit. If CR3 lost its offsite power, it would have to shut down for several days.
8 The NRC would likely investigate the incident as well. To illustrate, if such an event
9 is caused by unforeseen events like a hurricane, wind storm or wild fire, the response
10 by the NRC would be mild. If it was determined that the fire was caused by actions
11 taken by the Company which created the fire hazard, an NRC special inspection team
12 could be assigned.

13
14 **Q. Regarding the next concern, control room habitability, please explain the risks
15 posed by the characteristics of the PRB coal.**

16 **A.** As I stated previously, the control room staff must remain at the plant under all
17 conditions. This requires a control room envelope which protects them from all
18 potential hazards. For example, there are plants which have large chlorine tank cars
19 stored in the vicinity of the control room ventilation. Their control room ventilation
20 systems are designed to detect and automatically protect the control room staff from
21 the hazard of a tank car failure, which causes a large cloud of chlorine gas. This is
22 done even though these events are very rare. In this case, the likelihood of a coal fire
23 during the life of the plant would be fairly high if PRB coal was used. As such, the

1 engineering staff would have to demonstrate that the toxic smoke from that fire would
2 not represent a significant challenge to the operators. This might be something that
3 can be evaluated, or it might require significant modifications to the systems utilized,
4 similar to those plants with chlorine tank cars.

5
6 **Q. As for the final area of concern, common mode failure, how would this risk be**
7 **analyzed under 50.59?**

8 **A.** As explained above, the increased dustiness of the PRB coal may affect the electrical
9 components in the nuclear plant. This dust increases the risk that safety systems in
10 the unit could experience a common mode failure. The 50.59 analysis would include
11 an evaluation of various ways to control or prevent the dust, such as dust suppression
12 at the coal yard and filters within the nuclear plant. The evaluation would also
13 include an assessment of the amount of risk that a common mode failure of the safety
14 systems would occur, even with the mitigating strategies to control the dust.

15
16 **Q. Have you created a preliminary list of issues that would need to be analyzed and**
17 **resolved pursuant to 10 C.F.R. 50.59?**

18 **A.** Yes, I have created a preliminary list, which is reflected in the attached Exhibit No.
19 ___ (JF-9). This list is an initial assessment of the required analysis. The list may
20 change, however, once the actual evaluations began.

21

22 *Step 3: Does the change pass the 50.59 analysis?*

23 **Q. What is the next step in the overall analysis?**

1 A. PEF must evaluate the results of the 50.59 analysis and determine whether the tests
2 outlined in 10 C.F.R. 50.59 were met or passed. In other words, the Company would
3 have to determine whether there was no more than a minimal increase in risk posed
4 by the PRB coal.

5
6 **Q. What would happen if the Company determined that it passed the 50.59
7 evaluation?**

8 A. The Company would not have to submit a formal application for a license amendment
9 to the NRC. It could bring PRB coal on the site, provided that it made the changes
10 needed for the mitigating strategies that were evaluated (like dust suppression and fire
11 protection). I should note, however, that PEF would be taking the regulatory risk that
12 the NRC could come back and challenge the Company's assessment of the PRB coal
13 hazards.

14
15 ***Step 4: Submittal of License Amendment Application to the NRC***

16 **Q. What is the final step in the analysis of the proposed change?**

17 A. The Company would need to submit a license amendment application if the result of
18 the 50.59 evaluation indicated that the proposed change would result in more than a
19 minimal increase in risk. In other words, if PEF did not "pass" the 50.59 test, a
20 license modification would be required.

21
22 **Q. Would PEF be required to submit a license modification request that analyzed
23 the additional risks posed by the PRB coal?**

1 A. It would take a significant engineering effort to know the answer to that question and
2 fully understand what the potential effects of the PRB coal dust and fire hazard on the
3 electrical components. It could take six months to a year and might require special
4 testing of components. This is not a condition that is well understood by the nuclear
5 industry and we would therefore be treading new ground.

6

7 **Q. Does the fact that, as Mr. Hatt testifies, there are certain actions that can be**
8 **taken to control the risk of fire and suppress the dust, affect your assessment**
9 **whether a license modification would be needed?**

10 A. Again, I cannot say at this point whether these mitigation strategies will be adequate
11 for PEF to avoid having to submit a license amendment application to the NRC.
12 What I can say is that the mitigating actions referred to in Mr. Hatt's testimony would
13 have to be thoroughly evaluated by the Company to determine whether an increased
14 amount of risk is posed by the change. When it comes to nuclear power, you do not
15 roll the dice and take unnecessary risks without completely and fully evaluating those
16 risks, including mitigating strategies to control those risks.

17

18 **Q. What would PEF have to do if it decided it needed to apply for a license**
19 **modification after the 50.59 evaluation?**

20 A. As I have described, the Company must evaluate the additional risks that the hazards
21 of spontaneous combustion and increased dustiness would pose to the nuclear unit.
22 To do this, it must conduct an engineering evaluation of the systems that could be
23 affected by the new risks. This is a long process and it involves analysis from several

1 different angles. For each identifiable effect on the plant, as explained above, the
2 Company must provide detailed analysis regarding the solution it suggests to
3 eliminate or mitigate the problem. In order to evaluate these risks, the Company
4 might have to extensively test and conduct studies to assure that a significant
5 reduction in the identified risk could be achieved by the proposed mitigation measure.
6 Since there is significant experience with PRB coal available in the fossil generation
7 industry, the Company would evaluate that experience to see if an increase in risk is
8 still present with the proposed mitigation strategies.

9 For example, consider the risk that a coal fire on a barge or in the temporary
10 coal staging area could introduce a common mode failure for the emergency diesel
11 generators. Such a fire could envelope the diesel building for some period of time.
12 This is not a simple grass fire, like in the example from the other facility I mentioned
13 earlier, but a significant cloud of soot and hazardous gasses. PEF would have to
14 demonstrate that the diesel generators would be capable of supplying the required
15 electrical loads with this cloud serving as the air supply for the diesels. That would
16 most likely require a demonstration test using a diesel of similar construction and a
17 simulated cloud of smoke. Special filters might have to be installed to address both
18 the smoke challenge to the diesels and the effects of the continuous coal dust. An
19 alternative to this might include compensatory measures. We might have to install
20 additional fire suppression systems near the coal storage and handling locations. We
21 might then also have to permanently staff an independent fire brigade for the coal
22 yard which would have significant regulatory requirements for their training,

1 equipment testing, readiness to respond and ability to quickly extinguish the largest
2 reasonably possible fire.

3 After this special engineering evaluation and modeling, if the change failed
4 the 50.59 test and represented a previously un-reviewed safety question, the Company
5 would submit a license amendment application to the NRC for review. PEF's
6 application would have to include a detailed strategy for mitigating the additional
7 risks posed by the PRB coal. The preparation for a license amendment request of this
8 magnitude would very likely be lengthy considering the number of effects on the
9 plant that would have to be evaluated.

10
11 **Q. Can you give an example of how such a review can lead to plant modifications, at**
12 **CR3?**

13 **A.** Yes, a few years ago during a design review of the generator diesels, plant personnel
14 recognized that exhaust was coming from the muffler of the emergency diesel
15 generator and re-circulating into the generator. This re-circulation only occurred
16 when the wind blew in a particular direction, but the effect was that it increased both
17 the temperature in the room and the combustion gas mixes. This posed a risk to the
18 ability of the generator to maintain rating. Given this situation, PEF undertook a
19 series of tests and analyses to determine whether the exhaust situation could be
20 resolved. The complete analysis took months to complete. A proposed modification
21 to the building structure was designed to separate the diesel intake and exhaust. In
22 order to evaluate the design, the Company built an exact model of the unit, along with
23 an artificial wind tunnel. In the end, the Company was required to build an

1 approximately 10 foot wall in front of the diesels to protect them from the wind. The
2 cost of this capital modification was approximately \$1.7 million.

3

4 **Q. Once the application has been submitted, what happens next?**

5 **A.** The NRC then reviews the application and considers whether the capital modification
6 that PEF has suggested will adequately ensure the safe operation of the plant. Again,
7 given the number of different things to be analyzed, and because PRB coal presents a
8 new type of hazard to the nuclear industry, this would not be a simple evaluation.

9

10 **Q. What standard does the NRC apply when considering a license modification**
11 **such as this?**

12 **A.** The NRC is, first and foremost, concerned with the safety of the nuclear unit. Before
13 a license modification request will be approved, the licensee requesting the
14 amendment must show that the requested change will not create any undue risk to the
15 plant's safety.

16

17 **Q. If PEF could demonstrate that the PRB coal would represent a significant**
18 **savings in coal expenditures, would that impact NRC's decision to issue a license**
19 **modification?**

20 **A.** The price of coal is secondary to safety. The NRC is concerned with maintaining and
21 ensuring the safety of the nuclear unit. To prevent accidents at CR3, the NRC strictly
22 enforces its safety regulations. The focus is on safety.

23

1 **Q. Are there any other nuclear plants in the country that are located on the same**
2 **site as a fossil-fuel unit that is burning PRB, sub-bituminous coal?**

3 **A.** No, there are no other nuclear units located near a coal unit that burns sub-bituminous
4 or PRB coal. In fact, CR3 is one of the few nuclear units located near a coal unit
5 burning bituminous coal.

6
7 **Q. What effect, if any, will the fact that no other nuclear plant is located on the**
8 **same site as a PRB-burning coal plant have on NRC's review of an application**
9 **to amend PEF's license to permit long-term use of PRB coal at CR4 and CR5?**

10 **A.** First, this lack of prior nuclear experience with the risks presented by PRB coal will
11 increase the difficulty and length of PEF's evaluation of the change. In addition, the
12 NRC is likely to review the application even more carefully than it would any other,
13 more routine requests. Without any precedent of another nuclear unit being so close
14 to the handling and burning of PRB coal, the NRC may take an even longer amount
15 of time to evaluate the Company's proposed mitigating strategies and the risk.

16

17 **Q. Does the NRC have any special reaction to the risk of fire?**

18 **A.** Yes, the NRC is very sensitive to fires near and within nuclear plants. There are
19 several regulations, most notably Appendix R to Part 50 of the CFR, which are meant
20 to prevent and mitigate fires. Appendix R and other NRC regulations and guidance
21 constitute a lengthy set of compliance-based requirements that provides details with
22 regard to everything from plant design, cable routing, pre-fire planning, fire
23 mitigation strategies and fire fighting capabilities. In addition, as part of the licensing

1 condition of all plants, including CR3, there must not be a reduction in the
2 effectiveness of the plant's ability to prevent and mitigate fires.

3

4 **Q. To speed up the process, could PEF go ahead and make the capital modifications**
5 **suggested in its license modification application, should one be required?**

6 **A.** No, until the NRC gives its final approval of the license modification, the Company,
7 being prudent, would not make any capital modifications. This is because it is quite
8 possible that the NRC will not approve the application as written and will require
9 additional or different types of capital upgrades.

10

11 **Q. Is it possible that, even with the detailed analysis and evaluation, the PRB coal**
12 **could be determined to be unsafe?**

13 **A.** Yes, because the complete analysis has not been done, it is not clear that the
14 Company could convince itself or the NRC that bringing a significant amount of PRB
15 coal onto the Crystal River site on a long-term basis would be safe. Given the
16 characteristics of the PRB coal, even mitigating strategies may not provide adequate
17 assurance that no undue risk will be created.

18

19 **Q. Even if the NRC would approve the use of PRB at the Crystal River site, would**
20 **you feel comfortable with the coal being near the CR3 nuclear unit?**

21 **A.** Absolutely not. As the plant manager, I am most concerned with safety. Given the
22 risks posed by the volatile PRB coal, I do not want large quantities of it in the vicinity
23 of the CR3 nuclear plant. After what I have heard about this coal I would not propose

1 we go through the process of evaluating the effect of the coal on the design and
2 license basis of the plant.

3
4 **IV. EFFECTS ON CR3 DURING 2006 TEST BURN**

5
6 **Q. Were you working at CR3 during the time May 20-23, 2006, when PEF did a test**
7 **burn of a blend of PRB coal?**

8 **A.** Yes, I was at the plant during that time period.

9
10 **Q. What, if anything, did you notice during this test burn period?**

11 **A.** I and other employees at CR3 noticed a significant increase in the amount of dust at
12 CR3. On Saturday, May 20, when the barge of the PRB coal blend was offloaded,
13 there was a significant and noticeable increase in the amount of coal dust on the floor
14 of the plant. The increased dust was so noticeable that, even after sweeping the floor
15 in the morning, by the afternoon the floor once again had swirling piles of coal dust.

16
17 **Q. Isn't there always some amount of coal dust present at CR3 on a normal basis?**

18 **A.** Yes, but the amount of dust in the plant that day was significantly more than what is
19 usually found at CR3, when bituminous coal is burned and handled at Crystal River.

20
21 **Q. During that time period, was there a particular day on which the dust was**
22 **heaviest?**

1 A. The increased dust was definitely more noticeable when the barge was being
2 offloaded, on May 20, 2006. But the CR3 plant experienced more dust than normally
3 experienced during the entire trial burn, even after the barge was unloaded.

4

5 **Q. Does the increased level of dust at CR3 give you any concern?**

6 A. The amount of dust experienced during this relatively brief trial burn, especially
7 while offloading the barge, gives me a great amount of concern. As explained above,
8 the presence of dust may give rise to a common mode failure of one of CR3's safety
9 systems, and this failure may result in violations of NRC regulations.

10

11 **Q. Do you have an understanding as to the amount of PRB coal that was used**
12 **during the trial burn in May 2006?**

13 A. I understand that an 18% PRB coal, 82% bituminous coal blend was used to conduct
14 the test burn. I further understand that the coal was blended off-site, offloaded from
15 the barge, and sent straight to the CR5 unit.

16

17 **Q. Are you aware that OPC's expert, Mr. Sansom, alleges that PEF should bring in**
18 **100% PRB coal by barge to Crystal River, and blend it on-site with bituminous**
19 **coal before burning it at CR4 and 5?**

20 A. Yes, I am aware that Mr. Sansom advocates bringing in pure PRB coal by barge into
21 Crystal River.

22

1 **Q. Based on what happened at CR3 during the test burn of an 18% PRB blend, do**
2 **you have any additional concerns with PEF offloading and handling pure 100%**
3 **PRB coal?**

4 **A.** Yes, with CR3 being so close to the barge offloader, I am very concerned with the
5 level of dust that a barge of 100% PRB coal will cause in the CR3 nuclear plant. The
6 amount of dust caused by just an 18% blend of PRB coal was alarming enough; the
7 prospect of Crystal River taking in routine barges of 100% pure PRB coal is a major
8 concern. Likewise, the increased dust from the handling and blending of 100% PRB
9 coal is of great concern to PEF's ability to maintain CR3's safety systems.

10
11 **Q. Do the dust suppression and dust collection mechanisms, as described by Mr.**
12 **Hatt in his testimony, address those concerns?**

13 **A.** Not completely. As Mr. Hatt explains, even with the dust suppression and dust
14 collection mechanisms, it is very unlikely that all the dust can be eliminated. In fact,
15 these dust suppression and collection systems are least likely to be effective during
16 offloading. The most dramatic increase of dust was observed during offloading. At a
17 minimum, the dust suppression and dust collection mitigating strategies must be
18 subjected to the rigorous evaluation I explained earlier in my testimony, to ensure that
19 they would effectively limit the risk to an acceptable level.

20
21 **Q. Please explain why it was not necessary for the Company, from a nuclear**
22 **standpoint, to evaluate the decision to bring PRB coal onto the site for the short-**
23 **term test burn.**

1 A. The trial test burn was for a limited period of time, such that the PRB coal was only
2 on the site for a matter of days. The total amount of PRB coal was relatively small.
3 It was also never stored long-term at the site, because it went straight from the barge
4 to the coal unit. In addition, the blend of PRB/bituminous coal that was brought
5 onsite was so low (only 18% PRB) that the effect on the nuclear plant was not
6 substantial enough to require an analysis. However, the decision, to bring in 100%
7 PRB coal for long-term use, storage, on-site blending, and handling, would have to be
8 evaluated as explained above.

9

10 V. FUTURE TEST BURNS

11

12 Q. Are you aware that there may be future, longer-term test burns of PRB or sub-
13 bituminous coal, at Crystal River?

14 A. Yes, I am aware that such trial burns are being considered.

15

16 Q. What, if anything, do you plan to do about these plans?

17 A. Prior to any significant amounts of PRB coal being off loaded at the site, PEF must
18 evaluate the effect of that coal on the nuclear plant and if required, submit to the NRC
19 to seek an operating license modification for CR3. And, as explained above, the
20 review of this type of change is quite lengthy and there is no guaranty that it can be
21 performed without prior approval of the NRC.

22

1 **Q. Why didn't PEF perform such an analysis years ago when Units 4 and 5 first**
2 **were put into service?**

3 **A.** First, the risks associated with PRB coal and fires and flammable PRB coal dust were
4 not fully known or appreciated by the industry in the late 1970s, when Units 4 and 5
5 were sited. So even if the analysis had been performed then, such an analysis would
6 have been incomplete. In addition, Units 4 and 5 never actually burned PRB coal and
7 in fact the Company entered into two long-term contracts for bituminous coal. The
8 NRC evaluation process is so extensive and rigorous, no utility would undertake it
9 unless it was sure that it would ultimately use the PRB coal. In other words, it is not
10 reasonable to do the evaluation, and seek the license modification if necessary, as a
11 "placeholder" on the chance that the coal may be used at the units.

12

13

VI. CONCLUSION

14

15 **Q. Does this conclude your testimony?**

16 **A.** Yes, it does.

17


18


19


20

CRYSTAL RIVER ENERGY COMPLEX


Docket No. 090988
Progress Energy Florida
Exhibit No. (JF-1)
Page 1 of 1















Docket No. 060658
Progress Energy Florida
Exhibit No. _____ (JF-2)
Page 4 of 4









Docket No. 060658
Progress Energy Florida
Exhibit No. _____ (JF-3)
Page 4 of 9





Miller

01












Docket No. 060658
Progress Energy Florida
Exhibit No. (JF-3)
Page 8 of 9






Docket No. 090988
Progress Energy Florida
Exhibit No. ____ (JF-5)
Page 1 of 1










Analysis of Steps Taken to Evaluate Proposed Change at Nuclear Facility



Potential Affects to Electrical Equipment at CR-3 from use of Powder River Basin Coal

Problem	Dust	Fire/ Smoke
<p>Control Room Emergency Ventilation System --- Ability to detect and isolate for Control Room Habitability.</p> <p>Noxious gas monitors may need to be added. Leakage values may have to be improved, depending on any hazardous gasses present.</p>	X	X
<p>Potential Risk to Off-Site Power Reliability</p> <p>Dust and smoke from coal fires would increase the likelihood of a loss of off site power. Potential fire beneath off site power transmission lines. Increased maintenance to prevent or mitigate the effects of a fire.</p>	X	X
<p>Potential Common Mode Failure risk to instrumentation and breakers</p> <p>Dust intrusion would challenge safety system electrical equipment.</p>	X	X
<p>Potential impacts on Nuclear Safety</p> <p>Would the pile be a target set for terrorists. Ability to detect and engage adversary forces through smoke of a large fire set by the adversaries.</p>		X
<p>MET Tower instrumentation degradation due to dust</p> <p>Back up MET Tower located near U1 / U2 Coal Yard.</p>	X	
<p>Reliability of safety and non-safety motors</p> <p>Dust sticking to windings and fans in electric motors - This is a long term issue</p>	X	

Problem	Dust	Fire/ Smoke
<p>Motors out on the waterfront would be especially susceptible.</p> <p>Radiation Monitors in the Turbine Bldg.</p> <p>Potential effect on monitors requiring change in equipment.</p>	X	
<p>Ventilation Filters for various buildings may not filter smaller particulate.</p>	X	
<p>Any open fuel and lube oil systems will have increased dirt in them which may result in unplanned impact on plant safety system operability</p>	X	
<p>Vented tanks (ie: fire service) will have increased dirt in the system which may result in unplanned impact on plant safety system operability</p>	X	
<p>Emergency Vehicle Access</p> <p>Conveyor belt fire could restrict access to the nuclear plant by blocking the only road into the site, which may impair the ability of emergency vehicles to enter the site</p>		X