

Docket No. 060368-WS

Application to Increase Rates and Charges
For a "Class A" Utility
In

Florida

VOLUME 6

Book 5A

Containing
Additional Engineering Requirements

Sanitary Survey Water

CMP _____
COM _____
CTR _____
ECR _____
GCL _____
OPC _____
RCA _____
SCR _____
SGA _____
SEC _____
OTH _____

Aqua Utilities Florida, Inc.

Aqua Utilities Florida, Inc.
Sanitary Survey Reports
Water Systems

Book 5

<u>Name of System</u>	<u>Page Number</u>
48 Estates	3
Arredondo Estates	8
Arredondo Farms	14
Beecher's Point	20
Carlton Village	23
Chhuluota	27
East Lake Harris Estates	42
Fern Terrace	46
Friendly Center	50
Gibsonia Estates	54
Grand Terrace	56
Haines Creek	60
Harmony Homes	65
Hermits Cove	66
Hobby Hills	72
Holiday Haven	76
Imperial Mobile Terrace	80
Interlachen Lake/Park Manor	84
Jasmine Lakes	90
Jungle Den	92
Kings Cove	96
Kingswood	101
Lake Gibson Estates	102
Lake Josephine	104
Lake Osborne Estates	111
Leisure Lakes	112
Morningview	124
Oakwood	128
Ocala Oaks	129
Orange Hill/Sugar Creek	133
Palm Port	135

Docket No. 060368-WS

Application to Increase Rates and Charges

For a "Class A" Utility
In

Florida

Missing Report: Sanitary Survey Report

For: Palm Terrace

Aqua Utilities Florida, Inc.

Docket No. 060368-WS

Application to Increase Rates and Charges

For a "Class A" Utility
In

Florida

Missing Report: Sanitary Survey Report

For: Palms MHP

Aqua Utilities Florida, Inc.

State of Florida
Department of Environmental Protection
Central District
SANITARY SURVEY REPORT

Plant Name PICCIOLA ISLAND SUBDIVISION County Lake PWS ID # 3351009
Plant Location 05133 Albert Road, Fruitland Park Phone 352/787-0980
Owner Name Florida Water Services, Attn: Craig Anderson Phone 407/880-0058
Owner Address P.O. Box 609520, Orlando, FL 32860
Contact Person Will Fontaine Title Lead Operator Phone 352/787-0980
This Survey Date 4/29/04 Last Survey Date 10/3/01 Last C.I. Date 8/24/99

PWS TYPE & CLASS

- Community (5D)
- Non-transient Non-community
- Non-Community

PWS STATUS

- Approved system with approval number & date
HRS #3049, 12/15/58, WC35-192656 iss 3/7/91
WC35-214487, 6/29/92
- Unapproved system

SERVICE AREA CHARACTERISTICS

Subdivision _____

Food Service: Yes No N/A

OPERATION & MAINTENANCE

Certified Operator: Yes No Not required
Operator(s) & Certification Class-Number
B. Heath C-5824, W. Fontaine C-6813, J. Worrell
C-6597, G. Kissick C-7846

O & M Log: Yes No Not required

Operator Visitation Frequency
Hrs/day: Required _____ Actual _____
Days/wk: Required 3 Actual 5
Non-consecutive Days? Yes No N/A
MORs submitted regularly? Yes No N/A
Data missing from MORs? No Yes N/A

Number of Service Connections 137
Population Served 480 Basis per MOR
Average Day (from MORs) 33,642 gpd
Max. Day (from MORs) .0668 MGD 4/03
Max-day Design Capacity .198 MGD
Comments _____

COMET: SITE ID _____ PROJECT ID _____

RAW WATER SOURCE

- GROUND; Number of Wells 2
- SURFACE/UDI; Source _____
- PURCHASED from PWS ID # _____
- Emergency Water Source _____
Emergency Water Capacity _____

AUXILIARY POWER SOURCE

Yes None Not Required
Source Katolight Generator
Capacity of Standby (kW) 45
Switchover: Automatic Manual
Standby Plan: Yes No
Hrs Operated Under Load 4 hrs/mo.

What equipment does it operate?
 Well pumps All
 High Service Pumps _____
 Treatment Equipment All
Satisfy 1/2 max-day demand? Yes No Unk
Comments _____

TREATMENT PROCESSES IN USE

Chlorination
What additional treatment is needed?
For control of what deficiencies?

DISTRIBUTION SYSTEM

Flow Measuring Device Flow Meter
Meter Size & Type 4" McCrometer on each well
Backflow Prevention Devices: Yes No
Cross-connections None observed
Written Cross-connection Control Program: Yes
Coliform Sampling Plan: Yes No N/A
Comments _____

Received

MAY 12 2004

PWS ID # 3351009
 Date 5/6/04

GROUND WATER SOURCE

Well Number	1	2		
Year Drilled	1950	1959		
Depth Drilled	175'	164'		
Drilling Method	UNK	UNK		
Type of Grout	UNK	UNK		
Static Water Level	UNK	UNK		
Pumping Water Level	UNK	UNK		
Design Well Yield	UNK	UNK		
Test Yield	UNK	UNK		
Actual Yield (if different than rated capacity)	UNK	UNK		
Strainer	UNK	UNK		
Length (outside casing)	UNK	UNK		
Diameter (outside casing)	6"	6"		
Material (outside casing)	Black Steel	Black Steel		
Well Contamination History	None noted	None noted		
Is inundation of well possible?	No	No		
6' X 6' X 4" Concrete Pad	Yes	Yes		
SET BACKS	Septic Tank	200'	130'*	
	Reuse Water	--	--	
	WW Plumbing	>100'	>100'	
	Other Sanitary Hazard	None observed	None observed	
PUMP	Type	Vert. Turbine	Submersible	
	Manufacturer Name	Sta-rite	Goulds	
	Model Number	UNK	225H10-3	
	Rated Capacity (gpm)	100	175	
	Motor Horsepower	7.5	10	
Well casing 12" above grade?	Yes	No-Accepted		
Well Casing Sanitary Seal	Yes	Yes		
Raw Water Sampling Tap	Yes	Yes		
Above Ground Check Valve	Yes	Yes		
Fence/Housing	Yes	Yes		
Well Vent Protection	--	--		

COMMENTS Provide additional information for "UNK", if available.

*Set back distance accepted.

PWS ID # 3351009
 Date 5/6/04

CHLORINATION (Disinfection)

Type: Gas Hypo
 Make Chem-tech Capacity 15 gpd
 Chlorine Feed Rate 50% stroke rate
 Avg. Amount of Cl₂ gas used N/A
 Chlorine Residuals: Plant 1.1 Remote .8
 Remote tap location 33436 Picciola Drive
 DPD Test Kit: On-site With operator
 None Not Used Daily
 Injection Points Prior to H/1 & By-pass
 Booster Pump Info _____
 Comments _____

STORAGE FACILITIES

(G) Ground (H) Hydropneumatic (E) Elevated
 (B) Bladder (C) Clearwell

Tank Type/Number	H/1		
Capacity (gal)	5,000		
Material	Steel		
Gravity Drain	Yes		
By-pass Piping	Yes		
Pressure Gauge	Yes		
Sight Glass or Level Indicator	Yes		
Fittings for Sight Glass	Yes		
Protected Openings	Yes		
PRV/ARV	PRV		
On/Off Pressure	40/60		
Access Padlocked	Yes		
Height to Bottom of Elevated Tank			
Height to Max. Water Level			

Comments _____

Chlorine Gas Use Requirements	YES	NO	Comments
Dual System	<input type="checkbox"/>	<input type="checkbox"/>	
Auto-switchover	<input type="checkbox"/>	<input type="checkbox"/>	
Alarms:			
Loss of Cl ₂ capability	<input type="checkbox"/>	<input type="checkbox"/>	
Loss of Cl ₂ residual	<input type="checkbox"/>	<input type="checkbox"/>	
Cl ₂ leak detection	<input type="checkbox"/>	<input type="checkbox"/>	
Scale	<input type="checkbox"/>	<input type="checkbox"/>	
Chained Cylinders	<input type="checkbox"/>	<input type="checkbox"/>	
Reserve Supply	<input type="checkbox"/>	<input type="checkbox"/>	
Adequate Air-pak	<input type="checkbox"/>	<input type="checkbox"/>	
Sign of Leaks	<input type="checkbox"/>	<input type="checkbox"/>	
Fresh Ammonia	<input type="checkbox"/>	<input type="checkbox"/>	
Ventilation	<input type="checkbox"/>	<input type="checkbox"/>	
Room Lighting	<input type="checkbox"/>	<input type="checkbox"/>	
Warning Signs	<input type="checkbox"/>	<input type="checkbox"/>	
Repair Kits	<input type="checkbox"/>	<input type="checkbox"/>	
Fitted Wrench	<input type="checkbox"/>	<input type="checkbox"/>	
Housing/Protection	<input type="checkbox"/>	<input type="checkbox"/>	

AERATION (Gases, Fe, & Mn Removal)

Type _____ Capacity _____
 Aerator Condition _____
 Bloodworm Presence _____
 Visible Algae Growth _____
 Protective Screen Condition _____
 Comments _____

HIGH SERVICE PUMPS

Pump Number			
Type			
Make			
Model			
Capacity (gpm)			
Motor HP			
Date Installed			
Maintenance			

Comments _____

PWS ID # 3351009
Date 5/6/04

MONITORING VIOLATIONS	MCL VIOLATIONS

DEFICIENCIES:

No deficiencies at the time of the inspection. Overall, the plant looked good.

Inspector *K. J. ...* Title Env. Specialist I Date 5/6/04Approved by *Roberto C. ...* Title Env. Manager Date 5/6/04

State of Florida
Department of Environmental Protection
Central District
SANITARY SURVEY REPORT
PLANT #1

Plant Name PINEY WOODS S/D County Lake PWS ID # 3351021-01
Plant Location 2013 Spring Lake Road, Fruitland Park Phone 352/787-0980
Owner Name Florida Water Services, Attn: Craig Anderson Phone 407/880-0058
Owner Address P.O. Box 609520, Orlando, FL 32860
Contact Person Will Fontaine Title Lead Operator Phone 352/787-0980
This Survey Date 4/29/04 Last Survey Date 10/3/01 Last C.I. Date 8/24/99

PWS TYPE & CLASS

- Community (4C)
- Non-transient Non-community
- Non-Community

PWS STATUS

- Approved system with approval number & date
HRS #4695, 1/31/61, As-built 11/6/73,
HRS #B-4695-B, 5/23/75, WC35-275708, 9/7/95
WC35-0080519, 1/15/99
- Unapproved system

SERVICE AREA CHARACTERISTICS

Subdivision _____

Food Service: Yes No N/A

OPERATION & MAINTENANCE

Certified Operator: Yes No Not required
Operator(s) & Certification Class-Number
B. Heath C-5824, W. Fontaine C-6813, J. Worrell
C-6597, G. Kissick C-7846, M. Ponticelli C-8450
O & M Log: Yes No Not required
Operator Visitation Frequency
Hrs/day: Required _____ Actual _____
Days/wk: Required 6 Actual 6
Non-consecutive Days? Yes No N/A
MORs submitted regularly? Yes No N/A
Data missing from MORs? No Yes N/A

Number of Service Connections 171*
Population Served 596* Basis per MOR
Average Day (from MORs) 46,776 gpd
Max. Day (from MORs) .086 MGD 5/03
Max-day Design Capacity .216 MGD
Comments *Combined total for both plants.
Combined Max-day Design Capacity for both plants
is .316 MGD.

COMET: SITE ID _____ PROJECT ID _____

RAW WATER SOURCE

- GROUND; Number of Wells 1
- SURFACE/UDI; Source _____
- PURCHASED from PWS ID # _____
- Emergency Water Source Spring Lake
Emergency Water Capacity .1008 MGD

AUXILIARY POWER SOURCE

- Yes None Not Required
- Source Katolight generator (propane)
- Capacity of Standby (kW) 45
- Switchover: Automatic Manual
- Standby Plan: Yes No
- Hrs Operated Under Load 1 hr/wk.
- What equipment does it operate?
 Well pumps All
 High Service Pumps All
 Treatment Equipment All
- Satisfy 1/2 max-day demand? Yes No Unk
- Comments Interconnected with Spring Lake WTP.

TREATMENT PROCESSES IN USE

Chlorination
Aeration
What additional treatment is needed?

For control of what deficiencies?

DISTRIBUTION SYSTEM

Flow Measuring Device Flow Meter
Meter Size & Type 6" Precision
Backflow Prevention Devices: Yes No
Cross-connections None observed
Written Cross-connection Control Program: Yes
Coliform Sampling Plan: Yes No N/A
Comments Interconnected with Spring Lake WTP.

Received

MAY 12 2004

PWS ID # 3351021-01Date 5/6/04**GROUND WATER SOURCE**

Well Number	1		
Year Drilled	UNK		
Depth Drilled	480"		
Drilling Method	UNK		
Type of Grout	UNK		
Static Water Level	UNK		
Pumping Water Level	UNK		
Design Well Yield	UNK		
Test Yield	UNK		
Actual Yield (if different than rated capacity)	UNK		
Strainer	UNK		
Length (outside casing)	180'		
Diameter (outside casing)	6"		
Material (outside casing)	Black Steel		
Well Contamination History	Some		
Is inundation of well possible?	No		
6' X 6' X 4" Concrete Pad	Yes		
SET BACKS	Septic Tank	<100' Accepted	
	Reuse Water	--	
	WW Plumbing	>100'	
	Other Sanitary Hazard	None observed	
PUMP	Type	Vert. Turbine	
	Manufacturer Name	Worthington	
	Model Number	UNK	
	Rated Capacity (gpm)	300	
	Motor Horsepower	15	
Well casing 12" above grade?	Yes		
Well Casing Sanitary Seal	Yes		
Raw Water Sampling Tap	Yes		
Above Ground Check Valve	Yes		
Fence/Housing	Yes		
Well Vent Protection	Yes		

COMMENTS Provide additional information for "UNK", if available.

PWS ID # 3351021-01
 Date 5/6/04

CHLORINATION (Disinfection)

Type: Gas Hypo
 Make Chem-tech Capacity * gpd
 Chlorine Feed Rate 50% stroke rate
 Avg. Amount of Cl₂ gas used N/A
 Chlorine Residuals: Plant 1.3 Remote 1.0
 Remote tap location Toby & Hickory hosebibb
 DPD Test Kit: On-site With operator
 None Not Used Daily
 Injection Points Prior to Aerator.
 Booster Pump Info
 Comments * 2 - 30 gpd chlorinators

STORAGE FACILITIES

(G) Ground (H) Hydropneumatic (E) Elevated
 (B) Bladder (C) Clearwell

Tank Type/Number	G/1	H/2	
Capacity (gal)	50,000	5,000	
Material	Steel	Steel	
Gravity Drain	Yes	Yes	
By-pass Piping	Yes	Yes	
Pressure Gauge	N/A	Yes	
Sight Glass or Level Indicator	Yes	Yes	
Fittings for Sight Glass	N/A	Yes	
Protected Openings	Yes	Yes	
PRV/ARV	N/A	PRV	
On/Off Pressure		40/60	
Access Padlocked	Yes	Yes	
Height to Bottom of Elevated Tank			
Height to Max. Water Level			

Comments

Chlorine Gas Use Requirements	YES	NO	Comments
Dual System	<input type="checkbox"/>	<input type="checkbox"/>	
Auto-switchover	<input type="checkbox"/>	<input type="checkbox"/>	
Alarms:			
Loss of Cl ₂ capability	<input type="checkbox"/>	<input type="checkbox"/>	
Loss of Cl ₂ residual	<input type="checkbox"/>	<input type="checkbox"/>	
Cl ₂ leak detection	<input type="checkbox"/>	<input type="checkbox"/>	
Scale	<input type="checkbox"/>	<input type="checkbox"/>	
Chained Cylinders	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Reserve Supply	<input type="checkbox"/>	<input type="checkbox"/>	
Adequate Air-pak	<input type="checkbox"/>	<input type="checkbox"/>	
Sign of Leaks	<input type="checkbox"/>	<input type="checkbox"/>	
Fresh Ammonia	<input type="checkbox"/>	<input type="checkbox"/>	
Ventilation	<input type="checkbox"/>	<input type="checkbox"/>	
Room Lighting	<input type="checkbox"/>	<input type="checkbox"/>	
Warning Signs	<input type="checkbox"/>	<input type="checkbox"/>	
Repair Kits	<input type="checkbox"/>	<input type="checkbox"/>	
Fitted Wrench	<input type="checkbox"/>	<input type="checkbox"/>	
Housing/Protection	<input type="checkbox"/>	<input type="checkbox"/>	

AERATION (Gases, Fe, & Mn Removal)

Type Natural Draft Capacity 650 gpm
 Aerator Condition Good
 Bloodworm Presence None
 Visible Algae Growth None
 Protective Screen Condition Good
 Comments

HIGH SERVICE PUMPS

Pump Number	1		
Type	Centrif.		
Make	*		
Model	UNK		
Capacity (gpm)	300		
Motor HP	20		
Date Installed	UNK		
Maintenance	UNK		



Comments *Worthington

PWS ID # 3351021-01
 Date 5/6/04

MONITORING VIOLATIONS	MCL VIOLATIONS

DEFICIENCIES:

No deficiencies at the time of the inspection. Overall, the plant looked good.

Inspector  Title Env. Specialist I Date 5/6/04
 Approved by  Title Env. Manager Date 5/07/04



Jeb Bush
Governor

Department of Environmental Protection

Northeast District
7825 Baymeadows Way, Suite B200
Jacksonville, Florida 32256-7590

David B. Struhs
Secretary

March 5, 2004

Mr. Craig Anderson
Florida Water Services
Post Office Box 609520
Orlando, Florida 32860

Received

MAR 10 2004

Dear Mr. Anderson:

Environmental Services

Putnam County - Potable Water
Pomona Park WTP
PWS ID: 2540905

On March 3, 2004 a Sanitary Survey inspection of the referenced community water system was conducted with the courteous assistance of Mr. Paul Thompson and Mr. Donald Holcomb of Florida Water Services. I was pleased to find that the water system is in good operating condition and generally well maintained. Based on this survey and our records, the Department is pleased to inform you that the above referenced facility is in compliance with the Florida Safe Drinking Water Act, Sections 403, Florida Statutes (FS), and the rules promulgated there-under, Florida Administrative Code (FAC) Title 62.

A copy of the sanitary survey report is enclosed for your records. If I may be of further assistance to you, please contact me by e-mail at Annalise.Stahlman@dep.state.fl.us or by telephone at (904) 807-3335. Thank you for your cooperation with Florida's Safe Drinking Water Act.

Sincerely:

Annalise M. Stahlman
Environmental Specialist

AMS
EDC:BRK:AMS:ams
Correspondence File

Enclosure: Sanitary Survey Dated 3/3/04

"More Protection, Less Process"

Printed on recycled paper.

State of Florida
 Department of Environmental Protection
 Northeast District
SANITARY SURVEY REPORT

Plant Name POMONA PARK WTP County Putnam PWS ID # 2540905
 Plant Location Church Street, Pomona Park, Florida 32181 Phone 386-329-1122
 Owner Name Florida Water Services (Attn: Mr. Craig Anderson) Phone 407-880-0058
 Owner Address Post Office Box 609520, Orlando, Florida 32860
 Contact Person Mr. Paul Thompson Title Lead Operator, FWS Phone 386-329-1122
 This Survey Date 3/3/04 Last Survey Date 6/18/01 Last C.I. Date 8/1/02

PWS TYPE & CLASS: Community - (4C)

SERVICE AREA CHARACTERISTICS

Municipality _____

Food Service: Yes No N/A

GENERAL INFORMATION

Number of Service Connections 191
 Population Served 475 Basis approximation
 Plant Design Capacity 170,000 gpd
 Basis well capacity
 Average Day (from MORs) 39,068 gpd
 Max. Day (from MORs) 72,000 gpd
 Total Storage Capacity 3,000 gallons
 Comments based on January 2004 MOR data

LOCATION

Latitude 29° 29' 44.68" North
 Longitude 81° 35' 45.27" West
 GPS: Yes Date: 7/17/97
 Directions US 17 south, right on Main St., left at Church Street, Plant is on the left

OPERATION & MAINTENANCE

Certified Operator: Yes No Not required
 Operator(s) & Certification Class-Number
Paul Thompson, A-7251
Donald Holcomb, A-5091
 O & M Log: Yes No Not required
 Operator Visitation Frequency
 Hrs/day: Required N/A Actual N/A
 Days/wk: Required 2 Actual 5
 Non-consecutive Days? Yes No N/A
 MORs submitted regularly? Yes No N/A
 Data missing from MORs? No Yes N/A
complete operations, equipment, & maintenance logs and sampling plans on site.

COMET: SITE ID _____ PROJECT ID _____

RAW WATER SOURCE

GROUND; Number of Wells 2
 SURFACE/UDI; Source _____
 PURCHASED from PWS ID # _____
 Emergency Water Source _____
 Emergency Water Capacity _____

AUXILIARY POWER SOURCE

Yes None Not Required
 Source Onan Generator (natural gas fuel)
 Capacity of Standby (kW) 30
 Switchover: Automatic Manual
 Standby Plan: Yes No
 Hrs Operated Under Load 4 hrs/mo.

What equipment does it operate?

Well pumps _____
 High Service Pumps _____
 Treatment Equipment _____

Satisfy 1/2 max-day demand? Yes No Unk

Comments Satisfactory

TREATMENT PROCESSES IN USE

Hypo-chlorination

What additional treatment is needed?

None

For control of what deficiencies?

N/A

DISTRIBUTION SYSTEM

Flow Measuring Device Flow Meter
 Meter Size & Type 4" Neptune Meter
 Backflow Prevention Devices: Yes No
 Cross-connections none noted
 Written Cross-connection Control Program: Yes
 Coliform Sampling Plan: Yes No N/A
 Comments Satisfactory

PWS ID # 2540905
 Survey Date 3-Mar-04

GROUND WATER SOURCE

Well Number (PWS Identification)	2540905	2540905	
Well Name (System Identification)	1	2	
Year Drilled	1952	1962	
Depth Drilled	180'	180'	
Latitude	29:29:44.68 N	29:29:44.54 N	
Longitude	81:35:45.27 W	81:35:45.26 W	
GPS (Y or N) / Date (if applicable)	Yes, 7/16/97	Yes, 7/16/97	
Florida Well ID	AAC1868	AAC1867	
Static Water Level	28'	28'	
Actual Yield (if different than rated capacity)			
Strainer	Unknown	Unknown	
Length (outside casing)	126'	126'	
Diameter (outside casing)	4"	4"	
Material (outside casing)	Steel	Steel	
Well Contamination History	None	None	
Is Inundation of well possible?	No	No	
6' X 6' X 4" Concrete Pad	OK	OK	
SET BACKS	Septic Tank	Appx. 150'	Appx. 150'
	Reuse Water		
	WW Plumbing		
	Other Sanitary Hazard		
PUMP	Type	Submersible	Submersible
	Manufacturer Name	Unknown	Sta-Rite
	Model Number	Unknown	Unknown
	Rated Capacity (gpm)		
	Motor Horsepower	5	5
Well casing 12" above grade?	Yes	Yes	
Well Casing Sanitary Seal	OK	OK	
Raw Water Sampling Tap	OK - smooth	OK - smooth	
Above Ground Check Valve	OK	OK	
Fence/Housing	Secure	Secure	
Well Vent Protection	OK -screened	OK - screened	

COMMENTS The wells appear to be in good operating condition.

PWS ID # 2540905
 Survey Date 3-Mar-04

CHLORINATION (Disinfection)

Type: Hypo-Chlorination
 Make Stenner Capacity 17 gpd
 Chlorine Feed Rate 30%
 Avg. Amount of Cl₂ gas used N/A
 Chlorine Residuals: Plant 2.8 Remote 2.8
 Remote tap location _____
 DPD Test Kit: On-site With operator
 None Not Used Daily
 Injection Points upstream of hydro tank
 Booster Pump Info N/A
 Comments Satisfactory

Chlorine Gas Use Requirements	YES	NO	Comments
Dual System	<input type="checkbox"/>	<input type="checkbox"/>	
Auto-switchover	<input type="checkbox"/>	<input type="checkbox"/>	
Alarms:			
Loss of Cl ₂ capability	<input type="checkbox"/>	<input type="checkbox"/>	
Loss of Cl ₂ residual	<input type="checkbox"/>	<input type="checkbox"/>	
Cl ₂ leak detection	<input type="checkbox"/>	<input type="checkbox"/>	
Scale	<input type="checkbox"/>	<input type="checkbox"/>	
Chained Cylinders	<input type="checkbox"/>	<input type="checkbox"/>	
Reserve Supply	<input type="checkbox"/>	<input type="checkbox"/>	
Adequate Air-pak	<input type="checkbox"/>	<input type="checkbox"/>	
Sign of Leaks	<input type="checkbox"/>	<input type="checkbox"/>	
Fresh Ammonia	<input type="checkbox"/>	<input type="checkbox"/>	
Ventilation	<input type="checkbox"/>	<input type="checkbox"/>	
Room Lighting	<input type="checkbox"/>	<input type="checkbox"/>	
Warning Signs	<input type="checkbox"/>	<input type="checkbox"/>	
Repair Kits	<input type="checkbox"/>	<input type="checkbox"/>	
Fitted Wrench	<input type="checkbox"/>	<input type="checkbox"/>	
Housing/Protection	<input type="checkbox"/>	<input type="checkbox"/>	

AERATION (Gases, Fe, & Mn Removal)

Type _____ Capacity _____
 Aerator Condition _____
 Bloodworm Presence _____
 Visible Algae Growth _____
 Protective Screen Condition _____
 Comments Not Required

STORAGE FACILITIES

(G) Ground (H) Hydropneumatic (E) Elevated
 (B) Bladder (C) Clearwell

Tank Type/Number	H		
Capacity (gal)	5000		
Material	Steel		
Gravity Drain	Yes		
By-pass Piping	Yes		
Pressure Gauge	Yes		
Sight Glass or Level Indicator	Yes		
Fittings for Sight Glass	Yes		
Protected Openings	Yes		
PRV/ARV	PRV		
On/Off Pressure	60/70		
Access Padlocked	Yes		
Height to Bottom of Elevated Tank	N/A		
Height to Max. Water Level	N/A		

Comments Tank appears to be in good condition.

HIGH SERVICE PUMPS

Pump Number			
Type			
Make			
Model			
Capacity (gpm)			
Motor HP			
Date Installed			
Maintenance			


Comments _____

PWS ID # 2540905
 Survey Date 3-Mar-04

COMPLIANCE MONITORING COMMUNITY PUBLIC WATER SYSTEMS serving < 3300 persons			
CONTAMINANT	Last Sampled	Due Date	COMMENTS
Microbiological (Bacti)	xxxxxxx	Monthly	2 distribution samples + 1 from each raw source (based upon population served)
Volatile Organic Contaminants	2003	2006	Samples due every 3 years
Synthetic Organic Contaminants	2003	<u>2006</u>	Samples due every 3 years
Nitrate & Nitrite (as N)	2003	<u>2004</u>	Nitrate / Nitrite due annually
Inorganic Contaminants	2003	<u>2006</u>	Samples due every 3 years
Asbestos	Waiver	Waiver expires 12/31/2010	Samples taken from distribution. Waiver available if no asbestos pipe in the distribution system.
Secondary Standards	2003	<u>2006</u>	Samples due every 3 years
Radionuclides	2003	<u>2006</u>	Samples due every 3 years
Disinfection Byproducts (i.e. Total Trihalomethanes (TTHMs) and Haloacetic Acids (HAA5s));	N/A	<u>2004</u>	Per sampling plan
Lead and Copper	2002	<u>2005</u>	Sample locations are from pre-approved sample plan

Unless otherwise noted, all samples shall be taken at each entry point to the distribution system, and representative of each source after treatment.

SCHEMATIC:



PWS ID # 2540905
Survey Date 3-Mar-04

MONITORING VIOLATIONS	MCL VIOLATIONS
None	None

DEFICIENCIES:

This facility was well maintained and appeared to be in good operating condition. This system is in compliance with the Florida Safe Drinking Water Act.

Inspector Annalise Stahlman Title Environmental Specialist II Date 3/5/04
Annalise M. Stahlman

Approved by Blanca R. Rodriguez Title Engineer IV Date 3/8/04
Blanca R. Rodriguez

State of Florida
Department of Environmental Protection
Central District
SANITARY SURVEY REPORT

Plant Name QUAIL RIDGE ESTATES County Lake PWS ID # 3354867
Plant Location 33713 Quail Ridge Circle, Leesburg Phone 352/787-0980
Owner Name Florida Water Services, Attn: Craig Anderson Phone 407/880-0058
Owner Address P.O. Box 609520, Orlando, FL 32860
Contact Person Will Fontaine Title Lead Operator Phone 352/787-0980
This Survey Date 4/28/04 Last Survey Date 10/3/01 Last C.I. Date 8/24/99

PWS TYPE & CLASS

- Community (5C)
- Non-transient Non-community
- Non-Community

PWS STATUS

- Approved system with approval number & date
WC35-178565, 6/5/90, cleared 12/5/90
- Unapproved system

SERVICE AREA CHARACTERISTICS

Residential - MHP
Food Service: Yes No N/A

OPERATION & MAINTENANCE

Certified Operator: Yes No Not required
Operator(s) & Certification Class-Number
B. Heath C-5824, W. Fontaine C-6813, J. Worrell
C-6597, G. Kissick C-7846
O & M Log: Yes No Not required
Operator Visitation Frequency
Hrs/day: Required _____ Actual _____
Days/wk: Required 3 Actual 6
Non-consecutive Days? Yes No N/A
MORs submitted regularly? Yes No N/A
Data missing from MORs? No Yes N/A

Number of Service Connections 64
Population Served 160 Basis per MOR
Average Day (from MORs) 13,618 gpd
Max. Day (from MORs) .028 MGD/7/03
Max-day Design Capacity .468 MGD
Comments _____

COMET: SITE ID _____ PROJECT ID _____

RAW WATER SOURCE

- GROUND; Number of Wells 1
- SURFACE/UDI; Source _____
- PURCHASED from PWS ID # _____
- Emergency Water Source _____
Emergency Water Capacity _____

AUXILIARY POWER SOURCE

- Yes None Not Required
- Source _____
- Capacity of Standby (kW) _____
- Switchover: Automatic Manual
- Standby Plan: Yes No
- Hrs Operated Under Load _____
- What equipment does it operate?
 - Well pumps _____
 - High Service Pumps _____
 - Treatment Equipment _____
- Satisfy 1/2 max-day demand? Yes No Unk
- Comments _____

TREATMENT PROCESSES IN USE

Chlorination
What additional treatment is needed?
For control of what deficiencies?

DISTRIBUTION SYSTEM

Flow Measuring Device Flow Meter
Meter Size & Type 8" Water Specialities 1000 gpm
Backflow Prevention Devices: Yes No
Cross-connections None observed
Written Cross-connection Control Program: Yes
Coliform Sampling Plan: Yes No N/A
Comments _____

Received

MAY 12 2004

Environmental Services

PWS ID # 3354867Date 5/6/04**GROUND WATER SOURCE**

Well Number	1		
Year Drilled	1989		
Depth Drilled	340'		
Drilling Method	Rotary Combo		
Type of Grout	Neat Cement		
Static Water Level	62'		
Pumping Water Level	UNK		
Design Well Yield	UNK		
Test Yield	UNK		
Actual Yield (if different than rated capacity)	UNK		
Strainer	UNK		
Length (outside casing)	131'		
Diameter (outside casing)	10"		
Material (outside casing)	Black Steel		
Well Contamination History	Some		
Is inundation of well possible?	No		
6' X 6' X 4" Concrete Pad	Yes		
SET BACKS	Septic Tank	>200'	
	Reuse Water	--	
	WW Plumbing	--	
	Other Sanitary Hazard	None observed	
PUMP	Type	Vert. Turbine	
	Manufacturer Name	Goulds	
	Model Number	10RJHO-6	
	Rated Capacity (gpm)	650	
	Motor Horsepower	60	
Well casing 12" above grade?	Yes		
Well Casing Sanitary Seal	Yes		
Raw Water Sampling Tap	Yes		
Above Ground Check Valve	Yes		
Fence/Housing	Yes		
Well Vent Protection	Yes		

COMMENTS Provide additional information for "UNK", if available.

PWS ID # 3354867
 Date 5/6/04

CHLORINATION (Disinfection)

Type: Gas Hypo
 Make Chem-tech Capacity 60* gpd
 Chlorine Feed Rate @ 70% stroke rate
 Avg. Amount of Cl₂ gas used N/A
 Chlorine Residuals: Plant 1.0 Remote 0.9
 Remote tap location Fire hydrant **
 DPD Test Kit: On-site With operator
 None Not Used Daily
 Injection Points Prior to H/1 & by-pass
 Booster Pump Info _____
 Comments *2-30 gpd hypochlorinators.
**Corner of Bob white blvd. and Quail ridge.

Chlorine Gas Use Requirements	YES	NO	Comments
Dual System	<input type="checkbox"/>	<input type="checkbox"/>	
Auto-switchover	<input type="checkbox"/>	<input type="checkbox"/>	
Alarms:			
Loss of Cl ₂ capability	<input type="checkbox"/>	<input type="checkbox"/>	
Loss of Cl ₂ residual	<input type="checkbox"/>	<input type="checkbox"/>	
Cl ₂ leak detection	<input type="checkbox"/>	<input type="checkbox"/>	
Scale	<input type="checkbox"/>	<input type="checkbox"/>	
Chained Cylinders	<input type="checkbox"/>	<input type="checkbox"/>	
Reserve Supply	<input type="checkbox"/>	<input type="checkbox"/>	
Adequate Air-pak	<input type="checkbox"/>	<input type="checkbox"/>	
Sign of Leaks	<input type="checkbox"/>	<input type="checkbox"/>	
Fresh Ammonia	<input type="checkbox"/>	<input type="checkbox"/>	
Ventilation	<input type="checkbox"/>	<input type="checkbox"/>	
Room Lighting	<input type="checkbox"/>	<input type="checkbox"/>	
Warning Signs	<input type="checkbox"/>	<input type="checkbox"/>	
Repair Kits	<input type="checkbox"/>	<input type="checkbox"/>	
Fitted Wrench	<input type="checkbox"/>	<input type="checkbox"/>	
Housing/Protection	<input type="checkbox"/>	<input type="checkbox"/>	

AERATION (Gases, Fe, & Mn Removal)

Type _____ Capacity _____
 Aerator Condition _____
 Bloodworm Presence _____
 Visible Algae Growth _____
 Protective Screen Condition _____
 Comments _____

STORAGE FACILITIES

(G) Ground (H) Hydropneumatic (E) Elevated
 (B) Bladder (C) Clearwell

Tank Type/Number	H/1		
Capacity (gal)	6,500		
Material	Steel		
Gravity Drain	Yes		
By-pass Piping	Yes		
Pressure Gauge	Yes		
Sight Glass or Level Indicator	Yes		
Fittings for Sight Glass	Yes		
Protected Openings	Yes		
PRV/ARV	PRV		
On/Off Pressure	40/62		
Access Padlocked	Yes		
Height to Bottom of Elevated Tank			
Height to Max. Water Level			

Comments _____

HIGH SERVICE PUMPS

Pump Number			
Type			
Make			
Model			
Capacity (gpm)			
Motor HP			
Date Installed			
Maintenance			

Comments _____

PWS ID # 3354867
Date 5/6/04

MONITORING VIOLATIONS	MCL VIOLATIONS


DEFICIENCIES:

No deficiencies at the time of inspection. The plant looked good!!

Keep up the good work!!

Inspector *[Signature]* Title Env. Specialist I Date 5/6/04

Approved by *Roberto C. Chung* Title Env. Manager Date 5/2/04



Jeb Bush
Governor

Department of Environmental Protection

Central District
3319 Maguire Boulevard, Suite 232
Orlando, Florida 32803-3767

Colleen M. Castille
Secretary

January 10, 2005

Mr. Will Fontaine
Aqua Utilities
P.O. Box 490310
Leesburg, FL 34749-0310

OCD-PW-SS-05-0019

Lake County – PW
48 Estates – 3350005
King's Cove – 3350655
Summit Chase – 3354112

Haines Creek – 3350481
Ravenswood – 3351062 ←

Dear Mr. Fontaine:

The Department conducted an inspection of your public water systems on October 26, 2004. This inspection was conducted by Karen Milicic of this office in the presence of Will Fontaine. Copies of the Sanitary Survey Reports are enclosed for your reference and records.

There were no deficiencies at your water plant at the time of our visit. The overall operation of the water plant was good, which is a credit to both you and your operator. The Department appreciates the excellent work being done on your water system and values your continued spirit of cooperation in complying with Department rules.

The Department values your continued cooperation in operating and maintaining your water system, and appreciates the assistance provided during the sanitary survey.

If you have any questions concerning this letter, please contact Karen Milicic at the above address or by phone at (407) 894-7555, extension 2226.

Sincerely,


Roberto C. Ansag, Environmental Manager
Drinking Water Compliance/Enforcement

RCA/km
Enclosure

"More Protection, Less Process"

Printed on recycled paper.

State of Florida
Department of Environmental Protection
Central District
SANITARY SURVEY REPORT

Plant Name RAVENSWOOD PARK County Lake PWS ID # 3351062
Plant Location US Hwy 27, Leesburg, FL 34748 Phone 352/369-4881
Owner Name Aqua Utilities, Attn: Will Fontaine Phone 352/369-4881
Owner Address P.O. Box 490310, Leesburg, FL 34749-0310
Contact Person W. Fontaine Title Operator Phone 352/369-4881
This Survey Date 10/26/04 Last Survey Date 8/1/00 Last C.I. Date 10/30/02

PWS TYPE & CLASS

- Community (5D)
- Non-transient Non-community
- Non-Community

PWS STATUS

- Approved system with approval number & date
HRS, 8653, 8/18/66
- Unapproved system

SERVICE AREA CHARACTERISTICS

Residential

Food Service: Yes No N/A

OPERATION & MAINTENANCE

Certified Operator: Yes No Not required
Operator(s) & Certification Class-Number
W. Fontaine C-6813, M. Neal C-10027
J. Worrell C-6597
O & M Log: Yes No Not required
Operator Visitation Frequency
Hrs/day: Required Actual
Days/wk: Required 3 Actual 5
Non-consecutive Days? Yes No N/A
MORs submitted regularly? Yes No N/A
Data missing from MORs? No Yes N/A

Number of Service Connections 41
Population Served 82 Basis MOR
Average Day (from MORs) 10,234 gpd
Max. Day (from MORs) 25,000 gpd 5/04
Max-day Design Capacity 56,160 gpd
Comments

COMET: SITE ID PROJECT ID

RAW WATER SOURCE

- GROUND; Number of Wells 1
- SURFACE/UDI; Source
- PURCHASED from PWS ID #
- Emergency Water Source
Emergency Water Capacity

AUXILIARY POWER SOURCE

- Yes None Not Required
- Source MPSG20 (propane)
- Capacity of Standby (kW) 20
- Switchover: Automatic Manual
- Standby Plan: Yes No
- Hrs Operated Under Load 4 hrs/mo.
- What equipment does it operate?
 - Well pumps
 - High Service Pumps
 - Treatment Equipment
- Satisfy 1/2 max-day demand? Yes No Unk
- Comments

TREATMENT PROCESSES IN USE

Disinfection

What additional treatment is needed?

For control of what deficiencies?

DISTRIBUTION SYSTEM

Flow Measuring Device Flow Meter
Meter Size & Type 2" Master
Backflow Prevention Devices: Yes No
Cross-connections None Observed
Written Cross-connection Control Program: Yes
Coliform Sampling Plan: Yes No N/A
Comments Required to have a Coliform Sampling Plan.

PWS ID # 3351062
 Date 1/10/05

GROUND WATER SOURCE

Well Number	1		
Year Drilled	1966		
Depth Drilled	104'		
Drilling Method	UNK		
Type of Grout	UNK		
Static Water Level	UNK		
Pumping Water Level	UNK		
Design Well Yield	UNK		
Test Yield	UNK		
Actual Yield (if different than rated capacity)	UNK		
Strainer	UNK		
Length (outside casing)	83'6"		
Diameter (outside casing)	6"		
Material (outside casing)	Blk. Iron		
Well Contamination History	UNK		
Is inundation of well possible?	No		
6' X 6' X 4" Concrete Pad	Yes		
SET BACKS	Septic Tank	--	
	Reuse Water	--	
	WW Plumbing	>100'	
	Other Sanitary Hazard	None Observed	
PUMP	Type	Submersible	
	Manufacturer Name	UNK	
	Model Number	UNK	
	Rated Capacity (gpm)	UNK	
	Motor Horsepower	5	
Well casing 12" above grade?	Yes		
Well Casing Sanitary Seal	Yes		
Raw Water Sampling Tap	Yes		
Above Ground Check Valve	Yes		
Fence/Housing	Yes		
Well Vent Protection	--		

COMMENTS Provide additional information for "UNK", if available.

PWS ID # 3351062
 Date 1/10/05

CHLORINATION (Disinfection)

Type: Gas Hypo
 Make Stenner Capacity 17 gpd
 Chlorine Feed Rate 2.5%
 Avg. Amount of Cl₂ gas used N/A
 Chlorine Residuals: Plant 1.1 Remote 1.03
 Remote tap location 3840 Palm Drive
 DPD Test Kit: On-site With operator
 None Not Used Daily
 Injection Points Prior to H/1
 Booster Pump Info _____
 Comments _____

Chlorine Gas Use Requirements	YES	NO	Comments
Dual System	<input type="checkbox"/>	<input type="checkbox"/>	
Auto-switchover	<input type="checkbox"/>	<input type="checkbox"/>	
Alarms:			
Loss of Cl ₂ capability	<input type="checkbox"/>	<input type="checkbox"/>	
Loss of Cl ₂ residual	<input type="checkbox"/>	<input type="checkbox"/>	
Cl ₂ leak detection	<input type="checkbox"/>	<input type="checkbox"/>	
Scale	<input type="checkbox"/>	<input type="checkbox"/>	
Chained Cylinders	<input type="checkbox"/>	<input type="checkbox"/>	
Reserve Supply	<input type="checkbox"/>	<input type="checkbox"/>	
Adequate Air-pak	<input type="checkbox"/>	<input type="checkbox"/>	
Sign of Leaks	<input type="checkbox"/>	<input type="checkbox"/>	
Fresh Ammonia	<input type="checkbox"/>	<input type="checkbox"/>	
Ventilation	<input type="checkbox"/>	<input type="checkbox"/>	
Room Lighting	<input type="checkbox"/>	<input type="checkbox"/>	
Warning Signs	<input type="checkbox"/>	<input type="checkbox"/>	
Repair Kits	<input type="checkbox"/>	<input type="checkbox"/>	
Fitted Wrench	<input type="checkbox"/>	<input type="checkbox"/>	
Housing/Protection	<input type="checkbox"/>	<input type="checkbox"/>	

AERATION (Gases, Fe, & Mn Removal)

Type _____ Capacity _____
 Aerator Condition _____
 Bloodworm Presence _____
 Visible Algae Growth _____
 Protective Screen Condition _____
 Comments _____

STORAGE FACILITIES

(G) Ground (H) Hydropneumatic (E) Elevated
 (B) Bladder (C) Clearwell

Tank Type/Number	H/1		
Capacity (gal)	3,000		
Material	Steel		
Gravity Drain	Yes		
By-pass Piping	Yes		
Pressure Gauge	Yes		
Sight Glass or Level Indicator	Yes		
Fittings for Sight Glass	Yes		
Protected Openings	Yes		
PRV/ARV	PRV		
On/Off Pressure	35/50		
Access Padlocked	Yes		
Height to Bottom of Elevated Tank			
Height to Max. Water Level			

Comments _____

HIGH SERVICE PUMPS

Pump Number			
Type			
Make			
Model			
Capacity (gpm)			
Motor HP			
Date Installed			
Maintenance			

Comments _____



Jeb Bush
Governor

Department of Environmental Protection

Northeast District
7825 Baymeadows Way, Suite B200
Jacksonville, Florida 32256-7590

David B. Scrubs
Secretary

March 11, 2004

Mr. Craig Anderson
Florida Water Services
Post Office Box 609520
Orlando, Florida 32860

Received

MAR 15 2004

Dear Mr. Anderson:

Environmental Services

Putnam County – Potable Water
River Grove Subdivision WTP
PWS ID: 2540959

On March 3, 2004 a Sanitary Survey inspection of the referenced community water system was conducted with the courteous assistance of Mr. Paul Thompson and Mr. Donald Holcomb of Florida Water Services. I was pleased to find that the water system is in good operating condition and generally well maintained. Based on this survey and our records, the Department is pleased to inform you that the above referenced facility is in compliance with the Florida Safe Drinking Water Act, Sections 403, Florida Statutes (FS), and the rules promulgated there-under, Florida Administrative Code (FAC) Title 62.

A copy of the sanitary survey report is enclosed for your records. If I may be of further assistance to you, please contact me via my Internet e-mail address at Annalise.Stahlman@dep.state.fl.us or by telephone at (904) 807-3335. Thank you for your cooperation with Florida's Safe Drinking Water Act.

Sincerely:

Annalise M. Stahlman
Environmental Specialist

AMS
EDC:BRR:AMS:ams
Correspondence File

Enclosure: Sanitary Survey Dated 3/3/04

"More Protection, Less Process"

Printed on recycled paper.

State of Florida
 Department of Environmental Protection
 Northeast District
SANITARY SURVEY REPORT

Plant Name RIVER GROVE SUBDIVISION WTP County Putnam PWS ID # 2540959
 Plant Location River Drive, East Palatka, Florida 32131 Phone 388-329-1122
 Owner Name Florida Water Services (Attn: Mr. Craig Anderson) Phone 407-880-0058
 Owner Address Post Office Box 609520, Orlando, Florida 32860
 Contact Person Mr. Paul Thompson Title Lead Operator, FWS Phone 388-329-1122
 This Survey Date 3/3/04 Last Survey Date 6/19/01 Last C.I. Date 8/1/02

PWS TYPE & CLASS: Community - (4C)

SERVICE AREA CHARACTERISTICS

Residential Subdivision
 Food Service: Yes No N/A

GENERAL INFORMATION

Number of Service Connections 119
 Population Served 371 Basis estimate
 Plant Design Capacity 90,000 gpd
 Basis well design capacity
 Average Day (from MORs) 17,309 gpd
 Max. Day (from MORs) 26,747 gpd
 Total Storage Capacity 16,800 gallons
 Comments Data based on January 2004 MOR.

LOCATION

Latitude 29° 38' 54.23" North
 Longitude 81° 36' 27.22" West
 GPS: Yes Date: 7/23/97
 Directions Hwy. 17 south, North onto Masters Rd., east onto Ferry Rd., north onto River Terrace, right at River Drive, plant is on the right side.

OPERATION & MAINTENANCE

Certified Operator: Yes No Not required
 Operator(s) & Certification Class-Number
Paul Thompson, A-7251
Donald Holcomb, A-5091
 O & M Log: Yes No Not required
 Operator Visitation Frequency
 Hrs/day: Required N/A Actual N/A
 Days/wk: Required 5 Actual 5
 Non-consecutive Days? Yes No N/A
 MORs submitted regularly? Yes No N/A
 Data missing from MORs? No Yes N/A
Complete Operations, Equipment, & Maintenance logs and sampling plans at the facility.

COMET: SITE ID _____ PROJECT ID _____

RAW WATER SOURCE

GROUND; Number of Wells 1
 SURFACE/UDI; Source _____
 PURCHASED from PWS ID # _____
 Emergency Water Source _____
 Emergency Water Capacity _____

AUXILIARY POWER SOURCE

Yes None Not Required
 Source _____
 Capacity of Standby (kW) _____
 Switchover: Automatic Manual
 Standby Plan: Yes No
 Hrs Operated Under Load _____
 What equipment does it operate?
 Well pumps _____
 High Service Pumps _____
 Treatment Equipment _____
 Satisfy 1/2 max-day demand? Yes No Unk
 Comments _____

TREATMENT PROCESSES IN USE

Hypo-chlorination and Aeration
 What additional treatment is needed?
None
 For control of what deficiencies?
N/A

DISTRIBUTION SYSTEM

Flow Measuring Device Flow Meter
 Meter Size & Type 3" Neptune Meter
 Backflow Prevention Devices: Yes No
 Cross-connections none seen
 Written Cross-connection Control Program: Yes
 Coliform Sampling Plan: Yes No N/A
 Comments Satisfactory

PWS ID # 2540959
 Survey Date 3/3/04

GROUND WATER SOURCE

Well Number (PWS Identification)	2540959		
Well Name (System Identification)	1		
Year Drilled	1962		
Depth Drilled	200'		
Latitude	29:38:54.247 N		
Longitude	81:36:27.217 W		
GPS (Y or N) / Date (if applicable)	Yes, 7/23/07		
Florida Well ID	AAC1899		
Static Water Level	Unknown		
Actual Yield (if different than rated capacity)			
Strainer	Unknown		
Length (outside casing)	Unknown		
Diameter (outside casing)	6"		
Material (outside casing)	Steel		
Well Contamination History	None		
Is inundation of well possible?	No		
8' X 6' X 4" Concrete Pad	OK		
SET BACKS	Septic Tank		
	Reuse Water		
	WW Plumbing		
	Other Sanitary Hazard		
PUMP	Type	Centrifugal	
	Manufacturer Name	Goulds	
	Model Number	4BF15035	
	Rated Capacity (gpm)	125	
	Motor Horsepower	5	
Well casing 12" above grade?	OK		
Well Casing Sanitary Seal	OK		
Raw Water Sampling Tap	OK - smooth		
Above Ground Check Valve	OK		
Fence/Housing	Secure		
Well Vent Protection	Not Required		

COMMENTS The well appears to be in good operating condition.

PWS ID # 2540959
 Survey Date 3/3/04

CHLORINATION (Disinfection)

Type: Hypo-Chlorination
 Make Stenner Capacity 17 gpd
 Chlorine Feed Rate 40%
 Avg. Amount of Cl₂ gas used N/A
 Chlorine Residuals: Plant 2.1 Remote 2.1
 Remote tap location _____
 DPD Test Kit: On-site With operator
 None Not Used Daily
 Injection Points Upstream of Aerator
 Booster Pump Info Myers, QP20, HP=2
 Comments Satisfactory chlorination

Chlorine Gas Use Requirements	YES	NO	Comments
Dual System	<input type="checkbox"/>	<input type="checkbox"/>	
Auto-switchover	<input type="checkbox"/>	<input type="checkbox"/>	
Alarms:			
Loss of Cl ₂ capability	<input type="checkbox"/>	<input type="checkbox"/>	
Loss of Cl ₂ residual	<input type="checkbox"/>	<input type="checkbox"/>	
Cl ₂ leak detection	<input type="checkbox"/>	<input type="checkbox"/>	
Scale	<input type="checkbox"/>	<input type="checkbox"/>	
Chained Cylinders	<input type="checkbox"/>	<input type="checkbox"/>	
Reserve Supply	<input type="checkbox"/>	<input type="checkbox"/>	
Adequate Air-pak	<input type="checkbox"/>	<input type="checkbox"/>	
Sign of Leaks	<input type="checkbox"/>	<input type="checkbox"/>	
Fresh Ammonia	<input type="checkbox"/>	<input type="checkbox"/>	
Ventilation	<input type="checkbox"/>	<input type="checkbox"/>	
Room Lighting	<input type="checkbox"/>	<input type="checkbox"/>	
Warning Signs	<input type="checkbox"/>	<input type="checkbox"/>	
Repair Kits	<input type="checkbox"/>	<input type="checkbox"/>	
Fitted Wrench	<input type="checkbox"/>	<input type="checkbox"/>	
Housing/Protection	<input type="checkbox"/>	<input type="checkbox"/>	

AERATION (Gases, Fe, & Mn Removal)

Type Cascade Capacity 215 gpm
 Aerator Condition Clean, well maintained
 Bloodworm Presence None
 Visible Algae Growth None
 Protective Screen Condition Clean, Secure
 Comments Aerator appears to be clean and well maintained.

STORAGE FACILITIES

(G) Ground (H) Hydropneumatic (E) Elevated
 (B) Bladder (C) Clearwell

Tank Type/Number	H	G	
Capacity (gal)	3000	15000	
Material	Steel	Steel	
Gravity Drain	Yes	Yes	
By-pass Piping	Yes	Yes	
Pressure Gauge	Yes	N/A	
Sight Glass or Level Indicator	No	No	
Fittings for Sight Glass	N/A	N/A	
Protected Openings	Yes	Yes	
PRV/ARV	PRV	N/A	
On/Off Pressure	40/50	N/A	
Access Padlocked	Yes	Yes	
Height to Bottom of Elevated Tank	N/A	N/A	
Height to Max. Water Level	N/A	N/A	

Comments Storage tanks appear to be in good condition.

HIGH SERVICE PUMPS

Pump Number	1	2	
Type	Cent.	Cent.	
Make	Goulds	Goulds	
Model	unk.	unk.	
Capacity (gpm)	170	170	
Motor HP	10	10	
Date Installed	unk.	unk.	
Maintenance	Good	Good	


Comments HSP's appear to be in good operating condition.

PWS ID # 2540959
 Survey Date 3/3/04

COMPLIANCE MONITORING COMMUNITY PUBLIC WATER SYSTEMS serving < 3300 persons			
CONTAMINANT	Last Sampled	Due Date	COMMENTS
Microbiological (Bacti)	xxxxxxx	Monthly	2 distribution samples + 1 from each raw source (based upon population served)
Volatile Organic Contaminants	2003	2006	Samples due every 3 years
Synthetic Organic Contaminants	2003	2006	Samples due every 3 years
Nitrate & Nitrite (as N)	2003	2004	Nitrates / Nitrite samples due annually
Inorganic Contaminants	2003	2006	Samples due every 3 years
Asbestos	2003	2012	Samples taken from distribution. Waiver available if no asbestos pipe in the distribution system.
Secondary Standards	2003	2006	Samples due every 3 years
Radionuclides	2003	2006	Samples due every 3 years
Disinfection Byproducts (i.e. Total Trihalomethanes (TTHMs) and Haloacetic Acids (HAA5s));	N/A	2004	Per sampling plan
Lead and Copper	2001	2004	Sample locations are from pre-approved sample plan

Unless otherwise noted, all samples shall be taken at each entry point to the distribution system, and representative of each source after treatment.

SCHEMATIC:



PWS ID # 2540959
 Survey Date 3/3/04

MONITORING VIOLATIONS	MCL VIOLATIONS
None	None

DEFICIENCIES:

This facility is clean, well maintained, and appears to be in good operating condition.

Inspector Annalise M. Stahlman Title Environmental Specialist II Date 3/11/04
 Approved by Blanca R. Rodriguez Title Engineer IV Date 3/11/04

AQUA
Utilities Florida.

Aqua Utilities Florida, Inc.
1343 NE 17th Road
Ocala, FL 34470

www.aquafl.com

Via UPS Ground

November 9, 2004

Mr. Patrick W. Lewis
Environmental Specialist I
Polk County Health Department
2090 E. Clower Street
Bartow, FL 33830-6741

Re: Rosalie Oaks
PWS ID No. 3531546


Mr. Patrick Lewis;

The purpose of this correspondence is to provide a written response as requested in regards to the sanitary survey that was conducted at the above referenced facility on September 22, 2004

Aqua Utilities Florida has placed a generator on-site at the above reference water facility. Auxiliary power is not required for this facility at this time; however we feel it is essential to have a generator, thus our customers will be able to obtain water if power failure occurs. The generator is an Elliott, MNPSG (serial # 01-03272) and has a capacity of standby at 20 kW. It will be an automatic switchover when the generator is connected and will operate the well pumps and treatment equipment to satisfy ½ maximum day demand.

We trust this response is sufficient to address your concerns. However, should you need additional information please do not hesitate to contact me at (352)732-6027.

Sincerely,


Nicole A. Zinn
Administrative Assistant

An Aqua America Company



Job Bush
Governor

John O. Agwuobi, MD, MBA
Secretary

September 28, 2004

RECEIVED

COMMUNITY/ROSALIE OAKS
PWS: Id. No. 3531546

SEP 30 2004
Aqua Utilities
Florida Inc.

ROSALIE OAKS
6960 PROFESSIONAL PARKWAY E. STE. #400
SARASOTA, FL 34240

Elliott
MNPSG 2004

Dear Public Water System Owner:

A sanitary survey of your system conducted on September 22, 2004 indicates the following deficiencies in reference to the public drinking water requirements listed in *Chapter 62 Florida Administrative Code*.

There is a generator (unconnected) on-site. Please ensure that prior to permanent installation that it is in compliance with Chapter 62-555.320(14) and that adequate documentation including water system proposed modifications including equipment specification is submitted to our office for the Department to determine any applicable approval or clearance.

generator
operations
needs
treatment
equipment

Please take the necessary steps to correct this deficiency within thirty (30) days of the date of this notice and notify the Department in writing.

If you have any questions, please contact this office at (863) 519-8330 ext. 1148.

Thank you for your cooperation in resolving this matter.

Sincerely,

Patrick W. Lewis
Patrick W. Lewis
Environmental Specialist I

PWL:mag
xc: Aqua Source

Daniel O. Haight, MD
Director

POLK COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL ENGINEERING DIVISION
2090 East Clower Street, Bartow, FL 33830-6741
Phone (863) 519-8330 / SC 515-7365 / Fax (863) 534-0245

Lynne M. Saddler, MD, MPH
Assistant Director

Printed on recycled paper

AQUA
Utilities Florida.

1343 NE 17th Road
Ocala, FL 34470
(352)732-6027
(352)732-3213 fax

FACSIMILE TRANSMITTAL SHEET

TO: Carolyn	FROM: Nicole
FAX NUMBER: 941-907-0965	DATE: 1-11-2005
COMPANY:	TOTAL NO. OF PAGES INCLUDING COVER: 3
PHONE NUMBER:	

RE: Roseanne Oatis

URGENT FOR REVIEW PLEASE COMMENT PLEASE REPLY PLEASE RECYCLE

NOTES/COMMENTS:

This is the only thing I can find.



Docket No. 060368-WS

Application to Increase Rates and Charges

For a "Class A" Utility
In

Florida

Missing Report: Sanitary Survey Report

For: Sebring Lakes

Aqua Utilities Florida, Inc.

State of Florida
Department of Environmental Protection
Central District
SANITARY SURVEY REPORT

Plant Name SILVER LAKE ESTATES County Lake PWS ID # 3351182
Plant Location 10438 Barrington Court, Leesburg Phone 352/787-0980
Owner Name Florida Water Services, Attn: Craig Anderson Phone 407/880-0058
Owner Address P.O. Box 609520, Orlando, FL 32860
Contact Person Will Fontaine Title Lead Operator Phone 352/787-0980
This Survey Date 4/28/04 Last Survey Date 10/3/01 Last C.I. Date 8/24/99

PWS TYPE & CLASS

- Community (5C)
- Non-transient Non-community
- Non-Community

PWS STATUS

- Approved system with approval number & date
HRS #13594, 11/24/71
WC35-266211, 4/4/95, cleared 3/6/96
- Unapproved system

SERVICE AREA CHARACTERISTICS

Subdivision _____
Food Service: Yes No N/A

OPERATION & MAINTENANCE

Certified Operator: Yes No Not required
Operator(s) & Certification Class-Number
B. Heath C-5824, W. Fontaine C-6813, J. Worrell
C-6597, G. Kissick C-7846
O & M Log: Yes No Not required
Operator Visitation Frequency
Hrs/day: Required _____ Actual _____
Days/wk: Required 6 Actual 6
Non-consecutive Days? Yes No N/A
MORs submitted regularly? Yes No N/A
Data missing from MORs? No Yes N/A

Number of Service Connections 1120
Population Served 3928 Basis per MOR
Average Day (from MORs) .810 MGD
Max. Day (from MORs) 1.832 MGD 12/03
Max-day Design Capacity 2.202 MGD
Comments _____

COMET: SITE ID _____ PROJECT ID _____

RAW WATER SOURCE

- GROUND; Number of Wells 2
- SURFACE/UDI; Source _____
- PURCHASED from PWS ID # _____
- Emergency Water Source Western Shores
Emergency Water Capacity .432 MGD

AUXILIARY POWER SOURCE

Yes None Not Required
Source Catepillar generator
Capacity of Standby (kW) 250
Switchover: Automatic Manual
Standby Plan: Yes No
Hrs Operated Under Load 4 hrs/mo.
What equipment does it operate?
 Well pumps All
 High Service Pumps All
 Treatment Equipment All
Satisfy 1/2 max-day demand? Yes No Unk
Comments Interconnected with Western Shores
PWS ID no. 3351484

TREATMENT PROCESSES IN USE

Chlorination
What additional treatment is needed?
For control of what deficiencies?

DISTRIBUTION SYSTEM

Flow Measuring Device Flow Meter
Meter Size & Type *
Backflow Prevention Devices: Yes No
Cross-connections None observed
Written Cross-connection Control Program: Yes
Coliform Sampling Plan: Yes No N/A
Comments *10" McCrometer on each well and
10" flowmeter on discharge line to distribution.
with a totalizer.

Received

MAY 12 2004

Environmental Service

PWS ID # 3351182Date 5/6/04**GROUND WATER SOURCE**

Well Number		1	2		
Year Drilled		1971	1980		
Depth Drilled		366'	327'		
Drilling Method		UNK	Cable Tool		
Type of Grout		UNK	UNK		
Static Water Level		UNK	41'		
Pumping Water Level		UNK	UNK		
Design Well Yield		UNK	UNK		
Test Yield		UNK	UNK		
Actual Yield (if different than rated capacity)		UNK	UNK		
Strainer		UNK	UNK		
Length (outside casing)		200'	132'		
Diameter (outside casing)		10"	12"		
Material (outside casing)		Black Steel	Black Steel		
Well Contamination History		None noted	None noted		
Is inundation of well possible?		No	No		
6' X 6' X 4" Concrete Pad		Yes	Yes		
SET BACKS	Septic Tank	>200'	>200'		
	Reuse Water	--	--		
	WW Plumbing	>100'	>100'		
	Other Sanitary Hazard	None observed	None observed		
PUMP	Type	Vert. Turbine	Vert. Turbine		
	Manufacturer Name	Goulds	Goulds		
	Model Number	58895-7	58895-7		
	Rated Capacity (gpm)	1425	1425		
	Motor Horsepower	50	50		
Well casing 12" above grade?		Yes	Yes		
Well Casing Sanitary Seal		Yes	Yes		
Raw Water Sampling Tap		Yes	Yes		
Above Ground Check Valve		Yes*	Yes		
Fence/Housing		Yes	Yes		
Well Vent Protection		Yes	Yes		

COMMENTS Provide additional information for "UNK", if available.

*Check and repair/ replace leaking valve stem.

PWS ID # 3351182
 Date 5/6/04

CHLORINATION (Disinfection)

Type: Gas Hypo
 Make Regal Capacity * ppd
 Chlorine Feed Rate 37 ppd
 Avg. Amount of Cl₂ gas used 20 ppd
 Chlorine Residuals: Plant 1.7 Remote 1.3
 Remote tap location Cnr Brigdoon & Famich Ct
 DPD Test Kit: On-site With operator
 None Not Used Daily
 Injection Points Prior to ground storage
 Booster Pump Info 1 HP Goulds model no. HB2510
 Comments *100 ppd chlorinator for each well.

STORAGE FACILITIES

(G) Ground (H) Hydropneumatic (E) Elevated
 (B) Bladder (C) Clearwell

Tank Type/Number	G/1	G/2	
Capacity (gal)	25,000	25,000	
Material	(1)	(1)	
Gravity Drain	Yes	Yes	
By-pass Piping	Yes	Yes	
Pressure Gauge	N/A	N/A	
Sight Glass or Level Indicator	Yes	Yes	
Fittings for Sight Glass	N/A	N/A	
Protected Openings	Yes	Yes	
PRV/ARV	N/A	N/A	
On/Off Pressure	(2)	(2)	
Access Padlocked	Yes	Yes	
Height to Bottom of Elevated Tank			
Height to Max. Water Level			

Comments 1) Concrete. 2) On/off - 8'/10'.

Chlorine Gas Use Requirements	YES	NO	Comments
Dual System	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Auto-switchover	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Alarms:			
Loss of Cl ₂ capability	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Loss of Cl ₂ residual	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Cl ₂ leak detection	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Scale	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Chained Cylinders	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Reserve Supply	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Adequate Air-pak	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Sign of Leaks	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Fresh Ammonia	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Ventilation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Room Lighting	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Warning Signs	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Repair Kits	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Fitted Wrench	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Housing/Protection	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

AERATION (Gases, Fe, & Mn Removal)

Type Capacity
 Aerator Condition
 Bloodworm Presence
 Visible Algae Growth
 Protective Screen Condition
 Comments

HIGH SERVICE PUMPS

Pump Number			
Type			
Make			
Model			
Capacity (gpm)			
Motor HP			
Date Installed			
Maintenance			

Comments See page 3a

PWS ID # 3351182
 Date 10/29/01

HIGH SERVICE PUMPS

Pump Number	MP-1	MP-2*	MP-3	MP-4*	
Type	Centrif.	Centrif.	Centrif.	Centrif	
Make	Paco	Paco	Paco	Paco	
Model	Unk	Unk	Unk	Unk	
Capacity (gpm)	950	950	950	950	
Motor HP	50	50	50	50	
Date Installed	1996	1996	1996	1996	
Maintenance	--	--	--	--	

Comments _____

*Check and repair/ replace leaking valve stems.

JOCKEY PUMPS

Pump Number	JP-1	JP-2			
Type	Centrif.	Centrif.			
Make	Paco	Paco			
Model	Unk	Unk			
Capacity (gpm)	310	310			
Motor HP	15	15			
Date Installed	1996	1996			
Maintenance					

Comments _____

JP-1 and JP-2 are jockey pumps used during low flow conditions

PWS ID # 3351182
Date 5/6/04

MONITORING VIOLATIONS	MCL VIOLATIONS

DEFICIENCIES:

1. Check and repair/ replace leaking valve stem for HSP MP-2 and MP-4
2. Check and repair/ replace leaking valve stem for Well #1.

Overall, the plant looked good.

Inspector [Signature] Title Env. Specialist I Date 5/6/04

Approved by [Signature] Title Env. Manager Date 5/7/04

State of Florida
Department of Environmental Protection
Central District
SANITARY SURVEY REPORT

Plant Name WESTERN SHORES S/D County Lake PWS ID # 3351464
Plant Location 34210 Carl Road, Leesburg Phone 352/787-0980
Owner Name Florida Water Services, Attn: Craig Anderson Phone 407/880-0058
Owner Address P.O. Box 609520, Orlando, FL 32860
Contact Person Will Fontaine Title Lead Operator Phone 352/787-0980
This Survey Date 4/28/04 Last Survey Date 10/3/01 Last C.I. Date 8/24/99

PWS TYPE & CLASS

- Community (5C)
- Non-transient Non-community
- Non-Community

PWS STATUS

- Approved system with approval number & date
HRS #10900, 7/2/69, WC35-2077, 8/23/83
WC35-266209, 3/28/95, cleared 12/12/95
- Unapproved system

SERVICE AREA CHARACTERISTICS

Residential - MHP
Food Service: Yes No N/A

OPERATION & MAINTENANCE

Certified Operator: Yes No Not required
Operator(s) & Certification Class-Number
B. Heath C-5824, W. Fontaine C-6813, J. Worrell
C-6597, G. Kissick C-7846
O & M Log: Yes No Not required
Operator Visitation Frequency
Hrs/day: Required Actual
Days/wk: Required 6 Actual 6
Non-consecutive Days? Yes No N/A
MORs submitted regularly? Yes No N/A
Data missing from MORs? No Yes N/A

Number of Service Connections 384
Population Served 960 Basis per MOR
Average Day (from MORs) 22,030 gpd
Max. Day (from MORs) .149 MGD 11/03
Max-day Design Capacity 432 MGD
Comments

COMET: SITE ID PROJECT ID

RAW WATER SOURCE

- GROUND; Number of Wells 1
- SURFACE/UDI; Source
- PURCHASED from PWS ID #
- Emergency Water Source Silver Lake Estates
Emergency Water Capacity 2.202 MGD

AUXILIARY POWER SOURCE

Yes None Not Required
Source Interconnected w/ Silver Lake Estates
Capacity of Standby (kW) 250
Switchover: Automatic Manual
Standby Plan: Yes No
Hrs Operated Under Load 4 hrs/mo.
What equipment does it operate?
 Well pumps
 High Service Pumps
 Treatment Equipment
Satisfy 1/2 max-day demand? Yes No Unk
Comments Interconnected with Silver Lake Estates
PWS ID no. 3351182

TREATMENT PROCESSES IN USE

Chlorination
What additional treatment is needed?

For control of what deficiencies?

DISTRIBUTION SYSTEM

Flow Measuring Device Flow Meter
Meter Size & Type 6" McCrometer
Backflow Prevention Devices: Yes No
Cross-connections None observed
Written Cross-connection Control Program: Yes
Coliform Sampling Plan: Yes No N/A
Comments

Received

MAY 12 2004

Environmental Services

PWS ID # 3351464Date 5/6/04**GROUND WATER SOURCE**

Well Number	1(Abandoned)	2		
Year Drilled		1982		
Depth Drilled	223'	423'		
Drilling Method		Cable Tool		
Type of Grout		Neat Cement		
Static Water Level		11'		
Pumping Water Level		UNK		
Design Well Yield		UNK		
Test Yield		UNK		
Actual Yield (if different than rated capacity)		UNK		
Strainer		Open		
Length (outside casing)	80'	20'/175'		
Diameter (outside casing)	4"	14"/8"		
Material (outside casing)		Black Steel		
Well Contamination History		Some		
Is inundation of well possible?		No		
6' X 6' X 4" Concrete Pad		Yes		
SET BACKS	Septic Tank	>200'		
	Reuse Water	--		
	WW Plumbing	>100'		
	Other Sanitary Hazard	None observed		
PUMP	Type	Vert. Turbine		
	Manufacturer Name	Goulds		
	Model Number	8DHH		
	Rated Capacity (gpm)	600		
	Motor Horsepower	40		
Well casing 12" above grade?		Yes		
Well Casing Sanitary Seal		Yes		
Raw Water Sampling Tap		Yes		
Above Ground Check Valve		Yes		
Fence/Housing		Yes		
Well Vent Protection		Yes		

COMMENTS Provide additional information for "UNK", if available.

Well #1 properly abandoned 2/96.

PWS ID # 3351464
 Date 5/6/04

CHLORINATION (Disinfection)

Type: Gas Hypo
 Make Regal Capacity 25 ppd
 Chlorine Feed Rate 12ppd
 Avg. Amount of Cl₂ gas used .5 ppd
 Chlorine Residuals: Plant 1.1 Remote 1.5
 Remote tap location near 640 N. Abbey
 DPD Test Kit: On-site With operator
 None Not Used Daily
 Injection Points Prior to H/1 & by-pass
 Booster Pump Info 1 HP Goulds mod 25GBC10
 Comments _____

Chlorine Gas Use Requirements	YES	NO	Comments
Dual System	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Auto-switchover	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Alarms:			
Loss of Cl ₂ capability	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Loss of Cl ₂ residual	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Cl ₂ leak detection	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Scale	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Chained Cylinders	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Reserve Supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Adequate Air-pak	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Sign of Leaks	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Fresh Ammonia	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Ventilation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Room Lighting	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Warning Signs	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Repair Kits	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Fitted Wrench	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Housing/Protection	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

AERATION (Gases, Fe, & Mn Removal)

Type _____ Capacity _____
 Aerator Condition _____
 Bloodworm Presence _____
 Visible Algae Growth _____
 Protective Screen Condition _____
 Comments _____

STORAGE FACILITIES

(G) Ground (H) Hydropneumatic (E) Elevated
 (B) Bladder (C) Clearwell


Tank Type/Number	H/1		
Capacity (gal)	15,000		
Material	Steel		
Gravity Drain	Yes		
By-pass Piping	Yes		
Pressure Gauge	Yes		
Sight Glass or Level Indicator	Yes		
Fittings for Sight Glass	Yes		
Protected Openings	Yes		
PRV/ARV	PRV		
On/Off Pressure	60/80		
Access Padlocked	Yes		
Height to Bottom of Elevated Tank			
Height to Max. Water Level			

Comments _____

HIGH SERVICE PUMPS

Pump Number			
Type			
Make			
Model			
Capacity (gpm)			
Motor HP			
Date Installed			
Maintenance			

Comments _____



Department of Environmental Protection

Jeb Bush
Governor

Northeast District
7825 Baymeadows Way, Suite B-200
Jacksonville Florida 32256-7590

Colleen M. Castille
Secretary

July 18, 2006

SENT VIA EMAIL: CMMcClure@aquaamerica.com

Ms. Candice McClure
Silver Lake Oaks
P.O. Box 490310
Leesburg, FL 34749

Putnam County – Potable Water
Compliance Inspection 2006
Silver Lake Oaks// PWS ID: 2544258

Dear Ms. McClure:

On July 14, 2006, a Compliance Inspection of the above referenced Community water system was conducted with the courteous assistance of Mr. Paul Thompson. The Department is pleased to inform you that your facility is in compliance with the Florida Safe Drinking Water Act, Section 403, Florida Statutes (FS), and the Florida Administrative Code (FAC) Title 62.

As a reminder, this system is required to monitor for the following remaining parameters during 2006: All Inorganic Contaminants, including Nitrate and Nitrite, Synthetic Organic Contaminants, Volatile Organic Contaminants, Secondaries, Disinfection Byproducts (TTHMs and HAA5s), Bacteriologicals (monthly), and Disinfectant Residual Levels (monthly with Bacti's).

Enclosed is a copy of the Compliance Inspection. Please contact me at (904) 807-3321 or Amber.Otto@dep.state.fl.us if you have any questions.

Sincerely,

Amber Otto
Environmental Specialist

BRR:AMO:ao

cc: Paul Thompson, Operator (via mail)

**State of Florida
Department of Environmental Protection**

PUBLIC WATER SYSTEM INSPECTION REPORT

System Name:	<u>Silver Lake Oaks</u>	Inspection Date:	<u>7/14/2006</u>
Location:	<u>Silver Lake Dr. at Lake Shore Dr.</u>	PWS ID:	<u>2544258</u>
Owner:	<u>Candice McClure (CMMCCLURE@AQUAAMERICA.COM)</u>	Phone No.:	<u>(352)732-6027</u>
Address	<u>P.O. Box 490310</u>	Zip Code:	<u>34749</u> County: <u>Putnam</u>
Certified Operator:	<u>Mr. Paul Thompson</u>	Level & No.:	<u>A - 7251</u>
Type of System:	<u>Community</u>	Type of Inspection:	<u>Compliance</u>

INSPECTION RESULTS

Selections marked with an X are unsatisfactory. Selections marked with an I are in need of improvement.
Referenced sections are from Title 62, Florida Administrative Code

<u>OK</u>	Aeration	555.350	<u>Screens secure, Clean</u>
<u>OK</u>	Auxiliary Power	555.320(14)	<u></u>
<u>OK</u>	Check Valve	555.330(3)	<u></u>
<u>OK</u>	Cross Connection	555.360	<u>None Seen</u>
<u>OK</u>	Chlorination (Disinfection)	555.320(12)(d)&.350(6)	<u>Cl2 injection point was unclogged and fixed during inspection</u>
	Plant <u>0.66</u> mg/l Remote <u>0.35</u> mg/l		<u>Remote from WWTP</u>
<u>N/A</u>	Chlorination, Gas	555.320(13)(a)	<u></u>
<u>OK</u>	Chlorine Test Kit - DPD	555.330(3)	<u>On-site and with operator</u>
<u>OK</u>	Flow Meter	555.320(16)	<u>Master Meter</u>
<u>OK</u>	Logs, on-site	555.350(12)	<u>Current, 5 visits per week</u>
<u>OK</u>	Maintenance of Facilities	555.350	<u>Very good</u>
<u>OK</u>	Monitoring: Bacteriological	550.518	<u>Due MONTHLY; Current</u>
<u>OK</u>	Monitoring: Chemical	550.500-521	<u>DUE in 2006: Inorganics, SOCs, VOCs, Secondaries & DBPs</u>
<u>N/A</u>	Monitoring: Well Clearance	555.315(6)(b)	<u></u>
<u>OK</u>	Monthly Operation Reports	550.730(1)(d)	<u>Due MONTHLY; Current</u>
<u>OK</u>	Operator, Certified	555.350(8)	<u>Paul Thompson; A-7251</u>
<u>OK</u>	Plant Design	555.330	<u></u>
<u>OK</u>	Security of Water System	555.315(1) & .320(5)	<u>Locked fence</u>
<u>OK</u>	System Pressure	555.320(15)(a)2	<u>40psi, gauge on hydrotank</u>
<u>OK</u>	Well, Concrete Apron	532.500(3)(c)	<u></u>
<u>I</u>	Wells, Number of	555.315(2)	<u>AAC1924</u>
<u>OK</u>	Well, Raw Sample Tap	555.320(8)(b)2	<u></u>
<u>OK</u>	Well Set Backs	555.312	<u>None seen</u>

Comments: _____

It is required that a written response be provided to this office within ten days of receipt of this report regarding any unsatisfactory results listed above.

Inspector: Amber Otto Date: July 18, 2006
 Amber Otto, (904) 807-3321 or e-mail address: Amber.Otto@DEP.STATE.FL.US



Jeb Bush
Governor

Department of Environmental Protection

Northeast District
7825 Baymeadows Way, Suite B200
Jacksonville, Florida 32256-7590

David B. Struhs
Secretary

March 5, 2004

Mr. Craig Anderson
Florida Water Services
Post Office Box 609520
Orlando, Florida 32860

Received

MAR 10 2004

Dear Mr. Anderson:

Environmental Services

Putnam County - Potable Water
Silver Lake Oaks WTP
PWS ID: 2544258

On March 3, 2004 a Sanitary Survey inspection of the referenced community water system was conducted with the courteous assistance of Mr. Paul Thompson and Mr. Donald Holcomb of Florida Water Services. I was pleased to find that the water system is in good operating condition and generally well maintained. Based on this survey and our records, the Department is pleased to inform you that the above referenced facility is in compliance with the Florida Safe Drinking Water Act, Sections 403, Florida Statutes (FS), and the rules promulgated there-under, Florida Administrative Code (FAC) Title 62.

A copy of the sanitary survey report is enclosed for your records. If I may be of further assistance to you, please contact me at Annalise.Stahlman@dep.state.fl.us or (904) 807-3335. Thank you for your cooperation with Florida's Safe Drinking Water Act.

Sincerely:

Annalise M. Stahlman
Environmental Specialist

AMS
EDD:BRR:AMS:ams
Correspondence File

Enclosure: Sanitary Survey Dated 3/3/04

"More Protection, Less Process"

Printed on recycled paper.

State of Florida
Department of Environmental Protection
Northeast District
SANITARY SURVEY REPORT

Plant Name SILVER LAKE OAKS WTP County Putnam PWS ID # 2544258
 Plant Location Silver Lake Drive @ Lake Shore Drive, Palatka, Florida Phone 386-329-1122
 Owner Name Florida Water Services (Attn: Mr. Craig Anderson) Phone 407-880-0058
 Owner Address Post Office Box 609520, Orlando, Florida 32860
 Contact Person Mr. Paul Thompson Title Lead Operator, FWS Phone 386-329-1122
 This Survey Date 3/3/04 Last Survey Date 6/19/01 Last C.I. Date 8/1/02

PWS TYPE & CLASS: Community - (5D)

SERVICE AREA CHARACTERISTICS

Mobile Home Park
 Food Service: Yes No N/A

GENERAL INFORMATION

Number of Service Connections 35
 Population Served 88 Basis estimate
 Plant Design Capacity 57,600 gpd
 Basis well pump capacity
 Average Day (from MORs) 4,097 gpd
 Max. Day (from MORs) 10,100 gpd
 Total Storage Capacity 18,500 gallons
 Comments data based on December 2003 MOR

LOCATION

Latitude 29° 37' 23" North
 Longitude 81° 42' 53" West
 GPS: No Date: _____
 Directions US 17 south to Palatka, right on Hwy 19, right on Silver Lake Dr., plant is on left at Lake Shore Drive.

OPERATION & MAINTENANCE

Certified Operator: Yes No Not required
 Operator(s) & Certification Class-Number
Paul Thompson, A-7251
Donald Holcomb, A-5091
 O & M Log: Yes No Not required
 Operator Visitation Frequency
 Hrs/day: Required N/A Actual N/A
 Days/wk: Required 5 Actual 5
 Non-consecutive Days? Yes No N/A
 MORs submitted regularly? Yes No N/A
 Data missing from MORs? No Yes N/A
complete operations, maintenance, & equipment logs and sampling plans on site.

COMET: SITE ID _____ PROJECT ID _____

RAW WATER SOURCE

GROUND; Number of Wells 1
 SURFACE/UDI; Source _____
 PURCHASED from PWS ID # _____
 Emergency Water Source _____
 Emergency Water Capacity _____

AUXILIARY POWER SOURCE

Yes None Not Required
 Source _____
 Capacity of Standby (kW) _____
 Switchover: Automatic Manual
 Standby Plan: Yes No
 Hrs Operated Under Load _____
 What equipment does it operate?
 Well pumps _____
 High Service Pumps _____
 Treatment Equipment _____
 Satisfy 1/2 max-day demand? Yes No Unk
 Comments _____

TREATMENT PROCESSES IN USE

Hypo-chlorination, Aeration
 What additional treatment is needed?
None
 For control of what deficiencies?
N/A

DISTRIBUTION SYSTEM

Flow Measuring Device Flow Meter
 Meter Size & Type 2" Master Meter
 Backflow Prevention Devices: Yes No
 Cross-connections none observed
 Written Cross-connection Control Program: Yes
 Coliform Sampling Plan: Yes No N/A
 Comments Satisfactory

PWS ID # 2544258
 Survey Date 3/3/04

GROUND WATER SOURCE

Well Number (PWS Identification)	2544258		
Well Name (System Identification)	1		
Year Drilled	2000		
Depth Drilled	260'		
Latitude	29:37:23 N		
Longitude	81:42:53 W		
GPS (Y or N) / Date (if applicable)	No		
Florida Well ID	AAC1924		
Static Water Level	Unknown		
Actual Yield (if different than rated capacity)			
Strainer	Unknown		
Length (outside casing)	197'		
Diameter (outside casing)	4"		
Material (outside casing)	steel		
Well Contamination History	None		
Is inundation of well possible?	No		
6' X 6' X 4" Concrete Pad	OK		
SET BACKS	Septic Tank		
	Reuse Water		
	WW Plumbing		
	Other Sanitary Hazard		
PUMP	Type	Submersible	
	Manufacturer Name	Unknown	
	Model Number	Unknown	
	Rated Capacity (gpm)	75	
	Motor Horsepower	5	
Well casing 12" above grade?	OK		
Well Casing Sanitary Seal	OK		
Raw Water Sampling Tap	OK - smooth		
Above Ground Check Valve	OK		
Fence/Housing	Secure		
Well Vent Protection	Not required		

COMMENTS Well appears to be in good operating condition.

PWS ID # 2544258
 Survey Date 3-Mar-04

CHLORINATION (Disinfection)

Type: Hypo-Chlorination
 Make Stenner Capacity 10 gpd
 Chlorine Feed Rate 30%
 Avg. Amount of Cl₂ gas used N/A
 Chlorine Residuals: Plant 2.1 Remote 2.1
 Remote tap location _____
 DPD Test Kit: On-site With operator
 None Not Used Daily
 Injection Points upstream of aerator
 Booster Pump Info N/A
 Comments Satisfactory chlorination

Chlorine Gas Use Requirements	YES	NO	Comments
Dual System	<input type="checkbox"/>	<input type="checkbox"/>	
Auto-switchover	<input type="checkbox"/>	<input type="checkbox"/>	
Alarms:			
Loss of Cl ₂ capability	<input type="checkbox"/>	<input type="checkbox"/>	
Loss of Cl ₂ residual	<input type="checkbox"/>	<input type="checkbox"/>	
Cl ₂ leak detection	<input type="checkbox"/>	<input type="checkbox"/>	
Scale	<input type="checkbox"/>	<input type="checkbox"/>	
Chained Cylinders	<input type="checkbox"/>	<input type="checkbox"/>	
Reserve Supply	<input type="checkbox"/>	<input type="checkbox"/>	
Adequate Air-pak	<input type="checkbox"/>	<input type="checkbox"/>	
Sign of Leaks	<input type="checkbox"/>	<input type="checkbox"/>	
Fresh Ammonia	<input type="checkbox"/>	<input type="checkbox"/>	
Ventilation	<input type="checkbox"/>	<input type="checkbox"/>	
Room Lighting	<input type="checkbox"/>	<input type="checkbox"/>	
Warning Signs	<input type="checkbox"/>	<input type="checkbox"/>	
Repair Kits	<input type="checkbox"/>	<input type="checkbox"/>	
Fitted Wrench	<input type="checkbox"/>	<input type="checkbox"/>	
Housing/Protection	<input type="checkbox"/>	<input type="checkbox"/>	

AERATION (Gases, Fe, & Mn Removal)

Type Cascade Capacity 40 gpm
 Aerator Condition Clean
 Bloodworm Presence No
 Visible Algae Growth None
 Protective Screen Condition Secure, clean
 Comments Aerator is in good operating condition

STORAGE FACILITIES

(G) Ground (H) Hydropneumatic (E) Elevated
 (B) Bladder (C) Clearwell

Tank Type/Number	H	G	AG
Capacity (gal)	1,000	6,000	6,000
Material	Steel	Conc.	Conc.
Gravity Drain	Yes	Yes	Yes
By-pass Piping	Yes	Yes	Yes
Pressure Gauge	Yes	N/A	N/A
Sight Glass or Level Indicator	No	No	Yes
Fittings for Sight Glass	N/A	N/A	N/A
Protected Openings	Yes	Yes	Yes
PRV/ARV	PRV	N/A	N/A
On/Off Pressure	45/55	N/A	N/A
Access Padlocked	Yes	Yes	Yes
Height to Bottom of Elevated Tank	N/A	N/A	N/A
Height to Max. Water Level	N/A	N/A	N/A

Comments Storage tanks appear to be clean and in good operating condition.

HIGH SERVICE PUMPS

Pump Number	1	2
Type	Cent.	Cent.
Make	Peerless	Peerless
Model	C610A	C610A
Capacity (gpm)	20	20
Motor HP	5	5
Date Installed	unk	unk
Maintenance	Good	Good


Comments Pumps appear to be in good condition.

PWS ID # 2540258
 Survey Date 3-Mar-04

COMPLIANCE MONITORING COMMUNITY PUBLIC WATER SYSTEMS serving < 3300 persons			
CONTAMINANT	Last Sampled	Due Date	COMMENTS
Microbiological (Bacti)	xxxxxxx	Monthly	2 distribution samples + 1 from each raw source (based upon population served)
Volatile Organic Contaminants	2003	<u>2004</u>	Annual VOC samples due in 2004
Synthetic Organic Contaminants	2003	<u>2006</u>	SOC's on triennial monitoring.
Nitrate & Nitrite (as N)	2003	<u>2004</u>	Nitrate & Nitrite Samples are due annually
Inorganic Contaminants	2003	<u>2006</u>	Inorganic Contaminants due every 3 years
Asbestos	Waiver	Waiver expires 12/31/2010	Samples taken from distribution. Waiver available if no asbestos pipe in the distribution system.
Secondary Standards	2003	<u>2006</u>	Secondary Standards due every 3 years
Radionuclides	2003	<u>2006</u>	Radionuclides due every 3 years
Disinfection Byproducts [i.e. Total Trihalomethanes (TTHMs) and Haloacetic Acids (HAA5s)];	N/A	<u>2004</u>	Per sampling plan
Lead and Copper	2002	<u>2005</u>	Sample locations are from pre-approved sample plan

Unless otherwise noted, all samples shall be taken at each entry point to the distribution system, and representative of each source after treatment.

SCHEMATIC:



State of Florida
Department of Environmental Protection
Central District
SANITARY SURVEY REPORT

Plant Name SKYCREST S/D County Lake PWS ID # 3351205
Plant Location 36815 Skycrest Blvd., Leesburg Phone 352/787-0980
Owner Name Florida Water Services, Attn: Craig Anderson Phone 407/880-0058
Owner Address P.O. Box 609520, Orlando, FL 32860
Contact Person Will Fontaine Title Lead Operator Phone 352/787-0980
This Survey Date 4/29/04 Last Survey Date 10/3/01 Last C.I. Date 8/24/99

PWS TYPE & CLASS

- Community (5D)
- Non-transient Non-community
- Non-Community

PWS STATUS

- Approved system with approval number & date
HRS #8419, 4/21/66, WC35-8419, 10/2/86
WC35-162398, 6/11/91, WC35-229460, 5/28/93
WC35-242126, 12/27/93
- Unapproved system

SERVICE AREA CHARACTERISTICS

Subdivision _____
Food Service: Yes No N/A

OPERATION & MAINTENANCE

Certified Operator: Yes No Not required
Operator(s) & Certification Class-Number
B. Heath C-5824, W. Fontaine C-6813, J. Worrell
C-6597, G. Kissick C-7846
O & M Log: Yes No Not required
Operator Visitation Frequency
Hrs/day: Required _____ Actual _____
Days/wk: Required 3 Actual 5
Non-consecutive Days? Yes No N/A
MORs submitted regularly? Yes No N/A
Data missing from MORs? No Yes N/A

Number of Service Connections 116
Population Served 291 Basis per MOR
Average Day (from MORs) 25.345 gpd
Max. Day (from MORs) .0515 MGD 6/03
Max-day Design Capacity .126 MGD
Comments _____

COMET: SITE ID _____ PROJECT ID _____

RAW WATER SOURCE

- GROUND; Number of Wells 2
- SURFACE/UDI; Source _____
- PURCHASED from PWS ID # _____
- Emergency Water Source _____
Emergency Water Capacity _____

AUXILIARY POWER SOURCE

Yes None Not Required
Source Olympian generator (propane)
Capacity of Standby (kW) 150
Switchover: Automatic Manual
Standby Plan: Yes No
Hrs Operated Under Load 4 hrs/mo.
What equipment does it operate?
 Well pumps All
 High Service Pumps _____
 Treatment Equipment All
Satisfy 1/2 max-day demand? Yes No Unk
Comments _____

TREATMENT PROCESSES IN USE

Chlorination
What additional treatment is needed?
For control of what deficiencies?

DISTRIBUTION SYSTEM

Flow Measuring Device Flow Meter
Meter Size & Type (1)
Backflow Prevention Devices: Yes No
Cross-connections None observed
Written Cross-connection Control Program: Yes
Coliform Sampling Plan: Yes No N/A
Comments 1) Well #1 4" McCrometer,
Well #2 6" Precision

Received

MAY 12 2004

Environmental Services

PWS ID # 3351205Date 5/6/04**GROUND WATER SOURCE**

Well Number	1	2 Fire		
Year Drilled	UNK	1993		
Depth Drilled	130'	290'		
Drilling Method	UNK	UNK		
Type of Grout	UNK	UNK		
Static Water Level	UNK	UNK		
Pumping Water Level	UNK	UNK		
Design Well Yield	UNK	UNK		
Test Yield	UNK	UNK		
Actual Yield (if different than rated capacity)	UNK	UNK		
Strainer	UNK	UNK		
Length (outside casing)	60'	126'		
Diameter (outside casing)	6"	8"		
Material (outside casing)	Black Steel	Black Steel		
Well Contamination History	None noted	None noted		
Is inundation of well possible?	No	No		
6' X 6' X 4" Concrete Pad	Yes	Yes		
SET BACKS	Septic Tank	>200'	>200'	
	Reuse Water	--	--	
	WW Plumbing	>200'	>200'	
	Other Sanitary Hazard	None observed	None observed	
PUMP	Type	Submersible	Vert. Turbine	
	Manufacturer Name	Goulds	Goulds	
	Model Number	UNK	6DHHO	
	Rated Capacity (gpm)	175	500	
	Motor Horsepower	10	40	
Well casing 12" above grade?	No-Accepted	Yes		
Well Casing Sanitary Seal	Yes	Yes		
Raw Water Sampling Tap	Yes	Yes		
Above Ground Check Valve	Yes	Yes		
Fence/Housing	Yes	Yes		
Well Vent Protection	Yes	--		

COMMENTS Provide additional information for "UNK", if available.

Well #2 is for fire/ emergency. (It is not considered in the design capacity calculations.)

PWS ID # 3351205
 Date 5/6/04

CHLORINATION (Disinfection)

Type: Gas Hypo
 Make Stenner Capacity 34* gpd
 Chlorine Feed Rate (1)
 Avg. Amount of Cl₂ gas used N/A
 Chlorine Residuals: Plant 1.1 Remote 0.5
 Remote tap location 36421 West Drive
 DPD Test Kit: On-site With operator
 None Not Used Daily
 Injection Points Prior to H/1
 Booster Pump Info _____
 Comments *2 - 17gpd chlorinators
1) Well #1- 20, Well #2 - 70% stroke rate.

STORAGE FACILITIES

(G) Ground (H) Hydropneumatic (E) Elevated
 (B) Bladder (C) Clearwell

Tank Type/Number	H/1		
Capacity (gal)	5,000		
Material	Steel		
Gravity Drain	Yes		
By-pass Piping	Yes		
Pressure Gauge	Yes		
Sight Glass or Level Indicator	Yes		
Fittings for Sight Glass	Yes		
Protected Openings	Yes		
PRV/ARV	PRV		
On/Off Pressure	40/60		
Access Padlocked	Yes		
Height to Bottom of Elevated Tank			
Height to Max. Water Level			

Comments _____

Chlorine Gas Use Requirements	YES	NO	Comments
Dual System	<input type="checkbox"/>	<input type="checkbox"/>	
Auto-switchover	<input type="checkbox"/>	<input type="checkbox"/>	
Alarms:			
Loss of Cl ₂ capability	<input type="checkbox"/>	<input type="checkbox"/>	
Loss of Cl ₂ residual	<input type="checkbox"/>	<input type="checkbox"/>	
Cl ₂ leak detection	<input type="checkbox"/>	<input type="checkbox"/>	
Scale	<input type="checkbox"/>	<input type="checkbox"/>	
Chained Cylinders	<input type="checkbox"/>	<input type="checkbox"/>	
Reserve Supply	<input type="checkbox"/>	<input type="checkbox"/>	
Adequate Air-pak	<input type="checkbox"/>	<input type="checkbox"/>	
Sign of Leaks	<input type="checkbox"/>	<input type="checkbox"/>	
Fresh Ammonia	<input type="checkbox"/>	<input type="checkbox"/>	
Ventilation	<input type="checkbox"/>	<input type="checkbox"/>	
Room Lighting	<input type="checkbox"/>	<input type="checkbox"/>	
Warning Signs	<input type="checkbox"/>	<input type="checkbox"/>	
Repair Kits	<input type="checkbox"/>	<input type="checkbox"/>	
Fitted Wrench	<input type="checkbox"/>	<input type="checkbox"/>	
Housing/Protection	<input type="checkbox"/>	<input type="checkbox"/>	

AERATION (Gases, Fe, & Mn Removal)

Type _____ Capacity _____
 Aerator Condition _____
 Bloodworm Presence _____
 Visible Algae Growth _____
 Protective Screen Condition _____
 Comments _____

HIGH SERVICE PUMPS

Pump Number			
Type			
Make			
Model			
Capacity (gpm)			
Motor HP			
Date Installed			
Maintenance			

Comments _____

Docket No. 060368-WS

Application to Increase Rates and Charges

For a "Class A" Utility
In

Florida

Missing Report: Sanitary Survey Report

For: St. John's Highlands

Aqua Utilities Florida, Inc.

State of Florida
Department of Environmental Protection
Central District
SANITARY SURVEY REPORT

Plant Name STONE MOUNTAIN County Lake PWS ID # 3351282
Plant Location 1730 Lakeview Drive, Yalaha, FL Phone 352/787-0980
Owner Name Florida Water Services Attn: Craig Anderson Phone 407/880-0058
Owner Address P.O. Box 609520, Orlando, FL 32860-9520
Contact Person Will Fontaine Title Lead Operator Phone 352/787-0980
This Survey Date 4/29/04 Last Survey Date 6/6/00 Last C.I. Date 10/4/01

PWS TYPE & CLASS

- Community (5D)
- Non-transient Non-community
- Non-Community

PWS STATUS

- Approved system with approval number & date
WC35-2005, 4/14/78
- Unapproved system

SERVICE AREA CHARACTERISTICS

Subdivision _____

Food Service: Yes No N/A

OPERATION & MAINTENANCE

Certified Operator: Yes No Not required
Operator(s) & Certification Class-Number
J. Worrell C-6597, B. Heath C-5824
W. Fontaine C-6813

O & M Log: Yes No Not required
Operator Visitation Frequency

Hrs/day: Required _____ Actual _____
Days/wk: Required 3/wk Actual 5/wk

Non-consecutive Days? Yes No N/A
MORs submitted regularly? Yes No N/A
Data missing from MORs? No Yes N/A

Number of Service Connections 9
Population Served 32 Basis last MOR
Average Day (from MORs) 2,307 gpd
Max. Day (from MORs) .0106 gpd 7/03
Max-day Design Capacity .072 MGD
Comments _____

COMET: SITE ID _____ PROJECT ID _____

RAW WATER SOURCE

- GROUND; Number of Wells 1
- SURFACE/UDI; Source _____
- PURCHASED from PWS ID # _____
- Emergency Water Source _____
Emergency Water Capacity _____

AUXILIARY POWER SOURCE

- Yes None Not Required

Source _____

Capacity of Standby (kW) _____

Switchover: Automatic Manual

Standby Plan: Yes No

Hrs Operated Under Load _____

What equipment does it operate?

- Well pumps _____
- High Service Pumps _____
- Treatment Equipment _____

Satisfy 1/2 max-day demand? Yes No Unk

Comments _____

TREATMENT PROCESSES IN USE

Disinfection _____

What additional treatment is needed? _____

For control of what deficiencies? _____

DISTRIBUTION SYSTEM

Flow Measuring Device _____ Flow Meter _____

Meter Size & Type 2" Neptune 100 gpm

Backflow Prevention Devices: Yes No

Cross-connections None Observed

Written Cross-connection Control Program: Yes

Coliform Sampling Plan: Yes No N/A

Comments _____

Received

MAY 12 2004

Environmental Services

PWS ID # 3351282Date 5/6/04**GROUND WATER SOURCE**

Well Number	1			
Year Drilled	1976			
Depth Drilled	270'			
Drilling Method	UNK			
Type of Grout	UNK			
Static Water Level	56'			
Pumping Water Level	UNK			
Design Well Yield	500 gpm			
Test Yield	UNK			
Actual Yield (if different than rated capacity)	UNK			
Strainer	UNK			
Length (outside casing)	106'4"			
Diameter (outside casing)	8"			
Material (outside casing)	Steel			
Well Contamination History	None noted			
Is inundation of well possible?	No			
6' X 6' X 4" Concrete Pad	Yes			
SET BACKS	Septic Tank	165'		
	Reuse Water	N/A		
	WW Plumbing	>150'		
	Other Sanitary Hazard	*		
PUMP	Type	Submersible		
	Manufacturer Name	Sta-rite		
	Model Number	V1P4E02-01B		
	Rated Capacity (gpm)	100		
	Motor Horsepower	1		
Well casing 12" above grade?	Yes			
Well Casing Sanitary Seal	Yes			
Raw Water Sampling Tap	Yes			
Above Ground Check Valve	Yes			
Fence/Housing	Yes			
Well Vent Protection	Yes			

COMMENTS *Nursery and orange grove near well head area.

PWS ID # 3351282
 Date 5/6/04

CHLORINATION (Disinfection)

Type: Gas Hypo
 Make Chem-Tech Capacity 30 gpd
 Chlorine Feed Rate 50% Stroke
 Avg. Amount of Cl₂ gas used N/A
 Chlorine Residuals: Plant 1.2 Remote .8
 Remote tap location Cnr Stone Mtn & Lakeview
 DPD Test Kit: On-site With operator
 None Not Used Daily
 Injection Points Prior to H/1 & by-pass
 Booster Pump Info _____
 Comments _____

Chlorine Gas Use Requirements	YES	NO	Comments
Dual System	<input type="checkbox"/>	<input type="checkbox"/>	
Auto-switchover	<input type="checkbox"/>	<input type="checkbox"/>	
Alarms:			
Loss of Cl ₂ capability	<input type="checkbox"/>	<input type="checkbox"/>	
Loss of Cl ₂ residual	<input type="checkbox"/>	<input type="checkbox"/>	
Cl ₂ leak detection	<input type="checkbox"/>	<input type="checkbox"/>	
Scale	<input type="checkbox"/>	<input type="checkbox"/>	
Chained Cylinders	<input type="checkbox"/>	<input type="checkbox"/>	
Reserve Supply	<input type="checkbox"/>	<input type="checkbox"/>	
Adequate Air-pak	<input type="checkbox"/>	<input type="checkbox"/>	
Sign of Leaks	<input type="checkbox"/>	<input type="checkbox"/>	
Fresh Ammonia	<input type="checkbox"/>	<input type="checkbox"/>	
Ventilation	<input type="checkbox"/>	<input type="checkbox"/>	
Room Lighting	<input type="checkbox"/>	<input type="checkbox"/>	
Warning Signs	<input type="checkbox"/>	<input type="checkbox"/>	
Repair Kits	<input type="checkbox"/>	<input type="checkbox"/>	
Fitted Wrench	<input type="checkbox"/>	<input type="checkbox"/>	
Housing/Protection	<input type="checkbox"/>	<input type="checkbox"/>	

AERATION (Gases, Fe, & Mn Removal)

Type _____ Capacity _____
 Aerator Condition _____
 Bloodworm Presence _____
 Visible Algae Growth _____
 Protective Screen Condition _____
 Comments _____

STORAGE FACILITIES

(G) Ground (H) Hydropneumatic (E) Elevated
 (B) Bladder (C) Clearwell

Tank Type/Number	H/1		
Capacity (gal)	1,000		
Material	Steel		
Gravity Drain	Yes		
By-pass Piping	Yes		
Pressure Gauge	Yes		
Sight Glass or Level Indicator	Yes		
Fittings for Sight Glass	Yes		
Protected Openings	Yes		
PRV/ARV	PRV		
On/Off Pressure	35/53		
Access Padlocked	Yes		
Height to Bottom of Elevated Tank			
Height to Max. Water Level			

Comments _____

HIGH SERVICE PUMPS

Pump Number			
Type			
Make			
Model			
Capacity (gpm)			
Motor HP			
Date Installed			
Maintenance			

Comments _____

PWS ID # 3351282
Date 5/6/04

MONITORING VIOLATIONS	MCL VIOLATIONS


DEFICIENCIES:

Overall, the plant looked good!!

Keep up the good work!!

Inspector *KHL* Title Env. Specialist I Date 5/6/04

Approved by *Roberto C. Gomez* Title Env. Manager Date 5/7/04



Jeb Bush
Governor

Department of Environmental Protection

Central District
3319 Maguire Boulevard, Suite 232
Orlando, Florida 32803-3767

Colleen M. Castille
Secretary

January 10, 2005

Mr. Will Fontaine
Aqua Utilities
P.O. Box 490310
Leesburg, FL 34749-0310

OCD-PW-SS-05-0019

Lake County – PW
48 Estates – 3350005
King's Cove – 3350655
→ Summit Chase – 3354112

Haines Creek – 3350481
Ravenswood – 3351062

Dear Mr. Fontaine:

The Department conducted an inspection of your public water systems on October 26, 2004. This inspection was conducted by Karen Milicic of this office in the presence of Will Fontaine. Copies of the Sanitary Survey Reports are enclosed for your reference and records.

There were no deficiencies at your water plant at the time of our visit. The overall operation of the water plant was good, which is a credit to both you and your operator. The Department appreciates the excellent work being done on your water system and values your continued spirit of cooperation in complying with Department rules.

The Department values your continued cooperation in operating and maintaining your water system, and appreciates the assistance provided during the sanitary survey.

If you have any questions concerning this letter, please contact Karen Milicic at the above address or by phone at (407) 894-7555, extension 2226.

Sincerely,


Roberto C. Ansay, Environmental Manager
Drinking Water Compliance/Enforcement

RCA/km
Enclosure

"More Protection, Less Process"

Printed on recycled paper.

State of Florida
 Department of Environmental Protection
 Central District
SANITARY SURVEY REPORT

Plant Name SUMMIT CHASE County Lake PWS ID # 3354112
 Plant Location Tavares Ridge Road, Tavares, FL Phone 877/369-4880
 Owner Name Aqua Utilities, Attn: Will Fontaine Phone 877/369-4880
 Owner Address P.O. Box 490310, Leesburg, FL 34749-0310
 Contact Person W. Fontaine Title Operator Phone 877/369-4880
 This Survey Date 10/26/04 Last Survey Date 4/17/03 Last C.I. Date 9/20/00

PWS TYPE & CLASS

- Community (5D)
- Non-transient Non-community
- Non-Community

PWS STATUS

- Approved system with approval number & date
WC35-2066, 11/82, WC35-2066A, 11/88
WC35-259244, 12/8/94
- Unapproved system

SERVICE AREA CHARACTERISTICS

Subdivision _____
 Food Service: Yes No N/A

OPERATION & MAINTENANCE

Certified Operator: Yes No Not required
 Operator(s) & Certification Class-Number
W. Fontaine C-6813, M. Neal C-10027
J. Worrell C-6597
 O & M Log: Yes No Not required
 Operator Visitation Frequency
 Hrs/day: Required -- Actual --
 Days/wk: Required 6/wk Actual 6/wk
 Non-consecutive Days? Yes No N/A
 MORs submitted regularly? Yes No N/A
 Data missing from MORs? No Yes N/A

Number of Service Connections 220
 Population Served 162 Basis 10/04 MOR
 Average Day (from MORs) .0817 MGD
 Max. Day (from MORs) .096 MGD 5/04
 Max-day Design Capacity .4896 MGD
 Comments _____

COMET: SITE ID _____ PROJECT ID _____

RAW WATER SOURCE

- GROUND; Number of Wells 2
- SURFACE/UDI; Source _____
- PURCHASED from PWS ID # _____
- Emergency Water Source _____
 Emergency Water Capacity _____

AUXILIARY POWER SOURCE

Yes None Not Required
 Source Katolight Model no. 12TC2 (propane)
 Capacity of Standby (kW) 23
 Switchover: Automatic Manual
 Standby Plan: Yes No
 Hrs Operated Under Load 1 hr/wk.
 What equipment does it operate?
 Well pumps All
 High Service Pumps _____
 Treatment Equipment All
 Satisfy 1/2 max-day demand? Yes No Unk
 Comments _____

TREATMENT PROCESSES IN USE

Chlorination
 What additional treatment is needed?

 For control of what deficiencies?

DISTRIBUTION SYSTEM

Flow Measuring Device Flow Meter
 Meter Size & Type 6" McCrometer
 Backflow Prevention Devices: Yes No
 Cross-connections None observed
 Written Cross-connection Control Program: Yes
 Coliform Sampling Plan: Yes No N/A
 Comments _____

PWS ID # 3354112Date 1/10/05**GROUND WATER SOURCE**

Well Number	1(east)	2(west)	1 (Modified)	
Year Drilled	1982	1987	1994	
Depth Drilled	278'	278'	320'	
Drilling Method	Cable tool	Combination	Combination	
Type of Grout	Neat Cement	UNK	Cement	
Static Water Level	48'	UNK	50'	
Pumping Water Level	UNK	UNK	UNK	
Design Well Yield	UNK	UNK	UNK	
Test Yield	UNK	UNK	600 gpm	
Actual Yield (if different than rated capacity)	UNK	UNK	UNK	
Strainer	Open	UNK	UNK	
Length (outside casing)	159.5'	159'	155'	
Diameter (outside casing)	8"	6"	8"	
Material (outside casing)	Black steel	Black steel	Black steel	
Well Contamination History	None noted	None noted	None noted	
Is inundation of well possible?	No	No	No	
6' X 6' X 4" Concrete Pad	Yes	Yes	Yes	
SET BACKS	Septic Tank	--	--	--
	Reuse Water	--	--	--
	WW Plumbing	>100'	>100'	>100'
	Other Sanitary Hazard	None noted	None noted	None noted
PUMP	Type	Vert. Turbine	Submersible	Vert. Turbine
	Manufacturer Name	Goulds	Franklin	
	Model Number	UNK	2366026010	
	Rated Capacity (gpm)	550	80	600
	Motor Horsepower	40	10	
Well casing 12" above grade?	Yes	Yes		
Well Casing Sanitary Seal	Yes	Yes		
Raw Water Sampling Tap	Yes	Yes		
Above Ground Check Valve	Yes	Yes		
Fence/Housing	Yes	Yes		
Well Vent Protection	--	--		

COMMENTS _____

PWS ID # 3354112
 Date 1/10/05

CHLORINATION (Disinfection)

Type: Gas Hypo
 Make Stenner Capacity 17 gpd
 Chlorine Feed Rate Well 1 - 80 %, Well 2 - 30%
 Avg. Amount of Cl₂ gas used N/A
 Chlorine Residuals: Plant 1.01 Remote .97
 Remote tap location 12539 Orangewood Ct.
 DPD Test Kit: On-site With operator
 None Not Used Daily
 Injection Points Prior to H/1 & By-pass
 Booster Pump Info _____
 Comments Has 175 gal. tank

STORAGE FACILITIES

(G) Ground (H) Hydropneumatic (E) Elevated
 (B) Bladder (C) Clearwell

Tank Type/Number	H/1		
Capacity (gal)	5,000		
Material	Steel		
Gravity Drain	Yes		
By-pass Piping	Yes		
Pressure Gauge	Yes		
Sight Glass or Level Indicator	Yes		
Fittings for Sight Glass	Yes		
Protected Openings	Yes		
PRV/ARV	PRV		
On/Off Pressure	40/60		
Access Padlocked	Yes		
Height to Bottom of Elevated Tank			
Height to Max. Water Level			

Comments Tank replaced in 2004

Chlorine Gas Use Requirements	YES	NO	Comments
Dual System	<input type="checkbox"/>	<input type="checkbox"/>	
Auto-switchover	<input type="checkbox"/>	<input type="checkbox"/>	
Alarms:			
Loss of Cl ₂ capability	<input type="checkbox"/>	<input type="checkbox"/>	
Loss of Cl ₂ residual	<input type="checkbox"/>	<input type="checkbox"/>	
Cl ₂ leak detection	<input type="checkbox"/>	<input type="checkbox"/>	
Scale	<input type="checkbox"/>	<input type="checkbox"/>	
Chained Cylinders	<input type="checkbox"/>	<input type="checkbox"/>	
Reserve Supply	<input type="checkbox"/>	<input type="checkbox"/>	
Adequate Air-pak	<input type="checkbox"/>	<input type="checkbox"/>	
Sign of Leaks	<input type="checkbox"/>	<input type="checkbox"/>	
Fresh Ammonia	<input type="checkbox"/>	<input type="checkbox"/>	
Ventilation	<input type="checkbox"/>	<input type="checkbox"/>	
Room Lighting	<input type="checkbox"/>	<input type="checkbox"/>	
Warning Signs	<input type="checkbox"/>	<input type="checkbox"/>	
Repair Kits	<input type="checkbox"/>	<input type="checkbox"/>	
Fitted Wrench	<input type="checkbox"/>	<input type="checkbox"/>	
Housing/Protection	<input type="checkbox"/>	<input type="checkbox"/>	

AERATION (Gases, Fe, & Mn Removal)

Type _____ Capacity _____
 Aerator Condition _____
 Bloodworm Presence _____
 Visible Algae Growth _____
 Protective Screen Condition _____
 Comments _____

HIGH SERVICE PUMPS

Pump Number			
Type			
Make			
Model			
Capacity (gpm)			
Motor HP			
Date Installed			
Maintenance			

Comments _____



Jeb Bush
Governor

Department of Environmental Protection

Panama City Branch Office
2353 Jenks Ave
Panama City, FL 32405-4389
(850) 872-4375

69
RECIEVED
1/17/06

Colleen M. Castille
Secretary

January 5, 2006

Mr. Brian Heath,
Supervisor, Sunny Hills Utilities
Aqua Utilities Florida
P.O. Box 490310
Leesburg, FL 34749

Dear Mr. Heath,


A Sanitary Survey of the Sunny Hills Utilities public water system (PWS ID #1670647) was conducted on December 5th, 2005 by David Hines and Jerry Sheehan, Environmental Specialists of this office. The assistance kindly provided during the inspection by your operator, Ms. Jean Pitzer, was most helpful.

The purpose of this survey was to evaluate the capability of the water system to continually produce safe drinking water. Public water systems in this state are regulated by the Department under the Florida Safe Drinking Water Act as promulgated by Florida Administrative Code Chapters 62-550, 555 and 560. The Department determines compliance with these regulations.

Two deficiencies were identified during the survey, as described in the enclosed *Schedule of Deficiencies*. **We would appreciate a written response within 15 days of receipt of this letter advising us of the actions and time frames planned for correcting these deficiencies.** In addition, four other recommendations listed do not require a written response, but, of these, two do advise that studies be performed this year on your system's water loss and storage capacity. Please address your response to David Hines, Department of Environmental Protection, 2353 Jenks Avenue, Panama City, FL 32405.

If you have any questions, please contact Mr. Hines at (850) 872-4375 extension 106 or by e-mail at david.hines@dep.state.fl.us.

Sincerely,


Josie Penton
Environmental Manager

JP:dh

cc: Ms. Jean Pitzer - Sunny Hills Utilities
John Pope - DEP Pensacola
Tom Pratt - NFWMD

"More Protection, Less Process"

Printed on recycled paper.



STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION
SANITARY SURVEY REPORT
COMMUNITY SYSTEMS

SYSTEM AND OWNER INFORMATION

System Sunny Hills Utilities County Washington PWS ID # 1670647
 Address 3810 Gables Blvd., City Sunny Hills, FL 32428
 Phone 850-773-2802 Fax 850-773-2626 E-mail Jpitzer@aquaaamerica.com
 Owner Aqua Utilities Florida (Brian Heath, Supervisor) Phone 352-787-0980
(Candice, ext-4020) Fax 352-787-6333
 Address P.O. Box 490310 E-mail bheath@aquaaamerica.com
Leesburg, FL 34749

INSPECTION AND CONTACT INFORMATION

Date of this survey December 5, 2005 Date of last survey April 29, 2004
 DEP Representative(s) David Hines & Jerry Sheehan
 Person(s) Contacted Jean Pitzer (Operator), Ken Ledbetter (Maintenance)
 Emergency Number 258-8155 (Ken Ledbetter, Maint. Tech.) Cell 850-527-1529 Pager _____ Other _____

CERTIFIED OPERATORS AND CERTIFICATION NUMBER

Jean Pitzer #C 7605

DIRECTIONS TO PLANT OR OFFICE (see maps on page 12)

From the Panama City Branch Office go left (north) on Jenks Ave. and turn right (east) on Baldwin Rd. At Hwy 77, turn left (north) and follow this route approximately 24 miles and turn right on Sunny Hills Blvd. About 1 mile in, turn left on Gables Blvd. Water system is 1/4 mile in on the left.

SERVICE AREA

Service Area Sunny Hills is a residential community developed by Deltona Corporation.
 Characteristics There are approximately 500 home sites built, with 3000 more planned.

Population Served 1747 Basis Meter records
 Service Connections 499 % Metered 100
 Design Capacity (DC) (gallons) 1,872,000
 DC without best well 1,008,000
 Storage Capacity 87,500 Avg. Day 172,984
 Max. Day (GPD) 1,211,000 % Design Capacity 65%
 25% Max. Day 302,750 % Storage Capacity 346%

	NAME	PHONE NUMBER
Television	WMBB Ch 13 WJHG Ch 7	763-6000 233-1977
Radio TV	Styles Media	230-5855 (258-6381)
Radio FM	Styles Media	230-5855 (258-6381)
Newspaper	P.C. News Herald	747-5000

STANDBY POWER REQUIREMENTS

Emergency Preparedness Plan On file: Yes No Not Required
 Does plan include the following:
 Communication Chart Written Agreements Disaster Plan
 Standby Power Info Inventories Other
 Avg. Day Percentage of Auxiliary Supply _____
 Standby Equipment Operated at Least Monthly? Yes No
 Any Interconnects Yes No
 If yes, which systems: _____
 Comments: _____

PERMANENT SOURCES OF RAW WATER:

Ground* How Many Wells 3 (one offline)
 Surface** Source Floridan Aquifer
 Purchased*** PWS No. 1670647

EMERGENCY MEDIA CONTACT NUMBERS

TREATMENT IN USE AT THIS PLANT: (CHECK ALL THAT APPLY)

Number of Plants 3

Aeration E.D. Iron Removal (Well #1) pH Adjustment Chlorination
 Filtration (Well #1) Lime Softening T&O Control Chlorination-Pre Filt. Hi-Rate
 Recarbonation Settling (Well #1) Chlorination-Post Fluoridation Reverse Osmosis
 Zeolite Softener Coagulation Orthophosphate Aqua Mag Other-Specify

Any additional treatment is needed? _____ For control of what deficiencies? _____

Number of Licensed Operators 1 Plant Cat/Class 5C Staffing compliant? Yes No Actual visits per week: 6

WELL AND PUMP INFORMATION

Well Number (or name) →	1 (out of service)	4	5
Street location of well (street name)	3810 Gables Blvd. (@ System Office)	Cash Circle	Elkcam Blvd.
Year Drilled	1971	1973	1977
W Depth Drilled (feet)	433'	436'	400'
E Drilling Method	Rotary	Rotary	Rotary
L Length, Outside Casing (feet)	433'	204'	199'
L Diameter, Outside Casing (inches)	18"	12"	6"
Material, Outside Casing	Steel	Steel	Steel
D Type of Strainer	None	None	None
A Depth to Top of Strainer	N/A	N/A	N/A
T Type of Grout	Cement	Cement	Cement
A Depth to Static Water Level (feet)	86'	198'	156'
Normal Suction Lift (working level-ft)	94'	205'	158'
P Pump Type	Turbine (now water lubed)	Turbine	Turbine
U Horse Power	30	60	20
M Normal Yield, GPM / Test Yield (GPM)	500	600	200
P Capacity(GPM)	510	517	200
R Protection From Surface Water	Yes	Yes	Yes
O Is Inundation of Well Possible?	No	No	No
U Well Ever Been Contaminated?	No	No	No
T Check Valve Present in Line?	Yes	Yes	Yes
I Proper Venting?	Yes	Yes	Yes
N Meter Accuracy and Year of Test	See comments**	3/15/05 (FRWA)	3/15/05 (FRWA)
E Date of Last Servicing?	2005	2000	2000
A Auxiliary Capability (if yes, list type)	Yes (LP gas generator)	Yes (Kohler Diesel)	Yes (LP gas generator)
U Manual or Automatic?	Manual	Automatic	Manual
X Capacity (GPM)	500	600	200
G Florida Unique ID# (GPS well tag)	AAA5155	AAA5156	AAA1095
P GPS latitude N (accuracy≈1m)	30:32:39.3230	30:32:09.0000	30:33:33.058
S GPS longitude W (accuracy≈1m)	85:35:51.7800	85:35:55.0000	85:31:46.963

Comments: Well #1 offline since 4/4/05 for repairs. Recased to 433' in attempt to reduce iron problem there.
Pump bearings just replaced; Plan to start 20 bacti-s on 1/3/06 to restart pump and reassess iron situation.
**Meter accuracy test at Well #1 required larger gauge equipment than FRWA had on hand; test abandoned.

Sunny Hills Utilities – Sanitary Survey of December 5, 2005

PWS I.D. No. 1670647

TREATMENT**• CHLORINATOR**

PLANT NUMBER (OR NAME) →	1 (out of service)	2	3	comment
Type of chlorination (if hypo list strength)	Hypo (12.5%)	Hypo (12.5%)	Hypo (12.5%)	
Condition of Chlorination Equipment	Good	Good	Good	
Capacity (PPD, GPD)	30 gpd	30 gpd	30 gpd	
Chlorine Feed Rate (PPD, GPD)	N/A (usually 2 gpd)	1 gpd	0.17 gpd	
Adequate Housing and Security?	Yes	Yes	Yes - pumphouse door needs replacement (already ordered)	
Associated Well(s) (if any)	None	None	None	
Auxiliary Power Capability?	Yes	Yes	Yes	
O & M Log/Manual Onsite?	Yes	Yes	Yes	
Chlorine Residual (mg/L) / pH	Out of service	0.71 mg/L @ pH = 7.8	1.66 mg/L @ pH = 7.6	
G Chlorine Alarms Functional?	N/A	N/A	N/A	
G Auto Switchover	N/A	N/A	N/A	
G Dual System	N/A	N/A	N/A	
A Evidence of Leaks	N/A	N/A	N/A	
A Air-Pack Respirator Adequate?	N/A	N/A	N/A	
A Ammonia Smells Fresh	N/A	N/A	N/A	
S Chained Cylinders	N/A	N/A	N/A	
S Fitted Wrench	N/A	N/A	N/A	
S Proper Ventilation	N/A	N/A	N/A	
S Scale Condition	N/A	N/A	N/A	

Spare Parts/Backups Operative? Yes No Spare Parts Not Retained More capacity needed? Yes No

Comments: Hypochlorite solution is pumped full-strength directly from shipping drums. No daytanks are used at any of this facility's treatment plants.

Sunny Hills Utilities – Sanitary Survey of December 5, 2005

PWS I.D. No. 1670647

AERATOR

Type of Aerator N/A
 Tray Area or Weir Length _____
 Condition of Screens _____
 Bloodworms _____ Condition of aerator _____
 Adequate for Fe, H2S control _____

COAGULATION

Chemical used N/A
 Purpose _____
 Blanket visible _____ Flocculation good or poor _____
 Settling good? _____ Carryover _____

LIME SOFTENING

Quicklime or hydrated N/A
 Name of unit _____
 Size and type _____
 Any auxiliary chemicals used _____
 Points of application (in unit) _____
 Nature and abundance of flux _____
 Appearance of sludge blanket _____
 Is settling good? _____ Excessive carryover _____
 Any filter cementation _____
 Effluent stability _____
 Turbidity in clearwell _____ Secondary precipitation _____
 Recarbonation type _____
 Sludge recirculation Used _____

FLUORIDATION

Chemical Used Is Dilution N/A
 Strength if Acid _____ Used(acid) _____
 Corrosion Noted Feeder _____
 Gelling or Plugging _____
 Make and Model _____
 Split Sample Agreement _____
 Sufficient Analysis _____
 Feeder Condition _____

Is pH control Practiced? N/A
 Is a index computed? Yes No (if so, check below below)
 Langelier Ryznar Puckorius Larson
 Stiff Oddo Other _____
 Results of index _____
 Chemical(s) used _____

FILTERS & FILTRATION

Type of Well #1 only - Rapid sand filters
 filters (out of service)
 Size and number (2) 25.45 sq. ft.
 Length of filter runs 15 minutes
 Can you see filter media? N/A Clean after backwash? N/A
 Are mudballs visible? N/A Binding? N/A
 What is the normal filter rate 200 gpm/filter
 What is the usual backwash rate? 1500 gpm
 Capacity of filters 200 gpm Filters overloaded? N/A
 Loss in head gauge present? No
 At what head loss is BW done? Unknown
 Cracks and channeling? N/A Cementation ever occurred? Unk
 Where in relation to filtration is stabilization done? N/A
 If high rate, what is turbidity at interface Range of turbidity in effluent _____
 Can you observe algae in filters? N/A
 Distance from top of media to trough overflow Unknown

REVERSE OSMOSIS

Make and type of units N/A
 Pressure required _____
 Auxiliary chemicals _____
 Proportion of waste used to product streams _____
 Quality of effluent _____ Stabilization _____
 Type of Pre-treatment _____ Booster pump _____
 Type of membranes _____

ZEOLITE SOFTENING

Unit mfg. & model N/A
 Resin capacity _____ Disinfection of beds _____
 Grade of salt for regen. _____
 Stability of effluent _____ Resin prevented from escaping? _____

Sunny Hills Utilities – Sanitary Survey of December 5, 2005

PWS I.D. No. 1670647

PUMP CATEGORY: High-Service @ Well #1 (all out of service)							
PUMP NUMBER →	1	2	3				
PUMP TYPE	Peerless	Peerless	Peerless				
MOTOR HP	10 HP	25 HP	25 HP				
DATE INSTALLED	06/72	06/72	06/83				
CAPACITY (GPM)	100	200	200				
AUXILIARY CAPACITY?							
PROPER SECURITY?	Yes	Yes	Yes				
CONDITION OF PUMP	Good	Good	Good				
MAINT. SCHEDULE	Out of service	Out of service	Out of service				
DATE LAST SERVICED	Routine	Routine	Routine				

STORAGE FACILITIES:

TANK NUMBER →	1A	1B	1C
TYPE (GROUND, ELEVATED, HYPO)	Hydro	Hydro	Hydro
YEAR OF CONSTRUCTION			
CAPACITY (GALLONS)	30,000	30,000	10,000
MATERIAL	Steel	Steel	Steel
GRAVITY DRAIN CAPACITY/DIAMETER	6"	6"	6"
OVERFLOW STRUCTURES PROPER?	N/A	N/A	N/A
BYPASS CAPACITY	Yes	Yes	Yes
COVERED/SCREENED OPENINGS	N/A	N/A	N/A
PRESSURE GAUGE	Yes	Yes	Yes
ON/OFF PRESSURE (PSI)	Out of service	Out of service	Out of service
HGT. TO BOTTOM OF EL. TANK (FT)	N/A	N/A	N/A
HGT. TO MAX. WTR. LEVEL (FT)	N/A	N/A	N/A
DATE OF LAST ANNUAL INSPECTION	Ongoing	Ongoing	Ongoing
YEAR OF LAST 5-YEAR INSPECTION	2002	2002	2002
YEAR OF LAST WASHOUT	Uncertain (2002?)	Uncertain (2002?)	Uncertain (2002?)

Sunny Hills Utilities – Sanitary Survey of December 5, 2005

PWS I.D. No. 1670647

STORAGE FACILITIES:

TANK NUMBER→	4	5	
TYPE (GROUND, ELEVATED, HYPO)	Hydro	Hydro	
YEAR OF CONSTRUCTION	1993	1977	
CAPACITY (GALLONS)	10,000	7,500	
MATERIAL	Steel	Steel	
GRAVITY DRAIN CAPACITY/DIAMETER	6"	6"	
OVERFLOW STRUCTURES PROPER?	N/A	N/A	
BYPASS CAPACITY	Yes	Yes	
COVERED/SCREENED OPENINGS	N/A	N/A	
PRESSURE GAUGE	Yes	Yes	
ON/OFF PRESSURE (PSI)	50/60	42/52	
HGT. TO BOTTOM OF EL. TANK (FT)	N/A	N/A	
HGT. TO MAX. WTR. LEVEL(FT)	N/A	N/A	
DATE OF LAST ANNUAL INSPECTION	Ongoing	Ongoing	
YEAR OF LAST 5-YEAR INSPECTION	2002	2002	
YEAR OF LAST WASHOUT	Uncertain (2002?)	Uncertain (2002?)	
Does system provide fire protection? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Security Adequate? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Low Level Alarm? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Does current storage capacity comply with requirements in FAC 62-555? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
COMMENTS: Sight glasses on Tanks 4 and 5 have been removed for the winter to prevent freezing.			

DISTRIBUTION SYSTEM

Material of mains? Cast iron and PVC System looped? No How many hydrants? 92 new/25 old
 Any fire hydrants < 6" lines? Yes No Unknown Max. pipe diameter 16" Min. pipe diameter 4"
 General operation pressure 50/60# Lowest pressures 50 Location of low pressure Home on Zinnia Dr.
 Number of dead ends 60 How many without flush hydrants? None Flushing program? Monthly
 # of line valves Unknown How often exercised Monthly Properly Mapped? Yes Properly Marked? See comments
 System Maps Adequate? Yes Any uncleared permits? 2 Any uncleared and in use? No
 Percent water loss: Jan-05 47.8% Apr-05 34.5% Aug-05 14.0%
 Feb-05 51.7% May-05 38.0% Sep-05 45.5%
 Mar-05 44.4% Jun-05 35.9% Oct-05 8.0%
 Jul-05 33.3% Nov-05 17.0%
 Does the system have No reuse? No Comments: All valves were marked until recent paving was done in some areas. These are currently being re-marked.

CROSS CONNECTION CONTROL (C3)

Cross Connection Control (C3) Program Meet Requirements? Yes No (See comments below and deficiencies)

Comment:

Annual Testing - Annual testing on existing RPZ devices is not being performed by the water system, nor are they currently requiring either commercial or residential customers to submit their own test reports. For the coming year, a plumbing company has been contracted to resume testing.

Auxiliary Water Systems - New homes with irrigation systems are being built w/ RPZ's. Existing homes have been prohibited by ordinance from connecting wells to their homes, but it is known that approximately 90 of the system's customers have private wells, some of which are connected to the PWS. Until a connection is discovered, the issue is apparently not addressed. Upon discovery of an actual connection to the PWS, the system tells the owner to install a backflow device. If they refuse to install, however, no consistent action is currently being taken. Since 1996, both the current and former operators have tracked known and suspected wells through water-use records, visual observations, etc. They have addressed the situation with letters to Southern States Utilities (the system's former owner), verbal communications with the Health Department and county officials (notifying them as instances arose), and written and verbal communications with individual homeowners themselves. Despite their efforts, the problem continues. While up to fifteen homes may have been disconnected in the past for non-compliance, for the most part the Utility has stopped short of this in order to preserve their customer base. Two existing homes have installed RPZ's at the request of the current operator and she has gotten authorization from the Utility to mail letters to all homeowners with private wells, informing them of the requirement for RPZ's whether or not wells are connected. The Utility's C3 program manual contains several sample letters to be used for communicating with customers on this issue (attached), but the actual policy to be followed here in the event of non-compliance remains to be determined.

Testing Frequency N/A Tracking: Hard Copy CPU # of BFDs: 47 (plus 5 at a closed business) Hydrant Meters Lift Stations WWTP
 Date of Last Audit (commercial or residential): N/A Name of Certified BFD Tester: Corbitt Moseley's Plumbing Co.; (Possibly also former operator, Harold Register)

Chlorine & pH	Remote 1	Remote 2	Remote 3	Remote 4
Chlorine Residual	1.24 mg/L			
pH	7.6			
Location	Hydrant @ Ainsworth Dr. & Florence Ct.			

COMPLIANCE MONITORING

Compliance Schedule: The following parameters are due during the year shown.

Inorganics	2006	SOCs	2006**	TTHMs/HAA5	2006	Asbestos	2012
VOCs	2006	Radiologicals	2009	Secondaries	2006	Pb & Cu	2008

Comment: ****SOC's** - May apply for waiver for 2006. Regardless of the waiver, sampling for di(2-ethylhexyl)phthalate at Wells 1, 4 and 5 still required annually (due 2006).


System out of compliance with any of the above parameters?

Testing Equipment & Reagents Adequate Inadequate Comment: _____
 Bacteriological Sampling Plan: Adequate Inadequate Comment: Submitted 12/30/05; contains map.
 Disinfection Byproducts Plan: Adequate Inadequate Comment: Submitted 12/20/05; contains map.

How is the system structured? Investor Municipal Private Cooperative Other Does the system follow a budget? Yes No
 Preventative Maintenance Program in place? Yes No Is adequate training provided to water system personnel? Yes No

Comment: **Budget:** Aqua Florida plans a \$20M budget for 2006 for system expansion and the hiring of one or two additional employees. At least 90 additional service connections are planned for this year.
Training: Ms. Pitzer has recently (Dec. 2005) attended FRWA training on "Pumps" and is scheduled to take their "Focus on Change" seminar at Gulf Coast Community College in Feb 2006.

System Diagram
SUNNY HILLS WATER SYSTEM
 PWS ID# 1670647
 SANITARY SURVEY OF DECEMBER 5, 2005



Schedule of Deficiencies
SUNNY HILLS WATER SYSTEM
PWS ID# 1670647
SANITARY SURVEY OF DECEMBER 5, 2005

DEFICIENCY #1: CROSS CONNECTION CONTROL (C3) PROGRAM.

It was noted during the survey that the Utility's existing C3 program, outlined in their *Backflow Prevention Policy Manual*, is not being consistently implemented. Approximately ninety private wells are known to exist within the franchise area. Customers with these auxiliary water systems are not being required to install backflow prevention devices however, until it is known that they have connected to the PWS. In most cases, despite the Utility's efforts, these customers are not complying, but the Utility has stopped short of disconnection in an effort to preserve their customer base. As a result, in the event of a drop in system pressure, from Point A to Point B, it may not be certain whose water is actually in the distribution system.

It was also noted that existing backflow devices were lacking timely annual testing. AWWA Manual 14 states, in part, that it shall be the duty of the water system to insure, at any premises where backflow-prevention assemblies are installed, that certified inspections and operational tests are made at least once per year.

REGULATION REFERENCE: FAC Rule 62-555.360

Community water systems, and all public water systems that have service areas also served by reclaimed water systems regulated under Part III of Chapter 62-610, F.A.C., shall establish and implement a routine cross-connection control program to detect and control cross-connections and prevent backflow of contaminants into the water system. This program shall include a written plan that is developed using recommended practices of the American Water Works Association set forth in Recommended Practice for Backflow Prevention and Cross-Connection Control, AWWA Manual M14, as incorporated into Rule 62-555.330, F.A.C. AWWA recommends that C3 programs should require the installation and annual testing of a backflow prevention device of the reduced-pressure zone (RPZ) type at each service connection where the existence of an auxiliary water system on the property is either known or discovered. This should be done regardless of whether the auxiliary system is actually connected to the PWS, due to the potential high hazard posed by an unproven source of water on the premises and the ease of connection to the PWS.

RECOMMENDED ACTION:

- 1) Please develop your policies to be followed in the event of customer non-compliance on this issue (installation and/or testing) and implement your cross-connection control program as soon as possible within 90 days.
- 2) Arrange to have existing backflow preventers (RPZ, double-check valve) tested on an annual basis by a certified backflow prevention device tester. The testing should be completed no later than December 31, 2006.
- 3) Retain for at least 10 years accurate records of all backflow installation and testing and have them available for review during routine inspections and sanitary surveys.
- 4) It is also recommended that adequate training be provided to staff and education to the public in order to support and promote the program.

DEFICIENCY #2: WASHOUT FOR STORAGE FACILITIES REQUIRED EVERY 5 YEARS.

It was noted during the survey that documentation of washouts of your storage tanks in the last five years could not be found.

REGULATION REFERENCE: FAC Rules 62-555.350(2)

Finished-drinking-water storage tanks, including conventional hydropneumatic tanks with an access manhole but excluding bladder- or diaphragm-type hydropneumatic tanks without an access manhole, shall be checked at least annually to ensure that hatches are closed and screens are in place; shall be cleaned at least once every five years to remove biogrowths, calcium or iron/manganese deposits, and sludge from inside the tanks; and shall be inspected for structural and coating integrity at least once every five years by personnel under the responsible charge of a professional engineer licensed in Florida.

RECOMMENDED ACTION:

Please review your records further to ensure that your storage tanks have been washed-out in the last five years. If so, please forward that documentation to this office. If not, please perform the required actions referenced above, document, and forward a copy to this office within 90 days.

Recommendations and Remarks

Recordkeeping on the Premises

While it was noted that only one required record from the last year was missing from your files, (the MOR for April 2005, which had been submitted properly but a file copy had not been made due to a computer malfunction), **improved recordkeeping procedures would ease review at your next inspection.** The requirements for record retention for all documents relating to your water system are listed below.

REGULATION REFERENCE: FAC RULE 62-550.720

RECOMMENDED ACTION:

Retain on the premises of the public water system treatment plant or at a convenient location near the premises, the following records:

- (1) Records of bacteriological analyses shall be kept for not less than 5 years. Records of chemical analyses made shall be kept for not less than 10 years.
- (2) Records of action taken by the system to correct a violation of primary drinking water regulations shall be kept for a period not less than 3 years after the last action taken with respect to the particular violation involved.
- (3) Copies of any written reports, summaries, or communications relating to cross connection control programs or sanitary surveys of the system conducted by any local, State, or Federal agency, shall be kept for a period not less than 10 years after completion of the sanitary survey.
- (4) Records concerning a variance or exemption granted to the system shall be kept for a period ending not less than 5 years following the expiration of the variance and exemption.
- (5) Water plant operation reports shall be kept for a period of not less than 5 years.

Preventative Maintenance (PM) Program

Improper maintenance can lead to system failures and sanitary deficiencies. A written PM should be established and followed for each piece of equipment in the pumping facility. The programs should be based on manufacturers' recommended maintenance tasks, and records should be kept of maintenance as it is performed. In general, smaller water systems need much less sophisticated PM programs, however, all water system should have a program in place, even if it is very basic. Critical components of a PM program include:

- Equipment Inventory
- Manufacturers' Technical Literature
- Written PM Tasks and Schedule
- Records of Maintenance Performed
- List of Technical Resources
- Tools
- Spare Parts Inventory

The Department recommends that a PM program be established and implemented to prevent system failures and sanitary deficiencies. **The Department is pleased that the hiring of additional personnel is planned for this year to assist with this effort.**


Water Loss

A review of the pumping vs. sold statistics during the inspection indicated that the system's annual water loss for 2005 (year to date) was approximately 33.6%. As a rule, a water system with 20% or more of unaccounted for water should consider conducting a leak survey. The Department is aware of some flushing done by your system, which can contribute to water loss. **However, a leak survey should be strongly considered if the percentage remains constant during periods when water loss maintenance (flushing) is light.** If you are interested in conducting a leak survey, please contact the Florida Rural Water Association at (850) 668-2746.

Storage Capacity


According to the Flow and Capacity calculations below (page 11), while source capacity appears adequate, storage capacity may be falling short of requirements. A storage capacity study is strongly recommended this year to further assess the situation.

Flow & Capacity and Population Graphs



COMMENTS

This system is expanding due to a new round of home building within the development. The graph above shows that the system has experienced a gradual growth in demand through the past twelve months. Analysis of the system's capacity is complicated by the fact that Well #1 and its 70,000 gallons of storage are currently offline for upgrades, but are due to be back online soon. The production spike of 1.2M gallons seen in October 2005 may have been due to the flushing of Well #1 (as an attempt was being made to bring it back online), so this max day figure should likely be disregarded. If the 400,500 gallon demand seen in June 2005 is used instead, and the 70,000 gallon storage at Well #1 (currently offline) is included, the total storage capacity of 87,500 gal is still less than 1/4 of max day, at 21.85% of max day (about 13% under the storage needed to achieve the recommended 25% of max day level). Comparing total storage to an average day (again with Well #1's tanks included and without the extraordinary October 2005 demand), storage still falls short at only 57% of demand. As such, additional storage should be considered. Source capacity without Well #1 (max day as % of design capacity) is at 34%; with Well #1 it is 21%, both of which are in compliance. Figures for auxiliary capacity are similar, since all three wells have auxiliary power and are capable of full output even in emergency conditions.



After a slight drop in population between years 2000 and 2002, growth has begun anew, with 700 more served by the franchise, and 56 service connections having been added since the last survey in 2004. At least 90 more connections are planned for this year.

Geographical Information




DIRECTIONS: (see maps 1 and 2 above)

From the Panama City Branch Office go left (north) on Jenks Ave. and turn right (east) on Baldwin Rd. At Hwy 77, turn left (north) and follow this route approximately 24 miles and turn right on Sunny Hills Blvd. Approximately 1 mile in, turn left on Gables Blvd. The water system office and Well #1 are approximately ¼ mile in on the left.

COMMENTS:

The Sunny Hills community (see map 3, above) is a Deltona Corporation development with a planned build-out to approximately 3500 homesites. Of these, about 500 have been built to date. Sunny Hills is located in an area of limestone (or Karst) topography, with abundant sinkhole lakes. The water system, operated by Aqua Utilities Florida, Inc., draws from the Floridan Aquifer.

Digital Images




Well #1 (out of service for improvements)
- Pump house -



Well #1 (out of service) - Sand filtration system and twin hydro storage tanks (30,000 gal each)


Digital Images (cont'd)




Pump at Well #1 - pulled for refurbishing shortly after this visit; now resuming operations.




Preparing to pull pump



Well #1 - Auxiliary drive



Well #1 - Unusual vent placement



Well #1 - High service pump




Well #1 - 10,000 gal hydro tank in excellent condition

Digital Images (cont'd)




Well #4 - 10,000 gal hydro tank



Well #4 - Safety equipment (installed at all three plants)




Well #4 - Tank pressure 60#



Well #4 - Emergency power




Well #4 - Vertical turbine pump



Hypochlorite is pumped directly from shipping drum at all plants; no dilution is performed.


Digital Images (cont'd)




Security at Well #4




Security at Well #5




Well #5 - 10,000 gal hydro tank in excellent condition; sight glass removed for winter.



Well #5 - Pump and auxiliary drive



Door at Well #5 corroded - replacement already ordered.



Well #5 - Controls

OUTSTANDING PERMITS

As of 1/3/2006

- 1) Deadening Road (clearance granted 1/3/06)
(Permit # 0080182-008-DSGP/01)
- 2) Davenport Blvd (clearance package due to be mailed Jan. '06)
(Permit # 0255874-001-DSGP/01)

INSPECTOR'S SIGNATURE David Hines TITLE ESI DATE: January 5, 2006

INSPECTOR'S SIGNATURE Gerald Smith TITLE ESI DATE: January 5, 2006

APPROVED BY Jim Foster TITLE EM DATE: 1/6/06

END OF REPORT

State of Florida
Department of Environmental Protection
Central District
SANITARY SURVEY REPORT

Plant Name TANGERINE WATER County Orange PWS ID # 3481329
Plant Location 5539 Huron Street, Tangerine, FL Phone 352/787-0980
Owner Name Florida Water Services Attn: Craig Anderson Phone 407/880-0058
Owner Address P.O. Box 609520, Orlando, FL 32860-9520
Contact Person Will Fontaine Title Lead Supervisor Phone 352/787-0980
This Survey Date 4/28/04 Last Survey Date 6/6/00 Last C.I. Date 10/4/01

PWS TYPE & CLASS

- Community (5C)
- Non-transient Non-community
- Non-Community

PWS STATUS

- Approved system with approval number & date
3302, 4/28/59
- Unapproved system

SERVICE AREA CHARACTERISTICS

Residential
Food Service: Yes No N/A

OPERATION & MAINTENANCE

Certified Operator: Yes No Not required
Operator(s) & Certification Class-Number
G. Kissick C-7846
W. Fontaine C-6813
O & M Log: Yes No Not required
Operator Visitation Frequency
Hrs/day: Required _____ Actual _____
Days/wk: Required 6 Actual 6
Non-consecutive Days? Yes No N/A
MORs submitted regularly? Yes No N/A
Data missing from MORs? No Yes N/A

Number of Service Connections 255
Population Served 884 Basis MOR
Average Day (from MORs) 107 MGD
Max. Day (from MORs) .189 MGD 4/03
Max-day Design Capacity .360 MGD
Comments _____

COMET: SITE ID _____ PROJECT ID _____

RAW WATER SOURCE

- GROUND; Number of Wells 2
- SURFACE/UDI; Source _____
- PURCHASED from PWS ID # _____
- Emergency Water Source _____
Emergency Water Capacity _____

AUXILIARY POWER SOURCE

Yes None Not Required
Source Cummins Diesel
Capacity of Standby (kW) 35
Switchover: Automatic Manual
Standby Plan: Yes No
Hrs Operated Under Load 1 hr/wk.
What equipment does it operate?
 Well pumps Wells 1 & 2
 High Service Pumps _____
 Treatment Equipment Disinfection
Satisfy 1/2 max-day demand? Yes No Unk
Comments In process of upgrading system

TREATMENT PROCESSES IN USE

Disinfection
What additional treatment is needed?
For control of what deficiencies?

DISTRIBUTION SYSTEM

Flow Measuring Device Flow Meter
Meter Size & Type 4" Master Meter *
Backflow Prevention Devices: Yes No
Cross-connections None Observed
Written Cross-connection Control Program: Yes
Coliform Sampling Plan: Yes No N/A
Comments * on each well.

Received

MAY 12 2004

PWS ID # 3481329Date 5/6/04**GROUND WATER SOURCE**

Well Number	1(inside)	2(outside)		
Year Drilled	1945	1959		
Depth Drilled	438'	413'		
Drilling Method	Cable Tool	Cable Tool		
Type of Grout	UNK	UNK		
Static Water Level	UNK	UNK		
Pumping Water Level	UNK	UNK		
Design Well Yield	UNK	UNK		
Test Yield	UNK	UNK		
Actual Yield (if different than rated capacity)	UNK	UNK		
Strainer	None	None		
Length (outside casing)	130'	176'		
Diameter (outside casing)	6"	6"		
Material (outside casing)	Blk. Iron	Blk. Iron		
Well Contamination History	None noted	None noted		
Is inundation of well possible?	No	No		
6' X 6' X 4" Concrete Pad	Yes	Yes		
SET BACKS	Septic Tank	>200'	>200'	
	Reuse Water	N/A	N/A	
	WW Plumbing	>100'	>100'	
	Other Sanitary Hazard	N/A	N/A	
PUMP	Type	Vert. Turbine	Vert. Turbine	
	Manufacturer Name	Goulds	Peerless	
	Model Number	6DH2	UNK	
	Rated Capacity (gpm)	250	250	
	Motor Horsepower	25	25	
Well casing 12" above grade?	Yes	Yes		
Well Casing Sanitary Seal	Yes	Yes		
Raw Water Sampling Tap	Yes	Yes		
Above Ground Check Valve	Yes	Yes		
Fence/Housing	Yes	Yes		
Well Vent Protection	Yes	N/A		

COMMENTS Provide additional information for "UNK", if available.

Irrigation well installed less than 50' from well area. Operator stated the well will be abandoned.

PWS ID # 3481329
 Date 5/6/04

CHLORINATION (Disinfection)

Type: Gas Hypo
 Make Chem-tech Capacity * gpd
 Chlorine Feed Rate 100% stroke rate
 Avg. Amount of Cl₂ gas used N/A
 Chlorine Residuals: Plant 2.1 Remote 1.3
 Remote tap location 5107 Dora road
 DPD Test Kit: On-site With operator
 None Not Used Daily
 Injection Points Prior to H/1
 Booster Pump Info
 Comments Well #1 - 30 gpd, Well #2 - 30 gpd
and transfer pump 30 gpd.

Chlorine Gas Use Requirements	YES	NO	Comments
Dual System	<input type="checkbox"/>	<input type="checkbox"/>	
Auto-switchover	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Alarms:			
Loss of Cl ₂ capability	<input type="checkbox"/>	<input type="checkbox"/>	
Loss of Cl ₂ residual	<input type="checkbox"/>	<input type="checkbox"/>	
Cl ₂ leak detection	<input type="checkbox"/>	<input type="checkbox"/>	
Scale	<input type="checkbox"/>	<input type="checkbox"/>	
Chained Cylinders	<input type="checkbox"/>	<input type="checkbox"/>	
Reserve Supply	<input type="checkbox"/>	<input type="checkbox"/>	
Adequate Air-pak	<input type="checkbox"/>	<input type="checkbox"/>	
Sign of Leaks	<input type="checkbox"/>	<input type="checkbox"/>	
Fresh Ammonia	<input type="checkbox"/>	<input type="checkbox"/>	
Ventilation	<input type="checkbox"/>	<input type="checkbox"/>	
Room Lighting	<input type="checkbox"/>	<input type="checkbox"/>	
Warning Signs	<input type="checkbox"/>	<input type="checkbox"/>	
Repair Kits	<input type="checkbox"/>	<input type="checkbox"/>	
Fitted Wrench	<input type="checkbox"/>	<input type="checkbox"/>	
Housing/Protection	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

AERATION (Gases, Fe, & Mn Removal)

Type Capacity
 Aerator Condition
 Bloodworm Presence
 Visible Algae Growth
 Protective Screen Condition
 Comments

STORAGE FACILITIES

(G) Ground (H) Hydropneumatic (E) Elevated
 (B) Bladder (C) Clearwell

Tank Type/Number	H/1		
Capacity (gal)	10,000		
Material	Steel		
Gravity Drain	Yes		
By-pass Piping	Yes		
Pressure Gauge	Yes		
Sight Glass or Level Indicator	Yes		
Fittings for Sight Glass	Yes		
Protected Openings	Yes		
PRV/ARV	ARV		
On/Off Pressure	40/60		
Access Padlocked	Yes		
Height to Bottom of Elevated Tank			
Height to Max. Water Level			

Comments

HIGH SERVICE PUMPS

Pump Number			
Type			
Make			
Model			
Capacity (gpm)			
Motor HP			
Date Installed			
Maintenance			

Comments

PWS ID # 33514263481329
Date 5/6/04


MONITORING VIOLATIONS	MCL VIOLATIONS

DEFICIENCIES:

Plant looked great!!

Note: Irrigation well installed less than 50' from well area. Per operator well be abandoned in place.

Inspector *K. H. [Signature]* Title Env. Specialist I Date 5/6/04
 Approved by *Roberto C. [Signature]* Title Env. Manager Date 5/2/04



Jeb Bush
Governor


Department of Environmental Protection

Southwest District
13051 North Telecom Parkway
Temple Terrace, FL 33637-0926
Telephone: 813-632-7600

Colleen M. Castille
Secretary

August 11, 2006

Mr. Will Fountaine
P.O. Box 490310
Leesburg, FL 34749




Re: Compliance Inspection
The Woods
PWS-ID No. 660-0347
Sumter County

Dear Mr. Fountaine:

The attached Compliance Inspection was conducted on the referenced public water system. No deficiencies were noted at the time of this inspection.

If you have any questions, please contact me at (813) 632-7600, extension 460.

Sincerely,


James Berghorn
Environmental Specialist
Drinking Water Section

JB/dm^c

Attachment

cc: John Worrell, Operator

COMPLIANCE INSPECTION

OWNER/ADDRESS
Candice McClure
P.O. Box 490310
Leesburg, FL 34749

SYSTEM NAME The Woods
 ID# 6600347
 SYSTEM TYPE C
 COUNTY Sumter

SUPERVISOR: Bill Dunn
 INSPECTOR: Jim Berghorn
 INNSPECTION DATE: 7/31/06

Check List:

- Well Protection - Housing Security Fencing
- * Sanitary Seal/Disinfection Port * Sanitary Hazard _____
- * 6' x 6' x 4" Concrete Apron - Cracked Missing Inadequate size
- Raw Water Tap - Missing Threaded Wrong location
- * Check Valve - Inoperable Missing Wrong location
- Time Clock / Flow Meter Make 2-Rockwell Missing Broken
- Water Pressure Gauge - Missing Broken/Cracked On/Off _____ P.S.I.
- * Disinfection Free Cl₂ Plant 2.77 mg/l Remote _____ mg/l Chlorinator 2-Stenners 17 gpd
- * Gas Chlorination: Need Separate Room Cross-Ventilation
 Scales; Safety Equipment; Dual Gas; Cylinders Chained; Breathing Apparatus; Ammonia;
 Wrenches; Auto Switch Over; Lack of Chlorination Alarm
- NSF or UL Approved Chlorine Yes No
- * Cross-Connection - Location: Hose faucet
- * Auxiliary Power/Second Well Operated Monthly - Yes No 4 hrs/month
- Certified Operator Name: John Worrell Number C-6597 Maintenance Logs _____
- OTHER TREATMENT - Softeners Filters Aerators Other _____
- Tanks checked annually Yes No Date Cleaned _____ Date Inspected _____
- ARV/PRV testing on Hydro tank Yes No Exercising of isolation valves Yes No
- O & M manual Yes No Distribution Map Yes No N/A
- Emergency/response Plan Yes No N/A
- System flushing plan Yes No System flushed Yes No
- Preventative maintenance plan Yes No
- Miscellaneous _____
- NO DEFICIENCIES NOTED THIS DATE

***(X) REQUIRES REINSPECTION**

Well #	ID #	Well #	ID #	Well #	ID #	Well #	ID #
--------	------	--------	------	--------	------	--------	------

Comments

Provide back flow preventers on all faucets, operator installed one while on site



Department of Environmental Protection

Jeb Bush
Governor

Southwest District
3804 Coconut Palm Drive
Tampa, Florida 33619

Colleen M. Castille
Secretary

May 20, 2005

*Response due:
June 20, 2005*

Ms. Carolyn McFalls
6960 Professional Parkway
Suite 400
Sarasota, FL 34240

Re: Sanitary Survey Report
The Woods
PWS-ID No. 660-0347
Sumter County

Dear Ms. McFalls:

Enclosed please find a copy of the Sanitary Survey Report for the above-referenced potable water system. On the last page of the report you will find a list of deficiencies that were noted during the recent inspection, along with recommended corrective action.

You are requested to correct all listed deficiencies, as recommended, and to notify this office within 30 days, in writing, of your action.

If you have any questions or concerns, please contact me at (813) 744-6100, extension 460.

Sincerely,

James Berghorn
James Berghorn
Environmental Specialist
Drinking Water Section

JB

Enclosure

State of Florida
Department of Environmental Protection
Southwest District
SANITARY SURVEY REPORT

Plant Name THE WOODS County SUMTER PWS ID # 660-0347
Plant Location CR 675 Off 301 South Webster, FL 33597 Phone 352-260-2214
Owner Name Aqua Source Services, LP Phone 877-369-4881
Owner Address 1343 NE 17th Rd. Ocala, FL 33470
Contact Person Aqua Source/Brian Heath Title Owner/Manager Phone 352-787-0980
This Survey Date 5/18/05 Last Survey Date 2/13/02 Last C.I. Date 11/3/04

PWS TYPE & CLASS

- Community (3C)
- Non-transient Non-community
- Non-Community

PWS STATUS

- Approved system with approval number & date 02/78
- Unapproved system

SERVICE AREA CHARACTERISTICS

Mobile Home Community
Food Service: Yes No N/A

OPERATION & MAINTENANCE

Certified Operator: Yes No Not required
Operator(s) & Certification Class-Number
John Worrell C-6597

O & M Log: Yes No Not required
Operator Visitation Frequency
Hrs/day: Required _____ Actual _____
Days/wk: Required 6 Actual 6
Non-consecutive Days? Yes No N/A
MORs submitted regularly? Yes No N/A
Data missing from MORs? No Yes N/A

Number of Service Connections 70
Population Served 150 Basis Permanent
Average Day (from MORs) _____ gpd
Max. Day (from MORs) _____ gpd
Max-day Design Capacity _____ gpd
Comments _____

COMET: SITE ID _____ PROJECT ID _____

RAW WATER SOURCE

- GROUND; Number of Wells 1
- SURFACE/UDI; Source _____
- PURCHASED from PWS ID # _____
- Emergency Water Source _____
Emergency Water Capacity _____

AUXILIARY POWER SOURCE

- Yes None Not Required
- Source _____
Capacity of Standby (kW) _____
Switchover: Automatic Manual
Standby Plan: Yes No
Hrs Operated Under Load _____
What equipment does it operate?
 Well pumps _____
 High Service Pumps _____
 Treatment Equipment _____
Satisfy 1/2 max-day demand? Yes No Unk
Comments _____

TREATMENT PROCESSES IN USE

Hypo-Chlorination/Pottassium Permanganate
Filtration/ Aeration
What additional treatment is needed?
None
For control of what deficiencies?

DISTRIBUTION SYSTEM

Flow Measuring Device Flow Meter
Meter Size & Type Rockwell Internatioal 10^7
Backflow Prevention Devices: Yes No
Cross-connections _____
Written Cross-connection Control Program: Yes
Coliform Sampling Plan: Yes No N/A
Comments _____

PWS ID # 6600347
 Date 5/19/05

GROUND WATER SOURCE

I Number	1 (AAC 1546)			
Year Drilled	1974			
Depth Drilled	136'			
Drilling Method	Cable Tool			
Type of Grout	None			
Static Water Level				
Pumping Water Level				
Design Well Yield				
Test Yield				
Actual Yield (if different than rated capacity)				
Strainer				
Length (outside casing)	75'			
Diameter (outside casing)	4"			
Material (outside casing)	Steel			
Well Contamination History	No			
Is inundation of well possible?	No			
6' X 6' X 4" Concrete Pad	Yes			
SET BACKS	Septic Tank	Unk		
	Reuse Water	No		
	WW Plumbing			
	Other Sanitary Hazard			
PUMP	Type	Submersible		
	Manufacturer Name	Franklin		
	Model Number			
	Rated Capacity (gpm)	100		
	Motor Horsepower	5 H.P.		
Well casing 12" above grade?	Yes			
Well Casing Sanitary Seal	Yes			
Raw Water Sampling Tap	Yes			
Above Ground Check Valve	Yes			
Fence/Housing	Yes			
Well Vent Protection	Yes			

COMMENTS Directions: I-75 to Exit 62 (Webster). Take CR 673 and go left to SR 301. Then go 301 South to CR 675 and you will be at The Woods.

PWS ID # 6600347
 Date 5/19/05

CHLORINATION (Disinfection)

Type: Gas Hypo
 Make 2-Stenner Capacity 17 gpd
 Chlorine Feed Rate _____
 Avg. Amount of Cl₂ gas used N/A
 Chlorine Residuals: Plant 1.08 Remote _____
 Remote tap location _____
 DPD Test Kit: On-site With operator
 None Not Used Daily
 Injection Points _____
 Booster Pump Info _____
 Comments _____

Chlorine Gas Use Requirements	YES	NO	Comments
Dual System	<input type="checkbox"/>	<input type="checkbox"/>	
Auto-switchover	<input type="checkbox"/>	<input type="checkbox"/>	
Alarms:			
Loss of Cl ₂ capability	<input type="checkbox"/>	<input type="checkbox"/>	
Loss of Cl ₂ residual	<input type="checkbox"/>	<input type="checkbox"/>	
Cl ₂ leak detection	<input type="checkbox"/>	<input type="checkbox"/>	
Scale	<input type="checkbox"/>	<input type="checkbox"/>	
Chained Cylinders	<input type="checkbox"/>	<input type="checkbox"/>	
Reserve Supply	<input type="checkbox"/>	<input type="checkbox"/>	
Adequate Air-pak	<input type="checkbox"/>	<input type="checkbox"/>	
Sign of Leaks	<input type="checkbox"/>	<input type="checkbox"/>	
Fresh Ammonia	<input type="checkbox"/>	<input type="checkbox"/>	
Ventilation	<input type="checkbox"/>	<input type="checkbox"/>	
Room Lighting	<input type="checkbox"/>	<input type="checkbox"/>	
Warning Signs	<input type="checkbox"/>	<input type="checkbox"/>	
Repair Kits	<input type="checkbox"/>	<input type="checkbox"/>	
Fitted Wrench	<input type="checkbox"/>	<input type="checkbox"/>	
Housing/Protection	<input type="checkbox"/>	<input type="checkbox"/>	

AERATION (Gases, Fe, & Mn Removal)

Type Tray Capacity Unk
 Aerator Condition Ok
 Bloodworm Presence No
 Visible Algae Growth No
 Protective Screen Condition Good
 Comments _____

STORAGE FACILITIES

(G) Ground (H) Hydropneumatic (E) Elevated
 (B) Bladder (C) Clearwell

Tank Type/Number	(H)	(H)BW	
Capacity (gal)	2,500	5000	
Material	Steel	Steel	
Gravity Drain	Yes	Yes	
By-pass Piping	Yes	Yes	
Pressure Gauge	Yes	No	
Sight Glass or Level Indicator	Yes	No	
Fittings for Sight Glass	Yes	No	
Protected Openings	Yes	Yes	
PRV/ARV			
On/Off Pressure	28/38		
Access Padlocked	Yes	Yes	
Height to Bottom of Elevated Tank	N/A	N/A	
Height to Max. Water Level	N/A	N/A	

Comments The 5,000 Gallon tank is only used for back-wash water.

HIGH SERVICE PUMPS

Pump Number	1		
Type	Turbine		
Make	Baldor		
Model	JMM3219 7		
Capacity (gpm)	102		
Motor HP	7.5 H.P.		
Date Installed	1990		
Maintenance	weekly		

Comments _____

PWS ID # 6600347
 Date 5/19/05

COMPLIANCE MONITORING COMMUNITY PUBLIC WATER SYSTEMS									
CONTAMINANT	PWS Screen	# Samples Required	Sampling Location	C > 3300			C ≤ 3300		
				Frequency	Sample Date	Due Date	Frequency	Sample Date	Due Date
Microbiological (Bacte)	024	1	Each well	monthly			monthly		
		2	Distribution						
Volatile Organics	028	<i>(Note A)</i>	<i>(Note H)</i>	<i>(Notes A, 1)</i>			<i>(Notes A, 2)</i>		
Pesticides & PCBs	029	<i>(Notes B, E)</i>	<i>(Note H)</i>	3 years <i>(Note 1)</i>			3 years <i>(Note 2)</i>		
Nitrate & Nitrite (as N)	030	1	POE	annually			annually		
Inorganics	030	1	POE	3 years <i>(Note 1)</i>			3 years <i>(Note 2)</i>		
Asbestos	030	1 <i>(Note F)</i>	Distribution	9 years <i>(Note 7)</i>			9 years <i>(Note 8)</i>		
Secondaries	031	1	POE	3 years <i>(Note 1)</i>			3 years <i>(Note 2)</i>		
Radionuclides	033	<i>(Note C)</i>	POE	3 years <i>(Note 1)</i>			3 years <i>(Note 2)</i>		
Group I UOCs	035	<i>(Notes B, E, G)</i>	POE	<i>(Note 4)</i>			<i>(Note 5)</i>		
Group II UOCs	034	1 <i>(Notes E, G)</i>	POE	3 years <i>(Note 1)</i>			3 years <i>(Note 2)</i>		
Group III UOCs	036, 037	1 <i>(Note G)</i>	POE	<i>(Note 4)</i>			<i>(Note 5)</i>		
Lead and Copper	047	<i>(Note D)</i>	---	---			---		
TTHM (≥ 10,000 persons)	027	4/plant	Distribution	Quarterly			N/A		

POE = Point of Entry (Samples shall be taken at each entry point to the distribution system that is representative of each source after treatment.)

See Page 5 for description of italicized notes.

PWS ID # 6600347
 Date 5/19/05

NOTES:

SAMPLES REQUIRED/SAMPLING LOCATION:

Note A See Rule 62-550.515(1), F.A.C. Each system shall take four consecutive quarterly samples during its assigned year in the system's first compliance period. If no contaminant is detected, the system shall monitor annually during the next three-year compliance period. If still no contaminants are detected, systems shall take one sample during each subsequent three-year compliance period.

If the initial monitoring for contaminants listed in Rule 62-550.310(2)(b), F.A.C., was completed prior to December 31, 1992, then each system shall take one sample annually beginning January 1, 1993.

Note B 4 consecutive quarterly samples. Credit will be given for samples taken before January 1, 1993.

Note C See Rule 62-550.519, F.A.C. Compliance shall be based on the average of analyses of four consecutive quarterly samples. A maximum of two quarterly samples may be composited. Subsequent samples shall be collected once every three years.

Note D Contact the Southwest District's Drinking Water Program at (813) 744-6100 or contact the Florida Rural Water Association.

Note E Contact the Southwest District's Drinking Water Program at (813) 744-6100 to obtain an application for reduced monitoring.

Note F See Rule 62-550.511(4), F.A.C. A system without asbestos-containing components shall certify to the Department in writing, using DEP Form No. 62-555.910(10), that it is asbestos free. Certification shall satisfy subsections (1), (2), and (3) of the referenced rule, and shall be submitted each nine-year compliance cycle during the specified year the system is required to monitor.

Note G See Rule 62-550.521(4), F.A.C. Systems serving less than 150 service connections and serving fewer than 350 persons should notify the Department, by submitting DEP Form No. 62-555.910(11), that their system is available for testing. Normally, these small systems will not be required to monitor for UOCs. Do not send such samples to the Department unless required to do so by the Department.

Note H First quarter samples shall be representative of each well. Subsequent samples shall be taken at each entry point to the distribution system that is representative of each source after treatment.

FREQUENCY:

Note 1 First year of each three-year compliance period (calendar years 1993, 1996, 1999, etc.)

Note 2 Second year of each three-year compliance period (calendar years 1994, 1997, 2000, etc.)

Note 3 Third year of each three-year compliance period (calendar years 1995, 1998, 2001, etc.)

Note 4 First year of the first three-year compliance period (i.e. calendar year 1993)

Note 5 Second year of the first three-year compliance period (i.e. calendar year 1994)

Note 6 Third year of the first three-year compliance period (i.e. calendar year 1995)

Note 7 First year of each nine-year compliance cycle (calendar years 1993, 2002, etc.)

Note 8 Second year of each nine-year compliance cycle (calendar years 1994, 2003, etc.)

Note 9 Third year of each nine-year compliance cycle (calendar years 1995, 2004, etc.)

PWS ID # 6600347
Date 5/19/05

MONITORING VIOLATIONS	MCL VIOLATIONS

DEFICIENCIES:

1) Aerators walls leaking 62-555-350 Repair walls of aerator to stop leaks

Note: Please notify the Department in the future of any owner, or operator changes that occur.

Inspector J. Berghorn Title Env. Specialist II Date 5/19/05
 Approved by [Signature] Title Env. Supervisor II Date 5/26/05

February 23, 2005

Mr. Glenn LaBrecque, President
Aqua Utilities Florida, Inc.
6960 Professional Parkway East
Sarasota, Fl. 34240

FEB 23 2005
10:11 AM
Tomoka Inc.

**RE: Sanitary Survey Inspection Report : PWS # 3641373
Tomoka View Estates Community Water System**

Dear Mr. LaBrecque,

This will confirm my visit to the above referenced community public water system for the purpose of conducting a sanitary survey. The survey of the Tomoka View Estates water treatment plant was conducted on December 16, 2004 in the company of Mr. Paul Thompson, the facility's certified operator. I also visited the plant for a follow-up inspection on February 9, 2005.

Overall, the Tomoka View Estates drinking water system is well maintained and operated. However, this Department is concerned about the system's water quality problems - namely high copper and trihalomethane (THM) concentrations in the finished drinking water. Optimal corrosion control treatment needs to be maintained; and the treatment options for trihalomethane reduction need to be evaluated. As noted in previous correspondence, this office requests that a written proposal be submitted by no later than June 1, 2005 outlining a plan of action for achieving compliance with the THM Maximum Contaminant Level (MCL).

The three deficiencies noted during this survey are listed below. On page 6 of the enclosed sanitary survey report, these deficiencies have been listed along with reference to the pertinent section of the Florida Administrative Code. (FAC) Additionally at the end of this letter, I have included some additional information about new permitting requirements applicable to this water system.

The following is a description of corrective action required for each noted deficiency:

1. Repair the damaged areas of the fence surrounding the water plant including the top strands of barbed wire that are bent down or entirely missing in some sections.
2. Submit an updated written cross connection control plan to this office reflecting current system ownership and demonstrate implementation of this plan.
3. Document operator testing of phosphate additive concentration in finished water (at least twice per month) and compare operator's test kit readings to certified laboratory results of phosphate concentration at least once per year. (NOTE: A tap sample should be submitted to a laboratory for both ortho-phosphate and phosphate concentration when Lead/Copper tap samples are collected.)

You are required to correct the listed deficiencies for this water system no later than April 15, 2005. On or before this date provide a written response to this Department stating that all deficiencies have been corrected or listing specific dates of completion for any items still in progress. If any deficiencies need further explanation, please contact me immediately.

VOLUSIA COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH ENGINEERING • SAFE DRINKING WATER PROGRAM
1845 HOLSONBACK DRIVE
DAYTONA BEACH, FLORIDA 32117

In addition, this office requests that an updated Lead/Copper sample plan be submitted as soon as possible and prior to sample collection in the current monitoring period (January – June 2005). This system's service population has been increased to 644 based on a factor of 3.5 persons per household. Therefore, a minimum of 20 samples must be collected in each 6 month monitoring period. Please include at least five additional sample sites (minimum of 25 sites) in the sample plan - preferably selecting taps without water softeners. If a sample tap with a water softener is selected, note this in PART IV of the sample plan.


I have listed below some requirements for this community water system as detailed in the revised Chapter 62-555 F.A.C., effective August 28, 2003:

1. Biogrowths shall be routinely cleaned (at least annually) from the walls of the water storage tanks at this facility. Accumulated sludge and biogrowths shall be cleaned from inside water storage tanks and these tanks shall be inspected for structural and coating integrity by a professional engineer once every five years (certified no later than August 2008).
2. Equipment manuals must be bound and indexed or a plant operation and maintenance manual must be provided at the water treatment plant by no later than December 31, 2005. ALL preventive maintenance work and equipment repairs must be documented in plant maintenance logs.
3. A written "Emergency Response Plan" (ERP) for this water system addressing vandalism; drought; hurricanes; fire; flooding; and hazardous material release, if applicable, must be developed and be available for review by this office no later than December 31, 2005. (NOTE: Florida Rural Water Association will be conducting training seminars during March and April 2005.)
4. An audio-visual alarm system that is activated in the event that any power source fails must be provided by no later than December 31, 2005. If the water plant is not staffed during all hours that the stand-by power is in operation, the alarm shall telemeter notification to a place staffed during all hours that the stand-by power source is in operation; or trigger automatic telephone dialing or paging to enable notification to an authorized representative of the water system.
5. Key isolation valves of the distribution system need to be indentified and regularly exercised (or replaced, as needed) to ensure that line breaks can be repaired without total loss of system pressure. The exercising of these main valves should be documented in operational log and their replacement noted on distribution system map which must be kept up-to-date.
6. All legitimate customer complaints and responses by system personnel should be documented in a separate section of operational log book or in a separate log available for periodic review.

Please be aware that the Florida Rural Water Association (FRWA) is available to public water suppliers for consultation and technical assistance. Water suppliers are not required to be a member of the association in order to receive assistance and it is recommended that their services be utilized when assistance is needed. The local FRWA circuit rider is Mr. David Hanna and he may be contacted at (850) 668-2746.

In conclusion, I would like to thank Paul Thompson and Nicole Zinn of Aqua Utilities for their cooperation during the course of this survey. If you should have any questions regarding this correspondence, please feel free to contact me at (386) 274-0717.

Sincerely,



Patricia Carrico, R.E.H.S.
Environmental Specialist II

c.c: Paul Thompson, Operator – Central Florida Office

Department of Health
Volusia County Health Department
SANITARY SURVEY REPORT

101

Plant Name TOMOKA VIEW ESTATES County Volusia PWS ID # 3641373
Plant Location 336 Apache Trail, Ormond Beach, FL. 32176 Phone 386-937-1143
Owner Name Aqua Utilities Florida, Inc. Phone 941-907-7420
Owner Address 6960 Professional Parkway East, Sarasota, FL. 44240
Contact Person Paul Thompson Title Operator Phone 386-937-1143
This Survey Date 12/16/04 - 2/09/05 Last Survey Date 12/20/01 Last C.I. Date 04/27/04

PWS TYPE & CLASS

- Community (4C)
 Non-transient Non-community
 Non-Community

PWS STATUS

- Approved system with approval number & date
AS-BUILTS accepted 10/1975 (Plan #6348-5/1963)
 Unapproved system

SERVICE AREA CHARACTERISTICS

Subdivision (All single family homes)

Food Service: Yes No N/A

OPERATION & MAINTENANCE

Certified Operator: Yes No Not required
Operator(s) & Certification Class-Number
Paul Thompson #A 7251

O & M Log: Yes No Not required

Operator Visitation Frequency

Hrs/day: Required N/A Actual N/A

Days/wk: Required 6 Actual 7

Non-consecutive Days? Yes No N/A

MORs submitted regularly? Yes No N/A

Data missing from MORs? No Yes N/A

Number of Service Connections 184

Population Served 644 Basis 3.5 per S.C.

Average Day (from MORs) 45,841 gpd

Max. Day (from MORs) 85,000 gpd (Apr. 2004)

Max-day Design Capacity 193,000 gpd

Total Storage 18,000 gal. (%Storage/MaxDay=21%)

Comments Ave and Max Day based on period from

Jan. -Dec. 2004. Note: System is built-out. No increase in

service connections since last survey; but population

increased - previously a factor of 2.3 X (service

connections) was used.

RAW WATER SOURCE

- GROUND; Number of Wells 2
 SURFACE/UDI; Source _____
 PURCHASED from PWS ID # _____
 Emergency Water Source _____

NOTE: Ormond Bch. (PWS 3640963) water main with hydrants is adjacent to subdivision for some fire water.

AUXILIARY POWER SOURCE

- Yes None Not Required
Source LP gas fueled generator-GENERAC
Capacity of Standby (kW) 30 kW
Switchover: Automatic Manual
Standby Plan: Yes No
Hrs Operated Under Load 4 hrs/mo.

What equipment does it operate?

- Well pumps 2
 High Service Pumps 3 (All)
 Treatment Equipment All

Satisfy 1/2 max-day demand? Yes No Unk

Comments 250 gal. LP Storage Tank on-site.

TREATMENT PROCESSES IN USE

Aeration; Corrosion Control, Hypochlorination

What additional treatment is needed?

None Noted.

For control of what deficiencies?

N/A

DISTRIBUTION SYSTEM

Flow Measuring Device Flow Meter

Meter Size & Type 8D, Neptune, turbine meter-3"

Backflow Prevention Devices: Yes No

Cross-connections None observed.

Written Cross-connection Control Program: Yes

Coliform Sampling Plan: Yes No N/A

Comments Florida Rural Water checks calibration of

meters annually. Septic tanks are in use and some

residential wells. No RPZ or DC backflow devices are

installed on distribution system.

GROUND WATER SOURCES

Well Number		1 (North)	2 (South)	3	4
FLUID #	(NO FLUID #'s)	(Outside Plant Fence)	(Inside Plant Fence)		
Location					
Year Drilled		2003	1965		
Depth Drilled		136 ft.	150 ft.		
Drilling Method		Combination	Unknown		
Type of Grout		Neat Cement	Unknown		
Length (outside casing)		120 ft.	120 ft.		
Diameter (outside casing)		6 in.	6 in.		
Material (outside casing)		Black.Steel	Galv. Steel		
Well Contamination History		None	None		
Is inundation of well possible?		No	No		
6' X 6' X 4" Concrete Pad		Yes	Yes		
SET BACKS	Septic Tank	< 100 ft.*	< 100 ft.*		
	Reuse Water	N/A	N/A		
	WW Plumbing	< 100 ft.*	< 100 ft.*		
	Other Sanitary Hazard	None Noted	None Noted		
PUMP	Type	Submersible	Submersible		
	Manufacturer Name	Unknown	Unknown		
	Model Number	75S	Unknown		
	Rated Capacity (gpm)	75 gpm	200 gpm		
	Motor Horsepower	5 HP	5 HP		
Well casing 12" above grade?		Yes	Yes		
Well Casing Sanitary Seal		Good	Good		
Raw Water Sampling Tap		Yes	Yes		
Above Ground Check Valve		Yes	Yes		
Fence/Housing		Housing	Fence		
Well Vent Protection		Yes	Yes		

COMMENTS *Both Wells are within 100' of nearby septic systems. Department has waived setback requirement for septic tanks provided monthly well samples remain negative for total coliform bacteria.

CHLORINATION (Disinfection)

Type: Gas Hypo
 Make Stenner 85M5 (2) Capacity 85 gpd
 Chlorine Feed Rate _____
 Avg. Amount of Cl₂ used 30 gal. per day
 Chlorine Residuals: Plant 1.4 Remote 0.8
 Remote tap location 160 Greenbriar
 DPD Test Kit: On-site With operator
 None Not Used Daily
 Injection Points @ influent line of (15K) storage tank.
 Comments Individual CL2 pump for each well.
Dumont Chem. Co. fills two-150 gal. drums, as needed.

Chlorine Gas Use Requirements	YES	NO	Comments
Dual System	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Auto-switchover	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Alarms:			
Loss of Cl ₂ capability	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Loss of Cl ₂ residual	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
Cl ₂ leak detection	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Scale	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Chained Cylinders	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Reserve Supply	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Adequate Air-pak	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Sign of Leaks	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Fresh Ammonia	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Ventilation	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Room Lighting	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Warning Signs	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Repair Kits	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Fitted Wrench	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Housing/Protection	<input type="checkbox"/>	<input type="checkbox"/>	N/A

AERATION (Gases, Fe, & Mn Removal)

Type Cascade Capacity Unknown
 Aerator Condition Good
 Bloodworm Presence None
 Visible Algae Growth No
 Protective Screen Condition Good
 Comments Aerator trays located above 15K tank.

STORAGE FACILITIES

(G) Ground (H) Hydropneumatic (E) Elevated
 (B) Bladder (C) Clearwell

Tank Type/Number	G	C	
Capacity (gal)	15,000	3,000	
Material	Conc.	Conc.	
Gravity Drain	Yes	Yes	
By-pass Piping	Yes	No	
Pressure Gauge	N/A	N/A	
Sight Glass or Level Indicator	Yes	Yes	
Fittings for Sight Glass	N/A	N/A	
Protected Openings	Yes	Yes	
PRV/ARV	N/A	N/A	
On/Off Pressure	N/A	N/A	
Access Padlocked	Yes	Yes	
Height to Max. Water Level	N/A	N/A	

HIGH SERVICE PUMPS

Pump Number	1	2	3
Type	Cent.	Cent.	VFD
Make	Marathon	Marathon	StaRite
Model	Unknown	Unknown	Unknown
Capacity (gpm)	Unknown	Unknown	Unknown
Motor HP	5	5	5
Date Installed	1999	?	2004
Maintenance	OK	OK	OK

Comments VFD = Variable Frequency Drive pump
Pump #3 runs continuously. Others for back-up only to maintain pressure @ 55-60 psi.

OTHER CHEMICAL ADDITIVES:

Chemical Stiles-Kem Phosphate Blend= SK 7661
 Purpose Corrosion Control Inhibitor for Cu/Pb.
 Equipment Used 2-Stenner -3 GPD pumps (each well)
 Feed Rate/ Dose 1.0 ppm PO4 *
 Comments: 60% Poly/40% Ortho Blend added before aerator into larger tank. *PO4 conc. not documented regularly. Test kit should be checked annually with lab.

DISTRIBUTION SYSTEM MAINTENANCE

Cross-Connection Control

Is A CCC Plan On File?	Yes
CCC Plan Appears Adequate?	Yes
CCC Plan Date:	April 2002*
Record Of CCC Plan Implementation?	No *
Number Of RPZ-DC Backflow Devices on System:	None
ReUse Water in Use?	No
Adequate Annual Testing Records?	No testing/ No devices.

Comments: *Florida Water Services Plan. No record of adoption by Aqua Utilities. Operator checks individual homes, only if there is a problem.

Flushing And Valve Maintenance

Distribution	Size of Mains Shown?	Yes
	Valves and Dead-Ends Shown?	Yes
	Hydrants Shown?	No Hydrants on system
Is Distribution Map Available? Map Updated?		Yes /Yes
Is Flushing Plan on File?		No
Flushing Documented?		Yes
# Sites and Frequency of Flushing?		6*/ Monthly
Valve Maintenance Program?		No
Valve Maintenance Activity Documented?		No

Comments: *6 dedicated flush/sampling valves installed on distribution system.

SAMPLING PLANS

Total Coliform Sampling Plan

Approved Sampling Plan?	Yes
Total Coliform Plan Date:	6/2002
# of Samples Required Monthly:	2
Total # of Unique Sites in Plan:	6

Comments: Samples are being collected per plan

Disinfection By-Product (DBP) Sampling

Is The Plan Adequate?	Yes
Maximum Residence Time Site:	160 Greenbriar
Plan Date:	March 2004

Comments: July specified as "annual" sample month.

Lead And Copper (Tap Water) Sampling

Lead And Copper Plan Date:	Sept. 2002
No. Of Standard Sites (In Plan)	17 listed*
No. Of Reduced Sites (In Plan)	5*
Is Corrosion Control Treatment Required? (for Cu or Pb?)	Yes
Present Monitoring Status	Bi Annual
No. Of WQP Sites (In Plan)	1*
Samples Collected per Plan (# Collected)	7

Comments: *Sample plan based on 420 pop. Increase to 20 regular/10 reduced sites and 2 WQP sites required due to adjustment in population with this survey.

MISCELLANEOUS

Emergency Response Plan (ERP)

Required (+ 350 pop.)?	Yes
Date Created:	Due: 12/31/05
Location of Plan:	No plan currently

Comments: _____

Consumer Confidence Reports (CCR)

Distribution / Reporting Timeframes Met?	Yes
CCRs In Conformance With Rules?	Yes
Delivery Methods Appropriate?	Yes
Usual Delivery Method(s):	Mail/ Internet

Comments: _____

Recordkeeping

Analyses, MOR, Inspections Retained for 5 (Bacteria) to 10 yrs?	Yes
Where are the above records stored?	Main Office
Equipment Manuals at Plant (or nearby location)?	Yes*
Operation and Preventive Maintenance Manual ?	No
Maintenance Work Properly Documented?	Yes
Customer Complaints Documented?	Yes

Comments: *All manuals are not bound/indexed.

Security:

Security is adequate except fence is bent over in some areas. Some barbed wire is damaged and missing on top of entrance gate.

MONITORING REQUIREMENTS

Contaminant	Samples Required	Sampling Location	Frequency	Next Deadline For Sampling
Microbiological (Bacti)	2	Each Well	Monthly	02/28/05
	2	Distribution / Per Approved Sampling Plan	Monthly	02/28/05
Volatile Organic Contaminant Group	1	POE	3 years	12/31/06
Synthetic Organic Contaminant Group	1	POE	3 years	12/31/06
Nitrate & Nitrite (as N)	1	POE	Annually	12/31/05
Inorganic Contaminant Group	1	POE	3 years	12/31/06
Asbestos	1	Distribution / Per Approved Sampling Plan	9 years	09/30/12
Radionuclide Contaminant Group	1	POE	Qtrly	03/31/09
Disinfection By-Products (TTHM & HAA5)	1 each	Distribution / Per Approved Sampling Plan	TTHM - Qtrly HAA - Annual	03/31/05 07/31/05
Disinfection Residual Monitoring	2	Distribution / Same as microbiological samples	Monthly	02/28/05
Secondary Contaminant Group	1	POE	3 years	12/31/06
Lead and Copper (Tap Water)	20	Distribution / Per Approved Sampling Plan	6 months	06/30/05

Known Water Quality Issues
None - except for high Trihalomethane and Copper concentrations as listed below.

MAXIMUM CONTAMINANT Level / ACTION Level MCL / AL VIOLATIONS	Other Violations
Trihalomethane MCL Exceeded (12/2004)	Minor CCR Report Violation (7/2002)
90% Copper Action Level Exceeded (9/2004)	Insufficient Pb/Cu TAP Sample Sites (6/2002)
	Late Reporting Pb/Cu TAP Sample Results (12/2001)

Deficiencies:


- 1.) Water plant fence and top barbed wire damaged. (62-555.350 Florida Administrative Code= F.A.C.)
- 2.) No record of cross connection control plan implementation by current owner. (62-555.360 F.A.C.)
- 3.) No documentation of Phosphate concentration in finished water. (Chapter 62-555.35 F.A.C.)

Additional Requirements/Comments:


- 1.) Submit updated Lead/Copper sample plan with increased tap sample and water quality sites.
- 2.) Document annual cleaning of storage tanks and certified tank inspections every five years.
- 3.) Consolidate all equipment manuals into one bound and indexed notebook. (Due: 12/31/05)
- 4.) Create Emergency Response Plan by 12/31/05.
- 5.) Install audio-visual alarm system for power outage or auxiliary power source operation.
- 6.) Exercise key isolation valves and maintain updated distribution system map.
- 7.) Document all legitimate customer complaints and operator responses in a log book.

Inspector: Patricia Carrico / *Patricia Carrico* Title Environmental Specialist II Date 2/23/05

Approved by: Paul Hextell / *Paul Hextell* Title Environmental Supervisor II Date 2/24/05



REPLACE
BARBED
WIRE
HERE





Jeb Bush
Governor

John O. Agwunobi, M.D., M.B.A.
Secretary

Sent Certified: 7000 1670 0008 8254 3007

November 14, 2003

Twin Rivers, PWS ID: 3641399

Florida Water Services
Paul Thompson
P.O. Box 609520
Orlando, FL 32860

Dear Mr. Thompson:

This letter confirms my visit to the above referenced facility on October 17, 2003, in the presence of your representative (Jim Hogan) for the purpose of conducting a sanitary survey. A copy of the Sanitary Survey inspection form is enclosed for your records. There were deficiencies noted during the survey and an office file review was conducted. The deficiencies are listed on page six of the survey form and as follows:

1. Submit updated bacteriological sampling plan for review that represents the extent of the distribution area. Collect samples from indicated sampling points each month. Chapter 62-550.518(1) Florida Administrative Code.
2. Submit water line distribution system area map, valve locations, valve exercise plan and flushing plan. Submit justification that plans are adequate to control biofilm and sedimentation in distribution system. Ch.62-555.330(8) F.A.C. (2003)
3. Install flow meter at point of entry to record water flow rates. Ch.62-555.350(1) F.A.C.
4. Replace severely corroded Hydropneumatic tank. Ch. 62-555.350(1) F.A.C.
5. Submit Cross Connection Control Plan to include placement, annual maintenance, record keeping and potential sites of backsiphonage from used water, industrial, sewage, or any other substance other than potable water. Follow guidance of "Recommended Practice for Backflow Prevention and Cross Connection Control" by American Water Works Association.Ch.62-555.360(2)F.A.C.

You are required to correct items 1,2,3 and 5 deficiencies for the subject system and to provide a written statement to this Department no later than January 15, 2004. Letter should state any changes in equipment and when deficiencies were corrected. Replacement of hydropneumatic tank shall be replaced by March 1, 2004 and notify Department upon completion of replacement.

Please provide the information, where available, for items marked unknown "Unk" on the sanitary survey report. Thank you for your cooperation with this Department. If you have any questions or any items in this letter need further explanation, feel free to call Tuesday through Friday (386) 274-0719.

Sincerely,

Darren R. Guffey
Environmental Specialist II

CC: PWS File # 3641399

VOLUSIA COUNTY HEALTH DEPARTMENT
Environmental Health Engineering Section
1845 HOLSONBACK DRIVE
POST OFFICE BOX 9190
DAYTONA BEACH, FLORIDA 32120

State of Florida
Department of Health
Volusia County Health Department
SANITARY SURVEY REPORT

Plant Name TWIN RIVERS County Volusia PWS ID # 3641399
Plant Location Riverdale Avenue Phone 386-503-4339
Owner Name Florida Water Service Phone 386-445-3311
Owner Address #2 Utility Drive, Palm Coast, FL 32137
Contact Person Jim Hogan/Donald Hulcolm Title A operator Phone 386-503-4339
This Survey Date 10/17/03 Last Survey Date 9/27/00 Last C.I. Date 1/22/03

PWS TYPE & CLASS

- Community (4C)
- Non-transient Non-community
- Non-Community

PWS STATUS

- Approved system with approval number & date
9374 (9/5/67), As Builts (10/7/75)
209892-001 5/27/2003
- Unapproved system

SERVICE AREA CHARACTERISTICS

Subdivision _____
Food Service: Yes No N/A

OPERATION & MAINTENANCE

Certified Operator: Yes No Not required
Operator(s) & Certification Class-Number
David Nelson C-10109, Jim Hogan A-4052,
Ron Pirkle C-6762, Donnie Holcomb A-5091
O & M Log: Yes No Not required
Operator Visitation Frequency
Hrs/day: Required N/A Actual 1.5 hrs.
Days/wk: Required 6 Actual 6
Non-consecutive Days? Yes No N/A
MORs submitted regularly? Yes No N/A
Data missing from MORs? No Yes N/A
N/A

Number of Service Connections 82
Population Served 190 Basis 2.3 x con..est
Average Day (from MORs) 19,303 gpd
Max. Day (from MORs) 28,250 gpd
Max-day Design Capacity 385,000 gpd
Comments none

RAW WATER SOURCE

- GROUND; Number of Wells 1
- SURFACE/UDI; Source N/A
- PURCHASED from PWS ID # N/A
- Emergency Water Source N/A
Emergency Water Capacity N/A

AUXILIARY POWER SOURCE

- Yes None Not Required
- Source Generac Power Systems (Diesel Generator)
- Capacity of Standby (kW) 30
- Switchover: Automatic Manual
- Standby Plan: Yes No
- Hrs Operated Under Load 4 hrs/mo.
- What equipment does it operate?
 Well pumps 1 well pump
 High Service Pumps 2
 Treatment Equipment all treatment
- Satisfy 1/2 max-day demand? Yes No Unk
- Comments none

TREATMENT PROCESSES IN USE

Chloramine
corrosion inhibitor
What additional treatment is needed?
N/A
For control of what deficiencies?
N/A

DISTRIBUTION SYSTEM

Flow Measuring Device None
Meter Size & Type none
Backflow Prevention Devices: Yes No
Cross-connections none
Written Cross-connection Control Program: No
Coliform Sampling Plan: Yes No N/A
Comments Submit updated coliform sampling plan.
Submit distribution flushing and valve exercising
plan. Install flow meter at point of entry.

PWS ID # 3641399
 Date 10/17/03

GROUND WATER SOURCE

Well Number	1	2	3	4
Year Drilled	1967	N/A	N/A	N/A
Depth Drilled (ft.)	190'			
Drilling Method	Rotary			
Type of Grout	Unk			
Static Water Level (ft.)	Unk			
Pumping Water Level (ft. below surface)	Unk			
Design Well Yield (gpm)	Unk			
Test Yield (gpm)	Unk			
Actual Yield (if different than rated capacity)	Unk			
Strainer	Unk			
Length (outside casing) (ft.)	95'			
Diameter (outside casing) (in.)	6"			
Material (outside casing)	Steel			
Well Contamination History	No			
Is inundation of well possible?	No			
6' X 6' X 4" Concrete Pad	Yes			
SET BACKS	Septic Tank	150'		
	Reuse Water	No		
	WW Plumbing	100		
	Other Sanitary Hazard	N/A		
PUMP	Type	Submersible		
	Manufacturer Name	Franklin		
	Model Number	Unk		
	Rated Capacity (gpm)	268		
	Motor Horsepower	7.5		
Well casing 12" above grade?	Yes			
Well Casing Sanitary Seal	Yes			
Raw Water Sampling Tap	Yes			
Above Ground Check Valve	See comment			
Fence/Housing	Yes			
Well Vent Protection	Yes			

COMMENTS No check valve needed at well because of airgap at aeration spray nozzles.

PWS ID # 3641399
 Date 10/17/03

CHLORINATION (Disinfection)

Type: Gas Hypo
 Make Stenner Capacity 3 gpd
 Chlorine Feed Rate unk
 Avg. Amount of Cl₂ gas used N/A
 Chlorine Residuals: Plant * Remote *
 Remote tap location Last house on Tymber Creek rd.
 DPD Test Kit: On-site With operator
 None Not Used Daily
 Injection Points Drips into Clearwell
 Booster Pump Info N/A
 Comments Backup Chlorine pump with operator.
*Chloramine residuals: Plant: 1.82ppm.
Remote: 1.6

Chlorine Gas Use Requirements	YES	NO	Comments
Dual System	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Auto-switchover	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Alarms:			
Loss of Cl ₂ capability	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Loss of Cl ₂ residual	<input type="checkbox"/>	<input type="checkbox"/>	
Cl ₂ leak detection	<input type="checkbox"/>	<input type="checkbox"/>	
Scale	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Chained Cylinders	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Reserve Supply	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Adequate Air-pak	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Sign of Leaks	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Fresh Ammonia	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Ventilation	<input type="checkbox"/>	<input type="checkbox"/>	NA
Room Lighting	<input type="checkbox"/>	<input type="checkbox"/>	NA
Warning Signs	<input type="checkbox"/>	<input type="checkbox"/>	NA
Repair Kits	<input type="checkbox"/>	<input type="checkbox"/>	NA
Fitted Wrench	<input type="checkbox"/>	<input type="checkbox"/>	NA
Housing/Protection	<input checked="" type="checkbox"/>	<input type="checkbox"/>	NA

AERATION (Gases, Fe, & Mn Removal)

Type Spray Capacity unk
 Aerator Condition fair
 Bloodworm Presence no
 Visible Algae Growth no
 Protective Screen Condition very good
 Comments none

STORAGE FACILITIES

(G) Ground (H) Hydropneumatic (E) Elevated
 (B) Bladder (C) Clearwell

Tank Type/Number	C	C	G
Capacity (gal)	4500	4500	1500
Material	concrete	concrete	steel
Gravity Drain	No	No	No
By-pass Piping	No	No	Yes
Pressure Gauge	N/A	N/A	No
Sight Glass or Level Indicator	N/A	N/A	No
Fittings for Sight Glass	N/A	N/A	No
Protected Openings	Yes	Yes	N/A
PRV/ARV	N/A	N/A	Unk
On/Off Pressure	N/A	N/A	N/A
Access Padlocked	Yes	Yes	Yes
Height to Bottom of Elevated Tank	6'	6'	20'
Height to Max. Water Level	5'	5'	19'

Comments Hydropneumatic tank serves as ground storage. Hydropneumatic tank is in poor condition and has several patches covering leaky rusted areas.

HIGH SERVICE PUMPS

Pump Number	1	2	N/A
Type	cent.	cent.	
Make	Magnetek	Magnetek	
Model	Century	Century	
Capacity (gpm)	unk	unk	
Motor HP	5	5/3	
Date Installed	unk	unk	
Maintenance	monthly	monthly	

Comments Pressure gauge is inline at plant.

PWS ID # 3641399
 Date 10/17/03

COMPLIANCE MONITORING COMMUNITY PUBLIC WATER SYSTEMS								
CONTAMINANT	# Samples Required	Sampling Location	C > 3300			C ≤ 3300		
			Frequency	Sample Date	Due Date	Frequency	Sample Date	Due Date
Microbiological (Bact)	1	Each well	monthly			monthly	monthly	Tenth of next month
	2	Distribution						
Volatile Organics	<i>(Note A)</i>	<i>(Note G)</i>	<i>(Notes A, 1)</i>			<i>(Notes A, 2)</i>	2006	
Pesticides & PCBs	<i>(Notes B, E)</i>	<i>(Note G)</i>	3 years <i>(Note 1)</i>			3 years <i>(Note 2)</i>	2006	
Nitrate & Nitrite (as N)	1	POE	annually			annually	2004	
Inorganics	1	POE	3 years <i>(Note 1)</i>			3 years <i>(Note 2)</i>	2006	
Asbestos	1 <i>(Note F)</i>	Distribution	9 years <i>(Note 7)</i>			9 years <i>(Note 8)</i>	2012	
Secondaries	1	POE	3 years <i>(Note 1)</i>			3 years <i>(Note 2)</i>	2006	
Radionuclides	<i>(Note C)</i>	POE	3 years <i>(Note 1)</i>			3 years <i>(Note 2)</i>	2006	
Lead and Copper	<i>(Note D)</i>	---	---			Annually	2004	
Disinfection Byproduct	1	Distribution	Quarterly			Annually	2004	

POE = Point of Entry (Samples shall be taken at each entry point to the distribution system that is representative of each source after treatment.)

See Page 5 for description of italicized notes.

PWS ID # 3641399
 Date 10/17/03

NOTES:

SAMPLES REQUIRED/SAMPLING LOCATION:

Note A See Rule 62-550.515(1), F.A.C. Each system shall take four consecutive quarterly samples during its assigned year in the system's first compliance period. If no contaminant is detected, the system shall monitor annually during the next three-year compliance period. If still no contaminants are detected, systems shall take one sample during each subsequent three-year compliance period.

If the initial monitoring for contaminants listed in Rule 62-550.310(2)(b), F.A.C., was completed prior to December 31, 1992, then each system shall take one sample annually beginning January 1, 1993.

Note B 4 consecutive quarterly samples. Credit will be given for samples taken before January 1, 1993.

Note C See Rule 62-550.519, F.A.C. Compliance shall be based on the average of analyses of four consecutive quarterly samples. A maximum of two quarterly samples may be composited. Subsequent samples shall be collected once every three years.

Note D Contact the Volusia County Health Department at (904) 947-3436 or contact the Florida Rural Water Association.

Note E Contact the Volusia County Health Department at (904) 947-3436 to obtain an application for reduced monitoring.

Note F See Rule 62-550.511(4), F.A.C. A system without asbestos-containing components shall certify to the Department in writing, using DEP Form No. 62-555.910(10), that it is asbestos free. Certification shall satisfy subsections (1), (2), and (3) of the referenced rule, and shall be submitted each nine-year compliance cycle during the specified year the system is required to monitor.

Note G First quarter samples shall be representative of each well. Subsequent samples shall be taken at each entry point to the distribution system that is representative of each source after treatment.

FREQUENCY:

Note 1 First year of each three-year compliance period (calendar years 1993, 1996, 1999, etc.)

Note 2 Second year of each three-year compliance period (calendar years 1994, 1997, 2000, etc.)

Note 3 Third year of each three-year compliance period (calendar years 1995, 1998, 2001, etc.)

Note 4 First year of the first three-year compliance period (i.e. calendar year 1993)

Note 5 Second year of the first three-year compliance period (i.e. calendar year 1994)

Note 6 Third year of the first three-year compliance period (i.e. calendar year 1995)

Note 7 First year of each nine-year compliance cycle (calendar years 1993, 2002, etc.)

Note 8 Second year of each nine-year compliance cycle (calendar years 1994, 2003, etc.)

Note 9 Third year of each nine-year compliance cycle (calendar years 1995, 2004, etc.)

PWS ID # 41399
Date 10/17/03

MONITORING VIOLATIONS	MCL VIOLATIONS
9/9/02 Failed to certify public education per department's deadline concerning Lead and Copper	
7/1/02 Two minor deficiencies on CCR.	
6/30/02 Insufficient number of sites sampled for Lead and Copper.	

DEFICIENCIES:

1. Submit updated bacteriological sampling plan that represents the extent of the distribution area. Collect samples from indicated sampling points. Chapter 62-550.518 (1) Florida Administrative Code
2. Submit water line distribution system area map, valve locations, valve exercise plan and flushing plan. Submit justification that plans are adequate to control biofilm and sedimentation in distribution system. Ch. 62-555.330(8) F.A.C. (2003)
3. Install flow meter at point of entry to record water flow rates. Ch. 62-555.350 (1) F.A.C.
4. Replace severely corroded Hydropneumatic tank. Ch. 62-555.350(1) F.A.C.
5. Submit Cross Connection Control Plan to include placement, annual maintenance, record keeping and potential sites of backsiphonage from used water, industrial, sewage, or any other substance other than potable water. Follow guidance of "Recommended Practice for Backflow Prevention and Cross Connection Control" by American Water Works Association. Ch. 62-555.360(2) F.A.C.

COMMENTS:

1. Stage 1 Disinfection Byproduct Rule requirements pertinent to this system will become effective January 1, 2004. This includes 1 sample per treatment annually per sampling plan during month of warmest water temperature. Submit sampling plan by March 30, 2003 (Example: One sample during one of summer months.)
Chapter 62-550.310(2a) F.A.C.

2. Action Levels were exceeded from samplings of Lead and Copper during fall 2001 and spring 2002 (See data for dates and results). Owner of system changed corrosion inhibitor chemical on 8/21/02 from Stiles-Kem SK-7641 to SK-7661. The change was made upon recommendation of corrosion inhibitor supplier. Subsequent Lead and Copper results in November 2002 and May 2003 have shown no new Action Level trigger.

3. Disinfection Byproducts or total trihalomethanes were elevated consistently from February 2000 (See data for dates and results). Owner installed Ammoniation system early 2003 to reduce the levels of Disinfection Byproducts produced in water system. Subsequent Total Disinfection Byproduct sample from July 2003 show a significant reduction in contaminant levels.

Inspector _____ Title Environmental Specialist II Date 11/14/2003
Approved by _____ Title Environmental Supervisor II Date _____

PWS ID 3640557
Date 5-8-03

OTHER TASTE/ODOR CONTROL PROCESSES
Explain: N/A

AMMONIATION

Make Capital Capacity 400 #/day
Injection Points Recarb basin
Comments _____

COAGULATION (Turbidity Removal)

Chemicals Used N/A
Condition of Floc _____
Is settling OK? _____
Comments _____

SOFTENING (Ca/Mg Hardness Removal)

Chemical Precipitation Process:

Chemicals Used Slaked lime and a polymer:
LC-214 acrylamide
Nature of Floc white flocculent mass
Sludge Blanket Appearance fine
Is settling OK? settles
Excessive carry-over? No
Secondary Precipitation not seen
Effluent Stability stable
Recarbonation Type CO₂ gas
Sludge Recirculation Used Sludge piped to pond
Comments Repairs on softeners alternates

Ion Exchange Process:

Make N/A Model _____
Capacity _____
Grade of Salt for Regeneration _____
Backwash Effluent Destination _____
Comments _____

STABILIZATION

Effluent S.I. N/A Is pH control done? _____
Chemical Used _____
Injection Point _____
pH Range of Effluent _____

FILTRATION (Suspended Solids Removal)

Type Rapid Sand
Size 30 yards³ each No. of Units 3
Length of Filter Runs 95-100 hours
Type of Filter Media silica sand
Is media visible? yes Clean after BW? yes
Filter Rate 800 gpm BW Rate 2700 gpm
Filter Capacity 2.4 MG/d
Cracks/Cementation/Channeling none
Effluent Stability good Algae Growth no
Turbidity in clearwell? Not significant
Head Loss Gauge On each unit
Comments _____

FLUORIDATION

Chemical Used NaHSiF₆ Strength 22-26%
Corrosion Noted on glass Plugging Noted no
Feeder Make/Model LMI A-151-91 FS
High Level Ventilation (acid) Yes
Acid carboys/day tank vented outside N/A
Designated Electrical Outlet (acid) Yes
Analytical Testing Equipment Yes
Anti-siphon Valves Yes
Residual Range 0.6 mg/l
Point of Application Added to main whenever HS
pumps are engaged-then to service or storage
Emergency Eyewash Yes
Comments _____

ADDITIVES

Meets NSF 60 & 61 Yes

PWS ID 3641399
Date 10/17/2003

OTHER TASTE/ODOR CONTROL PROCESSES

Explain: N/A

AMMONIATION

Make Stenner/45M1 Capacity 3gpd
Injection Points Clear well feed point
Comments 19% aqua ammonia in 15 gal containers.

COAGULATION (Turbidity Removal)

Chemicals Used N/A
Condition of Floc _____
Is settling OK? _____
Comments _____

SOFTENING (Ca/Mg Hardness Removal)

Chemical Precipitation Process:

Chemicals Used: N/A
Nature of Floc _____
Sludge Blanket _____
Is settling OK? _____
Excessive carry-over? _____
Secondary Precipitation _____
Effluent Stability _____
Recarbonation Type _____
Sludge Recirculation Used Comments _____

Ion Exchange Process:

Make N/A Model _____
Capacity _____
Grade of Salt for Regeneration _____
Backwash Effluent Destination _____
Comments _____

STABILIZATION

Effluent S.I. N/A Is pH control done? _____
Chemical Used _____
Injection Point _____
pH Range of Effluent _____

FILTRATION (Suspended Solids Removal)

Type N/A
Size _____ No. of Units _____
Length of Filter Runs _____
Type of Filter Media _____
Is media visible? _____ Clean after BW _____
Filter Rate _____ BW Rate _____
Filter Capacity _____
Cracks/Cementation/Channeling _____
Effluent Stability _____ Algae Growth _____
Turbidity in clearwell? _____
Head Loss Gauge _____
Comments _____

FLUORIDATION

Chemical Used N/A Strength _____
Corrosion Noted _____ Plugging Noted _____
Feeder Make/Model _____
High Level Ventilation (acid) _____
Acid carboys/day tank vented outside N/A
Designated Electrical Outlet (acid) _____
Analytical Testing Equipment _____
Anti-siphon Valves _____
Residual Range _____
Point of Application _____
Emergency Eyewash _____
Comments _____

ADDITIVES NSF 60/61: YES

CORROSION CONTROL:

Corrosion Control is poly-orthophosphate
SK 7661, Stiles-Kem Division, Metro Corp. and
is NSF 60 Approved. Feeding rate of 1mg/l
Stenner Pump, Chlorine to Ammonia rate 4:1.

State of Florida
Department of Environmental Protection
Central District
SANITARY SURVEY REPORT

Plant Name VALENCIA TERRACE S/D County Lake PWS ID # 3351421
Plant Location Trout Lane, Fruitland Park Phone 352/787-0980
Owner Name Florida Water Services, Attn: Craig Anderson Phone 407/880-0058
Owner Address P.O. Box 609520, Orlando, FL 32860
Contact Person Will Fontaine Title Lead Operator Phone 352/787-0980
This Survey Date 4/29/04 Last Survey Date 10/4/01 Last C.I. Date 8/24/99

PWS TYPE & CLASS

- Community (5C)
- Non-transient Non-community
- Non-Community

PWS STATUS

- Approved system with approval number & date
HRS #8412, 11/8/72, HRS #B-14673, 7/26/73,
WC35-2019, 1/12/78, WC35-261196, 12/19/94
- Unapproved system

SERVICE AREA CHARACTERISTICS

Residential and Commercial
Food Service: Yes No N/A

OPERATION & MAINTENANCE

Certified Operator: Yes No Not required
Operator(s) & Certification Class-Number
B. Heath C-5824, W. Fontaine C-6813, J. Worrell
C-6597, G. Kissick C-7846
O & M Log: Yes No Not required
Operator Visitation Frequency
Hrs/day: Required _____ Actual _____
Days/wk: Required 6 Actual 6
Non-consecutive Days? Yes No N/A
MORs submitted regularly? Yes No N/A
Data missing from MORs? No Yes N/A

Number of Service Connections 330
Population Served 839 Basis per MOR
Average Day (from MORs) 73,935 gpd
Max. Day (from MORs) .1565 MGD 5/03
Max-day Design Capacity .720 MGD
Comments _____

COMET: SITE ID _____ PROJECT ID _____

RAW WATER SOURCE

- GROUND; Number of Wells 2
- SURFACE/UDI; Source _____
- PURCHASED from PWS ID # _____
- Emergency Water Source _____
Emergency Water Capacity _____

AUXILIARY POWER SOURCE

Yes None Not Required
Source Katolight Generator (propane)
Capacity of Standby (kW) 85
Switchover: Automatic Manual
Standby Plan: Yes No
Hrs Operated Under Load 1 hr/wk.
What equipment does it operate?
 Well pumps All
 High Service Pumps _____
 Treatment Equipment All
Satisfy 1/2 max-day demand? Yes No Unk
Comments _____

TREATMENT PROCESSES IN USE

Chlorination
Aqua Dene for corrosion control
What additional treatment is needed?
For control of what deficiencies?

DISTRIBUTION SYSTEM

Flow Measuring Device Flow Meter
Meter Size & Type 6" McCrometer
Backflow Prevention Devices: Yes No
Cross-connections None observed
Written Cross-connection Control Program: Yes
Coliform Sampling Plan: Yes No N/A
Comments _____

Received

MAY 12 2004

Environmental Services

PWS ID # 3351421Date 5/6/04**GROUND WATER SOURCE**

Well Number	1	2(back-up)		
Year Drilled	1973	1977		
Depth Drilled	285'	350'		
Drilling Method	UNK	Cable Tool		
Type of Grout	UNK	Cement		
Static Water Level	UNK	50'		
Pumping Water Level	UNK	UNK		
Design Well Yield	UNK	UNK		
Test Yield	UNK	UNK		
Actual Yield (if different than rated capacity)	UNK	UNK		
Strainer	UNK	UNK		
Length (outside casing)	130'	190'		
Diameter (outside casing)	8"	8"		
Material (outside casing)	Black Steel	Black Steel		
Well Contamination History	Some	Some		
Is inundation of well possible?	No	No		
6' X 6' X 4" Concrete Pad	Yes	Yes		
SET BACKS	Septic Tank	--	--	
	Reuse Water	--	--	
	WW Plumbing	>100'	>100'	
	Other Sanitary Hazard	None observed	None observed	
PUMP	Type	Vert. Turbine	Submersible	
	Manufacturer Name	Goulds	Jacuzzi	
	Model Number	8DHHC	2056-H5-TZ	
	Rated Capacity (gpm)	750	250	
	Motor Horsepower	50	20	
Well casing 12" above grade?	Yes	No-Accepted		
Well Casing Sanitary Seal	Yes	Yes		
Raw Water Sampling Tap	Yes	Yes		
Above Ground Check Valve	Yes	Yes		
Fence/Housing	Yes	Yes		
Well Vent Protection	Yes	Yes		

COMMENTS Provide additional information for "UNK", if available.

PWS ID # 3351421
 Date 5/6/04

CHLORINATION (Disinfection)

Type: Gas Hypo
 Make Regal Capacity 50 ppd
 Chlorine Feed Rate 9-10 ppd
 Avg. Amount of Cl₂ gas used 3 ppd
 Chlorine Residuals: Plant 1.5 Remote 1.1
 Remote tap location Clubhouse sink
 DPD Test Kit: On-site With operator
 None Not Used Daily
 Injection Points Prior to H/1 & by-pass
 Booster Pump Info 1 HP Goulds mod 25GBC10
 Comments _____

STORAGE FACILITIES

(G) Ground (H) Hydropneumatic (E) Elevated
 (B) Bladder (C) Clearwell

Tank Type/Number	H/1		
Capacity (gal)	6,600		
Material	Steel		
Gravity Drain	Yes		
By-pass Piping	Yes		
Pressure Gauge	Yes		
Sight Glass or Level Indicator	Yes		
Fittings for Sight Glass	Yes		
Protected Openings	Yes		
PRV/ARV	PRV		
On/Off Pressure	40/60		
Access Padlocked	Yes		
Height to Bottom of Elevated Tank			
Height to Max. Water Level			

Comments _____

Chlorine Gas Use Requirements	YES	NO	Comments
Dual System	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Auto-switchover	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Alarms:			
Loss of Cl ₂ capability	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Loss of Cl ₂ residual	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Cl ₂ leak detection	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Scale	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Chained Cylinders	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Reserve Supply	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Adequate Air-pak	<input checked="" type="checkbox"/>	<input type="checkbox"/>	w/operators
Sign of Leaks	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Fresh Ammonia	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Ventilation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Room Lighting	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Warning Signs	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Repair Kits	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Fitted Wrench	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Housing/Protection	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

AERATION (Gases, Fe, & Mn Removal)

Type _____ Capacity _____
 Aerator Condition _____
 Bloodworm Presence _____
 Visible Algae Growth _____
 Protective Screen Condition _____
 Comments _____

HIGH SERVICE PUMPS

Pump Number			
Type			
Make			
Model			
Capacity (gpm)			
Motor HP			
Date Installed			
Maintenance			

Comments _____

State of Florida
Department of Environmental Protection
Central District
SANITARY SURVEY REPORT

Plant Name VENETIAN VILLAGE County Lake PWS ID # 3351426
 Plant Location 38217 Tammi Drive, Lake Jern, FL Phone 352/787-0980
 Owner Name Florida Water Services Attn: Craig Anderson Phone 407/880-0058
 Owner Address P.O. Box 609520, Orlando, FL 32860-9520
 Contact Person Will Fontaine Title Lead Operator Phone 352/787-0980
 This Survey Date 4/28/04 Last Survey Date 6/6/00 Last C.I. Date 10/4/01

PWS TYPE & CLASS

- Community (5D)
 Non-transient Non-community
 Non-Community

PWS STATUS

- Approved system with approval number & date
HRS B14513, 11/9/72, WC35-193389, 6/24/92
WC35-21855, 9/28/94
 Unapproved system

SERVICE AREA CHARACTERISTICS

Subdivision _____

Food Service: Yes No N/A**OPERATION & MAINTENANCE**

Certified Operator: Yes No Not required
 Operator(s) & Certification Class-Number
B. Heath C-5824, J. Worrell C-6597
W. Fontaine C-6813

O & M Log: Yes No Not required

Operator Visitation Frequency

Hrs/day: Required _____ Actual _____

Days/wk: Required 3 Actual 6Non-consecutive Days? Yes No N/AMORs submitted regularly? Yes No N/AData missing from MORs? No Yes N/ANumber of Service Connections 144Population Served 502 Basis MORAverage Day (from MORs) 28,932 gpdMax. Day (from MORs) .063 gpd 5/03Max-day Design Capacity .216 MGD

Comments _____

COMET: SITE ID _____ PROJECT ID _____

RAW WATER SOURCE

- GROUND; Number of Wells 2
 SURFACE/UDI; Source _____
 PURCHASED from PWS ID # _____
 Emergency Water Source _____
 Emergency Water Capacity _____

AUXILIARY POWER SOURCE

- Yes None Not Required
 Source Katolight LP Gas
 Capacity of Standby (kW) 35
 Switchover: Automatic Manual
 Standby Plan: Yes No
 Hrs Operated Under Load 1 hr/wk.

What equipment does it operate?

- Well pumps Wells 1 & 2
 High Service Pumps _____
 Treatment Equipment All

Satisfy 1/2 max-day demand? Yes No Unk
 Comments _____**TREATMENT PROCESSES IN USE**Disinfection

What additional treatment is needed?

For control of what deficiencies?

DISTRIBUTION SYSTEMFlow Measuring Device Flow MeterMeter Size & Type *Backflow Prevention Devices: Yes NoCross-connections None ObservedWritten Cross-connection Control Program: YesColiform Sampling Plan: Yes No N/AComments *4" Precision on primary well.2" Master Meter on back-up well.**Received**

MAY 12 2004

Environmental Services

PWS ID # 3351426Date 5/6/04**GROUND WATER SOURCE**

Well Number	1(inside)	2(outside)		
Year Drilled	1971	1977		
Depth Drilled	200'	230'		
Drilling Method	Rotary	Cable Tool		
Type of Grout	UNK	Neat Cement		
Static Water Level	UNK	UNK		
Pumping Water Level	UNK	UNK		
Design Well Yield	UNK	UNK		
Test Yield	UNK	UNK		
Actual Yield (if different than rated capacity)	UNK	UNK		
Strainer	UNK	UNK		
Length (outside casing)	UNK	123'		
Diameter (outside casing)	8"	6"		
Material (outside casing)	Blk. Steel	Blk. Steel		
Well Contamination History	None noted	None noted		
Is inundation of well possible?	No	No		
6' X 6' X 4" Concrete Pad	Yes	Yes		
SET BACKS	Septic Tank	N/A	N/A	
	Reuse Water	N/A	N/A	
	WW Plumbing	>100'	>100'	
	Other Sanitary Hazard	N/A	N/A	
PUMP	Type	Vert. Turbine	Submersible	
	Manufacturer Name	Peerless	Goulds	
	Model Number	81B-6	6A5	
	Rated Capacity (gpm)	240	100	
	Motor Horsepower	15	5	
Well casing 12" above grade?	Yes	Yes		
Well Casing Sanitary Seal	Yes	Yes		
Raw Water Sampling Tap	Yes	Yes		
Above Ground Check Valve	Yes	Yes		
Fence/Housing	Yes	Yes		
Well Vent Protection	Yes	N/A		

COMMENTS Provide additional information for "UNK", if available.

PWS ID # 3351426
Date 5/6/04

CHLORINATION (Disinfection)

Type: Gas Hypo
Make Chem-tech Capacity 30* gpd
Chlorine Feed Rate 100% W1, 80% W2
Avg. Amount of Cl₂ gas used N/A
Chlorine Residuals: Plant 1.3 Remote 1.1
Remote tap location LS #4 hose bibb
DPD Test Kit: On-site With operator
 None Not Used Daily

Injection Points Prior to H/1
Booster Pump Info _____
Comments This is a dual system - primary system includes 2 chlorinators at 15 gpd capacity each. And a back-up chlorinator at 15 gpd capacity.

Chlorine Gas Use Requirements	YES	NO	Comments
Dual System	<input type="checkbox"/>	<input type="checkbox"/>	
Auto-switchover	<input type="checkbox"/>	<input type="checkbox"/>	
Alarms:			
Loss of Cl ₂ capability	<input type="checkbox"/>	<input type="checkbox"/>	
Loss of Cl ₂ residual	<input type="checkbox"/>	<input type="checkbox"/>	
Cl ₂ leak detection	<input type="checkbox"/>	<input type="checkbox"/>	
Scale	<input type="checkbox"/>	<input type="checkbox"/>	
Chained Cylinders	<input type="checkbox"/>	<input type="checkbox"/>	
Reserve Supply	<input type="checkbox"/>	<input type="checkbox"/>	
Adequate Air-pak	<input type="checkbox"/>	<input type="checkbox"/>	
Sign of Leaks	<input type="checkbox"/>	<input type="checkbox"/>	
Fresh Ammonia	<input type="checkbox"/>	<input type="checkbox"/>	
Ventilation	<input type="checkbox"/>	<input type="checkbox"/>	
Room Lighting	<input type="checkbox"/>	<input type="checkbox"/>	
Warning Signs	<input type="checkbox"/>	<input type="checkbox"/>	
Repair Kits	<input type="checkbox"/>	<input type="checkbox"/>	
Fitted Wrench	<input type="checkbox"/>	<input type="checkbox"/>	
Housing/Protection	<input type="checkbox"/>	<input type="checkbox"/>	

AERATION (Gases, Fe, & Mn Removal)

Type _____ Capacity _____
Aerator Condition _____
Bloodworm Presence _____
Visible Algae Growth _____
Protective Screen Condition _____
Comments _____

STORAGE FACILITIES

(G) Ground (H) Hydropneumatic (E) Elevated
(B) Bladder (C) Clearwell

Tank Type/Number	H/1		
Capacity (gal)	5,000		
Material	Steel		
Gravity Drain	Yes		
By-pass Piping	Yes		
Pressure Gauge	Yes		
Sight Glass or Level Indicator	Yes		
Fittings for Sight Glass	Yes		
Protected Openings	Yes		
PRV/ARV	PRV		
On/Off Pressure	40/60		
Access Padlocked	Yes		
Height to Bottom of Elevated Tank			
Height to Max. Water Level			

Comments 2-4" Neptune compound meter on discharge side of plant.

HIGH SERVICE PUMPS

Pump Number			
Type			
Make			
Model			
Capacity (gpm)			
Motor HP			
Date Installed			
Maintenance			

Comments _____



Jeb Bush
Governor

John O. Agwunobi, M.D., MBA
Secretary

July 19, 2005

CS/Village Water Ltd
PWS: Id. No. 6532779

Carolyn McFalls
Aqua Source Utility, Inc.
6960 Professional Parkway East, Suite 400
Sarasota, FL 34240

Dear Ms. McFalls:

A sanitary survey of your water system conducted on July 18, 2005 indicates the following deficiencies in reference to the public drinking water requirements listed in *Chapter 62 Florida Administrative Code*.

Deficiencies are listed below:

1. The system is not being flushed as necessary. Chapter 62-555.350(2) indicates that all dead end water mains conveying finished drinking water shall be flushed quarterly or in accordance with a written flushing program established by the supplier of water. Please submit a copy of the flushing plan to this Department.
2. Please revise the flushing plan and submit a copy to this Department since new flush valves have been added to the distribution conveyance. Chapter 62-555.350(2) indicates that all dead end water lines supplying drinking water shall be flushed in accordance with a written flushing program.
3. The operation and maintenance manual was not available for review during the sanitary survey. Chapter 62-555.350(13) states that the supplier of water shall provide an operation and maintenance manual for each drinking water treatment plant. The manual must be kept updated and shall contain operation and control procedures, and preventive maintenance and repair procedures, for all plant equipment. Bound and indexed equipment manufacturer manuals shall be considered sufficient to meet the requirements of this section. Please ascertain that a manual will be made available for reference at the plant or at a convenient location near the plant no later than December 31, 2005.

POLK COUNTY HEALTH DEPARTMENT

Daniel O. Haight
Director

ENVIRONMENTAL ENGINEERING DIVISION
2090 East Clower Street, Bartow, FL 33830


Lynne M. Saddler, MD, MPH
Assistant Director

CS/Village Water Ltd
Page 2

4. The drinking water distribution map was not available for review during the sanitary survey. Chapter 62-555.350(14) states that the supplier of water shall have an up-to-date map of the drinking water distribution system. The map must show the location and size of water mains if known; the location of valves and fire hydrants; and the location of any pressure zone boundaries, pumping facilities, storage tanks, and interconnections with other public water systems. Please submit a copy of the map to this office no later than December 31, 2005.

If you have any questions, please contact me at (863) 519-8330 extension 1137.

Sincerely,



Henry Taghiof
Engineer III

HT/adh

Cc: David Rodriguez



Jeb Bush
Governor

Department of Environmental Protection

Northeast District
7825 Baymeadows Way, Suite B-200
Jacksonville Florida 32256-7590

Colleen Castle
Secretary

May 3, 2006

SENT VIA EMAIL: CMMCCCLURE@AQUAAMERICA.COM

Ms. Candice McClure
P.O. Box 490310
Leesburg, FL 34749

Putnam County - Potable Water
Compliance Inspection 2006
Welaka Mobile Home Park // PWS ID: 2541242

Dear Ms. McClure:

A sanitary survey of the above referenced Community Public Water System was conducted on April 19, 2006 with the courteous assistance of Mr. Paul Thompson. The Department is pleased to inform you that your facility is in compliance with the Florida Safe Drinking Water Act, Section 403, Florida Statutes (FS), and the Florida Administrative Code (FAC) Title 62.

To update our files, please provide the Department copies of the following:


1. The Department does not have a Cross-Connection Control Plan for this system. Please provide a copy to this office. If needed, enclosed is a copy of two sample CCCP's to use as an example. Rule 62-555.360(2).
2. The Department has not received a copy of a written Coliform (i.e. bacteriological) Sampling Plan. Please provide a written Plan that addresses the location, timing, and frequency of sampling. Also, it is recommended that the Plan include the protocol that will be followed if either a well or a distribution sample is positive. A copy of a Sample Bacteriological Plan is enclosed. Rule 62-550.518(1).

As a reminder, this system is required to monitor for the following remaining parameters during 2006: All Inorganic contaminants, including Nitrate and Nitrite, Synthetic Organic Contaminants, Volatile Organic Contaminants, Bacteriologicals (monthly), and disinfectant residual levels (monthly with Bacti's).

Page 2 of 2
Ms. Candice McClure
5/3/06

Please call me at (904) 807-3321 or email me at Amber.Otto@dep.state.fl.us if you have any questions. Your cooperation with the Florida Safe Drinking Water Program is appreciated.

Sincerely,



Amber Otto
Environmental Specialist

JJD:BRR:AMO:ao

Correspondence File

cc: Paul Thompson, operator (via mail)

enclosed: Sanitary Survey, CCCP examples, Bacti plan example

State of Florida
 Department of Environmental Protection
 Northeast District
SANITARY SURVEY REPORT

Plant Name Welaka Mobile Home Park County Putnam PWS ID # 251242
 Plant Location Hamilton Road, Satsuma, FL Phone _____
 Owner Name Candice McClure Phone 352-732-0627
 Owner Address P.O. Box 490310, Leesburg, FL 34749
 Designated Rep. Paul Thompson Title Lead Operator Phone 386-937-1143
 Facility Contact Paul Thompson Title Lead Operator Phone 386-937-1143
 This Survey Date 4/19/2006 Last Survey Date 11/17/2006 Last C.I. Date 7/2/02

PWS TYPE & CLASS: Community - (5D)

SERVICE AREA CHARACTERISTICS
Mobile Home Park

Food Service: Yes No N/A

GENERAL INFORMATION

Number of Service Connections 110
 Population Served 250 Basis estimate
 Plant Design Capacity 86,000 gpd
 Basis MORs
 Average Day (from MORs) 13,577 gpd
 Max. Day (from MORs) 32,130 gpd
 Total Storage Capacity 1,800 gallons
 Comments Based on March 2006 data

LOCATION

Latitude 29° 31' 53.75" North
 Longitude 81° 40' 7.49" West
 GPS: Yes Date: 7/16/1997
 Directions HWY. 17 South, Right on CR309, Right on Hamilton Road, Plant is on left past Welaka MHP sign

OPERATION & MAINTENANCE

Certified Operator: Yes No Not required
 Operator(s) & Certification Class-Number
Paul Thompson A-7251

O & M Log: Yes No Not required
 Operator Visitation Frequency
 Hrs/day: Required _____ Actual _____
 Days/wk: Required 2 Actual 5
 Non-consecutive Days? Yes No N/A
 MORs submitted regularly? Yes No N/A
 Data missing from MORs? No Yes N/A

RAW WATER SOURCE

GROUND; Number of Wells _____
 SURFACE/UDI; Source _____
 PURCHASED from PWS ID # _____
 Emergency Water Source Saratoga Harbor
 Emergency Water Capacity _____

AUXILIARY POWER SOURCE

Yes None Not Required
 Source _____
 Capacity of Standby (kW) _____
 Switchover: Automatic Manual
 Standby Plan: Yes No
 Hrs Operated Under Load _____
 What equipment does it operate?
 Well pumps _____
 High Service Pumps _____
 Treatment Equipment _____
 Satisfy 1/2 max-day demand? Yes No Unk
 Comments _____

TREATMENT PROCESSES IN USE

Hypo-chlorination
 What additional treatment is needed?
None
 For control of what deficiencies?
N/A

DISTRIBUTION SYSTEM

Flow Measuring Device Flow Meter
 Meter Size & Type 4' Neptune Meter
 Backflow Prevention Devices: Yes No
 Cross-connections None Seen
 Written Cross-connection Control Program No
 Coliform Sampling Plan: Yes No N/A
 Comments Please submit a cross-connection control plan, and a coliform sampling plan - neither could be found in our files.

Welaka Mobile Home Park

PWS ID # 2541242

Survey Date 4/19/006

GROUND WATER SOURCE

Well Number (PWS Identification)	2541242	
Well Name (System Identification)	1	
Year Drilled	1963	
Depth Drilled	183'	
Latitude	29 31' 53.75"N	
Longitude	81 40 7.49'W	
GPS (Y or N) / Date (if applicable)	Yes 7/16/1997	
Florida Well ID	AAC1852	
Static Water Level	Unknown	
Actual Yield (if different than rated capacity)		
Strainer	Unknown	
Length (outside casing)	85'	
Diameter (outside casing)	4"	
Material (outside casing)	Steel	
Well Contamination History	None	
Is inundation of well possible?	Not Likely	
6' X 6' X 4" Concrete Pad	Yes	
SET BACKS	Septic Tank	None seen
	Reuse Water	None seen
	WW Plumbing	None seen
	Other Sanitary Hazard	None seen
PUMP	Type	Submersible
	Manufacturer Name	Unknown
	Model Number	Unknown
	Rated Capacity (gpm)	76 (last survey)
	Motor Horsepower	5 (last survey)
Well casing 12" above grade?	Yes	
Well Casing Sanitary Seal	Yes	
Raw Water Sampling Tap	Yes - Smooth	
Above Ground Check Valve	Yes	
Fence/Housing	Both	
Well Vent Protection	Yes	

COMMENTS

Welaka Mobile Home Park

PWS ID # 25-1242

Survey Date 4/11/2006

CHLORINATION (Disinfection)

Type: Hypo-Chlorination
 Make Stenner Capacity 10 gpd
 Chlorine Feed Rate _____
 Avg. Amount of Cl₂ gas used N/A
 Chlorine Residuals: Plant 1.5 Remote 1.6
 Remote tap location 118 Cherokee Road
 DPD Test Kit: On-site With operator
 None Not Used Daily
 Injection Points Upstream of hydrotank
 Booster Pump Info _____
 Comments _____

Chlorine Gas Use Requirements	YES	NO	Comments
	N/A		
Dual System	<input type="checkbox"/>	<input type="checkbox"/>	
Auto-switchover	<input type="checkbox"/>	<input type="checkbox"/>	
Alarms:			
Loss of Cl ₂ capability	<input type="checkbox"/>	<input type="checkbox"/>	
Loss of Cl ₂ residual	<input type="checkbox"/>	<input type="checkbox"/>	
Cl ₂ leak detection	<input type="checkbox"/>	<input type="checkbox"/>	
Scale	<input type="checkbox"/>	<input type="checkbox"/>	
Chained Cylinders	<input type="checkbox"/>	<input type="checkbox"/>	
Reserve Supply	<input type="checkbox"/>	<input type="checkbox"/>	
Adequate Air-pak	<input type="checkbox"/>	<input type="checkbox"/>	
Sign of Leaks	<input type="checkbox"/>	<input type="checkbox"/>	
Fresh Ammonia	<input type="checkbox"/>	<input type="checkbox"/>	
Ventilation	<input type="checkbox"/>	<input type="checkbox"/>	
Room Lighting	<input type="checkbox"/>	<input type="checkbox"/>	
Warning Signs	<input type="checkbox"/>	<input type="checkbox"/>	
Repair Kits	<input type="checkbox"/>	<input type="checkbox"/>	
Fitted Wrench	<input type="checkbox"/>	<input type="checkbox"/>	
Housing/Protection	<input type="checkbox"/>	<input type="checkbox"/>	

AERATION (Gases, Fe, & Mn Removal)

Type N/A Capacity _____
 Aerator Condition _____
 Bloodworm Presence _____
 Visible Algae Growth _____
 Protective Screen Condition _____
 Comments _____

STORAGE FACILITIES

(B) Bladder (CW) Clearwell (C) Contact (E) Elevated (G) Ground (H) Hydropneumatic (S.C.) See Comments

Tank Type/Number	H		
Capacity (gal)	3,000		
Material	Steel		
Gravity Drain	Yes		
By-pass Piping	No		
Pressure Gauge	Yes		
Sight Glass or Level Indicator	S.G.		
Fittings for Sight Glass	Yes		
Protected Openings	Yes		
PRV/ARV	PRV		
On/Off Pressure	40/58		
Access Padlocked	Yes		
Height to Bottom of Elevated Tank	N/A		
Height to Max. Water Level	N/A		

Comments _____

HIGH SERVICE PUMPS

Pump Number			
Type			
Make			
Model			
Capacity (gpm)			
Motor HP			
Date Installed			
Maintenance			

Comments _____

Welaka Mobile Home Park


PWS ID # 251242

Survey Date 4/19/2008

COMPLIANCE MONITORING COMMUNITY PUBLIC WATER SYSTEMS			
CONTAMINANT	Last Sampled	Due Date	COMMENTS
Microbiological (Bacteria)	xxxxxxx	Monthly	2 distribution samples + 1 from each raw source (distribution number based upon the population served)
Disinfectant Levels	xxxxxxx	Monthly	2 field readings (i.e. one taken with each microbiological sample that is taken from the distribution system). Only report the quarterly averages of the monthly readings.
Disinfection Byproducts (DBPs)	2004	waiver	Total Trihalomethanes (TTHMs) & Haloacetic Acids (HAA5s) taken in accordance with your D/DBPR Monitoring Plan.
Nitrate & Nitrite (as N)	2005	2006	Taken from each Point of Entry to the distribution system (i.e. from each plant's effluent)
Inorganic Contaminants	2003	2006	Taken from each Point of Entry to the distribution system (i.e. from each plant's effluent)
Volatile Organic Contaminants	2003	2006	Taken from each Point of Entry to the distribution system (i.e. from each plant's effluent)
Synthetic Organic Contaminants	2003	2006	Taken from each Point of Entry to the distribution system (i.e. from each plant's effluent). 2 quarterly samples required if >2,300 people served.
Radionuclides	2003	waiver	Taken from each Point of Entry to the distribution system (i.e. from each plant's effluent)
Secondary Standards	2003	2006	Taken from each Point of Entry to the distribution system (i.e. from each plant's effluent)
Lead and Copper	2005	2008	Samples taken from pre-approved sample points in sites.
Asbestos	waiver	2010	Samples taken from distribution. Waiver available if there is no asbestos pipe in the distribution system.

Unless otherwise noted, all samples shall be representative of each source after treatment.

SCHEMATIC:





Department of Environmental Protection

Jeb Bush
Governor

Northeast District
7825 Baymeadows Way, Suite B200
Jacksonville, Florida 32256-7590

Colleen M. Castille
Secretary

December 22, 2005

Mr. Paul Thompson
Aqua Utilities Inc.
P.O. Box 490310
Leesburg, FL 34749-0310

Putnam County – Potable Water
Saratoga Harbor Water System
PWS ID: 2541008

Dear Mr. Thompson:

On November 2, 2005 a sanitary survey was performed at the above referenced Community Water System with your courteous assistance. The water system was found in good condition. Based on the survey and the water quality data received, this facility is in compliance with the Safe Drinking Water Act, Section 403, Florida Statutes (FS), and the Florida Administrative Code (FAC) title 62.

However, the following is recommended to maintain the facility in compliance with the Drinking Water Program.

1. This facility needs to continue monitoring for Disinfection By-Products on a quarterly basis during 2006. Quarterly monitoring is needed because the annual average (last 4 quarters) for TTHMs is 70.2 ug/L which it is above 60 ug/L per Federal Rule 40 CFR 141.132(b). It is recommended that this water system continue adjusting the aeration/disinfection treatment as necessary to maintain the formation of TTHMs below the 80 ug/L MCL.
2. We recommend to schedule the cleaning and painting of the aerator and tanks during the next year to maintain the system in good condition.

We have received all the chemical analyses due for 2005, and the results were found satisfactory. Enclosed is a copy of the sanitary report for your records. If I may be of further assistance to you, please contact me at (904) 807-3303. Thank you for your cooperation with the Safe Drinking Water Act.

Sincerely,

Blanca R. Rodriguez
Potable Water Section

JD-BRR:brr

"More Protection, Less Process"

Printed on recycled paper.

State of Florida
Department of Environmental Protection
Northeast District
SANITARY SURVEY REPORT

Plant Name Saratoga Harbor WTP County Putnam PWS ID # 2541008
Plant Location Gibbs Road, Satsuma, Florida Phone 386-937-1143
Owner Name Aqua Utilities Inc. - Candice McClure Phone 352-435-4020
Owner Address P.O. Box 490310, Leesburg, FL 34749-0310
Designated Rep. Paul Thompson, Lead Operator Title Supervisor Phone 386-937-1143
Facility Contact Paul Thompson Title Lead Operator Phone 800-250-7532 emerg.
This Survey Date 11/2/2005 Last Survey Date 6/18/01 Last C.I. Date _____

PWS TYPE & CLASS: Community - (4D)

SERVICE AREA CHARACTERISTICS
subdivision _____

Food Service: Yes No N/A

GENERAL INFORMATION

Number of Service Connections 46
Population Served 160 Basis _____
Plant Design Capacity 158,400
Basis _____
Average Day (from MORs) 20,500 gpd
Max. Day (from MORs) 58,800 gpd
Total Storage Capacity 45,000
Comments _____

LOCATION

Latitude 29° 31' 55.16" North
Longitude 81° 40' 59.47" West
GPS: Yes Date: 7/16/97
Directions US 17 South, pass Palatka and continue to Satsuma. Turn right on CR-309 (light in Satsuma). Turn right on Hamilton Rd. Turn left on Saratoga Dr. Turn right on Gibbs Avenue. Plant is on the right on Gibbs Ave.

OPERATION & MAINTENANCE

Certified Operator: Yes No Not required
Operator(s) & Certification Class-Number
Mr. Paul Thompson, C-7251, Aqua Utilities
Operator/Uti superv. 386-937-1143 (cell)
O & M Log: Yes No Not required
Operator Visitation Frequency
Hrs/day: Required _____ Actual _____
Days/wk: Required 5 Actual 5
Non-consecutive Days? Yes No N/A
MORs submitted regularly? Yes No N/A
Data missing from MORs? No Yes N/A

RAW WATER SOURCE

GROUND; Number of Wells 1
 SURFACE/UDI; Source _____
 PURCHASED from PWS ID # _____
 Emergency Water Source _____
Emergency Water Capacity _____

AUXILIARY POWER SOURCE

Yes None Not Required
Source _____
Capacity of Standby (kW) _____
Switchover: Automatic Manual
Standby Plan: Yes No
Hrs Operated Under Load _____
What equipment does it operate?
 Well pumps _____
 High Service Pumps _____
 Treatment Equipment _____
Satisfy 1/2 max-day demand? Yes No Unk
Comments _____

TREATMENT PROCESSES IN USE

Aeration and hypo-chlorination
What additional treatment is needed?

For control of what deficiencies?

DISTRIBUTION SYSTEM

Flow Measuring Device Flow Meter
Meter Size & Type 3" Master Meter
Backflow Prevention Devices: Yes No
Cross-connections none noted
Written Cross-connection Control Program: Yes
Coliform Sampling Plan: Yes No N/A
Comments _____

Saratoga Harbor WTP

PWS ID # 2541008
 Survey Date 11/2/2005

GROUND WATER SOURCE

Well Number (PWS Identification)	1		
Well Name (System Identification)	1		
Year Drilled	1971		
Depth Drilled	179'		
Latitude	29 31' 55.156		
Longitude	81 40' 59.467"		
GPS (Y or N) / Date (if applicable)	Yes-1997		
Florida Well ID	AAC1853		
Static Water Level	Unk		
Actual Yield (if different than rated capacity)			
Strainer	Unk		
Length (outside casing)	Unk		
Diameter (outside casing)	4"		
Material (outside casing)	Steel		
Well Contamination History	None		
Is inundation of well possible?	No		
6' X 6' X 4" Concrete Pad	Yes		
SET BACKS	Septic Tank	Ok	
	Reuse Water	NA	
	WW Plumbing	Ok	
	Other Sanitary Hazard	Ok	
PUMP	Type	Centrifugal -two	
	Manufacturer Name	Goulds	
	Model Number	3556	
	Rated Capacity (gpm)	110 each	
	Motor Horsepower	7.5 each	
Well casing 12" above grade?	Yes		
Well Casing Sanitary Seal	Yes		
Raw Water Sampling Tap	Yes		
Above Ground Check Valve	Yes		
Fence/Housing	Fence		
Well Vent Protection	No		

COMMENTS

One well and two well pumps, same type.

Saratoga Harbor WTP

PWS ID # 2541008

Survey Date 11/2/2005

CHLORINATION (Disinfection)

Type: Hypo-Chlorination
 Make Stenner Capacity 3 gpd
 Chlorine Feed Rate 50%
 Avg. Amount of Cl₂ gas used N/A
 Chlorine Residuals: Plant 1.6 Remote 1.5
 Remote tap location _____
 DPD Test Kit: On-site With operator
 None Not Used Daily
 Injection Points prior hydrotank
 Booster Pump Info _____
 Comments CL2 analyzer is not used anymore

Chlorine Gas Use Requirements	YES	NO	Comments
Dual System	<input type="checkbox"/>	<input type="checkbox"/>	
Auto-switchover	<input type="checkbox"/>	<input type="checkbox"/>	
Alarms:			
Loss of Cl ₂ capability	<input type="checkbox"/>	<input type="checkbox"/>	
Loss of Cl ₂ residual	<input type="checkbox"/>	<input type="checkbox"/>	
Cl ₂ leak detection	<input type="checkbox"/>	<input type="checkbox"/>	
Scale	<input type="checkbox"/>	<input type="checkbox"/>	
Chained Cylinders	<input type="checkbox"/>	<input type="checkbox"/>	
Reserve Supply	<input type="checkbox"/>	<input type="checkbox"/>	
Adequate Air-pak	<input type="checkbox"/>	<input type="checkbox"/>	
Sign of Leaks	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Fresh Ammonia	<input type="checkbox"/>	<input type="checkbox"/>	
Ventilation	<input type="checkbox"/>	<input type="checkbox"/>	
Room Lighting	<input type="checkbox"/>	<input type="checkbox"/>	
Warning Signs	<input type="checkbox"/>	<input type="checkbox"/>	
Repair Kits	<input type="checkbox"/>	<input type="checkbox"/>	
Fitted Wrench	<input type="checkbox"/>	<input type="checkbox"/>	
Housing/Protection	<input type="checkbox"/>	<input type="checkbox"/>	

AERATION (Gases, Fe, & Mn Removal)

Type cascade Capacity 215 gpm
 Aerator Condition good
 Bloodworm Presence none
 Visible Algae Growth none
 Protective Screen Condition good
 Comments _____

STORAGE FACILITIES

(B) Bladder (CW) Clearwell (C) Contact (E) Elevated
 (G) Ground (H) Hydropneumatic (S.C.) See Comments

Tank Type/Number	G	H	
Capacity (gal)	40000	5000	
Material	steel	steel	
Gravity Drain	Yes	Yes	
By-pass Piping	Yes	No	
Pressure Gauge	N/A	Yes	
Sight Glass or Level Indicator	No	S.G.	
Fittings for Sight Glass	N/A	Yes	
Protected Openings	Yes	Yes	
PRV/ARV	N/A	PRV	
On/Off Pressure	NA	40-60	
Access Padlocked	Yes	Yes	
Height to Bottom of Elevated Tank		NA	
Height to Max. Water Level			

Comments _____

 Pressure, good.

HIGH SERVICE PUMPS

Pump Number	1	2	
Type	centr	centr	
Make	Goulds	Goulds	
Model			
Capacity (gpm)	140	140	
Motor HP	7.5	7.5	
Date Installed			
Maintenance	fair	fair	

Comments _____


Saratoga Harbor WTP

PWS ID # 2541008
 Survey Date 11/2/2005

COMPLIANCE MONITORING COMMUNITY PUBLIC WATER SYSTEMS			
CONTAMINANT	Last Sampled	Due Date	COMMENTS
Microbiological (Bacteria)	xxxxxxx	Monthly	distribution samples + 1 from <u>each</u> raw source (distribution number based upon the population served)
Disinfectant Levels	xxxxxxx	Monthly	field readings (i.e. one taken with each microbiological sample that is taken from the distribution system). Only report the quarterly averages of the monthly readings.
Disinfection Byproducts (DBPs)	2005	2006	Total Trihalomethanes (TTHMs) & Haloacetic Acids (HAA5s) taken in accordance with your D/DBPR Monitoring Plan.
Nitrate & Nitrite (as N)	2005	2006	Taken from <u>each</u> Point of Entry to the distribution system (i.e. from each plant's effluent)
Inorganic Contaminants	2003	2006	Taken from <u>each</u> Point of Entry to the distribution system (i.e. from each plant's effluent)
Volatile Organic Contaminants	2003	2006	Taken from <u>each</u> Point of Entry to the distribution system (i.e. from each plant's effluent)
Synthetic Organic Contaminants	2003	2006	Taken from <u>each</u> Point of Entry to the distribution system (i.e. from each plant's effluent). 2 quarterly samples required if >3,300 people served.
Radionuclides	2003	2009	Taken from <u>each</u> Point of Entry to the distribution system (i.e. from each plant's effluent)
Secondary Standards	2003	2006	Taken from <u>each</u> Point of Entry to the distribution system (i.e. from each plant's effluent)
Lead and Copper	2004	2007	Samples taken from pre-approved sample plan sites.
Asbestos	waiver	2011 or waiver	Samples taken from distribution. Waiver available if there is no asbestos pipe in the distribution system.

Unless otherwise noted, all samples shall be representative of each source after treatment.

SCHEMATIC:





Jeb Bush
Governor

Department of Environmental Protection

Northeast District
7825 Baymeadows Way, Suite B200
Jacksonville, Florida 32256-7590

David B. Struhs
Secretary

March 4, 2004

Mr. Craig Anderson
Florida Water Services
Post Office Box 609520
Orlando, Florida 32860

Received

MAR 08 2004

Dear Mr. Anderson:

Environmental Services

Putnam County – Potable Water
Wootens Mobile Home Park
PWS ID: 2541280

On March 3, 2004 a Sanitary Survey inspection of the referenced community water system was conducted with the courteous assistance of Mr. Paul Thompson and Mr. Donald Holcomb of Florida Water Services. I was pleased to find that the water system is in good operating condition and generally well maintained. Based on this survey and our records, the Department is pleased to inform you that the above referenced facility is in compliance with the Florida Safe Drinking Water Act, Sections 403, Florida Statutes (FS), and the rules promulgated there-under, Florida Administrative Code (FAC) Title 62.

A copy of the sanitary survey report is enclosed for your records. If I may be of further assistance to you, please contact me at Annalise.Stahlman@dep.state.fl.us or (904) 807-3335. Thank you for your cooperation with Florida's Safe Drinking Water Act.

Sincerely:

Annalise M. Stahlman
Environmental Specialist

AMS
Correspondence File
EDC:BRR:AMS:ams

Enclosure: Sanitary Survey Dated 3/3/04

"More Protection, Less Process"

Printed on recycled paper.

State of Florida
 Department of Environmental Protection
 Northeast District
SANITARY SURVEY REPORT

Plant Name WOOTENS MOBILE HOME PARK County Putnam PWS ID # 2541280
 Plant Location Point Pleasant at Hess Road, Georgetown, Florida Phone 386-329-1122
 Owner Name Florida Water Services Phone 407-880-0058
 Owner Address Post Office Box 609520, Orlando, Florida 32860
 Contact Person Mr. Paul Thompson Title Lead Operator, FWS Phone 386-329-1122
 This Survey Date 3/3/04 Last Survey Date 6/18/01 Last C.I. Date 8/1/02

PWS TYPE & CLASS: Community - (5D)

SERVICE AREA CHARACTERISTICS

Residential Mobile Home Park

Food Service: Yes No N/A

GENERAL INFORMATION

Number of Service Connections 29
 Population Served 29 Basis approximation
 Plant Design Capacity 36,000 gpd
 Basis well design capacity
 Average Day (from MORs) 2,267 gpd
 Max. Day (from MORs) 3,560 gpd
 Total Storage Capacity 670 gallons
 Comments Data based on January 2004 MOR

LOCATION

Latitude 29° 23' 45.66" North
 Longitude 81° 39' 0.56" West
 GPS: Yes Date: 7/30/97
 Directions US 17 South, Right at CR309, right on Parker Rd., Right on Hess Rd., Plant is at the intersection with Pleasant Circle

OPERATION & MAINTENANCE

Certified Operator: Yes No Not required
 Operator(s) & Certification Class-Number
Paul Thompson, A-7251
Donald Holcomb, A-5091
 O & M Log: Yes No Not required
 Operator Visitation Frequency
 Hrs/day: Required N/A Actual N/A
 Days/wk: Required 3 Actual 5
 Non-consecutive Days? Yes No N/A
 MORs submitted regularly? Yes No N/A
 Data missing from MORs? No Yes N/A
Complete Operations, Maintenance, Equipment Logs and Sampling plans on site.

COMET: SITE ID _____ PROJECT ID _____

RAW WATER SOURCE

GROUND; Number of Wells 1
 SURFACE/UDI; Source _____
 PURCHASED from PWS ID # _____
 Emergency Water Source _____
 Emergency Water Capacity _____

AUXILIARY POWER SOURCE

Yes None Not Required
 Source _____
 Capacity of Standby (kW) _____
 Switchover: Automatic Manual
 Standby Plan: Yes No
 Hrs Operated Under Load _____
 What equipment does it operate?
 Well pumps _____
 High Service Pumps _____
 Treatment Equipment _____
 Satisfy 1/2 max-day demand? Yes No Unk
 Comments _____

TREATMENT PROCESSES IN USE

Hypo-chlorination and Aeration
 What additional treatment is needed?
None
 For control of what deficiencies?
N/A

DISTRIBUTION SYSTEM

Flow Measuring Device Flow Meter
 Meter Size & Type 2" Precision Meter
 Backflow Prevention Devices: Yes No
 Cross-connections None Noted
 Written Cross-connection Control Program: Yes
 Coliform Sampling Plan: Yes No N/A
 Comments Satisfactory

PWS ID # 2541280Survey Date 3/3/04**GROUND WATER SOURCE**

Well Number (PWS Identification)	2541280		
Well Name (System Identification)	1		
Year Drilled	Unknown		
Depth Drilled	Unknown		
Latitude	29:23:45.66		
Longitude	81:39:0.559		
GPS (Y or N) / Date (if applicable)	Yes, 7/30/97		
Florida Well ID	AAC1981		
Static Water Level	Unknown		
Actual Yield (if different than rated capacity)			
Strainer	Unknown		
Length (outside casing)	Unknown		
Diameter (outside casing)	2"		
Material (outside casing)	Steel		
Well Contamination History	None		
Is inundation of well possible?	No		
6' X 6' X 4" Concrete Pad	OK		
SET BACKS	Septic Tank		
	Reuse Water		
	WW Plumbing		
	Other Sanitary Hazard		
PUMP	Type	Jet	
	Manufacturer Name	Goulds	
	Model Number	GT10	
	Rated Capacity (gpm)	20	
	Motor Horsepower	1	
Well casing 12" above grade?	OK		
Well Casing Sanitary Seal	OK		
Raw Water Sampling Tap	OK - smooth		
Above Ground Check Valve	OK		
Fence/Housing	Secure		
Well Vent Protection	Not required		

COMMENTS The well appears to be in good condition.

PWS ID # 2541280
 Survey Date 3-Mar-04

CHLORINATION (Disinfection)

Type: Hypo-Chlorination
 Make Stenner Capacity 17 gpd
 Chlorine Feed Rate 40%
 Avg. Amount of Cl₂ gas used N/A
 Chlorine Residuals: Plant 1.0 Remote 1.0
 Remote tap location outside tap
 DPD Test Kit: On-site With operator
 None Not Used Daily
 Injection Points upstream of hydro tank
 Booster Pump Info N/A
 Comments Satisfactory

Chlorine Gas Use Requirements	YES	NO	Comments
Dual System	<input type="checkbox"/>	<input type="checkbox"/>	
Auto-switchover	<input type="checkbox"/>	<input type="checkbox"/>	
Alarms:			
Loss of Cl ₂ capability	<input type="checkbox"/>	<input type="checkbox"/>	
Loss of Cl ₂ residual	<input type="checkbox"/>	<input type="checkbox"/>	
Cl ₂ leak detection	<input type="checkbox"/>	<input type="checkbox"/>	
Scale	<input type="checkbox"/>	<input type="checkbox"/>	
Chained Cylinders	<input type="checkbox"/>	<input type="checkbox"/>	
Reserve Supply	<input type="checkbox"/>	<input type="checkbox"/>	
Adequate Air-pak	<input type="checkbox"/>	<input type="checkbox"/>	
Sign of Leaks	<input type="checkbox"/>	<input type="checkbox"/>	
Fresh Ammonia	<input type="checkbox"/>	<input type="checkbox"/>	
Ventilation	<input type="checkbox"/>	<input type="checkbox"/>	
Room Lighting	<input type="checkbox"/>	<input type="checkbox"/>	
Warning Signs	<input type="checkbox"/>	<input type="checkbox"/>	
Repair Kits	<input type="checkbox"/>	<input type="checkbox"/>	
Fitted Wrench	<input type="checkbox"/>	<input type="checkbox"/>	
Housing/Protection	<input type="checkbox"/>	<input type="checkbox"/>	

AERATION (Gases, Fe, & Mn Removal)

Type Cascade Capacity _____
 Aerator Condition Good
 Bloodworm Presence No
 Visible Algae Growth No
 Protective Screen Condition Good
 Comments Aerator appears to be in good condition

STORAGE FACILITIES

(G) Ground (H) Hydropneumatic (E) Elevated
 (B) Bladder (C) Clearwell

Tank Type/Number	G	H1	H2
Capacity (gal)	1000	480	315
Material	fiber	steel	steel
Gravity Drain	Yes	Yes	Yes
By-pass Piping	Yes	Yes	Yes
Pressure Gauge	N/A	Yes	Yes
Sight Glass or Level Indicator	No	No	No
Fittings for Sight Glass	N/A	N/A	N/A
Protected Openings	Yes	N/A	N/A
PRV/ARV	N/A	None	None
On/Off Pressure	N/A	40/50	40/50
Access Padlocked	Yes	Yes	Yes
Height to Bottom of Elevated Tank	N/A	N/A	N/A
Height to Max. Water Level	N/A	N/A	N/A

Comments Storage Facilities appear to be in good operating condition.

HIGH SERVICE PUMPS

Pump Number	1	2	
Type	Cent.	Cent.	
Make	Goulds	Goulds	
Model	.	.	
Capacity (gpm)			
Motor HP	3	3	
Date Installed	Unk.	Unk.	
Maintenance	Good	Good	


Comments * Model # 3BF23012H
 Pumps appear in good condition

PWS ID # 2541280
 Survey Date 3-Mar-04

COMPLIANCE MONITORING COMMUNITY PUBLIC WATER SYSTEMS serving < 3300 persons			
CONTAMINANT	Last Sampled	Due Date	COMMENTS
Microbiological (Bacti)	xxxxxxx	Monthly	2 distribution samples + 1 from each raw source (based upon population served)
Volatile Organic Contaminants	2003	<u>2006</u>	Samples due every 3 years
Synthetic Organic Contaminants	2003	<u>2006</u>	Samples due every 3 years
Nitrate & Nitrite (as N)	2003	<u>2004</u>	Nitrate/Nitrite due annually
Inorganic Contaminants	2003	<u>2006</u>	Inorganic Samples due every 3 years
Asbestos	Waiver	Waiver expires 12/31/2010	Samples taken from distribution. Waiver available if no asbestos pipe in the distribution system.
Secondary Standards	2003	<u>2006</u>	Secondaries due every 3 years
Radionuclides	2003	<u>2006</u>	Radionuclides due every 3 years
Disinfection Byproducts [i.e. Total Trihalomethanes (TTHMs) and Haloacetic Acids (HAA5s)];	N/A	<u>2004</u>	Per sampling plan
Lead and Copper	2001	<u>2004</u>	Sample locations are from pre-approved sample plan

Unless otherwise noted, all samples shall be taken at each entry point to the distribution system, and representative of each source after treatment.

SCHEMATIC:





Jeb Bush
Governor

Department of Environmental Protection

Southwest District
3804 Coconut Palm Drive
Tampa, Florida 33619

Colleen M. Castille
Secretary

March 17, 2005

RECEIVED
MAR 18 2005
Aqua Utilities
Florida Inc.

Ms. Carolyn McFalls
Regional Compliance Supervisor
Aqua Utilities Florida, Inc.
6960 Professional Parkway East, Suite 400
Sarasota, FL 34240

Re: Sanitary Survey Report
Zephyr Shores MHP
PWS-ID No. 651-2018
Pasco County

Dear Ms. McFalls:

Enclosed please find a copy of the Sanitary Survey Report for the above referenced potable water system. No deficiencies were noted during the recent inspection.

If you have any questions or concerns, please contact me at (813) 744-6100, extension 319.

Sincerely,

Edward Watson
Environmental Specialist III
Drinking Water Section

EW

Enclosure

"More Protection, Less Process"

Printed on recycled paper.

State of Florida
Department of Environmental Protection
Southwest District
SANITARY SURVEY REPORT

Plant Name ZEPHYR SHORES ESTATES County PASCO PWS ID # 6512018
Plant Location SR 54 West of Zephyrhills Phone 941-907-747
Owner Name Aqua Utilities Florida, Inc. Phone _____
Owner Address 6960 Professional Pkwy. East, Suite 400 Sarasota, FL 34240
Contact Person Carolyn McFalls Title Compliance Sup. Phone _____
This Survey Date 2/25/05 Last Survey Date 9/5/01 Last C.I. Date _____

PWS TYPE & CLASS

- Community (SD)
- Non-transient Non-community
- Non-Community

PWS STATUS

- Approved system with approval number & date
permit 13515, 11-3-71 & WC-51-1146 10-2-78
- Unapproved system

SERVICE AREA CHARACTERISTICS

Mobile Home Park
Food Service: Yes No N/A

OPERATION & MAINTENANCE

Certified Operator: Yes No Not required
Operator(s) & Certification Class-Number
David Rodriguez 7880-A

O & M Log: Yes No Not required

Operator Visitation Frequency
Hrs/day: Required _____ Actual _____
Days/wk: Required 2 Actual 5
Non-consecutive Days? Yes No N/A
MORs submitted regularly? Yes No N/A
Data missing from MORs? No Yes N/A

Number of Service Connections 215
Population Served 540 Basis Jan. 2005 MOR
Average Day (from MORs) 37129 gpd
Max. Day (from MORs) 49000 gpd
Max-day Design Capacity _____ gpd
Comments _____

COMET: SITE ID _____ PROJECT ID _____

RAW WATER SOURCE

- GROUND; Number of Wells 1
- SURFACE/UDI; Source _____
- PURCHASED from PWS ID # 6512685
- Emergency Water Source _____
Emergency Water Capacity _____

AUXILIARY POWER SOURCE

- Yes None Not Required

Source _____
Capacity of Standby (kW) _____
Switchover: Automatic Manual
Standby Plan: Yes No
Hrs Operated Under Load _____
What equipment does it operate?
 Well pumps _____
 High Service Pumps _____
 Treatment Equipment _____
Satisfy 1/2 max-day demand? Yes No Unk
Comments Has interconnect with PCUD SE #1

TREATMENT PROCESSES IN USE

Chlorination
What additional treatment is needed?
For control of what deficiencies?

DISTRIBUTION SYSTEM

Flow Measuring Device Flow Meter
Meter Size & Type Water Spec.
Backflow Prevention Devices: Yes No
Cross-connections None
Written Cross-connection Control Program: Yes
Coliform Sampling Plan: Yes No N/A
Comments _____

PWS ID # 6512018
 Date 3/16/05

GROUND WATER SOURCE

Well Number	1 / AAC0104		
Year Drilled	Unk		
Depth Drilled	Unk		
Drilling Method	Unk		
Type of Grout	Unk		
Static Water Level	Unk		
Pumping Water Level	Unk		
Design Well Yield	Unk		
Test Yield	Unk		
Actual Yield (if different than rated capacity)	Unk		
Strainer	Unk		
Length (outside casing)	Unk		
Diameter (outside casing)	Unk		
Material (outside casing)	Unk		
Well Contamination History	None		
Is inundation of well possible?	No		
6' X 6' X 4" Concrete Pad	Yes		
SET BACKS	Septic Tank	-	
	Reuse Water	-	
	WW Plumbing	-	
	Other Sanitary Hazard	-	
PUMP	Type	Submersible	
	Manufacturer Name	Unk	
	Model Number	Unk	
	Rated Capacity (gpm)	Unk	
	Motor Horsepower	Unk	
Well casing 12" above grade?	Yes		
Well Casing Sanitary Seal	Ok		
Raw Water Sampling Tap	Yes		
Above Ground Check Valve	Yes		
Fence/Housing	Yes		
Well Vent Protection	Yes		

COMMENTS _____

PWS ID # 6512018
 Date 3/16/05

CHLORINATION (Disinfection)

Type: Gas Hypo
 Make Chem Tech Capacity 15 gpd
 Chlorine Feed Rate _____
 Avg. Amount of Cl₂ gas used N/A
 Chlorine Residuals: Plant 4.28 Remote 1.67
 Remote tap location lift station water tap
 DPD Test Kit: On-site With operator
 None Not Used Daily
 Injection Points _____
 Booster Pump Info _____
 Comments _____

Chlorine Gas Use Requirements	YES	NO	Comments
Dual System	<input type="checkbox"/>	<input type="checkbox"/>	
Auto-switchover	<input type="checkbox"/>	<input type="checkbox"/>	
Alarms:			
Loss of Cl ₂ capability	<input type="checkbox"/>	<input type="checkbox"/>	
Loss of Cl ₂ residual	<input type="checkbox"/>	<input type="checkbox"/>	
Cl ₂ leak detection	<input type="checkbox"/>	<input type="checkbox"/>	
Scale	<input type="checkbox"/>	<input type="checkbox"/>	
Chained Cylinders	<input type="checkbox"/>	<input type="checkbox"/>	
Reserve Supply	<input type="checkbox"/>	<input type="checkbox"/>	
Adequate Air-pak	<input type="checkbox"/>	<input type="checkbox"/>	
Sign of Leaks	<input type="checkbox"/>	<input type="checkbox"/>	
Fresh Ammonia	<input type="checkbox"/>	<input type="checkbox"/>	
Ventilation	<input type="checkbox"/>	<input type="checkbox"/>	
Room Lighting	<input type="checkbox"/>	<input type="checkbox"/>	
Warning Signs	<input type="checkbox"/>	<input type="checkbox"/>	
Repair Kits	<input type="checkbox"/>	<input type="checkbox"/>	
Fitted Wrench	<input type="checkbox"/>	<input type="checkbox"/>	
Housing/Protection	<input type="checkbox"/>	<input type="checkbox"/>	

AERATION (Gases, Fe, & Mn Removal)

Type _____ Capacity _____
 Aerator Condition _____
 Bloodworm Presence _____
 Visible Algae Growth _____
 Protective Screen Condition _____
 Comments _____

STORAGE FACILITIES

(G) Ground (H) Hydropneumatic (E) Elevated
 (B) Bladder (C) Clearwell

Tank Type/Number	H-1		
Capacity (gal)	7512		
Material	steel		
Gravity Drain	Yes		
By-pass Piping	Yes		
Pressure Gauge	Yes		
Sight Glass or Level Indicator	Yes		
Fittings for Sight Glass			
Protected Openings	N/A		
PRV/ARV	PRV		
On/Off Pressure	60 psi		
Access Padlocked	Yes		
Height to Bottom of Elevated Tank			
Height to Max. Water Level			

Comments _____

HIGH SERVICE PUMPS

Pump Number			
Type			
Make			
Model			
Capacity (gpm)			
Motor HP			
Date Installed			
Maintenance			

Comments _____

PWS ID # 6512018
 Date 03/16/05

03/22/2005 TUE 10:31 FAX

COMPLIANCE MONITORING COMMUNITY PUBLIC WATER SYSTEMS									
CONTAMINANT	PWS Screen	# Samples Required	Sampling Location	C > 3300			C ≤ 3300		
				Frequency	Sample Date	Due Date	Frequency	Sample Date	Due Date
Microbiological (Bacte)	024	1	Each well	monthly			monthly		monthly
		2	Distribution						monthly
Volatile Organics	028	<i>(Note A)</i>	<i>(Note H)</i>	<i>(Notes A, 1)</i>			<i>(Notes A, 2)</i>	2003	2006
Pesticides & PCBs	029	<i>(Notes B, E)</i>	<i>(Note H)</i>	3 years <i>(Note 1)</i>			3 years <i>(Note 2)</i>	2003	2006
Nitrate & Nitrite (as N)	030	1	POE	annually			annually	2004	2005
Inorganics	030	1	POE	3 years <i>(Note 1)</i>			3 years <i>(Note 2)</i>	2003	2006
Asbestos	030	1 <i>(Note F)</i>	Distribution	9 years <i>(Note 7)</i>			9 years <i>(Note 8)</i>	Waiver	
Secondaries	031	1	POE	3 years <i>(Note 1)</i>			3 years <i>(Note 2)</i>	2003	2006
Radionuclides	033	<i>(Note C)</i>	POE	3 years <i>(Note 1)</i>			3 years <i>(Note 2)</i>	2003	2009
Group I UOCs	035	<i>(Notes B, E, G)</i>	POE	<i>(Note 4)</i>			<i>(Note 5)</i>		
Group II UOCs	034	1 <i>(Notes E, G)</i>	POE	3 years <i>(Note 1)</i>			3 years <i>(Note 2)</i>		
Group III UOCs	036, 037	1 <i>(Note G)</i>	POE	<i>(Note 4)</i>			<i>(Note 5)</i>		
Lead and Copper	047	<i>(Note D)</i>	---	---			---	2003	2006
DBPs	027	1	Distribution				Annual	2004	2005

POE = Point of Entry (Samples shall be taken at each entry point to the distribution system that is representative of each source after treatment.)

See Page 5 for description of italicized notes.

PWS ID # 6512018Date 3/16/05**NOTES:****# SAMPLES REQUIRED/SAMPLING LOCATION:**

Note A See Rule 62-550.515(1), F.A.C. Each system shall take four consecutive quarterly samples during its assigned year in the system's first compliance period. If no contaminant is detected, the system shall monitor annually during the next three-year compliance period. If still no contaminants are detected, systems shall take one sample during each subsequent three-year compliance period.

If the initial monitoring for contaminants listed in Rule 62-550.310(2)(b), F.A.C., was completed prior to December 31, 1992, then each system shall take one sample annually beginning January 1, 1993.

Note B 4 consecutive quarterly samples. Credit will be given for samples taken before January 1, 1993.

Note C See Rule 62-550.519, F.A.C. Compliance shall be based on the average of analyses of four consecutive quarterly samples. A maximum of two quarterly samples may be composited. Subsequent samples shall be collected once every three years.

Note D Contact the Southwest District's Drinking Water Program at (813) 744-6100 or contact the Florida Rural Water Association.

Note E Contact the Southwest District's Drinking Water Program at (813) 744-6100 to obtain an application for reduced monitoring.

Note F See Rule 62-550.511(4), F.A.C. A system without asbestos-containing components shall certify to the Department in writing, using DEP Form No. 62-555.910(10), that it is asbestos free. Certification shall satisfy subsections (1), (2), and (3) of the referenced rule, and shall be submitted each nine-year compliance cycle during the specified year the system is required to monitor.

Note G See Rule 62-550.521(4), F.A.C. Systems serving less than 150 service connections and serving fewer than 350 persons should notify the Department, by submitting DEP Form No. 62-555.910(11), that their system is available for testing. Normally, these small systems will not be required to monitor for UOCs. Do not send such samples to the Department unless required to do so by the Department.

Note H First quarter samples shall be representative of each well. Subsequent samples shall be taken at each entry point to the distribution system that is representative of each source after treatment.

FREQUENCY:

Note 1 First year of each three-year compliance period (calendar years 1993, 1996, 1999, etc.)

Note 2 Second year of each three-year compliance period (calendar years 1994, 1997, 2000, etc.)

Note 3 Third year of each three-year compliance period (calendar years 1995, 1998, 2001, etc.)

Note 4 First year of the first three-year compliance period (i.e. calendar year 1993)

Note 5 Second year of the first three-year compliance period (i.e. calendar year 1994)

Note 6 Third year of the first three-year compliance period (i.e. calendar year 1995)

Note 7 First year of each nine-year compliance cycle (calendar years 1993, 2002, etc.)

Note 8 Second year of each nine-year compliance cycle (calendar years 1994, 2003, etc.)

Note 9 Third year of each nine-year compliance cycle (calendar years 1995, 2004, etc.)

PWS ID # 6512018
Date 03/16/05

MONITORING VIOLATIONS	MCL VIOLATIONS

DEFICIENCIES:

No deficiencies noted at the time of inspection

**CCR needs to contain information from sampling of Zephyr Shores and Pasco County Utilities interconnect.

* Operator indicated at inspection interconnect valve is kept 1/4 turn open at all times and no operational meter present to determine exact amount of water Pasco is providing.

Inspector *Ed Waters* Title Env. Specialist II Date 3/16/05
 Approved by *Craig McComb* Title Env. Manager Date 3/16/05