

ORIGINAL

Palm Port

Docket No. 060368-WS

Application to Increase Rates and Charges
For a "Class A" Utility
In

Florida

VOLUME 6

Book 7

Set 32 of 57

Containing
Additional Engineering Requirements

Monthly Operating Reports

CMP _____

COM _____

CTR _____

ECR 1

GCL _____

OPC _____

RCA _____

SCR _____

SGA _____

SEC _____

OTH _____

Aqua Utilities Florida, Inc.

DOCUMENT NUMBER-DATE

00862 JAN 26 8

FPSC-COMMISSION CLERK

Aqua Utilities Florida, Inc. Monthly Operating Reports

Palm Port

	Tab Number	Page Number
Year: 2004		
January	1	3
February	2	5
March	3	7
April	4	9
May	5	11
June	6	13
July	7	14
August	8	16
September	9	18
October	10	20
November	11	22
December	12	24
Year: 2005		
January	1	26
February	2	28
March	3	30
April	4	32
May	5	34
June	6	36
July	7	38
August	8	40
September	9	42
October	10	44
November	11	46
December	12	48

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540865 Plant Name: Palm Port

III. Daily Data for the Month/Year of: January, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²			
1	X	24.0	16,800		2.4									1.4	
2	X	24.0	17,300		2.0									1.0	
3		24.0	14,233												
4		24.0	14,233												
5	X	24.0	14,233		2.5									1.0	
6	X	24.0	16,300		2.2									1.0	
7	X	24.0	11,500		2.6									1.2	
8	X	24.0	15,800		2.4									1.2	
9	X	24.0	10,700		1.8									1.2	
10		24.0	14,667												
11		24.0	14,667												
12	X	24.0	14,667		2.0									1.2	
13	X	24.0	16,700		2.5									1.6	
14	X	24.0	15,700		2.8									1.6	
15	X	24.0	5,500		2.3									1.4	
16	X	24.0	16,700		2.5									1.4	
17		24.0	12,000												
18		24.0	12,000												
19	X	24.0	12,000		2.7									1.4	
20	X	24.0	14,600		2.7									1.4	
21	X	24.0	10,300		1.8									1.2	
22	X	24.0	15,800		2.0									1.2	
23	X	24.0	11,700		1.9									1.2	
24		24.0	16,000												
25		24.0	16,000												
26	X	24.0	16,000		2.6									1.2	
27	X	24.0	17,300		2.5									1.2	
28	X	24.0	10,800		2.7									1.3	
29	X	24.0	16,400		2.5									1.3	
30	X	24.0	10,700		2.6									1.4	
31		24.0													
Total			421,300												
Average			13,590												
Maximum			17,300												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540865 | Plant Name: Palm Port

III. Daily Data for the Month/year of: February, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)

Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Past Started or Visted by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer Measurement (T) at Contact Time Before or at First Customer Flow, mg-min/L	Lowest CT Disinfectant Provided Before or at First Customer Measurement (T) at Contact Time Before or at First Customer Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest UV Dose, mW-sec/cm ²	Minimum UV Dose, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
													CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*
1	X	24.0	22,350	2.8	2.8								
2	X	24.0	22,350	2.8	2.8								
3	X	24.0	10,100	2.8	1.4								
4	X	24.0	10,900	1.7	1.1								
5	X	24.0	17,200	1.5	1.0								
6	X	24.0	10,200	1.0	0.7								
7		24.0	15,433										
8		24.0	15,433										
9	X	24.0	15,433	2.0	1.1								
10	X	24.0	17,000	1.8	1.0								
11	X	24.0	11,300	1.7	1.0								
12	X	24.0	10,700	2.0	1.0								
13	X	24.0	10,600	2.0	1.0								
14		24.0	14,800										
15		24.0	14,800										
16	X	24.0	14,800	1.7	1.0								
17	X	24.0	13,500	2.1	1.0								
18	X	24.0	15,800	1.8	1.0								
19	X	24.0	10,700	2.0	1.0								
20	X	24.0	16,600	2.0	1.0								
21		24.0	15,033										
22		24.0	15,033										
23	X	24.0	15,033	1.7	1.1								
24	X	24.0	16,300	2.0	0.8								
25	X	24.0	10,600	1.8	1.0								
26	X	24.0	15,900	1.7	1.0								
27	X	24.0	10,600	1.6	0.8								
28		24.0											
29		24.0											
Total			388,500										
Average			13,397										
Maximum			22,350										

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540865 Plant Name: Palm Port

III. Daily Data for the Month/Year of: March, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions: Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations					UV Dose							
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²				
1	X	24.0	44,700		1.0										0.6	
2	X	24.0	10,400		1.0										0.6	
3	X	24.0	11,100		1.4										0.4	
4	X	24.0	16,600		1.2										0.4	
5	X	24.0	14,300		1.0										0.4	
6		24.0	15,300													
7		24.0	15,300													
8	X	24.0	15,300		0.8										0.4	
9	X	24.0	12,000		1.0										0.4	
10	X	24.0	11,100		1.0										0.9	
11	X	24.0	22,200		0.7										0.4	
12	X	24.0	6,000		0.8										0.4	
13		24.0	16,400													
14		24.0	16,400													
15	X	24.0	16,400		3.5										2.6	
16	X	24.0	15,500		2.5										1.4	
17	X	24.0	10,100		2.6										1.4	
18	X	24.0	16,600		1.6										0.5	
19	X	24.0	16,000		2.5										1.5	
20		24.0	17,767													
21		24.0	17,767													
22	X	24.0	17,767		2.7										1.2	
23	X	24.0	11,300		2.5										1.2	
24	X	24.0	10,100		2.5										1.2	
25	X	24.0	15,300		2.4										1.0	
26	X	24.0	11,600		2.4										1.2	
27		24.0	16,600													
28		24.0	16,600													
29	X	24.0	16,600		2.8										1.4	
30	X	24.0	18,800		2.5										1.0	
31	X	24.0	25,700		2.5										0.8	
Total			497,600													
Average			16,052													
Maximum			44,700													

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: April, 2004

A. Public Water System (PWS) Information

PWS Name:	Palm Port			PWS Identification Number:	2540865
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month:	106			Total Population Served at End of Month:	263
PWS Owner:	Florida Water Services				
Contact Person:	Craig Anderson			Contact Person's Title:	VP Environmental Services
Contact Person's Mailing Address:	P.O. Box 609520	City:	Orlando	State:	Florida
Contact Person's Telephone Number:	(407) 598-4199	Zip Code:	32860-9520		
Contact Person's E-Mail Address:	craig@florida-water.com				
Contact Person's Fax Number:	(407) 598-4217				

B. Water Treatment Plant Information

Plant Name:	Palm Port			Plant Telephone Number:	904-329-1122	
Plant Address:	East River Drive			City:	East Palatka	
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water	<input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	170,000					
PWS Category (per subsection 62-699.310(4), F.A.C.):	IV			Plant Class (per subsection 62-699.310(4), F.A.C.):	C	
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked		
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift		
Other Operators:	Donald Holcomb	A	5091	Days 1st Shift		

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date

Paul Thompson

Printed or Typed Name

A-7251

License Number

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540865 | Plant Name: Palm Port

III. Daily Data for the Month/Year of: April, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Started or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Measurement (T) at C Contact Time Before or at First Customer During Peak Flow, mg-minutes	Lowest CT Disinfectant Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C if Applicable	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Operating UV Dose, mW-sec/cm ²	Required UV Dose, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation

1	X	24.0	13,800	2.0									
2	X	24.0	14,700	1.7									0.9
3		24.0	14,967										
4		24.0	14,967										
5	X	24.0	14,967	2.1									
6	X	24.0	23,800	2.5									1.0
7	X	24.0	11,800	2.3									1.2
8	X	24.0	10,600	1.8									0.7
9	X	24.0	34,600	2.2									0.8
10		24.0	17,667										
11		24.0	17,667										
12	X	24.0	17,667	2.4									0.8
13	X	24.0	9,800	2.0									0.8
14	X	24.0	15,800	2.8									1.1
15	X	24.0	16,400	2.0									0.9
16	X	24.0	11,000	1.8									1.0
17		24.0	17,933										
18		24.0	17,933										
19	X	24.0	17,933	2.2									0.9
20	X	24.0	15,400	2.0									0.6
21	X	24.0	17,400	2.4									0.7
22	X	24.0	12,400	2.2									0.8
23	X	24.0	18,500	2.2									1.0
24		24.0	17,700										
25		24.0	17,700										
26	X	24.0	17,700	1.0									0.8
27	X	24.0	16,500	0.9									0.6
28	X	24.0	18,300	3.5									1.5
29	X	24.0	12,200	2.3									1.0
30	X	24.0	16,500	1.0									0.7
Total			494,300										
Average			16,477										
Maximum			34,600										

* Refer to the instructions for this report to determine which plants must provide this information.

DEP Form 62-555 900(3) Alternate

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540865 Plant Name: Palm Port

III. Daily Data for the Month/Year of: May, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations				UV Dose					
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C if Applicable	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²		
1		24.0	17,000										
2		24.0	17,000										
3	X	24.0	17,000		1.0							0.6	
4	X	24.0	5,700		1.0							0.6	
5	X	24.0	11,700		0.8							0.6	
6	X	24.0	16,700		1.0							0.5	
7	X	24.0	10,700		1.7							0.8	
8		24.0	16,667										
9		24.0	16,667										
10	X	24.0	16,667		1.2							0.6	
11	X	24.0	18,100		1.2							0.6	
12	X	24.0	15,700		1.4							0.6	
13	X	24.0	11,100		1.0							0.4	
14	X	24.0	11,800		1.7							0.8	
15		24.0	17,700										
16		24.0	17,700										
17	X	24.0	17,700		1.0							0.4	
18	X	24.0	10,600		1.2							0.4	
19	X	24.0	17,000		1.2							0.4	
20	X	24.0	10,400		1.0							0.4	
21	X	24.0	12,700		0.9							0.4	
22		24.0	14,333										
23		24.0	14,333										
24	X	24.0	14,333		1.0							0.4	
25	X	24.0	17,000		0.9							0.4	
26	X	24.0	16,600		0.7							0.3	
27	X	24.0	13,600		1.0							0.4	
28	X	24.0	16,900		1.0							0.4	
29		24.0	17,167										
30		24.0	17,167										
31	X	24.0	17,167		1.2							0.4	
Total			464,900										
Average			14,997										
Maximum			18,100										

* Refer to the instructions for this report to determine which plants must provide this information.

Docket No. 060368-WS

**Application to Increase Rates and Charges
For a "Class A" Utility
In**

Florida

Report Missing:

Monthly Operating Report

Palm Port

June 2004

Aqua Utilities Florida, Inc.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: July, 2004

A. Public Water System (PWS) Information

PWS Name: Palm Port		PWS Identification Number: 2540865	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 106		Total Population Served at End of Month: 263	
PWS Owner: Aqua Utilities Florida			
Contact Person: Michael Fitzgerald		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: 1343 NE 17th Road		City: Ocala	State: Florida
		Zip Code: 34470	
Contact Person's Telephone Number: (352) 732-6027		Contact Person's Fax Number: (352) 732-3213	
Contact Person's E-Mail Address: mvfitzgerald@aquaaamerica.com			

B. Water Treatment Plant Information

Plant Name: Palm Port		Plant Telephone Number: 904-329-1122	
Plant Address: East River Drive		City: East Palatka	State: Florida
		Zip Code: 32131	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 170,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C	
Licensed Operators	Name	License Class	License Number
Lead/Chief Operator:	Mark March	C	8287
Other Operators:	Paul Thompson	A	7251
			Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date

Mark March

Printed or Typed Name

C-8287

License Number

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540865 Plant Name: Palm Port

III. Daily Data for the Month/year of: July, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) (1 at C)	Disinfectant Contact Time Before or at Lowest CT	Disinfectant Measurement (T) at C	Peak Flow, mg/L During Peak Customer Flow, mg./min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg./mL	Operating UV Dose, mW-sec/cm ²	Lowest UV Dose Concentration at Remote Point in Distribution System, mg/L	CT Calculations, or UV Dose, to Demostatate Four-Log Virus Inactivation, if Applicable*		Emergency or Abnormal Operating Conditions. Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
													UV Dose	UV Dose	
1	X	24.0	11,900												
2	X	24.0	11,100												0.6
3		24.0	14,033												
4		24.0	14,033												
5	X	24.0	14,033												
6	X	24.0	6,800												0.4
7	X	24.0	15,600												0.5
8	X	24.0	10,800												1.2
9	X	24.0	10,300												0.8
10		24.0	11,533												8.0
11		24.0	11,533												
12	X	24.0	11,533												0.8
13	X	24.0	14,400												0.8
14	X	24.0	10,800												0.8
15	X	24.0	10,800												0.8
16	X	24.0	11,100												0.7
17		24.0	10,433												
18		24.0	10,433												
19	X	24.0	10,433												0.7
20	X	24.0	11,800												0.7
21	X	24.0	10,700												0.7
22	X	24.0	16,400												1.2
23		24.0	12,100												1.2
24		24.0	12,966												
25		24.0	12,966												
26	X	24.0	12,966												
27	X	24.0	12,966												1.1
28	X	24.0	11,200												1.0
29	X	24.0	11,300												1.2
30	X	24.0	13,600												1.0
31		24.0	11,600												
Total		376,898													
Average		12,158													
Maximum		17,700													

* Refer to the instructions for this report to determine which plants must provide this information.

DEF Form 62-555 900(3) Alternate

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: August, 2004

A. Public Water System (PWS) Information

PWS Name:	Palm Port			PWS Identification Number:	2540865	
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive		
Number of Service Connections at End of Month:	106			Total Population Served at End of Month:	263	
PWS Owner:	Aqua Utilities Florida					
Contact Person:	Michael Fitzgerald			Contact Person's Title:	Area Manager	
Contact Person's Mailing Address:	1343 NE 17th Road		City:	Ocala	State:	Florida
Contact Person's Telephone Number:	(352) 732-6027		Zip Code: 34470			
Contact Person's E-Mail Address:	mvfitzgerald@aquaamerica.com					
Contact Person's Fax Number:	(352) 732-3213					

B. Water Treatment Plant Information

Plant Name:	Palm Port			Plant Telephone Number:	904-329-1122	
Plant Address:	East River Drive		City:	East Palatka	State:	Florida
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water		<input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	170,000					
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV			Plant Class (per subsection 62-699.310(4), F.A.C.):	C	
Licensed Operators:	Name	License Class	License Number	Day(s) / Shift(s) Worked		
Lead/Chief Operator:	Mark March	C	8287			
Other Operators:	Paul Thompson	A	7251	Days 1st Shift		

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	<u>Mark March</u> Printed or Typed Name	<u>C-8287</u> License Number
--------------------	--	---------------------------------

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540865 Plant Name: Palm Port August, 2004

III. Daily Data for the Month/year of:

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Operator Visited by Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Peak Flow, mg/L	Disinfectant Contact Time Before or at First Measurement (T) at C	Disinfectant Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*	
												UV Dose	CT
1	24.0	24.0	24.750										
2	X	24.0	24.750	2.0									
3	X	24.0	11,000	2.0									
4	X	24.0	10,700	2.0									
5	X	24.0	11,200	2.0									
6	X	24.0	16,500	2.2									
7		24.0	13,167										
8		24.0	13,167										
9	X	24.0	13,167	2.2									
10	X	24.0	10,200	2.4									
11	X	24.0	17,300	2.2									
12	X	24.0	10,200	2.2									
13	X	24.0	17,000	2.0									
14		24.0	15,067										
15		24.0	15,067										
16	X	24.0	15,067	1.7									
17	X	24.0	11,000	1.7									
18	X	24.0	8,600	1.5									
19	X	24.0	12,400	1.6									
20	X	24.0	10,700	1.6									
21		24.0	12,900										
22		24.0	12,900										
23	X	24.0	12,900	1.5									
24	X	24.0	12,900	1.7									
25	X	24.0	10,500	1.6									
26	X	24.0	10,700	1.5									
27	X	24.0	11,300	2.0									
28		24.0	12,500										
29		24.0	12,500										
30	X	24.0	12,500	2.5									
31		24.0	11,400										
Total			414,000										
Average			13,355										
Maximum			24,750										

* Refer to the instructions for this report to determine which plants must provide this information. DEP Form 62-555 900(3) Alternate

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: September, 2004

A. Public Water System (PWS) Information

PWS Name: Palm Port		PWS Identification Number: 2540865	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community		<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month: 106		Total Population Served at End of Month: 263	
PWS Owner: Aqua Utilities Florida			
Contact Person: Michael Fitzgerald		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: 1343 NE 17th Road		City: Ocala	State: Florida
Contact Person's Telephone Number: (352) 732-6027		Zip Code: 34470	
Contact Person's E-Mail Address: mvfitzgerald@aquaaamerica.com		Contact Person's Fax Number: (352) 732-3213	

B. Water Treatment Plant Information

Plant Name: Palm Port		Plant Telephone Number: 904-329-1122	
Plant Address: East River Drive		City: East Palatka	State: Florida
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		Zip Code: 32131	
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 170,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C	
Licensed Operators	Name	License Class	License Number
Lead/Chief Operator:	Mark March	C	8287
Other Operators:	Paul Thompson	A	7251
			Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Mark March Printed or Typed Name	C-8287 License Number
--------------------	-------------------------------------	--------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540865 Plant Name: Palm Port

III. Daily Data for the Month/Year of: September, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations				UV Dose					
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²		
1	X	24.0	11,000		1.0							0.8	
2	X	24.0	19,300		0.8							0.4	
3	X	24.0	12,700		0.8							0.3	
4		24.0	8,367										
5		24.0	8,367										
6	X	24.0	8,367										
7	X	24.0	7,766										
8	X	24.0	7,766										
9	X	24.0	7,766		2.0							1.0	
10	X	24.0	14,200		3.0							1.6	
11		24.0	13,000										
12		24.0	13,000										
13	X	24.0	13,000		2.5							1.4	
14	X	24.0	16,400		3.0							2.5	
15	X	24.0	10,700		2.8							1.8	
16	X	24.0	16,500		2.8							1.6	
17	X	24.0	5,600		2.8							1.6	
18		24.0	14,533										
19		24.0	14,533										
20	X	24.0	14,533		2.5							1.5	
21	X	24.0	15,900		2.5							1.4	
22	X	24.0	7,500		2.7							1.4	
23	X	24.0	13,300		2.0							1.2	
24	X	24.0	7,100		1.8							1.0	
25		24.0	15,400										
26		24.0	15,400										
27	X	24.0	15,400		1.8							1.0	
28	X	24.0	15,900		2.4							1.2	
29	X	24.0	11,000		2.4							1.0	
30	X	24.0	11,200		2.8							1.4	
31		24.0											
Total			365,498										
Average			11,790										
Maximum			19,300										

* Refer to the instructions for this report to determine which plants must provide this information.
 DEP Form 62-555 900(3)Alternate

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: October, 2004

A. Public Water System (PWS) Information

PWS Name: Palm Port		PWS Identification Number: 2540865	
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community
Number of Service Connections at End of Month: 106		Total Population Served at End of Month: 263	
PWS Owner: Aqua Utilities Florida			
Contact Person: Michael Fitzgerald		Contact Person's Title: Area Manager	
Contact Person's Mailing Address:	1343 NE 17th Road	City: Ocala	State: Florida Zip Code: 34470
Contact Person's Telephone Number:	(352) 732-6027		Contact Person's Fax Number: (352) 732-3213
Contact Person's E-Mail Address:	mvfitzgerald@aquaamerica.com		

B. Water Treatment Plant Information

Plant Name: Palm Port		Plant Telephone Number: 904-329-1122	
Plant Address: East River Drive		City: East Palatka	State: Florida Zip Code: 32131
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water	<input type="checkbox"/> Purchased Finished Water	
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 170,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C	
Licensed Operators	Name	License Class	License Number
Lead/Chief Operator:	Mark March	C	8287
Other Operators:	Paul Thompson	A	7251
			Day(s) / Shift(s) Worked
			Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Mark March Printed or Typed Name	C-8287 License Number
--------------------	-------------------------------------	--------------------------

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540865 Plant Name: Palm Port

III. Daily Data for the Month/year of: October, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator in Hours plant Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer Measurement Point During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest UV Dose, mW-sec/cm ²	Required UV Dose, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
1	24.0	X	16,700	2.8						1.4	
2	24.0		4,867								
3	24.0		4,867								
4	24.0	X	4,867	2.6						1.4	
5	24.0	X	36,800	2.4						1.4	
6	24.0	X	11,100	2.3						1.4	
7	24.0	X	8,400	2.3						1.4	
8	24.0	X	20,700	2.4						1.4	
9	24.0		13,500								
10	24.0		13,500								
11	24.0	X	13,500	1.5						1.0	
12	24.0	X	10,000	0.5						1.0	
13	24.0	X	10,000	0.5						1.0	
14	24.0	X	10,000	0.5						1.0	
15	24.0	X	5,300	0.8						1.0	
16	24.0		17,000								
17	24.0		17,000								
18	24.0	X	17,000	2.5						1.2	
19	24.0	X	11,400	2.0						1.2	
20	24.0	X	13,100	2.0						1.2	
21	24.0	X	12,400	1.8						1.0	
22	24.0	X	11,900	2.0						1.0	
23	24.0		14,600								
24	24.0		14,600								
25	24.0	X	14,600	2.8						1.1	
26	24.0	X	10,600	2.8						1.1	
27	24.0	X	10,800	2.8						1.1	
28	24.0	X	19,700	3.5						1.8	
29	24.0	X	13,600	2.7						1.6	
30	24.0		7,416								
31	24.0		7,417								
Total	397,233										
Average	12,814										
Maximum	36,800										

* Refer to the instructions for this report to determine which plants must provide this information

DEP Form 62-555 900(3)A/temare

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: November, 2004

A. Public Water System (PWS) Information

PWS Name:	Palm Port			PWS Identification Number:	2540865	
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive		
Number of Service Connections at End of Month:	106			Total Population Served at End of Month:	263	
PWS Owner:	Aqua Utilities Florida					
Contact Person:	Brian Heath			Contact Person's Title:	Area Manager	
Contact Person's Mailing Address:	1343 NE 17th Road		City:	Ocala	State:	Florida
Contact Person's Telephone Number:	(352) 732-6027		Contact Person's Fax Number:	(352) 732-3213		
Contact Person's E-Mail Address:	beheath@aquaamerica.com					

B. Water Treatment Plant Information

Plant Name:	Palm Port			Plant Telephone Number:	904-329-1122	
Plant Address:	East River Drive		City:	East Palatka	State:	Florida
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water	<input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	170,000					
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV			Plant Class (per subsection 62-699.310(4), F.A.C.):	C	
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked		
Lead/Chief Operator:	Mark March	C	8287			
Other Operators:	Paul Thompson	A	7251	Days 1st Shift		

II Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date

Mark March
Printed or Typed Name

C-8287
License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540865 Plant Name: Palm Port

III. Daily Data for the Month/Year of: November, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*									Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations					UV Dose					
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²		
1	X	24.0	24,500		2.0								1.0	
2	X	24.0	14,200		2.5								1.4	
3	X	24.0	13,400		2.4								1.2	
4	X	24.0	15,500		2.7								1.2	
5	X	24.0	12,600		2.5								1.0	
6		24.0	15,333											
7		24.0	15,333											
8	X	24.0	15,333		2.7								1.2	
9	X	24.0	15,600		2.6								1.2	
10	X	24.0	16,200		3.0								1.4	
11	X	24.0	11,500		2.0								1.0	
12	X	24.0	17,400		2.3								1.0	
13		24.0	14,233											
14		24.0	14,233											
15	X	24.0	14,233		2.1								0.7	
16	X	24.0	16,100		2.0								0.7	
17	X	24.0	12,800		1.4								0.4	
18	X	24.0	15,600		1.6								0.4	
19	X	24.0	22,300		1.7								0.4	
20		24.0	17,250											
21	X	24.0	17,250		1.8								0.5	
22	X	24.0	5,200		1.7								0.5	
23	X	24.0	16,600		1.5								0.5	
24	X	24.0	10,600		1.7								0.5	
25		24.0	17,250											
26	X	24.0	17,250		1.6								0.5	
27		24.0	14,933											
28		24.0	14,933											
29	X	24.0	14,933		3.5								1.3	
30	X	24.0	10,700		3.5								1.2	
31		24.0												
Total			453,300											
Average			14,623											
Maximum			24,500											

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540865 Plant Name: Palm Port

III. Daily Data for the Month/Year of: December, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Visited or Started by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Point During Peak Flow, mg/L	Disinfectant Measurement (T) at C Contact Time Before or at First Customer During Peak Flow, minutes	Lowest CT	Temp of Water, °C if Applicable	pH of Water, if Applicable	Minimum CT Required, mg·min/L	Operating UV Dose, mW-sec/cm ²	Required UV Dose, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*		
													UV Dose	UV Dose	
1	X	24.0	11,200	2.8											
2	X	24.0	15,200	3.0											
3	X	24.0	12,700	2.4											
4		24.0	14,167												
5		24.0	14,167												
6	X	24.0	14,167	2.1											
7	X	24.0	16,100	2.2											
8	X	24.0	12,200	1.6											
9	X	24.0	16,400	1.4											
10	X	24.0	12,900	1.6											
11		24.0	15,567												
12		24.0	15,567												
13	X	24.0	15,567	3.5											
14	X	24.0	13,300	3.0											
15	X	24.0	15,600	3.5											
16	X	24.0	10,900	2.2											
17	X	24.0	16,600	1.5											
18		24.0	14,967												
19		24.0	14,967												
20	X	24.0	14,967	1.5											
21	X	24.0	17,300	1.6											
22	X	24.0	10,600	2.6											
23	X	24.0	18,100	2.6											
24	X	24.0	14,000	2.0											
25		24.0	15,600												
26		24.0	15,600												
27	X	24.0	15,600	2.8											
28	X	24.0	14,800	2.7											
29	X	24.0	13,800	2.2											
30	X	24.0	17,000	2.4											
31	X	24.0	18,800	2.6											
Total		458,400													
Average		14,787													
Maximum		18,800													

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540865 Plant Name: Palm Port

III. Daily Data for the Month/Year of: January, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator ("X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*				Peak Flow, mg/L	Customer During Before or at First Disinfectant Concentration (C) Measurement (T) at C	Peak Flow, mg-ml/L	Temp of Water, °C if Applicable	pH of Water	Minimum CT Required, mg-ml	Operating UV Dose, mW-sec/cm ²	Required UV Dose, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
					Lowest Residual Provided	Disinfectant Contact Time	Point During Measurement	Peak Flow										

1			24.0	14,967														
2	X		24.0	14,967														
3	X		24.0	14,967														
4	X		24.0	16,600														
5	X		24.0	17,500														
6	X		24.0	16,700														
7	X		24.0	14,500														
8			24.0	16,600														
9			24.0	16,600														
10	X		24.0	16,600														
11	X		24.0	23,300														
12	X		24.0	11,300														
13	X		24.0	16,800														
14	X		24.0	10,600														
15			24.0	13,067														
16			24.0	13,067														
17	X		24.0	13,067														
18	X		24.0	34,900														
19	X		24.0	6,600														
20	X		24.0	16,400														
21	X		24.0	32,800														
22			24.0	12,733														
23			24.0	12,733														
24	X		24.0	12,733														
25	X		24.0	22,800														
26	X		24.0	10,300														
27	X		24.0	13,800														
28	X		24.0	14,900														
29			24.0	19,800														
30			24.0	19,800														
31	X		24.0	19,800														
			Total	511,300														
			Average	16,494														
			Maximum	34,900														

* Refer to the instructions for this report to determine which plants must provide this information
 DEP Form 62-555 900(3) Alternate

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540865 Plant Name: Palm Port

III. Daily Data for the Month/Year of:

February, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Started or Visited by Operator ("X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Peak Flow Customer During Before or at First Disinfectant Measurement (C) Concentration (C) at C	Peak Flow, mg-minutes	Temp of Water, °C if Applicable	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions: Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*		CT Calculations														
														Lowest CT Provided	Disinfectant Contact Time	Lowest CT	Before or at First Customer During Peak Flow, mg-min/L													
1	X		17,200	24.0		2.1						0.8																		
2	X		16,700	24.0		2.0						0.8																		
3	X		16,700	24.0		2.0						0.8																		
4	X		23,200	24.0		1.9						0.8																		
5			15,367	24.0																										
6			15,367	24.0																										
7	X		15,367	24.0		1.0						0.4																		
8	X		16,900	24.0		1.0						0.6																		
9	X		18,300	24.0		1.1						0.6																		
10	X		16,000	24.0		0.9						0.6																		
11	X		17,100	24.0		1.8						0.7																		
12			17,633	24.0																										
13			17,633	24.0																										
14	X		17,633	24.0		1.0						0.4																		
15	X		16,800	24.0		2.3						1.1																		
16	X		11,400	24.0		1.8						1.0																		
17	X		13,200	24.0		1.8						0.9																		
18	X		13,800	24.0		1.9						0.9																		
19			17,200	24.0																										
20			17,200	24.0																										
21	X		17,200	24.0		3.5						1.4																		
22	X		17,000	24.0		1.8						0.8																		
23	X		18,100	24.0		2.8						1.2																		
24	X		10,100	24.0		2.5						1.2																		
25	X		12,000	24.0		2.6						1.4																		
26			14,667	24.0																										
27			14,667	24.0																										
28	X		14,667	24.0		1.8						1.2																		
29			24.0																											
30			24.0																											
31			24.0																											
Total													449,100																	
Average													14,487																	
Maximum													23,200																	

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540865 Plant Name: Palm Port

III. Daily Data for the Month/Year of: April, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations; or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²			
1	X	24.0	15,600		1.6									0.5	
2		24.0	14,733												
3		24.0	14,733												
4	X	24.0	14,733		1.2									0.8	
5	X	24.0	11,000		1.4									0.8	
6	X	24.0	16,300		1.5									0.9	
7	X	24.0	11,500		1.3									1.0	
8	X	24.0	10,700		1.3									1.1	
9		24.0	15,000												
10		24.0	15,000												
11	X	24.0	15,000		1.4									0.9	
12	X	24.0	17,100		1.6									1.4	
13	X	24.0	12,700		2.2									1.8	
14	X	24.0	14,400		2.2									1.6	
15	X	24.0	15,800		2.5									2.0	
16		24.0	16,933												
17		24.0	16,933												
18	X	24.0	16,933		1.6									1.3	
19	X	24.0	10,500		1.3									0.9	
20	X	24.0	16,900		1.5									1.2	
21	X	24.0	14,600		2.1									1.4	
22	X	24.0	12,200		1.5									1.1	
23		24.0	14,500												
24		24.0	14,500												
25	X	24.0	14,500		2.2									1.7	
26	X	24.0	21,100		1.3									1.0	
27	X	24.0	17,900		2.0									1.5	
28	X	24.0	12,300		1.3									1.1	
29	X	24.0	22,700		1.3									0.9	
30		24.0	16,233												
31		24.0													
Total			453,033												
Average			14,614												
Maximum			22,700												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540865 Plant Name: Palm Port

III. Daily Data for the Month/Year of: June, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L		
1	X	24.0	17,500		2.4									1.0	
2	X	24.0	10,800		1.6									1.1	
3	X	24.0	14,200		1.8									1.3	
4		24.0	12,467												
5		24.0	12,467												
6	X	24.0	12,467		1.7									1.4	
7	X	24.0	16,900		2.3									1.9	
8	X	24.0	10,700		1.3									1.1	
9	X	24.0	16,500		1.3									0.9	
10	X	24.0	11,200		1.2									0.8	
11		24.0	15,300												
12		24.0	15,300												
13	X	24.0	15,300		1.0									0.7	
14	X	24.0	11,400		1.0									0.6	
15	X	24.0	10,700		1.9									1.5	
16	X	24.0	16,200		2.1									1.5	
17	X	24.0	10,800		2.0									1.4	
18		24.0	14,567												
19		24.0	14,567												
20	X	24.0	14,567		1.4									1.3	
21	X	24.0	15,800		1.3									1.0	
22	X	24.0	11,000		1.1									0.7	
23	X	24.0	16,500		1.2									0.9	
24	X	24.0	16,000		2.0									0.9	
25		24.0	14,667												
26		24.0	14,667												
27	X	24.0	14,667		2.5									1.9	
28	X	24.0	16,100		2.6									2.0	
29	X	24.0	11,200		2.4									1.9	
30	X	24.0	15,400		2.0									1.4	
31		24.0													
Total			419,900												
Average			13,545												
Maximum			17,500												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: July, 2005

A. Public Water System (PWS) Information

PWS Name:	Palm Port			PWS Identification Number:	2540865
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month:	107			Total Population Served at End of Month:	375
PWS Owner:	Aqua Utilities Florida				
Contact Person:	Brian Heath			Contact Person's Title:	Area Manager
Contact Person's Mailing Address:	PO Box 490310	City:	Leesburg	State:	Florida
				Zip Code:	34749
Contact Person's Telephone Number:	(352) 787-0980			Contact Person's Fax Number:	(352) 787-6333
Contact Person's E-Mail Address:	beheath@aquaaamerica.com				

B. Water Treatment Plant Information

Plant Name:	Palm Port			Plant Telephone Number:	(352) 787-0980	
Plant Address:	East River Drive		City:	East Palatka	State: Florida	
				Zip Code:	32131	
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water		<input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	170,000					
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV			Plant Class (per subsection 62-699.310(4), F.A.C.):	C	
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked		
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift		
Other Operators:	Larry White	C	7082	Days 1st Shift		
	David Haring	C	14091	Days 1st Shift		

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date

Paul Thompson

Printed or Typed Name

A7251

License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540865 Plant Name: Palm Port

III. Daily Data for the Month/Year of: July, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations				UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C if Applicable	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²			Minimum UV Dose Required, mW-sec/cm ²
1	X	24.0	11,500		1.3								1.0	
2		24.0	12,433											
3		24.0	12,433											
4	X	24.0	12,433		1.5								1.2	
5	X	24.0	22,400		1.9								1.4	
6	X	24.0	10,400		2.0								1.6	
7	X	24.0	16,300		2.0								1.5	
8	X	24.0	10,900		2.2								1.7	
9		24.0	14,400											
10		24.0	14,400											
11	X	24.0	14,400		2.4								1.7	
12	X	24.0	20,800		2.2								1.4	
13	X	24.0	9,600		2.2								1.5	
14	X	24.0	19,000		2.3								1.5	
15	X	24.0	13,200		2.5								1.8	
16		24.0	14,500											
17		24.0	14,500											
18	X	24.0	14,500		2.5								1.7	
19	X	24.0	11,400		2.5								1.7	
20	X	24.0	11,400		2.0								1.5	
21	X	24.0	10,400		0.6								0.3	
22	X	24.0	19,300		0.9								0.4	
23		24.0	21,700											
24		24.0	21,700											
25	X	24.0	21,700		0.9								0.5	
26	X	24.0	11,700		0.9								0.5	
27	X	24.0	12,000		1.3								0.7	
28	X	24.0	16,900		1.1								0.6	
29	X	24.0	17,100		1.5								0.9	
30		24.0	17,267											
31		24.0	17,267											
Total			467,934											
Average			15,095											
Maximum			22,400											

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: August, 2005

A. Public Water System (PWS) Information

PWS Name: Palm Port		PWS Identification Number: 2540865	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 107		Total Population Served at End of Month: 375	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 787-0980		Zip Code: 34749	
Contact Person's E-Mail Address: beheath@aquamerica.com		Contact Person's Fax Number: (352) 787-6333	

B. Water Treatment Plant Information

Plant Name: Palm Port		Plant Telephone Number: (352) 787-0980		
Plant Address: East River Drive		City: East Palatka	State: Florida	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		Zip Code: 32131		
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 170,000				
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C		
Licensed Operators	Name	License Class	License Number	Day(s)/Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:	Larry White	C	7082	Days 1st Shift
	David Haring	C	14091	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A7251 License Number
--------------------	--	-------------------------

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540865 Plant Name: Palm Port

III. Daily Data for the Month/Year of: October, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Visited or Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Measurement (T) at C Point During Peak Flow, minutes	Lowest CT Provided Before or at Customer During Peak Flow, mg-min/L	Temp of Water, °C if Applicable	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest UV Dose, mW-sec/cm ²	UV Dose Provided, mW-sec/cm ²	Remote Point in Distribution System, mg/L	CT Calculations, or UV Dose, to Demostatate Four-Log Virus Inactivation, if Applicable*	
														UV Dose	UV Dose
1			14,833	24.0	14,833										
2	X		14,833	24.0	14,833										
3	X		14,833	24.0	14,833										
4	X		12,600	24.0	12,600										0.4
5	X		7,100	24.0	7,100										0.4
6	X		15,900	24.0	15,900										0.3
7	X		9,000	24.0	9,000										0.3
8			16,667	24.0	16,667										
9			16,667	24.0	16,667										
10	X		16,667	24.0	16,667										0.2
11	X		10,500	24.0	10,500										0.2
12	X		13,000	24.0	13,000										0.2
13	X		13,000	24.0	13,000										0.4
14	X		12,600	24.0	12,600										0.5
15			14,200	24.0	14,200										
16			14,200	24.0	14,200										
17	X		14,200	24.0	14,200										1.4
18	X		12,400	24.0	12,400										1.2
19	X		6,700	24.0	6,700										0.6
20	X		9,900	24.0	9,900										0.6
21	X		17,800	24.0	17,800										0.3
22			14,867	24.0	14,867										
23			14,867	24.0	14,867										
24	X		14,867	24.0	14,867										2.0
25	X		12,867	24.0	12,867										0.8
26	X		12,867	24.0	12,867										1.4
27	X		12,867	24.0	12,867										1.6
28	X		7,900	24.0	7,900										1.8
29			17,900	24.0	17,900										
30			17,900	24.0	17,900										
31	X		17,900	24.0	17,900										0.7
Total			422,400												
Average			13,626												
Maximum			17,900												

* Refer to the instructions for this report to determine which plants must provide this information.

DEF Form 62-555 900(3) Alternate

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540865 Plant Name: Palm Port

III. Daily Data for the Month/Year of: November, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*									Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations					UV Dose					
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²		
1	X	24.0	19,100		3.5								2.0	
2	X	24.0	15,100		3.5								2.0	
3	X	24.0	15,100		1.0								0.4	
4	X	24.0	18,300		1.0								0.4	
5		24.0	15,633											
6		24.0	15,633											
7	X	24.0	15,633		1.0								0.3	
8	X	24.0	16,000		1.0								0.3	
9	X	24.0	8,800		1.1								0.3	
10	X	24.0	16,000		1.0								0.3	
11	X	24.0	17,000		1.3								0.4	
12		24.0	17,633											
13		24.0	17,633											
14	X	24.0	17,633		0.8								0.3	
15	X	24.0	17,600		1.0								0.3	
16	X	24.0	18,000		1.2								0.3	
17	X	24.0	25,000		1.1								0.3	
18	X	24.0	8,400		1.1								0.3	
19		24.0	15,067											
20		24.0	15,067											
21	X	24.0	15,067		1.1								0.3	
22	X	24.0	13,100		1.6								0.4	
23	X	24.0	17,600		1.5								0.4	
24	X	24.0	9,800		3.5								2.5	
25	X	24.0	24,300		1.0								0.3	
26		24.0	18,233											
27		24.0	18,233											
28	X	24.0	18,233		1.8								0.4	
29	X	24.0	13,900		1.8								0.5	
30	X	24.0	13,900		1.6								0.7	
31		24.0												
Total			486,700											
Average			15,700											
Maximum			25,000											

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



Polymer Page 3 Due in December

See Pages 4 for Instructions.

I. General Information for the Month/Year of: December, 2005

A. Public Water System (PWS) Information

PWS Name: Palm Port		PWS Identification Number: 2540865	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community		<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month: 107		Total Population Served at End of Month: 375	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
		Zip Code: 34749	
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquaaamerica.com			

B. Water Treatment Plant Information

Plant Name: Palm Port		Plant Telephone Number: (352) 787-0980		
Plant Address: East River Drive		City: East Palatka	State: Florida	
		Zip Code: 32131		
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 170,000				
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C		
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:	Larry White	C	7082	Days 1st Shift
	David Haring	C	14091	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A7251 License Number
--------------------	--	-------------------------

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540865 Plant Name: Palm Port

III. Daily Data for the Month/year of: December, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Started or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Measurement Point During Peak Flow, minutes	Lowest CT Disinfectant Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest UV Dose (T) at C	Lowest UV Dose Required, mW-sec/cm ²	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*	
													UV Dose	UV Dose
1	X	24.0	13,900	1.5									0.7	
2	X	24.0	15,900	1.8									0.7	
3		24.0	12,067											
4		24.0	12,067											
5	X	24.0	12,067	1.4									0.7	
6	X	24.0	14,000	1.5									0.7	
7	X	24.0	14,250	1.8									0.8	
8	X	24.0	14,000	1.6									0.4	
9	X	24.0	14,000	1.7									0.4	
10		24.0	12,367											
11		24.0	12,367											
12	X	24.0	12,367	1.8									0.4	
13	X	24.0	16,300	1.8									0.4	
14	X	24.0	8,300	1.7									0.3	
15	X	24.0	16,900	1.7									0.3	
16	X	24.0	14,000	1.8									0.3	
17		24.0	14,300											
18		24.0	14,300											
19	X	24.0	14,300	1.6									0.3	
20	X	24.0	14,000	1.5									0.3	
21	X	24.0	8,300	1.7									0.3	
22	X	24.0	14,000	1.8									0.3	
23	X	24.0	15,400	1.8									0.3	
24		24.0	18,733											
25		24.0	18,733											
26	X	24.0	18,733	1.6									0.3	
27	X	24.0	4,300	1.7									0.3	
28	X	24.0	16,900	1.5									0.3	
29	X	24.0	16,900	1.5									0.3	
30	X	24.0	8,200	1.6									0.3	
31		24.0	17,366											
Total		429,316												
Average		13,849												
Maximum		18,733												

* Refer to the instructions for this report to determine which plants must provide this information