

ORIGINAL

Stone Mountain

Docket No. 060368-WS

Application to Increase Rates and Charges
For a "Class A" Utility
In

Florida

VOLUME 6

Book 7

Set 47 of 57

Containing
Additional Engineering Requirements

Monthly Operating Reports

CMP _____
COM _____
CTR _____
ECR 1 _____
GCL _____
OPC _____
RCA _____
SCR _____
SGA _____
SEC _____
OTH _____

Aqua Utilities Florida, Inc.

DOCUMENT NUMBER-DATE

00877 JAN 26 5

FPSC-COMMISSION CLERK

Aqua Utilities Florida, Inc. Monthly Operating Reports

Stone Mountain

	Tab Number	Page Number
Year: 2004		
January	1	3
February	2	5
March	3	7
April	4	9
May	5	11
June	6	13
July	7	15
August	8	17
September	9	19
October	10	21
November	11	23
December	12	25
Year: 2005		
January	1	27
February	2	29
March	3	31
April	4	33
May	5	35
June	6	37
July	7	39
August	8	41
September	9	43
October	10	45
November	11	47
December	12	49

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of:	January, 2004
--	---------------

A. Public Water System (PWS) Information

PWS Name: Stone Mountain		PWS Identification Number: 3351282	
PWS Type: <input checked="" type="checkbox"/> Community <input checked="" type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 9		Total Population Served at End of Month: 32	
PWS Owner: Florida Water Services			
Contact Person: Craig Anderson		Contact Person's Title: VP Environmental Services	
Contact Person's Mailing Address: P.O. Box 609520		City: Orlando	State: Florida
		Zip Code: 32860-9520	
Contact Person's Telephone Number: (407) 598-4199		Contact Person's Fax Number: (407) 598-4217	
Contact Person's E-Mail Address: craiga@florida-water.com			

B. Water Treatment Plant Information

Plant Name: Stone Mountain		Plant Telephone Number: 352-787-0980		
Plant Address: 1730 Lakeview Drive		City: Yalaha	State: Florida	
		Zip Code: 34797		
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 144,000				
Plant Category (per subsection 62-699.310(4), F.A.C.): V		Plant Class (per subsection 62-699.310(4), F.A.C.): D		
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Will Fontaine	C	6813	Days 1st Shift
Other Operators:	Brian Heath	C	5825	Days 1st Shift
	John Worrell	C	6597	Days 1st Shift
	Gary Kissick	C	7846	Days 1st Shift
	Mike Ponticelli	C	8450	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

2/9/2004 0:00	Will Fontaine	C-6813
Signature and Date	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identificaiton Number: 3351282 Plant Name: Stone Mountain

III. Daily Data for the Month/Year of: January, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations				UV Dose					
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²		
1		24.0	3,200										
2	X	24.0	3,200		1.3							0.9	
3		24.0	2,400										
4		24.0	2,400										
5	X	24.0	2,400		1.1							0.9	
6	X	24.0	2,400		1.2							0.9	
7	X	24.0	1,100		1.2							0.9	
8	X	24.0	1,400		1.3							1.1	
9	X	24.0	1,700		1.3							1.1	
10		24.0	1,567										
11		24.0	1,567										
12	X	24.0	1,567		1.2							0.8	
13	X	24.0	4,300		1.3							0.7	
14	X	24.0	1,900		1.2							0.9	
15	X	24.0	1,400		1.2							0.9	
16	X	24.0	1,500		1.1							0.9	
17		24.0	1,733										
18		24.0	1,733										
19	X	24.0	1,733		1.2							0.6	
20	X	24.0	1,900		1.1							0.8	
21	X	24.0	900		1.1							0.9	
22	X	24.0	1,700		1.1							0.8	
23	X	24.0	1,400		1.1							0.8	
24		24.0	1,667										
25		24.0	1,667										
26	X	24.0	1,667		1.0							0.7	
27	X	24.0	1,200		1.1							0.7	
28	X	24.0	1,500		1.1							0.8	
29	X	24.0	1,200		1.2							1.0	
30	X	24.0	1,500		1.2							0.9	
31		24.0	1,500										
Total			57,000										
Average			1,839										
Maximum			4,300										

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: February, 2004

A. Public Water System (PWS) Information

PWS Name: Stone Mountain		PWS Identification Number: 3351282	
PWS Type: <input checked="" type="checkbox"/> Community <input checked="" type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 9		Total Population Served at End of Month: 32	
PWS Owner: Florida Water Services			
Contact Person: Craig Anderson		Contact Person's Title: VP Environmental Services	
Contact Person's Mailing Address: P.O. Box 609520		City: Orlando	State: Florida
Contact Person's Telephone Number: (407) 598-4199		Contact Person's Fax Number: (407) 598-4217	
Contact Person's E-Mail Address: craiga@florida-water.com			

B. Water Treatment Plant Information

Plant Name: Stone Mountain		Plant Telephone Number: 352-787-0980	
Plant Address: 1730 Lakeview Drive		City: Yalaha	State: Florida
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 144,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): V		Plant Class (per subsection 62-699.310(4), F.A.C.): D	

Licensed Operators	Name	License Class	License Number	Day(s)/ Shift(s) Worked
Lead/Chief Operator:	Will Fontaine	C	6813	Days 1st Shift
Other Operators:	Brian Heath	C	5825	Days 1st Shift
	John Worrell	C	6597	Days 1st Shift
	Gary Kissick	C	7846	Days 1st Shift
	Mike Ponticelli	C	8450	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Printed or Typed Name	License Number
3/9/2004 0:00	Will Fontaine	C-6813

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3351282 Plant Name: Stone Mountain

III. Daily Data for the Month/year of: February, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)

Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer Measurement Point During Peak Flow, mg/L	Disinfectant Contact Time Before or at First Customer Measurement Point During Peak Flow, minutes	Lowest CT During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, If Applicable	Minimum CT Required, mg-min/L	Lowest UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions Requiring Water System Components Involves Taking Water System Components Out of Operation
1		24.0	2,250	1.2									
2	X	24.0	2,250	1.2								0.5	
3	X	24.0	1,500	1.1								0.9	
4	X	24.0	1,200	1.1								0.9	
5	X	24.0	2,400	1.0								0.7	
6	X	24.0	1,600	1.0								0.7	
7		24.0	2,767										
8		24.0	2,767										
9	X	24.0	2,767	1.0								0.6	
10	X	24.0	3,800	1.0								0.8	
11	X	24.0	2,200	1.0								0.7	
12	X	24.0	1,700	1.0								0.7	
13		24.0	1,925										
14		24.0	1,925										
15	X	24.0	1,925	1.1								0.8	
16	X	24.0	1,925	1.1								0.8	
17	X	24.0	1,500	1.0								0.8	
18	X	24.0	3,800	1.5								1.1	
19	X	24.0	1,400	1.5								1.3	
20	X	24.0	1,900	1.4								1.2	
21		24.0	1,500										
22		24.0	1,500										
23	X	24.0	1,500	1.3								1.0	
24	X	24.0	5,200	1.2								1.0	
25	X	24.0	1,300	1.2								0.9	
26	X	24.0	1,300	1.2								0.9	
27	X	24.0	1,500	1.3								1.1	
28		24.0	2,333										
29		24.0	2,333										
Total		61,967											
Average		2,137											
Maximum		5,200											

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: March, 2004

A. Public Water System (PWS) Information

PWS Name: Stone Mountain		PWS Identification Number: 3351282	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 9		Total Population Served at End of Month: 32	
PWS Owner: Florida Water Services			
Contact Person: Craig Anderson		Contact Person's Title: VP Environmental Services	
Contact Person's Mailing Address: P.O. Box 609520		City: Orlando	State: Florida
		Zip Code: 32860-9520	
Contact Person's Telephone Number: (407) 598-4199		Contact Person's Fax Number: (407) 598-4217	
Contact Person's E-Mail Address: craiga@florida-water.com			

B. Water Treatment Plant Information

Plant Name: Stone Mountain		Plant Telephone Number: 352-787-0980	
Plant Address: 1730 Lakeview Drive		City: Yalaha	State: Florida
		Zip Code: 34797	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 144,000			

Plant Category (per subsection 62-699.310(4), F.A.C.): V		Plant Class (per subsection 62-699.310(4), F.A.C.): D		
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Will Fontaine	C	6813	Days 1st Shift
Other Operators:	Brian Heath	C	5825	Days 1st Shift
	John Worrell	C	6597	Days 1st Shift
	Gary Kissick	C	7846	Days 1st Shift
	Adam Michaelson		Trainee	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

4/8/2004 0:00	Will Fontaine	C-6813
Signature and Date	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3351282 Plant Name: Stone Mountain

III. Daily Data for the Month/Year of: March, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair, or Maintenance Work that Involves Taking Water System Components Out of Operation		
				CT Calculations					UV Dose								
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²					
1	X	24.0	2,333		1.0										0.7		
2	X	24.0	1,700		0.9										0.7		
3	X	24.0	1,700		1.1										0.8		
4	X	24.0	1,600		1.1										0.8		
5	X	24.0	1,800		1.0										0.8		
6		24.0	2,733														
7		24.0	2,733														
8	X	24.0	2,733		1.1										0.8		
9	X	24.0	2,300		0.9										0.7		
10	X	24.0	1,300		0.9										0.7		
11	X	24.0	2,400		0.9										0.7		
12	X	24.0	2,300		1.0										0.7		
13		24.0	3,100														
14		24.0	3,100														
15	X	24.0	3,100		0.9										0.7		
16	X	24.0	1,700		0.8										0.7		
17	X	24.0	1,800		0.9										0.7		
18	X	24.0	1,900		1.0										0.7		
19	X	24.0	3,900		0.9										0.7		
20		24.0	1,867														
21		24.0	1,867														
22	X	24.0	1,867		1.2										0.9		
23	X	24.0	1,600		1.0										0.8		
24	X	24.0	1,900		0.9										0.6		
25	X	24.0	4,200		1.2										0.8		
26	X	24.0	2,400		1.2										0.9		
27		24.0	3,300														
28		24.0	3,300														
29	X	24.0	3,300		1.2										0.9		
30	X	24.0	2,400		1.3										1.0		
31	X	24.0	5,000		1.0										0.8		
Total			77,233														
Average			2,491														
Maximum			5,000														

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: April, 2004

A. Public Water System (PWS) Information

PWS Name: Stone Mountain		PWS Identification Number: 3351282	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 9		Total Population Served at End of Month: 32	
PWS Owner: Florida Water Services			
Contact Person: Craig Anderson		Contact Person's Title: VP Environmental Services	
Contact Person's Mailing Address: P.O. Box 609520		City: Orlando	State: Florida
Contact Person's Telephone Number: (407) 598-4199		Zip Code: 32860-9520	
Contact Person's E-Mail Address: craiga@florida-water.com		Contact Person's Fax Number: (407) 598-4217	

B. Water Treatment Plant Information

Plant Name: Stone Mountain		Plant Telephone Number: 352-787-0980	
Plant Address: 1730 Lakeview Drive		City: Yalaha	State: Florida
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		Zip Code: 34797	
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 144,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): V		Plant Class (per subsection 62-699.310(4), F.A.C.): D	

Licensed Operators	Name	License Class	License Number	Day(s)/ Shift(s) Worked
Lead/Chief Operator:	Will Fontaine	C	6813	Days 1st Shift
Other Operators:	Brian Heath	C	5825	Days 1st Shift
	John Worrell	C	6597	Days 1st Shift
	Gary Kissick	C	7846	Days 1st Shift
	Adam Michaelsen		Trainee	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date

Will Fontaine
Printed or Typed Name

C-6813
License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3351282 Plant Name: Stone Mountain

III. Daily Data for the Month/Year of: April, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L		
1	X	24.0	2,900		1.0									0.7	
2	X	24.0	3,100		1.4									1.1	
3		24.0	4,100												
4		24.0	4,100												
5	X	24.0	4,100		1.3									1.0	
6	X	24.0	6,600		1.3									1.1	
7	X	24.0	4,200		1.1									0.9	
8	X	24.0	3,600		1.2									0.9	
9	X	24.0	4,700		1.4									1.1	
10		24.0	3,233												
11		24.0	3,233												
12	X	24.0	3,233		1.2									0.9	
13	X	24.0	1,000		0.9									0.7	
14	X	24.0	1,700		1.0									0.7	
15	X	24.0	1,600		1.1									0.9	
16	X	24.0	1,700		1.1									0.8	
17		24.0	3,533												
18		24.0	3,533												
19	X	24.0	3,533		1.0									0.8	
20	X	24.0	3,800		0.9									0.7	
21	X	24.0	4,400		1.0									0.8	
22	X	24.0	5,600		0.9									0.6	
23	X	24.0	4,300		0.9									0.6	
24		24.0	4,000												
25		24.0	4,000												
26	X	24.0	4,000		1.6									1.3	
27	X	24.0	1,700		1.5									1.3	
28	X	24.0	2,000		1.4									1.1	
29	X	24.0	1,900		0.9									0.7	
30	X	24.0	5,400		1.3									1.0	
Total			104,800												
Average			3,493												
Maximum			6,600												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of:	May, 2004
--	-----------

A. Public Water System (PWS) Information

PWS Name: Stone Mountain		PWS Identification Number: 3351282	
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community
Number of Service Connections at End of Month: 9		Total Population Served at End of Month: 32	
PWS Owner: Florida Water Services			
Contact Person: Craig Anderson		Contact Person's Title: VP Environmental Services	
Contact Person's Mailing Address: P.O. Box 609520		City: Orlando	State: Florida
Contact Person's Telephone Number: (407) 598-4199		Contact Person's Fax Number: (407) 598-4217	
Contact Person's E-Mail Address: craiga@florida-water.com			

B. Water Treatment Plant Information

Plant Name: Stone Mountain		Plant Telephone Number: 352-787-0980	
Plant Address: 1730 Lakeview Drive		City: Yalaha	State: Florida
Type of Water Treatment by Plant:		<input checked="" type="checkbox"/> Raw Ground Water	<input type="checkbox"/> Purchased Finished Water
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 144,000		Plant Class (per subsection 62-699.310(4), F.A.C.): D	
Plant Category (per subsection 62-699.310(4), F.A.C.): V		Plant Class (per subsection 62-699.310(4), F.A.C.): D	

Licensed Operators	Name	License Class	License Number	Day(s)/Shift(s) Worked
Lead/Chief Operator:	Will Fontaine	C	6813	Days 1st Shift
Other Operators:	Brian Heath	C	5825	Days 1st Shift
	John Worrell	C	6597	Days 1st Shift
	Gary Kissick	C	7846	Days 1st Shift
	Adam Michaelsen		Trainee	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

6/8/2004 0:00	Will Fontaine	C-6813
Signature and Date	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3351282 Plant Name: Stone Mountain

III. Daily Data for the Month/Year of: May, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours Plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C	Lowest CT Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remove Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
1		24.0	1,367										
2		24.0	1,367										
3	X	24.0	1,367									0.9	
4	X	24.0	1,400									1.1	
5	X	24.0	1,600									1.0	
6	X	24.0	4,200									1.2	
7	X	24.0	1,200									1.0	
8		24.0	1,233										
9		24.0	1,233										
10	X	24.0	1,233									0.9	
11	X	24.0	1,500									0.9	
12	X	24.0	4,400									1.1	
13	X	24.0	1,600									0.9	
14	X	24.0	600									0.8	
15		24.0	1,333									1.0	
16		24.0	1,333									1.0	
17	X	24.0	1,333									1.0	
18	X	24.0	2,900									0.9	
19	X	24.0	2,100									1.1	
20	X	24.0	1,800									1.1	
21	X	24.0	1,700									1.2	
22		24.0	2,700										
23		24.0	2,700										
24	X	24.0	2,700									1.1	
25	X	24.0	900									0.9	
26	X	24.0	3,800									0.8	
27	X	24.0	1,400									0.6	
28	X	24.0	1,300									0.7	
29		24.0	11,000										
30		24.0	11,000										
31	X	24.0	11,000									0.6	
Total		85,300											
Average		2,752											
Maximum		11,000											

* Refer to the instructions for this report to determine which plants must provide this information

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: June, 2004

A. Public Water System (PWS) Information

PWS Name:	Stone Mountain			PWS Identification Number:	3351282
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month:	9			Total Population Served at End of Month:	32
PWS Owner:	Florida Water Services				
Contact Person:	Craig Anderson			Contact Person's Title:	VP Environmental Services
Contact Person's Mailing Address:	P.O. Box 609520		City:	Orlando	State: Florida Zip Code: 32860-9520
Contact Person's Telephone Number:	(407) 598-4199			Contact Person's Fax Number:	(407) 598-4217
Contact Person's E-Mail Address:	craig@florida-water.com				

B. Water Treatment Plant Information

Plant Name:	Stone Mountain			Plant Telephone Number:	352-787-0980
Plant Address:	1730 Lakeview Drive		City:	Yalaha	State: Florida Zip Code: 34797
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water		<input type="checkbox"/> Purchased Finished Water		
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	144,000				
Plant Category (per subsection 62-699.310(4), F.A.C.):	V			Plant Class (per subsection 62-699.310(4), F.A.C.): D	
Licensed Operators	Name	License Class	License Number	Day(s)/Shift(s) Worked	
Lead/Chief Operator:	Will Fontaine	C	6813	Days 1st Shift	
Other Operators:	Brian Heath	C	5825	Days 1st Shift	
	John Worrell	C	6597	Days 1st Shift	
	Gary Kissick	C	7846	Days 1st Shift	
	Adam Michealsen - Trainee			Days 1st Shift	

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date

Will Fontaine

Printed or Typed Name

C-6813

License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3351282 Plant Name: Stone Mountain

III. Daily Data for the Month/Year of: June, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation		
				CT Calculations					UV Dose							
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L			
1	X	24.0	1,500		0.9										0.7	
2	X	24.0	3,800		0.8										0.5	
3	X	24.0	1,000		0.9										0.6	
4	X	24.0	1,500		0.9										0.6	
5		24.0	1,367													
6		24.0	1,367													
7	X	24.0	1,367		1.0										0.7	
8	X	24.0	1,100		0.9										0.7	
9	X	24.0	1,500		1.0										0.7	
10	X	24.0	900		0.9										0.6	
11	X	24.0	1,200		0.9										0.7	
12		24.0	1,100													
13		24.0	1,100													
14	X	24.0	1,100		0.9										0.6	
15	X	24.0	800		0.9										0.7	
16	X	24.0	1,200		0.9										0.6	
17	X	24.0	1,500		1.1										0.9	
18	X	24.0	2,000		1.0										0.7	
19		24.0	1,100													
20		24.0	1,100													
21	X	24.0	1,100		0.9										0.6	
22	X	24.0	1,000		0.9										0.7	
23	X	24.0	1,400		1.2										0.9	
24	X	24.0	900		1.2										1.0	
25	X	24.0	1,000		1.2										1.0	
26		24.0	1,100													
27		24.0	1,100													
28	X	24.0	1,100		1.2										1.0	
29	X	24.0	800		1.1										0.8	
30	X	24.0	1,300		1.0										0.7	
Total			38,400													
Average			1,280													
Maximum			3,800													

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: July, 2004

A. Public Water System (PWS) Information

PWS Name: Stone Mountain		PWS Identification Number: 3351282	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 9		Total Population Served at End of Month: 32	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: 2315 Griffin Road		City: Leesburg	State: Florida Zip Code: 34748
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquamerica.com			

B. Water Treatment Plant Information

Plant Name: Stone Mountain		Plant Telephone Number: 352-787-0980		
Plant Address: 1730 Lakeview Drive		City: Yalaha	State: Florida Zip Code: 34797	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 144,000				
Plant Category (per subsection 62-699.310(4), F.A.C.): V		Plant Class (per subsection 62-699.310(4), F.A.C.): D		
Licensed Operators	Name	License Class	License Number	Day(s)/ Shift(s) Worked
Lead/Chief Operator:	Will Fontaine	C	6813	Days 1st Shift
Other Operators:	Brian Heath	C	5825	Days 1st Shift
	John Worrell	C	6597	Days 1st Shift

II Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Will Fontaine Printed or Typed Name	C-6813 License Number
--------------------	--	--------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3351282 Plant Name: Stone Mountain

III. Daily Data for the Month/year of: July, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Operator Visited by	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Disinfectant		CT Calculations		Lowest CT Provided	Disinfectant Contact Time	Measurement (T) at C	Point During Peak Flow	Customer During Peak Flow, mg./min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg./min/L	Operating UV Dose, mW-sec/cm ²	Lowest UV Dose, mW-sec/cm ²	Minimum UV Dose Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
					Lowest Residual	Disinfectant	Lowest UV Dose	Operating UV Dose													
1																					
2																					
3																					
4																					
5																					
6																					
7																					
8																					
9																					
10																					
11																					
12																					
13																					
14																					
15																					
16																					
17																					
18																					
19																					
20																					
21																					
22																					
23																					
24																					
25																					
26																					
27																					
28																					
29																					
30																					
31																					
Total																					
Average																					
Maximum																					

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: August, 2004

A. Public Water System (PWS) Information

PWS Name: Stone Mountain		PWS Identification Number: 3351282	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 9		Total Population Served at End of Month: 32	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: 2315 Griffin Road		City: Leesburg	State: Florida
		Zip Code: 34748	
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquaaamerica.com			

B. Water Treatment Plant Information

Plant Name: Stone Mountain		Plant Telephone Number: 352-787-0980		
Plant Address: 1730 Lakeview Drive		City: Yalaha	State: Florida	
		Zip Code: 34797		
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 144,000				
Plant Category (per subsection 62-699.310(4), F.A.C.): V		Plant Class (per subsection 62-699.310(4), F.A.C.): D		
Licensed Operators	Name	License Class	License Number	
Lead/Chief Operator:	Will Fontaine	C	6813	
	Days 1st Shift			
	Other Operators:	Brian Heath	C	5825
		Days 1st Shift		
John Worrell		C	6597	
Days 1st Shift				

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Will Fontaine Printed or Typed Name	C-6813 License Number
--------------------	--	--------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3351282 Plant Name: Stone Mountain

III. Daily Data for the Month/Year of: August, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Emergency or Abnormal Operating Conditions: Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L		
1		24.0	1,900												
2	X	24.0	1,900		1.4									1.1	
3	X	24.0	1,400		1.3									1.1	
4	X	24.0	1,400		1.4									1.2	
5	X	24.0	1,100		1.4									1.1	
6	X	24.0	1,500		1.2									0.9	
7		24.0	1,333												
8		24.0	1,333												
9	X	24.0	1,333		1.0									0.7	
10	X	24.0	1,200		1.0									0.8	
11	X	24.0	1,300		1.2									0.8	
12	X	24.0	1,000		1.4									0.9	
13	X	24.0	1,400		1.5									1.1	
14	X	24.0	900		1.1									0.9	
15		24.0	1,650												
16	X	24.0	1,650		1.0									0.7	
17	X	24.0	1,000		1.4									1.1	
18	X	24.0	1,200		1.4									1.1	
19	X	24.0	1,300		1.1									0.9	
20	X	24.0	1,400		1.2									0.9	
21		24.0	1,300												
22		24.0	1,300												
23	X	24.0	1,300		1.1									0.8	
24	X	24.0	1,800		1.1									0.9	
25	X	24.0	1,600		1.0									0.8	
26	X	24.0	1,600		1.1									0.8	
27	X	24.0	3,100		0.9									0.7	
28		24.0	2,200												
29		24.0	2,200												
30	X	24.0	2,200		1.3									1.0	
31	X	24.0	1,700		1.4									1.1	
Total			45,800												
Average			1,527												
Maximum			3,100												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: September, 2004

A. Public Water System (PWS) Information

PWS Name: Stone Mountain		PWS Identification Number: 3351282	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 9		Total Population Served at End of Month: 32	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: 2315 Griffin Road		City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquaamerica.com			

B. Water Treatment Plant Information

Plant Name: Stone Mountain		Plant Telephone Number: 352-787-0980		
Plant Address: 1730 Lakeview Drive		City: Yalaha	State: Florida	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 144,000				
Plant Category (per subsection 62-699.310(4), F.A.C.): V		Plant Class (per subsection 62-699.310(4), F.A.C.): D		
Licensed Operators	Name	License Class	License Number	Day(s)/Shift(s) Worked
Lead/Chief Operator:	Will Fontaine	C	6813	Days 1st Shift
Other Operators:	Brian Heath	C	5825	Days 1st Shift
	John Worrell	C	6597	Days 1st Shift

II Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date

Will Fontaine
Printed or Typed Name

C-6813
License Number

MONTHLY OPERATION REPORT FOR PW'S TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3351282 | Plant Name: Stone Mountain | September, 2004

III. Daily Data for the Month/Year of:

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) at Measurement Point During Peak Flow, mg/L	Disinfectant Contact Time Before or at First Customer Measurement (T) at C	Lowest CT Disinfectant Before or at First Customer Measurement During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, If Applicable	Required, mg-min/L	Minimum CT Operating UV Dose, mW-sec/cm ²	Lowest UV Dose, mW-sec/cm ²	Minimum Disinfectant Concentration at Remote Point in Distribution System, mg/L	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*		CT Calculations	
													UV Dose	UV Dose	CT Calculations	CT Calculations
1	X	1,700	24.0	1.2												
2	X	1,700	24.0	1.4												
3	X	1,400	24.0	1.2												
4		1,600	24.0													
5		1,600	24.0													
6	X	1,600	24.0	1.1												
7	X	3,000	24.0	1.2												
8	X	1,300	24.0	1.2												
9	X	1,900	24.0	1.2												
10	X	2,100	24.0	1.1												
11		1,733	24.0													
12		1,733	24.0													
13	X	1,733	24.0	1.0												
14	X	2,200	24.0	1.0												
15	X	2,100	24.0	1.4												
16	X	1,700	24.0	1.2												
17	X	2,400	24.0	1.0												
18		1,567	24.0													
19		1,567	24.0													
20	X	1,567	24.0	1.0												
21	X	2,100	24.0	1.1												
22	X	2,100	24.0	1.0												
23	X	1,900	24.0	1.0												
24	X	4,200	24.0	1.1												
25		3,600	24.0													
26		3,600	24.0													
27	X	3,600	24.0	0.8												
28	X	3,900	24.0	1.0												
29	X	5,700	24.0	1.2												
30	X	4,300	24.0	1.3												
31	X		24.0													
Total		71,200														
Average		2,373														
Maximum		5,700														

* Refer to the instructions for this report to determine which plants must provide this information

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: October, 2004

A. Public Water System (PWS) Information

PWS Name: Stone Mountain		PWS Identification Number: 3351282	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 9		Total Population Served at End of Month: 32	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: 2315 Griffin Road		City: Leesburg	State: Florida
		Zip Code: 34748	
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquaaamerica.com			

B. Water Treatment Plant Information

Plant Name: Stone Mountain		Plant Telephone Number: 352-787-0980	
Plant Address: 1730 Lakeview Drive		City: Yalaha	State: Florida
		Zip Code: 34797	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 144,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): V		Plant Class (per subsection 62-699.310(4), F.A.C.): D	

Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Will Fontaine	C	6813	Days 1st Shift
Other Operators:	Brian Heath	C	5825	Days 1st Shift
	John Worrell	C	6597	Days 1st Shift

II Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Will Fontaine Printed or Typed Name	C-6813 License Number
--------------------	--	--------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3351282 Plant Name: Stone Mountain

III. Daily Data for the Month/Year of: October, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Emergency or Abnormal Operating Conditions: Repair or Maintenance Work that Involves Taking Water System Components Out of Operation		
				CT Calculations					UV Dose							
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L			
1	X	24.0	4,600		1.3										1.0	
2		24.0	5,333													
3		24.0	5,333													
4	X	24.0	5,333		1.2										0.9	
5	X	24.0	4,300		1.2										1.0	
6	X	24.0	8,600		1.2										0.9	
7	X	24.0	5,000		1.2										0.8	
8	X	24.0	5,700		1.3										1.0	
9		24.0	4,967													
10		24.0	4,967													
11	X	24.0	4,967		1.3										1.0	
12	X	24.0	5,500		1.3										1.0	
13	X	24.0	6,800		1.2										1.0	
14	X	24.0	5,600		1.2										0.9	
15	X	24.0	1,000		1.0										0.8	
16		24.0	3,267													
17		24.0	3,267													
18	X	24.0	3,267		1.2										0.9	
19	X	24.0	1,200		1.2										1.0	
20	X	24.0	4,400		1.2										0.8	
21	X	24.0	1,000		1.2										0.8	
22	X	24.0	2,600		1.2										0.8	
23		24.0	2,567													
24		24.0	2,567													
25	X	24.0	2,567		1.1										0.8	
26	X	24.0	1,700		1.2										0.8	
27	X	24.0	2,500		1.3										1.0	
28	X	24.0	1,900		1.3										0.9	
29	X	24.0	1,300		1.5										0.9	
30		24.0	1,300													
31		24.0	1,300													
Total			114,700													
Average			3,700													
Maximum			8,600													

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: November, 2004

A. Public Water System (PWS) Information

PWS Name: Stone Mountain		PWS Identification Number: 3351282	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 9		Total Population Served at End of Month: 32	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: 2315 Griffin Road		City: Leesburg	State: Florida
		Zip Code: 34748	
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquaaamerica.com			

B. Water Treatment Plant Information

Plant Name: Stone Mountain		Plant Telephone Number: 352-787-0980	
Plant Address: 1730 Lakeview Drive		City: Yalaha	State: Florida
		Zip Code: 34797	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 144,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): V			
Plant Class (per subsection 62-699.310(4), F.A.C.): D			
Licensed Operators	Name	License Class	License Number
Lead/Chief Operator:	Will Fontaine	C	6813
Other Operators:	Brian Heath	C	5825
	John Worrell	C	6597

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

	Will Fontaine	C-6813
Signature and Date	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3351282 Plant Name: Stone Mountain

III. Daily Data for the Month/Year of: November, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation		
				CT Calculations				UV Dose							
				Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C if Applicable	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²			Minimum UV Dose Required, mW-sec/cm ²	
1	X	24.0	7,900		1.3									1.0	
2	X	24.0	2,700		1.4									1.2	
3	X	24.0	4,100		1.4									1.2	
4	X	24.0	1,500		1.4									1.2	
5	X	24.0	4,800		1.3									1.0	
6		24.0	1,467												
7		24.0	1,467												
8	X	24.0	1,467		1.2									1.0	
9	X	24.0	2,200		1.3									1.0	
10	X	24.0	1,300		1.3									1.1	
11	X	24.0	4,700		1.4									1.1	
12	X	24.0	1,200		1.3									1.0	
13		24.0	1,567												
14		24.0	1,567												
15	X	24.0	1,567		1.5									1.2	
16	X	24.0	1,700		1.3									1.1	
17	X	24.0	4,300		1.2									1.0	
18	X	24.0	1,200		1.3									1.0	
19	X	24.0	2,800		1.3									1.1	
20		24.0	1,667												
21		24.0	1,667												
22	X	24.0	1,667		1.2									1.0	
23	X	24.0	4,500		1.3									1.0	
24	X	24.0	1,500		1.3									1.1	
25	X	24.0	1,300		1.2									1.0	
26	X	24.0	1,300		1.2									1.0	
27		24.0	2,500												
28		24.0	2,500												
29	X	24.0	2,500		1.2									1.0	
30	X	24.0	1,200		1.2									0.9	
31		24.0													
Total			71,800												
Average			2,316												
Maximum			7,900												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



Polymer Page 3 Due in December

See Pages 4 for Instructions.

I. General Information for the Month/Year of:	December, 2004
--	----------------

A. Public Water System (PWS) Information

PWS Name: Stone Mountain		PWS Identification Number: 3351282	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 9		Total Population Served at End of Month: 32	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: 2315 Griffin Road		City: Leesburg	State: Florida
		Zip Code: 34748	
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquamerica.com			

B. Water Treatment Plant Information

Plant Name: Stone Mountain		Plant Telephone Number: 352-787-0980	
Plant Address: 1730 Lakeview Drive		City: Yalaha	State: Florida
		Zip Code: 34797	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 144,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): V		Plant Class (per subsection 62-699.310(4), F.A.C.): D	

Licensed Operators	Name	License Class	License Number	Day(s)/Shift(s) Worked
Lead/Chief Operator:	Will Fontaine	C	6813	Days 1st Shift
Other Operators:	Brian Heath	C	5825	Days 1st Shift
	John Worrell	C	6597	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Will Fontaine Printed or Typed Name	C-6813 License Number
--------------------	--	--------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identificaiton Number: 3351282 Plant Name: Stone Mountain

III. Daily Data for the Month/Year of: December, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log-Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations					UV Dose							
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²				
1	X	24.0	1,900		1.3										1.1	
2	X	24.0	1,900		1.2										1.0	
3	X	24.0	2,100		1.3										1.0	
4		24.0	2,367													
5		24.0	2,367													
6	X	24.0	2,367		1.1										0.9	
7	X	24.0	700		1.3										1.0	
8	X	24.0	2,200		1.4										1.2	
9	X	24.0	1,700		1.2										1.1	
10	X	24.0	2,000		1.2										1.0	
11		24.0	2,667													
12		24.0	2,667													
13	X	24.0	2,667		1.2										1.0	
14	X	24.0	1,900		1.1										0.9	
15	X	24.0	2,000		1.0										0.9	
16	X	24.0	1,500		1.0										0.8	
17	X	24.0	2,600		1.2										0.9	
18		24.0	2,300													
19		24.0	2,300													
20	X	24.0	2,300		1.1										0.9	
21	X	24.0	1,800		0.8										0.6	
22	X	24.0	1,600		0.8										0.6	
23	X	24.0	5,700		0.9										0.6	
24	X	24.0	1,300		1.2										1.0	
25		24.0	2,733													
26		24.0	2,733													
27	X	24.0	2,733		1.5										1.2	
28	X	24.0	1,800		1.4										1.2	
29	X	24.0	1,700		1.3										1.0	
30	X	24.0	1,800		1.3										1.0	
31	X	24.0	1,500		1.2										1.0	
Total			67,900													
Average			2,190													
Maximum			5,700													

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: January, 2005

A. Public Water System (PWS) Information

PWS Name:	Stone Mountain	PWS Identification Number:	3351282
PWS Type:	<input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive		
Number of Service Connections at End of Month:	9	Total Population Served at End of Month:	32
PWS Owner:	Aqua Utilities Florida		
Contact Person:	Brian Heath	Contact Person's Title:	Area Manager
Contact Person's Mailing Address:	PO Box 490310	City:	Leesburg
		State:	Florida
		Zip Code:	34749
Contact Person's Telephone Number:	(352) 787-0980	Contact Person's Fax Number:	(352) 787-6333
Contact Person's E-Mail Address:	beheath@aquaamerica.com		

B. Water Treatment Plant Information

Plant Name:	Stone Mountain	Plant Telephone Number:	352-787-0980
Plant Address:	1730 Lakeview Drive	City:	Yalaha
		State:	Florida
		Zip Code:	34797
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	144,000		
Plant Category (per subsection 62-699.310(4), F.A.C.):	V	Plant Class (per subsection 62-699.310(4), F.A.C.):	D

Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Will Fontaine	C	6813	Days 1st Shift
Other Operators:	Brian Heath	C	5825	Days 1st Shift
	John Worrell	C	6597	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

_____ Signature and Date	Will Fontaine _____ Printed or Typed Name	C-6813 _____ License Number
-----------------------------	---	-----------------------------------

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3351282 Plant Name: Stone Mountain

III. Daily Data for the Month/Year of: January, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Measurement Point During Customer First Disinfectant Contact Time	Disinfectant (T) at C	Peak Flow, mg/L	Peak Flow, minutes	CT Calculations				Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg/mL	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	System, mg/L	Day of the Month	
								CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*	UV Dose	Emergency or Abnormal Operating Conditions: Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	Emergency or Abnormal Operating Conditions: Repair or Maintenance Work that Involves Taking Water System Components Out of Operation								
1		24.0	2,067																
2		24.0	2,067																
3	X	24.0	2,067	1.8															
4	X	24.0	4,300	1.3															
5	X	24.0	1,600	1.3															
6	X	24.0	2,500	1.3															
7	X	24.0	2,100	1.3															
8		24.0	2,500																
9		24.0	2,500																
10	X	24.0	2,500	1.4															
11	X	24.0	2,100	1.3															
12	X	24.0	1,800	1.3															
13	X	24.0	1,500	1.2															
14	X	24.0	2,200	1.3															
15		24.0	1,800																
16		24.0	1,800																
17	X	24.0	1,800	1.4															
18	X	24.0	1,600	1.3															
19	X	24.0	1,800	1.4															
20	X	24.0	1,200	1.4															
21	X	24.0	2,200	1.3															
22		24.0	1,700																
23		24.0	1,700																
24	X	24.0	1,700	1.5															
25	X	24.0	1,900	1.0															
26	X	24.0	1,600	1.6															
27	X	24.0	1,400	1.6															
28	X	24.0	2,300	1.3															
29		24.0	1,700																
30		24.0	1,700																
31	X	24.0	1,700	1.4															
Total		61,400																	
Average		1,981																	
Maximum		4,300																	

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: February, 2005

A. Public Water System (PWS) Information

PWS Name: Stone Mountain		PWS Identification Number: 3351282	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 10		Total Population Served at End of Month: 35	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
		Zip Code: 34749	
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquaamerica.com			

B. Water Treatment Plant Information

Plant Name: Stone Mountain		Plant Telephone Number: 352-787-0980		
Plant Address: 1730 Lakeview Drive		City: Yalaha	State: Florida	
		Zip Code: 34797		
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 144,000				
Plant Category (per subsection 62-699.310(4), F.A.C.): V		Plant Class (per subsection 62-699.310(4), F.A.C.): D		
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Will Fontaine	C	6813	Days 1st Shift
Other Operators:	Brian Heath	C	5825	Days 1st Shift
	John Worrell	C	6597	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date

Will Fontaine

Printed or Typed Name

C-6813

License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identificaiton Number: 3351282 Plant Name: Stone Mountain

III. Daily Data for the Month/Year of: February, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm	Minimum UV Dose Required, mW-sec/cm			
1	X	24.0	1,300		1.3									1.1	
2	X	24.0	1,500		1.2									0.9	
3	X	24.0	1,100		1.3									1.1	
4	X	24.0	2,000		1.5									1.2	
5		24.0	1,700												
6		24.0	1,700												
7	X	24.0	1,700		1.4									1.0	
8	X	24.0	1,800		1.3									1.0	
9	X	24.0	1,600		1.3									1.0	
10	X	24.0	1,100		1.2									1.0	
11	X	24.0	2,300		1.3									1.1	
12		24.0	1,500												
13		24.0	1,500												
14	X	24.0	1,500		0.8									0.6	
15	X	24.0	4,900		1.2									0.3	
16	X	24.0	1,800		1.3									0.7	
17	X	24.0	1,900		1.3									1.0	
18	X	24.0	1,900		1.3									0.8	
19		24.0	2,033												
20		24.0	2,033												
21	X	24.0	2,033		1.4									1.1	
22	X	24.0	1,500		1.5									1.3	
23	X	24.0	1,300		1.5									1.2	
24	X	24.0	1,400		1.4									1.2	
25	X	24.0	1,400		1.3									1.1	
26	X	24.0	1,667												
27		24.0	1,667												
28	X	24.0	1,667		1.6									1.2	
29		24.0													
30		24.0													
31		24.0													
Total			49,500												
Average			1,597												
Maximum			4,900												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: March, 2005

A. Public Water System (PWS) Information

PWS Name:	Stone Mountain	PWS Identification Number:	3351282
PWS Type:	<input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month:	10	Total Population Served at End of Month:	35
PWS Owner:	Aqua Utilities Florida		
Contact Person:	Brian Heath	Contact Person's Title:	Area Manager
Contact Person's Mailing Address:	PO Box 490310	City:	Leesburg
		State:	Florida
		Zip Code:	34749
Contact Person's Telephone Number:	(352) 787-0980	Contact Person's Fax Number:	(352) 787-6333
Contact Person's E-Mail Address:	beheath@aquaaamerica.com		

B. Water Treatment Plant Information

Plant Name:	Stone Mountain	Plant Telephone Number:	352-787-0980
Plant Address:	1730 Lakeview Drive	City:	Yalaha
		State:	Florida
		Zip Code:	34797
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	144,000		
Plant Category (per subsection 62-699.310(4), F.A.C.):	V	Plant Class (per subsection 62-699.310(4), F.A.C.):	D

Licensed Operators	Name	License Class	License Number	Day(s)/Shift(s) Worked
Lead/Chief Operator:	Will Fontaine	C	6813	Days 1st Shift
Other Operators:	Brian Heath	C	5825	Days 1st Shift
	John Worrell	C	6597	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date

Will Fontaine
Printed or Typed Name

C-6813
License Number

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3351282 Plant Name: Stone Mountain March, 2005

III. Daily Data for the Month/Year of:

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide Ultraviolet Radiation Other (Describe):

Days Plant Visted or Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Provided	Contact Time Before or at First Measurement (T) at C	Disinfectant Before or at First Measurement (C) Before or at First Customer Point During Peak Flow, mg/L	Temp of Water, °C if Applicable	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Operating UV Dose, mW-sec/cm	Required UV Dose, mW-sec/cm	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	CT Calculations	
													UV Dose	UV Dose
1	X	24.0	2,000	1.7										1.4
2	X	24.0	1,700	1.2										1.0
3	X	24.0	1,900	1.4										1.0
4	X	24.0	2,000	1.4										1.2
5		24.0	1,733											
6	X	24.0	1,733											
7	X	24.0	1,733	1.3										1.0
8	X	24.0	2,000	1.1										0.9
9	X	24.0	1,400	1.1										0.9
10	X	24.0	1,400	1.1										0.8
11	X	24.0	2,400	1.0										0.8
12		24.0	1,367											
13		24.0	1,367											
14	X	24.0	1,367	1.1										0.8
15	X	24.0	1,800	1.1										0.8
16	X	24.0	1,300	1.0										0.8
17	X	24.0	1,900	1.1										0.9
18	X	24.0	1,700	1.2										0.9
19		24.0	1,900											
20		24.0	1,900											
21	X	24.0	1,900	1.0										0.7
22	X	24.0	1,800	1.1										0.9
23	X	24.0	1,000	1.0										0.8
24	X	24.0	1,400	1.0										0.8
25	X	24.0	2,000	1.0										0.7
26		24.0	1,433											
27		24.0	1,433											
28	X	24.0	1,433	1.0										0.7
29	X	24.0	1,200	0.9										0.7
30	X	24.0	2,000	0.9										0.7
31	X	24.0	1,200	1.0										0.9
Total		51,400												
Average		1,658												
Maximum		2,400												

* Refer to the instructions for this report to determine which plants must provide this information

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: April, 2005

A. Public Water System (PWS) Information

PWS Name: Stone Mountain		PWS Identification Number: 3351282	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 10		Total Population Served at End of Month: 35	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
		Zip Code: 34749	
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquamerica.com			

B. Water Treatment Plant Information

Plant Name: Stone Mountain		Plant Telephone Number: 352-787-0980	
Plant Address: 1730 Lakeview Drive		City: Yalaha	State: Florida
		Zip Code: 34797	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 144,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): V		Plant Class (per subsection 62-699.310(4), F.A.C.): D	
Licensed Operators	Name	License Class	License Number
Lead/Chief Operator:	Will Fontaine	C	6813
Other Operators:	Brian Heath	C	5825
	John Worrell	C	6597

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date

Will Fontaine

Printed or Typed Name

C-6813

License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identificaiton Number: 3351282 Plant Name: Stone Mountain

III. Daily Data for the Month/Year of: April, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions. Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations					UV Dose							
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²				
1	X	24.0	2,500		1.0										0.7	
2		24.0	2,400													
3		24.0	2,400													
4	X	24.0	2,400		1.0										0.8	
5	X	24.0	2,100		1.0										0.7	
6	X	24.0	2,400		1.0										0.8	
7	X	24.0	1,800		1.0										0.8	
8	X	24.0	1,900		1.2										0.9	
9		24.0	2,600													
10		24.0	2,600													
11	X	24.0	2,600		1.1										0.9	
12	X	24.0	2,000		1.1										0.8	
13	X	24.0	1,700		1.2										0.9	
14	X	24.0	1,000		1.2										1.0	
15	X	24.0	1,500		1.0										0.8	
16		24.0	2,267													
17		24.0	2,267													
18	X	24.0	2,267		0.9										0.6	
19	X	24.0	1,600		0.9										0.6	
20	X	24.0	1,000		0.9										0.7	
21	X	24.0	2,500		1.0										0.7	
22	X	24.0	4,000		0.8										0.6	
23		24.0	2,167													
24		24.0	2,167													
25	X	24.0	2,167		1.0										0.8	
26	X	24.0	2,700		1.1										0.8	
27	X	24.0	1,200		1.0										0.8	
28	X	24.0	1,900		1.1										0.9	
29	X	24.0	1,000		0.9										0.7	
30		24.0	1,500													
31		24.0														
Total			62,600													
Average			2,019													
Maximum			4,000													

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: May, 2005

A. Public Water System (PWS) Information

PWS Name:	Stone Mountain	PWS Identification Number:	3351282
PWS Type:	<input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive		
Number of Service Connections at End of Month:	10	Total Population Served at End of Month:	35
PWS Owner:	Aqua Utilities Florida		
Contact Person:	Brian Heath	Contact Person's Title:	Area Manager
Contact Person's Mailing Address:	PO Box 490310	City:	Leesburg
		State:	Florida
		Zip Code:	34749
Contact Person's Telephone Number:	(352) 787-0980	Contact Person's Fax Number:	(352) 787-6333
Contact Person's E-Mail Address:	beheath@aquaamerica.com		

B. Water Treatment Plant Information

Plant Name:	Stone Mountain	Plant Telephone Number:	352-787-0980
Plant Address:	1730 Lakeview Drive	City:	Yalaha
		State:	Florida
		Zip Code:	34797
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	144,000		
Plant Category (per subsection 62-699.310(4), F.A.C.):	V	Plant Class (per subsection 62-699.310(4), F.A.C.):	D

Licensed Operators	Name	License Class	License Number	Day(s)/Shift(s) Worked
Lead/Chief Operator:	Will Fontaine	C	6813	Days 1st Shift
Other Operators:	Brian Heath	C	5825	Days 1st Shift
	John Worrell	C	6597	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	<u>Will Fontaine</u>	<u>C-6813</u>
	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identificaiton Number: 3351282 Plant Name: Stone Mountain

III. Daily Data for the Month/Year of: May, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations				UV Dose					
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²		
1		24.0	1,500										
2	X	24.0	1,500		1.0								0.7
3	X	24.0	1,000		0.8								0.6
4	X	24.0	4,300		0.8								0.5
5	X	24.0	1,800		0.9								0.7
6	X	24.0	1,000		0.9								0.7
7		24.0	1,600										
8		24.0	1,600										
9	X	24.0	1,600		0.9								0.7
10	X	24.0	1,700		1.0								0.8
11	X	24.0	900		0.9								0.7
12	X	24.0	1,200		1.0								0.8
13	X	24.0	2,200		1.0								0.8
14		24.0	3,267										
15		24.0	3,267										
16	X	24.0	3,267		1.6								1.4
17	X	24.0	1,300		1.4								1.1
18	X	24.0	900		1.4								1.2
19	X	24.0	1,900		1.2								1.1
20	X	24.0	1,000		0.8								0.7
21		24.0	1,633										
22		24.0	1,633										
23	X	24.0	1,633		1.3								1.1
24	X	24.0	1,000		1.2								1.0
25	X	24.0	1,300		1.2								1.0
26	X	24.0	1,700		1.3								1.0
27	X	24.0	1,100		1.4								1.2
28		24.0	2,133										
29		24.0	2,133										
30	X	24.0	2,133		1.3								1.2
31	X	24.0	1,400		1.4								1.1
Total			54,600										
Average			1,761										
Maximum			4,300										

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: June, 2005

A. Public Water System (PWS) Information

PWS Name: Stone Mountain		PWS Identification Number: 3351282	
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community
Number of Service Connections at End of Month: 10		Total Population Served at End of Month: 35	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquaamerica.com			

B. Water Treatment Plant Information

Plant Name: Stone Mountain		Plant Telephone Number: 352-787-0980	
Plant Address: 1730 Lakeview Drive		City: Yalaha	State: Florida
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water		<input type="checkbox"/> Purchased Finished Water	
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 144,000		Plant Class (per subsection 62-699.310(4), F.A.C.): D	
Plant Category (per subsection 62-699.310(4), F.A.C.): V		Plant Class (per subsection 62-699.310(4), F.A.C.): D	
Licensed Operators	Name	License Class	License Number
Lead/Chief Operator:	Will Fontaine	C	6813
Other Operators:	Brian Heath	C	5825
	John Worrell	C	6597

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Will Fontaine Printed or Typed Name	C-6813 License Number
--------------------	--	--------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3351282 Plant Name: Stone Mountain

III. Daily Data for the Month/Year of: June, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demstrate Four-Log Virus Inactivation, if Applicable*										Emergency or Abnormal Operating Conditions: Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L		
1	X	24.0	1,000		1.2									1.0	
2	X	24.0	1,700		1.3									1.0	
3	X	24.0	4,200		1.3									1.1	
4		24.0	933												
5		24.0	933												
6	X	24.0	933		1.2									1.0	
7	X	24.0	900		1.2									1.0	
8	X	24.0	1,000		1.3									1.1	
9	X	24.0	1,300		1.2									1.1	
10	X	24.0	1,200		1.6									1.2	
11		24.0	1,233												
12		24.0	1,233												
13	X	24.0	1,233		1.2									1.0	
14	X	24.0	1,300		1.2									1.0	
15	X	24.0	1,000		1.2									0.9	
16	X	24.0	2,000		1.3									1.1	
17	X	24.0	1,700		1.4									1.1	
18		24.0	967												
19		24.0	967												
20	X	24.0	967		1.2									1.0	
21	X	24.0	1,100		1.3									1.1	
22	X	24.0	1,400		1.3									1.1	
23	X	24.0	1,100		1.2									1.0	
24	X	24.0	1,900		1.3									1.0	
25		24.0	1,200												
26		24.0	1,200												
27	X	24.0	1,200		1.2									1.0	
28	X	24.0	1,000		1.5									1.2	
29	X	24.0	1,000		1.5									1.2	
30	X	24.0	800		1.6									1.3	
31		24.0													
Total			38,600												
Average			1,245												
Maximum			4,200												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: July, 2005

A. Public Water System (PWS) Information

PWS Name: Stone Mountain		PWS Identification Number: 3351282	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 10		Total Population Served at End of Month: 35	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
		Zip Code: 34749	
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquamerica.com			

B. Water Treatment Plant Information

Plant Name: Stone Mountain		Plant Telephone Number: 352-787-0980		
Plant Address: 1730 Lakeview Drive		City: Yalaha	State: Florida	
		Zip Code: 34797		
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 144,000				
Plant Category (per subsection 62-699.310(4), F.A.C.): V		Plant Class (per subsection 62-699.310(4), F.A.C.): D		
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Will Fontaine	C	6813	Days 1st Shift
Other Operators:	Brian Heath	C	5825	Days 1st Shift
	John Worrell	C	6597	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

	Will Fontaine	C-6813
Signature and Date	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3351282 Plant Name: Stone Mountain

III. Daily Data for the Month/Year of: July, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)

Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations					UV Dose							
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²				
1	X	24.0	900		1.5										1.3	
2		24.0	467													
3		24.0	467													
4	X	24.0	467		1.5										1.2	
5	X	24.0	500		1.3										1.0	
6	X	24.0	1,700		1.3										1.1	
7	X	24.0	1,000		1.4										1.2	
8	X	24.0	800		1.4										1.1	
9		24.0	1,100													
10		24.0	1,100													
11	X	24.0	1,100		1.2										1.0	
12	X	24.0	1,300		1.2										0.9	
13	X	24.0	1,100		1.2										0.9	
14	X	24.0	700		1.2										0.9	
15	X	24.0	1,500		1.1										0.9	
16		24.0	1,567													
17		24.0	1,567													
18	X	24.0	1,567		1.0										0.8	
19	X	24.0	1,300		1.0										0.7	
20	X	24.0	1,400		1.3										1.1	
21	X	24.0	1,900		1.3										0.9	
22	X	24.0	1,700		1.3										1.0	
23		24.0	2,800													
24		24.0	2,800													
25	X	24.0	2,800		1.1										0.9	
26	X	24.0	6,600		1.0										0.7	
27	X	24.0	5,600		1.0										0.8	
28	X	24.0	6,200		1.1										0.9	
29	X	24.0	1,800		0.9										0.7	
30		24.0	3,400													
31		24.0	3,400													
Total			60,600													
Average			1,955													
Maximum			6,600													

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: August, 2005

A. Public Water System (PWS) Information

PWS Name: Stone Mountain		PWS Identification Number: 3351282	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 10		Total Population Served at End of Month: 35	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 787-0980		Zip Code: 34749	
Contact Person's E-Mail Address: beheath@aquaamerica.com		Contact Person's Fax Number: (352) 787-6333	

B. Water Treatment Plant Information

Plant Name: Stone Mountain		Plant Telephone Number: 352-787-0980	
Plant Address: 1730 Lakeview Drive		City: Yalaha	State: Florida
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		Zip Code: 34797	
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 144,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): V		Plant Class (per subsection 62-699.310(4), F.A.C.): D	

Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Will Fontaine	C	6813	Days 1st Shift
Other Operators:	Brian Heath	C	5825	Days 1st Shift
	John Worrell	C	6597	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Will Fontaine	C-6813
	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3351282 Plant Name: Stone Mountain

III. Daily Data for the Month/Year of: August, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations				UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²			Minimum UV Dose Required, mW-sec/cm ²
1	X	24.0	3,400		1.3								1.0	
2	X	24.0	2,500		1.3								1.0	
3	X	24.0	2,200		1.1								0.9	
4	X	24.0	3,000		1.3								1.0	
5	X	24.0	3,800		1.1								0.9	
6		24.0	3,833											
7		24.0	3,833											
8	X	24.0	3,833		1.0								0.8	
9	X	24.0	2,900		1.0								0.8	
10	X	24.0	3,100		1.1								0.8	
11	X	24.0	2,900		1.5								1.2	
12	X	24.0	3,400		1.5								1.3	
13		24.0	3,833											
14		24.0	3,833											
15	X	24.0	3,833		1.6								1.3	
16	X	24.0	4,600		1.3								1.1	
17	X	24.0	5,000		1.5								1.3	
18	X	24.0	2,100		1.2								1.1	
19	X	24.0	3,000		1.2								1.0	
20		24.0	4,100											
21		24.0	4,100											
22	X	24.0	4,100		1.1								0.9	
23	X	24.0	2,200		1.1								0.8	
24	X	24.0	3,700		1.0								0.8	
25	X	24.0	5,300		1.3								1.0	
26	X	24.0	2,900		1.3								1.1	
27		24.0	2,600											
28		24.0	2,600											
29	X	24.0	2,600		1.5								1.1	
30	X	24.0	2,500		1.3								1.0	
31	X	24.0	2,600		1.1								1.0	
Total			104,200											
Average			3,361											
Maximum			5,300											

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: September, 2005

A. Public Water System (PWS) Information

PWS Name: Stone Mountain		PWS Identification Number: 3351282	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 10		Total Population Served at End of Month: 35	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
		Zip Code: 34749	
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquaaamerica.com			

B. Water Treatment Plant Information

Plant Name: Stone Mountain		Plant Telephone Number: 352-787-0980	
Plant Address: 1730 Lakeview Drive		City: Yalaha	State: Florida
		Zip Code: 34797	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 144,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): V		Plant Class (per subsection 62-699.310(4), F.A.C.): D	

Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Will Fontaine	C	6813	Days 1st Shift
Other Operators:	Brian Heath	C	5825	Days 1st Shift
	John Worrell	C	6597	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Will Fontaine Printed or Typed Name	C-6813 License Number
--------------------	--	--------------------------

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3351282 Plant Name: Stone Mountain

III. Daily Data for the Month/year of: September, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*																				
				Lowest Residual Disinfectant Provided	Contact Time	Disinfectant Before or at First Measurement (1) at C	Customer First	Flow, mg-min/L	Temp of Water, °C	pH of Water, If Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm	Minimum UV Dose Required, mW-sec/cm											
1	X	24.0	3,900																		1.2		0.9	
2	X	24.0	2,000																					0.9
3		24.0	2,800																					
4		24.0	2,800																					
5	X	24.0	2,800																					1.0
6	X	24.0	2,400																					1.0
7	X	24.0	3,300																					0.9
8	X	24.0	2,900																					0.9
9	X	24.0	2,700																					0.9
10		24.0	3,100																					
11		24.0	3,100																					
12	X	24.0	3,100																					1.0
13	X	24.0	3,100																					1.0
14	X	24.0	3,600																					1.1
15	X	24.0	2,600																					1.0
16	X	24.0	4,200																					1.0
17		24.0	3,167																					
18		24.0	3,167																					
19	X	24.0	3,167																					1.0
20	X	24.0	4,400																					1.1
21	X	24.0	2,800																					1.1
22	X	24.0	2,800																					1.1
23		24.0	2,750																					
24	X	24.0	2,750																					1.1
25		24.0	2,150																					
26	X	24.0	2,150																					1.0
27	X	24.0	2,900																					1.2
28	X	24.0	2,200																					1.0
29	X	24.0	2,400																					1.0
30	X	24.0	3,800																					1.0
31		24.0	3,800																					1.0
Total			89,000																					
Average			2,871																					
Maximum			4,400																					

* Refer to the instructions for this report to determine which plants must provide this information

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of:	October, 2005
--	---------------

A. Public Water System (PWS) Information

PWS Name: Stone Mountain	PWS Identification Number: 3351282		
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 10	Total Population Served at End of Month: 35		
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath	Contact Person's Title: Area Manager		
Contact Person's Mailing Address: PO Box 490310	City: Leesburg	State: Florida	Zip Code: 34749
Contact Person's Telephone Number: (352) 787-0980	Contact Person's Fax Number: (352) 787-6333		
Contact Person's E-Mail Address: beheath@aquaamerica.com			

B. Water Treatment Plant Information

Plant Name: Stone Mountain	Plant Telephone Number: 352-787-0980			
Plant Address: 1730 Lakeview Drive	City: Yalaha	State: Florida	Zip Code: 34797	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 144,000				
Plant Category (per subsection 62-699.310(4), F.A.C.): V	Plant Class (per subsection 62-699.310(4), F.A.C.): D			
Licensed Operators:	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Will Fontaine	C	6813	Days 1st Shift
Other Operators:	Brian Heath	C	5825	Days 1st Shift
	John Worrell	C	6597	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Will Fontaine Printed or Typed Name	C-6813 License Number
--------------------	--	--------------------------

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3351282 Plant Name: Stone Mountain
 III. Daily Data for the Month/Year of: October, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer Point During Peak Flow, mg/L	Disinfectant Measurement (T) at C	Lowest CT Provided Before or at First Customer Point During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest UV Dose, mW-sec/cm	Minimum UV Dose Required, mW-sec/cm	Lowest Residual Disinfectant Concentration at Distribution Point in Involves Taking Water System Components Out of Operation	CT Calculations		
													UV Dose	UV Dose	
1		24.0	2,300												
2		24.0	2,300												
3	X	24.0	2,300												
4	X	24.0	2,500												1.0
5	X	24.0	4,100												1.1
6	X	24.0	2,600												1.3
7	X	24.0	1,700												1.3
8		24.0	2,167												1.3
9		24.0	2,167												
10	X	24.0	2,167												
11	X	24.0	2,900												1.2
12	X	24.0	2,500												1.2
13	X	24.0	4,200												1.0
14	X	24.0	2,400												1.0
15		24.0	2,567												
16		24.0	2,567												
17	X	24.0	2,567												1.0
18	X	24.0	2,200												1.0
19	X	24.0	2,700												0.9
20	X	24.0	5,100												0.9
21	X	24.0	3,200												1.0
22		24.0	1,967												
23		24.0	1,967												
24	X	24.0	1,967												1.0
25	X	24.0	2,500												1.0
26	X	24.0	2,200												1.0
27	X	24.0	1,900												1.1
28	X	24.0	2,300												1.1
29		24.0	1,900												1.2
30		24.0	1,900												
31	X	24.0	1,900												0.7
Total		77,700													
Average		2,506													
Maximum		5,100													

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: November, 2005

A. Public Water System (PWS) Information

PWS Name: Stone Mountain		PWS Identification Number: 3351282	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 10		Total Population Served at End of Month: 35	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
		Zip Code: 34749	
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquaaamerica.com			

B. Water Treatment Plant Information

Plant Name: Stone Mountain		Plant Telephone Number: 352-787-0980	
Plant Address: 1730 Lakeview Drive		City: Yalaha	State: Florida
		Zip Code: 34797	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 144,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): V		Plant Class (per subsection 62-699.310(4), F.A.C.): D	
Licensed Operators	Name	License Class	License Number
Lead/Chief Operator:	Will Fontaine	C	6813
Other Operators:	Brian Heath	C	5825
	John Worrell	C	6597

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

	Will Fontaine	C-6813
Signature and Date	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3351282		Plant Name: Stone Mountain													
III. Daily Data for the Month/Year of: November, 2005															
Means of Achieving Four-Log Virus Inactivation/Removal: <input checked="" type="checkbox"/> Free Chlorine <input type="checkbox"/> Chlorine Dioxide <input type="checkbox"/> Ozone <input type="checkbox"/> Combined Chlorine (Chloramines)															
<input type="checkbox"/> Ultraviolet Radiation <input type="checkbox"/> Other (Describe):															
Type of Disinfectant Residual Maintained in Distribution System: <input checked="" type="checkbox"/> Free Chlorine <input type="checkbox"/> Combined Chlorine (Chloramines) <input type="checkbox"/> Chlorine Dioxide															
Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demstrate Four-Log Virus Inactivation, if Applicable*									Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm	Minimum UV Dose Required, mW-sec/cm			
1	X	24.0	2,200		1.3									1.1	
2	X	24.0	1,900		1.2									1.1	
3	X	24.0	2,400		1.2									1.0	
4	X	24.0	2,800		1.2									1.0	
5		24.0	3,733												
6		24.0	3,733												
7	X	24.0	3,733		1.2									1.0	
8	X	24.0	3,100		1.2									1.0	
9	X	24.0	2,400												
10	X	24.0	2,400		1.3									1.1	
11	X	24.0	1,800		1.2									0.9	
12	X	24.0	2,000		1.2									1.0	
13		24.0	3,600												
14	X	24.0	3,600		1.1									0.8	
15	X	24.0	3,000		1.2									1.0	
16	X	24.0	2,100		1.3									1.1	
17	X	24.0	2,000		1.3									1.1	
18	X	24.0	4,800		1.2									1.1	
19		24.0	1,767												
20		24.0	1,767												
21	X	24.0	1,767		1.2									1.0	
22	X	24.0	3,000		1.2									1.0	
23	X	24.0	2,300		1.1									1.0	
24	X	24.0	1,700		1.2									1.0	
25	X	24.0	1,600		1.2									1.1	
26		24.0	2,567												
27		24.0	2,567												
28	X	24.0	2,567		1.2									1.0	
29	X	24.0	1,200		1.2									0.9	
30	X	24.0	1,400		1.2									0.9	
31		24.0													
Total			75,500												
Average			2,435												
Maximum			4,800												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



Polymer Page 3 Due in December

See Pages 4 for Instructions.

I. General Information for the Month/Year of:	December, 2005
--	----------------

A. Public Water System (PWS) Information

PWS Name: Stone Mountain		PWS Identification Number: 3351282	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 10		Total Population Served at End of Month: 35	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 787-0980		Zip Code: 34749	
Contact Person's E-Mail Address: beheath@aquamerica.com		Contact Person's Fax Number: (352) 787-6333	

B. Water Treatment Plant Information

Plant Name: Stone Mountain		Plant Telephone Number: 352-787-0980	
Plant Address: 1730 Lakeview Drive		City: Yalaha	State: Florida
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		Zip Code: 34797	
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 144,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): V		Plant Class (per subsection 62-699.310(4), F.A.C.): D	

Licensed Operators	Name	License Class	License Number	Day(s)/Shift(s) Worked
Lead/Chief Operator:	Will Fontaine	C	6813	Days 1st Shift
Other Operators:	Brian Heath	C	5825	Days 1st Shift
	John Worrell	C	6597	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Will Fontaine Printed or Typed Name	C-6813 License Number
--------------------	--	--------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3351282 Plant Name: Stone Mountain

III. Daily Data for the Month/Year of: December, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²			
1	X	24.0	1,500		1.2									0.9	
2	X	24.0	1,500		1.2									0.9	
3		24.0	1,733												
4		24.0	1,733												
5	X	24.0	1,733		1.5									1.2	
6	X	24.0	2,100		1.4									1.2	
7	X	24.0	2,200		1.3									1.1	
8	X	24.0	1,900		1.3									1.1	
9	X	24.0	1,700		1.3									1.1	
10		24.0	2,700												
11		24.0	2,700												
12	X	24.0	2,700		1.2									1.0	
13	X	24.0	1,500		1.3									1.0	
14	X	24.0	2,200		1.3									1.1	
15	X	24.0	900		1.4									1.2	
16	X	24.0	2,300		1.4									1.2	
17		24.0	1,533												
18		24.0	1,533												
19	X	24.0	1,533		1.2									1.0	
20	X	24.0	1,500		1.3									1.0	
21	X	24.0	1,300		1.2									1.0	
22	X	24.0	1,700		1.3									1.1	
23	X	24.0	1,300		1.3									1.1	
24		24.0	1,767												
25		24.0	1,767												
26	X	24.0	1,767		1.2									0.9	
27	X	24.0	2,200		1.2									1.0	
28	X	24.0	2,000		1.3									1.0	
29	X	24.0	2,100		1.2									1.0	
30	X	24.0	2,000		1.2									1.0	
31		24.0	1,670												

Total	56,770
Average	1,831
Maximum	2,700

* Refer to the instructions for this report to determine which plants must provide this information.