

State of Florida



ORIGINAL

Public Service Commission

CAPITAL CIRCLE OFFICE CENTER • 2540 SHUMARD OAK BOULEVARD
TALLAHASSEE, FLORIDA 32399-0850

-M-E-M-O-R-A-N-D-U-M-

RECEIVED
07 FEB 26 2007
11:06 AM
COMMISSION
CLEAR

DATE: February 26, 2007
TO: Blanca S. Bayó, Commission Clerk and Administrative Services Director
FROM: Richard P. Redemann, Professional Engineer III, Division of Economic Regulation
RE: Docket No. 060253-WS – Application for increase in water and wastewater rates in Marion, Orange, Pasco, Pinellas, and Seminole Counties by Utilities, Inc. of Florida.

Please add to the docket file the attached email dated February 23, 2007, from Mr. Patrick Flynn, Regional Manager, for the applicant to Mr. Richard Redemann, Commission staff. The attachment is the utility's response to an earlier email following up on the Orange and Seminole Counties customer meeting.

Attachment

cc: Division of Economic Regulation (Rendell, Lingo, Slemkewicz)
Office of General Counsel (Jaeger)

C:\Msword\060253e.doc

DOCUMENT NUMBER-DATE
01799 FEB 26 07
FPSC-COMMISSION CLERK

Richard Redemann

From: Patrick Flynn [pcflynn@uiwater.com]
Sent: Friday, February 23, 2007 8:41 AM
To: Richard Redemann; Bryan Gongre
Cc: mfriedman@rsbattorneys.com; vlord@rsbattorneys.com; Troy Rendell; Ralph Jaeger; John Slemkewicz; Jennie Lingo; Patti Daniel
Subject: RE: UIF Orange and Seminole Counties
Attachments: Patrick Flynn.vcf

Good morning, Richard,

The status on the items listed below are as follows:

1. The plastic meter box lid was removed and replaced with a concrete lid that fits.
2. Some fill dirt and mulch has been placed around the work area.
3. The water leak was coming from an old valve. The leak has been stopped. However, the valve is scheduled for replacement shortly since the valve no longer functions properly. I will notify you when that work is completed.

Please let me know if you have any questions.

Thanks,
Patrick

Patrick C. Flynn
Regional Director
Utilities, Inc. of Florida
A Subsidiary of Utilities, Inc.
200 Weathersfield Avenue
Altamonte Springs, FL 32714-4027
(407) 869-8588, ext. 228
(407) 869-6961 fax
pcflynn@uiwater.com

Please note the change in the domain name.

From: Richard Redemann [mailto:RRedeman@PSC.STATE.FL.US]
Sent: Wednesday, February 21, 2007 10:42 AM
To: Patrick Flynn
Cc: mfriedman@rsbattorneys.com; vlord@rsbattorneys.com; Troy Rendell; Ralph Jaeger; John Slemkewicz; Jennie Lingo; Patti Daniel
Subject: RE: UIF Orange and Seminole Counties

Mr. Flynn:

Oakland Shores

After the customer meeting I went to Mr. Danny Ward's house at 622 Lakeland Drive. His house is adjacent to the Oakland Shores water treatment plant. His plastic meter cover does not fit on the concrete meter box. I spoke to him after the meeting and I advised him that the utility probably no longer carried the concrete box and lid. He is not opposed to a new plastic meter box with lid. Please replace with a new plastic meter box with lid, unless you have a concrete lid that fits. He spends a lot of time in his yard. Please be sure to properly landscape

2/23/2007

the yard, after replacing the meter box.

The water pipe/valve repair that the utility made near the water plant did not hold and it is still leaking. The construction area was not properly landscaped. Please repair and landscape.

Please let me know when these items are complete.

Thanks,

Richard Redemann, PE
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399
PH (850) 413-6999
FAX (850) 413-7000