

ORIGINAL

AUSLEY & MCMULLEN

ATTORNEYS AND COUNSELORS AT LAW

227 SOUTH CALHOUN STREET
P.O. BOX 391 (ZIP 32302)
TALLAHASSEE, FLORIDA 32301
(850) 224-9115 FAX (850) 222-7560

April 2, 2007

HAND DELIVERED

RECEIVED
01 APR -2 PM 3:02
COMMISSION
CLERK

Ms. Blanca S. Bayo, Director
Division of Commission Clerk
and Administrative Services
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, FL 32399-0850

Re: Fuel and Purchased Power Cost Recovery Clause with Generating
Performance Incentive Factor; FPSC Docket No. 070001-EI

Dear Ms. Bayo:

Enclosed for filing in the above docket on behalf of Tampa Electric Company are the original and fifteen (15) copies of each of the following:

1. Prepared Direct Testimony and Exhibit DRK-1 of David R. Knapp regarding Generating Performance Incentive Factor True-Up for the period January 2006 through December 2006.
2. Prepared Direct Testimony and Exhibit JTW-1 of Joann T. Wehle regarding Tampa Electric company's risk management and hedging activities for the period January 2006 through December 2006.

Please acknowledge receipt and filing of the above by stamping the duplicate copy of this letter and returning same to this writer.

Thank you for your assistance in connection with this matter.

Sincerely,

James D. Beasley
James D. Beasley

RECEIVED & FILED
Oh
FPSC-BUREAU OF RECORDS

cc: All parties of record (w/encls.)

Wehle
DOCUMENT NUMBER-DATE
02857 APR-25
FPSC-COMMISSION CLERK

Knapp
DOCUMENT NUMBER-DATE
02856 APR-25
FPSC-COMMISSION CLERK

CMP _____
COM 5
CTR Orig
ECR 0
GCL 1
OPC _____
RCA 1
SCR _____
SGA _____
SEC _____
OTH _____

JDB/pp
Enclosures

CERTIFICATE OF SERVICE

I HEREBY CERTIFY that a true and correct copy of the foregoing Testimony and Exhibits of David R. Knapp and Joann T. Wehle has been furnished by U. S. Mail or hand delivery (*) on this 2nd day of April 2007 to the following:

Ms. Lisa Bennett*
Staff Attorney
Office of the General Counsel
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, FL 32399-0850

Mr. John T. Burnett
Associate General Counsel
Progress Energy Service Co., LLC
Post Office Box 14042
St. Petersburg, FL 33733-4042

Mr. Paul Lewis, Jr.
106 East College Avenue
Suite 800
Tallahassee, FL 32301-7740

Mr. John W. McWhirter, Jr.
McWhirter, Reeves & Davidson, P.A.
400 North Tampa Street, Suite 2450
Tampa, FL 33601-5126

Ms. Patricia A. Christensen
Associate Public Counsel
Office of Public Counsel
111 West Madison Street – Room 812
Tallahassee, FL 32399-1400

Mr. Norman Horton
Messer Caparello & Self, P.A.
Post Office Box 15579
Tallahassee, FL 32317

Ms. Cheryl Martin
Florida Public Utilities Company
P. O. Box 3395
West Palm Beach, FL 33402-3395

Mr. John T. Butler
Senior Attorney
Florida Power & Light Company
700 Universe Boulevard
Juno Beach, FL 33408-0420

Mr. William Walker, III
Florida Power & Light Company
215 South Monroe Street, Suite 810
Tallahassee, FL 32301-1859

Mr. R. Wade Litchfield
Associate General Counsel
Florida Power & Light Company
700 Universe Blvd.
Juno Beach, FL 33408-0420

Ms. Susan Ritenour
Secretary and Treasurer
Gulf Power Company
One Energy Place
Pensacola, FL 32520-0780

Mr. Jeffrey A. Stone
Mr. Russell A. Badders
Beggs & Lane
Post Office Box 12950
Pensacola, FL 32591-2950


Mr. Robert Scheffel Wright
Mr. John T. LaVia, III
Young van Assenderp, P.A.
225 South Adams Street, Suite 200
Tallahassee, FL 32301

Mr. Michael B. Twomey
Post Office Box 5256
Tallahassee, FL 32314-5256

Karen S. White, Lt Col, USAF
Damund E. Williams, Capt., USAF
AFLSA/JACL-ULT
139 Barnes Drive, Suite 1
Tyndall Air Force Base, FL 32403-5319

Mr. James W. Brew
Brickfield, Burchette, Ritts & Stone, P.C.
1025 Thomas Jefferson Street, NW
Eighth Floor, West Tower
Washington, D.C. 20007-5201

Mr. Jack Shreve
Senior General Counsel
Ms. Cecilia Bradley
Senior Assistant Attorney General
Office of the Attorney General
The Capitol – PL01
Tallahassee, FL 32399-1050



ATTORNEY

ORIGINAL



BEFORE THE
FLORIDA PUBLIC SERVICE COMMISSION

DOCKET NO. 070001-EI
IN RE: FUEL & PURCHASED POWER COST RECOVERY
AND
CAPACITY COST RECOVERY

GENERATING PERFORMANCE INCENTIVE FACTOR
TRUE-UP
JANUARY 2006 THROUGH DECEMBER 2006

TESTIMONY AND EXHIBIT
OF
DAVID R. KNAPP

DOCUMENT NUMBER-DATE

02056 APR-25

FPSC-COMMISSION CLERK

1 BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

2 PREPARED DIRECT TESTIMONY

3 OF

4 DAVID R. KNAPP

5
6 **Q.** Please state your name, business address, occupation and
7 employer.

8
9 **A.** My name is David R. Knapp. My business address is 702 N.
10 Franklin Street, Tampa, Florida 33602. I am employed by
11 Tampa Electric Company ("Tampa Electric" or "company") as
12 a Senior Engineer in the Operations Planning area of the
13 Resource Planning Department.

14
15 **Q.** Please provide a brief outline of your educational
16 background and business experience.

17
18 **A.** I received a Bachelor of Marine Engineering degree in
19 1986 from the Maine Maritime Academy and a Master of
20 Business Administration from the University of Tampa in
21 2002. Prior to joining Tampa Electric, I worked in the
22 areas of operations engineering and management. In
23 January 1996, I joined Tampa Electric and worked in
24 field operations and power plant engineering. In April
25 2000, I transferred to the Resource Planning department,

1 where I led a team that provides engineering and
2 technical support in the development of Tampa Electric's
3 integrated resource planning process and business
4 planning activities. In December 2006, I transferred to
5 the Operations Planning area of the Resource Planning
6 department, where I provide engineering and technical
7 support for the daily operations of Tampa Electric's
8 generating facilities.

9
10 **Q.** What is the purpose of your testimony?

11
12 **A.** My testimony presents Tampa Electric's actual performance
13 results from unit equivalent availability and station
14 heat rate used to determine the GPIF for the period
15 January 2006 through December 2006. I will also compare
16 these results to the targets established prior to the
17 beginning of the period.

18
19 **Q.** Have you prepared an exhibit to support your testimony?

20
21 **A.** Yes, I prepared Exhibit No. _____ (DRK-1), consisting of
22 two documents. Document No. 1, entitled "Tampa Electric
23 Company, Generating Performance Incentive Factor, January
24 2006 - December 2006, True-up" is consistent with the
25 GPIF Implementation Manual previously approved by the

1 Commission. In addition, Document No. 2 provides the
2 company's Actual Unit Performance Data for the 2006
3 period.

4
5 **Q.** Which generating units on Tampa Electric's system are
6 included in the determination of the GPIF?

7
8 **A.** Five of the company's units are included. They are Big
9 Bend Station Units 1, 2, 3, and 4 and Polk Station Unit
10 1.

11
12 **Q.** Have you calculated the results of Tampa Electric's
13 performance under the GPIF during the January 2006
14 through December 2006 period?

15
16 **A.** Yes, I have. This is shown on Document No. 1, page 4 of
17 28. Based upon 2.617 GPIF points, the result is a reward
18 amount of \$1,439,819 for the period.

19
20 **Q.** Please proceed with your review of the actual results for
21 the January 2006 through December 2006 period.

22
23 **A.** On Document No. 1, page 3 of 28, the actual average
24 common equity for the period is shown on line 14 as
25 \$1,399,297,816. This produces the maximum penalty or

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

reward amount of \$5,501,411 as shown on line 21.

Q. Will you please explain how you arrived at the actual equivalent availability results for the five units included within the GPIF?

A. Yes. Operating data for each of the units is filed monthly with the Commission on the Actual Unit Performance Data form. Additionally, outage information is reported to the Commission on a monthly basis. A summary of this data for the 12 months provides the basis for the GPIF.

Q. Are the equivalent availability results shown on Document No. 1, page 6 of 28, column 2, directly applicable to the GPIF table?

A. No. Adjustments to equivalent availability may be required as noted in section 4.3.3 of the GPIF Manual. The actual equivalent availability including the required adjustment is shown on Document No. 1, page 6 of 28. The necessary adjustments as prescribed in the GPIF Manual are further defined by a letter dated October 23, 1981, from Mr. J. H. Hoffsis of the Commission's Staff. The adjustments for each unit are as follows:

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

Big Bend Unit No. 1

On this unit, 1,344.0 planned outage hours were originally scheduled for 2006. Actual outage activities required 1,621.4 planned outage hours. Consequently, the actual equivalent availability of 55.2% is adjusted to 57.4% as shown on Document No. 1, page 7 of 28.

Big Bend Unit No. 2

On this unit, 336.0 planned outage hours were originally scheduled for 2006. Actual outage activities required 0.0 planned outage hours. Consequently, the actual equivalent availability of 82.8% is adjusted to 79.7% as shown on Document No. 1, page 8 of 28.

Big Bend Unit No. 3

On this unit, 840.0 planned outage hours were originally scheduled for 2006. Actual outage activities required 695.7 planned outage hours. Consequently, the actual equivalent availability of 61.9% is adjusted to 60.8% as shown on Document No. 1, page 9 of 28.

Big Bend Unit No. 4

On this unit, 504.0 planned outage hours were originally scheduled for 2006. Actual outage activities required 728.3 planned outage hours. Consequently, the actual

1 equivalent availability of 74.7% is adjusted to 76.7% as
2 shown on Document No. 1, page 10 of 28.

3

4 **Polk Unit No. 1**

5 On this unit, 384.1 planned outage hours were originally
6 scheduled for 2006. Actual outage activities required
7 1,054.6 planned outage hours. Consequently, the actual
8 equivalent availability of 78.8% is adjusted to 85.6%, as
9 shown on Document No. 1, page 11 of 28.

10

11 **Q.** How did you arrive at the applicable equivalent
12 availability points for each unit?

13

14 **A.** The final adjusted equivalent availabilities for each
15 unit are shown on Document No. 1, page 6 of 28, column 4.
16 This number is entered into the respective Generating
17 Performance Incentive Point ("GPIP") table for each
18 particular unit on pages 22 of 28 through 26 of 28. Page
19 4 of 28 summarizes the equivalent availability points to
20 be awarded or penalized.

21

22 **Q.** Will you please explain the heat rate results relative to
23 the GPIF?

24

25 **A.** The actual heat rate and adjusted actual heat rate for

1 Big Bend Units 1, 2, 3, and 4 and Polk Unit 1 are shown
2 on Document No. 1, page 6 of 28. The adjustment was
3 developed based on the guidelines of section 4.3.16 of
4 the GPIF Manual. This procedure is further defined by a
5 letter dated October 23, 1981, from Mr. J. H. Hoffsis of
6 the FPSC Staff. The final adjusted actual heat rates are
7 also shown on page 5 of 28. The heat rate value is
8 entered into the respective GPIF table for the particular
9 unit, shown on pages 22 of 28 through 26 of 28. Page 4
10 of 28 summarizes the weighted heat rate and equivalent
11 availability points to be awarded.

12
13 Q. What is the overall GPIF for Tampa Electric for the
14 January 2006 through December 2006 period?

15
16 A. This is shown on Document No. 1, page 28 of 28.
17 Essentially, the weighting factors shown on page 4 of 28,
18 column 3, plus the equivalent availability points and the
19 heat rate points shown on page 4 of 28, column 4, are
20 substituted within the equation. The resulting value,
21 2.617, is then entered into the GPIF table on page 2 of
22 28. Using linear interpolation, the reward amount is
23 \$1,439,819.

24
25 Q. Does this conclude your testimony?

1 A. Yes, it does.

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

DOCKET NO. 070001-EI
GPIF 2006 TRUE-UP
EXHIBIT DRK-1

TAMPA ELECTRIC COMPANY

GENERATING PERFORMANCE INCENTIVE FACTOR

JANUARY 2006 - DECEMBER 2006

GENERATING PERFORMANCE INCENTIVE FACTOR

INDEX

DOCUMENT NO.	TITLE	BATES PAGE NO.
1	GPIF Schedules	11
2	Actual Unit Performance Data	40

DOCKET NO. 070001-EI
GPIF 2006 TRUE-UP SCHEDULES
EXHIBIT DRK-1, DOCUMENT 1

EXHIBIT TO THE TESTIMONY OF
DAVID R. KNAPP

DOCKET NO. 070001-EI

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE FACTOR
JANUARY 2006 - DECEMBER 2006
TRUE-UP

DOCUMENT NO. 1

GPIF SCHEDULES

**TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE FACTOR
JANUARY 2006 - DECEMBER 2006
TRUE-UP**

<u>SCHEDULE</u>	<u>PAGE</u>
GPIF REWARD / PENALTY TABLE - ACTUAL	2
GPIF CALCULATION OF MAXIMUM ALLOWED INCENTIVE DOLLARS	3
CALCULATIONS OF SYSTEM GPIF POINTS - ACTUAL	4
GPIF TARGET AND RANGE SUMMARY	5
UNIT PERFORMANCE DATA - ACTUAL	6
ADJUSTMENTS TO PERFORMANCE	7 - 11
ADJUSTMENTS TO HEAT RATE	12 - 16
PLANNED OUTAGE SCHEDULE - ACTUAL	17
CRITICAL PATH METHOD DIAGRAMS	18 - 21
GENERATING PERFORMANCE INCENTIVE POINTS TABLES	22 - 26
COMPARISON OF GPIF TARGETS VS ACTUAL PERFORMANCE	27
GENERATING PERFORMANCE INCENTIVE POINTS CALCULATION	28

TAMPA ELECTRIC COMPANY
 GENERATING PERFORMANCE INCENTIVE FACTOR
 REWARD / PENALTY TABLE - ACTUAL
 JANUARY 2006 - DECEMBER 2006

<u>GENERATING PERFORMANCE INCENTIVE POINTS (GPIP)</u>	<u>FUEL SAVINGS / (LOSS) (\$000)</u>	<u>GENERATING PERFORMANCE INCENTIVE FACTOR (\$000)</u>
+10	47,304.8	5,501.4
+9	42,574.3	4,951.3
+8	37,843.8	4,401.1
+7	33,113.4	3,851.0
+6	28,382.9	3,300.8
+5	23,652.4	2,750.7
+4	18,921.9	2,200.6
+3	14,191.4	1,650.4
+2	9,461.0	1,100.3
+1	4,730.5	550.1
0	0.0	0.0
-1	(7,868.1)	(550.1)
-2	(15,736.3)	(1,100.3)
-3	(23,604.4)	(1,650.4)
-4	(31,472.6)	(2,200.6)
-5	(39,340.7)	(2,750.7)
-6	(47,208.9)	(3,300.8)
-7	(55,077.0)	(3,851.0)
-8	(62,945.2)	(4,401.1)
-9	(70,813.3)	(4,951.3)
-10	(78,681.5)	(5,501.4)

←	GPI POINTS 2.617	REWARD DOLLARS \$1,439,819	→
---	---------------------------------	---	---

**TAMPA ELECTRIC COMPANY
 GENERATING PERFORMANCE INCENTIVE FACTOR
 CALCULATION OF MAXIMUM ALLOWED INCENTIVE DOLLARS - ACTUAL
 JANUARY 2006 - DECEMBER 2006**

Line 1	Beginning of period balance of common equity:		\$	1,397,064,560
	End of month common equity:			
Line 2	Month of January	2006	\$	1,365,249,995
Line 3	Month of February	2006	\$	1,372,165,914
Line 4	Month of March	2006	\$	1,379,626,548
Line 5	Month of April	2006	\$	1,372,714,617
Line 6	Month of May	2006	\$	1,386,926,221
Line 7	Month of June	2006	\$	1,402,697,771
Line 8	Month of July	2006	\$	1,393,886,891
Line 9	Month of August	2006	\$	1,415,659,121
Line 10	Month of September	2006	\$	1,430,971,591
Line 11	Month of October	2006	\$	1,386,239,722
Line 12	Month of November	2006	\$	1,443,027,575
Line 13	Month of December	2006	\$	1,444,641,084
Line 14	(Summation of line 1 through line 13 divided by 13)		\$	1,399,297,816
Line 15	25 Basis points			0.0025
Line 16	Revenue Expansion Factor			61.38%
Line 17	Maximum Allowed Incentive Dollars (line 14 times line 15 divided by line 16)		\$	5,699,251
Line 18	Jurisdictional Sales			19,020,146 MWH
Line 19	Total Sales			19,704,144 MWH
Line 20	Jurisdictional Separation Factor (line 18 divided by line 19)			96.53%
Line 21	Maximum Allowed Jurisdictional Incentive Dollars (line 17 times line 20)		\$	5,501,411

**TAMPA ELECTRIC COMPANY
 CALCULATION OF SYSTEM GPIF POINTS - ACTUAL
 JANUARY 2006 - DECEMBER 2006**

<u>PLANT / UNIT</u>	<u>12 MONTH ADJ. ACTUAL PERFORMANCE</u>	<u>WEIGHTING FACTOR %</u>	<u>UNIT POINTS</u>	<u>WEIGHTED UNIT POINTS</u>
BIG BEND 1	57.4% EAF	12.33%	-6.268	-0.773
BIG BEND 2	79.7% EAF	11.47%	6.116	0.702
BIG BEND 3	60.8% EAF	19.05%	6.285	1.197
BIG BEND 4	76.7% EAF	13.62%	10.000	1.362
POLK 1	85.6% EAF	10.20%	10.000	1.020
BIG BEND 1	11,058 ANOHR	5.49%	-3.237	-0.178
BIG BEND 2	10,451 ANOHR	5.89%	0.000	0.000
BIG BEND 3	11,130 ANOHR	6.45%	-2.046	-0.132
BIG BEND 4	11,103 ANOHR	8.49%	-6.841	-0.581
POLK 1	10,442 ANOHR	7.00%	0.000	0.000
		100.00%		2.617

GPIF REWARD	\$ 1,439,819
--------------------	---------------------

TAMPA ELECTRIC COMPANY
 GPIF TARGET AND RANGE SUMMARY

EQUIVALENT AVAILABILITY (%)

<u>PLANT / UNIT</u>	<u>WEIGHTING FACTOR (%)</u>	<u>EAF TARGET (%)</u>	<u>EAF MAX. (%)</u>	<u>RANGE MIN. (%)</u>	<u>MAX. FUEL SAVINGS (\$000)</u>	<u>MAX. FUEL LOSS (\$000)</u>	<u>EAF ADJUSTED ACTUAL (%)</u>	<u>ACTUAL FUEL SAVINGS/ LOSS (\$000)</u>
BIG BEND 1	12.33%	63.6	68.6	53.7	5,832.8	(12,556.3)	57.4%	(3,655.7)
BIG BEND 2	11.47%	77.3	81.2	69.3	5,426.4	(11,122.1)	79.7%	3,318.9
BIG BEND 3	19.05%	56.2	63.5	41.6	9,010.8	(16,752.4)	60.8%	10,529.4
BIG BEND 4	13.62%	71.9	76.6	62.4	6,443.0	(12,663.9)	76.7%	12,663.9
POLK 1	<u>10.20%</u>	60.3	67.6	45.8	<u>4,825.5</u>	<u>(9,820.5)</u>	85.6%	9,820.5
GPIF SYSTEM	66.67%				31,538.5	(62,915.2)		

AVERAGE NET OPERATING HEAT RATE (Btu/kwh)

<u>PLANT / UNIT</u>	<u>WEIGHTING FACTOR (%)</u>	<u>ANOHR (Btu/kwh)</u>	<u>TARGET NOF (%)</u>	<u>ANOHR TARGET RANGE</u>		<u>MAX. FUEL SAVINGS (\$000)</u>	<u>MAX. FUEL LOSS (\$000)</u>	<u>ACTUAL ADJUSTED ANOHR</u>	<u>ACTUAL FUEL SAVINGS/ LOSS (\$000)</u>
				<u>MIN.</u>	<u>MAX.</u>				
BIG BEND 1	5.49%	10,841	75.9	10,327	11,355	2,597.3	(2,597.3)	11,058	(840.9)
BIG BEND 2	5.89%	10,510	84.2	10,074	10,947	2,786.9	(2,786.9)	10,451	0.0
BIG BEND 3	6.45%	10,923	69.1	10,205	11,641	3,053.2	(3,053.2)	11,130	(624.8)
BIG BEND 4	8.49%	10,672	81.6	10,077	11,267	4,018.3	(4,018.3)	11,103	(2,749.0)
POLK 1	<u>7.00%</u>	10,497	88.9	9,330	11,664	<u>3,310.5</u>	<u>(3,310.5)</u>	10,442	0.0
GPIF SYSTEM	33.33%					15,766.3	(15,766.3)		

**TAMPA ELECTRIC COMPANY
 UNIT PERFORMANCE DATA - ACTUAL
 JANUARY 2006 - DECEMBER 2006**

<u>PLANT / UNIT</u>	<u>ACTUAL EAF (%)</u>	<u>ADJUSTMENTS (1) TO EAF (%)</u>	<u>EAF ADJUSTED ACTUAL (%)</u>
BIG BEND 1	55.2	2.2	57.4
BIG BEND 2	82.8	-3.1	79.7
BIG BEND 3	61.9	-1.1	60.8
BIG BEND 4	74.7	2.0	76.7
POLK 1	78.8	6.8	85.6

<u>PLANT / UNIT</u>	<u>ACTUAL ANOHR (Btu/kwh)</u>	<u>ADJUSTMENTS (2) TO ANOHR (Btu/kwh)</u>	<u>ANOHR ADJUSTED ACTUAL (Btu/kwh)</u>
BIG BEND 1	11,069	-11	11,058
BIG BEND 2	10,395	56	10,451
BIG BEND 3	10,817	313	11,130
BIG BEND 4	11,149	-46	11,103
POLK 1	10,473	-31	10,442

(1) Documentation of adjustments to Actual EAF on pages 7 - 11

(2) Documentation of adjustments to Actual ANOHR on pages 12 - 16

TAMPA ELECTRIC COMPANY
 ADJUSTMENTS TO PERFORMANCE
 BIG BEND UNIT NO. 1
 JANUARY 2006 - DECEMBER 2006

WEIGHTING FACTOR = 12.33%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
PH	8,760.0	8,760.0	8,760.0
EAF	63.6	55.2	57.4
POH	1,344.0	1,621.4	1,344.0
FOH + EFOH	1,452.3	1,811.2	1,881.6
MOH + EMOH	389.7	489.5	508.5
POF	15.3	18.5	15.3
EFOF	16.6	20.7	21.5
EMOF	4.4	5.6	5.8
	-6.268		EQUIVALENT AVAILABILITY POINTS

ADJUSTMENTS TO ACTUAL EAF FOR COMPARISON

$$\frac{PH - POH_{TARGET}}{PH - POH_{ACTUAL}} \times (FOH + EFOH + MOH + EMOH) = EUOH_{ADJUSTED}$$

$$\frac{8760 - 1344}{8760 - 1621.4} \times (1811.2 + 489.5) = 2390.1$$

$$100 - POF_{TARGET} - \frac{EUOH_{ADJUSTED}}{PH} \times 100 = EAF_{ADJUSTED}$$

$$100 - 15.3 - \frac{2390.1}{8760.0} \times 100 = 57.4$$

PH = PERIOD HOURS
 EAF = EQUIVALENT AVAILABILITY FACTOR
 POH = PLANNED OUTAGE HOURS
 FOH = FORCED OUTAGE HOURS
 EFOH = EQUIVALENT FORCED OUTAGE HOURS
 MOH = MAINTENANCE OUTAGE HOURS
 EMOH = EQUIVALENT MAINTENANCE OUTAGE HOURS
 POF = PLANNED OUTAGE FACTOR
 EFOF = EQUIVALENT FORCED OUTAGE FACTOR
 EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR

TAMPA ELECTRIC COMPANY
 ADJUSTMENTS TO PERFORMANCE
 BIG BEND UNIT NO. 2
 JANUARY 2006 - DECEMBER 2006

WEIGHTING FACTOR = 11.47%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
PH	8,760.0	8,760.0	8,760.0
EAF	77.3	82.8	79.7
POH	336.0	0.0	336.0
FOH + EFOH	1,286.2	1,242.4	1,194.7
MOH + EMOH	368.6	263.5	253.4
POF	3.8	0.0	3.8
EFOF	14.7	14.2	13.6
EMOF	4.2	3.0	2.9
	6.116	EQUIVALENT AVAILABILITY POINTS	

ADJUSTMENTS TO ACTUAL EAF FOR COMPARISON

$$\frac{PH - POH_{TARGET}}{PH - POH_{ACTUAL}} \times (FOH + EFOH + MOH + EMOH) = EUOH_{ADJUSTED}$$

$$\frac{8760 - 336}{8760 - 0} \times (1242.4 + 263.5) = 1448.1$$

$$100 - POF_{TARGET} - \frac{EUOH_{ADJUSTED}}{PH} \times 100 = EAF_{ADJUSTED}$$

$$100 - 3.8 - \frac{1448.1}{8760.0} \times 100 = 79.7$$

PH = PERIOD HOURS
 EAF = EQUIVALENT AVAILABILITY FACTOR
 POH = PLANNED OUTAGE HOURS
 FOH = FORCED OUTAGE HOURS
 EFOH = EQUIVALENT FORCED OUTAGE HOURS
 MOH = MAINTENANCE OUTAGE HOURS
 EMOH = EQUIVALENT MAINTENANCE OUTAGE HOURS
 POF = PLANNED OUTAGE FACTOR
 EFOF = EQUIVALENT FORCED OUTAGE FACTOR
 EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR

**TAMPA ELECTRIC COMPANY
 ADJUSTMENTS TO PERFORMANCE
 BIG BEND UNIT NO. 3
 JANUARY 2006 - DECEMBER 2006**

WEIGHTING FACTOR = 19.05%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
PH	8,760.0	8,760.0	8,760.0
EAf	56.2	61.9	60.8
POH	840.0	695.7	840.0
FOH + EFOH	2,558.8	2,205.4	2,165.9
MOH + EMOH	438.3	436.2	428.4
POF	9.6	7.9	9.6
EFOF	29.2	25.2	24.7
EMOF	5.0	5.0	4.9
	6.285	EQUIVALENT AVAILABILITY POINTS	

ADJUSTMENTS TO ACTUAL EAF FOR COMPARISON

$$\frac{PH - POH_{TARGET}}{PH - POH_{ACTUAL}} \times (FOH + EFOH + MOH + EMOH) = EUOH_{ADJUSTED}$$

$$\frac{8760 - 840}{8760 - 695.7} \times (2205.4 + 436.2) = 2594.3$$

$$100 - POF_{TARGET} - \frac{EUOH_{ADJUSTED}}{PH} \times 100 = EAF_{ADJUSTED}$$

$$100 - 9.6 - \frac{2594.3}{8760.0} \times 100 = 60.8$$

PH = PERIOD HOURS
 EAF = EQUIVALENT AVAILABILITY FACTOR
 POH = PLANNED OUTAGE HOURS
 FOH = FORCED OUTAGE HOURS
 EFOH = EQUIVALENT FORCED OUTAGE HOURS
 MOH = MAINTENANCE OUTAGE HOURS
 EMOH = EQUIVALENT MAINTENANCE OUTAGE HOURS
 POF = PLANNED OUTAGE FACTOR
 EFOF = EQUIVALENT FORCED OUTAGE FACTOR
 EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR

TAMPA ELECTRIC COMPANY
 ADJUSTMENTS TO PERFORMANCE
 BIG BEND UNIT NO. 4
 JANUARY 2006 - DECEMBER 2006

WEIGHTING FACTOR = 13.62%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
PH	8,760.0	8,760.0	8,760.0
EAF	71.9	74.7	76.7
POH	504.0	728.3	504.0
FOH + EFOH	1,930.8	1,271.8	1,307.3
MOH + EMOH	29.2	217.6	223.7
POF	5.8	8.3	5.8
EFOF	22.0	14.5	14.9
EMOF	0.3	2.5	2.6
	10.000	EQUIVALENT AVAILABILITY POINTS	

ADJUSTMENTS TO ACTUAL EAF FOR COMPARISON

$$\frac{PH - POH_{TARGET}}{PH - POH_{ACTUAL}} \times (FOH + EFOH + MOH + EMOH) = EUOH_{ADJUSTED}$$

$$\frac{8760 - 504}{8760 - 728.3} \times (1271.8 + 217.6) = 1531.0$$

$$100 - POF_{TARGET} - \frac{EUOH_{ADJUSTED}}{PH} \times 100 = EAF_{ADJUSTED}$$

$$100 - 5.8 - \frac{1531.0}{8760.0} \times 100 = 76.7$$

PH = PERIOD HOURS
 EAF = EQUIVALENT AVAILABILITY FACTOR
 POH = PLANNED OUTAGE HOURS
 FOH = FORCED OUTAGE HOURS
 EFOH = EQUIVALENT FORCED OUTAGE HOURS
 MOH = MAINTENANCE OUTAGE HOURS
 EMOH = EQUIVALENT MAINTENANCE OUTAGE HOURS
 POF = PLANNED OUTAGE FACTOR
 EFOF = EQUIVALENT FORCED OUTAGE FACTOR
 EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR

TAMPA ELECTRIC COMPANY
 ADJUSTMENTS TO PERFORMANCE
 POLK UNIT NO. 1
 JANUARY 2006 - DECEMBER 2006

WEIGHTING FACTOR = 10.20%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
PH	8,760.0	8,760.0	8,760.0
EAF	60.3	78.8	85.6
POH	384.1	1,054.6	384.1
FOH + EFOH	2,984.6	597.5	649.5
MOH + EMOH	106.1	208.8	227.0
POF	4.4	12.0	4.4
EFOF	34.1	6.8	7.4
EMOF	1.2	2.4	2.6
	10.000	EQUIVALENT AVAILABILITY POINTS	

ADJUSTMENTS TO ACTUAL EAF FOR COMPARISON

$$\frac{PH - POH_{TARGET}}{PH - POH_{ACTUAL}} \times (FOH + EFOH + MOH + EMOH) = EUOH_{ADJUSTED}$$

$$\frac{8760 - 384}{8760 - 1054.6} \times (597.5 + 208.8) = 876.5$$

$$100 - POF_{TARGET} - \frac{EUOH_{ADJUSTED}}{PH} \times 100 = EAF_{ADJUSTED}$$

$$100 - 4.4 - \frac{876.5}{8760.0} \times 100 = 85.6$$

PH = PERIOD HOURS
 EAF = EQUIVALENT AVAILABILITY FACTOR
 POH = PLANNED OUTAGE HOURS
 FOH = FORCED OUTAGE HOURS
 EFOH = EQUIVALENT FORCED OUTAGE HOURS
 MOH = MAINTENANCE OUTAGE HOURS
 EMOH = EQUIVALENT MAINTENANCE OUTAGE HOURS
 POF = PLANNED OUTAGE FACTOR
 EFOF = EQUIVALENT FORCED OUTAGE FACTOR
 EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR

**TAMPA ELECTRIC COMPANY
 ADJUSTMENTS TO HEAT RATE
 BIG BEND UNIT NO. 1
 JANUARY 2006 - DECEMBER 2006**

WEIGHTING FACTOR = 5.49%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>
ANOHR (BTU/KWH)	10,841	11,069
NET GENERATION (GWH)	2,007.8	1,860.9
OPERATING BTU (10 ⁹)	21,766.1	20,599.1
NET OUTPUT FACTOR	75.9	75.4

-3.237 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

CURRENT EQUATION: $NOF * (-20.61) + 12405.19 = ANOHR$

$75.4 * (-20.61) + 12405.19 = 10,852$

$11,069 - 10,852 = 217$

$10,841 + 217 = 11,058$ ← ADJUSTED ACTUAL
HEAT RATE AT
TARGET NOF

ANOHR = AVERAGE NET OPERATING HEAT RATE
 NOF = NET OPERATING FACTOR

**TAMPA ELECTRIC COMPANY
 ADJUSTMENTS TO HEAT RATE
 BIG BEND UNIT NO. 2
 JANUARY 2006 - DECEMBER 2006**

WEIGHTING FACTOR = 5.89%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>
ANOHR (BTU/KWH)	10,510	10,395
NET GENERATION (GWH)	2,582.9	2,727.6
OPERATING BTU (10 ⁹)	27,146.5	28,353.8
NET OUTPUT FACTOR	84.2	87.2

0.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

CURRENT EQUATION: $\text{NOF} * (-18.22) + 12043.31 = \text{ANOHR}$

$$87.2 * (-18.22) + 12043.31 = 10,455$$

$$10,395 - 10,455 = (60)$$

$$10,510 + (60) = 10,451 \leftarrow \text{ADJUSTED ACTUAL HEAT RATE AT TARGET NOF}$$

ANOHR = AVERAGE NET OPERATING HEAT RATE
 NOF = NET OPERATING FACTOR

**TAMPA ELECTRIC COMPANY
 ADJUSTMENTS TO HEAT RATE
 BIG BEND UNIT NO. 3
 JANUARY 2006 - DECEMBER 2006**

WEIGHTING FACTOR = 6.45%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>
ANOHR (BTU/KWH)	10,923	10,817
NET GENERATION (GWH)	1,601.7	2,155.2
OPERATING BTU (10 ⁹)	17,496.5	23,313.0
NET OUTPUT FACTOR	69.1	74.2

-2.046 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

CURRENT EQUATION: $\text{NOF} * (-60.84) + 15124.77 = \text{ANOHR}$

$$74.2 * (-60.84) + 15124.77 = 10,611$$

$$10,817 - 10,611 = 206$$

$$10,923 + 206 = 11,130 \leftarrow \text{ADJUSTED ACTUAL HEAT RATE AT TARGET NOF}$$

ANOHR = AVERAGE NET OPERATING HEAT RATE
 NOF = NET OPERATING FACTOR

**TAMPA ELECTRIC COMPANY
 ADJUSTMENTS TO HEAT RATE
 BIG BEND UNIT NO. 4
 JANUARY 2006 - DECEMBER 2006**

WEIGHTING FACTOR = 8.49%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>
ANOHR (BTU/KWH)	10,672	11,149
NET GENERATION (GWH)	2,605.1	2,677.2
OPERATING BTU (10 ⁹)	27,802.0	29,847.2
NET OUTPUT FACTOR	81.6	78.8

-6.841 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

CURRENT EQUATION: $NOF * (-16.29) + 12001.29 = ANOHR$

$$78.8 * (-16.29) + 12001.29 = 10,718$$

$$11,149 - 10,718 = 431$$

$$10,672 + 431 = 11,103 \leftarrow \text{ADJUSTED ACTUAL HEAT RATE AT TARGET NOF}$$

ANOHR = AVERAGE NET OPERATING HEAT RATE
 NOF = NET OPERATING FACTOR

**TAMPA ELECTRIC COMPANY
 ADJUSTMENTS TO HEAT RATE
 POLK UNIT NO. 1
 JANUARY 2006 - DECEMBER 2006**

WEIGHTING FACTOR = 7.00%

	12 MONTH TARGET	12 MONTH ACTUAL PERFORMANCE
ANOHR (BTU/KWH)	10,497	10,473
NET GENERATION (GWH)	1,162.3	1,588.8
OPERATING BTU (10 ⁹)	12,201.2	16,640.3
NET OUTPUT FACTOR	88.9	86.7

0.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

CURRENT EQUATION: $\text{NOF} * (-14.06) + 11747.01 = \text{ANOHR}$

$86.7 * (-14.06) + 11747.01 = 10,528$

$10,473 - 10,528 = (55)$


$10,497 + (55) = 10,442$ ← ADJUSTED ACTUAL
HEAT RATE AT
TARGET NOF

ANOHR = AVERAGE NET OPERATING HEAT RATE
 NOF = NET OPERATING FACTOR

**TAMPA ELECTRIC COMPANY
 PLANNED OUTAGE SCHEDULE (ACTUAL)
 GPIF UNITS
 JANUARY 2006 - DECEMBER 2006**


PLANT / UNIT	PLANNED OUTAGE DATES	OUTAGE DESCRIPTION
BIG BEND 1	Oct 07 - Dec 12	CP - High Pressure rotor at first and then converted to the exciter at the end of the outage. Other jobs worked include the following: High pressure turbine replaced the 2 control stage blades, main steam inlet nozzle, blade replacement in the reaction stage, complete seals and inspection, intermediate pressure turbine complete seals and inspection, low pressure turbine complete seals and inspection, generator inspection, exciter complete rewire, turbine valve remove and inspection. Work in the boiler includes the following: Replaced rear wall and nose arch, both north and south burner fronts, both north and south windboxes, UT inspection of the boiler and NDE of high energy piping, BOP - 6th point heater, new condenser tubes and tube cleaning system, new coal feeders, precipitator inlet and outlet nozzle replacement.
BIG BEND 3	Apr 01 - Apr 28	CP - Boiler weld overlay of the southwest furnace wall. Other jobs worked during this outage include: new coal nozzles, NDE of high energy piping, 3A slag tank top roof top refractory, main steam stop valve and combined reheat valve inspection.
BIG BEND 4	Feb 11 - Mar 14	CP - Weld overlay of the furnace walls (5,000 Sq Ft). Other jobs worked during this outage include: 4C mill roller replacement, 4D Southwest burner rebuild, UT inspection of the furnace side tubes, economizer restub (100) high energy piping replacement, 4B circulating water pump and motor remove and inspection.
POLK 1	Apr 13 - May 26	Gasifier refractory replacement. Radiant syngas cooler tube additions and repairs to steam dump valves, waterwall and sootblower box. Gasifier fuel booster pump. Repaired superheater tube in heat recovery steam generator. Replaced compressor discharge casing. Steam turbine inspection.

**TAMPA ELECTRIC COMPANY
 CRITICAL PATH METHOD DIAGRAMS
 GPIF UNITS > FOUR WEEKS
 JANUARY 2006 - DECEMBER 2006**




TAMPA ELECTRIC COMPANY
 BIG BEND UNIT 1
 PLANNED OUTAGE 2006
 ACTUAL CPM

**TAMPA ELECTRIC COMPANY
 CRITICAL PATH METHOD DIAGRAMS
 GPIF UNITS > FOUR WEEKS
 JANUARY 2006 - DECEMBER 2006**




TAMPA ELECTRIC COMPANY
 BIG BEND UNIT 3
 PLANNED OUTAGE 2006
 ACTUAL CPM

TAMPA ELECTRIC COMPANY
CRITICAL PATH METHOD DIAGRAMS
GPIF UNITS > FOUR WEEKS
JANUARY 2006 - DECEMBER 2006



TAMPA ELECTRIC COMPANY
BIG BEND UNIT 4
PLANNED OUTAGE 2006
ACTUAL CPM

TAMPA ELECTRIC COMPANY
 CRITICAL PATH METHOD DIAGRAMS
 GPIF UNITS > FOUR WEEKS
 JANUARY 2006 - DECEMBER 2006



TAMPA ELECTRIC COMPANY
 POLK UNIT 1
 PLANNED OUTAGE 2006
 ACTUAL CPM

TAMPA ELECTRIC COMPANY
 GENERATING PERFORMANCE INCENTIVE POINTS TABLE
 JANUARY 2006 - DECEMBER 2006

BIG BEND 1

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	5,832.8	68.6	+10	2,597.3	10,327
+9	5,249.5	68.1	+9	2,337.6	10,371
+8	4,666.2	67.6	+8	2,077.9	10,415
+7	4,083.0	67.1	+7	1,818.1	10,459
+6	3,499.7	66.6	+6	1,558.4	10,502
+5	2,916.4	66.1	+5	1,298.7	10,546
+4	2,333.1	65.6	+4	1,038.9	10,590
+3	1,749.8	65.1	+3	779.2	10,634
+2	1,166.6	64.6	+2	519.5	10,678
+1	583.3	64.1	+1	259.7	10,722
0	0.0	63.6	0	0.0	10,766
-1	(1,255.6)	62.6	-1	(259.7)	10,841
-2	(2,511.3)	61.6	-2	(519.5)	10,916
-3	(3,766.9)	60.6	-3	(779.2)	10,960
-4	(5,022.5)	59.7	-4	(1,038.9)	11,004
-5	(6,278.1)	58.7	-5	(1,298.7)	11,048
-6	(7,533.8)	57.7	-6	(1,558.4)	11,091
-7	(8,789.4)	56.7	-7	(1,818.1)	11,135
-8	(10,045.0)	55.7	-8	(2,077.9)	11,179
-9	(11,300.7)	54.7	-9	(2,337.6)	11,223
-10	(12,556.3)	53.7	-10	(2,597.3)	11,267

← EAF POINTS -6.268

Adjusted EAF 57.4 →

← AHR POINTS -3.237

Adjusted ANOHR 11,058 →

Weighting Factor =

12.33%

Weighting Factor =

5.49%

TAMPA ELECTRIC COMPANY
 GENERATING PERFORMANCE INCENTIVE POINTS TABLE

JANUARY 2006 - DECEMBER 2006

BIG BEND 2

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	5,426.4	81.2	+10	2,786.9	10,074
+9	4,883.8	80.8	+9	2,508.2	10,110
+8	4,341.1	80.4	+8	2,229.5	10,146
+7	3,798.5	80.1	+7	1,950.9	10,182
+6	3,255.8	79.7	+6	1,672.2	10,218
+5	2,713.2	79.3	+5	1,393.5	10,254
+4	2,170.6	78.9	+4	1,114.8	10,291
+3	1,627.9	78.5	+3	836.1	10,327
+2	1,085.3	78.1	+2	557.4	10,363
+1	542.6	77.7	+1	278.7	10,399
0	0.0	77.3	0	0.0	10,435
-1	(1,112.2)	76.5	-1	(278.7)	10,621
-2	(2,224.4)	75.7	-2	(557.4)	10,658
-3	(3,336.6)	74.9	-3	(836.1)	10,694
-4	(4,448.8)	74.1	-4	(1,114.8)	10,730
-5	(5,561.0)	73.3	-5	(1,393.5)	10,766
-6	(6,673.3)	72.5	-6	(1,672.2)	10,802
-7	(7,785.5)	71.7	-7	(1,950.9)	10,838
-8	(8,897.7)	70.9	-8	(2,229.5)	10,874
-9	(10,009.9)	70.1	-9	(2,508.2)	10,911
-10	(11,122.1)	69.3	-10	(2,786.9)	10,947

← EAF POINTS 6.116

Adjusted EAF 79.7 →

← AHR POINTS 0.000

Adjusted ANOHR 10,451 →

Weighting Factor = 11.47%

Weighting Factor = 5.89%

TAMPA ELECTRIC COMPANY
 GENERATING PERFORMANCE INCENTIVE POINTS TABLE
 JANUARY 2006 - DECEMBER 2006

BIG BEND 3

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	9,010.8	63.5	+10	3,053.2	10,205
+9	8,109.7	62.8	+9	2,747.8	10,270
+8	7,208.6	62.1	+8	2,442.5	10,334
+7	6,307.6	61.3	+7	2,137.2	10,398
+6	5,406.5	60.6	+6	1,831.9	10,463
+5	4,505.4	59.9	+5	1,526.6	10,527
+4	3,604.3	59.1	+4	1,221.3	10,591
+3	2,703.2	58.4	+3	915.9	10,656
+2	1,802.2	57.7	+2	610.6	10,720
+1	901.1	56.9	+1	305.3	10,784
0	0.0	56.2	0	0.0	10,848
-1	(1,675.2)	54.7	-1	(305.3)	10,923
-2	(3,350.5)	53.3	-2	(610.6)	10,998
-3	(5,025.7)	51.8	-3	(915.9)	11,063
-4	(6,701.0)	50.3	-4	(1,221.3)	11,127
-5	(8,376.2)	48.9	-5	(1,526.6)	11,191
-6	(10,051.4)	47.4	-6	(1,831.9)	11,256
-7	(11,726.7)	45.9	-7	(2,137.2)	11,320
-8	(13,401.9)	44.5	-8	(2,442.5)	11,384
-9	(15,077.2)	43.0	-9	(2,747.8)	11,448
-10	(16,752.4)	41.6	-10	(3,053.2)	11,513

Weighting Factor =

19.05%

Weighting Factor =

6.45%

TAMPA ELECTRIC COMPANY
 GENERATING PERFORMANCE INCENTIVE POINTS TABLE

JANUARY 2006 - DECEMBER 2006

BIG BEND 4

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	6,443.0	76.6	+10	4,018.3	10,077
+9	5,798.7	76.2	+9	3,616.5	10,129
+8	5,154.4	75.7	+8	3,214.7	10,181
+7	4,510.1	75.2	+7	2,812.8	10,233
+6	3,865.8	74.7	+6	2,411.0	10,285
+5	3,221.5	74.3	+5	2,009.2	10,337
+4	2,577.2	73.8	+4	1,607.3	10,389
+3	1,932.9	73.3	+3	1,205.5	10,441
+2	1,288.6	72.8	+2	803.7	10,493
+1	644.3	72.3	+1	401.8	10,545
0	0.0	71.9	0	0.0	10,597
-1	(1,266.4)	70.9	-1	(401.8)	10,672
-2	(2,532.8)	70.0	-2	(803.7)	10,747
-3	(3,799.2)	69.0	-3	(1,205.5)	10,799
-4	(5,065.6)	68.1	-4	(1,607.3)	10,851
-5	(6,331.9)	67.1	-5	(2,009.2)	10,903
-6	(7,598.3)	66.2	-6	(2,411.0)	10,955
-7	(8,864.7)	65.2	-7	(2,812.8)	11,007
-8	(10,131.1)	64.3	-8	(3,214.7)	11,059
-9	(11,397.5)	63.3	-9	(3,616.5)	11,111
-10	(12,663.9)	62.4	-10	(4,018.3)	11,163

Weighting Factor =

13.62%

Weighting Factor =

8.49%

TAMPA ELECTRIC COMPANY
 GENERATING PERFORMANCE INCENTIVE POINTS TABLE

JANUARY 2006 - DECEMBER 2006

POLK 1

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	4,825.5	67.6	+10	3,310.5	9,330
+9	4,343.0	66.9	+9	2,979.5	9,439
+8	3,860.4	66.2	+8	2,648.4	9,549
+7	3,377.9	65.4	+7	2,317.4	9,658
+6	2,895.3	64.7	+6	1,986.3	9,767
+5	2,412.8	64.0	+5	1,655.3	9,876
+4	1,930.2	63.2	+4	1,324.2	9,985
+3	1,447.7	62.5	+3	993.2	10,095
+2	965.1	61.8	+2	662.1	10,204
+1	482.6	61.1	+1	331.1	10,313
0	0.0	60.3	0	0.0	10,422
-1	(982.1)	58.9	-1	(331.1)	10,497
-2	(1,964.1)	57.4	-2	(662.1)	10,572
-3	(2,946.2)	56.0	-3	(993.2)	10,681
-4	(3,928.2)	54.5	-4	(1,324.2)	10,791
-5	(4,910.3)	53.1	-5	(1,655.3)	10,900
-6	(5,892.3)	51.6	-6	(1,986.3)	11,009
-7	(6,874.4)	50.2	-7	(2,317.4)	11,118
-8	(7,856.4)	48.7	-8	(2,648.4)	11,227
-9	(8,838.5)	47.2	-9	(2,979.5)	11,336
-10	(9,820.5)	45.8	-10	(3,310.5)	11,446

Weighting Factor =

10.20%

Weighting Factor =

7.00%

**TAMPA ELECTRIC COMPANY
 COMPARISON OF GPIF TARGETS VS ACTUAL PERFORMANCE**

EQUIVALENT AVAILABILITY (%)

<u>PLANT / UNIT</u>	<u>TARGET WEIGHTING FACTOR (%)</u>	<u>NORMALIZED WEIGHTING FACTOR</u>	<u>TARGET PERIOD JAN 06 - DEC 06</u>			<u>ACTUAL PERFORMANCE JAN 06 - DEC 06</u>		
			<u>POF</u>	<u>EUOF</u>	<u>EUOR</u>	<u>POF</u>	<u>EUOF</u>	<u>EUOR</u>
BIG BEND 1	12.33%	18.5%	15.3	21.0	24.8	18.5	26.3	32.2
BIG BEND 2	11.47%	17.2%	3.8	18.9	19.6	0.0	17.2	17.2
BIG BEND 3	19.05%	28.6%	9.6	34.2	37.8	7.9	30.2	32.8
BIG BEND 4	13.62%	20.4%	5.8	22.4	23.7	8.3	17.0	18.5
POLK 1	10.20%	15.3%	4.4	35.3	36.9	12.0	9.2	10.5
GPIF SYSTEM	66.67%	100.0%	8.1	26.9	29.3	9.2	21.3	23.7
GPIF SYSTEM WEIGHTED EQUIVALENT AVAILABILITY (%)			<u>65.0</u>			<u>69.5</u>		
			<u>3 PERIOD AVERAGE</u>			<u>3 PERIOD AVERAGE</u>		
			<u>POF</u>	<u>EUOF</u>	<u>EUOR</u>	<u>EAF</u>		
			6.1	25.8	27.4	68.1		

AVERAGE NET OPERATING HEAT RATE (Btu/kwh)

<u>PLANT / UNIT</u>	<u>TARGET WEIGHTING FACTOR (%)</u>	<u>NORMALIZED WEIGHTING FACTOR</u>	<u>TARGET HEAT RATE</u>	<u>ADJUSTED ACTUAL HEAT RATE</u>
			<u>JAN 06 - DEC 06</u>	<u>JAN 06 - DEC 06</u>
BIG BEND 1	5.49%	16.5%	10,841	11,058
BIG BEND 2	5.89%	17.7%	10,510	10,451
BIG BEND 3	6.45%	19.4%	10,923	11,130
BIG BEND 4	8.49%	25.5%	10,672	11,103
POLK 1	7.00%	21.0%	10,497	10,442
GPIF SYSTEM	33.33%	100.0%		
GPIF SYSTEM WEIGHTED AVERAGE HEAT RATE (Btu/kwh)			<u>10,683</u>	<u>10,847</u>

**TAMPA ELECTRIC COMPANY
 GENERATING PERFORMANCE INCENTIVE POINTS CALCULATION
 JANUARY 2006 - DECEMBER 2006**

Points are calculated according to the formula:

$$GPIP = \sum_{i=1}^n [a_i(EAP_i) + e_i(AHRP_i)]$$

Where:

GPIP = Generating performance incentive points

a_i = Percentage of total system fuel cost reduction attributed to maximum reasonably attainable equivalent availability of unit *i* during the period

e_i = Percentage of total system fuel cost reduction attributed to minimum reasonably attainable average heat rate of unit *i* during the period

EAP_i = Equivalent availability points awarded/deducted for unit *i*

AHRP_i = Average heat rate points awarded/deducted for unit *i*

Weighting factors and point values are listed on page 4.

<i>GPIP</i> =	12.33%	*	(BB 1 EAP)	+	11.47%	*	(BB 2 EAP)	+	19.05%	*	(BB 3 EAP)
	+ 13.62%	*	(BB 4 EAP)	+							
	+ 10.20%	*	(PK 1 EAP)	+	5.49%	*	(BB 1 AHRP)	+	5.89%	*	(BB 2 AHRP)
	+ 6.45%	*	(BB 3 AHRP)	+	8.49%	*	(BB 4 AHRP)	+			
				+	7.00%	*	(PK 1 AHRP)				

<i>GPIP</i> =	12.33%	*	-6.268	+	11.47%	*	6.116	+	19.05%	*	6.285
	+ 13.62%	*	10.000	+				+			
	+ 10.20%	*	10.000	+	5.49%	*	-3.237	+	5.89%	*	0.000
	+ 6.45%	*	-2.046	+	8.49%	*	-6.841	+			
				+	7.00%	*	0.000				

<i>GPIP</i> =	-0.773	+	0.702	+	1.197
	+ 1.362	+	0.000	+	0.000
	+ 1.020	+	-0.178	+	0.000
	+ -0.132	+	-0.581	+	0.000
	+ 0.000	+	0.000		

GPIP = 2.617 POINTS

REWARD/PENALTY dollar amounts of the Generating Performance Incentive Factor (GPIF) are determined directly from the table for the corresponding Generating Performance Points (GPIP) on page 2.

GPIF REWARD = \$1,439,819

DOCKET NO. 070001-EI
GPIF 2006 ACTUAL UNIT
PERFORMANCE DATA
EXHIBIT DRK-1, DOCUMENT 2

EXHIBIT TO THE TESTIMONY OF
DAVID R. KNAPP

DOCKET NO. 070001-EI

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE FACTOR
JANUARY 2006 - DECEMBER 2006
TRUE-UP

DOCUMENT NO. 2

ACTUAL UNIT PERFORMANCE DATA

ORIGINAL SHEET NO. 8.401.06A
 TAMPA ELECTRIC COMPANY

ACTUAL UNIT PERFORMANCE DATA

JANUARY 2006 - DECEMBER 2006

PLANT/UNIT	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	PERIOD
	JAN 06	FEB 06	MAR 06	APR 06	MAY 06	JUN 06	JUL 06	AUG 06	SEP 06	OCT 06	NOV 06	DEC 06	DEC 06	DEC 06	DEC 06	DEC 06	2006
BIG BEND 1																	
1. EAF (%)	73.4	51.1	75.3	85.6	64.2	71.3	64.0	47.7	78.4	15.5	0.0	36.6					55.2
2. PH	744	672	744	719	744	720	744	744	720	745	720	744					8,760
3. SH	699.2	452.6	637.7	719.0	577.4	648.9	611.1	474.1	720.0	146.3	0.0	317.5					6,003.9
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0					0.0
5. UH	44.8	219.4	106.3	0.0	166.7	71.1	132.9	269.9	0.0	598.7	720.0	426.5					2,756.1
6. POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	598.7	720.0	302.7					1,621.4
7. FOH	16.8	123.0	106.3	0.0	166.7	71.1	7.8	269.9	0.0	0.0	0.0	123.8					885.3
8. MOH	28.0	96.4	0.0	0.0	0.0	0.0	125.1	0.0	0.0	0.0	0.0	0.0					249.5
9. PFOH	671.0	442.3	631.6	661.0	530.9	594.7	543.0	429.2	661.0	141.3	0.0	304.9					5,610.9
10. LR PF (MW)	82.6	96.4	48.1	45.2	57.5	68.0	68.2	85.1	72.2	80.8	0.0	61.0					67.8
11. PMOH	32.6	10.4	6.1	63.0	46.4	54.1	68.2	44.9	59.0	5.1	0.0	0.0					389.7
12. LR PM (MW)	231.0	211.1	248.5	203.2	227.8	282.7	272.3	278.6	276.1	272.4	0.0	0.0					253.1
13. NSC (MW)	411	411	411	411	411	411	411	411	411	411	411	411					411
14. OPR BTU(GBTU)	2,179.8	1,408.3	2,305.9	2,689.6	2,081.6	2,150.7	2,047.0	1,579.4	2,474.5	525.9	0.0	1,156.3					20,599.1
15. NET GEN (MWH)	203,426	128,337	213,552	241,557	185,664	196,328	181,812	137,553	219,697	46,321	0	106,667					1,860,915
16. ANOHR (BTU/KWH)	10,715	10,974	10,798	11,135	11,212	10,955	11,259	11,482	11,263	11,353	0	10,840					11,069
17. NOF (%)	70.8	69.0	81.5	81.7	78.2	73.6	72.4	70.6	74.2	77.0	0.0	81.7					75.4
18. NPC (MW)	411	411	411	411	411	411	411	411	411	411	411	411					411

ORIGINAL SHEET NO. 8.401.06A
TAMPA ELECTRIC COMPANY

ACTUAL UNIT PERFORMANCE DATA

JANUARY 2006 - DECEMBER 2006

PLANT/UNIT	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	PERIOD
BIG BEND 2	JAN 06	FEB 06	MAR 06	APR 06	MAY 06	JUN 06	JUL 06	AUG 06	SEP 06	OCT 06	NOV 06	DEC 06	2006
1. EAF (%)	93.1	84.8	91.4	69.6	92.2	75.2	96.2	92.0	51.2	77.9	72.4	95.8	82.8
2. PH	744	672	744	719	744	720	744	744	720	745	720	744	8,760
3. SH	744.0	584.4	744.0	582.0	736.2	584.3	744.0	732.2	506.1	745.0	554.8	744.0	8,001.1
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5. UH	0.0	87.6	0.0	137.0	7.8	135.7	0.0	11.8	213.9	0.0	165.2	0.0	758.9
6. POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7. FOH	0.0	0.0	0.0	0.0	7.8	135.7	0.0	11.8	213.9	0.0	165.2	0.0	534.3
8. MOH	0.0	87.6	0.0	137.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	224.6
9. PFOH	352.3	577.8	548.3	575.7	730.6	296.6	160.4	620.0	506.1	736.1	549.8	421.2	6,074.8
10. LR PF (MW)	54.8	7.7	37.1	52.7	25.6	56.2	39.6	30.0	106.1	85.8	24.0	28.8	45.6
11. PMOH	391.3	6.6	18.9	6.3	5.6	0.0	20.5	0.0	0.0	7.8	0.0	0.0	457.1
12. LR PM (MW)	2.3	198.5	245.3	228.9	162.1	0.0	235.9	0.0	0.0	152.6	0.0	0.0	33.3
13. NSC (MW)	391	391	391	391	391	391	391	391	391	391	391	391	391
14. OPR BTU(GBTU)	2,574.1	2,220.4	2,597.9	1,943.6	2,703.5	2,169.1	2,838.4	2,775.7	1,514.6	2,327.5	2,024.6	2,664.3	28,353.8
15. NET GEN (MWH)	252,579	216,742	254,463	188,185	262,277	207,185	273,031	260,943	142,137	220,423	195,720	253,907	2,727,592
16. ANOHR (BTU/KWH)	10,191	10,245	10,209	10,328	10,308	10,470	10,396	10,637	10,656	10,559	10,344	10,493	10,395
17. NOF (%)	86.8	94.8	87.5	82.7	91.1	90.7	93.9	91.1	71.8	75.7	90.2	87.3	87.2
18. NPC (MW)	391	391	391	391	391	391	391	391	391	391	391	391	391
19. ANOHR EQUATION	ANOHR = NOF(-12.783) + 11,130												

42

ORIGINAL SHEET NO. 8.401.06A
 TAMPA ELECTRIC COMPANY

ACTUAL UNIT PERFORMANCE DATA

JANUARY 2006 - DECEMBER 2006

PLANT/UNIT	JAN 06	FEB 06	MAR 06	APR 06	MAY 06	JUN 06	JUL 06	AUG 06	SEP 06	OCT 06	NOV 06	DEC 06	PERIOD
BIG BEND 3													2006
1. EAF (%)	78.7	77.2	79.6	1.2	63.7	65.6	63.0	51.3	76.9	49.4	81.4	56.4	61.9
2. PH	744	672	744	719	744	720	744	744	720	745	720	744	8,760
3. SH	716.3	672.0	741.4	23.3	603.9	562.5	580.5	503.8	693.9	517.0	670.5	624.4	6,909.5
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5. UH	27.7	0.0	2.6	695.7	140.1	157.5	163.5	240.2	26.1	228.0	49.5	119.6	1,850.5
6. POH	0.0	0.0	0.0	695.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	695.7
7. FOH	27.7	0.0	2.6	0.0	140.1	157.5	163.5	46.8	26.1	122.8	49.5	119.6	856.1
8. MOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	193.5	0.0	105.3	0.0	0.0	298.7
9. PFOH	663.9	608.5	695.0	22.0	588.5	548.5	571.3	487.8	666.6	513.4	648.3	624.4	6,638.1
10. LR PF (MW)	68.0	86.4	78.8	255.1	85.6	63.1	78.1	94.5	77.7	119.9	48.5	141.9	85.4
11. PMOH	52.4	63.5	44.0	1.3	15.4	14.0	9.3	16.0	27.3	0.0	22.2	0.0	265.3
12. LR PM (MW)	219.1	218.2	223.1	375.5	219.4	199.8	167.5	284.2	231.5	0.0	160.5	0.0	217.8
13. NSC (MW)	433	433	433	414	414	414	414	414	414	414	414	433	420
14. OPR BTU(GBTU)	2,412.5	2,326.0	2,519.5	36.5	1,972.2	1,988.5	2,064.2	1,669.3	2,388.7	1,617.2	2,391.8	1,926.5	23,313.0
15. NET GEN (MWH)	225,773	214,486	233,956	3,461	184,588	185,392	189,783	150,751	218,934	147,686	227,275	173,066	2,155,150
16. ANOHR BTU/KWH	10,686	10,844	10,769	10,550	10,685	10,726	10,877	11,073	10,911	10,950	10,524	11,132	10,817
17. NOF (%)	72.8	73.7	72.9	35.9	73.8	79.6	79.0	72.3	76.2	69.0	81.9	64.0	74.2
18. NPC (MW)	433	433	433	414	414	414	414	414	414	414	414	433	420
19. ANOHR EQUATION	ANOHR = NOF(-42.211) + 13,320												

ORIGINAL SHEET NO. 8.401.06A
 TAMPA ELECTRIC COMPANY

ACTUAL UNIT PERFORMANCE DATA

JANUARY 2006 - DECEMBER 2006

PLANT/UNIT	JAN 06	FEB 06	MAR 06	APR 06	MAY 06	JUN 06	JUL 06	AUG 06	SEP 06	OCT 06	NOV 06	DEC 06	PERIOD
BIG BEND 4													2006
1. EAF (%)	83.4	31.9	52.4	93.8	76.1	85.7	73.5	85.6	83.1	85.2	59.5	82.5	74.7
2. PH	744	672	744	719	744	720	744	744	720	745	720	744	8,760
3. SH	671.0	240.3	414.3	719.0	655.8	720.0	663.2	744.0	699.4	743.8	464.8	673.3	7,408.7
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5. UH	73.0	411.3	329.7	0.0	88.2	0.0	80.8	0.0	20.6	1.2	255.3	70.7	1,330.9
6. POH	0.0	411.3	317.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	728.3
7. FOH	72.5	0.0	12.8	0.0	88.2	0.0	80.8	0.0	20.6	1.2	255.3	70.7	602.1
8. MOH	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5
9. PFOH	485.9	240.3	327.3	686.3	635.9	666.7	593.9	683.0	635.7	709.0	464.8	673.3	6,802.0
10. LR PF (MW)	39.6	89.0	32.7	24.7	55.1	47.1	54.2	43.9	42.5	55.4	35.6	40.7	45.2
11. PMOH	14.1	0.0	3.6	32.2	19.9	49.4	69.3	61.0	63.7	34.9	0.0	0.0	348.0
12. LR PM (MW)	289.9	0.0	196.8	110.8	302.0	315.2	304.1	309.2	300.8	302.3	0.0	0.0	286.1
13. NSC (MW)	462	462	462	457	457	457	457	457	457	457	457	462	459
14. OPR BTU(GBTU)	2,761.8	889.7	1,671.7	3,126.5	2,528.3	2,734.2	2,498.5	3,004.7	2,756.8	2,964.1	2,001.5	2,909.5	29,847.2
15. NET GEN (MWH)	251,103	72,670	151,694	287,968	228,884	247,663	215,560	266,512	243,347	270,241	180,613	260,905	2,677,159
16. ANOHR BTU/KWH	10,999	12,243	11,020	10,857	11,046	11,040	11,591	11,274	11,329	10,968	11,082	11,152	11,149
17. NOF (%)	81.0	65.4	79.3	87.6	76.4	75.3	71.1	78.4	76.1	79.5	85.0	83.9	78.8
18. NPC (MW)	462	462	462	457	457	457	457	457	457	457	457	462	459
19. ANOHR EQUATION	ANOHR = NOF(-32.626) + 12,906												

ORIGINAL SHEET NO. 8.401.06A
TAMPA ELECTRIC COMPANY

ACTUAL UNIT PERFORMANCE DATA

JANUARY 2006 - DECEMBER 2006

PLANT/UNIT	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	PERIOD
POLK 1	JAN 06	FEB 06	MAR 06	APR 06	MAY 06	JUN 06	JUL 06	AUG 06	SEP 06	OCT 06	NOV 06	DEC 06	2006
1. EAF (%)	91.2	93.8	94.9	38.6	10.8	95.9	90.2	95.9	87.6	69.5	94.2	83.8	78.8
2. PH	744	672	744	719	744	720	744	744	720	745	720	744	8,760
3. SH	667.8	637.8	744.0	290.3	84.8	709.9	692.6	744.0	667.2	576.8	666.6	659.3	7,141.0
4. RSH	21.5	32.6	0.0	5.3	0.0	0.0	32.3	0.0	0.0	0.0	53.3	0.0	145.0
5. UH	54.7	1.5	0.0	423.4	659.2	10.1	19.2	0.0	52.8	168.2	0.1	84.8	1,474.0
6. POH	0.0	0.0	0.0	423.4	612.0	0.0	19.2	0.0	0.0	0.0	0.0	0.0	1,054.6
7. FOH	0.0	1.5	0.0	0.0	47.3	10.1	0.0	0.0	1.7	168.2	0.1	1.4	230.2
8. MOH	54.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	51.1	0.0	0.0	83.4	189.2
9. PFOH	0.9	124.8	353.4	30.1	37.0	271.0	745.8	767.0	681.2	698.9	304.8	659.9	4,674.7
10. LR PF (MW)	63.9	83.3	28.0	77.2	30.8	18.0	18.4	10.1	13.6	21.5	34.6	14.2	20.2
11. PMOH	34.6	0.0	0.0	138.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	173.1
12. LR PM (MW)	80.0	0.0	0.0	16.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	29.0
13. NSC (MW) **	260	260	260	255	255	255	255	255	255	255	255	260	257
14. OPR BTU(GBTU)	1,617.2	1,560.8	1,566.6	655.8	192.0	1,765.8	1,612.9	1,794.5	1,530.3	1,237.1	1,482.5	1,624.8	16,640.3
15. NET GEN (MWH)	161,559	151,558	161,152	57,549	6,863	168,182	148,918	177,075	147,837	107,989	147,130	153,026	1,588,838
16. ANOHR BTU/KWH	10,010	10,298	9,721	11,396	27,982	10,499	10,831	10,134	10,351	11,456	10,076	10,618	10,473
17. NOF (%)	93.1	91.4	83.3	77.7	31.7	92.9	84.3	93.3	86.9	73.4	86.6	89.3	86.7
18. NPC (MW) **	260	260	260	255	255	255	255	255	255	255	255	260	257
19. ANOHR EQUATION	ANOHR = NOF(-8.7647) + 11,223												

45