

ORIGINAL

Timolyn Henry

From: Trina Collins [TCollins@RSBattorneys.com]
Sent: Friday, May 25, 2007 3:38 PM
To: Filings@psc.state.fl.us
Cc: Trina Collins; Martin Friedman
Subject: Filing in Docket No.: 060726-WS; Application of Silver Lake Utilities, Inc. to Operate a Water and Wastewater Utility
Importance: High
Attachments: PSC Clerk 10 (Response to Data Request 1) 05-25-2007.pdf

- a. Martin S. Friedman, Esquire
Rose, Sundstrom & Bentley, LLP
2180 W. State Road 434, Suite 2118
Longwood, FL 32779
PHONE: (407) 830-6331
mfriedman@rsbattorneys.com
- b. In re: Application of Silver Lake Utilities, Inc., to Operate a Water Utility in Glades and Highlands Counties, Florida, and a Wastewater Utility in Glades County, Florida. Docket No.: 060726-WS
- c. Silver Lake Utilities, Inc.
- d. 18 pages
- e. 6 page cover letter to PSC Clerk, 12 pages of Schedules.

DOCUMENT NUMBER-DATE

04354 MAY 25 05

FPSC-COMMISSION CLERK

5/25/2007

ORIGINAL

LAW OFFICES
ROSE, SUNDSTROM & BENTLEY, LLP
2548 BLAIRSTONE PINES DRIVE
TALLAHASSEE, FLORIDA 32301

FREDERICK L. ASCHAUER, JR.
CHRIS H. BENTLEY, P.A.
ROBERT C. BRANNAN
F. MARSHALL DETERDING
JOHN R. JENKINS, P.A.
KYLE L. KEMPER
STEVEN T. MINDLIN, P.A.
CHASITY H. O'STEEN
DAREN L. SHIPPY
WILLIAM E. SUNDSTROM, P.A.
DIANE D. TREMOR, P.A.
JOHN L. WHARTON
ROBERT M. C. ROSE (1924-2006)

(850) 877-6555
FAX (850) 656-4029
www.rsbatorneys.com

CENTRAL FLORIDA OFFICE
SANLANDO CENTER
2180 W. STATE ROAD 434, SUITE 2118
LONGWOOD, FLORIDA 32779
(407) 830-6331
FAX (407) 830-8522

REPLY TO CENTRAL FLORIDA OFFICE

MARTIN S. FRIEDMAN, P.A.
VALERIE L. LORD
BRIAN J. STREET

May 25, 2007

E-FILING

Ann Cole, Commission Clerk
Office of Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, FL 32399

RE: Docket No.: 060726-WS; Application of Silver Lake Utilities, Inc., to Operate a Water Utility in Glades and Highlands Counties, Florida, and a Wastewater Utility in Glades County, Florida
Our File No.: 40001.01

Dear Ms. Cole:

The following are the Utility's responses to Staff's First Data Request dated May 9, 2007:

Existing Water System

1. Can the utility provide evidence to show that the existing facilities were not costed off on the Lykes Bros. income tax?

RESPONSE: The Utility cannot provide evidence to show that the existing facilities were not costed off on the Lykes Bros. tax returns. The Utility cannot specifically identify any of the water assets since they are a part of larger projects. It is Lykes Bros.' policy to capitalize such fixed assets.

2. Staff cannot determine the reasonableness of the plant items in the format given. For each system, can the utility provide a schedule which identifies plant items by NARUC account number, short description, type of unit, number of units, cost per unit, and total costs? For instance:

<u>Acct. No.</u>	<u>Description</u>	<u>Unit</u>	<u>No. of Units</u>	<u>Unit Cost</u>	<u>Total Cost</u>
370	Lift Station	Each	20	\$20,000	\$400,000
xxxx	3" Lateral	Linear Ft.	2,000	\$ 100	\$ 20,000

DOCUMENT NUMBER-DATE

04354 MAY 25 5

FPSC-COMMISSION CLERK

(Note: The data needed is similar to that provided on Schedule F-5. However, staff could not verify the unit cost from that or any other schedule).

RESPONSE: The cost estimates are preliminary and based on a conceptual design at a planning level, and as such, it is difficult to provide a detailed estimate. However, Johnson Engineering, Inc. has attempted to provide further detail of the estimates. While revisiting the cost estimates, five items were found in need of revised cost estimates based on current trends and additional evaluation performed since the original estimate was prepared, as reflected in the original submittal to the PSC. Please see Schedule 2 attached hereto for revised and more detailed cost estimates. See, Note below regarding rate impact.

Injection Wells

3. Can the utility provide recent water quality analysis for the Muse which includes the mg/l of total dissolved solids (TDS)?

RESPONSE: In 2006, a suite of water quality analyses was performed on two wells open to the Floridan aquifer located less than a mile from the proposed Muse Village utility site. Results from these analyses showed TDS of 920 and 956 mg/L and specific conductance values of 1,632 and 1,754 umohs/cm, respectively. Other Floridan aquifer wells in the area report similar ratios of TDS to specific conductance. Specific conductance value measured at the Muse Village Floridan aquifer test well was 1,749 umohs/cm following the completion of a 72-hour aquifer performance test. Based on the relationship between specific conductance and TDS established for this site, the Floridan aquifer test well has a TDS concentration of approximately 960 mg/L.

4. Can the utility provide information, such as engineering analysis, that shows that deep well injection is the least-cost alternative for disposal of brine concentrate and excess effluent?

RESPONSE: An engineering analysis of least-cost alternatives for disposal of brine concentrate and excess effluent has not been performed. Deep well injection is common practice. North Fort Myers Utility, City of Clewiston, Bonita Springs Utilities, Island Water Association, Greater Pine Island Water Association and Lee County Utilities have one or more injection wells in operation. Additionally, the City of LaBelle's Capital Improvement Plan includes an injection well and Town and County Utilities Company proposes to use a deep injection well as described in the publicly available Application for Master

Development Approval for the Babcock Ranch Community. The deep injection well method of disposal was not chosen on the basis of cost, but rather on the provision of permitting ability. Deep injection wells are favorably looked upon by FDEP rather than surface water, land application or shallow aquifer disposal mechanisms.

5. As staff understands it, the utility intends to construct two deep injection wells. One for bulk treated water and one for the Muse Development treated water and excess wastewater effluent disposal. Staff can see some breakdown in injection well costs in wastewater and bulk water. However, it is not broken out for potable water. Can the utility provide a complete breakdown of costs for the injection wells and the percentage assigned to each system?

RESPONSE: As originally submitted, the injection well cost was associated with the wastewater treatment facility. Both the water and wastewater facilities need the deep injection well on an equal basis to meet regulatory requirements so therefore cost has now been allocated on a 50/50 basis. See, Schedule 2 attached hereto. See, Note below regarding rate impact.

Reuse Irrigation

It is staff's understanding that the utility is using 250 gpd for water usage because irrigation from reuse will be available. As such, the utility is constructing facilities capable of providing high quality reuse and storage. It is also staff's understand that irrigation services are not included in the application because the service will be provided by the parent as an exempt service.

5. Please provide the rate the utility intends to charge the parent to purchase reuse from its facilities. Also, please provide a schedule which shows how the customers' rates have been offset by the proceeds from those sales.

RESPONSE: The Utility intends to charge \$0.05 per thousand for reuse water. See, Note below regarding rate impact.

Rate Structure

6. The utility has requested a two-tiered gallonage rate for potable water for the Muse Development. Since there is no historical data, what is the basis of the

utility's request and how was the 5kgal break point selected?

RESPONSE: Using 250 gpd average monthly usage equals 7,604 gallons per month. Using a 5,000 gallon breakpoint represents approximately 70% of the usage to be included in the first block.

7. If the rate structure was recommended by the local WMD, did the utility request a temporary pass on the IBRS for 12 to 24 months in favor of a uniform gallonage charge until historical data can be obtained?

RESPONSE: No. The Utility has requested an inclining block rate structure consistent with conservation goals in rate making.

Leases and Royalties

The application contains a proposed lease with Lykes Bros., Inc. for royalties of \$.20 per kgal for water withdrawn and \$1,000 per year rental for each lease site. It is staff's understanding that this was based on the amount approved for Town and Country in 1998. However, the most recent royalties approved for inclusion in rate base by the Commission were \$.10 for Farmton in 2002 and D & E in 2006.

8. The details in Appendix A to the engineering report, appear to be for 22 existing wells and 7 wells owned by the Seminole Indians. Please confirm the total number of well sites, both existing and proposed.

RESPONSE: Silver Lake Utilities currently has 22 existing wells and uses water from 7 bulk water connections with the Seminole Tribe potable water system. The bulk water connections are not well sites; they are tie-in points to the Seminole Tribe mainline running parallel with CR-721.

The Utility proposes a total of 7 new wells: 3 potable supply wells to serve the Muse Village development, 2 proposed wells to provide raw bulk water service, and 2 proposed wells to provide treated bulk water service.

9. Given the poor quality of water, can the utility justify the amount of the proposed royalty?

RESPONSE: Water quality data submitted in support of a South Florida Water Management District (SFWMD) water use permit application for Town and Country Utilities Company (SFWMD #060724-8) show similar water quality for the Floridan aquifer as that encountered at Muse Village. The PSC approved a rate based on a \$0.20/1,000 gallon royalty for Town and Country Utilities Company. Please refer to the Town and Country Utilities Company water quality data, which is attached hereto as Schedule 9. Additional information will be forthcoming.

10. The most recently approved well site leases for the Farmton and D&E were for \$100 per year, which is \$900 less than Lykes Bros., Inc. is proposing to charge. As such, leases are over 20% of the O&M for the existing systems. Can the utility justify the proposed lease cost?

RESPONSE: Yes, additional information will be forthcoming.

Salaries and Wages

11. Since the Utility is proposing to contract out some of its duties, can the utility provide a schedule for each service which shows the duties that are intended to be performed under salary and wages, verses contract costs, along with the total man-hours and hourly rate?

RESPONSE: See Schedule 11 attached hereto.

Meters

12. Can the utility provide the justification for the \$300 cost for 5/8" x 3/4" meter?

RESPONSE: Schedule C-6 (P.19) of the Special Report attached to the Application as Exhibit "E" provides that cost breakdown. The Utility will be installing electronic meters similar to those being utilized by O & S Water Company, Inc. A \$300.00 meter installation fee was approved for that type of meter in Order No. PSC-03-1474-TRF-WU. The cost breakdown for the meters the Utility proposes to install are substantially the same as those approved in that Order.

13. Can the utility provide cost justification for the other meter sizes?

Ann Cole, Commission Clerk
Office of Commission Clerk
Florida Public Service Commission
May 25, 2007
Page 6

RESPONSE: As is commonplace, the cost for meters larger than 5/8" x 3/4" will be actual cost.

14. Have the existing customers paid for meters?

RESPONSE: No. There are no existing meters.

Customer Deposits


15. Deposits. Since the utility has requested a late payment fee, can it provide the reason it did not request customer deposits?

RESPONSE: The Utility will amend its Application to include a request for customer deposits of twice an average monthly bill, once the initial rates have been established.

NOTE: The Utility next week will file revised revenue requirements and rates incorporating the more updated information provided herein.

Please contact me if you have any questions.

Very truly yours,



MARTIN S. FRIEDMAN
For the Firm

MSF/tlc
Enclosures

cc: Charles P. Lykes, Jr., Executive Vice President (w/enclosures - via U.S. Mail)
Frederick J. Bennett, Vice President & CFO (w/enclosures - via U.S. Mail)
Mr. Joe Collins (w/enclosures - via U.S. Mail)
Cari Lynn Roth, Esquire (w/enclosures - via U.S. Mail)
Lonnie Howard, P.E. (w/enclosures - via U.S. Mail)
Robert C. Nixon, CPA (w/enclosures - via U.S. Mail)
Ms. Patti Daniel, Division of Economic Regulation (w/enclosures - via U.S. Mail)
Mr. Richard Redemann, Division of Economic Regulation (w/enc. - via U.S. Mail)
Ms. Pat Brady, Division of Economic Regulation (w/enclosures - via U.S. Mail)

Schedule 2 Supplemental Cost Estimate Information

Johnson Engineering, Inc. has prepared a brief cost estimate for the utility systems described within Exhibit B, Application For An Initial Certification Of Authorization Before the Florida Public Service Commission Engineering Report, to provide further detail of the cost estimates. Five costs have been revised since the original application and are noted along side the revised cost estimate.

The cost estimates are based on conceptual planning level design. The costs are based on local knowledge and experience in Southwest Florida.

Muse Village Wastewater	Item	Quantity	Unit Cost	Extended Cost
Wastewater Treatment Plant				
	380 Headworks - Structure & Mechanical Bar Screen			\$767,724
	354 Flow Equalization Facilities			\$1,011,194
	380 Closed Loop Reactor/Clarifier w/ tanks, walkway, equipment			\$3,252,799
	380 Aerobic Digestors			\$365,672
	380 ABW Effluent Polishing Filters			\$1,565,299
	380 Chlorination Facilities, Tanks, Equipment			\$629,664
	370 Plant Site Lift Station			\$430,037
	354 Site Work			\$298,974
	380 Substandard Storage Pond			\$298,974
	380 Wet Weather Storage Pond			\$573,694
	354 Miscellaneous, Driveway, Fence, Seeding, Monitoring Wells, Control/Lab Building, Site Lighting, Engine-Gen, etc			\$1,805,970
	Total			\$11,000,000
Master Wastewater Pump Stations - each				
	371 Pumps (2 - 700gpm pumps and one low flow jockey pump)	3	\$187,500	\$562,500
	354 Concrete Wetwell	3	\$437,500	\$1,312,500
	380 Odor Control System	3	\$187,500	\$562,500
	355 Generator	3	\$187,500	\$562,500
	381 Piping	3	\$125,000	\$375,000
	339 Telemetry / SCADA Controls	3	\$125,000	\$375,000
	354 Electrical	3	\$125,000	\$375,000
	Total		\$1,375,000	\$4,125,000
	360 Spine Wastewater Force Mains - LF	27,000	\$69	\$1,866,400

Muse Village Injection Well	Item	Quantity	Unit Cost	Extended Cost
Deep Injection Well				
	380/339 Tubing & Packer Injection Well			\$3,875,000
	380/339 Monitor Well			\$1,000,000
	380/339 Well Heads, Piping, Monitoring Equipment			\$125,000
	Total			\$5,000,000
	339 Percent of cost associated with Potable Water - 50%			
	340 Percent of cost associated with Wastewater - 50%			

Muse Village Potable Water

Item	Quantity	Unit Cost	Extended Cost
------	----------	-----------	---------------

Water Treatment Plant

309	Raw Water Main/Yard Appurtenances		\$222,531
320	Pretreatment Facilities - Mixer, Micron Filters		\$257,302
309	RO Trains w/ Feed Pump Unit		\$1,466,968
320	Chemical Feed Facilities, Caustic, Anti-scalant		\$260,779
320	Post Treatment - Clearwell, Degasifier, Transfer Pumps, Electrical		\$1,049,896
311	High Service Pumping Units		\$232,962
310	Miscellaneous Electrical Power, Instrumentation, Lighting, HVAC, Engine-Gen, CIP Tanks		\$785,814
320	Hypochlorite Storage Feed Systems		\$90,403
330	Water Storage Tanks		\$1,157,858
309	Yard Piping, Valves, etc.		\$295,376
304	Building - Process Office, Lab		\$1,161,335
304	Outside Electrical		\$69,541
304	Injection Pump Station, Surface Facilities, Controls and Valves		\$177,330
304	Site Work		\$271,905

Total \$7,500,000
Previously Submitted \$10,500,000

Potable Wells

307	Well - each	3	\$312,500	\$937,500
311	Pump/Controls - each	3	\$81,250	\$243,750
309	Discharge Head/Piping - each	3	\$31,250	\$93,750
310	Backup Power - each	3	\$50,000	\$150,000
339	SCADA - each	3	\$25,000	\$75,000

Total \$500,000 \$1,500,000

309	Potable Raw Water Transmission Pipeline - LF	5,000	\$37	\$183,750
331	Spine Potable Water Mains - LF	46,000	\$86	\$3,942,038

0.5 MGD Bulk Raw Water

Item	Quantity	Unit Cost	Extended Cost
------	----------	-----------	---------------

Potable Wells

307	Well - each	2	\$343,750	\$687,500
311	Pump/Controls - each	2	\$81,250	\$162,500
309	Discharge Head/Piping - each	2	\$31,250	\$62,500
310	Backup Power - each	2	\$50,000	\$100,000
339	SCADA - each	2	\$25,000	\$50,000

Total \$531,250 \$1,062,500


309	Raw Water Supply Line - LF	17,633	\$38	\$661,250
-----	----------------------------	--------	------	-----------

304	Access Road (Limerock Road) - LF	4,752	\$28	\$130,680
			Previously Submitted	\$59,400

Item		Quantity	Unit Cost	Extended Cost
0.35 MGD Bulk Treated Water				
0.35 MGD Bulk Water Treatment Plant				
309	Raw Water Main/Yard Appurtenances			\$79,696
320	Pretreatment Facilities - Mixer, Micron Filters			\$92,149
309	RO Trains w/ Feed Pump Unit			\$498,340
320	Chemical Feed Facilities, Caustic, Anti-scalant			\$93,394
320	Post Treatment - Clearwell, Degasifier, Transfer Pumps, Electrical			\$331,238
311	High Service Pumping Units			\$270,932
310	Miscellaneous Electrical Power, Instrumentation, Lighting, HVAC, Engine-Gen, CIP Tanks			\$281,428
320	Hypochlorite Storage Feed Systems			\$32,377
309	Yard Piping, Valves, etc.			\$164,670
304	Building - Process Office, Lab			\$415,916
304	Outside Electrical			\$24,905
304	Injection Pump Station, Surface Facilities, Controls and Valves			\$63,508
304	Site Work			\$276,447
Total				\$2,625,000
		Previously Submitted		\$5,625,000
Storage and pump station				
330	0.175 Above Ground Storage Reservoir	1	\$437,500	\$437,500
311	Pump Station	1	\$125,000	\$125,000
Total			\$562,500	\$562,500
		Previously Submitted		\$1,468,750
Deen Injection Well				
307	Tubing & Packer Injection Well			\$3,875,000
339	Monitor Well			\$1,000,000
307	Well Heads, Piping, Monitoring Equipment			\$125,000
Total				\$5,000,000
Potable Wells				
307	Well - each	2	\$343,750	\$687,500
311	Pump/Controls - each	2	\$81,250	\$162,500
309	Discharge Head/Piping - each	2	\$31,250	\$62,500
310	Backup Power - each	2	\$50,000	\$100,000
339	SCADA - each	2	\$25,000	\$50,000
Total			\$531,250	\$1,062,500
309	Raw Water Supply Line - LF	2,640	\$31	\$82,500
304	Access Road (Limerock Road) - LF	4,752	\$28	\$130,680
		Previously Submitted		\$59,400
331	Treated Water Distribution Line - LF	15,000	\$31	\$468,750

All costs presented above are in 2006 dollars and include 25% contingency. The costs do not include engineering and permitting fees. Engineering, design, and permitting fees are estimated to be 12% of construction costs, not including construction services.

BENCHMARK
EnviroAnalytical Inc.



NELAC Certification # E84167

ANALYTICAL TEST REPORT
 THESE RESULTS MEET NELAC STANDARDS

Submission Number : 6090160

Johnson Engineering, Inc.
 2158 Johnson Street
 Fort Myers, FL 33901

Project Name : 20066400-01
Date Received : 09/07/2006
Time Received : 1430

Tim Denison

Submission Number 6090160

Sample Number: 1A **Sample Description:** S P L H / Field
Sample Date: 09/06/2006 **Sample Method:** Grab
Sample Time: 1033

Parameter	Result	Units	MDL	PQL	Procedure	Analysis		Analyst
						Date	Time	
PH	7.55	UNITS	0.1	0.4	150.1	09/06/2006	10:33	JOHN INC
TEMPERATURE	29.0	DEG C.	0.1	0.4	170.1	09/06/2006	10:33	JOHN INC
SPECIFIC CONDUCTANCE, FIELD	1619	UMHOS	1.24	4.96	SM2510B	09/06/2006	10:33	JOHN INC
DISSOLVED OXYGEN	3.75	MG/L	0.05	0.20	SM4500 OC	09/06/2006	10:33	JOHN INC

Submission Number 6090160


Sample Number: 1B **Sample Description:** S P L H / Lab
Sample Date: 09/06/2006 **Sample Method:** Grab
Sample Time: 1040

Parameter	Result	Units	MDL	PQL	Procedure	Analysis		Analyst
						Date	Time	
COLOR	5 U	PCU	5	20	110.2	09/07/2006	10:00	JS
PH	7.94	UNITS	0.1	0.4	150.1	09/07/2006	17:00	JSM
TOTAL DISSOLVED SOLIDS	916	MG/L	7.26	29.04	160.1	09/12/2006		CB
TURBIDITY	0.05 U	NTU	0.05	0.20	180.1	09/08/2006	14:25	DS
BARIUM	11.7	UG/L	2	8	200.7	09/11/2006		RCB
CALCIUM	38.5	MG/L	0.03	0.12	200.7	09/11/2006		RCB
IRON	29 U	UG/L	29	116	200.7	09/11/2006		RCB
MAGNESIUM	42.0	MG/L	0.006	0.024	200.7	09/11/2006		RCB

1711 12th Street East * Palmetto, FL 34221 * Phone (941) 723-9986 * Fax (941) 723-6061

BENCHMARK

EnviroAnalytical Inc.



NELAC Certification # E84167

MANGANESE	0.98 U	UG/L	0.98	3.92	200.7	09/11/2006	RCB
POTASSIUM	13.0	MG/L	0.169	0.676	200.7	09/11/2006	RCB
SODIUM	194	MG/L	0.034	0.136	200.7	09/11/2006	RCB
STRONTIUM	3.98	MG/L	0.001	0.004	200.7	09/11/2006	RCB
CHLORIDE	229	MG/L	0.353	1.412	300.0	09/12/2006	TDT
FLUORIDE	1.90	MG/L	0.030	0.120	300.0	09/12/2006	TDT
SULFATE	247	MG/L	0.339	1.356	300.0	09/13/2006	TDT
AMMONIA NITROGEN	0.006 U	MG/L	0.006	0.024	350.2		
NITRATE NITROGEN	0.004 U	MG/L	0.004	0.016	353.2	09/07/2006	17:33 JSM
NITRATE+NITRITE	0.004 U	MG/L	0.004	0.016	353.2	09/08/2006	CB
TOTAL PHOSPHORUS	0.002 U	MG/L	0.002	0.008	365.3		
SILICA	14.3	MG/L	0.044	0.176	370.1	09/22/2006	YW
UNIONIZED HYDROGEN SULFIDE	0.328	MG/L	0.005	0.020	CALC.	09/28/2006	RBK
BICARBONATE ALKALINITY	144	MG/L	0.594	2.376	SM2320B	09/08/2006	DS
CARBONATE ALKALINITY	0.594 U	MG/L	0.594	2.376	SM2320B	09/08/2006	DS
TOTAL ALKALINITY	144	MG/L	0.594	2.376	SM2320B	09/08/2006	DS
SPECIFIC CONDUCTANCE	1571	UMHOS/CM	1.24	4.96	SM2510B	09/08/2006	DS
NITRITE NITROGEN	0.003 U	MG/L	0.003	0.012	SM4500NO2B	09/07/2006	17:33 JSM
SULFIDE	1.91	MG/L	0.028	0.112	SM4500S2D	09/08/2006	RCB
TOTAL ORGANIC CARBON	0.271 U	MG/L	0.271	1.084	SM5310B	09/12/2006	TDT

Submission Number 6090160

Sample Number: 2A
 Sample Date: 09/06/2006
 Sample Time: N/A


Sample Description: H Q L H / Field
 Sample Method: Grab

Parameter	Result	Units	MDL	PQL	Procedure	Analysis		Analyst
						Date	Time	
PH	7.28	UNITS	0.1	0.4	150.1	09/06/2006		JOHN INC
TEMPERATURE	28.4	DEG C.	0.1	0.4	170.1	09/06/2006		JOHN INC
SPECIFIC CONDUCTANCE, FIELD	858	UMHOS	1.24	4.96	SM2510B	09/06/2006		JOHN INC
DISSOLVED OXYGEN	5.89	MG/L	0.05	0.20	SM4500 OC	09/06/2006		JONH INC

1711 12th Street East * Palmetto, FL 34221 * Phone (941) 723-9986 * Fax (941) 723-6061

BENCHMARK

EnviroAnalytical Inc.



NELAC Certification # E84167

Submission Number 6090160


Sample Number: 2B Sample Description: H Q L H / Lab
 Sample Date: 09/06/2006 Sample Method: Grab
 Sample Time: 1500

Parameter	Result	Units	MDL	PQL	Procedure	Analysis		Analyst
						Date	Time	
COLOR	5 U	PCU	5	20	110.2	09/07/2006	10:00	JS
PH	7.70	UNITS	0.1	0.4	150.1	09/07/2006	17:00	JSM
TOTAL DISSOLVED SOLIDS	512	MG/L	7.26	29.04	160.1	09/12/2006		CB
TURBIDITY	0.05 U	NTU	0.05	0.20	180.1	09/08/2006	14:25	DS
BARIUM	19.3	UG/L	2	8	200.7	09/11/2006		RCB
CALCIUM	43.5	MG/L	0.03	0.12	200.7	09/11/2006		RCB
IRON	29 U	UG/L	29	116	200.7	09/11/2006		RCB
MAGNESIUM	31.1	MG/L	0.006	0.024	200.7	09/11/2006		RCB
MANGANESE	0.98 U	UG/L	0.98	3.92	200.7	09/11/2006		RCB
POTASSIUM	7.03	MG/L	0.169	0.676	200.7	09/11/2006		RCB
SODIUM	79.4	MG/L	0.034	0.136	200.7	09/11/2006		RCB
STRONTIUM	3.94	UG/L	0.001	0.004	200.7	09/11/2006		RCB
CHLORIDE	71.6	MG/L	0.353	1.412	300.0	09/12/2006		TDT
FLUORIDE	1.30	MG/L	0.030	0.120	300.0	09/12/2006		TDT
SULFATE	66.4	MG/L	0.339	1.356	300.0	09/13/2006		TDT
AMMONIA NITROGEN	0.006 U	MG/L	0.006	0.024	350.2			
NITRATE NITROGEN	0.004 U	MG/L	0.004	0.016	353.2	09/07/2006	17:33	JSM
NITRATE+NITRITE	0.004 U	MG/L	0.004	0.016	353.2	09/08/2006		CB
TOTAL PHOSPHORUS	0.002 U	MG/L	0.002	0.008	365.3			
SILICA	39.1	MG/L	0.044	0.176	370.1	09/22/2006		YW
UNIONIZED HYDROGEN SULFIDE	1.79	MG/L	0.008	0.032	CALC.	09/28/2006		RBK
BICARBONATE ALKALINITY	230	MG/L	0.594	2.376	SM2320B	09/08/2006		DS
CARBONATE ALKALINITY	0.594 U	MG/L	0.594	2.376	SM2320B	09/08/2006		DS
TOTAL ALKALINITY	230	MG/L	0.594	2.376	SM2320B	09/08/2006		DS
SPECIFIC CONDUCTANCE	832	UMHOS/CM	1.24	4.96	SM2510B	09/08/2006		DS
NITRITE NITROGEN	0.003 U	MG/L	0.003	0.012	SM4500NO2B	09/07/2006	17:33	JSM
SULFIDE	6.20	MG/L	0.028	0.112	SM4500S2D	09/08/2006		RCB
TOTAL ORGANIC CARBON	2.76	MG/L	0.271	1.084	SM5310B	09/12/2006		TDT

1711 12th Street East * Palmetto, FL 34221 * Phone (941) 723-9986 * Fax (941) 723-6061

BENCHMARK

EnviroAnalytical Inc.



NELAC Certification # E84167

09/28/2006

Dale D. Dixon / Laboratory Director
Robert L. Sullivan / Laboratory Manager

Date

DATA QUALIFIERS THAT MAY APPLY:

- | | |
|---|--|
| A = Value reported is an average of two or more determinations. | N = Presumptive evidence of presence of material. |
| B = Results based upon colony counts outside the acceptable range. | Q = Sample held beyond accepted hold time. |
| H = Value based on field kit determination. Results may not be accurate. | T = Value reported is < MDL. Reported for informational purposes only and shall not be used in statistical analysis. |
| I = Reported value is between the laboratory MDL and the PQL. | U = Analyte analyzed but not detected at the value indicated. |
| J1 = Est. value surrogate recovery limits exceeded. | V = Analyte detected in sample and method blank. |
| J2 = Est. value. No quality control criteria exists for component. | Y = Analysis performed on an improperly preserved sample. Data may be inaccurate. |
| J3 = Est. value quality control criteria for precision or accuracy not met. | I = Data deviate from historically established concentration ranges. |
| J4 = Est. value. Sample matrix interference suspected. | ? = Data rejected and should not be used. Some or all of QC data were outside criteria, and the Presence or absence of the analyte cannot be determined from the data. |
| J5 = Est. value. Data questionable due to improper lab or field protocols | * = Not reported due to interference. |
| K = Off-scale low. Value is known to be < the value reported. | |
| L = Off-scale high. Value is known to be > the value reported | |

NOTES:

PQL = 4xMDL.

MBAS calculated as LAS; molecular weight = 348.

X = Value exceed MCL.

G = CBOD accuracy standard does not meet method QC criteria, but does not meet lab control limits that are in agreement with USEPA generated data. USEPA letter available upon request.

For questions and comments regarding these results, please contact Katharine Dixon at (941) 723-9986

Benchmark EnviroAnalytical, Inc.

1711 Twelfth Street East
 Palmetto, FL 34221
 (941) 723-986
 (941) 723-6061 fax
 BenchmarkEA@earthlink.net

Client: Johnson Engineering, Inc.

2158 Johnson Street
 Fort Myers, FL 33901
 (239) 461-2458 (Tim Denison)
 (239) 334-3661

A

Chain of Custody Form:
 Matrix: Groundwater

20066400-01

Laboratory Submission #:

6090160

Station ID	TDS SO ₄ Cl F T/B/C Alkalinity pH Cond. Color ntu Silica NO ₂	Total Fe (EPA 200.7) Ca, Mg, Na, K, Mn, Sr, Ba	TOC, NO ₃ -NO ₂ , NO ₃	Hydrogen Sulfide	Field Parameters Time: 1033 - SPLH							Laboratory Sample #
	(1)	(2)	(3)	(4)	Temp (° C)	Specific Conductance (µmhos)	pH (s.u.)	D.O. (mg/L)	H ₂ S	Turbidity (ntu)	T/B/C Alkalinity	
	Plain	1:4 HNO ₃ pH<2 □	1:4 H ₂ SO ₄ pH<2 □	ZnOAc NaOH								
	1 x 2 Quart	1x 1 Pint Plastic	1 x 1 Quart	1x1 Pint								
SPLH	Time 1040	Time 1040	Time 1040	Time 1040	29.0	1619	7.55	3.75				1 A/B
HQLH	Time 1500	Time 1500	Time 1500	Time 1500	28.40	0.838	7.28	5.89				2 A/B
	Time	Time	Time									3 A/B

1. Sample must be refrigerated or stored in wet ice after collection. The maximum temperature during storage should be 4°C (39.2°F).

Instructions:

- Each bottle has a label identifying sample ID, premeasured preservative contained in the bottle, sample type, client ID, and parameters for analysis. The following information should be added to each bottle label after collection with permanent black ink: date and time of collection, sampler's name or initials, and any field number or ID.
- All bottles not containing preservative may be rinsed with appropriate sample prior to collection.
- The client is responsible for documentation of the sampling event. Please note special sampling events on the sample custody form.

Laboratory Sample Acceptability
 Temperature:
 pH:

1	Collector: <i>Wesley Williams Daron Howard</i>	Date: <i>9/6/06</i>	Time: <i>1640</i>	Received By:	Date:	Time:
2	Relinquished by: <i>[Signature]</i>	Date: <i>9/6/06</i>	Time: <i>1700</i>	Received By: <i>Roger Brown</i>	Date: <i>9/7/06</i>	Time: <i>1220</i>
3	Relinquished by: <i>Roger Brown</i>	Date: <i>9/7/06</i>	Time: <i>1430</i>	Received By:	Date:	Time:
4	Relinquished by:	Date:	Time:	Received By: <i>SBe</i>	Date: <i>9/7/06</i>	Time: <i>1430</i>

Page 55

Ion Balance Sample 20066400-01SPLH


CATIONS	MG/L	FACTOR	MILLIEQUIVALENTS	ANIONS	MG/L	FACTOR	MILLIEQUIVALENTS
BARIUM	11.7	0.014	0.1638	CHLORIDE	229	0.028	6.412
CALCIUM	38.5	0.049	1.8865	FLUORIDE	1.9	0.052	0.0988
IRON	29	0.053	1.537	SULFATE	247	0.02	4.94
MAGNESIUM	42	0.082	3.444	NITRATE as NO3	0.004	0.016	0.000064
MANGANESE	0.98	0.036	0.03528	PHOSPHORUS as PO4	0.025	0.031	0.000775
POTASSIUM	13	0.025	0.325	SILICA as SO3	14.3	0.026	0.3718
SODIUM	194	0.043	8.342	BICARBONATE	144	0.033	4.752
STRONTIUM	3.98	0.022	0.08756	CARBONATE	0.594	0.016	0.009504
AMMONIUM	0.347	0.055	0.019085				
TOTAL CATION MILLIEQUIVALENT			15.840225	TOTAL ANION MILLIEQUIVALENT			16.584943

ion balance = $100 \frac{(\text{sum cations} - \text{sum anions})}{(\text{sum cations} + \text{sum anions})}$

Ion Balance= -2.29672827

BENCHMARK

EnviroAnalytical Inc.



NELAC Certification # E84167

ANALYTICAL TEST REPORT

THESE RESULTS MEET NELAC STANDARDS

Submission Number : 7030158

Johnson Engineering, Inc.
2158 Johnson Street
Fort Myers, FL 33901

Project Name : 20066400-01
Date Received : 03/06/2007
Time Received : 1510

Submission Number 7030158


Sample Number: 1 Sample Description: JE - 900
Sample Date: 03/05/2007 Sample Method: Grab
Sample Time: 0900

Parameter	Result	Units	MDL	PQL	Procedure	Analysis		Analyst
						Date	Time	
COLOR	5 U	PCU	5	20	110.2	03/08/2007	18:50	JS
PH	7.72	UNITS	0.1	0.4	150.1	03/08/2007	17:10	RCB
TOTAL DISSOLVED SOLIDS	932	MG/L	7.26	29.04	160.1	03/07/2007	15:45	CB
TURBIDITY	16.4	NTU	0.05	0.20	180.1	03/08/2007	17:10	DS
BARIUM	44.1	UG/L	2	8	200.7	03/08/2007	12:00	RCB
CALCIUM	58.8	MG/L	0.03	0.12	200.7	03/08/2007	12:00	RCB
DISSOLVED IRON	29 U	UG/L	29	116	200.7	03/29/2007	16:00	RCB/RLS
MAGNESIUM	60.7	MG/L	0.006	0.024	200.7	03/08/2007	12:00	RCB
MANGANESE	55.1	UG/L	0.88	3.92	200.7	03/08/2007	12:00	RCB
POTASSIUM	13.6	MG/L	0.169	0.676	200.7	03/08/2007	12:00	RCB
SODIUM	196	MG/L	0.034	0.136	200.7	03/08/2007	12:00	RCB
STRONTIUM	5516	UG/L	1	4	200.7	03/08/2007	12:00	RCB
CHLORIDE	324	MG/L	0.353	1.412	300.0	03/08/2007	17:20	JSM
FLUORIDE	1.29	MG/L	0.030	0.120	300.0	03/08/2007	17:20	JSM
SULFATE	204	MG/L	0.339	1.356	300.0	03/08/2007	17:20	JSM
NITRATE NITROGEN	0.004 U	MG/L	0.004	0.016	353.2	03/07/2007	08:52	TDT
NITRATE+NITRITE	0.050 U	MG/L	0.050	0.200	353.2	03/07/2007	10:30	CB
SILICA	18.9	MG/L	0.044	0.176	370.1	03/16/2007	10:20	TDT
BICARBONATE ALKALINITY	170	MG/L	0.594	2.376	SM2320B	03/08/2007	10:30	DS
CARBONATE ALKALINITY	0.594 U	MG/L	0.594	2.376	SM2320B	03/08/2007	10:30	DS
TOTAL ALKALINITY	170	MG/L	0.594	2.376	SM2320B	03/08/2007	10:30	DS
SPECIFIC CONDUCTANCE	1673	UMHOS/CM	1.24	4.96	SM2510B	03/07/2007	16:30	DS

1711 12th Street East * Palmetto, FL 34221 * Phone (941) 723-9986 * Fax (941) 723-6061

BENCHMARK

EnviroAnalytical Inc.



NELAC Certification # E84167

NITRITE NITROGEN	0.003 I	MG/L	0.003	0.012	SM4500NO2B	03/07/2007	08:52	TDT
TOTAL SULFIDE	3.34	UG/L	0.028	0.112	SM4500S2D	03/07/2007	14:18	RCB
TOTAL ORGANIC CARBON	0.570 I	MG/L	0.271	1.084	SM5310B	03/11/2007	14:00	JS

03/30/2007

Dale D. Dixon / Laboratory Director
Robert L. Sullivan / Laboratory Manager

Date

DATA QUALIFIERS THAT MAY APPLY:

A = Value reported is an average of two or more determinations.

B = Results based upon colony counts outside the acceptable range.

H = Value based on field kill determination. Results may not be accurate.

I = Reported value is between the laboratory MCL and the PQL.

J1 = Est. value surrogate recovery limits exceeded.

J2 = Est. value. No quality control criteria exists for component.

J3 = Est. value quality control criteria for precision or accuracy not met.

J4 = Est. value. Sample matrix interference suspected.

J5 = Est. value. Data questionable due to improper lab or field protocols.

K = Off-scale low. Value is known to be < the value reported.

L = Off-scale high. Value is known to be > the value reported.

N = Presumptive evidence of presence of material.

Q = Sample held beyond accepted hold time.

T = Value reported is < MDL. Reported for informational purposes only and shall not be used in statistical analysis.

U = Analyte analyzed but not detected at the value indicated.

V = Analyte detected in sample and method blank.

Y = Analysis performed on an improperly preserved sample. Data may be inaccurate.

Z = Data deviate from historically established concentration ranges.

? = Data rejected and should not be used. Some or all of QC data were outside criteria, and the presence or absence of the analyte cannot be determined from the data.

* = Not reported due to interference.

NOTES:

PQL = 4xMDL

MBAS calculated as LAS; molecular weight = 340.

X = Value exceed MCL.

G = CBOD accuracy standard does not meet method QC criteria, but does not meet lab control limits that are in agreement with USEPA generated data. USEPA letter available upon request.

For questions and comments regarding these results, please contact Katharine Dixon at (941) 723-9986

Silver Lake Utilities
Analysis of Plant Operating Expenses - Salaries & Wages Component
****Based on FDEP Plant Staffing Requirements****

SCHEDULE 11

<u>Personnel Type</u>	<u>Existing Facilities</u>	<u>Muse Potable (phase II)</u>	<u>Bulk Raw</u>	<u>Bulk Treated</u>	<u>Muse Wastewater (phase II)</u>
Initial salary/wage estimates (annual):	\$ 33,600	\$ 300,000	\$ 25,000	\$ 180,000	\$ 130,000
Plant avg daily flow operating at capacity (GPD):	57,000	466,667	500,000	350,000	615,385
<hr/>					
Full-time Class C certified operator 40 hours/week @ \$40/hour + 40% fringe benefit rate Sub-total:		83,200 <u>33,280</u> <u>116,480</u>			83,200 <u>33,280</u> <u>116,480</u>
Part-time Class C certified operator 20 hours/week @ \$40/hour 8 hours/week @ \$40/hour + 40% fringe benefit rate Sub-total:	16,640 <u>6,656</u> <u>23,296</u>		16,640 <u>6,656</u> <u>23,296</u>	41,600 <u>16,640</u> <u>58,240</u>	
Full-time utility maintenance worker 40 hours/week @ \$20/hour + 40% fringe benefit rate Sub-total:		41,600 <u>16,640</u> <u>58,240</u>		41,600 <u>16,640</u> <u>58,240</u>	
Full-time general labor 40 hours/week @ \$15/hour + 40% fringe benefit rate Sub-total:		31,200 <u>12,480</u> <u>43,680</u>		31,200 <u>12,480</u> <u>43,680</u>	
Part-time general labor 8 hours/week @ \$15/hour + 40% fringe benefit rate Sub-total:	6,240 <u>2,496</u> <u>8,736</u>				6,240 <u>2,496</u> <u>8,736</u>
Revised Estimate - Salaries/Wages:	\$ 32,032	\$ 218,400	\$ 23,296	\$ 160,160	\$ 125,216
Employee Count:	2	3	1	3	2