



ORIGINAL

070467-EI

BEFORE THE  
FLORIDA PUBLIC SERVICE COMMISSION

DOCKET NO. 07 \_\_\_\_\_ -EI

IN RE: TAMPA ELECTRIC'S  
PETITION TO DETERMINE NEED FOR  
POLK POWER PLANT UNIT 6

TESTIMONY AND EXHIBIT

OF

THOMAS J. SZELISTOWSKI

DOCUMENT NUMBER - DATE

06177 JUL 20 8

FPSC-COMMISSION CLERK

**ORIGINAL**

1                   BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

2                               PREPARED DIRECT TESTIMONY

3   OF

4   THOMAS J. SZELISTOWSKI

5  
6   **Q.**   Please state your name, business address, occupation and  
7           employer.

8  
9   **A.**   My name is Thomas J. Szelistowski. My business address  
10           is 702 N. Franklin Street, Tampa, Florida 33602. I am  
11           employed by Tampa Electric Company ("Tampa Electric" or  
12           "company") as Director, Energy Control Center.

13  
14   **Q.**   Please provide a brief outline of your educational  
15           background and business experience.

16  
17   **A.**   I received a Bachelor's of Electrical Engineering degree  
18           in 1983 from the Georgia Institute of Technology and a  
19           Master's degree in Business Administration from the  
20           University of Tampa in 1987. I am a registered  
21           professional engineer in the state of Florida. I joined  
22           Tampa Electric as a co-operative education student in  
23           1978 and became full time employee as an engineer in  
24           1983. From 1983 through 2001, I held various positions  
25           the Transmission Planning, Transmission Engineering, and

DOCUMENT NUMBER-DATE

06177 JUL 20 5

FPSC-COMMISSION CLERK

1 T&D Operations areas of Tampa Electric. In 2001, I was  
2 promoted to Director, Transmission and Distribution  
3 Operations. In this position, I was responsible for the  
4 construction and maintenance of the distribution and  
5 transmission facilities of Tampa Electric. In May 2007,  
6 I was named Director, Energy Control Center. My present  
7 responsibilities include the areas of day-to-day  
8 distribution outage restoration, transmission system  
9 operations, system reliability tracking and reporting,  
10 Energy Delivery emergency response and planning,  
11 wholesale energy accounting and billing, and Tampa  
12 Electric's long-term transmission and distribution  
13 infrastructure planning.

14  
15 **Q.** What is the purpose of your testimony?  
16

17 **A.** The purpose of my testimony is to describe how Tampa  
18 Electric determined the most cost-effective transmission  
19 plan for the interconnection and integration of Tampa  
20 Electric's proposed Polk Unit 6 that meets both North  
21 American Electric Reliability Council ("NERC") and  
22 Florida Reliability Coordinating Council ("FRCC")  
23 reliability standards. I will discuss the overall  
24 transmission evaluation process Tampa Electric conducted  
25 including the stability and steady state power flow study

1 results used in determining the most cost-effective  
2 manner to interconnect and integrate Polk Unit 6 into the  
3 transmission system. Finally, I will discuss the  
4 characteristics, estimated costs and construction  
5 schedule of the transmission system facilities required  
6 to interconnect and integrate Polk Unit 6 into Tampa  
7 Electric's system.

8  
9 **Q.** Have you prepared an exhibit to support your testimony?

10  
11 **A.** Yes. I sponsor Exhibit No. \_\_\_ (TJS-1) that consists of  
12 three documents:

13 Document No. 1 230 kV Lines Polk Power Substation to  
14 Pebbledale Substation

15 Document No. 2 Polk Unit 6 Interconnection and  
16 Integration

17 Document No. 3 Summary of Required Facilities,  
18 Ratings and Cost

19  
20 **Q.** Are you sponsoring any sections of Tampa Electric's  
21 Determination of Need Study for Electrical Power: Polk  
22 Unit 6 ("Need Study")?

23  
24 **A.** Yes. I sponsor section VII.D. of the Need Study entitled  
25 "Transmission Facilities".

1 Q. Please describe Tampa Electric's evaluation process that  
2 results in determining the most cost-effective  
3 transmission system requirements for new generation  
4 resources.

5  
6 A. Tampa Electric's process begins with evaluating the  
7 proposed generating plant site location to determine its  
8 proximity to existing transmission facilities. To the  
9 extent there are existing transmission facilities nearby,  
10 the site is then assessed to determine its capability for  
11 reliably interconnecting and integrating the proposed new  
12 generation into the transmission system as a firm Tampa  
13 Electric generation resource.

14  
15 Q. What factors are considered when integrating the proposed  
16 new generation into the transmission system?

17  
18 A. There are numerous factors that are considered prior to  
19 integration of a new generating unit into the bulk  
20 electric system. They include:

- 21  
22 • The megawatt ("MW") amount of generation being added  
23 at the generation site and various dispatch profiles  
24 of the new generation resource relative to existing  
25 generation resources serving Tampa Electric and

- 1 others utilities' load in the region;
- 2 • Compliance with NERC and FRCC reliability standards;
- 3 • Stability and system protection impacts;
- 4 • Impact on existing Tampa Electric or third party
- 5 facilities;
- 6 • Capability to upgrade existing substation or
- 7 transmission facilities;
- 8 • Ability to site new substation or transmission line
- 9 facilities including right-of-way requirements,
- 10 existing right-of-way capabilities, permitting
- 11 requirements, and expected time frame to acquire
- 12 right-of-way and necessary permits;
- 13 • Ability to construct the required transmission
- 14 facilities without having to take clearances on
- 15 existing operating facilities during periods that
- 16 would result in an adverse reliability impact;
- 17 • Operating considerations such as maintenance
- 18 requirements of the proposed interconnection and
- 19 integration facilities and impacts to the ongoing
- 20 operation of the system;
- 21 • The timing and amount of power needed for testing
- 22 equipment such as pumps and motors;
- 23 • Expected in-service testing and commercial
- 24 operations dates for new generation, which
- 25 determines the date transmission interconnection and

1 integration facilities must be completed for the  
2 unit's testing; and  
3 • The initial and ongoing costs of facilities and  
4 operations.

5  
6 **Q.** How did Tampa Electric evaluate the impact of the Polk  
7 Unit 6 generation addition on the system?

8  
9 **A.** Power flow studies are used to evaluate the impact of the  
10 generation additions on Florida's transmission system.  
11 The power flow studies include a review of stability  
12 requirements, system protection impacts and steady state  
13 requirements in compliance with NERC and FRCC reliability  
14 standards. These power flow studies are used to evaluate  
15 the performance of the system and to determine various  
16 project alternatives that would be needed to interconnect  
17 and integrate the new generation into the transmission  
18 system.

19  
20 **Q.** How are project alternatives for adding or upgrading  
21 transmission facilities developed?

22  
23 **A.** A Tampa Electric core team is used to develop and review  
24 potential alternatives and estimated costs. This core  
25 team is comprised of engineers from System Planning,

1 Substation Engineering, Transmission Engineering, and  
2 System Security. As part of their analysis, this team  
3 considers a number of the issues outlined previously  
4 including ability to construct, potential upgrade of  
5 existing facilities, right-of-way requirements, in-  
6 service dates and operating considerations. When the  
7 core team is satisfied that they have developed the most  
8 cost-effective transmission interconnection and  
9 integration plan that complies with NERC and FRCC  
10 reliability standards, the process is deemed complete.

11  
12 **Q.** Did Tampa Electric utilize any previous studies to help  
13 determine the most appropriate transmission system  
14 requirements for Polk Unit 6?

15  
16 **A.** Yes, Tampa Electric was an active participant in the 2005  
17 Central Florida Study and 2006 Central Florida Re-Study  
18 at the FRCC. The Central Florida Re-study and its  
19 recommendations were used as a starting point for the  
20 Polk Unit 6 transmission study.

21  
22 **Q.** What was the purpose of the Central Florida Re-Study?

23  
24 **A.** The purpose of the Central Florida Re-Study was to review  
25 the transmission assets needed given the planned

1 generation being added in the Polk and Hardee County  
2 areas from 2007 through 2012. The original study was  
3 completed prior to the issuance of the state utilities'  
4 Ten-Year Site Plans in April 2006. Because there were a  
5 number of significant changes in planned generation from  
6 the previous plans, the Re-Study was requested by the  
7 FRCC to review the impacts of those changes on the state  
8 transmission system.

9  
10 **Q.** How did Tampa Electric use the study results as a  
11 starting point for the Polk Unit 6 study?

12  
13 **A.** The computer models, which provide information on how the  
14 transmission system performs under a given set of  
15 conditions, were used as the basis for the Polk Unit 6  
16 study. These models included the transmission projects  
17 recommended in the 2006 Central Florida Re-Study. While  
18 the projects are not currently in place, they are  
19 projected to be in-service by the time Polk Unit 6 is  
20 expected to come on-line.

21  
22 **Q.** Did Tampa Electric utilize any other previous studies to  
23 help determine the most appropriate transmission system  
24 requirements?

1 **A.** Yes. In Tampa Electric's Determination of Need for the  
2 Willow Oak to Davis 230 kV Transmission Line<sup>1</sup>, Tampa  
3 Electric identified the need for a new 230 kV  
4 transmission line from Willow Oak Substation to Wheeler  
5 Substation to transfer power from a new baseload unit at  
6 Polk Station or to import the power from another  
7 resource. This transmission line was also included in  
8 the baseload flow cases used in the Polk Unit 6 study.

9  
10 **Q.** How is the Polk Station connected to the bulk electric  
11 system?

12  
13 **A.** The Polk Station switchyard is connected to the bulk  
14 electric system grid by four 230 kV lines. Two of these  
15 lines go from Polk to Tampa Electric's Pebbledale  
16 Substation.

17  
18 **Q.** What were the results of the power flow studies that  
19 Tampa Electric performed?

20  
21 **A.** The results of the power flow studies showed an overload  
22 might occur on either one of the existing Polk to  
23 Pebbledale 230 kV transmission lines for an outage of the  
24 other Polk to Pebbledale 230 kV transmission line. This

---

<sup>1</sup> Order No PSC-07-0522-FOF-EI in Docket 070193-EI, issued June 21, 2007.

1 result indicated that, under extreme conditions, there  
2 may not be enough transmission capability out of Polk  
3 Power Substation to transfer the entire plant's capacity.

4  
5 **Q.** What projects did the core team recommend after reviewing  
6 the power flow study results?

7  
8 **A.** The core team recommended upgrading both of the Polk to  
9 Pebbledale 230 kV transmission lines to eliminate any  
10 potential overload of one of the Polk to Pebbledale 230  
11 kV lines due to an outage of the parallel Polk to  
12 Pebbledale 230kV line.

13  
14 **Description of Planned Project**

15 **Q.** Please provide a general description of the existing  
16 transmission facilities at Polk Station.

17  
18 **A.** As I previously stated, Polk Power Substation is  
19 connected to the bulk electric system grid by four 230 kV  
20 transmission lines. Two of these lines go from Polk  
21 Station to the Tampa Electric Pebbledale Substation. The  
22 third line goes from Polk Station to Mines Substation and  
23 the fourth from Polk Station to Invenergy's Hardee  
24 Station.

25

1 Q. Please provide a general description of the transmission  
2 facilities required for interconnection and integration  
3 of Polk Unit 6 to Tampa Electric's system.

4  
5 A. There are two general types of transmission projects  
6 required: internal within the plant and external  
7 connections of the plant to Tampa Electric's bulk power  
8 system. Internally Polk Unit 6 will be connected to the  
9 existing Polk Power Substation located on-site with three  
10 new 0.7 mile 230 kV transmission lines connecting three  
11 new Polk 6 generator step-up transformers ("GSU").  
12 Externally the two Polk to Pebbledale transmission lines  
13 will need to be upgraded to a higher capacity as a result  
14 of Polk Unit 6. These two lines, 230605 and 230606, are  
15 approximately ten and 14 miles, respectively and are  
16 reflected in Document No. 1 of my Exhibit No. \_\_\_ (TJS-1).

17  
18 Q. Please describe the physical characteristics of the  
19 internal facilities that connect Polk Unit 6 and its  
20 associated integrated gasification combined cycle  
21 ("IGCC") equipment to the Polk Power Substation and the  
22 new additions at Polk Power Substation.

23  
24 A. The three GSU will be located near the combustion  
25 turbines, steam turbine and associated IGCC equipment. A

1 0.7 mile double circuit 230kV line will be built from two  
2 of the GSU to two new termination positions at the Polk  
3 Power Substation. A third 0.7 mile 230kV transmission  
4 line will be built from the remaining GSU to another new  
5 termination position at the Polk Power Substation. Polk  
6 Power Substation will have three new termination  
7 positions and six new circuit breakers as shown in  
8 Document No. 2 of my Exhibit No.\_\_\_\_ (TJS-1).  
9

10 **Q.** How did Tampa Electric evaluate the transmission related  
11 costs associated with the planned Polk Unit 6?  
12

13 **A.** An estimating team made up of members from Substation  
14 Engineering, Transmission Engineering, Real Estate,  
15 System Security, Telecommunications, and Environmental  
16 Health and Safety reviewed the transmission  
17 interconnection and integration requirements to develop a  
18 scope of work. This included the review of existing  
19 drawings and site visits. Each member then estimated the  
20 costs to complete their scope of work.  
21

22 **Q.** What is the total cost of the transmission  
23 interconnection and integration costs for Polk Unit 6?  
24

25 **A.** The total estimated project cost is approximately \$25

1 million. A summary of the facilities required and  
2 associated costs is provided in Document No. 3 of my  
3 Exhibit No. \_\_\_ (TJS-1).  
4

5 **Q.** How does the \$25 million estimate compare to earlier  
6 estimates of transmission and interconnection costs for  
7 Polk Unit 6?  
8

9 **A.** The \$25 million estimate is lower than the initial  
10 estimate of \$100 million used in Tampa Electric's 2013  
11 baseload generation capacity request for proposals issued  
12 February 7, 2007. This lower cost estimate is the result  
13 of the stability study which was subsequently completed  
14 showing that two new lines that were assumed to be  
15 required for stability purposes are not needed.  
16

17 **Q.** What is the schedule for construction of the transmission  
18 facilities needed for the interconnection and integration  
19 of Polk Unit 6?  
20

21 **A.** The Polk Unit 6 interconnection work is scheduled to  
22 begin in December 2010 and is estimated to be completed  
23 by September 2011. This will allow time for testing of  
24 the unit and associated IGCC equipment prior to its  
25 commercial in-service date. The Polk Power Substation to

1 Pebbledale line construction will begin by September 2010  
2 with an in-service date of March 2012. This ensures that  
3 all transmission facilities will be in-service prior to  
4 any full power testing of Polk Unit 6.

5  
6 **Q.** Has this assessment, along with the Polk Unit 6  
7 interconnection and integration requirements discussed  
8 above, been reviewed by the FRCC?

9  
10 **A.** Yes. According to the FRCC's Regional Transmission  
11 Planning Process, Tampa Electric's interconnection and  
12 integration plan for Polk Unit 6 as discussed above was  
13 provided to the FRCC for review and affirmation that no  
14 reliability issues exist. FRCC's review is scheduled to  
15 be complete by August 23, 2007. I intend to supplement  
16 my testimony once the review by the FRCC is completed if  
17 there is any material difference identified.

18  
19 **Q.** Please summarize your testimony.

20  
21 **A.** Tampa Electric has completed stability, system protection  
22 and power flow studies to determine the impact of the  
23 interconnection and integration of Polk Unit 6 to the  
24 bulk electric system. The studies indicate new  
25 interconnection facilities at the Polk Power Substation

1 are required, and two existing transmission lines need to  
2 be upgraded to ensure the full capacity of Polk Station  
3 can be delivered to the grid under extreme conditions.  
4 The upgrade of the two 230 kV transmission lines is the  
5 most cost-effective way to fully integrate the capacity  
6 of Polk Unit 6.

7

8 **Q.** Does this conclude your testimony?

9

10 **A.** Yes, it does.

11

12

13

14

15

16

17

18

19

20

21


22

23


24

25

230 kV Lines Polk Power Substation to Pebbledale Substation



### Polk Unit 6 Interconnection and Integration



**NOTE:** The boxed area represents the interconnections made as a result of Polk Unit 6.

### Summary of Required Facilities Ratings and Cost

New Facilities:	Required Rating		Estimated Cost (\$ 000's)		
	mva	amps			
2 Double circuit lines to interconnect Steam Unit and CT1 and associated substation equipment (0.7 miles)	749	1,880	6,000		
Single circuit line to connect CT2 and associated substation equipment (0.7 miles)	749	1,880	4,000		
<b>Non Facility Total:</b>			<b>\$10,000</b>		
Upgraded Facilities:	Existing Rating		Required Rating		Estimated Cost (\$ 000's)
	mva	amps	mva	amps	
Circuit 230305 (9.85 miles)	749	1,880	1,013	2,543	6,000
Circuit 230306 (13.46 miles)	637	1,880	1,013	2,543	9,000
<b>Upgraded Facility Total:</b>					<b>\$15,000</b>
<b>Total Cost:</b>					<b>\$25,000</b>

**Note:** The new facilities must be completed and in-service by September 1, 2011 and the upgraded facilities by March 1, 2012 for testing purposes.