

Dorothy Menasco

070000

From: Stright, Lisa [Lisa.Stright@pgnmail.com]
Sent: Thursday, October 11, 2007 1:24 PM
To: Filings@psc.state.fl.us
Cc: Burnett, John
Subject: PEF's Customer Interruptions and Curtailments Quarterly Report
Attachments: Bulk Power 07 3rd Qtr Rpt.doc

This electronic filing is made by

John T. Burnett
P.O. Box 14042
St. Petersburg, FL 33733
727-820-5184
john.burnett@pgnmail.com

Undocketed

On behalf of **Progress Energy Florida.**

Consisting of **1 page.**

The attached document for filing is Progress Energy's
Customer Interruptions and Curtailments Quarterly Report
for the quarter ending September 30, 2007.
<<Bulk Power 07 3rd Qtr Rpt.doc>>

Lisa Stright

Regulatory Affairs Analyst - Legal Dept.
Progress Energy Svc Co.
106 E. College Ave., Suite 800
Tallahassee, FL 32301
(850) 222-8738 office
(850) 222-9768 fax
VN 230-5095

DOCUMENT NUMBER-DATE

09332 OCT 11 6

10/11/2007

FPSC-COMMISSION CLERK



JOHN T. BURNETT
ASSOCIATE GENERAL COUNSEL
PROGRESS ENERGY SERVICE COMPANY, LLC

October 11, 2007

VIA ELECTRONIC FILING

Ms. Ann Cole, Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Re: Quarterly report of customer interruptions and curtailments.

Dear Ms. Cole:

Pursuant to Commission Rule 25-6.018(3), F.A.C., enclosed for filing on behalf of Progress Energy Florida, Inc., is the quarterly report of customer interruptions and curtailments for the quarter ending September 30, 2007.

Please acknowledge your receipt of this filing as provided in the Commission's electronic filing procedures. Thank you for your assistance in this matter.

Respectfully,

s/ John T. Burnett

JTB/lms

DOCUMENT NUMBER-DATE
09332 OCT 11 06
FPSC-COMMISSION CLERK



**Customer Interruption and Curtailment (Bulk Power)
Quarterly Report (3rd Quarter 2007)**

Date: October 8, 2007

Reason for Interruption	Crystal River 4 tripped – failure of Temperature Control Valve
Date	August 20, 2007
Time	5:04 pm (17:04)
Duration of Interruption	2 hours 24 minutes (17:04 – 19:28)
Amount of Load shed	144.08 MW

DOCUMENT NUMBER-DATE
09332 OCT 11 5
FPSC-COMMISSION CLERK