

**BEFORE THE
FLORIDA PUBLIC SERVICE COMMISSION**

**DOCKET NO. 070650 -EI
FLORIDA POWER & LIGHT COMPANY**

**IN RE: FLORIDA POWER & LIGHT COMPANY'S
PETITION TO DETERMINE NEED FOR
TURKEY POINT NUCLEAR UNITS 6 AND 7
ELECTRICAL POWER PLANT**

DIRECT TESTIMONY & EXHIBIT OF:

HECTOR J. SANCHEZ

DOCUMENT NUMBER-DATE

09461 OCT 16 5

FPSC-COMMISSION CLERK

1 **BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION**

2 **FLORIDA POWER & LIGHT COMPANY**

3 **DIRECT TESTIMONY OF HECTOR J. SANCHEZ**

4 **DOCKET NO. 07____-EI**

5 **OCTOBER 16, 2007**

6
7 **Q. Please state your name and business address.**

8 **A. My name is Hector J. Sanchez. My business address is Florida Power & Light**
9 **Company, 4200 West Flagler Street, Miami, FL 33134.**

10 **Q. By whom are you employed and what is your position?**

11 **A. I am employed by Florida Power & Light Company (FPL) as the Director of**
12 **Transmission Services and Planning.**

13 **Q. Please describe your duties and responsibilities in that position.**

14 **A. I am responsible for matters relating to the provision of transmission services**
15 **on the FPL system and for planning the expansion of the FPL transmission**
16 **system to meet the requirements of FPL's retail and wholesale customers, and**
17 **its transmission service obligations.**

18 **Q. Please describe your educational background and professional**
19 **experience.**

20 **A. In December 1985, I received a Bachelor of Science degree in Electrical**
21 **Engineering from the University of Miami. In 1990, I completed the**
22 **Southeastern Electric Exchange's Course in Modern Power Systems Analysis**
23 **held at Auburn University. In 1991, I received a Master of Business**

1 **DOCUMENT NO. DATE**

09461-07 10/16/07
 FPSC - COMMISSION CLERK

1 Administration degree from Florida International University. Additionally, I
2 have completed various other power system courses offered by Power
3 Technology Incorporated, courses offered internally at FPL, and business and
4 management courses at Columbia University.

5
6 Since joining FPL in 1986, I have held positions of increasing responsibility.
7 My first positions at FPL were as an Applications Engineer in the Power
8 Systems Control group and as an Engineer in the Protection and Control
9 department. In 1989, I joined the System Operations group in the area of
10 operations planning where I was responsible for performing technical analyses
11 associated with short-term planning and operation of the FPL system. In
12 1994, I became a Transmission Business Manager where I was responsible for
13 issues associated with the provision of transmission service. Subsequent to
14 that assignment, in March 2000, I held the position responsible for the
15 planning of the bulk transmission system and interconnections. In January of
16 2006, I became responsible for the operation and dispatch of the FPL system
17 on a real time basis. Lastly, in March of 2006 I assumed my current position
18 as Director of Transmission Services and Planning.

19 **Q. Are you sponsoring an exhibit in this case?**

20 **A.** Yes. I am sponsoring Exhibit HJS-1, Summary of Required Facilities for
21 Turkey Point Units 6 & 7 (Turkey Point 6 & 7), which is attached to my direct
22 testimony.

1 **Q. Are you sponsoring any sections in the Need Study document?**

2 **A.** Yes. I am sponsoring the portions of Section V.A.4 addressing Transmission
3 Facilities. In addition, I sponsor Appendix A of the Need Study.

4 **Q. What is the purpose of your testimony?**

5 **A.** The purpose of my testimony is to describe FPL's process for determining the
6 transmission plan for the interconnection and integration of FPL's Turkey
7 Point 6 & 7. The two nuclear units are expected to have in-service dates of
8 2018 and 2020, respectively, with each unit ranging in size from
9 approximately 1,100 to 1,520 MW net output. I discuss the overall
10 transmission evaluation process and the attendant results of preliminary
11 studies performed by FPL to determine how to interconnect and integrate
12 Turkey Point 6 & 7 into FPL's transmission system.

13 **Q. Please summarize your testimony.**

14 **A.** My testimony provides a description of the evaluation process used to develop
15 the transmission-related requirements for the Turkey Point 6 & 7 generation
16 expansion plan, considering factors associated with planning, construction,
17 and operation of the electric system. The results of FPL's evaluation are that
18 the transmission facilities and upgrades described in Exhibit HJS-1 present the
19 necessary transmission interconnection and integration requirements for
20 Turkey Point 6 & 7 within the range of generator sizes being contemplated.
21 Based on FPL's preliminary assessment, the addition of Turkey Point 6 & 7 at
22 approximately 1,200 MW gross output for each unit is not expected to
23 adversely impact the transmission import capability into the state of Florida.

1 If the unit size increases, more detailed studies will be needed to determine the
2 specific impacts and mitigation alternatives.

3
4 **EVALUATION PROCESS FOR DETERMINING FPL'S TRANSMISSION**
5 **SYSTEM REQUIREMENTS**
6

7 **Q. Please describe FPL's evaluation process for transmission**
8 **interconnection and integration of new generation resources.**

9 **A.** The process commences with an evaluation team, including engineers from
10 transmission and substation planning, operations, engineering, project
11 management, permitting, and siting who together use their combined
12 knowledge and years of experience to perform the evaluation and develop a
13 transmission interconnection and integration plan. The evaluation process
14 considers many factors, as outlined below, in order to develop an effective
15 transmission plan. In some instances, the determination of the transmission
16 interconnection and integration plan is relatively straightforward; however,
17 other times it requires an iterative assessment of various factors and a
18 substantial amount of time to perform appropriate studies. The resultant plan
19 must be in compliance with North American Electric Reliability Corporation
20 (NERC) and Florida Reliability Coordinating Council (FRCC) Reliability
21 Standards.

1 Generally, the first step in the process is to evaluate the proposed generating
2 plant site location to determine its proximity to existing transmission facilities.
3 To the extent there are existing transmission facilities nearby, those facilities
4 are assessed to determine their capabilities for reliably interconnecting and
5 integrating the proposed new generation into the transmission system as a firm
6 FPL generation resource. Next, other factors such as those listed below are
7 considered (as applicable):

- 8 • Amount of generation (MW) being added at the new generation site, and
9 the dispatch profile of the new generation resource relative to FPL's other
10 generation resources in serving FPL's load;
- 11 • Capabilities to upgrade existing facilities (e.g., can the conductor on an
12 existing transmission line be upgraded on the existing structures or would
13 the entire transmission line have to be rebuilt?);
- 14 • Capability of transmission lines needed, right-of-way requirements,
15 existing right-of-way capabilities, siting of new right-of-way, permitting
16 requirements, and expected time-frame to acquire right-of-way and
17 necessary permits;
- 18 • Ability to transport power efficiently (e.g., would using higher voltages be
19 more efficient by reducing the amounts of transmission losses incurred
20 when moving large amounts of power over long distances?);
- 21 • Existing and new substation requirements, capabilities, and availability;
- 22 • Impact on existing facilities (e.g., does the proposed interconnection and
23 integration plan result in an overload on an existing facility or does it

- 1 result in a material adverse impact somewhere else on the transmission
2 system?);
- 3 • Constructability (e.g., can the necessary transmission facilities be
4 constructed without having to take existing operating facilities out of
5 service during periods that would result in an adverse reliability impact?);
 - 6 • Overall compatibility with the system (e.g., do the new facilities require
7 new material stocking requirements or the need for new tools to
8 maintain?);
 - 9 • Compliance with NERC and FRCC Reliability Standards;
 - 10 • Operating considerations (e.g., what are the maintenance requirements of
11 the proposed interconnection and integration facilities and how will they
12 impact the on-going operation of the system?);
 - 13 • The timing and amount of power needed for testing of equipment such as
14 pumps and motors;
 - 15 • Expected in-service testing and commercial operations dates for new
16 generation (e.g., which transmission facilities necessary for
17 interconnection and integration need to be in-service prior to the
18 commercial operation in-service date for testing?);
 - 19 • The need for procuring transmission service from a third party;
 - 20 • Material adverse impact on third party transmission owner(s); and,
 - 21 • Initial and recurring costs of facilities and operations.

1 The next step in the interconnection and integration evaluation process is to
2 perform power flow studies for a proposed transmission interconnection and
3 integration plan. These power flow studies are used to evaluate the
4 performance of the system and to converge on specific new system facilities
5 and upgrades that would be needed to interconnect and integrate the new
6 generation into the transmission system.

7
8 When the evaluation team is satisfied that they have developed an effective
9 transmission interconnection and integration plan that is in compliance with
10 NERC and FRCC Reliability Standards for the new generation resources, the
11 process is deemed complete. If this result is not achieved, the evaluation
12 process proceeds iteratively, as needed, until this result is achieved.

13
14 I would also note that this evaluation process, including the power flow
15 studies, is the same as that used in FPL's recent Need Determination
16 proceedings.

17 **Q. Please describe how FPL evaluated the transmission-related**
18 **requirements associated with Turkey Point 6 & 7.**

19 **A.** When evaluating a generation plan, FPL considers different categories of
20 transmission requirements that arise from the proposed delivery of additional
21 power over FPL's transmission system. These categories are:

- 22 1) Transmission interconnection;
23 2) Transmission integration; and

1 3) Third party transmission service (as applicable).

2

3 FPL's Transmission Services and Planning Department evaluated the three
4 categories of transmission requirements for Turkey Point 6 & 7 under my
5 direction.

6 **Q. Please describe in more detail each of the three categories associated with**
7 **the transmission requirements that you have identified.**

8 **A.** The three categories can be summarized as follows:

9

10 **1) Transmission interconnection requirements**

11 Transmission interconnection requirements are generally the facilities
12 necessary to connect the new generation to the system. These facilities
13 typically include generator step-up transformers, connection facilities from the
14 transformers to the switchyard, and certain substation equipment at the point
15 of interconnection. Additionally, certain facilities may need to be replaced or
16 upgraded as a result of the generator interconnection at locations beyond the
17 point of interconnection, such as circuit breakers and overhead ground wires
18 due to increased fault current from the generator. Finally, there is the
19 potential that interconnecting a generator that is larger than the largest single
20 generator in the region may require upgrades to the transmission system to
21 accommodate the instantaneous loss of the larger generator. The
22 instantaneous loss of any generator in Peninsular Florida results in a sudden
23 in-rush of power into Florida from the eastern United States interconnection

1 reacting to make up for the deficiency in generation. The transmission system
2 must be capable of sustaining the loss of the single largest generator without
3 violating any NERC or FRCC Reliability Standards.

4

5 **2) Transmission integration requirements**

6 Transmission integration requirements include system upgrades of existing
7 transmission facilities and new transmission facilities that the power flow
8 studies have determined are necessary for the reliable operation and firm
9 delivery of the new FPL generation resources to FPL's load.

10

11 As part of this assessment, any adverse impacts that result in NERC or FRCC
12 Reliability Standard violations on third party transmission systems are
13 identified. In such instances, FPL would confer with the parties to confirm
14 that the violation is valid and, if so, determine if there is a mitigation measure
15 already available, or jointly develop mitigation measures to address the
16 violation.

17

18 **3) Third party transmission service requirements (as applicable)**

19 Third party transmission service requirements are considered when generation
20 resources are connected to an external transmission provider's system(s).

21 When a generation expansion plan, such as the plan that includes FPL's
22 Turkey Point 6 & 7, does not contain generation connected to a third party
23 transmission system, there is no need for transmission service for the delivery

1 of generation connected to a third party to the FPL system. As such, this
2 category of transmission service requirements will not be discussed further in
3 my testimony.
4

5 **TRANSMISSION SYSTEM REQUIREMENTS FOR**
6 **TURKEY POINT 6 & 7**
7

8 **Q. Please describe FPL's proposed Turkey Point 6 & 7 units for which**
9 **transmission requirements are being evaluated.**

10 **A.** As discussed in FPL witness Silva's testimony, Turkey Point 6 is proposed as
11 an 1,100 to 1,520 MW net nuclear unit (1,200 to 1,650 MW gross electrical
12 output) with a planned in-service date of 2018, and Turkey Point 7 is proposed
13 as an 1,100 to 1,520 MW net nuclear unit (1,200 to 1,650 MW gross electrical
14 output) with a planned in-service date of 2020.
15

16 **TRANSMISSION INTERCONNECTION**
17

18 **Q. Please describe the transmission interconnection requirements for**
19 **Turkey Point 6 & 7.**

20 **A.** The required transmission interconnection facilities for Turkey Point 6 & 7
21 are summarized in Exhibit HJS-1, Summary of Required Facilities for Turkey
22 Point 6 & 7. These facilities include:

- 1 • The connection of Turkey Point 6 & 7 Generator Step Up (GSU)
- 2 transformers to a new 500 kV switchyard at the Turkey Point site, and
- 3 attendant bus equipment; and,
- 4 • Circuit breaker and overhead ground wire upgrades that may be required.

5
6 Additionally, as discussed later in my testimony, there may be potential
7 upgrades associated with increasing the size of the largest unit in the FRCC
8 beyond approximately 1,200 MW gross output.

9

10 TRANSMISSION INTEGRATION

11

12 **Q. Please describe the transmission integration evaluation for the new**
13 **generation at Turkey Point 6 & 7.**

14 **A.** The integration evaluation is comprised of power flow studies. The power
15 flow studies are used to identify any upgrades to existing transmission
16 facilities or new transmission facilities that may be needed to integrate Turkey
17 Point 6 & 7 into the transmission system as firm FPL generation resources
18 while meeting NERC and FRCC Reliability Standards. The methodology
19 used to perform these power flow studies is the same as that used in
20 connection with FPL's other recent need determination proceedings, and is
21 consistent with the methods used to ensure compliance with the NERC and
22 FRCC Reliability Standards. In addition, compliance with U.S. Nuclear
23 Regulatory Commission (NRC) requirements must be ensured. I reviewed

1 and approved the results of the power flow studies and reviewed the need for
2 new facilities and upgrades required to integrate Turkey Point 6 & 7 into the
3 transmission system as firm FPL generation resources used to serve FPL's
4 retail customers.

5
6 My review determined that to reliably integrate the new generation resources
7 in compliance with NERC and FRCC Reliability Standards, and with NRC
8 requirements, new system facilities and upgrades are required for Turkey
9 Point 6 & 7 for either the 1,100 MW or 1,520 MW net units. Exhibit HJS-1
10 summarizes the new system facilities and facility upgrades required for the
11 range of unit sizes being considered.

12 **Q. Please describe the power flow studies performed.**

13 **A.** First contingency alternating current (AC) power flow analyses were
14 performed for Turkey Point 6 & 7 to assess the need for transmission system
15 upgrades and new facilities. All analyses were performed using the latest
16 available 2007 FRCC power flow databank cases, updated to reflect FPL's
17 latest load and resource forecast. Since the FRCC only developed load flow
18 cases through 2017, FPL's load in the 2017 case was scaled to the latest
19 available load information through 2020.

20
21 Analyses were performed using power flow simulations to identify the
22 facilities that may become overloaded because of the integration of the
23 capacity provided by Turkey Point 6 & 7, as well as the upgrades and new

1 transmission facilities required to mitigate such overload(s). An AC solution
2 technique was also used to assess the voltage performance of the system
3 against NERC and FRCC Reliability Standards. In the analysis, Turkey Point
4 6 & 7 were subjected to a first contingency screening for loss of transmission
5 elements or generators out of service, one at a time, in accordance with NERC
6 and FRCC Reliability Standards. This resulted in approximately 3,600 power
7 flow calculations being performed for each case assessed. All of the
8 Peninsular Florida interconnected transmission system was analyzed to
9 determine whether thermal or voltage reliability criteria violations for system
10 elements at voltages of 69 kV and above occur as a result of the generation
11 resource addition. NERC or FRCC Reliability Standard violations on any
12 FPL or other Peninsular Florida system elements directly related to the
13 generation resource addition could indicate the potential need for transmission
14 reinforcements.

15 **Q. What factors associated with Turkey Point 6 & 7 have a major impact on**
16 **the results of the analysis?**

17 **A.** The requirement to add major transmission facilities is the result of the need
18 to deliver from 2,200 MW (from two 1,100 MW net units) to 3,040 MW
19 (from two 1,520 MW net units) of new generation northward from the
20 existing Turkey Point site in the southern most part of Miami-Dade County in
21 order to serve FPL's load. This results in significant transmission facilities
22 being required in the area from Turkey Point to central Miami-Dade County.

1 **Q. Please provide a general description of the transmission upgrades and**
2 **new transmission facilities required for Turkey Point 6 & 7.**

3 **A.** Turkey Point 6 & 7 will be connected to a new switchyard at the site. The two
4 units will be connected to the new switchyard at 500 kV. This new
5 switchyard will be connected by two 500 kV transmission lines to the 500 kV
6 section of the existing Levee substation in central Miami-Dade County, which
7 is located approximately 42 miles north of the Turkey Point switchyard. A
8 new 230 kV line, approximately 13 miles long, will also be required from the
9 Levee substation to the Gragny substation located north and east of the
10 Levee substation in central Miami-Dade County. The new switchyard at
11 Turkey Point will also have a 230 kV section. The new 500 and 230 kV
12 sections will be connected via a 500/230 kV auto-transformer. The new 230
13 kV section will be connected to the Davis substation in southern Miami-Dade
14 County utilizing an approximately 18 mile line which will be rerouted from
15 the existing Turkey Point plant switchyard and rebuilt to larger capacity.
16 Additionally, the 230 kV line rerouted from the existing Turkey Point plant
17 switchyard will be replaced with a new 230 kV circuit from the switchyard to
18 the Levee 230 kV substation. The aforementioned facilities are required for
19 either the 1,100 MW net units or the 1,520 MW net units. Finally, depending
20 upon the amount of generation output of Turkey Point 6 & 7, certain other 230
21 and 138 kV upgrades to existing facilities are required. A summary of the
22 base and additional facilities is set forth below:

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22

Base Facilities Required for Two 1,100 MW Net Units:

- The connection of Turkey Point 6 Generator Step Up (GSU) transformer to the new Turkey Point switchyard, and attendant bus equipment.
- The connection of Turkey Point # 7 GSU transformer to the new Turkey Point switchyard, and attendant bus equipment.
- The new Turkey Point 500/230 kV switchyard.
- The two 500 kV transmission lines from the new Turkey Point switchyard to Levee Substation.
- The 230 kV transmission line from the Levee Substation to the Gratiigny Substation.
- Rebuild and rerouting of the existing Turkey Point-Davis #1 230 kV line to the new Turkey Point 230 kV switchyard.
- Replace the line removed from the existing Turkey Point switchyard with a new line from the existing Turkey Point switchyard to Levee 230 kV line.
- Upgrade Killian-Turkey Point 230 kV line
- Upgrade Turkey Point-Galloway Tap 230 kV line
- Upgrade Davis-Montgomery 138 kV line
- Upgrade Dadeland Tap-Snapper Creek 138 kV line
- Two 5-Ohm Reactors installed on the 230 kV side of the autotransformers at Levee Substation

- 1 • Two 5-Ohm Reactors installed on the 230 kV side of the
- 2 autotransformers at Andytown Substation
- 3 • Two 5-Ohm Reactors installed on the 230 kV buses at the existing
- 4 Turkey Point 230 kV switchyard.

5

6 Additional Facilities Required for Two 1,520 MW Net Units:

- 7 • Upgrade Killian-Miller 230 kV line
- 8 • Upgrade Mitchell-Court 138 kV line
- 9 • Upgrade Kendall-Suniland 138 kV line
- 10 • Upgrade Marion-Village Green 138 kV line
- 11 • Upgrade Marion-Montgomery 138 kV line

12

13 These facilities for Turkey Point 6 & 7 are also summarized in Exhibit HJS-1.

14 **Q. Are there other factors associated with Turkey Point 6 & 7 that have a**

15 **potential to require additional transmission facilities or upgrades?**

16 **A.** Yes. The size of the single largest generator in Peninsular Florida is a

17 significant factor because the transmission system must be capable of

18 sustaining the loss of that generator without violating any NERC or FRCC

19 Reliability Standards. This requirement may have a direct impact on the

20 import capability from the Southeast Electric Reliability Council (SERC).

1 **Q. Will either Turkey Point 6 or 7 increase the size of the single largest unit**
2 **in the FRCC when they enter service?**

3 **A.** Yes. Prior to the addition of Turkey Point 6 or 7, Progress Energy Florida
4 plans to uprate its Crystal River nuclear unit to 1,080 MW gross output,
5 making it the largest sized unit expected to be in-service in the FRCC. Turkey
6 Point 6 & 7 are each expected to be larger than 1,080 MW gross output under
7 either unit size scenario.

8 **Q. Because a unit size of greater than 1,080 MW gross output will be selected**
9 **for Turkey Point 6 & 7, how will such a unit impact the FRCC's import**
10 **capability from SERC?**

11 **A.** The import capability into Peninsular Florida from SERC is in large part
12 determined by the contingency of the instantaneous loss of the largest unit in
13 the FRCC, and the attendant sudden in-rush of power from the eastern United
14 States interconnection reacting to replace such lost power source until more
15 generation is dispatched in the FRCC region (within thirty minutes).
16 Currently, based upon preliminary assessments by FPL, the sudden outage of
17 a unit size of approximately 1,200 MW gross output or less should not
18 adversely impact the FRCC's import capability from SERC in this time frame.
19 If the unit size increases, more detailed studies will be needed to determine the
20 specific impacts and mitigation alternatives.

1 **Q. What evaluation process and assessments must be performed to**
2 **determine how the capability of the transmission system would be**
3 **increased to accommodate a larger sized unit?**

4 **A.** First, FPL would complete its preliminary assessments. Next FPL would
5 request through the FRCC that an FRCC/SERC regional/inter-regional study
6 be performed to review the preliminary assessment findings performed by
7 FPL and to determine the requirements, if any, to the transmission systems
8 within the FRCC and SERC to accommodate a larger sized unit. Such a study
9 would be performed with members of the FRCC, SERC, and FPL. Initial
10 communications with the FRCC are currently underway to prepare for the
11 commencement of this study. It is expected that this study would take up to
12 24 months to complete. The 2018 and 2020 commercial operation dates for
13 Turkey Point 6 & 7 should not be affected so long as the results indicate that
14 any required transmission improvements within the FRCC and SERC regions
15 to accommodate a larger sized unit will be effective and feasible within this
16 time frame.

17
18 Subsequent to the completion of such a study, FPL would seek an affirmation
19 by the FRCC that the interconnection and integration plan for Turkey Point 6
20 & 7 is adequate and results in no reliability issues. Additionally, FPL would
21 seek a determination from the FRCC and SERC that the interconnection and
22 integration plan for Turkey Point 6 & 7, as it relates to any impacts on the
23 FRCC-SERC interface, is adequate and results in no reliability issues.

1 Q. Does this conclude your testimony?

2 A. Yes.

Summary of Required Facilities for Turkey Point 6 & 7

Base Facilities required for two 1,100 MW net units.

| Transmission Facility Item # | Voltage (kV) | Description |
|------------------------------------|-----------------|--|
| TF-1 | 500 | The connection of Turkey Point # 6 Generator Step Up (GSU) transformer to the new Turkey Point switchyard, and attendant bus equipment. |
| TF-2 | 500 | The connection of Turkey Point # 7 Generator Step Up (GSU) transformer to the new Turkey Point switchyard, and attendant bus equipment. |
| TF-3 | 500 | The new Turkey Point 500/230 kV switchyard. |
| TF-4 | 500 | The two 500 kV transmission lines from the new Turkey Point switchyard to Levee Substation. (Approximately 42 miles each) |
| TF-5 | 230 | The 230 kV transmission line from the Levee Substation to the Gratigny Substation. (Approximately 13 miles) |
| TF-6 | 230 | Rebuild and rerouting of the existing Turkey Point-Davis #1 230 kV line to the new Turkey Point 230 kV switchyard. |
| TF-7 | 230 | Replace the line removed from the existing Turkey Point switchyard with a new line from the existing Turkey Point switchyard to Levee 230 kV. (Approximately 42 miles) |
| TF-8 | 230 | Upgrade Killian-Turkey Point 230 kV line |
| TF-9 | 230 | Upgrade Turkey Point-Galloway Tap 230 kV line |
| TF-10 | 138 | Upgrade Davis-Montgomery 138 kV line |
| TF-11 | 138 | Upgrade Dadeland Tap-Snapper Creek 138 kV line |
| TF-12 | 230 | Two 5-Ohm Reactors installed on the 230 kV side of the autotransformers at Levee Substation (one per auto) |
| TF-13 | 230 | Two 5-Ohm Reactors installed on the 230 kV side of the autotransformers at Andytown Substation (one per auto) |
| TF-14 | 230 | Two 5-Ohm Reactors installed on the 230 kV buses at the existing Turkey Point 230 kV switchyard. |

Additional Facilities required for two 1,520 MW net units.

| | | |
|-------|-----|--|
| TF-15 | 230 | Upgrade Killian-Miller 230 kV line |
| TF-16 | 138 | Upgrade Mitchell-Court 138 kV line |
| TF-17 | 138 | Upgrade Kendall-Suniland 138 kV line |
| TF-18 | 138 | Upgrade Marion-Village Green 138 kV line |
| TF-19 | 138 | Upgrade Marion-Montgomery 138 kV line |

Note: These facilities do not include other potential facilities that may be required to mitigate the effect of the largest unit in the FRCC being larger than 1,200 MW gross output.