

# Exhibit B

070007-EI

## REDACTED DOCUMENTS

### REDACTED

CMP \_\_\_\_\_  
COM \_\_\_\_\_  
CTR \_\_\_\_\_  
ECR 1 \_\_\_\_\_  
GCL \_\_\_\_\_  
OPC \_\_\_\_\_  
RCA \_\_\_\_\_  
SCR \_\_\_\_\_  
SGA \_\_\_\_\_  
SEC \_\_\_\_\_  
OTH \_\_\_\_\_

DOCUMENT NUMBER-DATE

09620 OCT 22 5

FPSC-COMMISSION CLERK

**Q.**

**For each of the CAIR and CAMR controls included in the March 30, 2007 FPL Supplemental CAIR/CAMR Filing:**

- A. Compare the total costs of the control, stated in terms of net present value, including a breakout of capital costs and O&M, versus the next most cost-effective, viable alternative.**
- B. Provide a timeline for the completion of each project.**
- C. Provide the annual reductions in emissions expected to be achieved by each project versus the current emissions.**

**A.**

A. The CAIR and CAMR controls included in the March 30, 2007 FPL Supplemental CAIR/CAMR Filing are:

- SJRPP – SCR with ammonia injection
- SJRPP – Mercury CEMS
- Scherer 4- Wet FGD Scrubber
- Scherer 4- SCR with ammonia injection
- Scherer 4- Mercury CEMS
- Scherer 4- Fabric filter baghouse and mercury sorbant injection
- 800 MW cycling projects

Many of these CAIR and CAMR control projects have no viable alternatives. These projects are listed below:

- The mercury CEMS at SJRPP and Scherer 4 do not have alternatives as they are required to monitor the output level of mercury.
- The SCR controls at both Scherer 4 and SJRPP had no viable alternatives at the time the decision was made to install these controls. The installation of SCR controls on base load coal-fired steam boilers are considered by EPA as the most cost effective controls for the reduction of NOx emissions. The rules requiring the installation and operation of an SCR for NOx controls and an FGD for SO2 controls on Scherer Unit 4 were approved on June 27, 2007 by the Georgia DNR Board as an amendment to GA-391-3.
- The fabric filter baghouse and mercury sorbant injection at Scherer 4 was the technology specified for Scherer Unit 4 in the Amendments to the rules of the Georgia EPD relating to air quality, Chapter 391-3-01 and 391-3-02. The rules requiring the installation and operation of a baghouse for mercury

control on Scherer Unit 4 were also approved in the June 27, 2007 amendment of GA-391-3 by the Georgia DNR Board.

- The following project did have viable alternatives. See discussion below:
- The wet FGD scrubber at Scherer 4 did have a viable alternative: dry FGD scrubber technology. A consultant of Southern Company completed a study which showed that, based on lifecycle costs, the wet FGD scrubber was the more economic choice at Scherer 4. This study is included as Attachment I.
- And finally, for the 800 MW Cycling Project, FPL did not identify a viable alternative (other than a "do not implement" or "do nothing" alternative). The 800 MW project, in addition to substantial emission savings, produces large fuel savings which would make it more cost effective than any other control technology under consideration for FPL's CAIR compliance strategy. The economics of this project vs. the "do nothing alternative" are shown in response to Staff POD No. 11.

B. FPL's estimates for the completion of each project are as follows:

- **Installation of an SCR and Ammonia Injection System on SJRPP Unit 1** - Currently scheduled for an in-service date of May 01, 2009.
- **Installation of an SCR and Ammonia Injection System on SJRPP Unit 2** - Currently scheduled for an in-service date of May 01, 2008.
- **Installation of a FGD (Flue Gas Desulfurization) on Scherer Unit 4** - Currently scheduled for an in-service date of April 08, 2012.
- **Installation of an SCR and Ammonia Injection System on Scherer Unit 4** - Currently scheduled for an in-service date of April 08, 2012.
- **Installation of a Fabric Filter Bag House and Mercury Sorbent Injection System on Scherer Unit 4** - Currently scheduled for an in-service date of April 04, 2012.
- **Installation of a Mercury CEMS on Scherer Unit 4** - Currently scheduled for an in-service date of March 01, 2008.
- **Installation of a Mercury CEMS on SJRPP Unit 1** - Currently scheduled for an in-service date of December 01, 2007.

- **Installation of a Mercury CEMS on SJRPP Unit 2** - Currently scheduled for an in-service date of December 01, 2007.
  - **800 MW Cycling Project** - This is being completed in numerous stages as scheduled unit outages on the four effected units are completed. The project consists of numerous small items that can be completed separately in an efficient and cost effective measure, which minimizes system impact. At the current time, the estimated completion time of all aspects of the project is the summer of 2010.
- C. Attachment II shows the annual reductions in emissions expected to be achieved by each project versus the current emissions.



**Southern Company Services, Inc.  
Plant Scherer FGD Project**

**FGD Process Selection Study  
Comparative Evaluation of Wet and Dry Scrubbing**

**SCHR-1-LI-021-0001  
Rev. B**

**Nov. 2006**



**WorleyParsons**

resources & energy

Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

Appendices

- A. Basic Design Basis – Wet FGD
- B. Basic Design Basis – Dry FGD
- C. Flue Gas Flow Diagrams
- D. Conceptual Process Design – Wet FGD
- E. Conceptual Process Design – Dry FGD
- F. General Arrangements – Wet FGD
- G. General Arrangements – Dry FGD
- H. Life Cycle Cost Spreadsheets – Wet FGD
- I. Life Cycle Cost Spreadsheets – Dry FGD
- J. Basis of the Capital Cost Estimates
- K. Project Capital Cost Estimates – Wet & Dry FGD
- L. Major Equipment Lists – Wet & Dry FGD
- M. Project Milestone Schedules – Wet & Dry FGD
- N. Electrical Single-Line Diagrams - Wet & Dry FGD



Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

1. EXECUTIVE SUMMARY

**CONFIDENTIAL**

*Approach*


Plant Scherer is a four-unit, coal-fired electric generating facility that currently fires a low-sulfur Powder River Basin (PRB) coal. The units are not presently equipped with flue gas desulfurization (FGD) facilities. By the years 2010 and 2015, the Clean Air Interstate Rule (CAIR) requires system-wide reductions in sulfur dioxide emissions. At Plant Scherer, it is planned to install FGD facilities that will achieve a minimum 95% reduction in SO<sub>2</sub> emissions.

An initial screening study by Southern Company Generation identified two candidate FGD technologies that held the highest potential for successful application to Plant Scherer. The FGD processes so identified, and evaluated further in the present study, were the following:

- Limestone Forced Oxidation (LSFO), i.e., wet FGD, and
- Lime Spray Drying (LSD), i.e., dry FGD.

The current evaluation includes an increased level of engineering detail to support the capital cost estimates and to provide a more comprehensive, quantitative comparison of the two alternative FGD technologies being considered. Two coals were specified for the design basis: the present PRB coal with a 0.3%-S content, and a Central Appalachian (CAPP) bituminous coal with a 1.5%-S content. The CAPP coal was specified as the basis of the facility design and study evaluation, and the PRB coal was evaluated as an alternative case.

The primary tool for quantitative evaluation of the alternative technologies was the calculation of net present values (NPV's) for each alternative's life cycle costs. These costs included capital, for project design/construction, and operating & maintenance for 20 years of FGD facility operations. The results, for the two study coals, are as follows.



Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

*Recommendation*

The comparison of the net present value costs of the two FGD technologies considered in this study shows that the LSFO, or wet, technology has a significantly lower life cycle cost than the lime spray drying, or dry, technology for Scherer. Therefore it is recommended that Southern Company proceed with the installation of a wet type process to meet the SO<sub>2</sub> emission limits for Plant Scherer.





Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

## 2. INTRODUCTION

Plant Scherer is a four-unit, coal-fired electric generating facility that currently fires a low-sulfur Powder River Basin (PRB) coal. The units are not presently equipped with flue gas desulfurization (FGD) facilities. By the years 2010 and 2015, the Clean Air Interstate Rule (CAIR) requires system-wide reductions in sulfur dioxide emissions. At Plant Scherer, it is planned to install FGD facilities that will achieve a minimum 95% reduction in SO<sub>2</sub> emissions.

An initial screening study was performed by Southern Company of means to meet this SO<sub>2</sub> emission reduction target. The study identified two candidate FGD technologies for application at Scherer: a wet scrubbing process (limestone forced oxidation) using limestone reagent, and producing gypsum byproduct; and a dry scrubbing process (lime spray drying) using a lime-based reagent, and producing a dry by-product.

In the present study, WorleyParsons was commissioned to perform a more detailed evaluation of these two alternative flue gas desulfurization technologies for Plant Scherer, to develop a recommendation for implementation and to document the work process and results.

The primary tool for evaluation of the alternative technologies was the calculation of net present values (NPV's) of the life cycle costs for each of the two alternatives. The development of the components of the life cycle costs were based on

- Project-specific conceptual engineering,
- Site-specific operating & maintenance costs, and
- Financial parameters specific to Southern Company for Scherer.

The process evaluation also addressed consideration of qualitative and quantitative issues, such as:

- facility layout and maintenance access,
- space and constructability considerations,
- reagent receiving, handling & storage,
- FGD byproduct handling and storage/disposal, and
- process wastewater generation.

## 3. STUDY BASIS

### 3.1 Plant Description

Plant Scherer is located near Juliette, GA. The plant generating facilities consist of 4 near-identical coal-fired, steam-electric units, each with a nameplate rating of 818 MW. The units were placed in commercial service in succeeding years during the period 1982-1989. The steam generators are sub-critical, tangentially-fired, units that operate in balanced draft with a set of 2 FD fans, a set of 4 ID fans and cold-side electrostatic precipitators, each.



Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

All four units currently fire a sub-bituminous Powder River Basin (PRB) coal, although Units 3 & 4 were originally designed for low-sulfur Central Appalachian coal. It is desired to maintain as much of this fuel flexibility as possible for future operations.

### 3.2 Conceptual Engineering Basis

#### 3.2.1 Design Criteria

The key design criteria for the FGD facilities are tabulated in the Basic Design Basis documents in Appendices A (wet FGD) and B (dry FGD).

Of particular note in these criteria is the specification of two design coals: the current low-sulfur PRB coal (about 0.7 lb SO<sub>2</sub>/MMBtu, 0.3% S) and a future Central Appalachian (CAPP) bituminous coal (about 2.3 lb SO<sub>2</sub>/MMBtu, 1.5% S). The FGD facility, using either the wet or the dry process, is to be capable of operating with either coal while maintaining specified performance. Consequently, the sizing of gas-side components is dictated by the larger gas flow rate associated with the PRB coal, whereas sizing of the solid/liquid systems (i.e., reagent handling, reagent prep, slurry handling, process water, etc.) is dictated by the larger sulfur content of the CAPP coal.

#### 3.2.2 Air Quality Control Project Integration

In addition to these quantitative design criteria, a critical consideration in the planning and evaluation of the FGD project is the recognition of the sequence of air quality control (AQC) projects that is to be implemented at Scherer. These projects are depicted functionally in the flow diagrams in Appendix C (sketches SCHR-0-SK-253-305-001 through -005).

The current 'back-end' configuration is shown in the first sketch (-001). Flue gas exits the boiler casing at the economizer hopper and then passes successively through the air heaters, the electrostatic precipitators, the ID fans and is discharged to the stack. The flyash collected in the precipitator is recovered (by a third party contractor) for commercial sale.

The first AQC projects to be implemented will be the addition of facilities to each unit for removal of mercury from the flue gas (sketch -002). Here, the existing ductwork train will be broken between the discharge of the ESP's and the suction of the ID fans and the gas flow processed through new baghouses (or pulse jet fabric filters, PJFF's) following the injection of the active media, carbon. At this time, it is also planned to upgrade the ID fans by increasing their head capability to overcome the additional draft loss created by the new flue gas train components. After addition of the baghouses, it is planned to continue operation of the precipitators to support flyash sales commitments. (Note that collecting the flyash in the baghouses would result in flyash contamination with carbon.)

The next series of AQC projects will be the addition of selective catalytic reduction (SCR) systems to each unit for the removal of nitrogen oxides (sketch -003). For installation of this facility, the existing flue gas train will be broken between the economizer discharges and the air heater inlets, and the flue gas processed through SCR reactors following the injection of ammonia for NO<sub>x</sub> reduction. It is anticipated that the



Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

upgrade of the ID fans, implemented during the mercury baghouse projects, will also provide sufficient head capability to operate the new SCR gas-side components.

The third and final phase of the AQC projects will be the addition of the FGD facility; the two alternatives are depicted in sketches -004 (wet FGD) and -005 (dry FGD).

- To install the wet FGD facility, the existing flue gas train on each unit will be broken at the discharge of the ID fans and new ductwork will feed the flue gas to a pair of booster fans, a single absorber vessel and exhaust through a new 'wet' dual-flue stack (common stack for each pair of units: 1&2, 3&4). A gas bypass path around each absorber is not included, but rather the existing stacks will be maintained for FGD system bypass operation via the indicated gas-side dampers.
- To install the dry FGD facility, a significant reconfiguration of the ductwork is required to achieve functional integration of the ID fans into the FGD facility. The baghouse supply and return ductwork (installed with the mercury control project) must be removed from tie-in points between the precipitators and ID fans, and reconstructed to originate from the discharge of the ID fans and to return to the existing stack. In addition, the supply ductwork must be reconstructed to incorporate the lime spray dryers. As with the wet system, a gas bypass path around the SO<sub>2</sub>-removal vessels (the spray dryers) is not included, but rather the ductwork incorporates a FGD system bypass.

### 3.2.3 Other

The retrofit of an FGD system to the Scherer boilers should also meet the following objectives.

- Comply with the emission requirements established by the state of Georgia for compliance with the Clean Air Interstate Rule (CAIR)
- Have minimal impact on other plant emissions
- Exhibit the lowest evaluated cost (net present value of 20-yr life cycle cost) of available alternatives
- Minimize plant impacts, such as unit capacity, efficiency, availability, and ramp rate, due to the operation of the FGD system

### 3.3 Economic Evaluation Criteria

The following parameters were used in the economic evaluation of the two alternative scrubbing technologies. All values were specified by Southern Company Generation, except as noted.



Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

Table 3-1  
Economic Evaluation Parameters

A B C D

Note 1: Forecasted unit costs (\$/T) for rail-delivered lime and limestone were provided year-by-year (by SoCo) for the time period 2011-2024. Extrapolated values (by WorleyParsons) were used for the time period 2025-2034. Specific values are listed in the spreadsheets contained in Appendices H and I.

Note 2: The present study is based on a gypsum handling process in which the absorber bleed slurry is pumped directly to a new, on-site gypsum pond, where the gypsum is allowed to settle out and the water recycled to the scrubbing operation. The cost of constructing the pond is included in the project capital cost. A cost of \$100,000/yr has been assessed (by WorleyParsons) for (drag-line) stacking of the gypsum at the pond area and is included in annual O&M charges for the wet FGD facility.

Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

Note 3: The present study is based on (on-site) landfill of the dry FGD byproduct. The cost of constructing the landfill is included in the project capital cost. Costs for both labor and mobile equipment to haul the material to the landfill from the process area and to stack/compact it in the landfill are included in the annual O&M costs for the dry FGD facility as described in Section 5.2.

Note 4: Forecasted unit costs (\$/T SO<sub>2</sub>) for SO<sub>2</sub> credits were provided year-by-year (by SoCo) for the time period 2011-2024. Extrapolated values (by WorleyParsons) were used for the time period 2025-2034. Specific values are listed in the spreadsheets contained in Appendices H and I.

Note 5: The unit costs listed are an 'all-in' annual costs, that were derived (by WorleyParsons) from hourly salary rates (provided by SoCo), as described in Section 5.2.

Note 6: The values listed in the table were taken from year-by-year, unit-specific data provided by SoCo, and are the forecasted daily cost for the FGD tie-in year for each unit.

#### 4. FGD SYSTEMS CHARACTERIZATION

##### 4.1 Process Descriptions

The following section contains process descriptions of the two technologies chosen by Southern Company for potential retrofit on Plant Scherer to reduce SO<sub>2</sub> emissions. These technologies were chosen on the basis of SO<sub>2</sub> removal capability, commercial experience, current availability, compatibility with projected fuels, affect on current emission limits, byproduct management and reagent availability.

##### 4.1.1 Limestone Forced Oxidation (LSFO) – Wet FGD Process

Refer to the process flow diagrams (SCHR-0-SK-021-305-001, SCHR-0-SK-021-305-002 & SCHR-0-SK-569-304-001) for the wet FGD process in Appendix D.

In the past 20 years, the LSFO process has evolved as the preferred wet FGD technology worldwide. LSFO offers the advantage of controlled oxidation of reaction products and potentially scale-free operation of the wet scrubber. Depending on process-specific conditions, LSFO may produce a salable byproduct in the form of commercial-grade synthetic gypsum that can be used for wallboard manufacturing or other industrial applications. A list of major equipment included in the LSFO facility is included in Appendix L.

##### *Gas Scrubbing*

In the LSFO process, hot flue gas exiting the ESP and ID/booster fans enters an absorber vessel where it is contacted with a dilute calcium carbonate and calcium sulfate slurry. The SO<sub>2</sub> reacts with the calcium carbonate in the limestone particles and the slurry drains into the reaction tank at the base of the vessel, where the neutralizing reactions are completed. After contact with the reagent spray, the flue gas continues an upward



Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

vertical flow to multiple stages of mist elimination to remove the mist droplets from the gas stream. Then the flue gas exits the absorber through the outlet duct and discharges through the stack.


Within the reaction tank/absorber vessel, the calcium-bearing solids are suspended with agitators to facilitate the neutralization reactions. Fresh reagent and make-up water are periodically added as needed to keep the recirculation tank at optimum conditions for reactions to occur. Large slurry recirculation pumps are used to continually transport the slurry into the absorber vessel for reintroduction into the flue gas. Recirculation piping and spray nozzles provide fine slurry droplets within the flue gas stream to provide a large slurry droplet surface area to enhance the gas to liquid contact in the spray zone. As solids build-up in the reaction tank, bleed pumps maintain tank density to optimum conditions by transporting the solids to the dewatering process.

Generally, additives are not required in the LSFO process since the gypsum crystals resulting from this process tend to be relatively large, dense crystals that do not retain water. The solids coming from the dewatering process are typically 90%+ gypsum and inerts. This material is self-supporting and can be trucked, conveyed and moved using a front-end loader, or other conventional earth-moving equipment.

The LSFO process requires makeup water to replace the losses that occur through evaporation and the liquor entrained in the byproduct solids. Some of this makeup water can be supplied from any source that is not saturated with respect to any dissolved solids and contains a relatively low concentration of suspended solids. When producing a wallboard-grade gypsum product, the quality of the makeup water to the FGD system may have more restrictions than if the product solids were being sent to a landfill. For example, only low TDS/TSS water should be used for washing the gypsum cake to reduce chloride content and eliminate contamination of the gypsum byproduct. Chlorides must be maintained below a specified maximum concentration (as determined by material selection) to prevent excessive corrosion of wetted components.

The mist eliminator wash stream must be higher quality water to maintain scale-free operation. This intermittent wash water stream serves as a portion of the scrubber makeup water. If poor quality wash water is used for makeup, or if scrubber liquor is utilized, this typically will lead to heavy scale formation that can not be removed without taking the unit off-line for manual cleaning. In some cases, the use of saturated wastewater has led to the complete blockage of the mist eliminators.

The chemistry for this process begins with limestone ( $\text{CaCO}_3$ ), the absorbing reagent, fed to the absorber reaction tank in an aqueous slurry at a molar feed rate of 1.03-1.05 moles of  $\text{CaCO}_3$ /mole of  $\text{SO}_2$  removed. The major product of  $\text{SO}_2$  reaction with limestone is the formation of hydrated calcium sulfite ( $\text{CaSO}_3 \cdot \frac{1}{2}\text{H}_2\text{O}(\text{s})$ ) according to the following reaction:




The sulfite is oxidized to sulfate by the injection of air into the bottom of the absorber sump, and then hydrated to form gypsum ( $\text{CaSO}_4 \cdot 2\text{H}_2\text{O}$ ) through the following reaction:



Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B



In addition to the LSFO chemistry occurring in the absorber vessel and reaction tank, two other process steps are needed – reagent preparation and solids dewatering.

#### *Reagent Preparation*

As configured for the Scherer project, limestone is delivered by rail and discharged into a under-track hopper. From this hopper the limestone is conveyed and deposited on the storage pile by a radial stacker. A plant dozer will be used to move the limestone into a storage pile, and also to reclaim the limestone into the below-grade reclaim hopper. The reclaim system includes a vibrating feeder and conveyor system to transfer limestone to the day bins. Limestone day bins and feeders supply limestone to the horizontal ball mills, which wet-grind the limestone to produce a slurry for use in the wet scrubber. The small limestone slurry particle size produces a large surface area for gas contact without excessive power consumption by the ball mill. The limestone slurry product is discharged to a limestone slurry storage tank, and then transferred to smaller feed tanks at the scrubber islands (a common tank for each unit pair) via slurry pumps.

#### *Solids Dewatering*

The solids dewatering process proceeds after the solids are precipitated in the absorber tower. The  $\text{SO}_2$  reaction with calcium carbonate initially forms calcium sulfite, which is subsequently oxidized to calcium sulfate (gypsum) in the absorber reaction tank. This oxidation process is accomplished by forcing air through spargers that are immersed in the reaction tank slurry inventory. The formation of gypsum crystals in the slurry helps to reduce scaling potential by providing suspended crystal surface for crystal growth and reducing the calcium sulfate saturation level in the slurry. A minimum level of calcium sulfate super-saturation is required to initiate gypsum crystal formation.

A balance between product gypsum and fresh limestone feed in the absorber reaction tank is maintained by removing a 'bleed' stream of slurry from the reaction tank inventory. In the Advatech absorber design, the absorber slurry inventory is operated at a concentration of 30 wt% solids. For the application at Scherer, this bleed stream from each of the four unit absorbers will be pumped to a new settling pond, where the slurry will be allowed to separate into its solid (gypsum) and liquid components. The sludge that settles is typically a 70/30 solids/liquid mixture, and the balance of the water will be reclaimed for re-use in the process.

Of the reclaimed water, a modest portion must typically be discharged, i.e., blown down, to maintain chloride concentration in the absorber below a maximum allowable value (normally 5,000-20,000 ppmw, depending on material selection). The balance of the reclaimed water is used for water supply to the limestone grinding operation and for makeup into the absorber reaction tank.



Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

#### 4.1.2 Lime Spray Drying (LSD) – Dry FGD Process

Refer to the process flow diagrams (SCHR-0-SK-021-305-201, SCHR-0-SK-021-305-202 & SCHR-0-SK-569-304-002) for the dry FGD process in Appendix E. A list of major equipment included in the LSD facility is included in Appendix L.


##### *Overview*

The lime spray drying process is a semi-dry FGD process that produces a dry mixture of fly ash and reaction products. The application of the lime spray dryer FGD process to coal-fired boilers is limited to medium and low sulfur fuels, in most cases where a SO<sub>2</sub> removal efficiency of 95% or less is required. The sulfur content of the coals specified for the FGD project at Scherer and the SO<sub>2</sub> removal efficiency required make the LSD process a candidate for the present application.


In the spray drying absorption process, flue gas enters the spray dryer absorption (SDA) module via the gas distribution system which spreads the incoming flue gas symmetrically around the atomizer. The atomizer, which is used to atomize the feed slurry (i.e. a mixture of hydrated lime slurry and recycle solids slurry) into a fine spray and inject it into the flue gas, can be either a rotary design or an air-atomized, two-fluid nozzle design. The finely atomized feed slurry mixes with the flue gas, resulting in the evaporation of water and the removal of the SO<sub>2</sub> via chemical reaction with the slurry.

The quantity of water contained in the atomized spray is precisely controlled so that it completely evaporates in suspension. Absorption of SO<sub>2</sub> takes place primarily as the flue gas is cooled adiabatically by the evaporation of the water contained in the atomized spray. The difference between the temperature of flue gas leaving the SDA and the adiabatic saturation temperature is known as the approach temperature. Reagent stoichiometry, residence time and approach temperature are the primary variables that control the SO<sub>2</sub> removal efficiency in the SDA module.


The primary product of the reaction between the hydrated lime, Ca(OH)<sub>2</sub>, component of the feed slurry and the SO<sub>2</sub> is hydrated calcium sulfite, according to the following relationship.



A smaller portion of the sulfur dioxide may also react with oxygen in the flue gas to produce the secondary product of calcium sulfate dihydrate by the following reaction.



Sulfur trioxide is also found in the flue gas in small amounts. The sulfur trioxide reaction produces additional calcium sulfate dihydrate by the following.



The majority of the water added to the lime in the initial hydration process is evaporated in the absorber. There are no wastewater streams exiting the absorber. The degree of





Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

reaction depends on the amount of liquid present, the approach to the adiabatic saturation temperature and the residence time for drying.

As the flue gas and feed slurry mixture passes through the SDA module, the spray drying and initial SO<sub>2</sub> removal processes are completed. The SDA module is designed to insure that most of the particulate that can be entrained in the flue gas is carried to the fabric filter dust collector, which is usually of the pulse-jet fabric filter (PJFF) type. The larger, coarser particulate that is not entrained in the flue gas is discharged from the bottom of the SDA module hopper for disposal.

The flue gas and entrained reaction products, un-reacted reagent, and flyash exit the SDA module and then flow into the PJFF, wherein additional SO<sub>2</sub> as well as particulate removal takes place. The reaction products, un-reacted reagent, and flyash collected in the PJFF hoppers is then conveyed by the ash handling system to either the recycle ash storage silo for reuse or the waste ash storage silo for disposal. Upon exiting the PJFF, cleaned flue gas is directed to the booster fans which discharge to the stack.

#### *Spray Dryer Absorber (SDA)*

Flue gas is introduced into each SDA module by means of a gas disperser and a roof gas distributor. The purpose of the gas dispersers is to distribute the incoming flue gas symmetrically around the atomizer unit at a velocity and direction appropriate to assure optimum absorption of the acids contained in the flue gas. In the rotary atomizer design, the roof gas disperser has a scroll inlet, which delivers the flue gas to the tapered, annular discharge nozzle positioned around the atomizer. Guide vanes are constructed of abrasion-resistant material and are mounted in the disperser discharge outlet. The purpose of the vanes is to distribute the flow of flue gas uniformly around the atomizer. Careful control of the gas distribution, slurry flow rate and droplet size assures that the droplets are evaporated to dryness prior to contacting the internal walls of the SDA module.

#### *Rotary Atomizer*

The rotary atomizer converts the feed slurry to a uniform, finely divided spray of droplets. The rotary atomizer is a precision-made machine designed for high-speed operation and is driven by a vertical, flange-mounted motor specifically designed for the atomizer.

The rotary atomizers are withdrawn from the top of the SDA module for periodic servicing. Gas flow through the SDA module may be maintained when the atomizer is removed for service. A hoist and trolley is typically used to facilitate the change out of the rotary atomizer.

#### *Pulse Jet Fabric Filter*

Flue gas with SDA reactant products and boiler fly ash enters the fabric filter inlet plenum and is distributed to each of the individual compartments. The inlet baffle distributes gas and particulate evenly to the filter bags. A portion of the gas is directed downward from the top of the bags minimizing upward velocity and enhancing on-line cleaning. Each filter bag is supported on a wire cage. The bags and cages are



Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

independently suspended from the PJFF tubesheet at the top of each compartment.

Flue gas flow is primarily horizontal and downward through the bags. This flow pattern enhances even gas distribution and minimizes reentrainment when pulsing on line. Collected particulate is cleaned from the bags by pulsing with dried, intermediate pressure compressed air (35 psig) while the compartment remains on line filtering flue gas. The pulse of air dislodges the collected particulate from the bags causing it to fall into the hopper. This material is then conveyed to storage for recycle or disposal. Clean gas exits upward from the filter bags, through the tubesheet and out to the outlet or clean air plenum.

A louver type damper is used to provide inlet isolation for each compartment. The inlet dampers are closed only when a compartment must be isolated for personnel entry when other compartments remain on line. Each compartment also includes poppet type outlet dampers. The outlet dampers must be closed to isolate a compartment for personnel entry, or they can be used for off-line cleaning.

The same type of poppet type damper is also used for system bypass. The poppet design creates a gas and dust tight seal at the common wall between the inlet and outlet plenums. These dampers provide a very reliable metal-to-metal seal without the use of wiper seals or air purge systems. The sealing plate is comprised of several metal discs that provide full contact with a machined metal seat when the damper is closed.

The PJFF control system can be set to operate automatically or manually. The filter bags in each jet assembly are cleaned two rows at a time. Each row of bags has a double diaphragm valve and solenoid which directs a controlled pulse of dry compressed air from the air header to the manifold located above the row of bags.

#### *Lime Preparation*

Pebble lime is delivered by rail car, and discharged into an under-track hopper. From the hopper it is transferred by conveyor directly to one of six covered lime storage silos.

The lime preparation system performs the hydration of pebble lime with process water to prepare hydrated lime slurry at approximately 20-25 wt% suspended solids concentration, for spraying into the SDA module. Lime is discharged from each storage silo through a weigh feeder and is fed to an individual lime slaking system, where it is wet-ground and hydrated in a vertical ball mill (or vertimill). The lime slurry product that is discharged from each slaker train is pumped to a common lime slurry storage tank. From this main slurry storage tank, the slurry is transferred to smaller feed tanks at the scrubber areas (a common tank for each unit pair) via slurry pumps.

Lime slurry feed pumps draw suction from the slurry feed tanks and discharge into the lime slurry feed loops. The lime slurry feed loops supply lime slurry to the SDA's for the spray drying process. Constant pump speeds and pipeline velocities are maintained to eliminate settling or caking within the lime slurry feed loop.

Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

### *Recycle Slurry Preparation*

The recycle slurry preparation system provides for mixing of solids collected from the SDA's and PJFF's with process water to prepare recycle slurry at up to 45 w% suspended solids concentration for spraying into the SDA module. The recycle slurry enhances utilization of the lime reagent as well as promoting droplet drying in the SDA modules.

FGD by-product solids being returned to the process are conveyed pneumatically by a (new) ash handling system to the recycle solids silo (one per unit). A bin vent filter captures dust released during silo filling. Recycle material is discharged from the recycle solids silo through a fluidized outlet cone and flows to one of two (2) 100%-capacity recycle slurry preparation trains.

The recycle solids discharged from the storage silo are combined initially with process water in a wetting box. The recycle solids/water mixture that is discharged from the wetting box flows by gravity into the recycle mix tanks where additional water is added. The recycle slurry that is discharged from the recycle mix tank flows via gravity through a vibrating grit screen to remove oversized particles larger than 8 mesh from the recycle slurry. The grit discharged from the grit screen flows via gravity to a disposal bin. Recycle slurry underflow from the vibrating grit screen flows via gravity to the recycle slurry storage tank.

Two, 100%-capacity centrifugal pumps are used for the recycle slurry feed service. Constant pump speeds and pipe line velocities are maintained to eliminate settling or caking within the dedicated recycle slurry supply line to the atomizer head tank.

### *Waste Solids*

Excess solids from the scrubbing process, not used for recycle, are pneumatically conveyed to the by-product storage silos (one each for each pair of units). This material is discharged from each silo through a pin mixer, where it is wetted to control dusting, and is dropped into a dump truck. Large, 100-T trucks are used to haul the material to the on-site landfill.

## 4.2 Process Operating Characteristics

To quantify the operation of the processes, project-specific combustion calculations, process flow diagrams and mass balances were developed for each of the two alternative FGD processes for each of the two project coals. This information is contained in Appendices D (wet FGD) and E (dry FGD).

At the present conceptual level of engineering, the operation of all four of the Scherer units was treated as identical (as reflected in the Basic Design Basis documents).

The tables in this section were derived from the calculational results in Appendices D & E, and provide the rates of commodity usage/production that enter into the calculation of variable O&M costs.



Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

Table 4-1  
Annual SO<sub>2</sub> Mass Balances @ 85% Capacity Factor (tons/yr)

Process	Coal	Input Unit	Removed Unit	Discharged Unit	% SO <sub>2</sub> Removal
Wet	CAPP	79,090	75,920	3,170	96.0
Dry	CAPP	79,090	75,130	3,960	95.0
Wet	PRB	23,570	23,100	470	98.0
Dry	PRB	23,570	21,870	1,700	92.8

The sulfur dioxide removal rates for the wet FGD process are those quoted by Advatech for the specified coals, and represent operation of a single-pass Advatech scrubber vessel.

The sulfur dioxide removal rates for the dry FGD process were estimated by WorleyParsons based on in-house process design experience. For both coals, these dry FGD performance values represent the upper limit of the capabilities of this technology. In the case of operation with PRB coal, the removal rate is limited by the concentration of SO<sub>2</sub> in the outlet flue gas (about 17 ppmv, see the material balance in App. E); that is, the process is not capable of removing SO<sub>2</sub> below this concentration.

Table 4-2  
FGD Facility Operating Characteristics at Full Load – Per Unit

FGD Process	Coal	SO <sub>2</sub> Removal (lb/hr)	FGD Reagent Feed (lb/hr)	FGD Byproduct Production (lb/hr)	FGD Makeup Water Usage (gpm)
Wet	CAPP	19,990	41,310	74,850*	1,285
Dry	CAPP	20,150	40,680	78,420	997
Wet	PRB	6,210	12,050	23,570*	1,110
Dry	PRB	5,870	11,500	23,510	1,022

(\*) dry basis

The mass feed rates of the two reagents, limestone and lime, are very nearly numerically equal for a given coal, reflecting a much higher calcium usage for the dry process as compared to the wet process (limestone, i.e., calcium carbonate, weighs 2.50 lb per lb of contained calcium, whereas lime, i.e., calcium oxide, weighs 1.40 lb per lb of contained calcium; hence equal mass feed rates of limestone and lime implies a significantly higher

Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

calcium feed rate for the lime case). The wet process is designed with a Ca/S stoichiometric ratio of 1.03, whereas the dry process requires a ratio of about 2.0. This high Ca usage for the dry process is a result of operating this technology at the limit of its capability.

The approximately equal mass rates of byproduct production for both processes, given the differences in Ca feed rates, is a result of differences in the chemical composition of compounds formed in the scrubbing process (i.e., calcium sulfate di-hydrate vs. calcium sulfite), as well as the excess, unreacted lime in the case of dry scrubbing. The chemical composition of the byproducts is described in Section 7.6.

The makeup water requirements, for a given coal, differ between the two processes due to the differences in the flue gas conditions exiting the FGD absorber vessels. The dry technology only requires that the flue gas temperature be reduced to within 35F of the saturation point, whereas the wet technology produces a saturated gas; thus there is less water lost to evaporation in the dry process.

Table 4-3  
FGD System Power Consumption at Full Load

FGD Process	Aux. Power / Unit (kW)
Wet	45,000
Dry	27,000

The auxiliary power consumption values listed in Table 4-3 represent order-of-magnitude estimates of time-averaged FGD-based load. The values include, in addition to operation of unit-specific process facilities, power consumption by the booster fans as well as a proportioned share of FGD common facilities. At the present conceptual level, differences in auxiliary power consumption due to operation with the two different design coals were not considered.

#### 4.3 Facility Arrangements

Conceptual-level arrangement drawings were developed for both the wet FGD and dry FGD facilities, including the gas flow train components, the reagent handling and preparation facilities and the by-product storage/disposal areas. These drawings are presented in Appendices F (wet FGD) and G (dry FGD).

These drawings serve to assess overall technical feasibility, to identify key constructability and tie-in issues, and to provide a basis for developing much of the engineering data required for the capital cost estimates.

Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

#### 4.3.1 Wet FGD

The arrangement of the wet FGD facilities reflects on-going work within SoCo Generation, and also incorporates the physical arrangement of the Advatech 'scrubber island'. The Unit 1 & 2 scrubber islands are grouped around a (new) common, two-flue stack to the south of the power block, with the new booster fans directly behind (to the east) of the existing stack. Adjacent to the new stack is a Unit 1 & 2-common electrical building that houses electrical distribution equipment, the new DCS cabinetry and miscellaneous other facilities.

The Unit 3 & 4 scrubber facilities are arranged similarly, to the north of the power block, but reflect the fact that the larger precipitators on these two units has restricted available space directly behind the boilers and has required that the new booster fans be located adjacent to the scrubber islands.

Four-unit common limestone receiving, storage and preparation facilities are located on the north side of the coal pile area. New rail spurs are provided for limestone delivery, and a radial-stacker conveyor system is used to transfer the limestone to the storage area from the car unloading area. A new access road around the limestone pile is included for emergency delivery of limestone by truck. Limestone is reclaimed from the pile and transferred via conveyor to the limestone preparation area.

The limestone preparation facilities are housed in a building, located adjacent to the limestone storage area. Limestone is received in two day silos, each feeding an individual, horizontal ball mill grinding operation. Limestone slurry product is discharged to an outside storage tank, prior to transfer to (smaller) feed tanks at the scrubber islands.

The new gypsum pond has been located about ½-mile to the north, adjacent to the existing ash pond, and makes use of a naturally-occurring valley. Slurry bleed is pumped out to this pond area, and reclaimed water is pumped back to a storage tank in the limestone preparation area for re-use in the process (primarily limestone grinding).

#### 4.3.2 Dry FGD

In developing conceptual arrangements for the dry FGD facilities, the approach used was to consolidate the locations of the various gas-side components to the maximum extent deemed feasible, because of the need to demolish/reconstruct ductwork during FGD system installation (as described in Section 3.2.2). Although SoCo has subsequently decided not to pursue this arrangement, should a dry FGD system be implemented, it serves as the basis for the current evaluation. The alternative approach of using more spread-out locations for the baghouses, as is currently planned for the mercury control projects, will result in dry FGD project costs that are increased over those estimated in the current study.

The process of developing these arrangements for the dry FGD facility has also resulted in the recognition that implementation of a cost-effective dry scrubber project requires that *the mercury control project and a dry FGD project should be designed as integrated*



Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

*projects and constructed in a sequential manner that minimizes reconstruction requirements and tie-in outage durations.*

The arrangement developed for the present study 'stacks' the baghouses, that is, the Unit 2 baghouse is stacked on top of the Unit 1 baghouse, and also uses a comparable under/over arrangement for the ductwork. A similar arrangement is used for Units 3 & 4. For Units 1 & 2, all of the major gas-side components (booster fans, spray dryers and baghouses) are located in the open area behind the units, between the stack and the existing access road. To the south are common facilities for these two units: an 'ash' silo, for storage of dry FGD by-product, and a building that houses the ash recycle facilities as well as electrical/DCS equipment.

The Unit 3 & 4 facilities follow a similar grouping, but must be located to the north of the existing stack, again due to the size of the Unit 3 & 4 precipitators, thus requiring more extensive ductwork runs.

Four-unit common lime receiving, storage and preparation facilities are located on the north side of the coal pile area. New rail spurs are provided for pebble lime delivery, and lime is transferred via conveyor from the below-grade unloading hopper to a set of 6 concrete storage silos. Individual lime slaking trains are housed in the bottom of each silo and are fed directly from the silo discharge hoppers. Lime slurry product is discharged to a common storage tank in the silo area, prior to transfer to (smaller) feed tanks in the absorber areas.

The landfill area, for disposal of the dry FGD by-product, has been located about ¼-mile to the north, adjacent to the existing ash pond, and makes use of a naturally-occurring valley. A new access road runs out to this disposal area, connecting to existing plant roads, that is used to haul the FGD by-product from the two silos in the scrubber area to the landfill via 100-T trucks.

## 5. ECONOMIC ANALYSIS

### 5.1 Approach

The economic performance of each of the two alternative scrubbing technologies was evaluated using a life cycle cost methodology. This type of analysis calculates the net present value of the cash flow associated with a given scenario, or alternative.

For the present study, year-by-year cash flows were developed, covering the period of project construction followed by 20 years of operation for each unit. Costs were developed to describe the two major phases of the commercial life of the FGD facilities.

- Capital costs, for design, construction and commissioning of the facilities.
- Operating & maintenance costs, for materials and labor to operate and maintain the facilities.



Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

The net present value (NPV) calculations were evaluated per the following relationship.

$$\begin{aligned}\text{Life Cycle Cost (\$)} &= \text{Sum of Discounted Annual Cash Flow} \\ &= \text{Net Present Value [ (yr-by-yr capital cash flow) +} \\ &\quad \text{(20 yrs of yr-by-yr O\&M costs) ]}\end{aligned}$$

A levelized unit cost was also calculated, which is defined as

$$\text{Levelized Unit Cost (\$/T SO}_2\text{ Removed)} = \text{NPV (\$)} / \text{(Tons of SO}_2\text{ Removed in 20-yr Life),}$$

where the denominator is calculated at the target removal efficiency of 95%.

## 5.2 O&M Costs

Operating and maintenance (O&M) cost estimates, specific to each technology, were developed on an annual basis. Specific costs were estimated for the following categories of O&M requirements.

- Fixed O&M Costs
  - FGD operating labor (additional new employees)
  - FGD facility maintenance (both labor and material)
  - FGD Administrative and Support Costs
  - Landfill operations
  - Fabric filter bag replacement (dry FGD only)
- Variable O&M Costs
  - FGD reagent supply
  - FGD auxiliary power consumption
  - FGD water consumption
  - SO<sub>2</sub> credits

The unit costs used to estimate these components of annual O&M costs were presented in Sec. 3.3.

### 5.2.1 Fixed

Fixed O&M costs refer to those costs that are independent of the number of hours of plant operation and type of coal fired.

#### *Operating Labor*

The number of new plant employees, required to support FGD facility operations, was estimated as shown in the following table for both the wet and dry FGD facilities.





**CONFIDENTIAL**

Florida Power & Light  
Docket No. 070007-E1  
Staff's Fourth Set of Interrogatories  
Interrogatory No. 36  
Attachment I, Page 22 of 131

Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

Table 5-1  
Estimate of FGD Operating Personnel (Plant-Wide)



# CONFIDENTIAL

Florida Power & Light  
Docket No. 070007-E1  
Staff's Fourth Set of Interrogatories  
Interrogatory No. 36  
Attachment I, Page 23 of 131

- 1 Southern Company Services
- 2 Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

3 The approach taken was to estimate separately, for the dry FGD facility, operating  
4 personnel requirements for the by-product landfill operation. Treatment of these costs is  
5 described in (the following) Section 5.2.2.

6 In this table, in addition to developing operating personnel requirements, the average  
7 wage rate is developed as a function of the skills mix, using hourly wage rates provided  
8 by SoCo for Plant Scherer. The annual all-in cost, used in the O&M estimate, was  
9 calculated as follows:

$$10 \quad \text{Annual Avg. Cost (all-in)} = \text{Hrly Rate (\$/hr)} * 1.6 * 2080 \text{ (hrs/yr)},$$

11 where the factor of 1.6 was applied to account for indirect costs (i.e., benefits, overhead,  
12 G&A).

13 Operating labor costs were then calculated for each technology from the relationship

$$14 \quad \text{Annual Cost} = \text{No. of Operating Personnel} * \text{Annual Avg. Cost}$$

#### 15 *Maintenance*

16 Maintenance costs for each of the alternative facilities were assessed at 2.7% of the  
17 respective FGD project capital costs. This factor of 2.7% is a typical allowance that has  
18 evolved in DOE/EPRI technology assessment methodology, and includes labor and  
19 material allowances (generally assumed to be a 60/40 split, respectively).

#### 20 *Administrative & Support*

21 Administrative and support costs for each of the alternative facilities were assessed at  
22 0.6% of the respective FGD project capital costs. Again, the 0.6% factor of is a typical  
23 allowance that has evolved in DOE/EPRI technology assessment methodology.

#### 24 *Pond / Landfill Operations*

25 FGD by-product sales/disposal costs are traditionally treated as variable costs, since the  
26 most common disposition of these materials is to sell the gypsum to a third-party  
27 manufacturer or to dispose of the dry by-product in an off-site landfill. In both cases, the  
28 associated financial transactions are on a \$/T of material handled. However, in the  
29 present study, annual costs were applied on a fixed basis per the following procedure.

30 In the case of the wet FGD facility, no operating personnel requirements were identified  
31 for the gypsum pond operation, but an annual cost of [REDACTED] was assessed for re-  
stacking of gypsum in the pond area (assumed to be an outside contractor).

For the dry FGD facility, operating personnel are required for hauling the dry by-product out to the landfill area, for stacking and compacting the material in the landfill, and for equipment maintenance and house-keeping. The estimated personnel needed to perform these functions were identified in Table 5-1, and costs were calculated as follows.

$$\text{Annual Cost} = \text{No. of Operating Personnel} * \text{Annual Avg. Cost}$$



# CONFIDENTIAL

Florida Power & Light  
Docket No. 070007-E1  
Staff's Fourth Set of Interrogatories  
Interrogatory No. 36  
Attachment I, Page 24 of 131

- 1 Southern Company Services
- 2 Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

3  
4

In addition, costs for the mobile equipment and associated spare parts were assessed. The equipment (5 trucks, 1 dozer) were estimated to cost [REDACTED] and to have a usable lifetime of 10 yrs. Annual cost for spare parts was estimated at 10% of the equipment cost.

### *PJFF Bag Replacement*

The bags in the pulse jet fabric filters used in the dry FGD facility require regular replacement; a 3-year life is typical in this application. Since the same situation occurs with the bags in the mercury removal application, but with a longer bag life (estimated to be 5 years) due to the lower particulate loading, the dry scrubber facility was assessed the incremental bag replacement costs (differential between 3 and 5 years). These costs included material (new bags) and bag installation costs. The bag replacement costs were thus treated in a quasi-fixed manner, in that they were not made dependent on operating hours per year; such treatment was considered justified based on the high capacity factor (85%) for the units.

### 5.2.2 Variable

Variable O&M costs are those costs that are directly dependent on the number of hours of plant operation. The approach taken to estimate each variable facility cost was to develop a continuous annual rate (i.e., tons/yr, kWh/yr, etc.) based on full-load, continuous operation (8760 hr/yr), and to multiply this value by the annual unit capacity factor to arrive at an equivalent annual rate. The appropriate unit cost (Sec 3.3) was then applied to this rate to arrive at an annual cost. The rates characterizing each of the two FGD technologies were presented in Sec. 4.2.

### *Reagent*

$$\text{Annual Reagent Costs} = 4 * \text{Consumption Rate (\#/hr / unit)} / 2000 (\#/T) * \text{Unit Cost (\$/T)} * 8760 * \text{Capacity Factor (hr/yr)}$$

### *Aux Power / Water Consumption*

Here, the cost relationships are straight forward.

$$\text{Annual Aux Power Costs} = 4 * \text{Consumption Rate (kW/unit)} / 1000 (\text{kW/MW}) * \text{Unit Cost (\$/MWh)} * 8760 * \text{Capacity Factor (hr/yr)}$$

$$\text{Annual Makeup Water Costs} = 4 * \text{Consumption Rate (gpm/unit)} / 60 (\text{min/hr}) / 10^6 * \text{Unit Cost (\$/Mimgal)} * 8760 * \text{Capacity Factor (hr/yr)}$$

### *SO<sub>2</sub> Credits*

As identified in Table 4-1, the various technology/fuel combinations have different sulfur dioxide removal efficiencies. To evaluate each of these on an equivalent performance basis, costs/credits were assessed for each relative to the target removal efficiency of



CONFIDENTIAL

Florida Power & Light  
Docket No. 070007-E1  
Staff's Fourth Set of Interrogatories  
Interrogatory No. 36  
Attachment I, Page 25 of 131

Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

95%. That is, for alternatives where the removal efficiency is below 95%, costs for SO<sub>2</sub> allowances were assessed based on tons/yr of SO<sub>2</sub> emitted that exceed the 95% removal rate. In a similarly fashion, a credit was given to a particular alternative for tons/yr of SO<sub>2</sub> removed that exceed the 95% removal rate.

$$\text{Annual SO}_2 \text{ Allowance Cost} = 4 * \text{SO}_2 \text{ Input/Unit (T/yr)} * \\ (0.95 - \text{Removal Efficiency}/100) * \text{SO}_2 \text{ Allowance Rate (\$/T)}$$


5.2.3 O&M Results

The annual O&M costs vary from year to year, due to varying year-by-year unit costs and/or due to differing treatment. The complete build-up of these costs, through the full 20 years of operating life for each unit, is contained in the spreadsheets in Appendices H (wet FGD) and I (dry FGD).

Here, for illustrative purposes, the results of the analysis are described just for the year 2015, which is the first full year that the FGD facilities on all four units are in service. The following table summarizes the results for operation with bituminous (CAPP) coal, which was specified as the baseline fuel for the economic comparison of the two alternatives technologies.

Table 5-2  
Annual Plant-Wide O&M Costs for Yr. 2015  
CAPP Coal

A B C



**CONFIDENTIAL**

Florida Power & Light  
Docket No. 070007-E1  
Staff's Fourth Set of Interrogatories  
Interrogatory No. 36  
Attachment I, Page 26 of 131

Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

Although there are modest differences between the two technologies in most cost categories, the key result is the significantly greater cost of lime for the dry FGD technology than the limestone for the wet FGD technology. This difference results in an annual O&M cost for dry FGD that is about twice that for wet FGD.

Comparable results for PRB coal are presented in the following Table 5-3. Here, the incremental total O&M cost for dry FGD in comparison to wet FGD is less pronounced but still significant.

Table 5-3  
Annual Plant-Wide O&M Costs for Yr. 2015  
PRB Coal

A B C

### 5.3 Capital Costs

See Appendix J for the basis of the capital cost estimates. See Appendix K for the capital cost estimates for both the wet and dry FGD systems. The associated major equipment lists for each technology are contained in Appendix L.



# CONFIDENTIAL

Florida Power & Light  
Docket No. 070007-E1  
Staff's Fourth Set of Interrogatories  
Interrogatory No. 36  
Attachment 1, Page 27 of 131

1 Southern Company Services  
2 Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

3  
4

Table 5-4  
Project Capital Cost Estimate Summaries

5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15



16 For application to the life cycle cost analysis, the total capital cost for each of the two  
17 alternatives was spread over the construction period to provide annual capital cost  
18 expenditures. The procedure was to first divide the project total into the sub-totals for  
19 units 0 through 4 (0 = common), and to then spread each unit sub-total into yearly  
20 expenditures; the distribution for these yr-by-yr spreads was based on WP's experience  
21 with another 4-unit FGD project. For each unit, the yearly cash flows were distributed  
22 over the unit-specific project dates identified in the preliminary project schedule (Section  
23 6), and summarized in the following table.

24  
25  
26  
27  
28  
29  
30  
31  
32  
33

Table 5-5  
Key Project Construction Dates



Design and construction of both the wet and dry facilities were assumed to follow this same schedule.

Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

In addition to the accounting for the project engineering and construction costs, as described above, both alternatives were assessed costs for lost generation during the tie-in outage for unit (using the daily costs listed in Table 3-1). Based on the constructability evaluation (Section 7.10), a tie-in outage duration of 2.5 weeks was used for each wet FGD unit, and 10 weeks for each dry FGD unit.

5.4 Life Cycle Cost Results

5.4.1 Baseline

The complete buildup of year-by-year costs, over the period of evaluation, for the wet and dry FGD alternatives are contained in the spreadsheet printouts in Appendices H and I, respectively. The resulting net present value costs for the baseline CAPP coal are shown in the following table.

Table 5-6  
Life Cycle Cost Results  
CAPP Coal

A	B	C
[Redacted Table Content]		

For the baseline CAPP fuel, the dry FGD facility is found to have a life cycle cost about 63 % greater than the comparable cost for a wet FGD system. The dry FGD technology is burdened by 25% higher capital costs, as well as 125% higher operating costs (primarily due to lime purchase). This difference in operating costs is the most significant differentiator.

5.4.2 Parametric Comparisons

The results of the corresponding life cycle cost analysis for the two technologies with the alternate project coal, PRB, are listed in Table 5-7.


# CONFIDENTIAL

1 Southern Company Services  
2 Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

3  
4  
5

Table 5-7  
Life Cycle Cost Results  
PRB Coal



6  
7  
8  
9  
10  
11  
12  
13

14  
15  
16


In this case, the operating costs are much reduced compared to the CAPP coal results, and subsequently the difference in life cycle costs is much less pronounced, but still results in a dry FGD levelized unit cost that is 43% greater than for the wet FGD.

17  
18  
19  
20  
21  
22

The effect of assessing costs/benefits for SO<sub>2</sub> allowances (as a method of compensating for differences in SO<sub>2</sub> removal efficiencies between the different coal/technology combinations) was quantified by calculating the baseline life cycle cost with this cost account deleted. The comparison of this variation is shown in the following table, and demonstrates that the effect is minor and that it does not have a significant impact on the comparison of the two technologies.

23  
24  
25

Table 5-8  
Life Cycle Cost Results - Without SO<sub>2</sub> Allowances  
CAPP Coal



26  
27  
28

The impact of uncertainty in the project capital costs was quantified by running the baseline life cycle analysis with the dry FGD capital costs varied by +/- 20%, while holding the wet FGD capital costs constant. The results are listed in Table 5-9.

Table 5-9





**CONFIDENTIAL**

Florida Power & Light  
Docket No. 070007-E1  
Staff's Fourth Set of Interrogatories  
Interrogatory No. 36  
Attachment I, Page 30 of 131


Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

Life Cycle Cost Results - Capital Cost Variation

CAPP Coal

A B C D E



These results indicate that even a significant variation in capital cost does not change the primary conclusion that the wet FGD technology has a significantly lower life cycle cost than the corresponding dry technology.

**6. MILESTONE PROJECT SCHEDULES**

The conceptual Project Milestone Schedules are illustrated in Appendix M. One schedule is prepared for each of the following.

- Wet FGD, Units 3 and 4
- Wet FGD, Units 1 and 2
- Dry FGD, Units 3 and 4
- Dry FGD, Units 1 and 2

The schedules illustrate the flow of preliminary and detailed engineering, procurement activities, and construction activities for both the wet and dry scrubbers. The dates for outages and in-service dates that were provided by Southern Company were followed and are determined to allow a realistic construction schedule. WorleyParsons has compared the Southern Company draft schedule to our previous milestone schedules and find that the durations provided are consistent with our previous experience.

Generally, the level of effort for design, procurement and construction and nearly the same between the scope of the Wet and Dry FGD systems, so we have left the schedules very similar in overall duration. We have, however, reduced the overall construction schedule for Units 4 and 1 from 30 months to 27 months but kept the in-service dates for both the wet and dry scrubbers. This is primarily due to the first units carrying the responsibility of construction and preparing the Common equipment, such as the reagent unloading and preparation systems, and the new chimneys for the Wet FGD systems. For these reasons, Units 4 and 1 should have a slightly shorter construction schedule than Units 3 and 2.



Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

Note that all procurement activities for all four units will begin with the first unit. This will allow continuity of equipment and spares by purchasing all equipment at one time for the four units. The vendor engineering and drawing reviews will be completed for all four units, but shipment will be scheduled as appropriate for each unit.

The major difference in the schedules is the outage duration for the wet versus the dry FGD systems. Due to the demolition work of PJFF ductwork and the complexity of the construction plan, the dry FGD System outage will require a minimum of 10 weeks. Note that the complexity of the dry FGD Construction Plan could require the outage schedule to grow to 12 to 14 weeks. The duration will be determined after careful evaluation of construction activities and sequence in the preliminary and detailed engineering phases. The wet FGD system outage will only require 2 weeks, due to the relatively straight-forward nature of the construction plan.

Note that the major complicating factor for the dry FGD system is the reconfiguration and removal of PJFF ductwork that was originally installed for Mercury Control. With the installation of the dry FGD system, the PJFF ductwork must now be re-configured to position the PJFF downstream of the dry FGD system to catch the spray dryer reaction products for disposal. For the Mercury Removal system, the PJFF was directly downstream of the ESP to allow the flyash to be collected in the ESP rather than contaminated by mercury solids in the PJFF. This maximizes the amount of uncontaminated flyash that Southern Company can collect and sell. However, the ductwork reconfiguration will be a significant effort. A majority of the previous ductwork will be removed prior to installation of the ductwork to all spray dryers. The construction area will be very congested and will be a major reason for the 10 week minimum outage duration.

## 7. ENGINEERING EVALUATION OF BALANCE-OF-PLANT ISSUES

### 7.1 ID and Booster Fans

Both the dry and the wet FGD facilities will introduce substantial additional draft loss into the flue gas flow train, requiring upgrade of the static pressure (SP) capability of the flue gas draft system. Only minor changes, at most, to the gas flow *rate* will occur.

The present set of 4x25% centrifugal ID fans on each unit provide draft for the flue gas flow through the existing flow train, as depicted in the diagram SCHR-0-253-305 -001 (Appendix C). In the first phase of the up-coming AQC projects, i.e., the mercury removal project, it is planned that these existing ID fans will be upgraded to give them sufficient additional head capability to provide draft for both AQC phases that will precede the FGD facility installation (the mercury removal facility and the selective catalytic reduction (SCR) facility), while maintaining draft for the existing flow train. This flow configuration is depicted in the diagram SCHR-0-253-305 -003 (Appendix C).

Both the wet and dry FGD facilities will tie in their supply ductwork at the discharge of the existing ID fans. Since an (approximate) null draft will exist at this point, it will be necessary to provide additional draft capability for the FGD flow train; it is planned that



Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

this requirement will be met by addition of a pair of axial flow booster fans for each unit as part of the FGD installation scope.

The functional flow arrangements for the booster fans are shown in diagrams SCHR -0-253-305 -004 and -005 (Appendix C) for the wet and dry technologies, respectively. The (assumed) null draft condition at the ID fans discharge establishes the starting point for estimating the head capability of the booster fans for the present study.

**Note:** The flow/SP values listed in this section for the booster fans were developed early in the study to serve as a basis for a vendor budgetary quotation. As such, there are modest differences in these values when compared to the corresponding values in the final process material balances (Appendices D & E).

#### 7.1.1 Wet FGD

The booster fans for the wet FGD installation will operate in a configuration where the fans will have a slightly negative suction pressure (resulting from the draft loss between the tie-in point and the fan inlet), and discharge into a positive-pressure flow train through the scrubber island, connecting ductwork and stack.

The head requirements for the booster fans, operating to support this wet FGD configuration, were estimated as indicated in the following table. Here, the 1<sup>st</sup> component was estimated based on engineering experience, and the 2<sup>nd</sup> component is specified in the Basic Design Basis document.

Table 7-1  
Draft Loss for Booster Fans – Wet FGD

Component	MCR Draft Loss ("wg)
Booster Fans Supply & Discharge Ductwork Loss	3.0
Scrubber Island Inlet to Stack Discharge	12.0
Total	15.0

The gas flow rate was estimated at 5,820,000 lb/hr per fan, or 1,944,000 (A)CFM. The corresponding performance requirements for the booster fans were specified as follows.

Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

Table 7-2  
Booster Fan Performance Specifications – Wet FGD

Operating Condition	Flow / Fan (CFM)	Static Pressure SP (in wg)	Temperature (F)	Inlet Density (lb/ft <sup>3</sup> )
Boiler MCR	1,944,000	15.0	345	0.0499
Test Block	2,236,000	19.8	345	0.0499

A budgetary quotation from Howden/Buffalo for the fans specified the following design parameters.

Table 7-3  
Booster Fan Design Parameters – Wet FGD

Parameter	Value
Impeller Diameter	176.4"
Speed	720 rpm
No. Stages / Blades	1 / 20
Motor Rating	12,000 hp
Brake hp (MCR)	8,234
Brake hp (Test Block)	10,911

### 7.1.2 Dry FGD

The booster fans for the dry FGD installation will operate in a configuration where the fans will pull flue gas, under negative pressure, from the ID fans discharge through the spray dryer modules, the baghouses and connecting ductwork to the fans suction; the fans will discharge at slightly positive pressure into connecting ductwork and the existing stack.

The head requirements for the booster fans in the dry FGD facility were estimated as follows.

Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

Table 7-4  
Draft Loss for Booster Fans – Dry FGD

Component	MCR Draft Loss (in wg)
ID Fans to LSD's Dkwk	1.0
Lime Spray Dryers (LSD's)	2.0
Baghouses	5.0
Booster Fan Supply/Discharge Dkwk	3.0
Total	10.0

The gas flow was estimated at 5,862,000 lb/hr per fan, or 1,702,000 (A)CFM. Thus fan performance criteria were established as follows.

Table 7-5  
Booster Fan Performance Specifications – Dry FGD

Operating Condition	Flow / Fan (CFM)	Static Pressure, SP (in wg)	Temperature (F)	Inlet Density (lb/ft <sup>3</sup> )
Boiler MCR	1,702,000	10.0	166	0.0574
Test Block	1,957,000	13.2	166	0.0574

A budgetary quotation for fans meeting these specifications was solicited from Howden/Buffalo. Their response offered fans with the following characteristics.

Table 7-6  
Booster Fan Design Parameters – Dry FGD

Parameter	Value
Impeller Diameter	196.9"
Speed	590 rpm
No. Stages / Blades	1 / 20
Motor Rating	6,500 hp
Brake hp (MCR)	4,716
Brake hp (Test Block)	5,842

Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

7.2 Pulse Jet Fabric Filters

7.2.1 Wet FGD

An activated carbon injection system and PJFF for mercury control will be installed upstream of the limestone wet FGD system. In this configuration, there will be two (2) 12-compartment PJFF's installed on each unit. This equipment will be installed downstream of the existing ESPs which will stay in service. With the ESPs in service, the PJFFs will operate at higher air to cloth ratios in a TOXECON™ arrangement. Under the Basic Design Basis criteria, these PJFFs will operate at 5.48 fpm (gross) and 5.98 fpm (net-2) at maximum conditions. These are typical air to cloth ratios for a TOXECON™ installation. At higher air to cloth ratios, the PJFF becomes very sensitive to the particulate loadings from flyash carryover and from the particle size of the activated carbon.

The design parameters are shown in column A in the table below. One (1), two(2)-casing, 24-compartment, Size 2830 Model 315 VIP Pulse Jet Type Fabric Filter from Wheelabrator (WAPC) will be supplied for each unit.

Table 7-7  
Mercury Control PJFF Design Parameters

Item	A	B
	With Wet FGD	With Dry FGD
Casings per Unit	2	3
Number of Compartments in each Casing	2@12	2@12, 1@6
Bag Array (Per Compartment):		
Bag Quantity (Width Direction)	28	28
Bag Quantity (Depth Direction)	30	30
Bag Length (ft.)	26.25	26.25
Bag Diameter (in.)	5 (nominal)	5 (nominal)
Cloth Area per Compartment (ft <sup>2</sup> )	28,698	28,698
Total Cloth Area (ft <sup>2</sup> )	688,750	860,938
Volumetric Flow rate, acfm	3,774,160	3,372,974
Gas to Cloth Ratios (At Max. Conditions):		
All Compartments on-line	5.48	3.92
Two Compartments off-line	5.98	4.20

7.2.2 Dry FGD

An activated carbon injection system for mercury control will be installed upstream of a lime dry FGD system. In this configuration, the PJFF is installed downstream of the dry FGD system. The design parameters are shown in column B in the Table 7-7, above. With the addition of the dry FGD in front of the PJFFs, everything changes. With the current PJFF size, the air to cloth ratios would be 4.76 gross and 5.20 net-1. These are much too high for a dry FGD particulate removal application due to the high solids

Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

loading generated by the DFGD. *For conceptual design purposes, we have assumed the addition of a 5th row of six (6) PJFF modules in parallel with the existing casings for each unit.* These compartments would be the same size (840 bags) as the current WAPC design. Under these conditions, the modified PJFF system with the additional 6 compartments will operate at air to cloth ratios of 3.92 fpm (gross) and 4.120 fpm (net-2). This configuration represents an acceptable design for a PJFF with dry FGD and activated carbon injection.

### 7.3 Flyash Handling

#### 7.3.1 Wet FGD

The wet FGD facility is configured so that it will have no direct impact on the existing flyash handling operation, or material handling from the baghouse hoppers in the up-coming mercury removal project.

Following installation of a wet FGD facility, it is planned that the existing precipitators will remain in service, and that collection and sale of the flyash will continue.

#### 7.3.2 Dry FGD

The dry FGD facility is configured so that it will have no direct impact on the existing flyash handling operation. Following installation of a dry FGD facility, it is planned that the existing precipitators will remain in service, and that collection and sale of the flyash will continue.

However, the dry FGD facility will require modification/replacement of the pneumatic ash handling system that serves the hoppers of the baghouses installed for the (prior) mercury removal project. Since the volume of material handled, in changing from mercury removal to dry FGD service, will increase by at least an order of magnitude, it was assumed that the pneumatic handling system would be replaced.

The baghouses, when functioning as components of the dry FGD facility, will collect a mixture of particulate composed of FGD byproduct waste (calcium/sulfur compounds), unreacted lime, reacted/unreacted carbon, inerts and (minor amounts of) fly ash.

Refer to diagram SCHR-0-021-305-201 (Appendix E). The waste solids collected in the spray dryer and baghouse hoppers will be pneumatically conveyed to either the solids recycle silos (one per unit, located in the recycle/electrical buildings) or to the ash storage silos (one for Units 1&2, one for Units 3&4). This new ash handling system will include hopper feeders, two pressure blower skids, two ash storage silos, truck loading mixers and feeders (one set per silo), and the necessary piping and valves to transport the ash to the desired locations.



Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

7.4 Bulk Material Handling

7.4.1 Wet FGD

The limestone handling system will accept delivery of limestone primarily by rail. Limestone from the rail unloading hoppers will be transported to a storage pile formed by means of a radial stacker. The storage pile will be uncovered. Two hoppers with belt feeders in a tunnel below the limestone pile and associated conveyor system will gravity reclaim the limestone and transport it to two limestone silos.

As shown on Southern Company's own plant concept drawing for the wet FGD option, a radial stacker is provided for the stacking of the limestone storage pile. On a similar project, WorleyParsons has used a fixed stacking conveyor with a telescopic chute for this type of application. Given the capacity of the storage pile needed, the fixed stacking conveyor with telescopic chute offers advantages over the radial stacker. These include less capital, operating and maintenance costs. This issue can be discussed further in Phase I - Preliminary Engineering of the project.

Given the 30 day storage capacity of the storage pile, no equipment redundancy has been provided for the flow path from railcar unloading to storage pile. While the reliability of this equipment is high, any downtime must be minimized so as not delay the unloading of railcars and cause any possible demurrage.

One belt feeder, conveyor and radial stacker will be used to unload limestone railcars and transport the limestone to the top of the storage pile. Two belt feeders, each supplying one of two redundant reclaim conveyors that convey limestone to the top of the silos, will be provided. A dust suppression system will be provided at the unloading hoppers. Dust collectors will be provided to serve the two silos.

Table 7-8  
Limestone Material Handling Design Parameters

Limestone Physical Properties	
Size:	½" x 0
Moisture Content:	10 % Max.
Bulk Density Range:	80 - 120 lb/ft <sup>3</sup>
Bulk Density for Volumetric Sizing of Conveyor Chutes, etc.:	80 lb/ft <sup>3</sup>
Bulk Density for Volumetric Sizing of Silos:	85 lb/ft <sup>3</sup>
Bulk Density for Volumetric Sizing of Storage Piles:	95 lb/ft <sup>3</sup>
Bulk Density for Structural Design:	120 lb/ft <sup>3</sup>
Angle of Repose:	38°
Limestone Use Requirement	
Design Basis:	1.5 % sulfur coal (Appalachian) at 100% plant





Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

	load (4 units operating)
Hourly Requirement:	81.8 tons/hr
Daily Requirement:	1,962± tons/day
<b>Limestone Unloading Requirements</b>	
Primary method is rail receiving.	
Approximate Maximum Weekly Delivery Requirement:	13,750 tons
Train Sizes (Estimated):	120 car unit trains; will split into 30 car units for unloading
Rail Car Capacity:	100 tons
Weekly Rail Car Unloading Requirement:	138 cars (approximate)
Rail Car Maximum Length:	53' - 1" c. to c.
Rail Car Type:	Open, bottom dump cars with multiple discharge doors, manually operated from one or both sides of car
<b>Limestone Unloading Pit</b>	
Unloading Pit Length:	One rail car length
Minimum Hopper Length:	≥ 32' (based on maximum bottom opening of N.S. limestone service rail cars)
Minimum Hopper Capacity:	125 tons (125% of one rail car)
Maximum (Design) Unloading Capacity:	20 cars/hr
<b>Receiving and Stacking System</b>	
Limestone Belt Feeder #1 and Limestone Conveyor #2 Capacity:	2,200 tph
Radial Stacker	Slewing, variable height style; 2200 tph
<b>Limestone Stockpile</b>	
Shape:	Kidney Shaped with extension
Stacking Method:	Radial Stacker
Capacity: (Total requirement of kidney shaped pile plus extension [live and dead storage] for 30 days)	60,000 tons
<b>Reclaim System Design Basis</b>	
Stockpile reclaim shall utilize live gravity reclaim with remotely controlled feeders and conveyors to the greatest extent possible without requiring mobile equipment support. System	

Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

shall use two redundant reclaim systems to deliver to the limestone silos.	
Available Live Capacity in Stacked Pile Filled to Maximum Height:	8,000 tons – 4 days (estimated)
Available Capacity in Stacked Kidney Shaped Pile Filled to Maximum Height: Note: Not all of this storage is reclaimable without the use of mobile unloading equipment.	24,000 tons – 12 days (estimated)
Required Capacity of Reclaim and Distribution Conveyors:	100% of daily requirement delivered within 4 hr operating time = 480 tph
<b>Design Capacities</b>	
Belt Feeders:	480 tph
Conveyors:	480 tph
<b>Limestone Silos Design Basis</b>	
Quantity:	Two (2)
Capacity:	675 ton each (8 hours at daily rate)
<b>Dust and Emission Control</b>	
Unloading Pit:	Water/surfactant suppression system at hoppers
Silo Loading:	One dust collector at top of each silo
Conveyors:	Outdoor sections of conveyors have continuous hood covers

7.4.2 Dry FGD

The lime handling system will accept delivery of pebble lime primarily by rail from covered railcars. Lime from the two rail unloading hoppers will be transported by belt feeder and belt conveyor directly to six concrete silos. The lime will be distributed among the silos by a horizontal belt conveyor and traveling tripper atop the silos. Dust collectors will be provided to serve the six silos.

Given the 30 day storage capacity of the storage silos, no equipment redundancy has been provided for the flow path from railcar unloading to storage silo. While the reliability of this equipment is high, any downtime must be minimized so as not delay the unloading of railcars and cause any possible demurrage.

A conventional sloped belt conveyor is provided from the railcar unloading to the top of the storage silos. Based on this estimated height of the storage silos, this conveyor elevates the lime over 265 ft. from underground feeder discharge to the top of the silos. A potential savings may be realized based on the use of a High Angle Conveyor (HAC) in place of this conventional belt conveyor. This issue can be discussed further in Phase I – Preliminary Engineering of the project.

Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

Table 7-9  
Lime Material Handling Design Parameters

Lime Physical Properties	
Type:	Pebble
Size:	¾" x 0
Bulk Density Range:	50 – 70 lb/ft <sup>3</sup>
Bulk Density for Volumetric Sizing of Conveyor Chutes, etc.:	50 lb/ft <sup>3</sup>
Bulk Density for Volumetric Sizing of Silos:	60 lb/ft <sup>3</sup>
Bulk Density for Structural Design:	70 lb/ft <sup>3</sup>
Angle of Repose:	38°
Lime Use Requirement	
Design Basis:	1.5 % sulfur coal (Appalachian) at 100% plant load (4 units operating)
Hourly Requirement:	83.7 tons/hr
Daily Requirement:	2,009± tons/day
Lime Unloading Requirements	
Primary method is rail receiving.	
Approximate Maximum Weekly Delivery Requirement:	14,060 tons
Train Sizes (Estimated):	120 car unit trains; will split into 30 car units for unloading
Rail Car Capacity:	100 tons
Weekly Rail Car Unloading Requirement:	141 cars (approximate)
Rail Car Maximum Length:	42' – 0" c. to c.
Rail Car Type:	Covered, bottom dump cars with multiple discharge doors, manually operated from one or both sides of car
Lime Unloading Pit	
Unloading Pit Length:	One rail car length
Minimum Hopper Capacity:	125 tons (125% of one rail car)
Maximum (Design) Unloading Capacity:	20 cars/hr
Receiving System	
Lime Belt Feeder #1 and Lime Conveyor #2	2,200 tph

**CONFIDENTIAL**

Florida Power & Light  
Docket No. 070007-EI  
Staff's Fourth Set of Interrogatories  
Interrogatory No. 36  
Attachment I, Page 41 of 131

1 Southern Company Services  
2 Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19

Capacity:	
Silo Conveyor #3 and Tripper Capacity:	2,200 tph
Lime Silos Design Basis:	
Quantity:	Six (6)
Capacity:	10,000 ton each for a total of 60,000 tons – Approx. 30 days storage
Dust and Emission Control:	
Unloading Pit:	Dust collection system at hoppers and feeder discharge
Silo Loading:	One dust collector at top of each silo
Conveyors:	Outdoor sections of conveyors have continuous hood covers

20 7.5 Wastewater Treatment

21 7.5.1 Wet FGD

22 The wet FGD process is configured such that slurry bleed from the absorbers is pumped  
23 to a (new) settling pond where separation of the solid material (gypsum) from the water  
24 occurs. The water that is reclaimed from this process is recycled back into the scrubbing  
25 process.

26 This water recycle configuration concentrates dissolved solids, notably chlorides and  
27 heavy metals, in the process water streams. The preliminary FGD water balance for the  
28 CAPP coal indicates that it will be necessary to blow down a portion (~ 8%) of the  
29 recycle water to maintain the chloride concentration within the design value of 20,000  
30 ppmw.

31 The estimate of blow-down quantity from the four units is on the order of 100 gpm  
32 (~ 0.15 Mgd); this liquid is characterized as a flow containing high chloride and heavy  
33 metals concentrations. Discharge of this flow to one of the ponds or basins on site could  
34 require a revision of NPDES permit to include new monitoring requirements and/or  
35 effluent limits, depending on the quality and volume of the discharge and any additional  
36 wastewater treatment systems the plant may install.

37 It is recommended that a comprehensive and thorough evaluation of the need for  
38 treatment of this blowdown be conducted.

39 In the present study, no costs were included for wastewater treatment from the wet FGD  
40 facility. If a wastewater treatment facility were required, based on recent WorleyParsons  
41 project experience the costs would likely be in the range of [REDACTED]

Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

7.5.2 Dry FGD

Installation of a dry FGD facility will not require a wastewater treatment facility. However, it will be necessary to dispose of an estimated 25-30K gpd of sump discharge water (due to wash-downs). It is assumed that sump discharge water can be disposed of in the ash pond, but may require a revision to the NPDES permit.

Waste water generated by the proposed dry FGD facility is expected to amount to about 10-15K gpd in the lime slaking and recycle operations due to periodic wash-downs. Waste water that would be generated during periodic wash-downs at the ash storage silos is expected to be about another 15K gpd. Waste water would be collected in the floor sumps located in the various process areas, and discharged to the ash pond or other on-site wastewater basin.

7.6 FGD By-Product Storage/Disposal

7.6.1 Wet FGD

The by-product resulting from the wet LSFO process is primarily gypsum ( $\text{CaSO}_4 \cdot 2\text{H}_2\text{O}$ ), with minor components consisting of inerts, unreacted limestone and flyash.

Table 7-10  
FGD By-product Characteristics – Limestone Forced Oxidation  
CAPP Coal

MCR Rate	(T/hr)
Production (4 Units)	149.7 (dry basis)
Composition	(Wt %)
$\text{CaSO}_4 \cdot 2\text{H}_2\text{O}$	81
Moisture	-
$\text{CaSO}_3 \cdot 1/2\text{H}_2\text{O}$	<1
$\text{CaCO}_3$	2
$\text{MgCO}_3$	<1
Alkali Inerts	13
Flyash	2

This material, commonly known as synthetic gypsum, has substantial commercial application for wallboard manufacture. In the present study, the wet FGD process has been configured to deposit the gypsum slurry (bled from the absorbers) in a new settling pond, as described in Section 7.9.1, and to then let the gypsum separate and accumulate in the pond. It is planned to then regularly use a drag-line excavator to stack the settled gypsum into a long term storage arrangement. This procedure thus permits the options of

Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

either reclaiming the gypsum some time in the future for commercial sale, or ultimately closing the stack as a permanent land fill.

7.6.2 Dry FGD

The by-product produced by the dry LSD process consists of reaction products, excess hydrated lime, inerts, flyash, and moisture. The reaction products are calcium sulfite, gypsum, and calcium chloride. Based on using a lime reagent with 90% activity (CaO), the byproduct production rate and composition are as listed in the following table.

Table 7-11  
FGD By-product Characteristics – Lime Spray Drying  
CAPP Coal

MCR Rate (4 Units)	(T/hr)
Recycle	220.8
Disposal	156.8
Total Production	377.6
Composition	(Wt %)
Ca(OH) <sub>2</sub>	15
CaSO <sub>3</sub> -1/2H <sub>2</sub> O	80
CaSO <sub>4</sub> -2H <sub>2</sub> O	incl. above
CaCl <sub>2</sub> -2H <sub>2</sub> O	incl. above
CaCO <sub>3</sub>	incl. above
Inerts, Carbon	incl. above
Flyash	3
Moisture	2

At present, there are only very limited commercial uses for this dry FGD by-product material. In almost all instances, the byproduct material from operating LSD facilities is disposed of in a landfill. In the present study, it is assumed that the material will be hauled to a new on-site landfill, as described in Section 7.9.2.

7.7 **Control System**

Plant Scherer requires an expansion, for each unit, of the existing Foxboro 1A Series Distributed Control System (DCS) for control of the new flue gas desulfurization (FGD) system. The expansion of the existing Foxboro 1A Series DCS will allow connection of the new controls for the FGD system.



Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

The new DCS equipment must meet guidelines in response to the requirements of the North America Energy Reliability Council (NERC). Due to the criticality of the DCS to Unit Operation, means of digital and physical security will need to be provided. The use of wireless devices will not be permitted.

The design requirement is to expand the DCS for control of the new FGD system equipment. The existing DCS equipment will be retained and new FGD DCS equipment controls will be provided as a separate node on the existing data highway.

All control and monitoring functions for equipment and control devices associated with either the wet or dry FGD system will be controlled by the DCS. Selected equipment may be locally controlled. The limestone handling equipment and reagent preparation or dry FGD baghouses will each be controlled by a stand-alone Programmable Logic Controller (PLC). All interface signals required between the PLC's and the DCS will be hardwired.

All control and monitoring functions will be available from the main control room utilizing the existing operator work stations. No new operator work stations are required for the expansion. Signals required for interface between the expanded FGD DCS and the existing plant DCS will be hardwired. It is assumed that any new control cabinets will be located in the FGD electrical equipment buildings.

New graphics will be configured for the FGD equipment using the current plant convention for symbols, colors and initiating operation of equipment/devices. This approach will ensure common presentation of plant displays throughout the control system. The new graphics will provide all the functionality of the existing graphic design.

There are no control issues specific to either the wet or dry technology. It is recommended that the control logic for the booster fans be added to the existing Combustion Control process. The ID Fan logic should remain as is; however, the booster fan control and Main Fuel Trip (MFT) scenarios should be investigated in more detail.

## 7.8 Electrical Distribution

### 7.8.1 Wet FGD

The wet FGD system for Unit 1 will be fed from a 50/66/83 MVA, three winding transformer tapped off the generator ISO phase bus. See drawing SCHR-0-SK-625-206-001 (Appendix N). Each winding will feed a 13.8 KV switchgear. The 13.8 KV switchgear will provide power to the 12,000 hp booster fans. Another feed will supply power to a 13/17/25 MVA, two winding transformer for the FGD electrical distribution system.

The FGD electrical distribution system will use 4.16 KV switchgear as the source of power for large and medium voltage motors and the unit substations. The unit substations are the source of power for the motor control centers and the larger low voltage motors. The motor control centers supply power to the smaller low voltage motors, lighting, and other miscellaneous loads.

This same arrangement will be used for Unit 2.



**WorleyParsons**

resources & energy

Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

Start-up power for the FGD facilities and booster fans, for both Units 1 & 2, will come from the 115 KV switchyard. The 115 KV supply will be transformed to 13.8 KV through a three winding transformer rated 50/66/83 MVA. Each of the 13.8 KV windings will supply one of the 13.8 KV switchgear in Units 1 & 2.

Units 3 & 4 will have an electrical distribution arrangement similar to Units 1 & 2.

#### 7.8.2 Dry FGD

The electrical distribution for the dry FGD facility is similar to that for the wet FGD facility. The primary source is from a three winding transformer rated 30/40/50 MVA. See drawing SCHR-0-SK-625-206-002 (Appendix N). Each winding supplies a 6.9 KV switchgear. This switchgear supplies power to the 6500 hp booster fans and, unlike the wet system, the medium voltage motor and unit substations are fed from this switchgear.

The remainder of the electrical distribution is similar to the wet system. Like the wet system, start-up power will come from the 115 KV switchgear through a three winding transformer. The transformer will be rated 30/40/50 MVA. As in the wet system, each winding will supply a 6.9 KV switchgear in Units 1 & 2.

Units 3 & 4 will have an electrical distribution arrangement similar to Units 1 & 2.

#### 7.8.3 General

It is noted that confirmatory studies on these conceptual arrangements are needed to assure booster fan starting ability which will finalize transformer size rating, voltage level and transformer impedance. Along with motor starting, short circuit withstand must be investigated. These studies will be conducted when further data is available and preliminary design is underway.

#### 7.9 Civil

##### 7.9.1 Wet FGD

Gypsum slurry will be pumped to a proposed settling pond for storage or final disposal. The decanted water will be returned to the FGD process for reuse. The pond will be located east of the existing ash pond and will be formed by constructing an earthen embankment dam in a natural valley (see dwg. No. SCHR-0-111-002-101, App. F). The pond and its related facilities will cover approximately 185 acres. The area at the pond water line will be approximately 150 acres. The storage volume required for a 20-year life is approximately 12,000 to 14,000 acre-feet of gypsum.

The pond will have a maximum depth of about 60 feet and when the pond storage capacity is reached, the gypsum will be "stacked" on the previously deposited gypsum by a drag line excavator, as described in the EPRI report No. TR-104731. The drag line will construct a new pond embankment with gypsum. When the embankment is completed, the gypsum sluice discharge pipes will be relocated to the newly formed, elevated pond. Additional stacking operations will be used to accommodate the total gypsum volume. It has been assumed that the pond will require a liner to prevent infiltration of contaminants





Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

into the surrounding soil. A single layer of geosynthetic clay liner (GCL) was used for the cost estimate. Closure of the pond/stack was not included. Final closure, if implemented, may require a liner "cap" over the gypsum.

#### 7.9.2 Dry FGD

The dry FGD by-product will be trucked to a proposed landfill site for final disposal. The landfill will be located east of the existing ash pond and will be formed by the valley-fill method in a natural valley (see dwg. No. SCHR-0-111-002-201, App. G). The solid waste material will be placed, spread and compacted with earthmoving equipment. The landfill and its related facilities will cover approximately 185 acres. The area at the waste material limits will be approximately 150 acres. The storage volume required for a 20-year life is approximately 12,000 to 14,000 acre-feet.

The landfill will have an average final depth of about 80 to 95 feet when the storage capacity is reached. It has been assumed that the landfill will require a liner to prevent infiltration of contaminants into the surrounding soil. A single layer of geosynthetic clay liner (GCL) was used for the cost estimate. Closure of the landfill was not included. Final closure may require a liner "cap" over the waste material.

#### 7.10 Constructability Evaluation

##### 7.10.1 Wet FGD

###### *Units 3 & 4*

The wet FGD facility layout for these two units allows for sufficient construction access to both units. With the current pipe bridge location, the ideal layout for construction would be to place the Unit 3 scrubber island to the east. This would eliminate working around live utilities during construction of Unit 4 and create a safer working environment. The electrical building placement is critical to keep wire runs short, and at the same time not interfere with access to the construction site. The stack erection would be critical path due to an exclusion zone required to erect the stack prior to beginning scrubber island erection. If the schedule is critical and a 50' exclusion zone could be agreed upon with the stack erector, the scrubber islands could be arranged outside of this zone. This arrangement would allow for concurrent installation, but would increase the cost of the fiberglass duct from the scrubber outlet to the stack. The liner installation could continue concurrently with the scrubber island erection; for safety reasons both liners should be installed before operation of the first unit. Most if not all of this ductwork could be modularized or ground fabricated which would reduce cost and schedule. The PJFF ductwork for these units (associated with the mercury control project) will remain permanent and should not interfere with construction or the FGD tie-in outage activities. The tie-in outage for each of these units would consist of a single point tie-in with an approximate duration of two to three weeks. These outages could be kept to a minimum if the FGD bypass dampers could be installed during outages associated with the earlier AQC projects.



Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

### *Units 1 & 2*

The wet FGD facility layout for Units 1 & 2 offers considerably better access for cranes and equipment than the dry FGD layout. The equipment is spread out and it is not entirely confined within the area bounded by the existing coal conveyors. The sequence of installation would still be critical but would be easier than for the dry FGD layout. The new stack would again be critical path for Units 1 & 2 due to the exclusion zone required during stack erection. As with Units 3 & 4, most of the ductwork could be modularized or ground fabricated. Unit 1 ductwork and booster fan installation will be more difficult due to limited access after Unit 2 is operating. The pipe bridge location and elevation is critical such that it does not block access for cranes and equipment to construct Unit 1. The permanent PJFF ductwork will not significantly interfere with installation of the booster fans or ductwork. The PJFF ductwork (for mercury removal) for these units will be considerably shorter than for Units 3 & 4, and again, remain permanent and should not interfere with construction or FGD tie-in outage activities. The tie-in outage duration for these units would be similar to Units 3 & 4, approximately two to three weeks each.

### 7.10.2 Dry FGD

#### *Units 3 & 4*

The majority of the dry FGD facility for Units 3 & 4 will be located north of the Unit 4 coal conveyor. This will ease the installation for Unit 3 by allowing greater accessibility for cranes and equipment. The majority of the Unit 3 supply duct and return duct to the existing stack could be modularized or ground fabricated modules, only limited by transporting them to the erection site and crane selection. Per the study layout, all of Unit 4 equipment is "inside" the construction area, which will limit access and productivity for this unit. The pipe bridge, depending on its location and elevation, and the temporary ductwork from the PJFF's may cut off access and ability to install large ductwork modules for Unit 4. The duration of a final outage for this system could be quite substantial depending on the location of the temporary ductwork and how much of it would need to be removed during the outage. Other outage activities would include coating the existing stack liners, coating the inlet ducts, tie-in of the new PJFF extensions, tie-in new ductwork to the PJFF inlet and outlet, and tie-in duct to the damper at the stack. Additional detailing is required to determine accurate outage durations, but anywhere from 10 to 14 weeks is highly possible.

#### *Units 1 & 2*

The entire dry FGD facility for Units 1 & 2 will be confined between existing coal conveyors. Construction of these units will be very challenging for a variety of reasons. The sequence of construction will be very critical due to the limited space and accessibility to the erection site for cranes and equipment. The ductwork will require long radius picks which will limit the size of ground fabricated duct modules, require larger cranes and increase field erection labor. It should be considered to make the tie-ins and install dampers, including some of the ductwork, during an earlier outage while there is greater access to the area. Appropriate measures must be taken to ensure the safety of all personnel and equipment if this is done. The PJFF is located where it makes sense for



Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

the final layout, but will require extensive "temporary ductwork" that not only increases cost to install and then remove, but also significantly adds to the congestion and safety during construction. The study arrangement of the dry scrubbers, duct work, PJFF's and booster fans aligns well with starting Unit 2 first. One of the difficulties will be the installation of the Unit 1 booster fans while Unit 2 is running, unless they could be installed and protected at the same time as Unit 2. The Unit 1 ductwork and scrubbers could be installed in sequence to back out of the corner, although this would add coordination and cost to the project. The same situation as Units 3 & 4 would apply for coating the stack liners, PJFF location and the substantial amount of "temporary" ductwork that would add to cost, congestion and outage duration. The outage activities would be the same as Units 3 & 4 and would require additional detailing to determine accurate outage durations.

#### 8. RECOMMENDATION

The present study evaluated FGD operation with both a CAPP coal (future, FGD design coal) and a PRB coal (present operating coal). Based on a comparison of the net present value of the life-cycle costs of the two FGD technologies, the LSFO or wet system has a lower life-cycle cost than the dry or LSD system for both coals.

Therefore it is recommended that Southern Company proceed with the installation of a wet system to meet the SO<sub>2</sub> emission targets for Plant Scherer.



Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

**APPENDIX A**  
**BASIC DESIGN BASIS – WET FGD**



**WorleyParsons**  
resources & energy

**BASIC DESIGN BASIS**

**SCHERER UNITS 1-4**

**WET FGD**

<b>1. Project Description</b>	
Name of Client	Georgia Power and Southern Company Generation
Project order number	
Name of project	Plant Scherer Units 1, 2, 3 & 4 Wet FGD System
Plant location	Julesburg, Georgia (near Macon)
Elevation	465 ft above sea level 142 m
Standards, Codes and Instructions	

<b>2. Site Conditions</b>				
Ambient temperature	F	Max 100 F	Minimum 10 F	Performance Design 90 F
Barometric Pressure	in.Hg	Min. 29.07 in.Hg	Max. 31.07 in.Hg	Performance Design 29.43 in.Hg @ 465 ft above MSL 14.451 psia
Relative Humidity	%	Max 100 %	Minimum 10 %	Performance Design 85 %
Rainfall	mm/d inches	Average 5.24 mm/d 0.206 inches	Daily max recorded 5.84 mm/d	Design 5.6 mm/d
Snowfall	psf	Snow load shall be determined by ASCE 7-02		Design snow load 5 psf Occupancy Importance Factor 1.20 - Snow Exposure Coefficient 0.9 -
Wind	mph	Wind load shall be determined by ASCE 7-02		Direction N/A Velocity 90 mph Exposure Category : C Wind importance Factor = 1.15
Earthquake		Seismic importance factor determined by ASCE 7-02		seismic importance factor = 1.50

# CONFIDENTIAL

Florida Power & Light  
Docket No. 070007-E1  
Staff's Fourth Set of Interrogatories  
Interrogatory No. 36  
Attachment I, Page 51 of 131

10/30/2008 Rev D

**BASIC DESIGN BASIS      SCHERER UNITS 1 - 4**

**WET FGD**

1  
2  
3  
4

3. General Process Information								
<b>Boiler Combustion Data</b>		Unit	Units 1, 2, 3 & 4 (Identical units)					
Gross Generation	MW							
Heat Input	mmBtu/hr		9074.4			9074.4		
Heat Rate	Btu/kWh		9831.4			9300		
Excess Combustion Air **	%		25			25		
In-Leakage*	%		25			25		
Load Case			PRB Coal			Appalachian Coal		
<b>Fuel Data</b>			Design					
<b>Source</b>			PRB Coal (Primary Fuel)			Appalachian Coal (Future Back-up Fuel)		
<b>Proximate Analysis (As Received)</b>			Minimum	Maximum	Design	Minimum	Maximum	Design
Ash	%		2.6	7.2	5.2	4.0	19.00	10.14
Volatile Matter	%							
Fixed Carbon	%							
Heat Content	Btu/lb		8,300	9,150	8,600	10,500	13,400	12,800
Sulfur	%		0.1	0.90	0.3	0.50	1.50	1.50
<b>Evaluation Coal Analysis</b>			PRB Coal			Appalachian Coal		
			Minimum	Maximum	Design	Minimum	Maximum	Design
Moisture	%		24.6	29.5	27.23	5.25	7.89	6.35
ASH	%		2.60	7.20	5.20	13.00	4.50	9.24
CARBON	%		48.2	54.60	51.21	70.83	73.21	71.30
HYDROGEN	%		2.40	4.00	3.43	4.38	4.74	4.54
NITROGEN	%		0.40	1.50	0.69	1.31	1.56	1.39
SULFUR	%		0.10	0.90	0.30	0.64	1.50	1.50
OXYGEN	%		9.60	13.00	11.93	4.53	6.43	5.49
CHLORINE	ppm-w		30	150	100	68	2157	2167
FLUORINE	ppm-w		32	100	53	62	132	132
Total	%		n/a	n/a	100.0	100.0	100.0	100.0
HEAT CONTENT	Btu/lb		8,300	9,150	8,600	10,500	13,400	12,800
* Air In-leakage total for air heater(15%), ESP(5%) & baghouse(5%)								
** Includes 5% design margin.								

10/30/2006 Rev D

**BASIC DESIGN BASIS**      **SCHERER UNITS 1 - 4**

**WFGD**

Coal Trace Analysis - Statistics		PRB Coal			Appalachian Coal		
		Minimum	Maximum	Medium	Minimum	Maximum	Medium
As	mg/kg	0.3	3.5	0.8	3.8	9	5.3
Ba	mg/kg	190	340	240	30	320	100
Be	mg/kg	0.1	2.4	0.2	1.8	4.4	2.7
B	mg/kg	NA	NA	NA	NA	NA	NA
Ca	mg/kg	0.02	0.28	0.04	0.04	0.07	0.05
Cl	mg/kg	30	204	46	68	1757	1534
Co	mg/kg	1.4	3.5	2.1	6.6	14.7	9.6
Cr	mg/kg	2	8	3	12	20	18
Cu	mg/kg	7	14	10	18	27	20
F	mg/kg	32	98	52	62	126	62
Hg	mg/kg	0.03	0.1	0.06	0.02	0.06	0.04
Li	mg/kg	NA	NA	NA	NA	NA	NA
Mg	% by Wt	0.09	0.2	0.15	0.05	0.14	0.06
Mn	mg/kg	0	38	8	7	76	21
Mo	mg/kg	NA	NA	NA	NA	NA	NA
Na	mg/kg	0.04	0.08	0.06	0.02	0.09	0.04
Ni	mg/kg	2	10	3	12	24	16
Pb	mg/kg	0.9	3.6	1.9	5.5	11	8.4
Sb	mg/kg	0	0.4	0.1	0.3	2.1	0.9
Se	mg/kg	0.25	2	0.5	2.3	4.17	2.5
Sr	mg/kg	0	0	0	0	0	0
V	mg/kg	7	23	11	24	44	34
Zn	mg/kg	2	32	7	8	21	14

There are two flue gas cases for FGD design basis.

Case	Load and Fuel	Relevance
Case 1: Max Load, PRB Coal	923MW, 0.3% S 8,800 Btu/lb PRB	Primary fuel will be PRB. Primary scrubber design case with 96% SO <sub>2</sub> removal. The FGD system is to be robust and rigorous for this case, with complete redundancy and equipment sizing margins.
Case 2: Max. Load, Appalachian Coal	923MW, 1.5% S 12,800 Btu/lb Appalachian	Appalachian coal may be used in future. Secondary scrubber design case with 96% SO <sub>2</sub> removal. The FGD system is to be robust and rigorous for this case, with complete redundancy and equipment sizing margins.

10/30/2008 Rev D

**BASIC DESIGN BASIS**      **SCHERER UNITS 1 - 4**

**WET FGD**

	Case #	1	2				
	Case Description	0.3% Sulfur Max. 923MW PRB	1.5% Sulfur Max. 923MW Appalachian				
<b>Raw flue gas condition at Absorber Inlet</b>							
Mass flow	lb/hr	11,636,000	11,034,000				
Flue gas pressure	in. WG	12	12				
Volume flow	acfm	3,935,000	2,885,000				
at 68F	scfm-w	2,583,000	2,419,000				
O2	lb/hr	800,900	782,800				
N2	lb/hr	7,830,700	7,654,500				
Ar	lb/hr	134,300	131,300				
CO2	lb/hr	1,976,800	1,840,800				
SO2	lb/hr	6,325	21,250				
SO3	lb/hr	127	425				
H2O	lb/hr	886,500	601,800				
HCl	lb/hr	110.00	1,460.00				
HF	lb/hr	60.00	100.00				
H2O	vol%	7.62	5.45				
O2	vol%	6.88	7.09				
CO2	vol%	17.00	16.68				
SO2	ppm-d	298	1,023				
SO3	ppm-d	8	20				
HCl	ppm-d	10	135				
HF	ppm-d	9	15				
Particulate matter	lb/hr	453.70	453.70				
	lb/mmStu	0.05	0.05				
	gr/scf-d	0.044	0.044				
Temperature	F	356	353				
Pressure (assumed, Advatech to verify)	in wg	12	12				
SO <sub>2</sub> → SO <sub>3</sub> conversion in boiler	%	1	1				
SO <sub>2</sub> → SO <sub>3</sub> conversion in SCR	%	1	1				
<b>Clean gas condition</b>							
Gas temperature	F	135-145	130-140				
SO2	lb/h	126.5	850.0				
	ppm(d)	5.9	41.0				
Particulate matter	lb/hr	113.43	113.43				
	lb/mmStu	0.012	0.012				
Mist	gpm/ft2	0.0005	0.0005				
Desulfurization efficiency	%	98.0	96.0				
Particulate matter removal	%	75%	75%				
FGD process		Wet Limestone-Gypsum Forced Oxidation Process					
Byproduct gypsum							



10/30/2008 Rev D

**BASIC DESIGN BASIS**

**SCHERER UNITS 1-4**

**WET FGD**

<b>Base Case:</b>		<b>Disposable Grade (not dewatered)</b>		
<b>Alternate:</b>  The properties specified to the right. These are required by contract with the wallboard manufacturer. The gypsum dewatering system must be designed to include operating margin on these constraints.		<b>Wallboard Quality</b> CaSO4·2H2O                    94% min            ASTM C471 CaSO3·½H2O                1.0% max           TGA SiO2                                1.0% max           AA Fe2O3                            1.5% max           AA R2O3                             3.5% max           AA Cl                                 120 ppm max      Sp. Ion Elect. Total soluble salts            600 ppm max      USGC method pH                                8 - 8                USGC method Mean Particle Size            20 - 65 microns   Laser Diffract. Moisture content              10% max            At 110 deg F		The gypsum byproduct shall not be toxic or hazardous as defined under applicable federal or state laws. The gypsum byproduct shall also not contain and toxic or hazardous constituents in concentrations which would restrict its use in the manufacture of or its end use as wallboard.
Bulk density	lb/ft3	62 lb/ft3 for gypsum storage sizing		
<b>Limestone</b>		<b>Design Basis</b>	<b>Range</b>	
Type				
Receiving particle size	inch	3/4 X 0		
Chemical composition				
CaCO3 Total	wt%-d	90.00		
MgCO3	wt%-d	0.75 Soluble 0.25 Inert		
Inerts	wt%-d	9.00		
Moisture	wt%	8.00 Max		
Limestone grindability	kWh/ston	n/a		
Bulk density	lb/ft3	80 lb/ft3 for structural load, 62 lb/ft3 for volume capacity		
Reactivity	%	80		
Makeup water name	-	Service water pond		
B.L.		Intake from pond		
Temperature at B.L.	F	Ambient		
Pressure at B.L.	psig	Atmospheric		
Composition*				
Magnesium	ppm	1.6		
Calcium	ppm			
Sodium	ppm			
Potassium	ppm			
Chloride	ppm			
Bicarbonate	ppm			
Sulfate	ppm	10		
Iron	ppm	0.68		
Silica	ppm			
pH s.u.	-			
Turbidity, NTU	ppm			
TOC	ppm	2		
COD	ppm	12		
TSS	ppm	12		
Total Hardness	ppm as CaCO3			

\*From 1988 data, will obtain more current data.

10/30/2006 Rev D

**BASIC DESIGN BASIS SCHERER UNITS 1 - 4**

**WET FGD**

Cooling Water (Raw water, open loop)	psi	Supply	Return			
		Atmospheric	psi	40	psi	
Pressure						
Temperature (Max)	F	See Makeup		103	deg F	
		Water Conditions	deg F			
Air		Instrument		Service		
Name		Max	Advatech Scope (No existing capacity)	Max	Advatech Scope (No existing capacity)	
Supply pressure	psig	Min	Advatech Scope (No existing capacity)	Min	Advatech Scope (No existing capacity)	
Supply temperature	F	Max	Advatech Scope (No existing capacity)	Max	Advatech Scope (No existing capacity)	
		Min	Advatech Scope (No existing capacity)	Min	Advatech Scope (No existing capacity)	
Dew point	F	Dry, Oil-free (-40F)		Dry, Oil-free (-40F)		
Steam		Max	N/A			
Supply pressure	psig	Min	N/A			
Supply temperature	F	Max	N/A			
		Min	N/A			
Electrical Power	V - F - Hz	>= 250HP	4160	3φ	60Hz	Advatech Scope (as required)
		< 250HP	480	3φ	60Hz	Advatech Scope (as required)

<b>4. System Design Requirement</b>	
Gas Path System	
Duct	1 x 100 % Capacity
Velocity	60 ft/s max
By-pass	To existing stack
Stack	1 x % Capacity
type	Wet stack
Gas Velocity	45 ft/s maximum
Height	675 ft (preliminary) — same as Bowen
ID Booster Fan	2 x 50 % Capacity Axial
ID Booster Fan Test Block	15 % Flowrate margin on Case 1 (823MW) gas flow
ID Booster Fan Test Block	32 % Pressure margin on Case 1 (823MW) SPR
Limestone Receiving System	(Limestone Bulk Storage)
System capacity	1+0 x 100 % Capacity at 1.5% S Coal (future)***
Storage Capacity	30 days at 1.5% S coal (future)***
Feeder capacity	1+1 x 100 % Capacity at 1.5% S Coal (future)***
Conveyor capacity	1+1 x 100 % Capacity at 1.5% S Coal (future)***
Operation time	24 hrs per day
Limestone Supply System	(Feed to Wet Bed Mill)
System capacity	1+1 x 100 % Capacity at 1.5% S Coal (future)***
Storage Capacity	8 hrs at 1.5% S coal (future)***
Feeder capacity	1+1 x 100 % Capacity
Conveyor capacity	1+1 x 100 % Capacity
Operation time	24 hrs per day

10/30/2006 Rev D

**BASIC DESIGN BASIS**

**SCHERER UNITS 1-4**

**WET FGD**

<b>Limestone Supply System</b>	(Slurry feed)
System Capacity	1 x 100 % Capacity at 1.5% S Coal (future)***
Slurry Tank Storage Capacity	2 hrs at 1.5% S coal (future)***
Limestone slurry feed pump	2 x 100 % Capacity at 1.5% S Coal (future)***
LS prep. area sump/pump/agitator	1 set of 1 + 1 pumps, 1 + 0 agitator
Operation time	24 hrs per day
<b>Absorption System</b>	
Operation time	24 hrs per day
Absorber recirculation pumps	As required + 1 stand-by for 96% SO <sub>2</sub> Removal @ 1.5% S coal (future)***
Jer Air Spargers	As required for 96% SO <sub>2</sub> Removal @ 1.5% S coal (future)***
Agitator/Oxidation device	As required
Bleed pump	1+1 x 130% Capacity at 1.5% S coal (future)***
Absorber area sump/pump/agitator	1 set of 1 + 1 pumps, 1 + 0 agitator
<b>Secondary Dewatering System</b>	NA
Filter Feed Storage Tank	
Filtrate Tank	
Gypsum Cyclone O/F tank	
Belt Filter Washing Tank	
Belt Filter	
Operation time	
<b>Gypsum Storage System</b>	NA
Storage Capacity	
Front-end loader	
Operation time	
*** = 1.5% S coal may be used in the future and therefore is used as the design coal. The plant is currently using 0.3% S coal.	
<b>Utility Systems</b>	
Process Water Tank	N/R
Process Water Intake Pumps	1+1 x 100 % Capacity (If Req'd)
FGD Plant Air Compressor	1+1 x 100 % Capacity

Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

## APPENDIX B

### BASIC DESIGN BASIS – DRY FGD



**WorleyParsons**

resources & energy

10/30/2008 Rev A

**BASIC DESIGN BASIS**

**SCHERER UNITS 1-4**

**DRY FGD**

<b>1. Project Description</b>		
Name of Client	Georgia Power and Southern Company Generation	
Project order number		
Name of project	Plant Scherer Units 1, 2, 3 & 4 Dry FGD System	
Plant location	Juliette, Georgia (near Macon)	
Elevation	465 ft above sea level	142 m
Standards, Codes and Instructions		

<b>2. Site Conditions</b>				
Ambient temperature	F	Max 100 F	Minimum 10 F	Performance Design 90 F
Barometric Pressure	In.Hg	Min. 29.07 in.Hg	Max. 31.07 in.Hg	Performance Design 29.43 in.Hg @ 465 ft above MSL  14.451 psia
Relative Humidity	%	Max 100 %	Minimum 10 %	Performance Design 85 %
Rainfall	mm/d Inches	Average 5.24 mm/d 0.208 inches	Daily max recorded 5.94 mm/d	Design 5.6 mm/d
Snowfall	psf	Snow load shall be determined by ASCE 7-02 Design snow load Occupancy Importance Factor Snow Exposure Coefficient		5 psf 1.20 - 0.9 -
Wind	mph	Wind load shall be determined by ASCE 7-02 Direction N/A Exposure Category : Wind Importance Factor =		Velocity 80 mph C 1.15
Earthquake		Seismic importance factor determined by ASCE 7-02  seismic importance factor =		1.50

# CONFIDENTIAL

Florida Power & Light  
Docket No. 070007-E1  
Staff's Fourth Set of Interrogatories  
Interrogatory No. 36  
Attachment I, Page 59 of 131

10/30/2006 Rev A

1 BASIC DESIGN BASIS      SCHERER UNITS 1 - 4  
2 DRY FGD

3  
4  
5

<b>3. General Process Information</b>							
<b>Boiler Combustion Data</b>	Unit	Units 1, 2, 3 & 4 (Identical units)					
Gross Generation	MW	██████████			██████████		
Heat Input	mmBtu/hr	9074.4			9074.4		
Heat Rate	Btu/kWh	9831.4			9300		
Excess Combustion Air **	%	25			25		
In-Leakage*	%	20			20		
Load Case		PRB Coal			Appalachian Coal		
<b>Fuel Data</b>		Design					
<b>Source</b>		PRB Coal (Primary Fuel)			Appalachian Coal (Future Back-up Fuel)		
<b>Proximate Analysis (As Received)</b>		Minimum	Maximum	Design	Minimum	Maximum	Design
Ash	%	2.6	7.2	5.2	4.0	19.00	10.14
Volatile Matter	%						
Fixed Carbon	%						
Heat Content	Btu/lb	8,300	9,150	8,600	10,500	13,400	12,800
Sulfur	%	0.1	0.90	0.3	0.50	1.60	1.50
<b>Evaluation Coal Analysis</b>		PRB Coal			Appalachian Coal		
		Minimum	Maximum	Design	Minimum	Maximum	Design
Moisture	%	24.8	29.5	27.23	5.25	7.89	6.35
ASH	%	2.60	7.20	5.20	13.00	4.60	9.24
CARBON	%	48.2	54.60	51.21	70.83	73.21	71.30
HYDROGEN	%	2.40	4.00	3.43	4.39	4.74	4.54
NITROGEN	%	0.40	1.50	0.69	1.31	1.56	1.39
SULFUR	%	0.10	0.90	0.30	0.64	1.50	1.50
OXYGEN	%	8.60	13.00	11.93	4.53	6.43	5.49
CHLORINE	ppm-w	30	150	100	88	2167	2167
FLUORINE	ppm-w	32	100	63	82	132	132
Total	%	n/a	n/a	100.0	100.0	100.0	100.0
HEAT CONTENT	Btu/lb	8,300	9,150	8,600	10,500	13,400	12,800
* Air in-leakage total for air heater(15%) & ESP(5%)							
** Includes 5% design margin.							

10/30/2008 Rev A

**BASIC DESIGN BASIS**

**SCHERER UNITS 1 - 4**

**DRY FGD**

Coal Trace Analysis - Statistics		PRB Coal			Appalachian Coal		
		Minimum	Maximum	Medium	Minimum	Maximum	Medium
As	mg/kg	0.3	3.5	0.6	3.8	9	5.3
Ba	mg/kg	190	340	240	30	320	100
Ba	mg/kg	0.1	2.4	0.2	1.8	4.4	2.7
B	mg/kg	NA	NA	NA	NA	NA	NA
Cd	mg/kg	0.02	0.28	0.04	0.04	0.07	0.05
Cl	mg/kg	30	204	46	68	1757	1534
Co	mg/kg	1.4	3.8	2.1	6.8	14.7	9.8
Cr	mg/kg	2	8	3	12	20	18
Cu	mg/kg	7	14	10	18	27	20
F	mg/kg	32	99	52	62	126	82
Hg	mg/kg	0.03	0.1	0.06	0.02	0.06	0.04
U	mg/kg	NA	NA	NA	NA	NA	NA
Mg	% by Wt	0.09	0.2	0.15	0.05	0.14	0.06
Mn	mg/kg	0	38	8	7	78	21
Mo	mg/kg	NA	NA	NA	NA	NA	NA
Na	mg/kg	0.04	0.08	0.06	0.02	0.09	0.04
Ni	mg/kg	2	10	3	12	24	18
Pb	mg/kg	0.9	3.6	1.9	5.5	11	8.4
Sb	mg/kg	0	0.4	0.1	0.3	2.1	0.9
Se	mg/kg	0.25	2	0.5	2.3	4.17	2.5
Sr	mg/kg	0	0	0	0	0	0
V	mg/kg	7	23	11	24	44	34
Zn	mg/kg	2	32	7	8	21	14

There are two flue gas cases for FGD design basis.		
Case	Load and Fuel	Relevance
Case 1: Max Load, PRB Coal	923MW, 0.3% S 11,800 Btu/lb PRB	Primary fuel will be PRB. Primary scrubber design case with 92.8% SO <sub>2</sub> removal. The FGD system is to be robust and rigorous for this case, with complete redundancy and equipment sizing margins.
Case 2: Max. Load, Appalachian Coal	923MW, 1.5% S 17,800 Btu/lb Appalachian	Appalachian coal may be used in future. Secondary scrubber design case with 95% SO <sub>2</sub> removal. The FGD system is to be robust and rigorous for this case, with complete redundancy and equipment sizing margins.

**BASIC DESIGN BASIS**

**SCHERER UNITS 1-4**

**DRY FGD**

	Case #	1	2				
	Case Description	0.3% Sulfur Max. 923MW PRB	1.5% Sulfur Max. 923MW Appalachian				
<b>Raw flue gas condition at Spray Dryer Absorber Inlet</b>							
Mass flow (incl. ACl)	lb/hr	11,283,000	10,689,000				
Flue gas pressure	In. WG	0.0	0.0				
Volume flow	acfm	3,904,000	3,651,000				
at 88F	acfm-w	2,503,000	2,341,000				
O2	lb/hr	720,800	704,300				
N2	lb/hr	7,570,000	7,400,000				
Ar	lb/hr	129,900	126,900				
CO2	lb/hr	1,977,000	1,841,000				
SO2	lb/hr	6,262	21,035				
SO3	lb/hr	79	266				
H2O	lb/hr	877,300	592,600				
HCl	lb/hr	109.00	1,458.00				
HF	lb/hr	59.00	99.00				
H2O	vol%	12.50	9.03				
O2	vol%	5.78	6.04				
CO2	vol%	11.53	11.48				
SO2	ppm-d	290	990				
SO3	ppm-d	3	13				
HCl	ppm-d	10	120				
HF	ppm-d	9	15				
Particulate matter	lb/hr	2,087	2,060				
	lb/mmBtu	0.230	0.227				
	gr/scf-d						
Temperature	F	350	350				
Pressure	In wg	0.0	0.0				
SO <sub>2</sub> → SO <sub>3</sub> conversion in boiler	%	1	1				
SO <sub>2</sub> → SO <sub>3</sub> conversion in SCR	%	1	1				
<b>Clean gas condition</b>							
Gas temperature	F	169	162				
SO2	lb/hr	454	1,064				
	ppm(d)	20.0	49.0				
Particulate matter	lb/hr	136	136				
	lb/mmBtu	0.015	0.015				
Mist	gpm/ft2	NA	NA				
Desulfurization efficiency	%	92.8	95.0				
Particulate matter removal	%	99.82	99.92				
<b>FGD Process</b>							
FGD Process		Lime Spray Dryer Process					
<b>FGD Byproduct Mixture</b>							
Base Case		Landfill					



**BASIC DESIGN BASIS**

**SCHERER UNITS 1 - 4**

**DRY FGD**

Composition	w%	Ca(OH) <sub>2</sub>	16.0%	
	w%	CaSO <sub>3</sub> ·½H <sub>2</sub> O	80.0%	
	w%	CaSO <sub>4</sub> ·2H <sub>2</sub> O	Incl. above	
	w%	CaCl <sub>2</sub> ·2H <sub>2</sub> O	Incl. above	
	w%	Inerts + Carbon	Incl. above	
	w%	Flyash	3.0%	
	w%	Moisture	2.0%	
		Mean Particle Size		
Bulk density	lb/ft <sup>3</sup>	103 lb/ft <sup>3</sup> for landfill sizing		
<b>Lime</b>		<b>Design Basis</b>	<b>Range</b>	
Type		Pebble		
Receiving particle size	inch	¾ X 0		
Chemical Composition				
CaO	wt%-d	90.0		
Inerts	wt%-d	10.0		
Moisture	wt%	0.0		
Grindability	kWh/ton			
Bulk density	lb/ft <sup>3</sup>	70 lb/ft <sup>3</sup> for structural load, 60 lb/ft <sup>3</sup> for volume capacity of silos		
Reactivity	%			
<b>Makeup Water</b>				
Name	-	Service water pond		
B.L.		Intake from pond		
Temperature at B.L.	F	Ambient		
Pressure at B.L.	psig	Atmospheric		
Composition*				
Magnesium	ppm	1.6		
Calcium	ppm			
Sodium	ppm			
Potassium	ppm			
Chloride	ppm			
Bicarbonate	ppm			
Sulfate	ppm	10		
Iron	ppm	0.68		
Silica	ppm			
pH s.u.	-			
Turbidity, NTU	ppm			
TOC	ppm	2		
COD	ppm	12		
TSS	ppm	12		
Total Hardness	ppm as CaCO <sub>3</sub>			
*From 1988 data, will obtain more current data.				

**BASIC DESIGN BASIS**

**SCHERER UNITS 1 - 4**

**DRY FGD**

Cooling Water (Raw water, open loop)	psi	Supply	Return			
		Atmospheric	psi	40	psi	
Pressure						
Temperature (Max)	F	See Makeup	103			
		Water Conditions	deg F		deg F	
<b>Air</b>						
Name		Instrument		Service		
Supply pressure	psig	Max			Max	
	psig	Min			Min	
Supply temperature	F	Max			Max	
	F	Min			Min	
Dew point	F	Dry, Oil-free (-10F)				
<b>Steam</b>						
Supply pressure	psig	Max	N/A			
	psig	Min	N/A			
Supply temperature	F	Max	N/A			
	F	Min	N/A			
<b>Electrical Power</b>						
V - F - Hz		> 250HP	4160	3φ	60Hz	Advatech Scope (as required)
		< 250HP	480	3φ	60Hz	Advatech Scope (as required)

<b>4. System Design Requirement</b>	
<b>Gas Path System</b>	
Duct	1 x 100 % Capacity
Velocity	60 ft/s max
By-pass	To existing stack
Stack	Existing (liner to be coated)
type	Dry stack
Gas Velocity	Existing
Height	Existing
ID Booster Fan	2 x 50 % Capacity Axial
ID Booster Fan Test Block	15 % Flowrate margin on Case 1 (923MW) gas flow
ID Booster Fan Test Block	32 % Pressure margin on Case 1 (923MW) SPR
<b>Lime Receiving System</b>	<i>(Lime Bulk Storage)</i>
System capacity	1+0 x 100 % Capacity at 1.5% S Coal (future)***
Storage Capacity	30 days at 1.5% S coal (future)*** (6 silos)
Feeder capacity	1+0 x 100 % Capacity at 1.5% S Coal (future)***
Conveyor capacity	1+0 x 100 % Capacity at 1.5% S Coal (future)***
Operation time	24 hrs per day
<b>Lime Supply System</b>	<i>(feed to Vertimill Slaker)</i>
System capacity	1+0 x 33 % Capacity at 1.5% S Coal (future)*** per silo
Slurry Storage Tank Capacity	8 hrs at 1.5% S coal (future)*** - common for 6 slakers
Feeder capacity	1+0 x 33 % Capacity per silo
Lime prep. area sump/pump/agitator	1 set of 1 + 1 pumps, 1 + 0 agitator
Operation time	24 hrs per day

BASIC DESIGN BASIS

SCHERER UNITS 1-4

DRY FGD

<b>Limestone Supply System</b>	
System Capacity	(Slurry feed to SDA's) 1 x 100 % Capacity at 1.5% S Coal (future)*** per pair of units
Slurry Feed Tank Capacity	2 hrs at 1.5% S coal (future)*** - 1 per pair of units
Limestone slurry feed pump	1+1 x 100 % Capacity at 1.5% S Coal (future)*** per pair of units
Operation time	24 hrs per day
<b>Absorption System</b>	
Lime Spray Dryers	3+0 x 100% capacity
Pulse Jet Fabric Filter	2+0 x 100% capacity
Absorber area sump/pump/agitator	1 set of 1 + 1 pumps, 1 + 0 agitator - per pair of units
Operation time	24 hrs per day
<b>Recycle Ash System</b>	
Silo Storage Capacity	8 hrs - 1 silos per unit
Mixers	1+1 x 100% per unit
Slurry Storage Tank Capacity	4 hrs - 1 per unit
Slurry Feed Pumps	1+1 x 100% per unit
Operation time	24 hrs per day
<b>Flyash Handling System</b>	
Storage Capacity	4 days @ 1.5% S coal (future)***
Operation time	8-10 hrs per day
*** = 1.5% S coal may be used in the future and therefore is used as the design coal. The plant is currently using 0.3% S coal.	
<b>Utility Systems</b>	
Process Water Tank	N/R
Process Water Intake Pumps	1+1 x 100 % Capacity if req'd
FGD Plant Air Compressor	1+1 x 100 % Capacity

Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B


## APPENDIX C

### FLUE GAS FLOW DIAGRAMS

SCHR-1-SK-253-305-001  
SCHR-1-SK-253-305-002  
SCHR-1-SK-253-305-003  
SCHR-1-SK-253-305-004  
SCHR-1-SK-253-305-005




**WorleyParsons**  
resources & energy



NOTES

PROJECT NO. 244 PROJECT NAME: Southern Power Plant PROJECT LOCATION: Florida PROJECT OWNER: Southern Power Corp. PROJECT ENGINEER: J. D. BENDER PROJECT NO. 244	
DATE: 10/15/68 DRAWING NO.: SCHR-0-SK-253-305-001 SHEET NO.: 1	PROJECT NO. 244 PROJECT NAME: Southern Power Plant PROJECT LOCATION: Florida PROJECT OWNER: Southern Power Corp. PROJECT ENGINEER: J. D. BENDER PROJECT NO. 244
<b>WorleyParsons</b> CONSULTING ENGINEERS	
<b>SOUTHERN POWER COMPANY</b> PLANT SCHEMER	
WET / DRY FGD STUDY FLUE GAS FLOW DIAGRAM EXISTING TYPICAL UNIT	
SCALE: AS SHOWN DATE: 10/15/68 DRAWING NO.: SCHR-0-SK-253-305-001 SHEET NO.: 1	

Florida Power & Light  
 Docket No. 070007-E1  
 Staff's Fourth Set of Interrogatories  
 Interrogatory No. 36  
 Attachment I, Page 66 of 131



NOTES:

DESIGNED BY	DATE	APPROVED BY	DATE
REVISED BY	DATE	REVISIONS	DATE
PROJECT NO.	PROJECT NAME		
SCALE	SHEET NO. OF TOTAL SHEETS		
DATE	DRAWN BY		
CHECKED BY	PROJECT MANAGER		
DATE	PROJECT NO.		
PROJECT NAME	PROJECT LOCATION		
CLIENT	PROJECT NO.		
PROJECT NO.	PROJECT NAME		
PROJECT LOCATION	PROJECT NO.		
PROJECT NO.	PROJECT NAME		
PROJECT LOCATION	PROJECT NO.		
PROJECT NO.	PROJECT NAME		
PROJECT LOCATION	PROJECT NO.		




**SOUTHERN COMPANY**  
 PLANT ENGINEER

WET/ DRY FGD STUDY  
 FLUE GAS FLOW DIAGRAM  
 MERCURY CONTROL ADDITION - PHASE I  
 TYPICAL UNIT

DATE: APR 2 1991  
 SHEET NO. 36 OF 36  
 PROJECT NO. SCHR-0-SK-253-305-002

Florida Power & Light  
 Docket No. 070007-E1  
 Staff's Fourth Set of Interrogatories  
 Interrogatory No. 36  
 Attachment J, Page 67 of 131




NOTES:

DESIGNED BY	DATE
CHECKED BY	
APPROVED BY	
DATE	
SCALE	
PROJECT NO.	
CLIENT	
LOCATION	
DESCRIPTION	
REVISIONS	
NO.	DESCRIPTION
1	
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	
25	
26	
27	
28	
29	
30	
31	
32	
33	
34	
35	
36	
37	
38	
39	
40	
41	
42	
43	
44	
45	
46	
47	
48	
49	
50	
51	
52	
53	
54	
55	
56	
57	
58	
59	
60	
61	
62	
63	
64	
65	
66	
67	
68	
69	
70	
71	
72	
73	
74	
75	
76	
77	
78	
79	
80	
81	
82	
83	
84	
85	
86	
87	
88	
89	
90	
91	
92	
93	
94	
95	
96	
97	
98	
99	
100	

WorleyParsons  
SOUTHERN AIR COMPANY  
PLANT SCHERER  
WET/ DRY FGD STUDY  
FLUE GAS FLOW DIAGRAM  
SCR ADDITION - PHASE 2  
TYPICAL UNIT

PROJECT NO. SCHR-0-SX-253-305-003

Florida Power & Light  
Docket No. 070007-E1  
Staff's Fourth Set of Interrogatories  
Interrogatory No. 36  
Attachment I, Page 68 of 131




NOTES:

<b>REVISIONS</b>	
NO.	DATE
1	04/22/04
2	05/14/04
3	05/14/04
4	05/14/04
5	05/14/04
6	05/14/04
7	05/14/04
8	05/14/04
9	05/14/04
10	05/14/04
11	05/14/04
12	05/14/04
13	05/14/04
14	05/14/04
15	05/14/04
16	05/14/04
17	05/14/04
18	05/14/04
19	05/14/04
20	05/14/04
21	05/14/04
22	05/14/04
23	05/14/04
24	05/14/04
25	05/14/04
26	05/14/04
27	05/14/04
28	05/14/04
29	05/14/04
30	05/14/04
31	05/14/04
32	05/14/04
33	05/14/04
34	05/14/04
35	05/14/04
36	05/14/04
37	05/14/04
38	05/14/04
39	05/14/04
40	05/14/04
41	05/14/04
42	05/14/04
43	05/14/04
44	05/14/04
45	05/14/04
46	05/14/04
47	05/14/04
48	05/14/04
49	05/14/04
50	05/14/04
51	05/14/04
52	05/14/04
53	05/14/04
54	05/14/04
55	05/14/04
56	05/14/04
57	05/14/04
58	05/14/04
59	05/14/04
60	05/14/04
61	05/14/04
62	05/14/04
63	05/14/04
64	05/14/04
65	05/14/04
66	05/14/04
67	05/14/04
68	05/14/04
69	05/14/04
70	05/14/04
71	05/14/04
72	05/14/04
73	05/14/04
74	05/14/04
75	05/14/04
76	05/14/04
77	05/14/04
78	05/14/04
79	05/14/04
80	05/14/04
81	05/14/04
82	05/14/04
83	05/14/04
84	05/14/04
85	05/14/04
86	05/14/04
87	05/14/04
88	05/14/04
89	05/14/04
90	05/14/04
91	05/14/04
92	05/14/04
93	05/14/04
94	05/14/04
95	05/14/04
96	05/14/04
97	05/14/04
98	05/14/04
99	05/14/04
100	05/14/04
101	05/14/04
102	05/14/04
103	05/14/04
104	05/14/04
105	05/14/04
106	05/14/04
107	05/14/04
108	05/14/04
109	05/14/04
110	05/14/04
111	05/14/04
112	05/14/04
113	05/14/04
114	05/14/04
115	05/14/04
116	05/14/04
117	05/14/04
118	05/14/04
119	05/14/04
120	05/14/04
121	05/14/04
122	05/14/04
123	05/14/04
124	05/14/04
125	05/14/04
126	05/14/04
127	05/14/04
128	05/14/04
129	05/14/04
130	05/14/04
131	05/14/04
132	05/14/04
133	05/14/04
134	05/14/04
135	05/14/04
136	05/14/04
137	05/14/04
138	05/14/04
139	05/14/04
140	05/14/04
141	05/14/04
142	05/14/04
143	05/14/04
144	05/14/04
145	05/14/04
146	05/14/04
147	05/14/04
148	05/14/04
149	05/14/04
150	05/14/04

**WorleyParsons**  
**SOUTHERN POWER COMPANY**  
**PLANT SCHEMATIC**  
**WET/ DRY FGD STUDY**  
**FLUE GAS FLOW DIAGRAM**  
**WET FGD ADDITION - PHASE 3A**  
**TYPICAL UNIT**  
**SCHR-0-SK-253-305-004**





DATE	10/1/85	BY	J. B. WELLS
PROJECT	SOUTHERN COMPANY		
UNIT	UNIT 1		
DESCRIPTION	FLUE GAS FLOW DIAGRAM		
SCALE	AS SHOWN		
APP'D	[Signature]		
CHECKED	[Signature]		
DESIGNED	[Signature]		
DRAWN	[Signature]		
DATE	10/1/85		
BY	J. B. WELLS		
PROJECT	SOUTHERN COMPANY		
UNIT	UNIT 1		
DESCRIPTION	FLUE GAS FLOW DIAGRAM		
SCALE	AS SHOWN		
APP'D	[Signature]		
CHECKED	[Signature]		
DESIGNED	[Signature]		
DRAWN	[Signature]		
DATE	10/1/85		
BY	J. B. WELLS		

**WorleyParsons**  
ENGINEERS & ARCHITECTS

**SOUTHERN COMPANY**  
PLANT ENGINEER

WET DRY FGD STUDY  
FLUE GAS FLOW DIAGRAM  
DRY FGD ADDITION - PHASE 2B  
TYPICAL UNIT

NO. SCHR-8-SK-253-385-885 A

Florida Power & Light  
 Docket No. 070007-E1  
 Staff's Fourth Set of Interrogatories  
 Interrogatory No. 36  
 Attachment I, Page 70 of 131

Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

## APPENDIX D


### CONCEPTUAL PROCESS DESIGN – WET FGD

- Limestone Handling Flow Diagram  
SCHR-0-SK-569-304-001
- FGD Process Flow Diagram (2 shts)  
SCHR-0-SK-021-305-101  
SCHR-0-SK-021-305-102
- Combustion Calculations
- Material Balance



**WorleyParsons**  
resources & energy





**WorleyParsons**  
resources & energy


**SOUTHERN POWER COMPANY**  
 PLANT SCHEMER

WET/DRY FEED STUDY  
 PROCESS FLOW DIAGRAM  
 WET FEED - GAS SCRUBBING

REV: 10/2/87

SCHR-B-SK-021-305-101    A

Florida Power & Light  
 Docket No. 07007-ET  
 Staff's Fourth Set of Interrogatory  
 Interrogatory No. 36  
 Attachment I, Page 73 of 131



Florida Power & Light  
 Docket No. 070007-51  
 Staff's Fourth Set of Interrogatories  
 Interrogatory No. 36  
 Attachment I, Page 74 of 131



**WorleyParsons** CLIENT NAME: **Georgia Power & Southern Company** Revision: \_\_\_\_\_  
 PROJECT NAME: **Scherer FGD Study** *WST* Original: \_\_\_\_\_  
 SUBJECT: **Design Basis (MCR) - Appalachian Coal** Revisit: \_\_\_\_\_  
 DATE: \_\_\_\_\_  
 JOB NUMBER: \_\_\_\_\_

COAL COMBUSTION CALCULATION  
 DESIGN BASIS (MCR) - Appalachian Coal  
 CALCULATION NUMBER: \_\_\_\_\_

Type	Coal Moisture or Coal Analysis		Appalachian Coal		Moisture	M.C. Cont	Major Component Analysis								N2 Generation and Airborne Requirements for SCR
	PPYCB	AD. Unit	Btu/lb	M.C. Cont			M.C. Cont	CO2	H2O	SO2	NOx	O2	AR	HCL	
Carbon	71.18%	70,884	12,911	8.8569	8.8569										
Hydrogen	4.54%	4,543	3,918	7.2466	1.2464										
Sulfur	1.59%	1,590	3,164	0.0487	0.0487										
Nitrogen	1.39%	1,390	28,613	0.3575	0.3575										
Moisture	6.11%	6,127	16,615	0.1717	0.1717										
Oxygen	8.48%	8,480	31,930	0.0084	0.0084										
Chlorine	0.29%	0,290	36,453	0.0004	0.0004										
Fluorine	0.21%	0,210	19,928	0.0001	0.0001										
Ash	8.24%	8,240													
TOTAL	100.00%	99,485													
Excess air %	38.00%	37,749	7.12%												
HEF	1268														
Coal Heating Value	12,917														
% Difference	0.16%														
DETERMINANTS															
Bar Press 144	26.43														
Temp F	90.36														
Rel Humidity %	81.20														
Water Vapor Pressure	0.644														
W. Cont. W. air	0.008														
Electrical Air (PPYCB)	0.0009														
Flow Rate (SCFM)	48,913.44														
Flow Rate (M3/hr)	1,393.67														
Flow Rate (kg/hr)	181,909.17														
Flow Rate (lb/hr)	3,980,000.00														
Flow Rate (M3/hr)	1,393.67														
Flow Rate (kg/hr)	3,980,000.00														
Flow Rate (lb/hr)	8,670,000.00														
Flow Rate (M3/hr)	1,393.67														
Flow Rate (kg/hr)	3,980,000.00														
Flow Rate (lb/hr)	8,670,000.00														
TOTALS	1,393.67	3,980,000.00													
Actual Air Including Losses	19,363.158														

Boiler Heat Input		Air Flow Rate Calculation		Gas Flow Rate Calculation		Boiler Efficiency Calc (Heat Loss Method)		Ash Disposition		Coal Analysis		N2 Generation and Airborne Requirements for SCR	
Btu/hr	kg/hr	Temp F	% MO. Cont	Btu/hr	M3/hr	Temp F	% MO. Cont	Wt %	Wt %	CO2	H2O	SO2	NOx
9.87440E+09	708,938	12.00	10,303,156	0.0700	2,467,228	126.0	-6.80	11,033,548	0.0340	6,760,123			
9.87440E+08	708,938	126.0	10,303,156	0.0707	2,460,804	126.0	17.00	11,033,548	0.0489	3,685,252			
9.87440E+06	708,938	88.0	10,303,156	0.0733	2,361,438	126.0	12.60	11,033,548	0.0605	3,040,013			
9.87440E+04	708,938	70.0	10,303,156	0.0747	2,318,630	126.0	12.00	11,033,548	0.0571	3,526,088			
9.87440E+02	708,938		10,303,156	0.0836	2,079,841	88.0	0.800	11,033,548	0.0761	2,416,182			
BOILER EFFICIENCY CALC (HEAT LOSS METHOD)		ASH DISPOSITION		COAL ANALYSIS		N2 GENERATION AND AIRBORNE REQUIREMENTS FOR SCR		TOTAL HEAT INPUT Btu/C		BOILER EFFICIENCY %		N2 GENERATION AND AIRBORNE REQUIREMENTS FOR SCR	
Fly Ash %	0.23	Total Ash	0.0080	CO2	10.1500	H2O	7.0942	SO2	2.2784	NOx	0.0000	0.0000	0.0000
URC in Ash %	4.8	Flux/Total Ash	0.1733	LO2ES	14384	LO2	6348	SO2	10	NOx	1	0.0000	0.0000
URC in Ash %	0.15	Total Flux	0.1733	Flux	14384	Flux	6348	Flux	10	Flux	1	0.0000	0.0000
CO %	0	Bottom Ash	0.0080	Flux	14384	Flux	6348	Flux	10	Flux	1	0.0000	0.0000
Residual & Other %	0.23	Ash to FGD	0.0033	Flux	14384	Flux	6348	Flux	10	Flux	1	0.0000	0.0000
A H Lossage (% Hot air)	15	Ash to ESP	0.1700	Flux	14384	Flux	6348	Flux	10	Flux	1	0.0000	0.0000
A H Lossage (% Hot air)	0.42	Flux	0.1733	Flux	14384	Flux	6348	Flux	10	Flux	1	0.0000	0.0000
No-Stackage gas loss (%)	345	Flux	0.1733	Flux	14384	Flux	6348	Flux	10	Flux	1	0.0000	0.0000
A H Hot Air Temp (F)	80	Flux	0.1733	Flux	14384	Flux	6348	Flux	10	Flux	1	0.0000	0.0000
TOTAL HEAT INPUT Btu/C		ASH DISPOSITION		COAL ANALYSIS		N2 GENERATION AND AIRBORNE REQUIREMENTS FOR SCR		TOTAL HEAT INPUT Btu/C		BOILER EFFICIENCY %		N2 GENERATION AND AIRBORNE REQUIREMENTS FOR SCR	
1,200,000								1,200,000		87.62%		N2 GENERATION AND AIRBORNE REQUIREMENTS FOR SCR	
87.62%								87.62%		87.62%		N2 GENERATION AND AIRBORNE REQUIREMENTS FOR SCR	

Florida Power & Light  
 Docket No. 070007-E1  
 Staff's Fourth Set of Interrogatories  
 Interrogatory No. 36  
 Attachment I, Page 75 of 131

	CLIENT NAME:	Georgia Power & Southern Company	Revisor:				JOB NUMBER:																										
	PROJECT NAME:	Scherer FGD Study <i>WEST</i>	Originator:																														
	SUBJECT:	Design Basis (MCR) - PRB Coal	Reviewer:					CALCULATION NUMBER:																									
	COAL COMBUSTION CALCULATION		Date:																														
Fuel:	Coal Name or Coal Identifier:	PRB Design Basis - rtrv From Proximate Analysis	Molal Combustion Products C.D.						NOx Generation and Abatement Requirements for SCR:																								
Carbon	51.210	51.131	12.011	4.25483	4.25063	4.257	CO2	1.701	SO2	0.008	NO	0.024	NOx Generation and Abatement Requirements for SCR:	Generated NOx																			
Hydrogen	3.430	3.430	2.018	1.70115	0.95958		H2O	1.511					NOx as NO2																				
Sulfur	0.300	0.300	32.064	0.00838	0.00978		SO2						NOx Removal																				
Nitrogen	0.885	0.885	26.013	0.02445			NO						NOx removed as NO2																				
Moisture	27.230	27.230	18.015	1.1149			O2						Molar NOx as NO2																				
Oxygen	11.838	11.930	31.989	0.37285	-0.37285		NO2						NO2 removed																				
Chlorine	0.019	0.019	25.453	0.00068			NO						NO2 removed as NO																				
Fluorine	0.005	0.005	18.998	0.00028			HCl						Molar NOx as NO																				
Ash	0.780	0.200					HF																										
TOTAL	100.008	89.921																															
Excess air %	66.00	O2% (dry gas)	7.001																														
HHV	9600																																
Calc. Heating Value	9600																																
% Difference	0.73%																																
INLET AIR DATA			Three Mole O2/C to Excess Mole O2/C = 2.7027			Total Mole O2/C = 7.11005			Mole H2O/C = 26.46741			Mole N2/C = 0.31808			Total Mole D A/C = 33.80218			Mole H2O/C as air = 4.50883			Total Mole W A/C = 25.36301			Total D A E/C = 0.6187743			Total W A A/C = 1.0080169						
Bar Press. "Hg	28.43	Mol CP/C = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%										
Temp F	80.80	Mol CP/C = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%										
Rel Humidity %	85.90	Mol CP/C = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%										
Water Vapor Press. psia	0.6981	Mol CP/C = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%										
to mol/lb dry air	0.0280	Mol CP/C = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%										
Theoretical Air (lb per mole fuel)	10.65735	Mol CP/C = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%										
Theo Mole O2/C	4.7404	Mol CP/C = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%										
Theo Mole H2O/C	17.8458	Mol CP/C = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%										
Theo Mole A/C	0.21245	Mol CP/C = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%										
Theo Mole H2O/C	0.95728	Mol CP/C = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%			Mol H2O = 100.00%										
(Cb = 100 lb coal)	TOTALS:	1.00000	248.98837	lbmol/hr																													
Actual Air Including Excess:	373,002.66	lbmol/hr																															
	10,836,218	lb dry air																															
BOILER EFFICIENCY CALC (HEAT LOSS METHOD):			ASH DISPOSITION:			LOSSES:			TOTAL HEAT INPUT:			BOILER EFFICIENCY %:			Total:			W Loss:			Fuel Dryness Temperature:												
Coal Gas Temp (F, inlet)	233	Total Ash	55,904	lb	Losses to Air	10398	Losses to Water	1925	Total Heat Input	84,000	Boiler Efficiency %	84.23%	Total	82,298	W Loss	7.24%	Fuel Dryness Temperature	311	Total	82,298	W Loss	7.24%	Fuel Dryness Temperature	311									
UBC to Ash %	1.8	Flashes/Total Ash	0.39	Losses to Air	10398	Losses to Water	1925	Total Heat Input	84,000	Boiler Efficiency %	84.23%	Total	82,298	W Loss	7.24%	Fuel Dryness Temperature	311	Total	82,298	W Loss	7.24%	Fuel Dryness Temperature	311										
UBC to C	0.070	Total Flashes	50,134	lb	Losses to Air	10398	Losses to Water	1925	Total Heat Input	84,000	Boiler Efficiency %	84.23%	Total	82,298	W Loss	7.24%	Fuel Dryness Temperature	311	Total	82,298	W Loss	7.24%	Fuel Dryness Temperature	311									
CO ppm	0	Bottom Ash	5,370	lb	Losses to Air	10398	Losses to Water	1925	Total Heat Input	84,000	Boiler Efficiency %	84.23%	Total	82,298	W Loss	7.24%	Fuel Dryness Temperature	311	Total	82,298	W Loss	7.24%	Fuel Dryness Temperature	311									
Radiation & Conr %	8.25	Ash to ESP	5,828	lb	Losses to Air	10398	Losses to Water	1925	Total Heat Input	84,000	Boiler Efficiency %	84.23%	Total	82,298	W Loss	7.24%	Fuel Dryness Temperature	311	Total	82,298	W Loss	7.24%	Fuel Dryness Temperature	311									
A H Leakage (% base air)	15	Ash to ESP	50,134	lb	Losses to Air	10398	Losses to Water	1925	Total Heat Input	84,000	Boiler Efficiency %	84.23%	Total	82,298	W Loss	7.24%	Fuel Dryness Temperature	311	Total	82,298	W Loss	7.24%	Fuel Dryness Temperature	311									
A H Leakage (% AH base)	5.14	Ash to ESP	50,134	lb	Losses to Air	10398	Losses to Water	1925	Total Heat Input	84,000	Boiler Efficiency %	84.23%	Total	82,298	W Loss	7.24%	Fuel Dryness Temperature	311	Total	82,298	W Loss	7.24%	Fuel Dryness Temperature	311									
leakage gas temp (F)	244	(Units MAF to AH Hot Down)		Losses to Air	10398	Losses to Water	1925	Total Heat Input	84,000	Boiler Efficiency %	84.23%	Total	82,298	W Loss	7.24%	Fuel Dryness Temperature	311	Total	82,298	W Loss	7.24%	Fuel Dryness Temperature	311										
A H Inlet Air Temp (F)	80			Losses to Air	10398	Losses to Water	1925	Total Heat Input	84,000	Boiler Efficiency %	84.23%	Total	82,298	W Loss	7.24%	Fuel Dryness Temperature	311	Total	82,298	W Loss	7.24%	Fuel Dryness Temperature	311										

CALCULATION SHEET	CLIENT NAME:	George Power and Southern Company Services	Revised:	A	B	1	2	3	4	JOB NUMBER: 0
	PROJECT NAME:	Wind Access Study L1, L2 & FWD System	Designed:	B. Gresh						
	SUBJECT:	Overall Windmill Balance - Application Cost	Reviewed:							CALCULATION NUMBER: 0
	WORKSHEET:	Report Sheet - Material Balance	Date:							0

Gas Path

Stream		04	1	2	3	4		
AV		132,340	3,313	139,348	3,310	139,388	3,309	0
COF		1,048,598	42,844	1,091,358	42,844	1,091,896	42,838	0
HCL		1,790	26	1,590	36	0	0	0
HF		87	5	87	5	0	0	0
H2O		888,881	33,824	888,881	33,824	1,258,177	42,739	1,888
H2		7,715,880	276,851	7,715,881	276,851	7,764,880	276,816	38,989
H2S		0	0	0	0	0	0	0
NOx		281	18	304	18	304	18	0
OX		784,089	24,829	784,089	24,829	852,874	28,882	11,883
SO2		38,881	32	38,884	32	823	13	0
SO3		88	7	88	7	138	11	0
Total Gas Flow, Wet								
Total Gas Flow, Dry								
Coal	788,828	0			0		0	
Ash	0	88,848	851		113		6	
Total Solids Flow	788,828	88,851	854		113		6	
Gas Flow, 6CFR		3,837,318		3,718,181		3,858,318		7,382
Std. Vol.		29,284		28,282		28,287		28,817
Temp. Avg P		200		200		200		200
Pressure, psia		13.683		14.884		14.479		15.584



CALCULATION SHEET	CLIENT NAME:	Design Power and Southern Company Generation	Revision:	4	5	1	2	3	4	JOB NUMBER	5
	PROJECT NAME:	Plant Subarea Units 1, 2, 3 & FGD System	Originator:	R. Grubb							
	SUBJECT:	Overall Material Balance - Appraisal/Coal	Revised:								ENCALCULATION NUMBER
	WORKSHEET:	Report Sheet - Material Balance	Date:								8

Liquid Path

Stream	5	6	7	8	9	10
	lb/hr	lb/hr	lb/hr	lb/hr	lb/hr	lb/hr
CaCO3	34,437	34,432	1,491	6,894	-	-
CaSO3·1/2H2O	0	0	460	1,826	-	-
CaSO4·2H2O	0	3	49,612	342,434	14	1
H2O	3,690	104,896	166,255	134,251	263,673	43,814
MgCO3	267	263	131	524	-	-
Alkal Inerts	2,443	2,440	8,837	38,739	3	-
Flyash	0	0	1,725	6,894	-	-
TDS	0	1,493	6,441	3,394	17,236	1,483
Mass Flow Solids, lb/hr	38,248	38,261	74,883	209,266	17	1
Mass Flow Liquids, lb/hr	3,690	120,511	174,637	138,319	263,690	45,295
Flow, gpm	-	217	410	410	149	66
Specific Gravity	-	1.31	1.32	-	0.86	0.89
Cl-, ppmw	-	25,146	20,895	-	28,572	28,572
TSS, %	-	22.67	28.99	79.89	6.825	5.033
TDS, %	-	1.92	3.69	2.29	3.89	3.29

Stream	11	12	13	14
	lb/hr	lb/hr	lb/hr	lb/hr
CaCO3	0	0	-	-
CaSO3·1/2H2O	0	0	-	-
CaSO4·2H2O	0	0	-	13
MgCO3	0	0	-	0
H2O	269,983	1,379	3,179	269,164
Alkal Inerts	0	0	-	0
Flyash	0	0	-	0
TDS	0	0	168	13,799
Mass Flow Solids, lb/hr	0	0	-	13
Mass Flow Liquids, lb/hr	269,983	1,379	3,179	269,183
Flow, gpm	1233	3	7	1229
Specific Gravity	0.89	0.89	0.89	0.89
Cl-, ppmw	0	0	28,977	28,977
TSS, %	0.00	0.00	0.03	0.005
TDS, %	0.00	0.00	3.08	3.00



CALCULATION SHEET	CLIENT NAME:	Orange Power and Southern Company Generation	Revision:	A	B	1	2	3	4	JOB NUMBER	8	
	PROJECT NAME:	Plant Balance Units 1, 2, 3 & 4 FGD System	Originator:	B. Chaffin								
	SUBJECT:	Dewalt Material Balance - FGD Conf	Revisor:								CALCULATION NUMBER:	
	WORKSHEET:	Report Sheet - Material Balance	Date:									8

Liquid Path

Stream	5	6	7	8	9	10
	lb/hr	lb/hr	lb/hr	lb/hr	lb/hr	lb/hr
CaCO3	98.82	98.99	428			
CaSO3 1/2H2O	0	0	125			
CaSO4 2H2O	0	0	10,865			
H2O	80	41,284	43,431			
MgCO3	112	120	49			
Ash&Inerts	1,884	1,842	2,880			
Flyash	0	0	1,791			
TDS	0	398	624			
Mass Flow Solids, lb/hr	13,051	13,916	23,960			
Mass Flow Liquids, lb/hr	0	41,284	94,344			
Flow, gpm			216			
Specific Gravity		1.16	1.12			
Cl, ppmw		2,825	4,058			
TSS, %		24.56	29.00			
TDS, %		0.84	0.85			

Stream	11	12	13	14
	lb/hr	lb/hr	lb/hr	lb/hr
CaCO3	0	0		
CaSO3 1/2H2O	0	0		
CaSO4 2H2O	0	0		
MgCO3	0	0		
H2O	64,280	49		
Ash&Inerts	0	0		
Flyash	0	0		
TDS	7	7		
Mass Flow Solids, lb/hr	0	0		
Mass Flow Liquids, lb/hr	64,280	49		
Flow, gpm	1292	1		
Specific Gravity	0.99	0.99		
Cl, ppmw	0	0		
TSS, %	0.00	0.00		
TDS, %	0.00	0.00		

Southern Company Services  
Plant Scherer FGD Project

Florida Power & Light  
Docket No. 070007-EI  
Staff's Fourth Set of Interrogatories  
Interrogatory No. 36  
Attachment I, Page 81 of 131

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B


## APPENDIX E

### CONCEPTUAL PROCESS DESIGN – DRY FGD

- Lime Handling Flow Diagram  
SCHR-0-SK-569-304-002
- FGD Process Flow Diagram (2 shts)  
SCHR-0-SK-021-305-201  
SCHR-0-SK-021-305-202
- Combustion Calculations
- Material Balance




**WorleyParsons**  
resources & energy



NOTES:


SIX (6) SLO'S @ 40,000 TONS EACH  
 240,000 TONS TOTAL  
 150 BAY STORAGE

<b>WorleyParsons</b> <small>resources &amp; energy</small>	
<b>SOUTHERN COMPANY</b> <b>PLANT SCHERER</b>	
<b>DRY FGD</b> <b>LINE HANDLING</b> <b>FLDW SHEET</b>	
PROJECT NO. SCHR-0-SK-569-304-002 SHEET NO. 110	DATE: 01/24/87 DRAWN BY: [unintelligible] CHECKED BY: [unintelligible]



NOTES:  
1. ALL 4 UNITS SHW IDENTICAL FLOW

<b>WorleyParsons</b> <small>Engineering &amp; Construction</small>	
<b>SOUTHERN COMPANY</b> PLANT SCHERER	
WET/DRY FGD STUDY PROCESS FLOW DIAGRAM DRY FGD - GAS SCRUBBING	
PROJECT NO. SHEET NO.	DATE SCALE
DRAWN BY CHECKED BY	APPROVED BY
SCHR-0-SK-021-305-201 A	



NOTES:  
 1. ALL 4 SLOTS ARE SHOWN, NONE FLOW

 <b>WorleyParsons</b> <small>resources &amp; energy</small>	
 <b>SOUTHERN COMPANY</b> PLANT SCHEMER	
WET/DRY FGD STUDY PROCESS FLOW DIAGRAM DRY FGD - LINE PREP	
SCHR-0-SK-021-305-202    A	







**MATERIAL BALANCE - DRY FGD PROCESS w/ CAPP COAL**  
**Scherer Wet/Dry FGD Study**

Stream -	(Ref)	1	2	3	4	5
Flue Gas	Flue Gas	Flue Gas	Flue Gas	Flue Gas	Flue Gas	(Not
	from AH	to Spray	from Spray	from	to Stack	Used)
	to ESP	(inc. ACl)	Absorber	Baghouse		
Total gas, lb/hr	10,087,070	10,689,127	11,307,064	11,140,285	11,140,285	
Total (Gas), Dry	10,004,471	10,094,471	10,062,757	10,081,904	10,081,904	
Flow, ACFM	3,870,518	3,850,605	3,052,674	3,082,530	3,024,608	
Flow, SCFM	2,348,940	2,348,940	2,518,706	2,518,608	2,518,608	
Temp, °F	330	350	167	162	167	
Pressure, in.w.c.	-12.0	0.0	-3.0	-10.0	0.5	
Pressure, psia	14.02	14.46	14.35	14.09	14.47	
Density, lb/ft <sup>3</sup>	0.0485	0.0488	0.0608	0.0602	0.0602	
Part. lb/MMBtu	0.803	0.227	18.368	0.015	0.015	
SO <sub>2</sub> , ppmv	910.1	910.1	66.7	42.5	42.5	
SO <sub>2</sub> , lb/MMBtu	2.341	2.341	0.18	0.12	0.12	

Stream -	5	7	8	9	10	11	12	13	14	15
Solid/Liquid	Lime Feed	Slaker	Lime	Absorber	Baghouse	Recycle	Recycle	Total	Pin	Total
to	to	Water	Slurry to	Solids	Solids	Water	Slurry to	Solid	Mixer	to
	Slaker*	Feed**	Atomizer	Catch	Catch	Feed	Atomizer	Product	Water**	Landfill*
Component										
CaO, lb/hr	148,461	0	0	0	0	0	0	0	0	0
Ca(OH) <sub>2</sub> , lb/hr	0	0	48,378	2,811	25,278	0	16,437	11,864	0	46,656
Flyash, lb/hr	0	0	0	495	4,455	0	2,887	2,058	0	8,222
Other, lb/hr	16,273	0	4,068	15,214	138,813	0	88,962	63,129	0	252,514
TSS, lb/hr	162,735	0	52,446	18,520	168,546	0	108,295	78,848	0	307,393
H <sub>2</sub> O, lb/hr	0	676,404	157,338	378	3,399	322,878	324,886	1,568	13,941	34,155
Total, lb/hr	162,735	676,404	209,786	18,898	169,945	322,678	433,182	78,418	13,941	341,547
Flow, GPM		1351	383	-	-	845	743	-	-	28
Specific Gravity		1.000	1.155	-	-	1.000	1.165	-	-	1.000
Temp, °F		Ambient	100 - 150	167	162	Ambient	Ambient	162	Ambient	Ambient
pH			10 - 12.5	-	-		7 - 8	-	-	-
TSS, %	100	0	25.00	98	98	0	25	98	0	90
Max. Flow, GPM	-	-	-	-	-	-	-	-	-	-

\* 4 Units \* 4 Units

\*\* 2 Units \* 4 Units

MATERIAL BALANCE - DRY FGD PROCESS w/ PRB COAL  
Scherer Wet/Dry FGD Study

Stream -	(Ref)	1	2	3	4	5
Flue Gas	Flue Gas	Flue Gas	Flue Gas	Flue Gas	Flue Gas	(Not
	from AH	to Spray	from Spray	from	to Stack	Used)
	to ESP	Absorber	Absorber	Baghouse		
		(inc. ACI)				
Total gas, lb/hr	11,281,140	11,283,224	11,856,778	11,780,010	11,780,010	
Total (Gas), Dry	10,403,830	10,403,830	10,394,062	10,394,750	10,304,750	
Flow, ACFM	3,925,211	3,903,917	3,297,102	3,329,730	3,267,155	
Flow, SCFM	2,511,930	2,511,930	2,092,510	2,092,491	2,069,491	
Temp, °F	330	350	174	169	173	
Pressure, in.w.c.	-12.0	0.0	-3.0	-10.0	0.5	
Pressure, psia	14.02	14.46	14.35	14.09	14.47	
Density, lb/ft <sup>3</sup>	0.0479	0.0482	0.0595	0.0500	0.0590	
Part, lb/MMBtu	5.525	0.230	8.341	0.015	0.015	
SO <sub>2</sub> , ppmv	253.3	253.3	23.7	17.1	17.1	
SO <sub>2</sub> , lb/MMBtu	0.697	0.697	0.070	0.050	0.050	

Stream -	6	7	8	9	10	11	12	13	14	15
Solid/Liquid	Lime Feed	Slaker	Lime	Absorber	Baghouse	Recycle	Recycle	Total	Pin	Total
	to	Water	Slurry to	Solids	Solids	Water	Slurry to	Solid	Mixer	to
	Slaker*	Feed*	Atomizer	Catch	Catch	Feed	Atomizer	Product	Water**	Landfill*
Component										
CaO, lb/hr	41,394	0	0	0	0	0	0	0	0	0
Ca(OH) <sub>2</sub> , lb/hr	0	0	13,673	1,237	11,112	0	8,976	3,388	0	13,552
Flyash, lb/hr	0	0	0	760	8,824	0	5,512	2,081	0	8,322
Other, lb/hr	4,589	0	1,150	6,414	67,819	0	48,541	17,567	0	70,288
TSS, lb/hr	45,993	0	14,823	8,410	75,556	0	81,029	23,035	0	92,142
H <sub>2</sub> O, lb/hr	0	250,462	59,291	172	1,542	448,305	447,549	470	4,179	10,238
Total, lb/hr	45,993	250,462	74,114	8,582	77,098	448,305	508,578	23,506	4,179	102,380
Flow, GPM		500	133	-	-	893	947	-	8	-
Specific Gravity		1.000	1.117	-	-	1.000	1.073	-	1.000	-
Temp, °F		Ambient	100 - 150	174	169	Ambient	Ambient	169	Ambient	Ambient
pH		0	10 - 12.5	-	-	7 - 8	-	-	-	-
TSS, %		100	0	20	98	98	0	12	98	0
Max. Flow, GPM		0	-	-	-	-	-	-	-	-

\* 4 Units \* 4 Units

\*\* 2 Units \* 4 Units

Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

## APPENDIX F


### GENERAL ARRANGEMENTS – WET FGD

SCHR-0-SK-111-002-101  
SCHR-0-SK-111-002-102  
SCHR-0-SK-111-002-103  
SCHR-0-SK-111-002-104



**WorleyParsons**

resources & energy



- LANDMARK DESCRIPTION**
1. UNIT 1 ID BOOSTER FANS
  2. UNIT 1 MET FGD
  3. UNIT 2 ID BOOSTER FANS
  4. UNIT 2 MET FGD
  5. UNIT 1 82 FGD STACK
  6. UNIT 3 ID BOOSTER FANS
  7. UNIT 3 MET FGD
  8. UNIT 4 ID BOOSTER FANS
  9. UNIT 4 MET FGD
  10. UNIT 3 64 FGD STACK
  11. PIPE BRIDGE
  12. NEW RAILROAD SPURS
  13. LIMESTONE RAILCAR UNLOADING
  14. LIMESTONE RADIAL STACKER
  15. LIMESTONE STORAGE PILE, 60,000 TONS (30 DAY)
  16. LIMESTONE RECLAIM TUNNEL
  17. LIMESTONE CONVEYORS
  18. LIMESTONE PREPARATION
  19. MET FGD GYPHEM POND/ STACK
  20. EXISTING ASH POND

REVISIONS	DATE	DESCRIPTION
1	11/11/03	ISSUE FOR PERMITTING
2	01/14/04	REVISED TO REFLECT PERMITTING COMMENTS
3	02/10/04	REVISED TO REFLECT PERMITTING COMMENTS
4	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS
5	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS
6	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS
7	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS
8	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS
9	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS
10	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS
11	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS
12	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS
13	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS
14	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS
15	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS
16	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS
17	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS
18	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS
19	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS
20	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS
21	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS
22	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS
23	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS
24	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS
25	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS
26	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS
27	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS
28	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS
29	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS
30	03/02/04	REVISED TO REFLECT PERMITTING COMMENTS


**WorleyParsons**  
resources & energy

**SOUTHERN POWER COMPANY**  
PLANT SCHERER

WET/ DRY FGD STUDY  
WET FGD OVERALL SITE PLAN  
GENERAL ARRANGEMENT


1"=500'-0"  
SCHR-0-SK-111-002-101

Florida Power & Light  
Docket No. 070007-EI  
Staff's Fourth Set of Interrogatories  
Interrogatory No. 36  
Attachment I, Page 90 of 131



- COMPONENT DESCRIPTIONS**
- 1. UNIT 1 ID BOOSTER FANS
  - 2. UNIT 1 WET FGD
  - 3. UNIT 2 ID BOOSTER FANS
  - 4. UNIT 2 WET FGD
  - 5. UNIT 1 & 2 FGD STACK
  - 6. UNIT 3 ID BOOSTER FANS
  - 7. UNIT 3 WET FGD
  - 8. UNIT 4 ID BOOSTER FANS
  - 9. UNIT 4 WET FGD
  - 10. UNIT 3 & 4 FGD STACK
  - 11. PIPE BRIDGE
  - 12. UNIT 1 & 2 ELECTRICAL/CONTROLS BLDG.
  - 13. UNIT 3 & 4 ELECTRICAL/CONTROLS BLDG.


DATE	11/11/82	BY	W.P.
PROJECT	SOUTHERN COMPANY PLANT SCHEER WET/ DRY FGD ISLAND GENERAL ARRANGEMENT		
SCALE	AS SHOWN		
APP. BY	W.P.		
CHK. BY	W.P.		
DESIGNED BY	W.P.		
PROJECT NUMBER	SCHR-B-SK-111-082-102		
REV. NO.	1	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	2	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	3	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	4	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	5	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	6	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	7	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	8	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	9	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	10	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	11	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	12	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	13	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	14	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	15	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	16	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	17	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	18	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	19	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	20	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	21	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	22	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	23	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	24	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	25	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	26	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	27	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	28	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	29	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	30	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	31	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	32	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	33	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	34	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	35	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	36	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	37	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	38	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	39	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	40	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	41	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	42	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	43	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	44	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	45	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	46	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	47	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	48	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	49	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION
REV. NO.	50	REV. DATE	11/11/82
REV. BY	W.P.	REV. DESCRIPTION	ISSUE FOR CONSTRUCTION



NOTES:

DESIGNED BY	DATE
CHECKED BY	DATE
APPROVED BY	DATE
PROJECT NO.	
SCALE	
 <b>WorleyParsons</b> ENGINEERS & ARCHITECTS	
<b>SOUTHERN POWER COMPANY</b> PLANT SCHEMER	
WET/ DRY FGD STUDY WET FGD ELEVATION VIEWS GENERAL ARRANGEMENT	
PROJECT NO.	SCH-B-SK-111-002-103
SCALE	A

Florida Power & Light  
 Docket No. 070007-EI  
 Staff's Fourth Set of Interrogatories  
 Interrogatory No. 36  
 Attachment I, Page 92 of 131



- EQUIPMENT DESCRIPTION**
- 1. LIMESTONE UNLOADING
  - 2. LIMESTONE PADMA STACKER
  - 3. LIMESTONE PILE COLUMN TONS UN DATA
  - 4. LIMESTONE RECLAIM TUNNEL
  - 5. ESCAPE HATCH
  - 6. LIMESTONE CONVEYORS
  - 7. LIMESTONE SILO
  - 8. LIMESTONE PREPARATION BUILDING
  - 9. WPT BRIDGE TO WET FGD'S
  - 10. NEW ACCESS ROAD
  - 11. NEW RAIL SPURS

NOTES

**REFERENCE DRAWINGS**  
 SCHR-B-SK-369-384-001 - FLOW SHEET

- LEGEND**
- EXISTING STRUCTURE
  - PROPOSED STRUCTURE
  - EXISTING ROAD
  - PROPOSED ROAD

RAIL SPURS FOR  
 36 RAIL CARS EACH

RAIL SPUR FOR  
 36 RAIL CARS FIRST  
 UNLOADING HOPPERS



<b>1. MAUSCHER</b> PROJECT ENGINEER	
<b>2. MAUSCHER</b> PROJECT ENGINEER	
<b>3. MAUSCHER</b> PROJECT ENGINEER	
<b>4. MAUSCHER</b> PROJECT ENGINEER	
<b>5. MAUSCHER</b> PROJECT ENGINEER	
<b>6. MAUSCHER</b> PROJECT ENGINEER	
<b>7. MAUSCHER</b> PROJECT ENGINEER	
<b>8. MAUSCHER</b> PROJECT ENGINEER	
<b>9. MAUSCHER</b> PROJECT ENGINEER	
<b>10. MAUSCHER</b> PROJECT ENGINEER	
<b>11. MAUSCHER</b> PROJECT ENGINEER	
<b>12. MAUSCHER</b> PROJECT ENGINEER	
<b>13. MAUSCHER</b> PROJECT ENGINEER	
<b>14. MAUSCHER</b> PROJECT ENGINEER	
<b>15. MAUSCHER</b> PROJECT ENGINEER	
<b>16. MAUSCHER</b> PROJECT ENGINEER	
<b>17. MAUSCHER</b> PROJECT ENGINEER	
<b>18. MAUSCHER</b> PROJECT ENGINEER	
<b>19. MAUSCHER</b> PROJECT ENGINEER	
<b>20. MAUSCHER</b> PROJECT ENGINEER	
<b>21. MAUSCHER</b> PROJECT ENGINEER	
<b>22. MAUSCHER</b> PROJECT ENGINEER	
<b>23. MAUSCHER</b> PROJECT ENGINEER	
<b>24. MAUSCHER</b> PROJECT ENGINEER	
<b>25. MAUSCHER</b> PROJECT ENGINEER	
<b>26. MAUSCHER</b> PROJECT ENGINEER	
<b>27. MAUSCHER</b> PROJECT ENGINEER	
<b>28. MAUSCHER</b> PROJECT ENGINEER	
<b>29. MAUSCHER</b> PROJECT ENGINEER	
<b>30. MAUSCHER</b> PROJECT ENGINEER	
<b>31. MAUSCHER</b> PROJECT ENGINEER	
<b>32. MAUSCHER</b> PROJECT ENGINEER	
<b>33. MAUSCHER</b> PROJECT ENGINEER	
<b>34. MAUSCHER</b> PROJECT ENGINEER	
<b>35. MAUSCHER</b> PROJECT ENGINEER	
<b>36. MAUSCHER</b> PROJECT ENGINEER	
<b>37. MAUSCHER</b> PROJECT ENGINEER	
<b>38. MAUSCHER</b> PROJECT ENGINEER	
<b>39. MAUSCHER</b> PROJECT ENGINEER	
<b>40. MAUSCHER</b> PROJECT ENGINEER	
<b>41. MAUSCHER</b> PROJECT ENGINEER	
<b>42. MAUSCHER</b> PROJECT ENGINEER	
<b>43. MAUSCHER</b> PROJECT ENGINEER	
<b>44. MAUSCHER</b> PROJECT ENGINEER	
<b>45. MAUSCHER</b> PROJECT ENGINEER	
<b>46. MAUSCHER</b> PROJECT ENGINEER	
<b>47. MAUSCHER</b> PROJECT ENGINEER	
<b>48. MAUSCHER</b> PROJECT ENGINEER	
<b>49. MAUSCHER</b> PROJECT ENGINEER	
<b>50. MAUSCHER</b> PROJECT ENGINEER	
<b>51. MAUSCHER</b> PROJECT ENGINEER	
<b>52. MAUSCHER</b> PROJECT ENGINEER	
<b>53. MAUSCHER</b> PROJECT ENGINEER	
<b>54. MAUSCHER</b> PROJECT ENGINEER	
<b>55. MAUSCHER</b> PROJECT ENGINEER	
<b>56. MAUSCHER</b> PROJECT ENGINEER	
<b>57. MAUSCHER</b> PROJECT ENGINEER	
<b>58. MAUSCHER</b> PROJECT ENGINEER	
<b>59. MAUSCHER</b> PROJECT ENGINEER	
<b>60. MAUSCHER</b> PROJECT ENGINEER	
<b>61. MAUSCHER</b> PROJECT ENGINEER	
<b>62. MAUSCHER</b> PROJECT ENGINEER	
<b>63. MAUSCHER</b> PROJECT ENGINEER	
<b>64. MAUSCHER</b> PROJECT ENGINEER	
<b>65. MAUSCHER</b> PROJECT ENGINEER	
<b>66. MAUSCHER</b> PROJECT ENGINEER	
<b>67. MAUSCHER</b> PROJECT ENGINEER	
<b>68. MAUSCHER</b> PROJECT ENGINEER	
<b>69. MAUSCHER</b> PROJECT ENGINEER	
<b>70. MAUSCHER</b> PROJECT ENGINEER	
<b>71. MAUSCHER</b> PROJECT ENGINEER	
<b>72. MAUSCHER</b> PROJECT ENGINEER	
<b>73. MAUSCHER</b> PROJECT ENGINEER	
<b>74. MAUSCHER</b> PROJECT ENGINEER	
<b>75. MAUSCHER</b> PROJECT ENGINEER	
<b>76. MAUSCHER</b> PROJECT ENGINEER	
<b>77. MAUSCHER</b> PROJECT ENGINEER	
<b>78. MAUSCHER</b> PROJECT ENGINEER	
<b>79. MAUSCHER</b> PROJECT ENGINEER	
<b>80. MAUSCHER</b> PROJECT ENGINEER	
<b>81. MAUSCHER</b> PROJECT ENGINEER	
<b>82. MAUSCHER</b> PROJECT ENGINEER	
<b>83. MAUSCHER</b> PROJECT ENGINEER	
<b>84. MAUSCHER</b> PROJECT ENGINEER	
<b>85. MAUSCHER</b> PROJECT ENGINEER	
<b>86. MAUSCHER</b> PROJECT ENGINEER	
<b>87. MAUSCHER</b> PROJECT ENGINEER	
<b>88. MAUSCHER</b> PROJECT ENGINEER	
<b>89. MAUSCHER</b> PROJECT ENGINEER	
<b>90. MAUSCHER</b> PROJECT ENGINEER	
<b>91. MAUSCHER</b> PROJECT ENGINEER	
<b>92. MAUSCHER</b> PROJECT ENGINEER	
<b>93. MAUSCHER</b> PROJECT ENGINEER	
<b>94. MAUSCHER</b> PROJECT ENGINEER	
<b>95. MAUSCHER</b> PROJECT ENGINEER	
<b>96. MAUSCHER</b> PROJECT ENGINEER	
<b>97. MAUSCHER</b> PROJECT ENGINEER	
<b>98. MAUSCHER</b> PROJECT ENGINEER	
<b>99. MAUSCHER</b> PROJECT ENGINEER	
<b>100. MAUSCHER</b> PROJECT ENGINEER	

**WorleyParsons**  
 SERVICES & ENERGY

**SOUTHERN COMPANY**  
 PLANT SCHERER

WET/ DRY FGD STUDY  
 WET FGD LIMESTONE HANDLING  
 GENERAL ARRANGEMENT

FILE # SCHR-B-SK-111-002-104 A



Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B



## APPENDIX G

### GENERAL ARRANGEMENTS – DRY FGD

SCHR-0-SK-111-002-201  
SCHR-0-SK-111-002-202  
SCHR-0-SK-111-002-203  
SCHR-0-SK-111-002-204



**WorleyParsons**  
resources & energy




OVERALL SITE PLAN

**EQUIPMENT DESCRIPTION**

1. UNIT 1 DRY FGD
2. UNIT 2 DRY FGD
3. UNIT 1 & 2 MERCURY REMOVAL ACTIVATED CARBON SILOS
4. UNIT 1 MERCURY REMOVAL P.F.F.F
5. UNIT 2 MERCURY REMOVAL P.F.F.F
6. UNIT 1 SO BOOSTER FANS
7. UNIT 2 SO BOOSTER FANS
8. UNIT 1 P.F.F.F ADDITION FOR DRY FGD
9. UNIT 2 P.F.F.F ADDITION FOR DRY FGD
10. UNIT 3 DRY FGD
11. UNIT 4 DRY FGD
12. UNIT 3 & 4 MERCURY REMOVAL ACTIVATED CARBON SILOS
13. UNIT 4 MERCURY REMOVAL P.F.F.F
14. UNIT 3 MERCURY REMOVAL P.F.F.F
15. UNIT 4 P.F.F.F ADDITION FOR DRY FGD
16. UNIT 3 P.F.F.F ADDITION FOR DRY FGD
17. UNIT 3 SO BOOSTER FANS
18. UNIT 4 SO BOOSTER FANS
19. DRY FGD BY-PRODUCT LANDFILL
20. EXISTING ASH POND
21. NEW ASH SPLASH
22. LINE RAIL FOR UNLOADING
23. LINE CONVEYOR L2
24. LINE STORAGE SILOS

<p><b>WorleyParsons</b> APPRAISAL &amp; SURVEY</p>	
<p><b>SOUTHERN COMPANY</b> PLANT SCHOER</p>	
<p>WET/ DRY FGD STUDY DRY FGD OVERALL SITE PLAN GENERAL ARRANGEMENT</p>	
<p>DATE: 2010-07-27</p>	<p>PROJECT NO.: SCHR-0-SK-111-002-201</p>






- EQUIPMENT DESCRIPTION**
- 1. UNIT 1 DRY FGD
  - 2. UNIT 2 DRY FGD
  - 3. UNIT 1 & 2 MERCURY REMOVAL, ACTIVATED CARBON SILOS
  - 4. UNIT 1 MERCURY REMOVAL, P.F.F.F.
  - 5. UNIT 2 MERCURY REMOVAL, P.F.F.F.
  - 6. UNIT 1 30 BOOSTER FANS
  - 7. UNIT 2 30 BOOSTER FANS
  - 8. UNIT 1 P.F.F.F. ADDITION FOR DRY FGD
  - 9. UNIT 2 P.F.F.F. ADDITION FOR DRY FGD
  - 10. UNIT 1 DRY FGD
  - 11. UNIT 2 DRY FGD
  - 12. UNIT 3 & 4 MERCURY REMOVAL, ACTIVATED CARBON SILOS
  - 13. UNIT 4 MERCURY REMOVAL, P.F.F.F.
  - 14. UNIT 3 MERCURY REMOVAL, P.F.F.F.
  - 15. UNIT 4 P.F.F.F. ADDITION FOR DRY FGD
  - 16. UNIT 3 P.F.F.F. ADDITION FOR DRY FGD
  - 17. UNIT 3 30 BOOSTER FANS
  - 18. UNIT 4 30 BOOSTER FANS
  - 19. UNIT 1 & 2 RECYCLE/ELECTRICAL BLDG.
  - 20. UNIT 3 & 4 RECYCLE/ELECTRICAL BLDG.
  - 21. UNIT 1 & 2 ASH SILO
  - 22. UNIT 3 & 4 ASH SILO

<b>WorleyParsons</b> PLANNED & DESIGNED	
<b>SOUTHERN CO. COMPANY</b> PLANT SCHEDER	
WET/ DRY FGD STUDY DRY FGD ISLAND GENERAL ARRANGEMENT	
PROJECT NO.	SCHR-0-SK-111-002-202
DATE	NOV 09 2011
SCALE	AS SHOWN


Florida Power & Light  
 Docket No. 070007-EI  
 Staff's Fourth Set of Interrogatories  
 Interrogatory No. 36  
 Attachment I, Page 96 of 131



**NOTE:**  
DIMENSIONS ARE CONCEPTUAL -  
FOR ESTIMATING PURPOSES ONLY  
ELEVATIONS APPLY TO UNITS 3 & 4 -  
PLAN ORIENTATION OF EQUIPMENT DIFFERS

**WorleyParsons**  
SOUTHERN COPPER COMPANY  
PLANT SCHEDER  
VET/ DRY FGD STUDY  
DRY FGD ELEVATIONS VIEWS  
GENERAL ARRANGEMENT

**SCHR-B-SK-111-002-203**



**EQUIPMENT DESCRIPTION**  
 1. LINE IMPROVING  
 2. LINE CONVERTOR L2  
 3. LINE CONVERTOR L3 AND TRIPPER  
 4. LINE SILOS - (6) - SPECIAL SILOS FOR DAY STORAGE  
 5. LINE S&D PULVERIZER  
 6. NEW ACCESS ROAD  
 7. NEW RAIL SPUR  
 8. PIPE BRIDGE TO DRY POND  
 9. LINE SLURRY STORAGE TANK

**NOTES**

**REFERENCE DRAWINGS**  
 SCHR-B-SK-104-002 - FLOWDIAG

**LEGEND**  
 [Symbol] CONVEYOR  
 [Symbol] EQUIPMENT  
 [Symbol] ROAD

RAIL SPUR FOR  
60 RAIL CARS EACH

RAIL SPUR FOR  
20 RAIL CARS FAST  
LANDING HOPPERS

SCALE IN FEET  
 0 100 200 300

<b>WorleyParsons</b> <small>consultants &amp; engineers</small>	
<b>SOUTHERN RAIL COMPANY</b> PLANT SCHEDER	
WET/ DRY FGD STUDY DRY FGD LINE HANDLING GENERAL ARRANGEMENT	
PROJECT NO. SCHR-B-SK-111-002-204	
SHEET NO. 13	

Florida Power & Light  
 Docket No. 070007-EI  
 Staff's Fourth Set of Interrogatories  
 Interrogatory No. 36  
 Attachment I, Page 98 of 131

Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

## APPENDIX H

### LIFE CYCLE COST SPREADSHEETS – WET FGD

Table H-1

Table H-2




**WorleyParsons**  
resources & energy

**CONFIDENTIAL**

Florida Power & Light  
Docket No. 070007-E1  
Staff's Fourth Set of Interrogatories  
Interrogatory No. 36  
Attachment I, Page 100 of 131

b7(h)




**SCHUBB 14 WET HOD FACILITY**  
LifCycle Cost Calculations / Summary Cost  
TABLE II-1

CONFIDENTIAL

Florida Power & Light  
Docket No. 070007-E1  
Staff's Fourth Set of Interrogatorie  
Interrogatory No. 36  
Attachment I, Page 101 of 131

11/1/06


SCHIEBER I-4 WET FGD FACILITY  
Lifecycle Cost Calculation / Billback Cost  
TABLE 34






10/1/06

SCHIEBER 1-4 WET FGD FACILITY  
LIC/Cycle Cost Calculations / PHS Cost  
TABLE II-2



11/1/16

SCHUBER LA WET PCD FACILITY  
Life Cycle Cost Calculation / PRR Cost  
TABLE II-2



Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

## APPENDIX I

### LIFE CYCLE COST SPREADSHEETS – DRY FGD

Table I-1  
Table I-2




**WorleyParsons**  
resources & energy

# CONFIDENTIAL

Florida Power & Light  
Docket No. 070007-E1  
Staff's Fourth Set of Interrogatories  
Interrogatory No. 36  
Attachment I, Page 105 of 131

10/1/04

SCHREIBER LAJ DRY FGD FACILITY  
MicroCyst Cell Calculations / Measurement Cell  
TABLE I-1




# CONFIDENTIAL

Florida Power & Light  
Docket No. 070007-E1  
Staff's Fourth Set of Interrogator  
Interrogatory No. 36  
Attachment 1, Page 106 of 131

10/1/06

SCHEIDER 1-4 DRY FGD FACILITY  
LukCynta Corp. Capital & Business Cost  
TABLE 11




# CONFIDENTIAL

Florida Power & Light  
Docket No. 070007-E1  
Staff's Fourth Set of Interrogatories  
Interrogatory No. 36  
Attachment 1, Page 107 of 131


11/27/20

SCHEIBER 1-4 DRY FGD FACILITY  
LifeCycle Cost Calculation / FRB Cost  
TABLE 1.2



10/06

SCHUBER I-1 DRY FGD FACILITY  
LX-Cycle Cost Calculations / PRR Cost  
TABLE 12



Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

## APPENDIX J

### BASIS OF THE CAPITAL COST ESTIMATES



**WorleyParsons**  
resources & energy





## **Estimate Basis** **Southern Company – Plant Scherer (4x900 MW)** **Wet vs. Dry FGD Study**

### **Introduction**

WorleyParsons has been requested by Southern Company to prepare conceptual cost estimates to evaluate wet and dry flue gas de-sulfurization (FGD) technologies at Plant Scherer near Juliette, GA.

The estimates provide conceptual costs for engineering, procurement, and construction for the project. The estimates are based on brief descriptions and general arrangements. The estimate accuracy is - 25%/+35%. The pricing is based on the WorleyParsons pricing database and supplemented with quotes. The estimates were developed to evaluate the costs and benefits of the two technologies and are not intended to represent the complete project cost. A detailed cost estimate of the total scope must be prepared to establish costs suitable for budgeting.

### **Scope of Work**

The wet FGD estimate is based on using the Advatech FGD technology. The scope includes new chimneys, new booster ID fans, ductwork, wet FGD absorbers, new rail spurs, limestone unloading system, limestone handling system, limestone preparation system, field-erected tanks, gypsum disposal pond, additional DCS, start-up transformers, unit auxiliary transformers, foundations, sitework, utility piping, and bulk electrical. Engineered buildings are included for the limestone preparation system, and the electrical/control equipment.

The dry FGD estimate is based on current spray dryer absorber technology. The scope includes re-using the existing chimneys, new booster ID fans, ductwork, spray dry absorbers, fabric filter (baghouse) addition, new rail spurs, lime unloading system, lime storage and handling system, lime slaking system, SDA solids recycle system, field erected tanks, disposal solids handling system, disposal solids silo, gypsum landfill, additional DCS, start-up transformers, unit auxiliary transformers, foundations, sitework, utility piping, and bulk electrical. An engineered building is included for the SDA solids recycle system and electrical equipment. The lime slaking system is located under the lime storage silos.

### **General Basis**

- The mercury removal project will install fabric filters for removal of the particulate associated with the injection of activated carbon. As discussed in Section 7.2, these components would have to be upgraded with additional



**Estimate Basis**  
**Southern Company – Plant Scherer (4x900 MW)**  
**Wet vs. Dry FGD Study**

compartments for use in a dry FGD system. The cost for the additional bank of fabric filters is included in this study.

- Water treatment facilities are excluded.
- Gypsum dewatering facilities are excluded.
- Construction is based on multiple contracts with only one tier of overhead and profit.
- Crew rates are based on merit shop wage rates for Georgia. The crew rates include fringes, taxes, contractor indirect costs, and fee.
- The construction is based on 50-hour work-weeks.
- Removal of hazardous materials or site remediation is excluded.
- Aboveground and underground demolition and relocation allowances are included.
- All costs in the estimate are expressed in 4th Quarter 2006 dollars.
- Escalation is excluded.
- All taxes are excluded.
- BOP Engineering is included as an allowance.
- Construction management and start-up are by the Owner.
- General contingency of 15% is included.
- Owners' costs are excluded.
- Contractor's overhead and profit are included.
- Additional contractor's fees to cover risks typically associated on an EPC contract are excluded.

**Budgetary Quotes Received**

**Wet FGD**

- FGD island (furnish & erect)
- Booster ID fans and motors
- CEMS
- DCS addition
- Limestone preparation system

**Dry FGD**

- SDA (furnish only)
- Booster ID fans and motors
- CEMS
- DCS addition
- Lime slaking system
- Lime storage silos
- Lime unloading & conveying system



**Estimate Basis**  
**Southern Company – Plant Scherer (4x900 MW)**  
**Wet vs. Dry FGD Study**

- Disposal solids silo and handling system
- Stack & duct lining

Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

**APPENDIX K**  
**PROJECT CAPITAL COST ESTIMATES**  
**WET & DRY**



**WorleyParsons**  
resources & energy


**CONFIDENTIAL**


Florida Power & Light  
Docket No. 070007-E1  
Staff's Fourth Set of Interrogatories  
Interrogatory No. 36  
Attachment I, Page 114 of 131

**CONCEPTUAL ESTIMATE**


**Plant Scherer  
Wet vs Dry FGD Study**

11/20/2006






CONCEPTUAL ESTIMATE  
Plant Scherer  
Wet vs Dry FGD Study



# CONFIDENTIAL

Florida Power & Light  
Docket No. 070607-EI  
Staff's Fourth Set of Interrogatories  
Interrogatory No. 36  
Attachment I, Page 116 of 131



CONCEPTUAL ESTIMATE

Plant Scherer  
Wet FGD Study

# CONFIDENTIAL

Florida Power & Light  
Docket No. 070007-E1  
Staff's Fourth Set of Interrogatories  
Interrogatory No. 36  
Attachment 1, Page 117 of 131

CONCEPTUAL ESTIMATE

Plant Scherer  
Dry FGD Study



Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

**APPENDIX L**  
**MAJOR EQUIPMENT LISTS**  
**WET & DRY**



**WorleyParsons**  
resources & energy

**Plant Scherer  
Wet FGD Major Equipment List**

System	Equipment Name	Total Qty	Sizing Criteria	Size	Motor HP
1. Limestone Handling	Rail Spur	3	Minimum of one unit train reagent delivery		N/A
	Railcar Receiving Hopper - dual dischg	1	125 T capacity		N/A
	Vibratory Feeders (Receiving Hopper)	2	2200 TPH capacity		15
	Belt Feeder (Receiving Hopper)	1	2200 TPH capacity	72" belt, 110 fpm	
	Stockout Conveyor	1	2200 TPH capacity	48" belt, 500 fpm	15
	Belt Scale	1	48" belt		
	Magnetic Separator	1	48" belt		
	Dust Suppression System	1			15
	Limestone Radial Stackers	1	2200 TPH capacity	48" belt, 500 fpm	
	Reclaim Hoppers	2			
	Vibratory Feeders (Reclaim Hoppers)	2	480 TPH ea.		5
	Belt Feeders (Reclaim Hoppers)	2	480 TPH ea.	36" belt, 135 fpm	
	Reclaim Conveyors	2	480 TPH ea.	30" belt, 290 fpm	
	Limestone Day Bins w/Vent Filters	2	8 hr capacity	675 T	NA
2. Limestone Prep	Vibratory Feeders (Day Bins)	2	80 tph		3
	Slide Gates	2			N/A
	Weighbelt Feeder & Chutes	2	80 tph ea.		5
	Limestone Ball Mills	2	80 tph ea	15' dia x 30' lg	4000
	Mill Lubrication System	2			
	Mill Product Tank Agitator	2			15
	Mill Product Tank	2			N/A
	Classifier Feed Pumps	4			25
	Mill Classifier	2			N/A
	Limestone Slurry Storage Tank	1	8 hr working storage capacity	450,000 gal.	N/A
	Slurry Storage Tank Agitator	1			40
	Limestone Slurry Transfer Pumps	4			80
	Recycle Water Tank	1	8 hr working storage capacity	550,000 gal.	N/A
	Mill Area Sump Pumps	2			25
Mill Area Sump Agitator	1			15	
3. Wet FGD Area (Advatech Scrubber Island)	Absorber Vessel	4	Single Pass		N/A
	Absorber Recirc Pumps	36			1200
	Oxidation Air Blowers	8			2500
	Absorber Bleed Pumps	8			30
	Absorber Agitators	24			75
	Sump Pumps	4			25
	Sump Agitators	4			15

**Plant Scherer  
Wet FGD Major Equipment List**

System	Equipment Name	Total Qty	Sizing Criteria	Size	Motor HP
	Limestone Slurry Feed Tanks	2	2 hr storage capacity		N/A
	Limestone Slurry Feed Tank Agitators	2			40
	Limestone Slurry Feeds Pumps	8			80
<b>4. Flue Gas System</b>	Booster Fans	8			12000
	Stack Bypass Dampers w/Actuator	4			
	Bypass Damper Seal Air Fans	8			50
	WFGD Inlet Damper w/Actuator	4			
	WFGD Inlet Damper Seal Air Fans	8			50
<b>5. Mech. BOP Equipment</b>	Service Air Compressors	4			
	Air Receivers	3			
	Instrument Air Dryers	3			
	Reclaim Water Pumps	2			
	Recycle water Feed Pumps	2			
<b>6. Electrical Distribution Sys.</b>	FGD Service Transformers	4	25KV-13.8KV-13.8KV	50/66/83 MVA	
	FGD MV Transformers	8	13.8-4.16 KV	13/17/21 MVA	
	FGD Startup Transformers	2	115KV-13.8KV-13.8KV	50/66/83 MVA	
	13.8 KV Switchgear	1 Lt			
	4.16 KV Switchgear	1 Lt			
	Unit Substations	1 Lt			
	480V Motor Control Centers	1 Lt			
<b>7. Control System</b>	I/O Cabinets	1 Lt			
	Processor Cabinets	1 Lt			
	Engr Workstations	2			

**Plant Scherer  
Dry FGD Major Equipment List**

System	Equipment Name	Total Qty	Sizing Criteria	Size	Motor HP
<b>1. Lime Handling</b>	Rail Spur	3	Minimum of one unit train reagent delivery		N/A
	Railcar Receiving Hopper - below grade	2	2200 TPH capacity		N/A
	Belt Feeder	1	2200 TPH capacity	72" BW, 24-120 FPM, 37' long	60
	Stockout Conveyor	1	2200 TPH capacity	60" BW, 500 FPM, 960' long	700
	Silo Conveyor on top of silos	1	2200 TPH capacity	60" BW, 500 FPM, 360' long	100
	Traveling Tripper on top of Silos	1	2200 TPH capacity		10
	Lime Bulk Storage Silos	6	30 Day Storage Combined (60,000 tons)	60'Dia x 200'H, Concrete	N/A
<b>2. Lime Prep</b>	Live Bottom Feeders	6	0 to 50 TPH		5
	Rotary Feeders	6	1 to 50 TPH		
	Weigh Belt Feeders	6	0 to 50 TPH	30" belt	15
	Hot Water Heaters	6	Match slaker water need		
	Vertimil Lime Slakers	6	2,000 TPD Lime feed Total, 3 op, 3 spare		
	Separating Chambers	6			
	Slurry Recycle Pumps	6			
	Slurry Product Pumps	6			20
	Lime Slurry Storage Tank	1	8 hour capacity - 4 units		
	Lime Slurry Tank Agitator	1			40
	Lime Slurry Transfer Pumps	2			80
	Sump Pumps	2	Area Washdown		15
	Sump Agitator	1			25
<b>3. Dry FGD Area</b>	Lime Slurry Feed Tanks	2	2 hr capacity - 2 units		
	Feed Tank Agitators	2			
	Lime Slurry Feed Pumps	4			
	Spray Dryer Absorbers	12			
	Rotary Atomizers	36			
	SDA Hopper Heaters	12			
	Rotary Airlock Valves	12			
	Atomizer Feed Tanks	4			
	Atomizer Feed Tank Agitators	4			40
	Atomizer Feed Pumps	8			80
	SDA Area Sump Pumps	4			25
<b>4. Fabric Filter System (Addition)</b>	Pulse Jet Fabric Filter - Add'l Cmprts	24			
	Pulse Air Compressors	-	(Existing)		
	Hopper Heaters	24			

**Plant Scherer  
Dry FGD Major Equipment List**

System	Equipment Name	Total Qty	Sizing Criteria	Size	Motor HP
	Compartment Inlet Louver Dampers	24			
	Compartment Outlet Poppet Dampers	24			
	Bags and Cages	20,160			
<b>5. Recycle Solids System</b>	Recycle Solids Silos	4	8 hr capacity		
	Live Bottom Feeders	4			
	Rotary Feeders	4			
	Welgh Belt Feeders	4			
	Recycle Mix Tanks	4			
	Recycle Mix Tank Agitators	4			
	Recycle Slurry Storage Tanks	4			
	Recycle Slurry Storage Tank Agitators	4			
	Recycle Slurry Feed Pumps	8			
<b>6. Flue Gas System</b>	Booster Fans	8			6500
	Stack Bypass Damper w/Actuator	4			
	Stack Bypass Damper Seal Air Fans	8			50
	SDA Inlet Damper w/Actuator	4			
	SDA Inlet Damper Seal Air Fans	8			50
	SDA Outlet Damper w/Actuator	4			
	SDA Outlet Damper Seal Air Fans	8			50
<b>7. By-Product Solids Handling</b>	Conveying Air Blowers	4			
	Pressure Feeders	120			
	Pressure Feeder Bodies	120			
	Pressure Feeder Valving	1 Lt			
	By-Product Silos	2	5,000T ea.		
	Silo Fluidizing System	2			
	Mixer/Unloaders	2			
<b>8. Mech. BOP Equipment</b>	Service Air Compressors	4			
	Air Receivers	3			
	Instrument Air Dryers	3			
<b>9. Electrical Distribution Sys.</b>	FGD Service Transformers	4	25KV-6.9KV-6.9KV	30/40/50 MVA	
	FGD Startup Transformers	2	115KV-6.9KV-6.9KV	30/40/50 MVA	
	6.9 KV Switchgear	1 Lt			
	Unit Substations	1 Lt			

**Plant Scherer  
Dry FGD Major Equipment List**


System	Equipment Name	Total Qty	Sizing Criteria	Size	Motor HP
	480V Motor Control Centers	1 Lt			
10. Control System	I/O Cabinets	1 Lt			
	Processor Cabinets	1 Lt			
	Engr Workstations	2			

Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

**APPENDIX M**  
**PROJECT MILESTONE SCHEDULES**  
**WET & DRY**

CONFIDENTIAL




Start Date	31 JUL 00	Early Bar	SOUTHERN COMPANY - PLANT SCHEDER CONCEPTUAL CONSTRUCTION MILESTONES WET FGD UNITS 1 & 2	Sheet 1 of 1		Work/Persons		Checked	Approved
Finish Date	27 JUN 14	Progress Bar		Date	Revision	LF-31			
Data Date	11 SEP 00	Critical Activity				FL-31			
Run Date	21 NOV 08 12:10								

© Primavera Systems, Inc.

Florida Power & Light  
 Docket No. 070007-FL  
 Staff's Fourth Set of Interrogatories  
 Interrogatory No. 36  
 Attachment 1, Page 125 of 131



CONFIDENTIAL




Start Date	31 JUL 06	Legend	Early Bar	Sheet 1 of 1	WorleyParsons		Checked	Approved	
Finish Date	27 JUN 14	Progress Bar		SOUTHERN COMPANY - PLANT SCHERER CONCEPTUAL CONSTRUCTION MILESTONES WET FGD UNITS 3 & 4	Date	Revision	LT-30		
Days Data	11 SEP 06	Critical Activity						FL-30	
Run Date	21 NOV 09 12:19								

© Primavera Systems, Inc.

Florida Power & Light  
 Docket No. 070007-E1  
 Staff's Fourth Set of Interrogatories  
 Interrogatory No. 36  
 Attachment I, Page 126 of 131

CONFIDENTIAL




Start Date 31JUL06  
 Finish Date 27JUN14  
 Data Date 11SEP06  
 Run Date 21NOV06 12:18

Early Bar  
 Progress Bar  
 Critical Activity

SOUTHERN COMPANY - PLANT BCHER  
 CONCEPTUAL CONSTRUCTION MILESTONES  
 DRY FGD UNITS 1 & 2

WadeyParsons		Checked	Approved
Date	Revision	LT-26	
		FL-29	

CONFIDENTIAL



Start Date 31JUL06  
 Finish Date 27JUN14  
 Data Date 11SEP08  
 Run Date 21NOV06 12:17

Early Bar  
 Progress Bar  
 Critical Activity

SOUTHERN COMPANY - PLANT SCHERER  
 CONCEPTUAL CONSTRUCTION MILESTONES  
 DRY FGD UNITS 3 & 4

Sheet 1 of 1

Date	Revision	WorleyParsons	Checked	Approved
			LT-38	
			FL-28	

© Primavera Systems, Inc.

Florida Power & Light  
 Docket No. 070007-ET  
 Staff's Fourth Set of Interrogatories  
 Interrogatory No. 36  
 Attachment I, Page 128 of 131

Southern Company Services  
Plant Scherer FGD Project

FGD Process Selection Study  
SCHR-1-LI-021-0001, Rev. B

## APPENDIX N


### ELECTRICAL SINGLE-LINE DIAGRAMS (Typical – Units 1 & 2) WET & DRY

SCHR-0-SK-625-206-001  
SCHR-0-SK-625-206-002




**WorleyParsons**

resources & energy



<b>WorleyParsons</b> <small>CONSTRUCTION &amp; ENERGY</small>	
SERVICE CENTER QUALITY PROJECT	
ELECTRICIAN VET. ST. BY SINGLE LINE DIAGRAM	
SCALE: 1/8" = 1'-0"	SHEET NO. 130 OF 131

Florida Power & Light  
 Project No. 070007-E1  
 Staff's Fourth Set of Interrogatories  
 Interrogatory No. 16  
 Attachment I, Page 130 of 131



<b>WorleyParsons</b> ENGINEERING COMPANY GENERAL PROJECT	
ELECTRICAL ONE STORY SINGLE LINE DIAGRAM	
SHEET NO. 0-5K-625-206-002 A	

Florida Power & Light  
 Docket No. 070007-E1  
 Staff's Fourth Set of Interrogatories  
 Interrogatory No. 36  
 Attachment I, Page 131 of 131

**Annual System Emissions Reduction by Pollutant**

Site	SJRPP Unit 1 & 2	SJRPP Unit 1 & 2	Scherer 4	Scherer 4	Martin 1 & 2 - Manatee 1 & 2		
Project:	SCR with Ammonia Injection	SCR with Ammonia Injection	Wet FGD Scrubber	Baghouse & Mercury Sorbant Injection	800 MW Cycling Project	800 MW Cycling Project	800 MW Cycling Project
Year	Yearly NOx Reduction (Tons)	Yearly NOx Reduction (Tons)	Yearly SO2 Reduction (Tons)	Yearly Mercury Reduction (Tons)	Yearly SO2 Reduction (Tons)	Yearly NOx Reduction (Tons)	Yearly CO2 Reduction (Tons)
2008	3,611	0	0	0.00	0	0	0
2009	7,666	0	0	0.00	6,619	2,627	1,137,423
2010	7,644	0	0	0.10	9,401	3,293	1,336,497
2011	7,669	0	0	0.14	7,376	4,355	1,485,389
2012	7,723	2,340	15,618	0.13	7,969	4,873	1,612,764
2013	7,706	2,951	19,534	0.13	8,507	4,762	1,622,297
2014	7,690	2,929	19,535	0.13	8,690	4,195	1,496,406
2015	7,138	2,929	19,537	0.13	8,039	4,559	1,567,416
2016	3,294	2,931	19,591	0.13	6,393	4,113	1,373,473
2017	3,270	2,939	19,535	0.13	6,261	4,532	1,469,354
2018	3,274	2,924	19,488	0.13	8,058	4,904	1,582,008
2019	3,277	2,924	19,513	0.13	9,196	4,882	1,593,025
2020	3,287	2,945	19,591	0.13	8,216	5,240	1,642,888
2021	3,284	2,940	19,534	0.13	7,921	5,136	1,622,994
2022	3,278	2,935	19,534	0.13	8,005	4,892	1,679,445
2023	3,273	2,925	19,536	0.13	6,658	4,691	1,690,528
2024	3,319	2,976	19,594	0.13	6,769	4,271	1,712,155
2025	3,283	2,945	19,497	0.13	6,716	4,533	1,774,348

**Q.**

**What entities were solicited and what entities responded to RFPs with bids for each CAIR/CAMR project valued at over \$1 Million?**

**A.**

For the reburn and low NOx burner projects, four entities (G.E., B&W, Ansaldo, and Mobotec) were requested to provide proposals for the 400 MW units and two entities (G.E. and Mobotec) provided proposals. For the Putnam water injection project, the combustion turbine OEM Siemens provided a Customer Informational Letter outlining the modifications necessary and estimated costs. Siemens was considered the only viable source for supplying the parts and services for the Putnam Units due to the complexity of implementing a modification such as water injection on a gas turbine.

FPL did not issue any RFPs for CAIR/CAMR projects Related to St. Johns River Power Park (SJRPP) or Scherer Unit 4. FPL is a non-operating partial owner of SJRPP and Scherer Unit 4. Services are procured for SJRPP by JEA on their own behalf and as agent for FPL. Equipment and services are procured for Plant Scherer by Georgia Power Company/Southern Company on their behalf and as agent for the six other co-owners.



**Q.**

**Provide a financial analysis comparing the retrofit of FPL's Scherer 4 as proposed by FPL with replacement generation based on a natural gas combined cycle unit, considering base, high, and low fuel price sensitivities. Consider the most cost effective approach available to FPL regarding the physical location of the combined cycle unit.**

**A.**

FPL has ownership and contractual commitments to pay its share of the capital and operating costs of Scherer 4, which FPL must pay regardless of how much energy output FPL takes from Scherer 4. Thus, FPL would not avoid having to pay its share of Scherer 4 costs, other than its portion of variable costs, if it decided to build an additional combined cycle unit and took power from that unit instead of Scherer 4. While FPL has not performed a formal economic analysis of that alternative, considering that the energy costs for combined cycle generation are significantly greater than the energy costs of Scherer 4, FPL strongly doubts that one could economically justify the costs of building and operating a combined cycle unit with just the avoided Scherer 4 variable costs.

- Q.** Provide a financial analysis comparing the retrofit of FPL's Scherer 4 as proposed by FPL with replacement generation based on a natural gas combined cycle unit (s), considering base, high, and low future carbon capture/sequestration requirements sensitivities. Consider the most cost effective approach available to FPL regarding the physical location of the combined cycle unit.
- A.** FPL believes that it is inappropriate to evaluate the replacement of FPL's ownership share of Scherer Unit 4 with gas fired combined cycle technology as described in the response to interrogatory question 38.

Florida Power & Light Company  
Docket No. 070007-EI  
Staff's Fourth Set of Interrogatories  
Interrogatory No. 40  
Page 1 of 1

Q.


**What are the FGD technologies proposed for the Scherer Units 1 through 4, the proposed installation dates, and the relative costs of the units? What synergies and cost savings, if any, are planned in the design, procurement, and installation of Scherer Units 1 through 4 by a single vendor or group of vendors working together?**


A.

The proposed FGD technology for Scherer Units 1 through 4 is the Advatech Wet FGD (Wet Scrubber).

Current required operation dates of the flue gas desulfurization and total cost estimates (as of 08/10/2007) are as follows:

Unit 1	Operational Prior to 12/31/2014	
Unit 2	Operational Prior to 12/31/2013	
Unit 3	Operational Prior to 12/31/2011	
Unit 4	Operational Prior to 12/31/2012	



FPL's share of the cost of the Unit 4 FGD upgrade is 

Georgia Power Company acting as Operating Agent per contractual agreement has selected the Advatech Wet Scrubber with the goal of completing the detail design for all four Scherer units within 18 months and commit to equipment procurement for all units for better pricing and lower risk.

Southern Company, parent to Georgia Power Company, has a bulk procurement program to leverage price and other contractual concessions based on the volume of materials purchased for the fleet of environmental projects being executed within their system.

Georgia Power Company is developing a construction bid package strategy that will utilize contractor cost in the most efficient manner. An example is to bid piling / caisson installation packages for SCR and FGD for all four Scherer units.

In every phase of the project Georgia Power Company has committed to look for ways to improve efficiencies.

**Q.** Show how the aggregate emissions of FPL, both with and without the planned controls, compare to FPL's expected annual emission allowances.

**A.** Attachment I shows the system total emissions, before and after the planned controls.

**Total System Emissions with and without planned controls**

Year	Base Assumptions			With Controls			Incremental System Emissions		
	(1) SO2 System Emissions Tons	(2) NOx System Emissions Tons	(3) Hg System Emissions Tons	(4) SO2 System Emissions Tons	(5) NOx System Emissions Tons	(6) Hg System Emissions Tons	(7) SO2 System Emissions Tons =(4) - (1)	(8) NOx System Emissions Tons =(5) - (2)	(9) Hg System Emissions Tons =(6) - (3)
2008	109,019	47,611	0.41	109,065	44,000	0.41	45	-3,611	0.00
2009	110,897	46,045	0.43	104,369	35,749	0.43	-6,528	-10,295	0.00
2010	89,247	40,047	0.35	79,945	29,118	0.25	-9,302	-10,929	-0.10
2011	64,931	34,976	0.32	57,637	22,973	0.18	-7,294	-12,003	-0.14
2012	65,388	35,642	0.32	41,912	20,727	0.19	-23,476	-14,915	-0.13
2013	66,776	35,739	0.32	38,861	20,360	0.19	-27,915	-15,379	-0.13
2014	72,703	37,569	0.32	44,644	22,758	0.19	-28,059	-14,811	-0.13
2015	64,962	36,067	0.31	37,489	21,443	0.18	-27,473	-14,624	-0.13
2016	56,845	31,673	0.25	30,954	21,330	0.12	-25,891	-10,343	-0.13
2017	53,167	30,071	0.25	27,451	19,339	0.12	-25,716	-10,732	-0.13
2018	55,910	28,304	0.25	28,394	17,193	0.12	-27,516	-11,111	-0.13
2019	60,179	28,904	0.25	31,551	17,817	0.12	-28,628	-11,086	-0.13
2020	55,497	28,004	0.25	27,756	16,538	0.12	-27,741	-11,466	-0.13
2021	55,039	28,406	0.25	27,665	17,065	0.12	-27,374	-11,341	-0.13
2022	55,899	28,569	0.25	28,453	17,481	0.12	-27,446	-11,087	-0.13
2023	51,859	27,912	0.25	25,759	17,019	0.12	-26,100	-10,893	-0.13
2024	52,013	27,817	0.25	25,723	17,326	0.12	-26,290	-10,491	-0.13
2025	46,624	26,758	0.22	20,567	16,015	0.09	-26,058	-10,743	-0.13

Note: The values above are based on FPL's system capability; ie., FPL units and purchases.

**Controls:**

- SJRPP Unit 1 and 2: -SCR with ammonia injection
- Mercury CEMS
- Scherer 4: -Wet FGD Scrubber
- SCR with ammonia injection
- Fabric filter baghouse & mercury sorbant injection
- Mercury CEMS
- Manatee Unit 1 and 2; Martin Unit 1 and 2: -800 MW cycling project

**Q.**

**Provide FPL's comparison of the ECRC cost of implementing the originally-planned reburn and low NOx burner projects at Cape Canaveral, Port Everglades, Turkey Point, and Putnam plants, plus required NOx allowance costs, to the cost of installation of the proposed 800 MW cycling project, plus required NOx allowance costs.**

**A.**

FPL has not compared the costs of implementing the reburn and low NOx burner projects to the costs of 800 MW cycling projects. The 800 MW project, in addition to substantial emission savings, produces large fuel savings which makes it more cost-effective than any other project under consideration for FPL's CAIR compliance strategy. In FPL's strategy, the gas reburn and low NOx burner projects were considered to be additional or complimentary projects to the 800 MW cycling project.

**Q.**  
**Who provided the detailed information contained in Exhibit RRL-5 of Witness LaBauve's direct testimony of August 3, 2007?**

**A.**  
APTECH, an engineering firm, was contracted by FPL to provide the detailed information.

**Q. What method(s) is FPL using to solicit vendors for the design, procurement, and construction of the 800 MW Unit Cycling Project in the most cost effective way?**

**A.** FPL is utilizing the normal, established company procurement process. This provides controls, access to favorable FPL rates with vendors and takes advantage of economy of scale where applicable. Work on the first unit will begin in 2008. Bids have been received for the finishing superheater tube (FSH) replacements and a review is in progress. Specifications for the heat recovery area (HRA) drains have been developed and are being reviewed by FPL engineering personnel.



**Q. How might future carbon capture requirements impact the full implementation of the 800 MW Unit Cycling Project, as referenced on Page 11 of Witness LaBauve's August 3, 2007 direct testimony?**

**A.** The 800 MW Unit Cycling Project is anticipated to produce both reductions in NOx emissions and associated reductions in fuel use. Reductions in fuel use will produce related reductions in emission of CO2. Prior to the availability of commercially available cost-effective carbon capture equipment for fossil steam generating units, FPL is unaware of any effects, either positive or negative, of the individual projects being performed as part of the 800 MW Unit Cycling Project on the ability to add future carbon capture equipment.

**Q.**

**What impact is the proposed 800 MW unit cycling project expected to have on fuel costs for each generating unit?**

**A.**

It is important to note that in deciding whether the cycling project is economic, the relevant fuel costs are the system costs, not the fuel costs of the individual 800 MW units. Attachment I, shows the system fuel costs, before and after the cycling projects.

**System Production Cost Difference Due to Economically Cycling of the 800 MW Units**

	(1)	(2)	(3) =(2)-(1)
	Base Case with economically cycling 800 MW units	Change Case without economically cycling 800 MW units	System FUEL SAVINGS
<u>YEAR</u>	<u>Cost (\$M)</u>	<u>Cost (\$M)</u>	<u>(\$M)</u>
2007	5,246	5,246	0
2008	5,569	5,569	0
2009	5,105	5,202	97
2010	5,168	5,230	62
2011	4,986	5,054	68
2012	5,330	5,433	103
2013	5,614	5,704	90
2014	5,825	5,933	108
2015	6,357	6,454	98
2016	7,078	7,192	114
2017	7,715	7,838	123
2018	8,126	8,276	151
2019	8,707	8,845	139
2020	9,105	9,280	175
2021	9,448	9,634	186
2022	9,974	10,181	207
2023	10,497	10,748	251
2024	11,191	11,443	252
2025	11,989	12,265	276

**Q.**

**Provide the updated annual price projections for SO<sub>2</sub>, NO<sub>x</sub>, and mercury allowances. Compare to the cost of CAIR/CAMR compliance for each unit by year under FPL's most recent CAIR/CAMR plan.**

**A.**

The annual price projections for SO<sub>2</sub>, NO<sub>x</sub>, and mercury are shown in Attachment I.

FPL has compared the costs of its CAIR/CAMR strategy versus a strategy where FPL relies only in the purchase of allowances. This is done at the system level, not at the unit level, as FPL believes that the proper comparison is at the system level. This system-level comparison is provided in Attachment II.

**Nominal \$/Ton**

<b>Year</b>	<b>NOx \$/Ton</b>	<b>SO2 \$/Ton</b>	<b>Hg \$/Ton</b>
2008	0	972	0
2009	1,674	1,065	0
2010	1,826	1,165	59,971,424
2011	1,991	1,276	59,360,067
2012	2,182	1,398	58,754,359
2013	2,391	1,532	58,154,370
2014	2,619	1,677	60,539,881
2015	2,867	1,838	66,290,458
2016	3,140	2,013	72,584,634
2017	3,436	2,203	79,445,273
2018	3,761	2,411	86,708,345
2019	4,116	2,638	95,175,091
2020	4,506	2,888	104,170,294
2021	3,337	3,163	114,099,102
2022	2,473	3,465	124,973,551
2023	1,831	3,795	136,885,007
2024	1,356	4,155	149,931,006
2025	1,004	4,552	164,218,862

**Revenue Requirements: Base Case**

[1] Year	[2] Annual Discount Factor at 0.08302	[3] Incremental Generation Capital (Millions)	[4] System Generation Variable O&M (Millions)	[5] Incremental Generation Fixed O&M (Millions)	[6] Total System Fuel (Millions)	[7] Total Emission Costs* (Millions)	[8] Annual Costs (Millions)	[9] NPV Annual Cost (Millions)	[10] NPV Cumulative Costs (Millions)
2008	1.000	0	97	0	5,745	106	5,948	5,948	5,948
2009	0.923	0	100	0	6,148	17	6,266	5,785	11,733
2010	0.853	0	109	0	6,174	9	6,292	5,364	17,098
2011	0.787	0	113	0	6,006	83	6,202	4,882	21,980
2012	0.727	0	119	0	5,724	226	6,069	4,411	26,391
2013	0.671	0	121	0	5,991	403	6,515	4,373	30,763
2014	0.620	0	122	0	6,484	508	7,114	4,409	35,172
2015	0.572	0	131	0	7,066	653	7,850	4,491	39,664
2016	0.528	0	136	0	7,698	725	8,559	4,522	44,186
2017	0.488	0	149	0	8,029	891	9,069	4,424	48,609
2018	0.450	0	154	0	8,188	1,051	9,393	4,231	52,840
2019	0.416	0	158	0	8,684	1,221	10,062	4,185	57,025
2020	0.384	0	160	0	8,950	1,403	10,513	4,037	61,062
2021	0.355	0	170	0	9,392	1,553	11,115	3,941	65,004
2022	0.327	0	177	0	10,008	1,821	12,006	3,931	68,934
2023	0.302	0	187	0	10,594	1,999	12,780	3,863	72,798
2024	0.279	0	197	0	11,384	2,283	13,863	3,870	76,667
2025	0.258	0	210	0	12,192	2,419	14,822	3,820	80,487
Total NPV =		0	1,315	0	72,506	6,667	80,487		

**Revenue Requirements: Planned Controls Implemented**

[1] Year	[2] Annual Discount Factor at 0.08302	[3] Incremental Generation Capital (Millions)	[4] System Generation Variable O&M (Millions)	[5] Incremental Generation Fixed O&M (Millions)	[6] Total System Fuel (Millions)	[7] Total Emission Costs* (Millions)	[8] Annual Costs (Millions)	[9] NPV Annual Cost (Millions)	[10] NPV Cumulative Costs (Millions)
2008	1.000	10	98	1	5,747	106	5,962	5,962	5,962
2009	0.923	24	105	2	6,029	10	6,169	5,696	11,658
2010	0.853	57	119	2	6,049	(2)	6,225	5,307	16,965
2011	0.787	58	123	2	5,838	74	6,095	4,798	21,763
2012	0.727	111	133	2	5,542	193	5,981	4,347	26,110
2013	0.671	126	136	2	5,803	360	6,427	4,314	30,424
2014	0.620	121	138	2	6,308	461	7,030	4,357	34,781
2015	0.572	121	146	2	6,872	602	7,743	4,430	39,211
2016	0.528	115	148	2	7,519	673	8,457	4,468	43,679
2017	0.488	113	159	2	7,828	835	8,937	4,360	48,038
2018	0.450	108	165	2	7,974	985	9,234	4,159	52,197
2019	0.416	105	168	2	8,474	1,145	9,895	4,115	56,312
2020	0.384	100	171	2	8,712	1,323	10,308	3,958	60,271
2021	0.355	97	181	2	9,144	1,467	10,891	3,862	64,132
2022	0.327	93	188	2	9,743	1,726	11,752	3,847	67,980
2023	0.302	90	196	2	10,307	1,900	12,495	3,777	71,757
2024	0.279	85	207	2	11,085	2,174	13,553	3,783	75,540
2025	0.258	83	221	2	11,869	2,301	14,475	3,731	79,271
Total NPV =		820	1,415	19	70,784	6,234	79,271		

**Controls:**

- SJRPP Unit 1 and 2:
  - SCR with ammonia injection
  - Mercury CEMS
- Scherer 4:
  - Wet FGD Scrubber
  - SCR with ammonia injection
  - Fabric filter baghouse & mercury sorbant injection
  - Mercury CEMS
- Manatee Unit 1 and 2; Martin Unit 1 and 2:
  - 800 MW cycling project

**Change in Revenue Requirements: (Planned Controls Implemented) - ( Base Case)**

[1] Year	[2] Annual Discount Factor at 0.08302	[3] Incremental Generation Capital (Millions)	[4] System Generation Variable O&M (Millions)	[5] Incremental Generation Fixed O&M (Millions)	[6] Total System Fuel (Millions)	[7] Total Emission Costs* (Millions)	[8] Annual Costs (Millions)	[9] NPV Annual Cost (Millions)	[10] NPV Cumulative Costs (Millions)
2008	1.000	10	1	1	2	0	14	14	14
2009	0.923	24	4	2	(119)	(7)	(96)	(89)	(75)
2010	0.853	57	10	2	(125)	(11)	(67)	(57)	(132)
2011	0.787	58	11	2	(168)	(9)	(107)	(84)	(217)
2012	0.727	111	14	2	(183)	(33)	(88)	(64)	(281)
2013	0.671	126	15	2	(188)	(43)	(88)	(59)	(340)
2014	0.620	121	16	2	(176)	(47)	(84)	(52)	(392)
2015	0.572	121	15	2	(195)	(51)	(107)	(61)	(453)
2016	0.528	115	12	2	(179)	(52)	(102)	(54)	(507)
2017	0.488	113	11	2	(201)	(57)	(132)	(64)	(571)
2018	0.450	108	11	2	(214)	(66)	(160)	(72)	(643)
2019	0.416	105	11	2	(210)	(76)	(167)	(69)	(713)
2020	0.384	100	11	2	(238)	(80)	(205)	(79)	(791)
2021	0.355	97	11	2	(248)	(87)	(224)	(80)	(871)
2022	0.327	93	10	2	(265)	(95)	(255)	(83)	(954)
2023	0.302	90	9	2	(287)	(99)	(285)	(86)	(1,040)
2024	0.279	85	10	2	(299)	(109)	(311)	(87)	(1,127)
2025	0.258	83	10	2	(324)	(119)	(347)	(89)	(1,217)
Total NPV =		820	100	19	(1,721)	(434)	(1,217)		

Notes: Negative Indicates Savings

Controls:

- SJRPP Unit 1 and 2:
  - SCR with ammonia injection
  - Mercury CEMS
- Scherer 4:
  - Wet FGD Scrubber
  - SCR with ammonia injection
  - Fabric filter baghouse & mercury sorbant injection
  - Mercury CEMS
- Manatee Unit 1 and 2; Martin Unit 1 and 2:
  - 800 MW cycling project



Florida Power & Light Company  
Docket No. 070007-EI  
Staff's Fourth Set of Interrogatories  
Interrogatory No. 40  
Page 1 of 1

Q.

**What are the FGD technologies proposed for the Scherer Units 1 through 4, the proposed installation dates, and the relative costs of the units? What synergies and cost savings, if any, are planned in the design, procurement, and installation of Scherer Units 1 through 4 by a single vendor or group of vendors working together?**


A.

The proposed FGD technology for Scherer Units 1 through 4 is the Advatech Wet FGD (Wet Scrubber).

Current required operation dates of the flue gas desulfurization and total cost estimates (as of 08/10/2007) are as follows:

Unit 1	Operational Prior to 12/31/2014
Unit 2	Operational Prior to 12/31/2013
Unit 3	Operational Prior to 12/31/2011
Unit 4	Operational Prior to 12/31/2012



FPL's share of the cost of the Unit 4 FGD upgrade is 

Georgia Power Company acting as Operating Agent per contractual agreement has selected the Advatech Wet Scrubber with the goal of completing the detail design for all four Scherer units within 18 months and commit to equipment procurement for all units for better pricing and lower risk.

Southern Company, parent to Georgia Power Company, has a bulk procurement program to leverage price and other contractual concessions based on the volume of materials purchased for the fleet of environmental projects being executed within their system.


Georgia Power Company is developing a construction bid package strategy that will utilize contractor cost in the most efficient manner. An example is to bid piling / caisson installation packages for SCR and FGD for all four Scherer units.

In every phase of the project Georgia Power Company has committed to look for ways to improve efficiencies.

CONFIDENTIAL




CONFIDENTIAL




ECRC 07-00385

CONFIDENTIAL




ECRC 07-00386

CONFIDENTIAL




ECRC 07-00387

CONFIDENTIAL




ECRC 07-00388

CONFIDENTIAL



ECRC 07-00389


CONFIDENTIAL



ECRC 07-00390




CONFIDENTIAL




ECRC 07-00391

CONFIDENTIAL




ECRC 07-00392

CONFIDENTIAL




CONFIDENTIAL




ECRC 07-00394

~~CONFIDENTIAL~~




ECRG-07-00395

CONFIDENTIAL




ECRC 07-00396

CONFIDENTIAL



ECRC 07-00397

CONFIDENTIAL




ECRC 07-00398

*f*




CONFIDENTIAL




ECRC 07-00399

CONFIDENTIAL




ECRC 07-00400

CONFIDENTIAL




ECRC 07-00401

CONFIDENTIAL




ECRC 07-00402

CONFIDENTIAL




ECRC 07-00403

CONFIDENTIAL




ECRC 07-00404

CONFIDENTIAL



ECRC 07-00405


CONFIDENTIAL



ECRC 07-00406




CONFIDENTIAL




ECRC 07-00407

CONFIDENTIAL




ECRC 07-00408

CONFIDENTIAL




ECRC 07-00409

CONFIDENTIAL




ECRC 07-00410

CONFIDENTIAL




ECRC 07-00411

CONFIDENTIAL



ECRC 07-00412


CONFIDENTIAL



ECRC 07-00413

CONFIDENTIAL


CONFIDENTIAL



ECRC 07-00414




CONFIDENTIAL




ECRC 07-00415

CONFIDENTIAL




ECRC 07-00416

CONFIDENTIAL




ECRC 07-00417

CONFIDENTIAL




ECRC 07-00418

CONFIDENTIAL




ECRC 07-00419

CONFIDENTIAL




ECRC 07-00420

CONFIDENTIAL



ECRC 07-00421


CONFIDENTIAL



ECRC 07-00422




CONFIDENTIAL




ECRC 07-00423

CONFIDENTIAL




ECRC 07-00424

CONFIDENTIAL




ECRC 07-00425

CONFIDENTIAL




ECRC 07-00426

CONFIDENTIAL




ECRC 07-00427

CONFIDENTIAL




ECRC 07-00428

CONFIDENTIAL



ECRC 07-00429

CONFIDENTIAL




ECRC 07-00430



CONFIDENTIAL




CONFIDENTIAL




ECRC 07-00432

CONFIDENTIAL




ECRC 07-00433

CONFIDENTIAL




ECRC 07-00434

CONFIDENTIAL




ECRC 07-00435

CONFIDENTIAL




ECRC 07-00436

CONFIDENTIAL




CONFIDENTIAL



ECRC 07-00438




CONFIDENTIAL




ECRC 07-00439

CONFIDENTIAL



ECRC 07-00440

CONFIDENTIAL



ECRC 07-00441