

Susan D. Ritenour
Secretary and Treasurer
and Regulatory Manager

One Energy Place
Pensacola, Florida 32520-0781

Tel 850.444.6231
Fax 850.444.6026
SDRITENO@southernco.com

RECEIVED
COMMUNICATIONS CENTER
01-22-08 11:17:23



January 18, 2008

Ms. Ann Cole, Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee FL 32399-0850

Dear Ms. Cole:

RE: COMMISSION STAFF'S MINIMUM FILING REQUIREMENTS IN
SUPPORT OF THE MONTHLY FUEL AND PURCHASED POWER COST
RECOVERY CHARGE IN DOCKET NO. 080001-EI

Enclosed are an original and ten copies of Gulf Power Company's Actual Unit Performance Data Schedules and the Actual Unit Outage Data Schedules through December 2007, Retail Cost Recovery Charges for Plant Crist, Plant Smith, and Plant Daniel. These schedules are being sent separate from the monthly filing.

Sincerely,

- CMP _____
- COM _____
- CTR _____
- ECR _____
- GCL _____
- OPC _____
- RCA _____
- SCR _____
- SGA _____
- SEC _____
- OTH _____

Susan D. Ritenour
buh

bh

Enclosures

cc w/attachment: Florida Public Service Commission
Sid Matlock

DOCUMENT NUMBER-DATE

00502 JAN 22 08

FPSC-COMMISSION CLERK

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

PERIOD OF: January 2006 - December 2006

	CRIST 4	Jan '07	Feb '07	Mar '07	Apr '07	May '07	Jun '07	Jul '07	Aug '07	Sep '07	Oct '07	Nov '07	Dec '07	Total
1.	EAF (%)	100.0	100.0	99.9	99.7	100.0	100.0	100.0	98.0	93.3	99.2	100.0	97.7	99.0
2.	PH	744.0	672.0	743.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	721.0	744.0	8760.0
3.	SH	715.5	672.0	743.0	720.0	744.0	720.0	744.0	744.0	674.8	744.0	721.0	507.6	8449.9
4.	RSH	28.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	236.4	264.9
5.	UH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	45.2	0.0	0.0	0.0	45.2
6.	POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7.	FOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
8.	MOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	45.2	0.0	0.0	0.0	45.2
9.	PFOH	0.0	0.0	2.7	6.4	0.0	0.0	0.0	41.2	19.9	19.9	0.0	48.4	138.5
10.	LR pf (MW)	0.0	0.0	30.0	30.0	0.0	0.0	0.0	27.8	13.1	23.1	0.0	27.5	25.1
11.	PMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12.	LR pm (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
13.	NSC (MW)	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0
14.	Oper MBtu	486146.0	469210.0	518554.0	509080.0	526318.0	557451.0	559407.0	544781.0	457889.0	531485.0	503463.0	348218.0	6012002.0
15.	Net Gen (MWH)	45128.0	44005.0	48311.0	47388.0	47833.0	49480.0	50199.0	47560.0	41322.0	47735.0	45784.0	32793.0	547538.0
16.	ANOHR (Btu/KWH)	10773.0	10663.0	10734.0	10743.0	11003.0	11266.0	11144.0	11455.0	11081.0	11134.0	10996.0	10619.0	10980.0
17.	NOF %	80.9	84.0	83.4	84.4	82.4	88.1	86.5	82.0	78.5	82.3	81.4	82.8	83.1
18.	NPC (MW)	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0
19.	ANOHR Equation	$10^6 / AKW * [32.38 - 15.16 * JAN - 14.84 * FEB + 13.60 * JUN + 10.74 * NOV]$ + 10.131												

DOCUMENT NUMBER-DATE

00502 JAN 22 08

FPSC-COMMISSION CLERK

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

PERIOD OF: January 2006 - December 2006

CRIST 5	Jan '07	Feb '07	Mar '07	Apr '07	May '07	Jun '07	Jul '07	Aug '07	Sep '07	Oct '07	Nov '07	Dec '07	Total
1. EAF (%)	100.0	87.1	100.0	99.8	100.0	100.0	94.3	97.1	99.2	100.0	99.8	100.0	98.2
2. PH	744.0	672.0	743.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	721.0	744.0	8760.0
3. SH	720.8	585.0	743.0	720.0	744.0	720.0	701.4	744.0	720.0	744.0	719.4	508.4	8370.0
4. RSH	23.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	235.6	258.8
5. UH	0.0	87.0	0.0	0.0	0.0	0.0	42.6	0.0	0.0	0.0	1.6	0.0	131.2
6. POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7. FOH	0.0	5.2	0.0	0.0	0.0	0.0	42.6	0.0	0.0	0.0	1.6	0.0	49.4
8. MOH	0.0	81.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	81.8
9. PFOH	0.0	0.0	1.0	1.5	0.0	0.0	0.0	122.6	12.4	0.0	0.0	0.0	137.5
10. LR pf (MW)	0.0	0.0	25.0	73.0	0.0	0.0	0.0	13.7	37.8	0.0	0.0	0.0	16.6
11. PMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12. LR pm (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
13. NSC (MW)	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0
14. Oper MBtu	475692.0	400550.0	520086.0	508562.0	517995.0	540362.0	523713.0	537828.0	478322.0	533819.0	504813.0	364474.0	5906216.0
15. Net Gen (MWH)	44920.0	37352.0	49095.0	48336.0	48262.0	49993.0	47647.0	48391.0	43848.0	48553.0	47769.0	35289.0	549455.0
16. ANOHR (Btu/KWH)	10590.0	10724.0	10593.0	10521.0	10733.0	10809.0	10992.0	11114.0	10909.0	10995.0	10568.0	10328.0	10749.0
17. NOF %	79.9	81.9	84.7	86.1	83.2	89.0	87.1	83.4	78.1	83.7	85.1	89.0	84.2
18. NPC (MW)	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0
19. ANOHR Equation	$10 * 6 / AKW * [66.40 - 11.85 * JAN]$ $+ 9.596$												

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

PERIOD OF: January 2006 - December 2006

CRIST 6	Jan '07	Feb '07	Mar '07	Apr '07	May '07	Jun '07	Jul '07	Aug '07	Sep '07	Oct '07	Nov '07	Dec '07	Total
1. EAF (%)	99.4	94.2	100.0	89.5	99.0	100.0	87.9	96.2	96.5	99.4	99.9	85.3	95.6
2. PH	744.0	672.0	743.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	721.0	744.0	8760.0
3. SH	739.7	633.3	743.0	645.9	744.0	720.0	673.5	715.5	696.6	744.0	721.0	646.2	8422.7
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5. UH	4.3	38.7	0.0	74.1	0.0	0.0	70.5	28.5	23.4	0.0	0.0	97.8	337.3
6. POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7. FOH	4.3	38.7	0.0	0.0	0.0	0.0	0.0	0.0	23.4	0.0	0.0	51.0	117.4
8. MOH	0.0	0.0	0.0	74.1	0.0	0.0	70.5	28.5	0.0	0.0	0.0	46.8	219.9
9. PFOH	0.7	0.0	0.0	16.5	0.0	1.2	314.8	0.0	37.9	102.2	19.3	128.5	621.1
10. LR pf (MW)	127.0	0.0	0.0	22.0	0.0	83.0	18.8	0.0	11.9	13.3	7.7	27.3	19.2
11. PMOH	0.0	0.0	0.0	0.0	13.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	13.0
12. LR pm (MW)	0.0	0.0	0.0	0.0	177.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	177.0
13. NSC (MW)	302.0	302.0	302.0	302.0	302.0	302.0	302.0	302.0	302.0	302.0	302.0	302.0	302.0
14. Oper MBtu	1763121.0	1643916.0	1879736.0	1681410.0	1892412.0	2068164.0	1848769.0	1862379.0	1760546.0	2002297.0	1753372.0	1737591.0	21893713.0
15. Net Gen (MWH)	166720.0	154904.0	177821.0	160957.0	176198.0	192957.0	169220.0	175215.0	162178.0	182785.0	167420.0	159585.0	2045960.0
16. ANOHR (Btu/KWH)	10575.0	10612.0	10571.0	10446.0	10740.0	10718.0	10925.0	10629.0	10856.0	10954.0	10473.0	10888.0	10701.0
17. NOF %	74.6	81.0	79.2	82.5	78.4	88.7	83.2	81.1	77.1	81.4	76.9	81.8	80.4
18. NPC (MW)	302.0	302.0	302.0	302.0	302.0	302.0	302.0	302.0	302.0	302.0	302.0	302.0	302.0
19. ANOHR Equation	$10^6 / AKW * [87.10 + 105.75 * JAN - 109.59 * FEB - 192.13 * MAR - 148.46 * APR]$ + 10.071												

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

PERIOD OF: January 2006 - December 2006

CRIST 7	Jan '07	Feb '07	Mar '07	Apr '07	May '07	Jun '07	Jul '07	Aug '07	Sep '07	Oct '07	Nov '07	Dec '07	Total
1. EAF (%)	98.8	84.3	96.9	55.4	93.2	84.5	86.5	94.4	77.3	97.7	64.5	95.1	85.9
2. PH	744.0	672.0	743.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	721.0	744.0	8760.0
3. SH	744.0	566.4	743.0	418.9	699.4	613.6	645.4	703.2	590.2	738.6	465.4	744.0	7672.1
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5. UH	0.0	105.6	0.0	301.1	44.6	106.4	98.6	40.8	129.8	5.4	255.6	0.0	1087.9
6. POH	0.0	0.0	0.0	301.1	0.0	0.0	0.0	0.0	0.0	0.0	255.6	0.0	556.7
7. FOH	0.0	105.6	0.0	0.0	44.6	106.4	68.5	40.8	92.7	5.4	0.0	0.0	464.0
8. MOH	0.0	0.0	0.0	0.0	0.0	0.0	30.1	0.0	37.1	0.0	0.0	0.0	67.2
9. PFOH	56.6	0.0	266.4	236.9	52.0	155.3	48.6	23.4	42.9	132.0	0.0	42.9	1057.0
10. LR pf (MW)	48.3	0.0	40.6	40.0	17.5	15.0	18.0	19.8	65.4	39.7	0.0	56.5	36.0
11. PMOH	15.1	0.0	0.0	0.0	8.3	0.0	0.0	0.0	47.3	3.4	0.0	299.2	373.3
12. LR pm (MW)	87.7	0.0	0.0	0.0	214.0	0.0	0.0	0.0	273.0	65.0	0.0	49.6	83.2
13. NSC (MW)	472.0	472.0	472.0	472.0	472.0	472.0	472.0	472.0	472.0	472.0	472.0	472.0	472.0
14. Oper MBtu	3247367.0	2512916.0	3348918.0	1860331.0	3075629.0	2954756.0	3075361.0	3393872.0	2479957.0	3320010.0	1964792.0	3159063.0	34392972.0
15. Net Gen (MWH)	311063.0	237365.0	313385.0	172164.0	288598.0	271602.0	287142.0	310915.0	231849.0	312291.0	179070.0	309376.0	3224820.0
16. ANOHR (Btu/KWH)	10440.0	10587.0	10686.0	10806.0	10657.0	10879.0	10710.0	10916.0	10696.0	10631.0	10972.0	10211.0	10665.0
17. NOF %	88.6	88.8	89.4	87.1	87.4	93.8	94.3	93.7	83.2	89.6	81.5	88.1	89.1
18. NPC (MW)	472.0	472.0	472.0	472.0	472.0	472.0	472.0	472.0	472.0	472.0	472.0	472.0	472.0
19. ANOHR Equation	$10^6 / AKW * [568.24 + 132.87 * MAR + 84.49 * APR] + 8.992$												

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

PERIOD OF: January 2006 - December 2006

SMITH 1	Jan '07	Feb '07	Mar '07	Apr '07	May '07	Jun '07	Jul '07	Aug '07	Sep '07	Oct '07	Nov '07	Dec '07	Total
1. EAF (%)	100.0	99.9	29.2	0.0	68.6	100.0	59.0	95.3	100.0	99.9	100.0	99.2	79.1
2. PH	744.0	672.0	743.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	721.0	744.0	8760.0
3. SH	744.0	672.0	216.6	0.0	531.8	720.0	455.6	709.3	720.0	744.0	721.0	744.0	6978.3
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5. UH	0.0	0.0	526.4	720.0	212.2	0.0	288.4	34.7	0.0	0.0	0.0	0.0	1781.7
6. POH	0.0	0.0	526.4	720.0	212.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1458.6
7. FOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
8. MOH	0.0	0.0	0.0	0.0	0.0	0.0	288.4	34.7	0.0	0.0	0.0	0.0	323.1
9. PFOH	4.7	1.2	0.0	0.0	0.4	0.0	109.9	0.0	0.0	2.2	0.0	11.8	130.2
10. LR pf (MW)	9.0	97.0	0.0	0.0	65.0	0.0	24.6	0.0	0.0	36.7	0.0	78.7	29.9
11. PMOH	0.0	0.0	0.0	0.0	23.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	23.0
12. LR pm (MW)	0.0	0.0	0.0	0.0	149.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	149.7
13. NSC (MW)	162.0	162.0	162.0	162.0	162.0	162.0	162.0	162.0	162.0	162.0	162.0	162.0	162.0
14. Oper MBtu	1028584.0	948618.0	301309.0	0.0	745502.0	1098909.0	676565.0	1050973.0	980236.0	1072398.0	984648.0	1106596.0	9994338.0
15. Net Gen (MWH)	99259.0	91941.0	29083.0	0.0	72500.0	107545.0	65153.0	101874.0	95634.0	105475.0	97327.0	108834.0	974625.0
16. ANOHR (Btu/KWH)	10363.0	10318.0	10360.0	0.0	10283.0	10218.0	10384.0	10316.0	10250.0	10167.0	10117.0	10168.0	10255.0
17. NOF %	82.4	84.5	82.9	0.0	84.2	92.2	88.3	88.7	82.0	87.5	83.3	90.3	86.2
18. NPC (MW)	162.0	162.0	162.0	162.0	162.0	162.0	162.0	162.0	162.0	162.0	162.0	162.0	162.0
19. ANOHR Equation	$10^6 / AKW * [20.54 * JAN + 13.19 * FEB + 19.94 * JUN + 16.67 * JUL + 11.07 * AUG + 20.27 * SEP]$ + 10.080												

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

PERIOD OF: January 2006 - December 2006

SMITH 2	Jan '07	Feb '07	Mar '07	Apr '07	May '07	Jun '07	Jul '07	Aug '07	Sep '07	Oct '07	Nov '07	Dec '07	Total
1. EAF (%)	94.9	100.0	90.3	55.0	100.0	95.3	100.0	100.0	99.8	100.0	100.0	100.0	94.6
2. PH	744.0	672.0	743.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	721.0	744.0	8760.0
3. SH	705.8	672.0	671.2	396.2	744.0	686.0	744.0	744.0	718.9	744.0	721.0	744.0	8291.1
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5. UH	38.2	0.0	71.8	323.8	0.0	34.0	0.0	0.0	1.1	0.0	0.0	0.0	468.9
6. POH	0.0	0.0	71.8	201.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	273.4
7. FOH	0.0	0.0	0.0	0.0	0.0	34.0	0.0	0.0	1.1	0.0	0.0	0.0	35.1
8. MOH	38.2	0.0	0.0	122.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	160.4
9. PFOH	0.0	0.0	1.0	0.0	1.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.2
10. LR pf (MW)	0.0	0.0	53.0	0.0	59.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	56.3
11. PMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12. LR pm (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
13. NSC (MW)	195.0	195.0	195.0	195.0	195.0	195.0	195.0	195.0	195.0	195.0	195.0	195.0	195.0
14. Oper MBtu	1159360.0	1130800.0	1113343.0	703301.0	1321017.0	1273251.0	1384565.0	1330313.0	1201854.0	1322599.0	1210587.0	1369874.0	14520864.0
15. Net Gen (MWH)	111911.0	109668.0	108371.0	69467.0	129082.0	122353.0	132028.0	128326.0	116921.0	129166.0	117868.0	132864.0	1408025.0
16. ANOHR (Btu/KWH)	10360.0	10311.0	10273.0	10124.0	10234.0	10406.0	10487.0	10367.0	10279.0	10240.0	10271.0	10310.0	10313.0
17. NOF %	81.3	83.7	82.8	89.9	89.0	91.5	91.0	88.5	83.4	89.0	83.8	91.6	87.1
18. NPC (MW)	195.0	195.0	195.0	195.0	195.0	195.0	195.0	195.0	195.0	195.0	195.0	195.0	195.0
19. ANOHR Equation	$10\% / AKW * [273.24 - 36.28 * MAR + 49.10 * APR - 13.76 * JUL]$ $+ 6.470 + 0.01265 * LSRF / AKW$												

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

PERIOD OF: January 2006 - December 2006

DANIEL 1	Jan '07	Feb '07	Mar '07	Apr '07	May '07	Jun '07	Jul '07	Aug '07	Sep '07	Oct '07	Nov '07	Dec '07	Total
1. EAF (%)	99.5	100.0	74.7	100.0	99.8	98.8	100.0	99.7	76.8	0.0	67.7	99.8	84.6
2. PH	744.0	672.0	743.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	721.0	744.0	8760.0
3. SH	744.0	672.0	556.2	720.0	744.0	720.0	744.0	744.0	561.6	0.0	491.2	744.0	7441.0
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5. UH	0.0	0.0	186.8	0.0	0.0	0.0	0.0	0.0	158.4	744.0	229.8	0.0	1319.0
6. POH	0.0	0.0	186.8	0.0	0.0	0.0	0.0	0.0	48.2	744.0	213.0	0.0	1192.0
7. FOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	110.2	0.0	0.0	0.0	110.2
8. MOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	16.8	0.0	16.8
9. PFOH	8.0	0.0	0.8	11.6	1.5	4.7	0.0	2.2	32.5	0.0	5.5	6.5	73.3
10. LR pf (MW)	231.8	0.0	81.0	12.4	33.0	291.1	0.0	497.0	136.4	0.0	172.6	136.1	147.9
11. PMOH	0.0	0.0	2.0	0.0	5.0	13.6	0.0	0.0	0.0	0.0	1.8	0.0	22.4
12. LR pm (MW)	0.0	0.0	275.0	0.0	123.0	208.0	0.0	0.0	0.0	0.0	263.0	0.0	199.4
13. NSC (MW)	503.0	503.0	503.0	503.0	503.0	503.0	503.0	503.0	503.0	503.0	503.0	503.0	503.0
14. Oper MBtu	3601824.0	3235916.0	2650857.0	3149815.0	3205020.0	3278615.0	3414096.0	3297870.0	2399304.0	0.0	2329057.0	3630687.0	34193062.0
15. Net Gen (MWH)	350736.0	319854.0	259404.0	311707.0	308417.0	325334.0	331360.0	323212.0	242656.0	0.0	227009.0	358385.0	3358074.0
16. ANOHR (Btu/KWH)	10269.0	10117.0	10219.0	10105.0	10392.0	10078.0	10303.0	10203.0	9888.0	0.0	10260.0	10131.0	10182.0
17. NOF %	93.7	94.6	92.7	86.1	82.4	89.8	88.5	86.4	85.9	0.0	91.9	95.8	89.7
18. NPC (MW)	503.0	503.0	503.0	503.0	503.0	503.0	503.0	503.0	503.0	503.0	503.0	503.0	503.0
19. ANOHR Equation	$10^6 / AKW * [2547.49 + 95.70 * APR - 90.73 * SEP - 114.94 * OCT]$ $- 538 + 10^6 / AKW * [-0.0550 * BTU/LB] + 0.01343 * LSRF / AKW$												

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

PERIOD OF: January 2006 - December 2006

	DANIEL 2	Jan '07	Feb '07	Mar '07	Apr '07	May '07	Jun '07	Jul '07	Aug '07	Sep '07	Oct '07	Nov '07	Dec '07	Total
1.	EAF (%)	99.9	100.0	80.2	77.5	99.2	99.9	99.1	83.5	99.5	88.3	99.7	98.6	93.7
2.	PH	744.0	672.0	743.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	721.0	744.0	8760.0
3.	SH	744.0	672.0	600.9	680.0	744.0	720.0	744.0	630.5	720.0	657.1	721.0	744.0	8377.5
4.	RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5.	UH	0.0	0.0	142.1	40.0	0.0	0.0	0.0	113.5	0.0	86.9	0.0	0.0	382.5
6.	POH	0.0	0.0	142.1	24.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	167.0
7.	FOH	0.0	0.0	0.0	15.1	0.0	0.0	0.0	2.5	0.0	0.0	0.0	0.0	17.6
8.	MOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	111.0	0.0	86.9	0.0	0.0	197.9
9.	PFOH	3.9	0.0	16.5	463.1	10.0	7.4	29.4	3.8	38.9	0.0	6.5	25.2	604.7
10.	LR pf (MW)	109.4	0.0	151.8	133.6	65.6	49.5	87.4	203.3	45.1	0.0	174.1	90.9	122.9
11.	PMOH	0.0	0.0	0.0	8.3	19.4	4.3	3.5	12.4	0.0	0.0	0.0	9.3	57.2
12.	LR pm (MW)	0.0	0.0	0.0	44.0	126.4	14.0	258.1	322.6	0.0	0.0	0.0	330.0	189.7
13.	NSC (MW)	510.0	510.0	510.0	510.0	510.0	510.0	510.0	510.0	510.0	510.0	510.0	510.0	510.0
14.	Oper MBtu	3018044.0	2583163.0	2163214.0	2633294.0	3212261.0	3390375.0	3347570.0	2764711.0	3394586.0	3077546.0	3504199.0	3481842.0	36570805.0
15.	Net Gen (MWH)	295599.0	252786.0	212118.0	261444.0	324038.0	335238.0	336384.0	273715.0	335036.0	311990.0	359142.0	356646.0	3654136.0
16.	ANOHR (Btu/KWH)	10210.0	10219.0	10198.0	10072.0	9913.0	10113.0	9952.0	10101.0	10132.0	9864.0	9757.0	9763.0	10008.0
17.	NOF %	77.9	73.8	69.2	75.4	85.4	91.3	88.7	85.1	91.2	93.1	97.7	94.0	85.5
18.	NPC (MW)	510.0	510.0	510.0	510.0	510.0	510.0	510.0	510.0	510.0	510.0	510.0	510.0	510.0
19.	ANOHR Equation	$10^6 / AKW * [1237.97 + 120.49 * JUL - 109.59 * SEP]$ $+ 9.584 + 10^6 / AKW * [-0.0983 * BTU/LB]$												

