

**Ruth Nettles**

---

**From:** Stright, Lisa [Lisa.Stright@pgnmail.com]  
**Sent:** Monday, March 03, 2008 1:45 PM  
**To:** Filings@psc.state.fl.us  
**Cc:** Burnett, John  
**Subject:** PEF / Pasco Cogeneration Event - Undocketed  
**Attachments:** Document.pdf

**This electronic filing is made by:**

**John T. Burnett**  
**P.O. Box 14042**  
**St. Petersburg, FL 33733**  
**(727) 820-5184**  
**john.burnett@pgnmail.com**

**Undocketed**

**On behalf of Progress Energy Florida**

**Consisting of 2 pages.**

**Please find attached PEF's letter summarizing  
the Pasco Cogeneration event on February 26,  
2008.**

<<Document.pdf>>

**Lisa Stright**

Regulatory Analyst - Legal Dept.  
Progress Energy  
106 E. College Ave., Suite 800  
Tallahassee, FL 32301  
(850) 222-8738 office  
(850) 222-9768 fax  
Email: lisa.stright@pgnmail.com

3/3/2008

DOCUMENT NUMBER-DATE  
01567 MAR-3 8  
FPSC-COMMISSION CLERK



March 3, 2008

**VIA ELECTRONIC FILING**

Ms. Ann Cole, Commission Clerk  
Florida Public Service Commission  
2540 Shumard Oak Boulevard  
Tallahassee, FL 32399-0850

Re: *Summary of Pasco Cogeneration Event on February 26, 2008; Undocketed*

Dear Ms. Cole:

According to FPSC Rule 25-17.086, "Periods During Which Purchases are Not Required", Progress Energy Florida (PEF) is providing notice to the Florida Public Service Commission that PEF limited the output of the Pasco Cogen facility to 50 MW on 2/26/08 from 0600 hours until 0605 hours. The Pasco Cogen facility is interconnected to the PEF transmission system at PEF's Union Hall substation. PEF took this action in its capacity as Transmission Operator in order to ensure the reliability of the transmission system and prevent equipment damage.

The incident began during startup of the Pasco Cogen unit between 0500 and 0600 hours on 2/26/08. The PEF Energy Control Center system operator informed the Pasco Cogen operator that Tampa Electric Company (TEC) was performing work on a TEC line in Dade City and recommended that Pasco not exceed 50 MW output until notified by PEF that the work was complete and that the Pasco units were released for full output.

The PEF system operator monitored the situation and determined at 0600 hours that it was not necessary to limit the output of Pasco Cogen to 50 MW based on prevailing system conditions. The PEF system operator notified Pasco Cogen at 0605 hours that the Pasco units were released from curtailed operations and could begin ramping up to full power.

Thank you for your assistance in this matter. Should you have any question, please feel free to call me at (727) 820-5184.

Sincerely,

  
John T. Burnett

JTB/lms

DOCUMENT NUMBER-DATE

01567 MAR-3 8

FPSC-COMMISSION CLERK