

**BEFORE THE
FLORIDA PUBLIC SERVICE COMMISSION
DOCKET NO. 080317-EI**

**IN RE: TAMPA ELECTRIC COMPANY'S
PETITION FOR AN INCREASE IN BASE RATES
AND MISCELLANEOUS SERVICE CHARGES**

**DIRECT TESTIMONY AND EXHIBIT
OF
STEVEN P. HARRIS
ON BEHALF OF TAMPA ELECTRIC COMPANY**

DOCUMENT NUMBER-DATE

07061 AUG 11 8

FPSC-COMMISSION CLERK

BEFORE THE
FLORIDA PUBLIC SERVICE COMMISSION

DOCKET NO. 080317-EI
IN RE: TAMPA ELECTRIC COMPANY'S
PETITION FOR AN INCREASE IN BASE RATES
AND MISCELLANEOUS SERVICE CHARGES

DIRECT TESTIMONY AND EXHIBIT

OF

STEVEN P. HARRIS

ON BEHALF OF TAMPA ELECTRIC COMPANY

DOCUMENT NUMBER-DATE

07061 AUG 11 8

FPSC-COMMISSION CLERK

1 **BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION**

2 **PREPARED DIRECT TESTIMONY**

3 **OF**

4 **STEVEN P. HARRIS**

5 **ON BEHALF OF TAMPA ELECTRIC COMPANY**

6
7 **Q.** Please state your name and business address.

8
9 **A.** My name is Steven P. Harris. My business address is ABSG
10 Consulting, Inc. ("ABS Consulting"), 475 14th Street,
11 Oakland, California 94612.

12
13 **Q.** Who is your employer and what is your position?

14
15 **A.** I am a Vice President with ABS Consulting, an affiliated
16 company of EQECAT, Inc. both of which are subsidiaries of
17 the ABS Group of Companies, Inc. Together these two
18 companies are leading global providers of catastrophic
19 risk management services, including software and
20 consulting, to major insurers, re-insurers, corporations,
21 governments and other financial institutions. In
22 addition, these companies develop and license
23 catastrophic underwriting, pricing, risk management and
24 risk transfer models that are used extensively in the
25 insurance industry. The companies provide financial,

DOCUMENT NUMBER - DAE

07061 AUG 11 8

FPSC-COMMISSION CLERK

1 insurance and brokerage communities with a science and
2 technology-based source of independent quantitative risk
3 information.

4
5 **Q.** Please describe your educational background and business
6 experience.

7
8 **A.** I received Bachelors and Masters Degrees in engineering
9 from the University of California at Berkeley. I am a
10 licensed civil engineer in the State of California. Over
11 the past 25 years, I have conducted and supervised
12 independent risk and financial studies for public
13 utilities, insurance companies and other entities both
14 regulated and unregulated. My areas of expertise include
15 natural hazard risk analysis, operational risk analysis,
16 risk profiling and financial analysis, insurance loss
17 analysis, loss prevention and control, business
18 continuity planning and risk transfer.

19
20 A significant portion of my consulting experience has
21 involved the performance of multi-hazard risk studies,
22 including earthquake, ice storm and windstorm perils, for
23 electric, water and telephone utility companies, as well
24 as insurance companies.

25

1 I have performed or supervised windstorm (tropical storm
2 or hurricane) loss and solvency analyses for utilities
3 including Tampa Electric Company ("Tampa Electric" or
4 "company"), Florida Power & Light, Progress Energy
5 Florida, Gulf Power Company and others. Additionally, I
6 have performed loss analyses for earthquake hazard for
7 utilities including the Los Angeles Department of Water
8 and Power, the California-Oregon Transmission Project,
9 Big Rivers Electric and Anchorage Municipal Light and
10 Power.

11
12 For energy companies that have assets in a wide array of
13 geographic locations, I have performed or supervised
14 multi-peril analyses for all natural hazards, including
15 earthquakes, windstorms and ice storms.

16
17 **Q.** Are you sponsoring an exhibit in this case?

18
19 **A.** Yes. I am sponsoring Exhibit No. ____ (SPH-1), entitled
20 "Exhibit of Steven P. Harris on Behalf of Tampa Electric
21 Company", was prepared under my direction and
22 supervision. It consists of one document, "Transmission
23 and Distribution Assets - Storm Loss and Reserve
24 Performance Analysis".
25

1 **Q.** What is the purpose of your direct testimony?

2

3 **A.** My direct testimony presents the results of ABS
4 Consulting's independent analyses of risk of uninsured
5 losses to Tampa Electric's transmission and distribution
6 assets and insurance retentions from hurricanes and
7 tropical storms. These studies include Storm Loss
8 Analysis and Reserve Performance Analysis.

9

10 **Q.** Please briefly describe the studies performed for Tampa
11 Electric.

12

13 **A.** ABS Consulting performed two analyses relative to the
14 reserve: The Storm Loss Analysis ("Loss Analysis"), and
15 The Reserve Performance Analysis ("Performance
16 Analysis"). The Loss Analysis is a probabilistic
17 windstorm analysis that uses proprietary software to
18 develop an estimate of the expected annual amount of
19 uninsured windstorm losses to which Tampa Electric is
20 exposed. The Reserve Performance Analysis is a dynamic
21 financial simulation analysis that evaluates the
22 performance of the reserve in terms of the expected
23 balance of the reserve and the likelihood of positive
24 reserve balances over a five-year period, given the
25 potential uninsured losses determined from the Loss

1 Analysis, at various annual accrual levels.

2

3 **Q.** Please summarize the results of your analyses.

4

5 **A.** The Loss Analysis was performed to estimate the level of
6 annual damage that Tampa Electric is exposed to from
7 hurricanes and tropical storms. The Reserve Performance
8 Analysis was performed to test three levels of possible
9 annual accrual to the reserve. This analysis tests the
10 performance of the reserve against the potential storm
11 losses determined from the storm Loss Analyses. The
12 accrual levels tested are the company's current \$4
13 million per year accrual as well as two other higher
14 levels of \$15 million and \$20 million. The study
15 estimated the total expected average annual uninsured
16 cost to Tampa Electric from all storms to be \$17.8
17 million.

18

19 The Reserve Performance Analysis demonstrated that an
20 accrual level of \$4 million would result in an expected
21 reserve deficit of \$52.4 million and a probability of
22 negative reserve balances of 55.4 percent within the
23 five-year simulation time horizon. The Reserve
24 Performance Analysis demonstrated that an accrual level
25 of \$15 million would result in an expected reserve

1 balance of \$0.3 million and a probability of negative
2 reserve balances of 32.9 percent within the five-year
3 simulation time horizon. The Reserve Performance
4 Analysis demonstrated that an accrual level of \$20
5 million would result in an expected reserve balance of
6 \$28 million and a probability of negative reserve
7 balances of 26.1 percent within the five-year simulation
8 time horizon.

9
10 **LOSS ANALYSIS**

11 **Q.** Please summarize the Loss Analysis.

12
13 **A.** The Loss Analysis determined the expected annual
14 magnitude of windstorm losses to Tampa Electric's
15 transmission and distribution ("T&D") system. Windstorm
16 losses include costs associated with service restoration
17 and repair of Tampa Electric's T&D system as a result of
18 hurricanes and tropical storms. Also included are
19 estimates of the costs of windstorm insurance deductibles
20 attributable to non-T&D assets.

21
22 **Q.** Please describe the computer software used to perform the
23 Loss Analysis.

24
25 **A.** USWIND™ is a probabilistic model designed to estimate

1 damage and losses due to the occurrence of storms.
2 EQECAT's proprietary computer software USWIND™ is one of
3 only four models evaluated and determined acceptable by
4 the Florida Commission on Hurricane Loss Projection
5 Methodology for projecting hurricane loss costs.

6
7 Probabilistic annual damage and loss is computed using
8 the results of over 100,000 random variable storms.
9 Annual damage and loss estimates are developed for each
10 individual site and aggregated to overall portfolio
11 damage and loss amounts. USWIND™ climatological models
12 are based on the National Oceanic and Atmospheric
13 Administration's ("NOAA") National Weather Service
14 Technical Reports.

15
16 **Q.** Does USWIND™ take into account storm frequency and
17 severity?

18
19 **A.** Yes. The analysis is based on storm frequency and
20 severity distributions developed from the entire 105-year
21 historical record. USWIND™ also allows the estimation of
22 frequency of storms in the current period of heightened
23 hurricane activity.

24
25 **Q.** Please describe the current period of heightened

1 hurricane activity.

2

3 **A.** Hurricanes are known to occur in multi-year cycles. The
4 recent decades of the 1970s through the mid-1990s had
5 significantly lower activity than the 105-year long-term
6 average. Other decades have had periods of higher
7 activity. NOAA has expressed its belief that we entered
8 a period of increased hurricane formation around 1995.

9

10 There is the emerging consensus that changes in the El
11 Niño/Southern Oscillation and North Atlantic Oscillation
12 variables indicate we have entered a more active period
13 for hurricane formation like the 1920s and 1940s.
14 Therefore, Tampa Electric may expect to experience higher
15 damage to its T&D assets over the next several years than
16 would be predicted by the long-term hurricane hazard.

17

18 The Loss Analysis is based on hurricane frequency and
19 severity distributions that are reflective of the
20 relatively more active periods of the 1920s and 1940s.
21 The length of these active periods is thought to be about
22 25 to 40 years or more, and the recent period of higher
23 activity is believed to have begun only about a decade
24 ago.

25

1 The hurricane hazard cases analyzed therefore represent
2 frequencies associated with the current period that may
3 be associated with a higher frequency of hurricane
4 formation. If the view held by NOAA other meteorological
5 experts is correct, we may expect to see larger numbers
6 of hurricanes form and larger numbers of landfalls in the
7 coming decades than we have in the pre-1995 period.

8
9 **Q.** Do the storm frequency assumptions include the
10 possibility of having multiple hurricane landfalls within
11 Florida in any given year?

12
13 **A.** Yes. USWIND™ does include the possibility of having
14 multiple hurricane landfalls within Florida in any given
15 year, including the impact of such landfalls on aggregate
16 losses, consistent with the 2004 hurricane season.

17
18 **Q.** Did the Loss Analysis take into account the frequency of
19 storms during the 2004 and 2005 storm seasons?

20
21 **A.** The current analysis takes into account the hurricane
22 history up to and including the 2004 storm season. While
23 the frequency and severity of the 2005 storm season was
24 not incorporated into the EQECAT model used for the Tampa
25 Electric analysis, this impact is expected to be small

1 since there were no hurricane landfalls near Tampa in
2 2005.

3
4 **Q.** What impact did the 2004 experience have on the results
5 of the analysis?

6
7 **A.** Adding the 2004 season increased the long-term hurricane
8 hazard in the Tampa area by about 60 percent over the
9 prior modeled hazard.

10
11 **Q.** What were the results of the Loss Analysis?

12
13 **A.** The total expected annual uninsured cost to Tampa
14 Electric's system from all storms is estimated to be
15 \$17.8 million.

16
17 **Q.** What does this expected annual loss estimate represent?

18
19 **A.** The expected annual loss estimate represents the average
20 annual cost associated with damage to T&D assets,
21 insurance deductibles for damage to other assets such as
22 generating plants and substations, and service
23 restoration activities resulting from windstorms over a
24 long period of time.

25

1 Q. Is the Loss Analysis performed for Tampa Electric the
2 same analysis performed for insurance companies to price
3 an insurance premium?
4

5 A. Yes. The natural hazards loss modeling and analysis
6 would be similar for an insurance company, electric
7 utility or other entity. The expected annual loss is
8 also known as the "pure premium", which when insurance is
9 available is the insurance premium level needed to pay
10 just the expected losses. Although insurance companies
11 would add their expenses and profit margin to the pure
12 premium to develop the premium charged to customers,
13 those costs are not reflected in ABS Consulting's
14 analyses results.
15

16 **RESERVE PERFORMANCE ANALYSIS**

17 Q. Please summarize the Reserve Performance Analysis.
18

19 A. ABS Consulting performed a dynamic financial simulation
20 analysis of the impact of the estimated windstorm losses
21 on the reserve for specified levels of annual funding.
22 The starting assumption for the Reserve Performance
23 Analysis was a reserve balance of \$21.6 million. This
24 Performance Analysis performed 10,000 simulations of
25 windstorm losses within the Tampa Electric service

1 territory, each covering a five-year period, to determine
2 the effect of the charges for loss on the reserve.

3
4 The analysis technique used relies on repeated sampling
5 to model multiple storm seasons and simulates variable
6 storm losses consistent with the results of the Loss
7 Analysis. Because storm seasons and losses are highly
8 variable, 10,000 five-year simulations are performed to
9 estimate the performance of the reserve with various
10 accrual levels and ensure an adequate number of samples
11 of rare storm events. Monte Carlo simulations were used
12 to generate damage samples for the analysis.

13
14 The simulations were used to generate loss samples
15 consistent with the expected \$17.8 million annual loss
16 from the Loss Analysis results. The analysis provides
17 the expected balance of the reserve in each year of the
18 simulation accounting for the annual accrual and losses
19 using a financial model.

20
21 **Q.** How are the results of the Loss Analysis used in the
22 Reserve Performance Analysis?

23
24 **A.** Both the likelihoods and amounts of uninsured annual
25 losses determined in the Loss Analysis are used to

1 simulate losses in each of the five years in the
2 Performance Analysis in order to determine the likelihood
3 of the reserve having positive balances.

4
5 **Q.** Please describe the assumptions that were included in the
6 Reserve Performance Analysis.

7
8 **A.** All computations were performed with an initial reserve
9 balance of \$21.6 million and all results are shown in
10 constant 2007 dollars. The analysis also assumed future
11 growth of the customer base and system assets and
12 inflationary cost increases for new T&D assets of 4.5
13 percent annually.

14
15 **Q.** Please summarize the results of the Reserve Performance
16 Analysis.

17
18 **A.** Reserve performance can be viewed in terms of the
19 expected or mean balance of the reserve and the
20 likelihood of positive reserve balances occurring within
21 the five-year period. Based on the simulated loss
22 distributions, there is some likelihood of negative
23 reserve balances for each of the annual accrual levels
24 analyzed. Higher accrual levels will result in a lower
25 probability of negative reserve balances, and will have a

1 higher probability of a positive reserve balance at the
2 end of the five-year simulation period. If the annual
3 accrual levels are smaller, there is a greater chance of
4 negative reserve balances, especially in the early years.
5

6 **TAMPA ELECTRIC'S RECOMMENDED ACCRUAL**

7 **Q.** Did you make a recommendation for Tampa Electric's annual
8 level of accrual?
9

10 **A.** No. My role was not to recommend an annual level of
11 accrual. It was to present probabilities to Tampa
12 Electric regarding reserve performance based on various
13 levels of annual accrual. There are large uncertainties
14 associated with the hurricane hazard and the specific
15 storm outcomes have large variances. There could be
16 hurricane seasons with no loss at all and hurricane
17 seasons with hundreds of millions of dollars in losses.
18 The Performance Analysis presents information about the
19 likelihood of the adequacy of funding that can be used to
20 make decisions about the reserve. I do believe that
21 given Tampa Electric's objectives, a \$20 million annual
22 accrual is appropriate.
23

24 **Q.** What factors are contributing to the significant increase
25 in Tampa Electric's proposed reserve accrual of \$20

1 million compared to the existing \$4 million accrual?

2

3 **A.** It is my understanding that the current \$4 million
4 accrual was authorized based on an analysis performed in
5 1994. Since that time, there have been significant
6 changes in Tampa Electric's T&D exposures. The
7 replacement value of T&D assets estimated by Tampa
8 Electric to be \$1.1 billion at that time is now estimated
9 to be \$3.4 billion. The Loss Analysis performed also
10 reflects the current view of the increased frequency of
11 hurricane formation resulting in a higher likelihood of
12 losses. Potential un-recovered losses to Tampa Electric
13 in the current analyses also include tropical storms
14 damage and property deductibles.

15

16 **Q.** Is Tampa Electric's recommendation of a \$120 million
17 target level for the reserve adequate?

18

19 **A.** Yes. Based on the current value of Tampa Electric's T&D
20 assets, a reserve balance of \$120 million would be
21 adequate to cover uninsured losses during most, but not
22 all, storm seasons. There is a 2.6 percent chance every
23 year that storm loss could exceed \$120 million.

24

25 **Q.** Did you analyze a range of annual accrual levels in your

1 evaluation?

2

3 **A.** Yes. My evaluation included analyses of the reserve
4 performance at the current annual accrual level of \$4
5 million, and at the annual accrual levels of \$15 million
6 and \$20 million.

7

8 **Q.** What is the likelihood of company's reserve having an
9 inadequate balance at the current annual accrual level of
10 \$4 million?

11

12 **A.** At the current annual accrual level of \$4 million, the
13 likelihood of the reserve having negative balances within
14 the five-year period is 55.4 percent, and it is estimated
15 that the reserve would have a deficit of \$52.4 million at
16 the end of five years.

17

18 **Q.** What did your evaluation show with respect to a \$20
19 million accrual?

20

21 **A.** At an annual accrual level of \$20 million, the likelihood
22 of the reserve having negative balances within the five-
23 year period is 26.1 percent, and the expected balance of
24 the reserve at the end of five years would be
25 approximately \$28 million.

1 Q. Would a \$20 million accrual cover all potential storm
2 loss outcomes?

3
4 A. No. The expected or mean balance of \$28 million has a 50
5 percent chance of being exceeded. The analysis also
6 provides estimates of the fifth percentile and ninety-
7 fifth percentile reserve balances. At the fifth
8 percentile reserve balance, only five percent of the
9 simulated outcomes have smaller values. Similarly, for
10 the ninety-fifth percentile reserve balance, only five
11 percent of simulated outcomes have values, which would be
12 greater than that value. The fifth percentile represents
13 an extremely adverse five years of storm experience where
14 the losses would far exceed the reserve levels.
15 Conversely, the ninety-fifth percentile line would
16 represent an extremely favorable five years of storm
17 experience where only five percent of simulated reserve
18 outcomes would be greater than the estimated balance or
19 five years of very small or no storm damage.

20
21 Q. What is your conclusion with respect to the \$20 million
22 annual level of accrual selected by Tampa Electric?

23
24 A. My analysis indicates that, with an expected annual loss
25 of \$17.8 million and an annual accrual of \$20 million,

1 the balance of the reserve at the end of five years is
2 expected to be \$28 million. This represents a slight
3 increase in reserve from the initial balance of \$21.6
4 million. There is about a one in four chance that storm
5 losses would create a deficit in the reserve within the
6 five-year period. Additionally, only with an extremely
7 favorable five-year storm experience would the reserve
8 balance reach or exceed the \$120 million target. Tampa
9 Electric's recommendation appears reasonable and
10 appropriate.

11
12 **Q.** Does this conclude your direct testimony?

13
14 **A.** Yes.
15
16
17
18
19
20
21
22
23
24
25

EXHIBIT

OF

STEVEN P. HARRIS

ON BEHALF OF TAMPA ELECTRIC COMPANY

Table of Contents

DOCUMENT NO.	TITLE	PAGE
1	Transmission And Distribution Assets - Storm Loss And Reserve Performance Analysis	21



Tampa Electric

Transmission and Distribution Assets

Storm Loss and Reserve Performance Analyses

July 2008



ABS Consulting
An ABS Group Company

Table of Contents

	<u>Page</u>
RISK PROFILE	iv
1. STORM LOSS ANALYSIS	1-1
2. HURRICANE HAZARD	2-1
3. STORM LOSS ANALYSIS RESULTS	3-1
4. HURRICANE LANDFALL ANALYSES FOR SSI RANGES	4-1
5. RESERVE PERFORMANCE ANALYSIS	5-1
6. REFERENCES	6-1

Tables

1-1 Distribution Asset Replacement Values by County	1-2
1-2 Transmission Asset Replacement Value.....	1-2
3-1 TECO T & D Assets Aggregate Damage Exceedance Probabilities.....	3-3
5-1a Reserve Accruals and Reserve Balances for Annual Accrual Cases	4-2
5-1b Reserve Accruals and Probability of Reserve Balances	4-2

Figures

1-1 Distribution Asset Values by Zip Code	1-3
1-2 Transmission Asset Values by Zip Code	1-4

Table of Contents

Figures (Continued)

4-1	Figure 1: Hurricane Landfall Mileposts.....	4-2
4-2	Frequency Weighted Average Transmission & Distribution Damage from Single SSI 1 Landfalls	4-3
4-3	Frequency Weighted Average Transmission & Distribution Damage from Single SSI 2 Landfalls	4-4
4-4	Frequency Weighted Average Transmission & Distribution Damage from Single SSI 3 Landfalls	4-5
4-5	Frequency Weighted Average Transmission & Distribution Damage from Single SSI 4 Landfalls	4-6
5-1:	\$21.6 million initial balance, \$ 4 million Annual Accrual;	5-4
5-2:	\$21.6 million initial balance, \$15 million Annual Accrual;	5-5
5-3:	\$21.6 million initial balance, \$20 million Annual Accrual;	5-6

DISCLAIMER

THE RECIPIENT OF THIS CONFIDENTIAL "RISK PROFILE MEMORANDUM" RECOGNIZES THE INHERENT RISKS THAT ARE ATTENDANT WITH THE RISK ANALYSIS WHICH IS THE SUBJECT OF THIS MEMORANDUM. IN PERFORMING ITS PROFESSIONAL SERVICES, ABSG CONSULTING (ABS CONSULTING) HAS PERFORMED IN A WORKMANLIKE MANNER CONSISTENT WITH INDUSTRY STANDARDS.

ABS CONSULTING BELIEVES THE DATA AND METHODOLOGIES DESCRIBED IN THE MEMORANDUM TO BE ACCURATE; HOWEVER, THE DATA AND METHODOLOGY DESCRIBED HEREIN, AND THE ANALYSES AND SERVICES PROVIDED HEREIN, ARE PROVIDED "AS IS" WITHOUT ANY WARRANTY OR GUARANTY OF ANY KIND. NEITHER ABS CONSULTING NOR ANY OF ITS OFFICERS, DIRECTORS, AGENTS, SUBSIDIARIES OR AFFILIATES GUARANTEES OR WARRANTS THE CORRECTNESS, COMPLETENESS, CURRENTNESS, MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE OF THE ANALYSIS PROVIDED HEREUNDER. BY ACCEPTING THIS MEMORANDUM, THE RECIPIENT RECOGNIZES THAT METEOROLOGICAL, TOPOGRAPHICAL, ENVIROMENTAL, AND STRUCTURAL CONDITIONS CAN VARY FROM THOSE ENCOUNTERED WHEN AND WHERE ABS CONSULTING HAS OBTAINED ITS DATA, AND THAT THE LIMITED NATURE OF THE DATA NECESSARILY CAUSES A LEVEL OF UNCERTAINTY. CONSEQUENTLY, ANY SOFTWARE USED IN CONNECTION WITH THE PERFORMANCE OF SERVICES MAY NOT INCLUDE DATA PERTAINING TO THE MOST RECENT NATURAL CATASTROPHES.

A SIGNIFICANT AMOUNT OF UNCERTAINTY EXISTS IN KEY ANALYSIS PARAMETERS THAT CAN ONLY BE ESTIMATED. PARTICULARLY, SUCH UNCERTAINTIES EXIST IN, BUT ARE NOT LIMITED TO: STORM SEVERITY AND LOCATIONS; ASSET VULNERABILITIES, REPLACEMENT COSTS, AND OTHER COMPUTATIONAL PARAMETERS, ANY OF WHICH ALONE CAN CAUSE ESTIMATED LOSSES TO BE SIGNIFICANTLY DIFFERENT THAN LOSSES SUSTAINED IN SPECIFIC EVENTS.

Risk Profile

The following is a summary description of analyses performed by ABS Consulting of Tampa Electric ("TECO") storm loss exposure and reserve performance. This report is intended to be used solely by TECO and the Florida Public Service Commission for estimation of potential future TECO losses to the reserve and the estimation of the performance of the reserve.

OWNER	Tampa Electric	
ASSETS	Transmission and Distribution (T & D) System: Transmission towers, and conductors; Distribution poles, transformers, conductors, lighting and other miscellaneous assets; Non-recovered property insurance policy deductibles.	
LOCATION	All T & D assets located within the State of Florida,	
ASSET VALUE	Normal replacement value is approximately \$ 3.4 billion, of which approximately 15% is transmission and 85% is distribution	
LOSS PERILS	Hurricane Windstorm (SSI 1 to 5), Tropical Storms	
EXPECTED ANNUAL LOSS (T&D and deductibles)	\$17.8 million	
1% AGGREGATE DAMAGE EXCEEDANCE VALUE	\$301 million	
	Reserve Performance	
Reserve Analysis Cases \$21.6 m initial balance	Expected balance at 5 years	Probability of negative balance within 5 years
\$4 million Annual Accrual	(\$52.4 million)	55.4%
\$15 million Annual Accrual	\$0.3 million	32.9%
\$20 million Annual Accrual	\$27.9 million	26.1%

1. Storm Loss Analysis

Tampa Electric ("TECO") transmission and distribution (T & D) systems and general property are exposed to and in the past have sustained damage from hurricanes and tropical storms. The exposure of these assets to storm damage is described and potential losses are quantified. Loss analyses were performed by ABS Consulting, using an advanced computer model simulation program USWIND™ developed by EQECAT, an ABS Group Company. All results which are presented here have been calculated using USWIND, and the TECO provided T & D asset portfolio data.

The storm exposure is analyzed from a probabilistic approach, which considers the full range of potential storm characteristics and corresponding losses. Probabilistic analyses identify the probability of damage exceeding a specific dollar amount. USWIND™ is a probabilistic model designed to estimate damage and losses due to the occurrence of hurricanes. EQECAT proprietary computer software USWIND is one of only four models evaluated and determined acceptable by the Florida Commission on Hurricane Loss Projection Methodology (FCHLPM) for projecting hurricane loss costs (Reference 1).

Probabilistic Annual Damage & Loss is computed using the results of thousands of random variable storms. Annual damage and loss estimates are developed for each individual site and aggregated to overall portfolio damage and loss amounts. Damage is defined as the cost associated with repair and/or replacement of T & D assets necessary to promptly restore service in a post-storm environment. This cost is typically larger than the costs associated with scheduled repair and replacement programs.

Factors considered in the analysis include the location of TECO's overhead and underground T & D assets, the probability of storms of different intensities and/or landfall points impacting those assets, the vulnerability of those assets to storm damage, and the costs to repair assets and restore electrical service.

Transmission and Distribution asset data are provided in the Tables 1-1 and 1-2 below. Distribution and transmission asset values by zip code are shown in Figure 1-1 and Figure 1-2 respectively.

1. Storm Loss Analysis

Table 1-1
DISTRIBUTION ASSET REPLACEMENT VALUES BY COUNTY

County	Replacement Value (\$000)
Hardee	\$414
Hernando	\$491
Hillsborough	\$2,353,186
Manatee	\$4,144
Pasco	\$89,886
Pinellas	\$56,020
Polk	\$361,180
Total	\$2,865,321

Table 1-2
TRANSMISSION ASSET REPLACEMENT VALUE

	Replacement Value (\$000)
TOTAL	\$492,497

1. Storm Loss Analysis




Figure 1-1: Distribution Asset Values by Zip Code

1. Storm Loss Analysis




Figure 1-2: Transmission Asset Values by Zip Code

1. Storm Loss Analysis

Transmission and Distribution Asset Vulnerabilities

The TECO loss history from the 2004 Hurricanes Charley, Frances, and Jeanne were considered in the calibration of the storm loss model. These hurricanes provide data on recent storm recovery costs from low intensity winds. The 2004 storm loss experience includes the effects of many factors including the post hurricane costs of labor and other factors associated with the storm restoration process utilized by TECO. The 2004 loss history is believed to be most reflective of the current TECO storm restoration practices and cost experience.

Insured Property Policy Deductibles

Tampa Electric insured property was also modeled for hurricane loss potential. The insured property consisted of power plants, general buildings and substations. The model analyzed the property exposures and the Tampa Electric insurance policy which requires the insured's retention of up to the first \$25 million loss per storm occurrence. These non-recovered deductible losses were estimated using USWIND and a methodology similar to that described above.

Loss Estimation Methodology

The basic components of the hurricane risk analysis include:

- **Assets at risk:** define and locate
- **Storm hazard:** apply probabilistic storm model for the region
- **Asset vulnerabilities:** severity (wind speed) versus damage
- **Portfolio Analysis:** probabilistic analysis -damage/ loss

2. Hurricane Hazard

Hurricane Exposure

The hurricane exposure is analyzed from a probabilistic approach, which considers the full range of potential hurricane characteristics and corresponding losses. Probabilistic analyses identify the probability of damage exceeding a specific dollar amount.

USWIND™ is a probabilistic model designed to estimate damage and losses due to the occurrence of hurricanes. EQECAT, Inc. proprietary computer software USWIND is one of only four models evaluated and determined acceptable by the Florida Commission on Hurricane Loss Projection Methodology (FCHLPM) for projecting hurricane loss costs.

The historical annual frequency of hurricanes has varied significantly over time. There are many causes for the temporal variability in hurricane formation. While stochastic variability is a significant factor, many scientists believe that the formation of hurricanes is also related to climate variability.

One of the primary climate cycles having a significant correlation with Hurricane activity is the Atlantic Multidecadal Oscillation (AMO). It has been suggested that the formation of hurricanes in the Atlantic Ocean off the coast of Africa is related to the amount of rainfall in the Western African Sahel region. Years in which rainfall is heavy have been associated with the formation of a greater number of hurricanes. The AMO cycle consists of a warm phase, during which the tropical and sub-tropical North Atlantic have warmer than average temperatures at the surface and in the upper portion relevant to hurricane activity, and a cool phase, during which these regions of the ocean have cooler than average temperatures. In the period 1900 through 2005, the AMO has gone through the following phases:

2. Hurricane Hazard

1900 through 1925	Cool	(Decreased Hurricane Activity)
1926 through 1969	Warm	(Increased Hurricane Activity)
1970 through 1994	Cool	(Decreased Hurricane Activity)
1995 through 2005	Warm	(Increased Hurricane Activity)

The National Oceanic and Atmospheric Administration (NOAA) believes that we entered a warm phase of AMO around 1995 which can be expected to continue for at least several years; historically, each phase of AMO has lasted approximately 25 to 40 years. This view of the current period of increased hurricane activity is reflected in the analyses.

Probabilistic Annual Damage & Loss is computed using the results of thousands of random variable hurricanes. Annual damage estimates are developed for each individual site and aggregated to overall portfolio damage amounts. Damage is defined as the total cost including the operations and maintenance (O&M) and capital components associated with repair and/or replacement of T & D assets necessary to promptly restore service in a post storm environment. This cost is typically larger than the costs associated with scheduled repair and replacement programs.

Factors considered in the analysis include the location of TECO's overhead and underground T & D assets, the probability of hurricanes of different intensities and/or landfall points impacting those assets, the vulnerability of those assets to hurricane damage, and the costs to repair assets and restore electrical service.

3. Storm Loss Analysis Results

Aggregate Loss Exceedance and Expected Annual Loss

A probabilistic database of T&D and insured property deductible losses is developed using the storm hazard, assets at risk and their vulnerabilities. The analysis reflects the current view that we are in a period of heightened hurricane formation. For each hurricane, the center, shape, geographical orientation, track and wind speeds were defined. The wind field for each storm is integrated with the asset vulnerability and the asset locations to compute the damage. The annual frequency and the portfolio damage for each is simulated. By manipulating this database of thousands of hurricane losses, various loss exceedance or non-exceedance distributions are generated.

The frequencies and computed damage for all hurricanes are combined to calculate the expected annual loss (EAL) and the annual aggregate exceedance relations.

Aggregate damage exceedance calculations are developed by keeping a running total of damage from *all possible events* in a year. At the end of year, the aggregate damage for all events is then determined by probabilistically summing the damage distribution from each event, taking into account the event frequency. The process considers the probability of having zero events, one event, two events, etc. during a year.

A series of probabilistic analyses were performed, using the vulnerability curves derived for TECO assets and the computer program USWIND™. A summary of the analysis is presented in Table 3-1, which shows the aggregate loss exceedance probability for damage layers between zero and over \$250 million dollars.

For each damage layer shown, the probability of damage exceeding a specified value is shown. For example, the probabilities of loss exceeding \$100 million in one year is 3.15%. The analysis calculates the probability of damage from all storms and aggregates the total.

3. *Storm Loss Analysis Results*

Tables 3-1 provides the aggregate loss exceedance probabilities for the TECO T & D damage and property deductibles analyzed for a series of layers. Each layer has a layer amount of \$10 million, except for the final layer which represents all damage \$250 million and greater. The value in the first column, labeled Loss Layer, is the attachment point for each layer, with the exception of the last layer, for which the attachment point is \$250 million.

The second column of the table, labeled 1 year Exceedance Probability, provides the annual modeled probability of penetrating each layer, i.e. the probability that the total damage from all events in a 1 year period will exceed the attachment point of the layer.

The expected annual loss (EAL) and exposure to TECO's reserve from hurricane and tropical storm damage to T&D and insured property deductibles is \$17.8 million. This value represents the average loss from all simulated storms. The EAL is not expected to occur each and every year. Some years will have no damage from storms, some years will have small amounts of damage and a few years will have large amounts of damage. The EAL represents the average of all storm years over a long period of time.

It should be noted that the National Oceanographic and Atmospheric Administration (NOAA) believes that in 1995 we entered a period of heightened hurricane formation in the Atlantic Basin and near term frequencies of hurricanes over the coming decade should be expected to be significantly higher than those over the long term.

3. Storm Loss Analysis Results

Table 3-1

**TECO T & D ASSETS AND DEDUCTIBLES
AGGREGATE LOSS EXCEEDANCE PROBABILITIES**

Loss Layer	1 Year
(\$millions)	Exceedance Probability
(> 0.5)	41.2 %
10	24.3 %
20	17.7 %
30	12.5 %
40	8.88%
50	6.70%
60	5.39%
70	4.52%
80	3.92%
90	3.48%
100	3.15%
110	2.85%
120	2.62%
130	2.42%
140	2.23%
150	2.08%
160	1.94%
170	1.82%
180	1.72%
190	1.62%
200	1.54%
210	1.46%
220	1.39%
230	1.33%
240	1.27%
>250	1.22%

4. Hurricane Landfall Analyses for SSI Ranges

In order to provide further insight into Tampa Electric's risk profile, the full set of stochastic hurricane events were analyzed by landfall for four hurricane intensities, SSI 1 through 4. The landfall locations are at mileposts from about 1090 to 1300 on the Gulf Coast. The Figure below illustrates the landfall locations. The mileposts extend east from Cross City, FL near milepost 1090 to Fort Meyers near milepost 1290 in 10 mile intervals.

The full set of stochastic hurricanes within each SSI category was analyzed for Tampa Electric's T&D portfolio. For each milepost and SSI category, the frequency-weighted average damage was computed from all stochastic hurricanes making landfall within 10 nautical miles of a given milepost and within that SSI category. Figures 4-2 through 4-5 provide these results.

4. Hurricane Landfall Analyses For SSI Ranges




Figure 4-1: Hurricane Landfall Milepost




Figure 4-2: Frequency Weighted Average Transmission & Distribution Damage from Single SSI 1 Landfalls

38




Figure 4-3: Frequency Weighted Average Transmission & Distribution Damage from Single SSI 2 Landfalls

4. Hurricane Landfall Analyses For SSI Ranges




Figure 4-4: Frequency Weighted Average Transmission & Distribution Damage from Single SSI 3 Landfalls

40

TAMPA ELECTRIC COMPANY
 DOCKET NO. 080317-EI
 EXHIBIT NO. _____ (SPH-1)
 WITNESS: HARRIS
 DOCUMENT NO. 1
 PAGE 20 OF 29
 FILED: 08/11/2008




Figure 4-5: Frequency Weighted Average Transmission & Distribution Damage from Single SSI 4 Landfalls

41

5. Reserve Performance Analysis

A probabilistic analysis of losses from hurricanes was performed for Tampa Electric to determine their potential impact on the reserve. The analysis included transmission and distribution (T & D) damage as well as estimates of insurance deductibles paid on insured property assets.

Analysis

The Reserve Performance Analysis consisted of performing 10,000 iterations of hurricane loss simulations within the Tampa Electric service territory, each covering a 5-year period, to determine the effect of the charges for damage on the TECO reserve. Monte Carlo simulations were used to generate damage samples for the analysis. The analysis provides an estimate of the reserve assets in each year of the simulation, accounting for the annual accrual and storm damage using a dynamic financial model.

The analyses consider three accrual cases, each with an initial \$21.6 million reserve balance. The cases have annual accruals of \$4 million, \$15 million and \$20 million over the five year period.

Assumptions

The analyses performed included the following assumptions:

- An initial reserve balance of \$21.6 million for all cases.
- Storm losses are assumed to increase by 4.5% per year as replacement values of T&D increase due to inflation and system growth.
- Storm losses include estimates of property insurance policy deductibles up to the policy limit of \$25 million per occurrence.

The results for the cases analyzed are shown in Tables 5-1a and b below. The results show the annual reserve accrual amount, the mean (expected) reserve

5. Reserve Performance Analysis

balance as well as the probability that the reserve balance will be negative in any one or more of the five years of the simulated time horizon.

Table 5-1a

**RESERVE ACCRUALS AND
RESERVE BALANCES FOR
ANNUAL ACCRUAL CASES
(\$ Millions)**

Reserve Balance at the end of 5 years			
Expected Annual Loss	\$17.80		
Accrual	5%ile	Mean	95%ile
\$4	(\$324)	(\$52)	\$41
\$15	(\$292)	\$0	\$97
\$20	(\$255)	\$28	\$122

Table 5-1b

**RESERVE ACCRUALS AND
PROBABILITY OF RESERVE BALANCES
(\$ Millions)**

Accrual	Mean Reserve Balance at the end of 5 years	Probability of Balance <\$0 in 5 years	Probability of Balance >\$20m in 5 years
\$4	(\$52)	55%	77%
\$15	\$0	33%	91%
\$20	\$28	26%	94%

Figures 5-1 through 5-3 show the results of the \$21.6 million initial balance, and \$4 million, \$15 million and \$20 million contribution cases. These results show the mean (expected) reserve balance as well as the 5th and 95th percentile reserve balances.

For example, given an initial reserve balance of \$21.6 million and the specified \$4 million, Figures 5-1 illustrates the expected performance of the reserve. The reserve has a mean (expected) Balance of negative (\$52 million) at the end of the five-year period. The 5th percentile and 95th percentile 5 year ending reserve balances are negative (\$324

5. Reserve Performance Analysis

million) and \$41 million respectively. The reserve has a 55% chance of negative balances in one or more years of the five-year simulation.

The annual accrual of \$4 million is less than the Expected Annual Loss from storms of \$17.8. Therefore with each passing year, the reserve ending balance has a decreasing likelihood of accumulating surpluses and an increasing likelihood of negative balances. The expected (mean) reserve balance declines rapidly over the five-year simulation to negative values

Figures 5-2 through 5-3 below show the results of the \$15 million and \$20 million annual accrual cases. The annual accruals of \$15 million to \$20 million for these cases are near the Expected Annual Loss from storms of \$17.8. The EAL would be expected to grow at a 4.5% annual rate due to inflation and system growth to \$20.8 at the end of the five year period. The EAL value would also be between the \$15 million to \$20 million accrual levels. Therefore with each passing year, the reserve ending balance has an increasing likelihood of accumulating surpluses and a decreasing likelihood of negative balances. The expected (mean) reserve balance increases gradually over the five-year simulation from the intial balance of \$21.6 million to \$28 million.

Annual Accrual = \$4,000,000
 Initial Balance = \$21,643,000




Figure 5-1: \$21.6 million initial balance, \$4 million annual accrual

Annual Accrual = \$15,000,000
 Initial Balance = \$21,643,000




Figure 5-2: \$21.6 million initial balance, \$15 million annual accrual

46

TAMPA ELECTRIC COMPANY
 DOCKET NO. 080317-EI
 EXHIBIT NO. _____ (SPH-1)
 WITNESS: HARRIS
 DOCUMENT NO. 1
 PAGE 26 OF 29
 FILED: 08/11/2008

Annual Accrual = \$20,000,000
 Initial Balance = \$21,643,000




Figure 5-3: \$21.6 million initial balance, \$20 million annual accrual

47

TAMPA ELECTRIC COMPANY
 DOCKET NO. 080317-EI
 EXHIBIT NO. (SPH-1)
 WITNESS: HARRIS
 DOCUMENT NO. 1
 PAGE 27 OF 29
 FILED: 08/11/2008

6. References

1. "Florida Commission on Hurricane Loss Projection Methodology", EQECAT, an ABS Group Company, February 2006 Submission.



ABS Consulting

475 14th Street, Suite 550
Oakland, CA 94612 USA
Tel: 510-817-3100/Fax: 510-663-1046
www.absconsulting.com

Offices Worldwide:

Americas

Beaverton, OR
Bethesda, MD
Denver, CO
Houston, TX
Knoxville, TN
Richland, WA
Rockville, MD
Salt Lake City, UT
San Antonio, TX
Shillington, PA
Stratham, NH
Wilmington, DE

Ciudad del Carmen, Mexico
Mexico City, Mexico
Monterrey, Mexico
Reynosa, Mexico
Veracruz, Mexico

Sao Paulo, Brazil
Rio de Janeiro, Brazil
Buenos Aires, Argentina
Valparaiso, Chile

Europe

Aberdeen, UK
Abu Dhabi, UAE
Doha, Qatar
Dubai, UAE
Genoa, Italy
Istanbul, Turkey
Dammam, Saudi Arabia
London, UK
Muscat, Oman
Paris, France
Piraeus, Greece
Rotterdam,
The Netherlands
Sofia, Bulgaria
Vizcaya, Spain
Warrington, UK

Asia-Pacific

Bangkok, Thailand
Jakarta, Indonesia
Kuala Lumpur, Malaysia
Manila, Philippines
Mumbai, India
Pusan, Korea
Seoul, Korea
Shanghai
Singapore
Taiwan
Tokyo, Japan
Yokohama, Japan

