

FLORIDA PUBLIC SERVICE COMMISSION

VOTE SHEET

September 16, 2008

Docket No. 080256-EI – Petition to modify wood pole inspection plan by Progress Energy Florida, Inc.

Issue 1: Should Progress Energy Florida, Inc. be granted approval to modify its wood pole inspection plan to allow the flexibility to use either the drilling resistance measuring device (RMD) or the more traditional sound and bore inspection methods on concrete encased poles?

Recommendation: Yes. PEF has demonstrated that the RMD inspection method and the more traditional sound and bore inspection methods provide similar inspection results. Additionally, the proposed modification may result in annual savings of more than \$45,000. Therefore staff recommends that PEF be granted the proposed modifications.

APPROVED

Issue 2: Should this docket be closed?

Recommendation: If no person whose substantial interests are affected by the proposed agency action files a protest within 21 days of the issuance of the order, this docket should be closed upon the issuance of a consummating order.

APPROVED

COMMISSIONERS ASSIGNED: All Commissioners

COMMISSIONERS' SIGNATURES

MAJORITY

DISSENTING

Neil A. Singh

Katrina J. McMurrian

John A. C. Hill

Greg Eddy

N. C. ...

REMARKS/DISSENTING COMMENTS:

DOCUMENT NUMBER-DATE

08710 SEP 16 g