

AUSLEY & MCMULLEN

ATTORNEYS AND COUNSELORS AT LAW

227 SOUTH CALHOUN STREET
P.O. BOX 391 (ZIP 32302)
TALLAHASSEE, FLORIDA 32301
(850) 224-9115 FAX (850) 222-7560

November 24, 2008

HAND DELIVERED

RECEIVED--FPSC
08 NOV 24 PM 3:11
COMMISSION
CLERK

Ms. Ann Cole, Director
Division of Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Re: UNDOCKETED; Rule 25-6.018 -- Records of Interruptions and Commission Notification of Threats to Bulk Power Supply Integrity or Major Interruptions of Service


Dear Ms. Cole:

Pursuant to Rule 25-6.018, Florida Administrative Code, we enclose for filing with the Commission the original and fifteen (15) copies of Tampa Electric Company's revised Interruptible Customer filing and Report on Optional Provision for the quarter ending September 30, 2008.

Please acknowledge receipt and filing of the above by stamping the duplicate copy of this letter and returning same to this writer.

Thank you for your assistance in connection with this matter.

Sincerely,


James D. Beasley

JDB/pp
Enclosure

COM	_____
ECR	_____
GCL	_____ 2
OPC	_____
RCP	_____
SSC	_____
SGA	_____
ADM	_____
CLK	_____

DOCUMENT NUMBER--DATE

10920 NOV 24 08

FPSC-COMMISSION CLERK

Interruption 09/29/08 from 06:40 to 07:04

Reason: Loss of Generation in State

	2 hours before control 15 min high kW	control low 15 min kW	difference	control low 30 min kW	difference	control low 60 min kW	difference	control avg kW	difference
	(a)	(b)	(c)=(a) - (b)	(d)	(e)=(a) - (d)	(f)	(g)=(a) - (f)	(h)	(i)=(a) - (h)
1	1440.0	1440.0	0.0	1440.0	0.0	1440.0	0.0	1488.0	1440.0
2	3842.7	3746.4	96.3	3794.6	48.1	3778.5	64.3	3914.2	0.0
3	900.9	863.2	37.7	871.7	29.2	787.9	113.0	874.6	0.0
4	8104.4	7806.2	298.2	7955.3	149.1	8004.5	99.9	8020.0	7939.5
5	1364.7	1241.0	123.7	1243.4	121.4	1254.7	110.0	1257.7	0.0
6	382.3	510.6	0.0	451.4	0.0	351.7	30.6	566.5	0.0
7	1080.0	1520.0	0.0	1300.0	0.0	945.0	135.0	1633.3	0.0
8	5527.7	5563.2	0.0	5548.4	0.0	5519.6	8.1	5578.3	4559.3
9	122.6	123.5	0.0	123.1	0.0	102.4	20.3	124.6	0.0
10	742.1	641.9	100.2	650.3	91.8	648.2	93.9	650.9	0.0
11	720.7	771.7	0.0	746.2	0.0	699.7	21.0	908.4	0.0
12	4233.6	3561.7	671.9	3729.7	504.0	3889.2	344.4	3841.6	478.8
13	2698.1	2699.8	0.0	2699.0	0.0	2684.2	13.9	2773.1	0.0
14	761.9	671.2	90.7	678.3	83.6	680.8	81.1	682.1	320.0
15	1212.4	1181.0	31.4	1196.7	15.7	1130.7	81.7	1361.7	42.6
16	91794.9	30930.7	60864.2	34680.1	57114.9	56392.2	35402.7	45915.6	29217.6
17	686.3	701.4	0.0	693.9	0.0	673.9	12.4	709.2	0.0
18	5177.8	5144.2	33.6	5149.2	28.6	5158.5	19.4	5155.4	0.0
19	1255.0	1309.8	0.0	1282.4	0.0	1243.1	11.9	1315.9	0.0
20	67.2	67.2	0.0	50.4	16.8	50.4	16.8	2598.4	0.0
21	1429.7	1426.3	3.4	1426.8	3.0	1424.4	5.3	1441.1	0.0
22	571.2	541.8	29.4	541.8	29.4	550.2	21.0	543.2	76.1
23	6501.7	6501.7	0.0	6501.7	0.0	6476.4	25.3	6535.2	0.0
24	45.6	98.0	0.0	71.8	0.0	44.0	1.6	110.0	6.7
Total:	140663.5	79062.5	62380.7	82825.8	58235.5	103930.0	36733.5	106096.7	44080.5

Note: Only one location for one customer interrupted.

DOCUMENT NUMBER-DATE
10920 NOV 24 08
EPSC-COMMISSION CLERK

Interruption 09/30/08 from 13:41 to 13:52

Reason: Loss of Generation in State

	2 hours before control 15 min high kW	control low 15 min kW	difference	control low 30 min kW	difference	control low 60 min kW	difference	control avg kW	difference
	(a)	(b)	(c)=(a) - (b)	(d)	(e)=(a) - (d)	(f)	(g)=(a) - (f)	(h)	(i)=(a) - (h)
1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2	4172.0	3929.0	243.0	3866.8	305.2	3867.4	304.7	4000.4	171.6
3	1393.4	1238.7	154.7	1217.8	175.7	1220.3	173.1	1241.4	152.1
4	156.6	1226.0	0.0	691.3	0.0	408.7	0.0	1231.4	0.0
5	2301.6	1986.6	315.0	1709.6	592.1	1575.1	726.5	2141.9	159.8
6	674.1	625.5	48.6	631.8	42.4	642.5	31.6	631.8	42.4
7	2480.0	2260.0	220.0	2320.0	160.0	2385.0	95.0	2320.0	160.0
8	901.4	649.9	251.5	656.2	245.3	657.1	244.3	656.2	245.3
9	482.6	485.8	0.0	475.8	6.8	467.4	15.2	491.4	0.0
10	878.1	842.4	35.7	856.1	22.0	804.6	73.6	864.3	13.8
11	1632.7	1556.0	76.7	1571.0	61.8	1529.2	103.6	1571.0	61.8
12	3662.5	3259.3	403.2	3292.8	369.7	3301.3	361.3	3309.7	352.8
13	4262.2	4003.4	258.8	4008.5	253.8	4058.5	203.8	4068.1	194.1
14	382.2	372.1	10.1	367.1	15.1	358.5	23.7	373.0	9.2
15	1258.3	1253.8	4.5	1240.4	17.9	1228.7	29.6	1269.7	0.0
16	100474.3	43805.0	56669.3	69000.1	31474.3	84243.5	16230.8	69000.1	31474.3
17	850.1	785.4	64.7	779.1	71.0	795.7	54.4	825.7	24.4
18	5171.0	5147.5	23.5	5150.9	20.1	5155.1	15.9	5150.9	20.1
19	1662.6	1644.7	17.9	1629.6	33.0	1640.8	21.8	1648.7	13.9
20	5577.6	1579.2	3998.4	3796.8	1780.8	4174.8	1402.8	3796.8	1780.8
21	1472.5	1444.0	28.5	1444.8	27.7	1456.1	16.4	1444.8	27.7
22	541.8	483.0	58.8	485.1	56.7	505.1	36.7	485.1	56.7
23	6804	6703.2	100.8	6728.5	75.6	6728.4	75.6	6728.5	75.6
24	1086.4	1029.0	57.4	1067.2	19.2	1054.8	31.7	1067.2	19.2
Total:	148278.0	86309.5	63041.1	112986.9	35825.9	128258.1	20272.0	114317.5	35055.4

Note: Only one location for one customer interrupted.