

**Susan D. Ritenour**  
Secretary and Treasurer  
and Regulatory Manager

One Energy Place  
Pensacola, Florida 32520-0781

Tel 850.444.6231  
Fax 850.444.6026  
SDRITENO@southernco.com

RECEIVED--FPSC  
08 DEC 23 AM 10:13

COMMISSION  
CLERK



December 19, 2008

Ms. Ann Cole, Commission Clerk  
Florida Public Service Commission  
2540 Shumard Oak Boulevard  
Tallahassee FL 32399-0850

Vertical stamp: RECEIVED  
COMMISSION CLERK  
DEC 23 2008 10:13 AM

Dear Ms. Cole:

RE: COMMISSION STAFF'S MINIMUM FILING REQUIREMENTS IN  
SUPPORT OF THE MONTHLY FUEL AND PURCHASED POWER COST  
RECOVERY CHARGE IN DOCKET NO. 080001-EI

Enclosed are an original and ten copies of Gulf Power Company's Actual Unit Performance Data Schedules and the Actual Unit Outage Data Schedules through November 2008, Retail Cost Recovery Charges for Plant Crist, Plant Smith, and Plant Daniel. These schedules are being sent separate from the monthly filing.

Sincerely,

*Susan D. Ritenour*

- COM \_\_\_\_\_
- ECR 9 \_\_\_\_\_
- GCL 1 \_\_\_\_\_
- OPC \_\_\_\_\_
- RCP \_\_\_\_\_
- SSC \_\_\_\_\_
- SGA \_\_\_\_\_
- ADM \_\_\_\_\_
- CLK \_\_\_\_\_

mv  
Enclosures  
cc w/attachment: Florida Public Service Commission  
Sid Matlock

DOCUMENT NUMBER-DATE

11820 DEC 23 08

FPSC-COMMISSION CLERK

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

PERIOD OF: January 2008 - December 2008

	CRIST 4	Jan '08	Feb '08	Mar '08	Apr '08	May '08	Jun '08	Jul '08	Aug '08	Sep '08	Oct '08	Nov '08	Dec '08	Total
1.	EAF (%)	12.9	0.0	47.1	100.0	100.0	100.0	100.0	100.0	100.0	96.0	99.8		
2.	PH	744.0	696.0	743.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	721.0		
3.	SH	0.0	0.0	98.6	674.8	664.1	720.0	744.0	744.0	720.0	238.1	299.8		
4.	RSH	96.0	0.0	251.1	45.2	79.9	0.0	0.0	0.0	0.0	475.9	419.5		
5.	UH	648.0	696.0	393.3	0.0	0.0	0.0	0.0	0.0	0.0	30.0	1.7		
6.	POH	648.0	696.0	383.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
7.	FOH	0.0	0.0	10.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.7		
8.	MOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	30.0	0.0		
9.	PFOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
10.	LR pf (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
11.	PMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
12.	LR pm (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
13.	NSC (MW)	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0		
14.	Oper MBtu	0.0	0.0	57425.0	477654.0	416372.0	482617.0	517882.0	481548.0	492730.0	155177.0	194165.0		
15.	Net Gen (MWH)	0.0	0.0	4952.0	46345.0	39291.0	43684.0	47499.0	44809.0	46048.0	13753.0	18229.0		
16.	ANOHR (Btu/KWH)	0.0	0.0	11596.0	10306.0	10597.0	11048.0	10903.0	10747.0	10700.0	11283.0	10651.0		
17.	NOF %	0.0	0.0	64.4	88.1	75.9	77.8	81.8	77.2	82.0	74.1	78.0		
18.	NPC (MW)	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0		
19.	ANOHR Equation	$10^6 / AKW * [ -508.01 + 11.33 * MAR + 21.63 * MAY + 36.12 * JUN + 26.37 * JUL + 39.93 * AUG + 26.37 * SEP + 18.89 * OCT + 12.20 * NOV ]$ $+ 28,136 - 0.14571 * LSRF / AKW$												

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

PERIOD OF: January 2008 - December 2008

CRIST 5	Jan '08	Feb '08	Mar '08	Apr '08	May '08	Jun '08	Jul '08	Aug '08	Sep '08	Oct '08	Nov '08	Dec '08	Total
1. EAF (%)	12.9	0.0	75.2	90.9	98.2	87.5	100.0	99.4	98.6	98.8	99.2		
2. PH	744.0	696.0	743.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	721.0		
3. SH	0.0	0.0	558.6	654.3	742.3	638.1	744.0	744.0	720.0	744.0	719.1		
4. RSH	96.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
5. UH	648.0	696.0	184.4	65.7	1.7	81.9	0.0	0.0	0.0	0.0	1.9		
6. POH	648.0	696.0	184.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
7. FOH	0.0	0.0	0.0	24.5	0.0	0.0	0.0	0.0	0.0	0.0	1.9		
8. MOH	0.0	0.0	0.0	41.2	1.7	81.9	0.0	0.0	0.0	0.0	0.0		
9. PFOH	0.0	0.0	0.0	0.0	29.1	16.6	0.0	15.0	24.3	21.6	7.7		
10. LR pf (MW)	0.0	0.0	0.0	0.0	32.0	38.0	0.0	24.0	33.0	32.6	36.0		
11. PMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
12. LR pm (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
13. NSC (MW)	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0		
14. Oper MBtu	0.0	0.0	305156.0	466634.0	493600.0	452638.0	550090.0	544148.0	510086.0	459479.0	456492.0		
15. Net Gen (MWH)	0.0	0.0	31028.0	45356.0	45852.0	40465.0	50384.0	47754.0	47115.0	44047.0	43761.0		
16. ANOHR (Btu/KWH)	0.0	0.0	9835.0	10288.0	10765.0	11186.0	10918.0	11395.0	10826.0	10432.0	10431.0		
17. NOF %	0.0	0.0	71.2	88.9	79.2	81.3	86.8	82.3	83.9	75.9	78.0		
18. NPC (MW)	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0	78.0		
19. ANOHR Equation	$10^6 / AKW * [ 107.79 - 10.84 * APR + 13.62 * MAY + 14.07 * JUN + 22.79 * JUL + 23.21 * AUG + 28.04 * SEP + 23.17 * OCT ]$ + 8,943												

**ACTUAL UNIT PERFORMANCE DATA**

**GULF POWER COMPANY**

**PERIOD OF: January 2008 - December 2008**

CRIST 6	Jan '08	Feb '08	Mar '08	Apr '08	May '08	Jun '08	Jul '08	Aug '08	Sep '08	Oct '08	Nov '08	Dec '08	Total
1. EAF (%)	85.2	95.4	84.6	5.3	92.7	90.7	95.0	82.2	88.6	100.0	95.9		
2. PH	744.0	696.0	743.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	721.0		
3. SH	657.4	670.6	629.1	38.4	614.2	655.3	717.1	611.9	643.2	167.1	332.7		
4. RSH	0.0	0.0	0.0	0.0	76.3	0.0	0.0	0.0	0.0	576.9	361.5		
5. UH	86.6	25.4	113.9	681.6	53.5	64.7	26.9	132.1	76.8	0.0	26.8		
6. POH	0.0	0.0	71.7	537.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
7. FOH	29.5	0.0	42.2	143.8	24.1	53.7	26.9	76.4	27.6	0.0	0.0		
8. MOH	57.1	25.4	0.0	0.0	29.4	11.0	0.0	55.7	49.2	0.0	26.8		
9. PFOH	402.1	74.0	23.8	0.0	9.9	29.1	64.2	0.0	99.9	3.9	20.3		
10. LR pf (MW)	17.8	27.8	6.0	0.0	18.4	23.2	49.0	0.0	16.0	22.0	42.0		
11. PMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
12. LR pm (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
13. NSC (MW)	302.0	302.0	302.0	302.0	302.0	302.0	302.0	302.0	302.0	302.0	302.0		
14. Oper MBtu	1932950.0	1920972.0	1191402.0	60921.0	1441483.0	1595690.0	1843139.0	1554185.0	1767866.0	430446.0	749198.0		
15. Net Gen (MWH)	177033.0	180542.0	106316.0	5498.0	131040.0	148447.0	172411.0	137882.0	158430.0	36396.0	71149.0		
16. ANOHR (Btu/KWH)	10919.0	10640.0	11206.0	11081.0	11000.0	10749.0	10690.0	11272.0	11159.0	11827.0	10530.0		
17. NOF %	89.2	89.1	56.0	47.4	70.6	75.0	79.6	74.6	81.6	72.1	70.8		
18. NPC (MW)	302.0	302.0	302.0	302.0	302.0	302.0	302.0	302.0	302.0	302.0	302.0		
19. ANOHR Equation	$10^6 / AKW * [ 457.20 - 54.35 * FEB - 64.08 * MAR + 52.17 * JUN - 50.16 * OCT ]$ $+ 8.761$												

**ACTUAL UNIT PERFORMANCE DATA**

**GULF POWER COMPANY**

**PERIOD OF: January 2008 - December 2008**

CRIST 7	Jan '08	Feb '08	Mar '08	Apr '08	May '08	Jun '08	Jul '08	Aug '08	Sep '08	Oct '08	Nov '08	Dec '08	Total
1. EAF (%)	95.0	98.4	96.2	84.8	99.8	88.3	91.4	92.7	85.7	99.6	88.5		
2. PH	744.0	696.0	743.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	721.0		
3. SH	708.4	696.0	743.0	622.2	744.0	638.4	685.7	710.4	619.9	744.0	652.3		
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
5. UH	35.6	0.0	0.0	97.8	0.0	81.6	58.3	33.6	100.1	0.0	68.7		
6. POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
7. FOH	35.6	0.0	0.0	0.0	0.0	81.6	0.0	0.0	28.8	0.0	68.7		
8. MOH	0.0	0.0	0.0	97.8	0.0	0.0	58.3	33.6	71.3	0.0	0.0		
9. PFOH	88.9	470.8	111.0	256.9	11.8	4.6	65.3	32.8	37.0	0.0	74.1		
10. LR pf (MW)	10.1	4.3	120.6	21.7	8.0	252.0	38.4	81.3	18.2	0.0	91.5		
11. PMOH	0.0	63.7	0.0	0.0	19.3	0.0	0.0	25.1	9.5	5.9	0.0		
12. LR pm (MW)	0.0	50.8	0.0	0.0	33.9	0.0	0.0	282.0	85.0	254.0	0.0		
13. NSC (MW)	472.0	472.0	472.0	472.0	472.0	472.0	472.0	472.0	472.0	472.0	472.0		
14. Oper MBtu	3304515.0	3278878.0	2496502.0	2735478.0	2987352.0	2570546.0	2864585.0	2891013.0	2678012.0	2641152.0	2272143.0		
15. Net Gen (MWH)	316154.0	306009.0	226602.0	257018.0	275495.0	239124.0	269656.0	266162.0	249379.0	257933.0	218306.0		
16. ANOHR (Btu/KWH)	10452.0	10715.0	11017.0	10643.0	10844.0	10750.0	10623.0	10862.0	10739.0	10240.0	10408.0		
17. NOF %	94.6	93.2	64.6	87.5	78.5	79.4	83.3	79.4	85.2	73.5	70.9		
18. NPC (MW)	472.0	472.0	472.0	472.0	472.0	472.0	472.0	472.0	472.0	472.0	472.0		
19. ANOHR Equation	$10^6 / AKW * [ 575.62 - 136.35 * FEB + 117.15 * MAR + 87.68 * APR + 104.03 * JUN ]$ $+ 9.081$												

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

PERIOD OF: January 2008 - December 2008

SMITH 1	Jan '08	Feb '08	Mar '08	Apr '08	May '08	Jun '08	Jul '08	Aug '08	Sep '08	Oct '08	Nov '08	Dec '08	Total
1. EAF (%)	100.0	99.8	99.4	60.8	100.0	99.9	99.9	98.6	100.0	75.2	98.3		
2. PH	744.0	696.0	743.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	721.0		
3. SH	744.0	696.0	743.0	448.8	744.0	720.0	744.0	744.0	720.0	255.2	579.2		
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	305.5	129.7		
5. UH	0.0	0.0	0.0	271.2	0.0	0.0	0.0	0.0	0.0	183.3	12.1		
6. POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
7. FOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
8. MOH	0.0	0.0	0.0	271.2	0.0	0.0	0.0	0.0	0.0	183.3	12.1		
9. PFOH	0.0	5.5	0.0	0.0	0.0	4.3	0.0	122.8	0.0	0.0	0.4		
10. LR pf (MW)	0.0	42.0	0.0	0.0	0.0	27.0	0.0	13.6	0.0	0.0	22.0		
11. PMOH	0.0	0.0	18.9	46.0	0.0	0.0	3.2	2.0	0.0	6.2	0.0		
12. LR pm (MW)	0.0	0.0	39.0	39.0	0.0	0.0	37.0	24.0	0.0	32.0	0.0		
13. NSC (MW)	162.0	162.0	162.0	162.0	162.0	162.0	162.0	162.0	162.0	162.0	162.0		
14. Oper MBtu	1185267.0	1107918.0	918684.0	681581.0	1037857.0	1034121.0	1074223.0	1036786.0	976013.0	351939.0	857707.0		
15. Net Gen (MWH)	116187.0	108123.0	89160.0	66589.0	102133.0	99499.0	104096.0	99918.0	94159.0	34356.0	83489.0		
16. ANOHR (Btu/KWH)	10201.0	10247.0	10304.0	10236.0	10162.0	10393.0	10320.0	10376.0	10366.0	10244.0	10273.0		
17. NOF %	96.4	95.9	74.1	91.6	84.7	85.3	86.4	82.9	80.7	83.1	89.0		
18. NPC (MW)	162.0	162.0	162.0	162.0	162.0	162.0	162.0	162.0	162.0	162.0	162.0		
19. ANOHR Equation	$10^6 / AKW * [ 96.28 + 12.10 * JUN + 11.27 * JUL - 11.78 * OCT ]$ + 9.613												

**ACTUAL UNIT PERFORMANCE DATA**

**GULF POWER COMPANY**

**PERIOD OF: January 2008 - December 2008**

	SMITH 2	Jan '08	Feb '08	Mar '08	Apr '08	May '08	Jun '08	Jul '08	Aug '08	Sep '08	Oct '08	Nov '08	Dec '08	Total
1.	EAF (%)	99.9	69.1	96.8	93.4	28.7	84.6	99.8	98.2	86.5	95.0	100.0		
2.	PH	744.0	696.0	743.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	721.0		
3.	SH	744.0	646.3	743.0	672.4	215.5	633.0	744.0	744.0	623.7	706.8	721.0		
4.	RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
5.	UH	0.0	49.7	0.0	47.6	528.5	87.0	0.0	0.0	96.3	37.2	0.0		
6.	POH	0.0	0.0	0.0	47.6	528.5	0.0	0.0	0.0	0.0	0.0	0.0		
7.	FOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
8.	MOH	0.0	49.7	0.0	0.0	0.0	87.0	0.0	0.0	96.3	37.2	0.0		
9.	PFOH	5.0	291.8	41.9	0.0	42.0	128.2	4.4	115.6	0.0	0.0	0.0		
10.	LR pf (MW)	35.0	110.6	112.0	0.0	10.0	36.1	78.0	22.8	0.0	0.0	0.0		
11.	PMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0	0.0	0.0		
12.	LR pm (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	126.0	0.0	0.0		
13.	NSC (MW)	195.0	195.0	195.0	195.0	195.0	195.0	195.0	195.0	195.0	195.0	195.0		
14.	Oper MBtu	1391962.0	934357.0	1104352.0	1219712.0	366611.0	1058254.0	1265498.0	1278858.0	1074298.0	1132885.0	1248748.0		
15.	Net Gen (MWH)	135307.0	89004.0	105945.0	117541.0	34769.0	100195.0	120915.0	121420.0	100881.0	109149.0	119880.0		
16.	ANOHR (Btu/KWH)	10287.0	10498.0	10424.0	10377.0	10544.0	10562.0	10466.0	10533.0	10649.0	10379.0	10417.0		
17.	NOF %	93.3	70.6	73.1	89.6	82.7	81.2	83.3	83.7	82.9	79.2	85.3		
18.	NPC (MW)	195.0	195.0	195.0	195.0	195.0	195.0	195.0	195.0	195.0	195.0	195.0		
19.	ANOHR Equation	$10^{*6} / AKW * [ 275.87 - 16.87 * MAY - 11.84 * JUL - 10.07 * SEP ]$ $+ 7,294 + 0.00822 * LSRF / AKW$												

**ACTUAL UNIT PERFORMANCE DATA**

**GULF POWER COMPANY**

**PERIOD OF: January 2008 - December 2008**

	DANIEL 1	Jan '08	Feb '08	Mar '08	Apr '08	May '08	Jun '08	Jul '08	Aug '08	Sep '08	Oct '08	Nov '08	Dec '08	Total
1.	EAF (%)	97.1	88.0	92.1	99.6	99.9	99.4	99.1	57.3	6.6	99.4	99.9		
2.	PH	744.0	696.0	743.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	721.0		
3.	SH	744.0	478.6	685.7	720.0	744.0	720.0	740.0	427.2	48.4	740.0	721.0		
4.	RSH	0.0	140.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
5.	UH	0.0	76.6	57.3	0.0	0.0	0.0	4.0	316.8	671.6	4.0	0.0		
6.	POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
7.	FOH	0.0	14.0	57.3	0.0	0.0	0.0	4.0	316.8	671.6	4.0	0.0		
8.	MOH	0.0	62.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
9.	PFOH	39.9	14.9	10.3	9.0	2.5	8.0	9.8	10.1	0.8	1.5	11.8		
10.	LR pf (MW)	271.3	237.2	68.6	174.4	13.0	221.6	118.8	61.8	473.0	146.5	38.0		
11.	PMOH	0.0	0.0	0.0	0.0	5.5	7.0	0.0	0.0	0.0	0.0	0.0		
12.	LR pm (MW)	0.0	0.0	0.0	0.0	36.2	53.5	0.0	0.0	0.0	0.0	0.0		
13.	NSC (MW)	500.0	500.0	500.0	500.0	500.0	500.0	500.0	500.0	500.0	500.0	500.0		
14.	Oper MBtu	3618149.0	2181259.0	3419610.0	3494244.0	3578533.0	3474347.0	3539542.0	1995427.0	179599.0	2618076.0	2796596.0		
15.	Net Gen (MWH)	355261.0	219617.0	338772.0	349259.0	349229.0	343158.0	347405.0	191753.0	16382.0	250618.0	272923.0		
16.	ANOHR (Btu/KWH)	10184.0	9932.0	10094.0	10005.0	10247.0	10125.0	10189.0	10406.0	10963.0	10446.0	10247.0		
17.	NOF %	95.5	91.8	98.8	97.0	93.9	95.3	93.9	89.8	67.7	67.7	75.7		
18.	NPC (MW)	500.0	500.0	500.0	500.0	500.0	500.0	500.0	500.0	500.0	500.0	500.0		
19.	ANOHR Equation	$10^6 / AKW * [ 695.23 ]$ $+ 8.686$												



**ACTUAL UNIT PERFORMANCE DATA**

**GULF POWER COMPANY**

**PERIOD OF: January 2008 - December 2008**

DANIEL 2	Jan '08	Feb '08	Mar '08	Apr '08	May '08	Jun '08	Jul '08	Aug '08	Sep '08	Oct '08	Nov '08	Dec '08	Total
1. EAF (%)	63.9	98.9	66.7	85.6	88.8	99.6	99.9	98.4	99.4	87.0	0.0		
2. PH	744.0	696.0	743.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	721.0		
3. SH	480.6	696.0	497.8	619.6	669.1	720.0	744.0	737.2	720.0	405.9	0.0		
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.9	0.0	242.1	0.0		
5. UH	263.4	0.0	245.2	100.4	74.9	0.0	0.0	3.9	0.0	96.0	721.0		
6. POH	0.0	0.0	227.9	0.0	0.0	0.0	0.0	0.0	0.0	96.0	721.0		
7. FOH	234.6	0.0	0.0	0.0	0.0	0.0	0.0	3.9	0.0	0.0	0.0		
8. MOH	28.8	0.0	17.3	100.4	74.9	0.0	0.0	0.0	0.0	0.0	0.0		
9. PFOH	28.8	14.2	5.0	12.9	17.2	3.5	2.9	30.2	23.3	6.3	0.0		
10. LR pf (MW)	53.7	150.5	178.8	62.7	87.3	48.2	68.7	138.2	97.9	84.0	0.0		
11. PMOH	3.5	6.8	9.9	23.7	8.8	3.7	0.0	0.0	0.0	0.0	0.0		
12. LR pm (MW)	342.8	270.0	40.8	34.0	301.0	370.0	0.0	0.0	0.0	0.0	0.0		
13. NSC (MW)	507.0	507.0	507.0	507.0	507.0	507.0	507.0	507.0	507.0	507.0	507.0		
14. Oper MBtu	2249958.0	3150307.0	2359958.0	2954737.0	3195381.0	3488145.0	3558221.0	3493831.0	3406947.0	1804238.0	0.0		
15. Net Gen (MWH)	230517.0	330839.0	240149.0	300596.0	316558.0	351337.0	358131.0	345094.0	342434.0	181766.0	0.0		
16. ANOHR (Btu/KWH)	9760.0	9522.0	9827.0	9830.0	10094.0	9928.0	9936.0	10124.0	9949.0	9926.0	0.0		
17. NOF %	94.6	93.8	95.2	95.7	93.3	96.2	94.9	92.3	93.8	88.3	0.0		
18. NPC (MW)	507.0	507.0	507.0	507.0	507.0	507.0	507.0	507.0	507.0	507.0	507.0		
19. ANOHR Equation	$10^6 / AKW * [ 398.00 - 123.89 * MAR - 108.06 * MAY - 96.34 * SEP ] + 9,262$												

















