

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

In re: Petition for rate increase by
Progress Energy Florida, Inc.

Docket No. 090079-EI

Submitted for filing:
March 20, 2009

**DIRECT TESTIMONY OF
DAVID SORRICK**

On behalf of Progress Energy Florida

DOCUMENT NUMBER-DATE

02417 MAR 20 8

FPSC-COMMISSION CLERK

DIRECT TESTIMONY OF
DAVID SORRICK

1 **I. Introduction.**

2 **Q. Please state your name and business address.**

3 A. My name is David Sorrick. My business address is 299 First Avenue North, St.
4 Petersburg, Florida 33701.

5
6 **Q. By whom are you employed and in what capacity?**

7 A. I am employed by Progress Energy Florida in the capacity of Vice President Power
8 Generation – Florida (“PGF”).

9
10 **Q. What are the duties and responsibilities of your position with PEF?**

11 A. As Vice President of PEF’s Power Generation organization, my responsibilities
12 include overall leadership and strategic direction of PEF’s power generation fleet
13 including 18 steam units and 46 simple cycle CT units which employ over 700
14 people and provide more than 9,400 nominal MW of total winter generation for PEF
15 customers.

16 In this position, it is part of my responsibility to develop and implement
17 strategic and tactical plans to operate and maintain the generation fleet, recommend
18 major modifications and additions to the fleet, and recommend retirement of
19 generation facilities. I am also responsible for budget allocation decisions that
20 determine funding levels within the fleet utilizing the allocated budget for PGF. My
21 duties further include workforce planning and staffing, major maintenance programs

1 strategy and implementations, outage and project management, and support services
2 for the fleet. My responsibilities also include organizational alignment and design.
3 This includes the review and analysis of the organizational structure within PGF and
4 making the appropriate changes to optimize the organization. I am also responsible
5 for the conduct of continuous business improvement within PGF. These efforts are
6 focused on the review of current business processes and making appropriate changes
7 to them in an effort to make the organization function more efficient. I am also
8 engaged in efforts to attract, hire and retain employees across PGF.

9
10 **Q. Please describe your educational background and professional experience.**

11 A. I earned a Bachelor of Science degree in Engineering from the University of
12 Tennessee at Chattanooga in 1986 and an MBA from University of South Florida in
13 2006. I am also a Registered Professional Engineer and Licensed Electrical
14 Contractor (inactive) in the state of Florida.

15 I have over 20 years of power plant and production experience in various
16 engineering, supervisory, managerial and executive positions at Progress Energy
17 managing Combustion Turbine (CT) Operations, Fossil Steam Operations, and CT
18 Services as well as new plant construction. While at Progress Energy, I have
19 managed new unit construction, start-up, and commissioning of major combustion
20 turbine installations and retrofits at our Intercession City and Debary sites. In
21 addition, I have managed new unit projects from construction to operations and I
22 have extensive contract negotiation and management experience with Progress
23 Energy and General Electric. I also have extensive bargaining unit management and

1 negotiation experience. My prior experience also includes nuclear engineering
2 positions at Tennessee Valley Authority and project management experience with
3 General Electric.
4

5 **II. Purpose and Summary of Testimony.**

6 **Q. What is the purpose of your direct testimony?**

7 A. I appear on behalf of PEF to support the reasonableness of its power operation costs
8 reflected in the Company's Minimum Filing Requirements ("MFRs").
9

10 **Q. Have you prepared any exhibits to your testimony?**

11 A. Yes, I have prepared or supervised the preparation of the following exhibits to my
12 direct testimony:

- 13 • Exhibit No. __ (DS-1), a list of the MFR schedules I sponsor or co-sponsor; and
- 14 • Exhibit No. __ (DS-2), Tables: Power Plant Performance – Combined Cycle ("CC")
15 Equivalent Availability Factor, Fossil Equivalent Availability Rates, CC Equivalent
16 Forced Outage Rate, Fossil Equivalent Forced Outage Rates and Simple Cycle
17 Starting Reliability.

18 In addition, I am co-sponsoring a portion of the Fossil Dismantlement Cost Study
19 attached as an exhibit to Peter Toomey's testimony, specifically Section 7 of that
20 study. These exhibits, and the portion of the Fossil Dismantlement Cost Study that I
21 sponsor, are true and accurate.
22

1 **Q. Do you sponsor any schedules of the Company's Minimum Filing**
2 **Requirements (MFRs)?**

3 A. I sponsor or co-sponsor the MFR schedules listed on Exhibit No. ____ (DS-1). These
4 schedules are true and correct, subject to their being updated in the course of this
5 proceeding.

6
7 **Q. Please summarize your testimony.**

8 A. The Power Generation organization's mission is to provide safe, environmentally
9 responsible, reliable, and competitively priced power to our customers.

10 PEF's capital (\$134 million) and O&M (\$175 million) expenditures for power
11 plant generation support Progress Energy's "Balanced Solution" initiative. PEF is
12 committed to maintaining the existing generation fleet by making investments in
13 these plants to ensure they run efficiently while meeting the highest standards of
14 safety and environmental stewardship. PEF is also committed to pursuing options
15 for building new, state-of-the-art plants, such as the new Bartow Combined Cycle
16 units, while at the same time delivering superior performance from our existing
17 fleet. Because power plants take many years to plan and build, PEF is engaged in
18 careful planning and prudent investment today to make sure we are ready for the
19 future. PEF's long term strategy is designed to deliver reliable, affordable power
20 with less dependence on foreign fuel and for a cleaner environment. The Bartow
21 Repowering project is an example of successfully fulfilling this strategic objective.
22 PEF is further committed to provide the infrastructure necessary to minimize power
23 outages and to ensure that our power plants are reliable. PEF's generation fleet in

1 Florida continues to operate at high levels of performance while integrating new
2 fleet additions, like the Hines 3 and Hines 4 Power Blocks, and minimizing
3 production costs. This performance is made possible through the implementation of
4 effective maintenance and human performance programs that facilitate the
5 prioritization of work activities. These programs are aimed at optimizing planned
6 outage activities and minimizing unplanned outages and will be further discussed
7 later in my testimony.

8 PEF has provided and continues to provide, superior performance from its
9 generation fleet while balancing costs with the multiple challenges and requirements
10 facing the Power Generation Florida (PGF) organization. PGF's capital and O&M
11 revenue requirements are reasonable and prudent, and should be approved.

12
13 **III. PEF's Generation Fleet.**

14 **Q. Please describe PEF's generation fleet.**

15 A. PEF's generation fleet consists of 12 fossil steam units, 5 combined cycle units (not
16 including the new Bartow units), 1 cogeneration unit and 46 simple cycle
17 combustion turbine units. PEF's generation fleet can produce approximately 9,400
18 megawatts of power. The fleet provides safe and reliable power to PEF's customers
19 365 days a year.

20
21 **Q. Has PEF added additional megawatts since January 1, 2005?**

22 A. Since 2005, PEF has continued to grow its generation fleet in order to meet
23 increasing demand. In response to this increase in load, PEF added Hines Power

1 Block 3 (PB3), a 570 MW combined cycle power block in November of 2005.

2 Moreover, in December of 2007, PEF added Hines Power Block 4 (PB4), a 517 MW
3 combined cycle power block.

4
5 **Q. Are there any other plants that will be placed in service before the test year?**

6 A. Yes. PEF is scheduled to bring the Bartow Combined Cycle plant on line by June 1,
7 2009. This state of the art plant is a repowering project that will replace the existing
8 Bartow Steam plant, which consists of three heavy oil units which came on-line
9 between 1958 and 1963. The new Bartow Combined Cycle facility consists of four
10 combustion turbines (CTs) and four heat recovery steam generators (HRSGs)
11 feeding one steam turbine -- a 4x4x1 configuration -- capable of producing a
12 combined approximate 1,279 MW, or an increase of approximately 827 MW over
13 the existing site capacity. The project design includes auxiliary duct firing for the
14 HRSGs, steam power augmentation for the CTs, by-pass stack dampers on the CTs
15 and ultra-low NOx burners and state of the art pollution control equipment. These
16 design features provide maximum output and system dispatch flexibility. PEF has
17 entered into a contract with Gulfstream Natural Gas System for the firm pipeline
18 transportation needed to support operation of the plant. The transmission and
19 substation improvements needed to integrate the repowered plant into the electric
20 grid and handle the increased MW output will also be in-service by June 1, 2009.
21 The total capital cost of the project, including generation, transmission, and
22 AFUDC, is \$800.2 million.

23

1 **Q. What are the benefits of the Bartow repowering project?**

2 A. The analysis performed at the study phase in 2005 and 2006 showed that repowering
3 the Bartow plant was the most cost-effective option to provide additional capacity
4 by summer 2009 in order to meet PEF's 20 percent minimum reserve margin
5 obligation. Based on that analysis, the repowering provides \$171 million net present
6 value (NPV) of after-tax cash flow savings and avoids the need for a capacity
7 purchase in the summer of 2009, the Hines 5 combined cycle unit, and CTs
8 originally planned for 2010 and 2012. Other benefits of the project include: reduced
9 plant start-up time and increased dispatch flexibility; its location near the Pinellas
10 County load center reduces loading on existing transmission used for importing
11 power into the area; the project reduces site emissions, including a 98% reduction in
12 SO₂ and reduced levels of NO_x, enabling PEF to meet CAIR requirements without
13 installing costly Selective Catalytic Reduction equipment at the Anclote Plant; and it
14 allows the Company to take advantage of existing site assets and further avoids the
15 need to develop a new site in the area.

16
17 **Q. Does the addition of generation units to PEF's system increase PEF's**
18 **generation fleet capital and operation and maintenance costs?**

19 A. Yes. Fleet growth has been and continues to be a significant cost driver for the
20 Company. Fleet growth drives cost increases in two distinct ways: 1) through plant
21 base budget increases; and 2) through major maintenance budget increases. When a
22 new unit has been added to the fleet, costs associated with staffing the plant to
23 perform routine operations and maintenance of the plant is covered by the plant's

1 base budget increase. The types of incremental costs being incurred include labor,
2 materials, and permit fees among other costs. As new equipment is added to the
3 fleet and begins operations, maintenance is required to keep the equipment in good
4 repair. The frequency and cost of this major maintenance depends upon the type of
5 equipment and how it is operated. Examples of major maintenance work include:
6 combustion turbine combustion inspections, hot gas path inspections, and major
7 inspections. This work also includes steam turbine outages, generator outages, and
8 boiler outages.

9
10 **Q. What does it take to operate and maintain PEF's generation fleet?**

11 A. The operation and maintenance of PEF's generation fleet requires substantial
12 human and financial resources. PGF employs over 700 employees to operate and
13 maintain the fleet. These employees have a wide range of diverse skills and
14 experience sets. These include managers, engineers, technical specialists, craft
15 employees, finance professionals, safety professionals and administrative staff. It
16 takes each of these employees performing their job duties well in order to operate
17 and maintain the fleet in the most cost effective manner possible.

18 The operation and maintenance of the fleet also requires substantial O&M and
19 capital funding. This funding can be divided into two primary categories of work: 1)
20 base budgets and 2) outage & project budgets. The base budgets include funding for
21 all of the routine activities for each plant and the support of centralized groups for
22 each plant. Examples of base budget items include base labor, tools, materials
23 required for routine activities, plant environmental permits, basic utility services and

1 other such costs. The outage and project budgets include all major maintenance
2 activities and non-routine projects that improve unit operating reliability or
3 efficiency. Examples include combustion turbine major maintenance, steam turbine
4 outage work, generator major maintenance work, minor construction projects and
5 other projects of this type.

6
7 **Q. What is PGF's maintenance philosophy?**

8 A. By their very nature, electrical and mechanical equipment require periodic
9 maintenance in order to maintain their reliability, efficiency and usefulness. The
10 bulk of the generation-producing equipment is no different. Just as an automobile
11 requires varying degrees of maintenance at different intervals, combustion turbines,
12 steam turbines, boilers, generators and other significant pieces of equipment require
13 different inspections, repairs, refurbishments and replacement of components on
14 periodic intervals. PGF weighs several factors in the scheduling and execution of our
15 major maintenance program.

16 First among these is the "tiering" strategy of our generation assets. Each unit is
17 classified by fuel cost, unit efficiency (heat rate), size of output, impact to the
18 transmission system reliability and strategic importance to determine the unit's tier.
19 There are 3 total tiers. Tier 1 primarily consists of base loaded units; tier 2 is
20 primarily comprised of intermediate and gas-fired simple cycle combustion turbine
21 units, while tier 3 units are more typically simple cycle CT units utilizing fuel oil.

22 Second, the manufacturer's recommended maintenance intervals are used as a
23 guideline when planning the major maintenance expenditures of the department.

1
2 There are three distinct maintenance intervals for a combustion turbine. Each of
3 these intervals is driven by actual unit performance (unit starts or actual hours
4 operated). In order of increasing expense, they are:

- 5 1. Combustion Inspection - this is the major maintenance activity performed on
6 the combustion components of the unit (burners, transition pieces, combustion
7 liners, etc.). This is the most frequent maintenance performed.
- 8 2. Hot Gas Path Inspection – this is the maintenance activity that includes all
9 elements of the combustion inspection work scope plus activities performed on
10 the power turbine components of the unit (blades, vanes, diaphragms, etc.).
- 11 3. Major Inspection – this is the maintenance activity that includes all elements of
12 the combustion inspection, hot gas path inspection, plus activities performed
13 on the compressor section of the unit.

14 The steam turbine fleet also has two major maintenance cycles based on
15 periodicity and the operational profile. The first is Turbine Valve Outage, which
16 typically occurs every three years and includes major maintenance activities on the
17 turbine control valves, main and reheat steam valves. The other maintenance cycle
18 is Major Turbine Outage, which typically occurs every 9-12 years depending on the
19 unit type. It includes the activity performed during the turbine valve outages plus the
20 disassembly of the turbine for inspection and repairs of the internal components.

21 The steam boilers, generators and other plant equipment also have periodic
22 maintenance requirements that have recommended maintenance intervals associated
23 with them.

1 Third, a system operating forecast is utilized to estimate unit operational hours
2 and unit starts. This data allows comparisons between a given unit's expected
3 operational parameters and that unit's position in the maintenance schedule.

4 The actual material condition of the equipment is also taken into consideration.
5 This condition assessment is made by inspections, operating data analysis, past
6 equipment history, predictive maintenance techniques (specifically oil analysis,
7 vibration and thermography) and industry knowledge.

8 Finally, all of the information above is compiled and analyzed in an effort to
9 identify and prioritize maintenance requirements for any given unit in any given
10 year for business planning purposes. These maintenance requirements are then
11 prioritized with other projects in the given year the maintenance is required. Funding
12 decisions are made based upon budget targets assuming the methodology explained
13 above.

14
15 **IV. Power Operations Performance.**

16 **Q. Please explain the operating performance of PEF's generation fleet.**

17 A. All segments of PEF's steam fleet have performed well since 2005. The fleet's
18 Equivalent Availability ("EA") rates have compared favorably to the industry and
19 have generally exceeded the NERC average EA rates for coal, oil, and combined
20 cycle units. The EA metric is a measure of a unit's availability over the course of a
21 year. Higher EA rates compared to industry averages, which is the case for PEF's
22 coal, oil, and gas-fired combined cycle units, indicates PGF generation is typically
23 available when needed to meet increasing customer demand. As a result, PEF's

1 generation fleet can be efficiently committed to meet load, therefore, providing
2 customers with an optimized fuel cost. See pages 4 and 5 of Exhibit No. __ (DS-2).

3 The PEF fleet has also outperformed the NERC average with respect to
4 Equivalent Forced Outage Rates (“EFOR”) over the same time period. EFOR is an
5 industry measurement of how often a unit is off-line due to an unexpected or forced
6 condition. The lower the EFOR, the higher percentage of time the unit is available.
7 This availability allows PEF to again optimize its unit dispatch to meet load and
8 subsequently minimizes fuel cost impacts to the customer. In particular, the
9 combined cycle fleet outperformed the industry average EFOR by almost 4.5%. See
10 page 3 of Exhibit No. __ (DS-2). The coal & oil fleet also outperformed the
11 industry by achieving a combined EFOR that was less than half the industry average
12 for similar type units. See page 2 of Exhibit No. __ (DS-2). These results are
13 indicative of an effective major maintenance program.

14 PEF’s simple cycle fleet has demonstrated extremely high levels of starting
15 reliability since 2005. In fact, starting reliability levels have exceeded 99.5% over
16 the last 4 years. See page 1 of Exhibit No. __ (DS-2). Between 2005 and 2007, the
17 fleet was called upon to start an average of over 5,200 times per year. PGF has
18 maintained this starting reliability performance across the entire fleet even though
19 the average age of the fleet is over 29 years old. This performance is indicative of an
20 effective preventive maintenance program at each plant. For example, regular
21 proactive maintenance performed on plant instrumentation, pumps, motors, etc. will
22 allow the plant maintenance staff to discover and correct problems before the units

1 are committed for system needs. These actions will make the units more likely to
2 start successfully when called upon.

3
4 **Q. How do PEF's customers benefit from this positive operating performance?**

5 A. Positive fleet operating performance enables PEF to minimize fuel cost. These fuel
6 cost savings are realized by ensuring that units with the lowest average fuel cost are
7 available to meet customer demand. Otherwise, units with higher average fuel costs
8 must be committed or potentially higher priced purchased power scheduled to meet
9 demand which, in turn, increases the customers' overall fuel bill. Therefore, the
10 reliability of the generating units with lower average fuel costs is very important to
11 minimizing fuel costs to our customers. Moreover, unit reliability increases the
12 probability that generation is available during times of lower customer demand to
13 enter the off-system sales market and further offset customer fuel costs.

14 Increased levels of operating performance also enhance system reliability by
15 providing PEF's Energy Control Center ("ECC") more reliable generation
16 alternatives to address system contingencies. In day-to-day operation of the
17 interconnected system, ECC is tasked with ensuring that grid instability will not
18 occur as a result of the loss of a transmission element or generator. Increased unit
19 reliability reduces the number of contingencies a transmission operator must
20 mitigate. In addition, the loss of a transmission element can result in the overload of
21 subsequent transmission lines. In such situations, generation units can be brought on
22 to relieve adverse line loading. Failure of a unit to respond when called upon may

1 result in a requirement for the ECC to initiate more drastic measures (e.g. load
2 reduction).

3
4 **Q. How has PEF achieved its positive operating performance?**

5 A. PEF focuses on operational efficiencies and performance improvements in order to
6 maximize the benefits from its generation fleet. PEF invested substantial dollars
7 since 2005 targeting projects and work that improved unit flexibility, increased unit
8 capacity, and increased unit reliability. Examples of these projects and work
9 include:

- 10 • Fleet Major Maintenance Program. PGF's major maintenance program is designed
11 to enhance the fleet's reliability through the proactive performance of major
12 maintenance activities. Each unit in the fleet has regularly scheduled major
13 maintenance requirements based on the amount of operating hours, number of unit
14 starts, condition assessment of the equipment, or other operational parameters. The
15 majority of the PGF annual project budget is spent on major maintenance activities.
16 The PGF major maintenance program is designed to invest O&M and capital dollars
17 to optimize the fleet. For example, we have a process in which an entire set of
18 operating parts is replaced during an outage with a set of spares. The unit is returned
19 to service and the set of parts removed from the unit are sent for repair. This
20 facilitates less outage time and more operating availability. These parts repairs
21 extend the beneficial use of most unit parts over several cycles of unit operation,
22 thus prolonging their useful life.

- 1 • Hines Power Block 4 Combustion Optimization Package. This project, completed
2 in 2007, increased the capacity of the Hines Power Block 4 by 14 MW. Installation
3 of the combustion optimization package also allows PGF to monitor combustion
4 dynamics for gas turbines in order to lower combustion part wear. PGF expects this
5 monitoring capability to reduce future parts' repair costs.
- 6 • Crystal River 2 Boiler Pressure Parts Replacement. In the spring of 2007, Boiler
7 Pressure Parts replacement work at Crystal River Unit 2 was performed in order to
8 reduce unplanned outage time due to tube leaks. As a result of the CR2 replacement
9 project, EFOR has improved from a rate of 6.45% in 2006 to 5.55% in 2007 and
10 2.78% in 2008. The improved EFOR for CR2 means greater unit availability when
11 it is most economical to dispatch CR2 to meet load, thus, minimizing customer fuel
12 costs.
- 13 • Hines Low Load Carbon Monoxide (LLCO) Modification. In 2008, PGF
14 negotiated and executed gas turbine mechanical retrofits and control changes on
15 Hines Power Block 2 in order to allow lower load operation at Hines which prevents
16 having to cycle off units or reduce load on less expensive units. The modification is
17 expected to decrease fuel costs for the fleet in 2009 and beyond.
- 18 • Tiger Bay Combustion Turbine Rotor Replacement. The original rotor for this unit
19 was nearing end of life due to design limitations. This rotor was replaced in 2008
20 with a rotor of improved design which increased capacity of the power block by 9
21 MW. This work means this unit provides even more power at a more efficient fuel
22 cost to meet customer load.

- 1 • Hines Gas Blending Station. In 2007, PEF installed a state of the art gas blending
2 station at the Hines Energy Complex to allow blending of gas supplies between FGT
3 and Gulfstream. This allows flexibility to achieve fuel savings and increases the
4 reliability of plant capacity to meet load in the event one source of gas supply is
5 interrupted.
- 6 • Aeroderivative Modular Maintenance. PEF purchased several spare engine modules
7 in 2005 to minimize downtime during engine overhauls. As a result of this strategy,
8 PGF has increased aeroderivative fleet availability. This strategy has allowed PGF to
9 utilize modules from different engines to expedite the units' return to service from
10 scheduled outages. PGF's aeroderivative fleet is primarily used to provide fast
11 start/black start capabilities to the PEF system. These units are versatile and provide
12 significant system reliability benefits. Specifically, these units represent the primary
13 mitigation measure for responding to interruptions on the system, such as the loss of
14 a transmission line or the loss of a generating unit. Because they can be started so
15 quickly, they provide needed generation when such events occur.
- 16 • Anclote 2 Major Turbine Outage. In 2006, PEF replaced the low pressure feed
17 water heaters, one row of turbine blades, and the high and intermediate pressure
18 packing strips at Anclote 2. These replacements improved turbine efficiency.
19 Installation of a debris filter system also improved condenser cleanliness resulting in
20 improved turbine efficiency. These efficiency improvements resulted in lower costs
21 for Anclote 2 for each hour of operation.
- 22 • Anclote Cooling Towers. The concrete cooling towers at the Anclote facility were
23 replaced with corrosion resistant fiberglass structures which reduce the amount of

1 chloride attack from the salt water environment they are in. This reduces
2 maintenance requirements and thus reduces future maintenance costs.

- 3 • Anclote Fuel Flexibility. At Anclote units 1 and 2, modifications to the bottom ash
4 hoppers of the boilers and changes to the operational procedures now enable the
5 plant to burn a combination of No. 6 oil and natural gas. This modification can
6 reduce fuel costs for running the plant, and provides additional flexibility when
7 choosing fuels.

8 Many of these projects are on-going and will continue to yield unit
9 performance benefits for customers in 2010 and beyond.

10
11 **Q. Has the Company undertaken any other initiatives to improve the operating
12 performance of its generation fleet?**

13 A. Yes. In addition to major projects, PGF has invested in several initiatives and
14 programs that are aimed at improving fleet equipment performance and/or
15 workforce performance. Some of these include:

- 16 • Operations Excellence Program. The purpose of the Operations Excellence
17 Program (“OEP”) is to develop and maintain a highly skilled operational workforce.
18 The OEP is an effort to rapidly develop qualified employees while preserving and
19 disseminating the experiential knowledge of our current experienced employees.
- 20 • Simulators. PEF utilizes simulators in the execution of the OEP. Simulators that
21 replicate facility operation provide continuing training for existing operating
22 personnel. Infrequently performed tasks can be practiced, thus increasing skills and
23 reducing potential errors. The simulators also can be used for troubleshooting actual

1 unit controls utilizing “what if” scenarios and locating logic and control problems in
2 the actual plant system they simulate. Finally, simulators can be used to verify
3 procedure and plant modification changes.

- 4 • Automated Training Manager (“ATM”). The ATM module is a web-based learning
5 management system that provides web-based training, electronic skill signoffs,
6 progression tracking, trainee profiles, and supervisor mentoring functions. The
7 ATM allows users to self-enroll in selected technical or required regulatory courses.
8 It also allows supervisors to assign site-specific qualification criteria and course
9 materials to their direct reports. ATM also provides administrative tools for
10 reporting and tracking opportunities to monitor an employee’s progress in their
11 training assignments.
- 12 • Human Performance Improvement. The Human Performance Improvement
13 Program (“HPI”) efforts involve error reduction training at all levels in the
14 organization. The primary goal of the program is to eliminate those errors that result
15 in Significant Human Performance Events, which are defined as any event resulting
16 from human error that results in any of the following events: (1) an OSHA
17 recordable or lost time injury; (2) asset damage in excess of \$25,000; (3) significant
18 environmental impact; (4) significant loss of power generation capability; or (5) an
19 event deemed by management to be significant by virtue of the value of lessons
20 learned. Since the inception of the HPI program in 2001, the number of human
21 performance events has declined considerably. For example, from 2003 to 2008
22 PGF reduced significant events from 153 to 26 resulting in an 83 percent reduction.

1 This program has allowed PGF to improve in the areas of safety and operational
2 performance.

- 3 • Apprentice Program. The Apprentice Program provides structured training to
4 increase the capabilities of new craft employees entering the work force. The
5 program includes the following positions: Operators, Mechanics, Electricians,
6 Instrumentation and Control Technicians, Laboratory Technicians, and Combustion
7 Turbine Maintenance Operators. The program provides final assessment of
8 qualification levels for apprentices to become Journeymen and provides a cost
9 effective mechanism for training new employees to equip them with the skills and
10 knowledge needed in today's workforce.

11 These are on-going initiatives and programs that continue in 2010 and beyond
12 to provide efficient workforce performance for the ultimate benefits of customers
13 through lower capital and O&M costs.

14
15 **Q. Please describe any PEF Power Generation organizational changes and**
16 **associated benefits since 2005.**

- 17 A. Over the past three years, PEF's Power Generation Group has re-aligned resources
18 in order to more effectively operate and maintain the fleet of assets. In 2006 PEF
19 implemented the Crystal River Maintenance Organization ("CRMO"). CRMO's
20 purpose is to coordinate and perform maintenance activities across the Crystal River
21 Fossil site. These activities include normal preventative maintenance, corrective
22 maintenance, and equipment outage response. This realignment has resulted in

1 efficiency gains, enhanced forced outage response which minimizes impacts to
2 EFOR, and overtime savings. The overtime savings alone have been estimated at
3 nearly \$1 million. This money has been reinvested into additional maintenance
4 activities.

5 In addition to the organizational changes made at Crystal River, PGF executed
6 a consolidation strategy starting in 2007 focused on integrating fossil and CT
7 operations organizations. The results of this integration to date include the
8 elimination of four plant manager positions as well as two service manager
9 positions. These consolidations were accomplished by using attrition and
10 redeploying resources to other areas of the Company.

11
12 **Q. Has the Power Generation group been able to sustain a good safety record**
13 **while improving performance?**

14 A. Yes. At PEF, safety is the highest priority in every task we perform and is an
15 integral part of our decision making process. PEF is committed to a healthy and
16 injury-free workplace. PGF is also committed to the safety of our employees,
17 families, customers, contractors, visitors and the communities in which we operate.
18 In 2005, PGF incurred five OSHA recordable injuries which was Top Quartile
19 Performance for EEI utilities. In 2006, twelve workplace injuries occurred. As a
20 result of this increase, the Company did not achieve top quartile performance for
21 2006. Therefore, Progress Energy took action and launched a "Zero in on Safety"
22 Campaign that focuses on eliminating accidents and injuries from the work place.
23 The campaign focuses on personal accountability, job hazard recognition and

1 mitigation, and active caring and peer coaching. Furthermore, the campaign
2 emphasizes that whatever the nature of the work, the first and most important
3 outcome is that employees sustain zero injuries in the preparation and completion of
4 their tasks. Subsequently, workplace injuries in 2007 declined to nine. This
5 performance represented a return to top quartile. In 2008, PGF again improved
6 safety performance by reducing the number of workplace injuries to seven. PGF's
7 goal is zero accidents in the work place and we will continue to work toward that
8 goal.

9
10 **Q. Please explain PGF's approach to environmental performance.**

11 A. PGF takes its environmental responsibilities very seriously. PGF measures and
12 tracks environmental performance through a mechanism called the PGF
13 Environmental Index ("EI"). This metric is comprised of performance standards
14 representing compliance to air and water permit compliance, and total waste
15 generation. For example, exceedances on real time air emission limits, any amount
16 of oil spilled in state waters or generation of hazardous waste all adversely impact
17 the index. PGF's overall performance with respect to the EI has exceeded targets
18 since 2005. The environmental index measures performance on a scale from 1.0 to
19 5.0 with 5.0 being the highest level. A rating of 4.0 is defined as good and a rating
20 of 5.0 is defined as outstanding and should only be reached by achieving stretch
21 goals and demonstrating high levels of environmental performance in all areas. PGF
22 has consistently exceeded the goal of 4.0. Over the last 3 years, PGF's performance
23 against the index has averaged 4.63. This indicates a strong commitment to

1 environmental stewardship by consistently adhering to permit conditions and, in
2 many cases, performing better than permitted requirements. Compliance and good
3 stewardship are the cornerstones of our environmental programs.
4

5 **Q. Has the Company efficiently managed its costs in achieving the positive**
6 **operating performance of its generating fleet?**

7 A. Yes. Since 2006, PEF has invested nearly \$220 million in capital improvements to
8 our fossil steam, CT and CC plants. The majority of these capital improvements
9 include major maintenance on gas turbines, steam turbines, boilers, generators and
10 other balance of plant equipment. In addition to maintenance capital, investment has
11 also been made in unit uprates and fuel flexibility modifications. Specific projects
12 include replacement of the Anclote Cooling Towers, multiple pressure parts
13 replacements in several fossil plant boilers, condenser replacement projects, Crystal
14 River coal yard improvements, as well as turbine parts replacements and
15 refurbishments. By choosing those projects that deliver the most benefits in terms of
16 unit reliability, fuel savings, and increased efficiencies, the Company has made the
17 most of its capital and O&M dollars for the generation fleet.
18

19 **V. Major Maintenance Outages.**

20 **Q. Please describe PEF's planned outages since 2005.**

21 A. Planned maintenance outages are performed to address known equipment issues in
22 an effort to increase unit availability and reliability and/or to reestablish unit
23 capabilities. Since January 2005, a total of 120 planned outages greater than one

1 week in duration have been performed across the PGF fleet. These outages were
2 performed on a wide range of equipment including steam turbines, combustion
3 turbine engines, generators, boilers, heat recovery steam generators, and
4 miscellaneous balance of plant equipment. PGF utilizes a maintenance planning
5 procedure using actual equipment condition, unit operational missions, and original
6 equipment manufacturer (“OEM”) recommendations regarding maintenance
7 intervals. PGF seeks to execute planned outages in the most cost effective manner
8 possible.

9
10 **Q. Have any unplanned outages occurred since 2005?**

11 A. Yes, unfortunately unplanned outages are bound to happen because of the number,
12 type, and vintage of the generation fleet that PGF operates. The effectiveness of
13 avoiding unplanned outages, however, is measured by EFOR. PGF has
14 outperformed the NERC average with respect to EFOR, thus, demonstrating that
15 PGF has effectively avoided and managed unplanned outages on its system. See
16 pages 2 and 3 of Exhibit No. __ (DS-2).

17 Since 2005, PGF has incurred 40 unplanned outages of one week or greater in
18 duration. Only 7 of the 40 unplanned outages occurred on a steam unit (coal, oil or
19 combined cycle). The remaining 33 unplanned outages occurred on various simple
20 cycle CT units, predominantly the older units in the fleet. This performance
21 indicates that the major maintenance planning methodology has been effective in
22 minimizing forced outages on the base load and intermediate load segments of the
23 fleet.

1 PGF's excellence in avoiding unplanned outages and managing them when
2 they cannot be avoided is demonstrated by PGF's record regarding FRCC Reserve
3 Sharing Group (RSG) reserve calls from 2005 to 2007. Typically, reserve calls are
4 initiated by RSG members upon an unplanned loss of generation in excess of 200
5 MWs. PGF represents about 25 percent of the state's generation capacity.
6 However, PEF was responsible for only about 12 percent of the FRCC reserve calls
7 from 2005 through 2007.

8 PGF will continue to work towards improving EFOR across the entire fleet by
9 proactively performing major maintenance activities. These maintenance
10 requirements continue to increase as PEF's fleet continues to grow.

11
12 **VI. Generation Fleet Revenue Requirements.**

13 **Q. What are the Company's generation capital and O&M expenditures for 2010?**

14 A. The Company needs \$134 million in capital and \$175 million for O&M expenses for
15 generation for the test year 2010.

16
17 **Q. How do the Company's O&M expenditures compare to others in the industry?**

18 A. Industry benchmarks indicate that PGF is performing extremely well as compared to
19 other generating fleets in the industry. The Non-fuel O&M dollars per MWh for the
20 Oil-fired steam and Combined Cycle fleet is in top quartile. Non-fuel O&M
21 represents the O&M costs without the costs associated with fuel. The Non-fuel
22 O&M dollars per KW for our Oil-fired Steam, Combustion Turbine and Combined
23 Cycle fleet are also well below the industry averages. This is based on the GKS

1 Gold benchmarking study that was produced in 2008 which includes 2005 through
2 2007 data.

3
4 **Q. Are the Company's O&M revenue requirements within the Commission**
5 **benchmark?**

6 A. No. Despite best efforts from the PGF management team, there is a \$53.1 million
7 variance between the costs to operate and maintain the fleet and the Commission
8 benchmark target amount. There are various reasons why the generation revenue
9 requirements are above the benchmark amount. One reason is that labor and
10 material escalations have increased the costs to perform unit operations and
11 maintenance, but the work must be done despite these increasing costs. To
12 illustrate, approximately \$7.3 million of additional employees, flyash disposal costs,
13 and maintenance work associated with boiler waterwall replacements, boiler
14 circulating pumps, circulating water pump system repairs, generator stator rewedge,
15 and other boiler repair work in the pendant reheat section of these units must be
16 completed despite increasing costs to ensure the continued efficient operation of
17 these base load units. Simply put, additional O&M expenditures are necessary to
18 perform essential routine and major maintenance activities.

19 Fully 85 percent of the \$53.1 million variance in PEF's O&M costs from the
20 benchmark target cost, however, is attributable to O&M requirements that have
21 nothing to do with the mere escalation in costs over time that the benchmark test
22 using the Consumer Price Index (CPI) captures and measures PEF's costs against.
23 These are (1) additional maintenance requirements for fleet growth from new

1 generation of \$21.3 million with an offsetting retirement of a unit (\$7.2 million), (2)
2 additional, combined outage projects of \$15.1 million, (3) incremental security costs
3 of \$1.9 million, and (4) major maintenance and other miscellaneous cost increases of
4 \$14.7 million for the CC and CT fleet driven by the unique mechanical and
5 operational characteristics of these units.

6 More specifically, the new generation portion of the variance is due to the
7 addition of two power blocks at the Hines Energy Complex (“HEC”), as well as the
8 addition of the Bartow Combined Cycle plant. These units were not online in 2006,
9 which is the base year against which the Commission benchmark is measured, and,
10 therefore, the O&M costs associated with these additional generation units are fairly
11 outside the scope of the costs the benchmark test is intended to address.

12 To illustrate, the additional Hines power blocks require higher staffing levels
13 and an increase in maintenance projects outlays, resulting in an increase of
14 approximately \$10.1 million. In addition, with the Bartow Combined Cycle plant
15 coming online in June 2009, there will be higher staffing and maintenance needs for
16 2010, the unit’s first full year of operation. This represents an additional \$6.6
17 million of costs over 2006 benchmark levels. The first scheduled outage for Bartow
18 will take place in 2010, pursuant to the Bartow Long-Term Service Agreement
19 (“LTSA”). The LTSA benefits PEF by providing more protection for key
20 components and less financial exposure to unexpected events that would otherwise
21 result in additional costs to the Company. The maintenance work in 2010 under the
22 LTSA is estimated at \$4.6 million. Finally, because the Bartow Steam facility will
23 be retired in 2009, the Company will save approximately \$7.2 million due to

1 reduced staffing. The net impact represents \$21.3 million of the benchmark
2 variance.

3 Another major driver of the variance is additional, combined outage projects.
4 PEF will be adding major Clean Air equipment, Flue Gas Desulfurization Systems
5 (“FGD”) and Selective Catalytic Reduction (“SCRs”), to Crystal River Unit 4 during
6 an extended outage in the Spring of 2010. To take advantage of this lengthy outage,
7 PEF has scheduled the Unit 4 major boiler and turbine maintenance outages during
8 the same outage. PEF would normally schedule these maintenance outages in the
9 normal course of its operations but PEF decided to accelerate them to capture
10 synergies in outage costs with the outage for the FGD and SCR work as well as
11 minimize lost generation by doing the work while the plant is already down. This
12 represents a significant cost savings to customers in replacement fuel costs, because
13 additional future outages will be reduced in scope and duration, and the
14 corresponding replacement of generation with higher average costs during those
15 future outages will be reduced or avoided. To achieve these efficiency and potential
16 fuel savings benefits, however, the combined outage work must be done in 2010
17 with the resulting \$15.1 million variance from the benchmark.

18 Additionally, \$1.9 million of the variance is attributed to incremental security
19 costs, which were previously recovered through the Capacity Cost Recovery clause
20 in the year incurred. These costs are now included in base rates for 2010.

21 The final driver of the O&M variance is associated with maintenance of PEF’s
22 CT and CC units in its existing fleet. Approximately \$14.7 million of the variance is
23 the result of various maintenance projects for these units. Specifically,

1 approximately \$4.7 million is estimated for major maintenance projects at various
2 CT plants, including: rotor inspections and rotor out work for the various Debarry,
3 Rio Pinar, and Turner units; combustion inspections for Debarry Units 2 to 5; hot gas
4 path inspections for Debarry units 7 and 9; and a major inspection for Turner unit 3.
5 The Hines Energy Complex and Tiger Bay units have approximately \$4.7 million
6 worth of projects associated with Hines Power Blocks 1 and 2 and Tiger Bay. The
7 type of work includes the removal of the Combustion Turbine rotor, inspection and
8 repair of the combustion part, inspection and repair of the power turbine components
9 and repair work on other balance of plant components. Additionally, there is
10 approximately \$5.3 million budgeted for emerging equipment issues and parts
11 repairs. This funding would be used for forced outage repairs or to take advantage
12 of opportunities to enhance the fleet.

13
14 **Q. Do you believe the Commission O&M benchmark test accurately reflects the**
15 **Company's experience with maintenance of CT and CC generating units?**

16 A. No, I do not. For power plant O&M, as I explained previously, the Commission
17 O&M benchmark test uses the CPI to escalate costs and therefore assumes that all
18 O&M costs will increase at the same rate. This may be a reasonable assumption for
19 some O&M costs but it is not appropriate for maintenance of generating units like
20 CTs and CCs, which are impacted by how often the units are started, how long the
21 units run, and other factors regarding how the system is operated.

22 Unlike the maintenance associated with fossil steam generating units, which
23 have conventional turbines and therefore more readily anticipated maintenance

1 needs, maintenance of CT and CC units is dynamic and dependent on unit
2 operations. The combustion turbines in these units are high performance engines,
3 and their maintenance needs are heavily impacted by their usage. The fossil steam
4 plants, because they are either base load or intermediate plants, tend to run more
5 predictably and more often. Conversely, the usage rates of CTs and CCs can vary
6 dramatically. The Commission O&M benchmark test, therefore, simply does not
7 and cannot capture the dynamic nature of the ever-changing maintenance needs of
8 the CT and CC units. PEF prudently considers whether to bring these units down
9 and perform maintenance on them based on all these unique mechanical and
10 operational characteristics as well as the continued benefit to customers to continue
11 to operate the units to get the most value from them. Accordingly, the Commission
12 benchmark test is an inappropriate mechanism to evaluate the O&M costs
13 attributable to the CC and CT units in PEF's existing fleet.

14
15 **Q. Why does PEF need the capital investment and O&M expenses in generation**
16 **that it requests?**

17 A. PEF needs the capital investment and O&M expenses to reliably and efficiently
18 operate the generation equipment. For example, PEF's capital investment includes
19 approximately \$25 million to upgrade the turbines at Crystal River Unit 4 during the
20 extended outage in 2010. This upgrade will result in the production of an additional
21 14 MWs of base load capacity from an existing unit for the benefit of the
22 Company's customers. The Company further needs the requested capital and O&M
23 investment to continue the maintenance programs I described earlier that have

1 produced proven results in generation unit availability and efficiently, providing
2 customers with the continuing fuel savings benefits of a generation system that is
3 efficiently dispatched to meet their energy needs. Simply put, the capital investment
4 and O&M expenses the Company requests are needed so that we can continue to
5 efficiently and reliably operate our generating fleet.

6 Any reduction in the maintenance capital and O&M activities that we need
7 means the overall cost to the customer will increase. Undoubtedly, if the
8 Company's needs are not met, tough choices will have to be made and deferred
9 maintenance may occur. Deferred maintenance can be more expensive than planned
10 maintenance due to more extensive repair requirements on the components because
11 of longer run cycles. Deferred maintenance also reduces the flexibility of the
12 generation fleet to take advantage of the daily energy spot market in Florida which
13 can reduce the overall fuel cost to the customer by realizing off-system sales.
14 Further, forced outages may occur more frequently and forced outages are typically
15 more expensive than planned outages in terms of capital and O&M costs and higher
16 fuel costs. Proper capital investment in and maintenance of the equipment and
17 systems is essential for continued safe operations of the equipment.

18
19 **Q. Are the Company's generation capital and O&M revenue requirements**
20 **reasonable and prudent?**

21 A. Yes. PEF's long term generation strategy is designed to deliver reliable, affordable
22 power with less dependence on foreign fuel from cleaner power sources. PEF is
23 committed to provide the infrastructure necessary to minimize power outages and to

1 ensure that our power plants are reliable, efficient, and meet or exceed
2 environmental requirements. PEF has provided and will continue to provide
3 superior performance from its generation fleet while balancing costs and expenses
4 with the multiple challenges and requirements facing the Power Generation
5 organization but PEF must be provided the necessary capital and O&M resources to
6 do so.

7 PEF's generation capital and O&M revenue requirements will allow us to
8 continue to provide that superior performance and they are therefore reasonable and
9 prudent, and should be approved.

10
11 **VII, Fossil Dismantlement Cost Study**

12 **Q. Please describe PEF's Fossil Dismantlement Cost Study filed as an exhibit to**
13 **Mr. Toomey's testimony.**

14 A. PEF commissioned Burns and McDonnell to prepare a fossil dismantlement study to
15 determine the ultimate cost to dismantle and decommission the Company's fossil
16 power plant fleet. Burns and McDonnell is a nationally recognized consulting firm
17 with extensive expertise in preparing studies, such as the one commissioned by PEF.
18 A copy of the fossil dismantlement study is contained in Section 7 of Mr. Toomey's
19 Exhibit No. ___ (PT-10).

20
21 **Q. Does this conclude your direct testimony?**

22 A. Yes.
23

MINIMUM FILING REQUIREMENT SCHEDULES
Sponsored, All or in Part, by David Sorrick

<u>Schedule</u>	<u>Schedule Title</u>
B-7	Plant Balances by Account and Sub-Account
B-8	Monthly Balances Test Year – 13 Months
B-9	Depreciation Reserve Balances by Account and Sub-Account
B-10	Monthly Reserve Balances Test Year – 13 Months
B-12	Production Plant Additions
B-13	Construction Work in Progress
B-24	Leasing Arrangements
C-6	Budgeted Versus Actual Operating Income and Expenses
C-9	Five Year Analysis – Change in Cost
C-15	Industry Association Dues
C-16	Outside Professional Services
C-33	Performance Indices
C-35	Payroll & Fringe Benefit Increases Compared to CPI
C-36	Non-Fuel Operation and Maintenance Expense Compare to CPI
C-37	O&M Benchmark Comparison by Function
C-38	O&M Adjustments by Function
C-39	Benchmark Year Recoverable O&M Expenses by Function
C-41	O&M Benchmark Comparison by Function
C-43	Security Costs

Table 1: PGF Simple Cycle Starting Reliability

	2002	2003	2004	2005	2006	2007	YTD July 2008
Avon Park Plant	100.0%	100.0%	100.0%	100.0%	99.2%	99.2%	98.3%
Bartow Peaker Plant	100.0%	98.6%	99.8%	100.0%	99.8%	99.3%	100.0%
Bayboro Plant	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%
DeBary Plant	100.0%	99.3%	99.4%	99.2%	99.5%	99.7%	99.1%
Higgins Plant	98.7%	94.9%	98.4%	99.0%	100.0%	100.0%	100.0%
Intercession City Plant	99.5%	99.4%	99.5%	99.6%	99.3%	99.8%	99.4%
Rio Pinar	100.0%	98.0%	100.0%	100.0%	100.0%	100.0%	100.0%
Suwannee Peaker Plant	99.7%	99.8%	99.8%	100.0%	100.0%	99.4%	100.0%
Turner Plant	98.2%	99.1%	99.2%	99.4%	99.4%	94.6%	100.0%
PEF Simple Cycle Total	99.6%	99.2%	99.5%	99.6%	99.6%	99.5%	99.5%
NERC Average - Gas Turbine	96.8%	96.9%	97.0%	97.0%	97.9%	98.3%	NA
Difference	2.8%	2.3%	2.5%	2.6%	1.7%	1.2%	NA

Table 2: Coal and Oil-fired Steam Equivalent Forced Outage Rates					
	2004	2005	2006	2007	YTD July 2008
Crystal River 1	3.72%	3.09%	4.23%	4.77%	2.89%
Crystal River 2	3.42%	10.27%	6.45%	5.55%	3.94%
Crystal River 4	4.60%	2.63%	2.98%	1.24%	2.67%
Crystal River 5	2.05%	2.04%	3.88%	1.04%	5.76%
PEF Coal	3.39%	4.10%	4.18%	2.56%	3.96%
NERC Avg. - Coal-Fired	6.43%	6.78%	6.50%	7.33%	NA
Anclote 1	2.67%	3.19%	2.06%	2.27%	0.86%
Anclote 2	1.21%	2.58%	2.70%	0.29%	0.35%
Anclote Plant	1.99%	2.89%	2.40%	1.27%	0.60%
Bartow 1	0.24%	0.89%	4.38%	5.47%	13.00%
Bartow 2	0.41%	0.23%	1.90%	13.64%	22.59%
Bartow 3	1.57%	2.96%	9.14%	10.71%	2.37%
Bartow Plant	0.87%	1.52%	6.20%	9.89%	9.09%
Suwannee 1	1.52%	0.00%	0.35%	0.00%	1.71%
Suwannee 2	0.00%	0.09%	0.24%	0.37%	0.16%
Suwannee 3	3.68%	9.26%	8.34%	9.32%	0.00%
Suwannee Plant	2.22%	5.39%	5.24%	5.46%	0.43%
PEF Oil	1.69%	2.63%	3.68%	3.81%	2.93%
NERC Avg. - Oil-Fired Steam	26.74%	18.70%	21.65%	9.23%	NA
PEF Fossil Steam Total (coal & oil fired)	2.73%	3.55%	4.01%	3.02%	3.62%
NERC Avg - Fossil Steam All Fuel Types	8.14%	7.70%	7.59%	7.71%	NA

Table 3: Combined Cycle Equivalent Forced Outage Rate					
	2004	2005	2006	2007	2008
Hines 1	0.47%	2.27%	6.76%	2.40%	0.72%
Hines 2	2.37%	0.97%	1.16%	0.24%	0.27%
Hines 3*	NA	NA	5.62%	0.22%	0.07%
Hines 4**	NA	NA	NA	NA	1.07%
Hines Total	1.44%	1.58%	4.59%	0.74%	0.52%
Tiger Bay	4.87%	4.74%	3.15%	35.11%	42.54%
University of Florida	5.16%	0.75%	0.69%	1.63%	0.60%
PEF CC	2.12%	1.93%	4.31%	5.03%	3.53%
NERC Average - Combined Cycle	8.74%	8.00%	7.92%	8.66%	NA

*Hines 3 began commercial operation in November 2005

Table 4: Coal and Oil-fired Steam Equivalent Availability Rates					
	2004	2005	2006	2007	YTD July 2008
Crystal River 1	80.25%	90.45%	93.19%	81.43%	89.09%
Crystal River 2	85.48%	79.63%	86.42%	76.14%	92.39%
Crystal River 4	91.00%	89.85%	91.51%	93.82%	92.64%
Crystal River 5	94.33%	90.85%	85.58%	91.14%	92.16%
PEF Coal	89.12%	88.15%	88.86%	87.20%	91.86%
NERC Average - Coal-Fired	84.82%	85.44%	85.55%	83.72%	NA
Anclote					
Anclote 1	95.68%	92.64%	85.13%	88.23%	95.95%
Anclote 2	84.60%	88.50%	80.86%	92.49%	76.98%
Anclote Plant	90.15%	90.57%	83.00%	90.38%	86.39%
Bartow					
Bartow 1	92.98%	88.94%	91.09%	90.03%	77.57%
Bartow 2	96.52%	92.99%	96.44%	80.28%	78.25%
Bartow 3	89.62%	70.96%	84.10%	82.92%	85.57%
Bartow Plant	92.38%	81.76%	89.31%	84.15%	81.43%
Suwannee					
Suwannee 1	92.75%	76.61%	81.91%	53.62%	91.37%
Suwannee 2	94.97%	98.85%	81.34%	99.00%	47.56%
Suwannee 3	83.70%	84.73%	78.55%	52.43%	92.20%
Suwannee Plant	88.22%	85.99%	79.92%	62.92%	82.32%
PEF Oil	90.59%	87.71%	84.47%	86.21%	84.66%
NERC Average - Oil-Fired Steam	76.42%	78.15%	80.27%	84.39%	NA
PEF Fossil Steam Total (coal & oil-fired)					
	89.73%	87.96%	87.05%	86.80%	88.94%
NERC Average - Fossil Steam All Fuel Types	84.82%	85.44%	85.55%	84.75%	NA

Table 5: Combined Cycle Equivalent Availability Factor				
	2004	2005	2006	2007
Hines 1	81.74%	90.65%	85.09%	75.49%
Hines 2	93.95%	90.44%	91.53%	90.23%
Hines 3*	NA	NA	92.55%	87.75%
Hines 4**	NA	NA	NA	NA
Hines Total	88.17%	90.54%	89.90%	84.69%
Tiger Bay	89.31%	95.32%	96.51%	66.47%
University of Florida	84.55%	91.78%	89.00%	86.16%
PEF CC	88.22%	91.39%	90.66%	82.68%
NERC Average - Combined Cycle	85.82%	87.31%	87.54%	86.73%

*Hines 3 began commercial operation in November 2005

**Hines 4 began commercial operation in December 2007