

RECEIVED-FPSC

State of Florida



09 MAR 26 2009 Public Service Commission

CAPITOL CIRCLE OFFICE CENTER • 2540 SHUMARD OAK BOULEVARD
TALLAHASSEE, FLORIDA 32399-0850
COMMISSION CLERK

-M-E-M-O-R-A-N-D-U-M-

DATE: March 26, 2009

TO: Office of Commission Clerk (Cole)

FROM: Division of Economic Regulation (Draper, Kummer)
Office of the General Counsel (Young, Brown)

EJD
ED
AB
MCB

RE: Docket No. 080317-EI – Petition for rate increase by Tampa Electric Company.

AGENDA: 04/07/09 – Regular Agenda – Post-Hearing Decision – Participation is Limited to Commissioners and Staff

COMMISSIONERS ASSIGNED: All Commissioners

PREHEARING OFFICER: Skop

CRITICAL DATES: 04/13/09 (8-Month Effective Date)

SPECIAL INSTRUCTIONS: None

FILE NAME AND LOCATION: S:\PSC\ECR\WP\080317A.RCM.DOC

Case Background

This proceeding commenced on August 11, 2008, with the filing of a petition for a permanent rate increase by Tampa Electric Company (TECO or Company). The Company is engaged in business as a public utility providing electric service as defined in Section 366.02, Florida Statutes (F.S.), and is subject to the jurisdiction of the Commission. A hearing was conducted on January 20-21, and 27-30, 2009. At the March 17, 2009, Agenda Conference, the Commission approved an increase to operating revenue of \$104,268,536 for the 2009 projected test year. TECO requested an increase of \$228,167,000.

The Commission also approved an additional increase in base rates, effective January 1, 2010, of \$33,561,370 to recover the cost of the five combustion turbine (CT) units and the Big Bend Rail Facilities, subject to the condition that these investments are needed and in

DOCUMENT NUMBER-DATE

02632 MAR 26 8

FPSC-COMMISSION CLERK

commercial operation by December 31, 2009. The final revenue requirements and step increase calculations are contained in Schedule 1.

This recommendation addresses the issues that were not addressed at the March 17, 2009, Agenda Conference, and which set the final rates (Issues 101, 102, and 107). In Issue 108 the recommendation addresses the Capacity Cost Recovery, Energy Conservation Cost Recovery (ECCR), and Environmental Cost Recovery Clause (ECRC) factors that will change based on the Commission's vote in various cost of service and rate design issues. New Issue 114A addresses how the increase in revenue requirements effective January 1, 2010, be collected from the customers. Based on the Commission vote at the March 17, 2009, Agenda Conference, TECO filed a compliance cost of service study on March 25, 2009, to be used to establish revenue requirements for each rate class and final rates and charges.¹

Staff's recommendation on Issue 86, approved by the Commission on March 17, 2009, establishes the method by which any increase in revenue requirements is allocated to the various customer classes to set new rates. That decision set certain parameters for designing new rates: (1) to the extent possible, consistent with other parameters, the revenue increase should be allocated so as to bring all rate classes as close to parity as practicable; (2) no class should receive an increase greater than 1.5 times the system average increase; and (3) no class should receive a decrease. The final class revenue requirements are shown in Schedule 2.

Several interim steps are necessary to establish final rates. First, to determine the increase by class, the present revenues must be restated to reflect the change in rate structure for the interruptible (IS) class approved in Issue 87. Because production demand costs will now be allocated to the IS class based on its actual measured 12 Coincident Peak load responsibility, demand costs to all other rate classes are reduced. However, the ECCR charge for all classes will increase to reflect the demand-side management (DSM) credits payable to IS customers, in lieu of the reduced base rate. If current revenues are not adjusted to reflect the IS rate restructuring, firm customers will see an increase in their total bills (base rates plus clauses) simply due to the restructuring, even without any change in total revenue requirements.

Second, the unadjusted revenue requirement by class is determined by subtracting the revenues at current rates (determined in Step 1) by class, from the revenue requirement shown in the compliance cost of service study. This unadjusted result must then be evaluated against the parameters set forth in Issue 86. If the increase to any class is greater than 1.5 times the system average increase (11.6 percent), revenue requirements will be shifted to other classes to meet that constraint. Also, since no class is granted a decrease in a general rate increase, the surplus shown for the IS class is reallocated to reduce the increase to other classes.² Class revenue requirements are then adjusted to recognize unbilled revenues (Issue 85) to arrive at the final revenue requirement by rate class.

¹ Charges and credits approved in Issues 93, 104, and 105 have been adjusted consistent with the Compliance Cost study. This adjustment was contemplated in the Commission's vote on these issues on March 17, 2009.

² Staff would note that this apparent surplus for the IS class is likely the result of the one-time change from a discount base rate to the treatment of this rate group as a DSM program. There is no way to know if the credit built into the existing base rate was greater or less than the currently available credit used to adjust current revenues for the structure change, and that relationship determines if the class is shown as under- or over-earning in this analysis.

The final step is to translate the class revenue requirement into actual rates. The total revenue requirement for each rate class is first reduced by the customer charge revenue approved in Issue 100. The proposed energy and demand charges are designed to provide approximately the same percentage increase in energy and demand charge revenues as the overall percentage increase in class revenues. All other rates, charges, and credits reflect the decisions made on March 17, 2009. Final rates, charges, and credits by rate class are contained in Schedule 3.

Pursuant to the Commission vote in Issue 88, TECO also developed rates and charges for the new firm IS and IS standby and supplemental rate schedule. The IS customer charge is based on the approved GSD customer charges for primary and subtransmission level (Issue 100) plus the cost of interruptible equipment. IS service is only provided at primary or higher level. TECO proposed to keep the current IS-1 and IS-3 demand charge of \$1.45 per kW at the same level, while increasing the non-fuel energy charge. The dollar increase in the energy charge will be offset by the per kW DSM credit interruptible customers will now receive under the GSLM-2 and GSLM-3 load management riders. Since the DSM credit is a load factor adjusted credit, increasing the energy charge in lieu of the demand charge will ensure that the base rate component of bills for all IS customers with varying load factors will remain unchanged.

Schedule 5 contains a calculation of TECO's 1,000 kilowatt-hour (kWh) monthly residential bill at both present and recommended rates. While the base rate component of the bill will increase by \$1.45, overall bills will decrease due to projected lower fuel costs for the remainder of 2009. TECO filed a petition for a modification to its fuel and purchased power cost recovery factors in Docket No. 090001-EI, which is also scheduled for the April 7, 2009, Agenda Conference. Staff notes that TECO proposed in its midcourse correction petition to adjust fuel factors by the 2009 estimated over-recovery of \$190 million. Staff recommends in Docket No. 090001-EI that TECO also include the final 2008 true-up of \$35 million in its calculation of the May through December 2009 fuel factors. Thus, the Commission's decision in the fuel docket will impact the final bill calculations.

TECO proposes that the revised fuel factors be effective May 7, 2009, coincident with the Company's base rate changes approved in this docket. Based on the staff-recommended fuel factor, the 1,000 kWh residential bill will decrease from \$128.44 to \$114.06, a \$14.38 decrease.³ Schedule 5 also contains residential bill calculations at various other usage levels based on staff's recommended base rates and fuel adjustment.

Based upon the stipulation approved in Issue 111 in this docket, the revised rates will be effective for meter readings taken on or after May 7, 2009. The Commission has jurisdiction pursuant to Sections 366.06(2) and (4), and 366.071, F. S.

³ Under TECO's proposed fuel factor in Docket No. 090001-EI, the residential bill would be \$116.66.

Discussion of Issues

Issue 101: What are the appropriate demand charges?

Recommendation: The appropriate demand charges are shown in Schedule 3. Staff requests that the Commission grant staff the authority to administratively approve the tariffs filed to implement the rates, charges, and credits presented in Schedule 3. (Draper)

Staff Analysis: The appropriate demand charges are shown in Schedule 3. The demand charges were set at a level that, in combination with the remaining rate components, will result in the recovery of the total revenues allocated to each rate class. Staff requests that the Commission grant staff the authority to administratively approve the tariffs filed to implement the rates presented in this recommendation.

Docket No. 080317-EI

Date: March 26, 2009

Issue 102: What are the appropriate Standby Service charges?

Recommendation: The appropriate Standby Service charges are shown in Schedule 3. (Draper)

Staff Analysis: The appropriate Standby Service charges are shown in Schedule 3. These rates are calculated using the revenue requirement approved, consistent with Commission Order 17159, issued February 6, 1987, in Docket No. 850673-EU, In re: Generic Investigation of Standby Rates for Electric Utilities.

Docket No. 080317-EI
Date: March 26, 2009

Issue 107: What are the appropriate energy charges?

Recommendation: The appropriate energy charges are shown in Schedule 3. (Draper)

Staff Analysis: The appropriate energy charges are shown in Schedule 3. The energy charges were set at a level that, in combination with the remaining rate components, will result in the recovery of the total revenues allocated to each rate class.

Docket No. 080317-EI

Date: March 26, 2009

Issue 108: What changes in allocation and rate design should be made to TECO's rates established in Docket Nos. 080001-EI, 080002-EG, and 080007-EI, to recognize the decisions in various cost of service rate design issues in this docket? (Stipulated)

Recommendation: The methodology for adjusting the affected cost recovery clause factors was stipulated in Issue 108. Pursuant to the stipulation, the revised factors are shown in Schedule 4 and should be approved. The revised factors should become effective May 7, 2009. (Draper)

Staff Analysis: The Commission approved the following language in Issue 108:

The changes in allocation and rate design to TECO's capacity cost recovery factors established in Docket No. 080001-EI, conservation cost recovery factors established in Docket No. 080002-EI, and environmental cost recovery factors established in Docket No. 080007-EI should reflect the Commission vote in Issues 83, 87, and 88. In addition, the capacity cost recovery clause and energy conservation cost recovery clause factors should be recovered on demand basis rather than an energy basis as it is currently done.

The current factors need to be revised for four reasons. First, the Commission approved in Issue 83 a change in cost of service methodology from 12 CP and 1/13 Average Demand (AD) to 12 CP and 25 percent AD to allocate production demand costs. This change in cost of service methodology applies to both base rates and cost recovery clause factors. Second, pursuant to the Commission's approval of staff's recommendation in Issue 87, interruptible customers will now be responsible for their full 12 CP load share of production capacity related costs in base rates and cost recovery clause factors. Third, the DSM credits payable to interruptible customers will be recovered from all rate classes through the ECCR clause. Finally, as approved in Issue 108, the capacity and ECCR factors will be recovered on a demand basis from the demand rate classes rather than an energy basis as it is currently done.

Pursuant to the approved language in Issue 108, TECO revised the factors in the above dockets. Staff has reviewed the calculation and recommends approval of the factors by rate class as shown in Schedule 4. The factors should become effective May 7, 2009.

New Issue 114A: How should the step increase in revenue requirements effective January 1, 2010, be collected from the customers?

Recommendation: The total step increase in revenue requirements should be allocated to all customer classes based on the cost of service study approved in this docket. The energy charge, or energy and demand for demand metered classes, and non-clause recoverable credits should be increased by the percentage increase in each class's revenue requirements. Staff further requests that the Commission grant staff the authority to approve the step increase rates administratively, once the dollar amount of the increase has been verified and staff has confirmed the new plant and facilities are in service by December 31, 2009. (Kummer)

Staff Analysis: The Commission voted to authorize an additional increase in base rates of \$33.5 million, effective January 1, 2010, provided that the investments in the five Combustion Turbines and the Big Bend Rail facilities are in service by December 31, 2009. The Commission further stated that such costs should be allocated to rate classes consistent with the cost of service methodology approved in Issue 83.

In order to retain the relative class relationships developed in the current cost of service study, staff believes the incremental costs should first be allocated to each rate class, consistent with the 12 CP and 25 percent AD cost methodology approved in this docket. Once the dollar increase per class is established, staff recommends that the base rate energy, or energy and demand charges, be increased by the percentage increase in class revenues. In addition, non-clause recoverable credits should also be increased by a similar amount to retain the relationship between the charges and credits approved in the current cost study.

Staff further requests that the Commission grant staff the authority to approve the step increase rates administratively, once the dollar amount of the increase has been verified and staff has confirmed the new plant and facilities are in service by December 31, 2009.

Docket No. 080317-EI

Date: March 26, 2009

Issue 114: Should this docket be closed?

Recommendation: The docket should be closed upon the expiration of the time for filing an appeal. (Young, Brown)

Staff Analysis: The docket should be closed upon the expiration of the time for filing an appeal.

TAMPA ELECTRIC COMPANY
DOCKET NO. 080317-EI
DECEMBER 2009 PROJECTED TEST YEAR
REVENUE REQUIREMENTS CALCULATION

<u>Line No.</u>	<u>As Filed</u>	<u>Commission Adjusted</u>
1. Rate Base	\$3,656,800,000	\$3,437,610,836
2. Overall Rate of Return	<u>8.82%</u>	<u>8.11%</u>
3. Required Net Operating Income (1)x(2)	322,530,000	278,790,239
4. Achieved Net Operating Income	<u>182,970,000</u>	<u>215,013,533</u>
5. Net Operating Income Deficiency (3)-(4)	139,560,000	63,776,706
6. Net Operating Income Multiplier	<u>1.63490</u>	<u>1.63490</u>
7. Operating Revenue Increase (5)x(6)	<u>\$228,167,000</u>	<u>\$104,268,536</u>

TAMPA ELECTRIC COMPANY
DOCKET NO. 080317-EI
CALCULATION OF JANUARY 1, 2010 STEP INCREASE

Step Increase Revenue Requirement

Big Bend Rail Facility	\$7,006,720
May 2009 CTs	7,924,344
September 2009 CTs	<u>18,630,306</u>
Total Step Increase	<u>\$33,561,370</u>

Line No.	Big Bend Rail Facility	May CTs (2 Units)	September CTs (3 Units)	Total CTs (5 Units)
1	Net Plant in Service	\$44,754,000	\$36,125,000	\$94,563,000
2	Rate Of Return	8.11%	8.11%	8.11%
3	Required Return (2x3)	3,629,549	2,929,738	7,669,059
4	O&M Expenses	0	212,000	658,000
5	Depreciation	906,000	1,391,000	4,034,000
6	Taxes Other Than Income	1,039,000	2,226,000	3,227,000
7	Income Taxes (4+5+6) x (-.38575)	(750,284)	(1,477,037)	(3,054,754)
8	Income Tax Effect of Interest [(1) x 3.12% x (-.38575)]	(538,548)	(434,711)	(1,137,925)
	Total NOI Requirement (3+4+5+6+7+8)	<u>4,285,718</u>	<u>4,846,990</u>	<u>11,395,380</u>
9	NOI Multiplier	1.6349	1.6349	1.6349
10	Revenue Requirement (9x10)	<u>\$7,006,720</u>	<u>\$7,924,344</u>	<u>\$18,630,306</u>
11				<u>\$26,554,650</u>

	Amount	Ratio	Cost Rate	Weighted Cost
Common Equity	1,585,140,254	53.97%	N/A	N/A
Long Term Debt	1,344,280,696	45.77%	6.80%	3.11%
Short Term Debt	7,430,567	0.25%	2.75%	0.01%
Total	<u>2,936,851,516</u>	<u>100.00%</u>		<u>3.12%</u>

TAMPA ELECTRIC COMPANY
TEST PERIOD: PROJECTED CALENDAR YEAR 2009
DEVELOPMENT OF TARGET FINAL CLASS SALES REVENUES
IN \$(000)

Line No.	Rate Class	(A)	(B)	(C)	Revision of Base Revenues for IS Restructuring			Present Class Revenue Deficiency / (Surplus)		Allocated Class Sales Revenue Increase		Target Final Class Sales Revenue		
		Cost of Service w/ Other Oper. Rev. Cr. Prod. Cap. Alloc.: 12 CP & 25% AD	Additional Revenue Credits	Class Sales Revenue Requirement (A) - (B)	Present Class Revenue	IS Restructuring Change for Restructured Present Class Revenue	Restructured Present Class Revenue (D) + (E)	\$	%	\$	%	Total	Unbilled Revenue Change	Billed Sales Revenue (K) - (M)
							(C) - (F)	(G) / (F)		(I) / (F)	(F) + (I)			
1			(a)		(b)					(d)		(e)		
2														
3	I. Residential (RS)	512,944	6,094	506,850	454,812	(11,914)	442,898							
4														
5	II. General Service - Non-Demand (GS)	57,783	835	56,948	53,970	(1,366)	52,604							
6														
7														
8	Total: I + II	570,727	6,929	563,798	508,782	(13,280)	495,502	68,296	13.8%	(c)	80,150	12.1%	555,652 (67) 555,719	
9														
10														
11	III. General Service - Demand (GSD)	298,141	188	297,953	286,206	(8,198)	278,008	39,945	15.5%		35,181	13.6%	293,189 (54) 293,243	
12														
13														
14						22,698								
15	IV. Interruptible General Service (IS)	37,374	1	37,373	21,915	(1,134)	20,781	(6,106)	-14.0%		-	0.0%	(g) 43,479 (9) 43,488	
16														
17														
18														
19	V. Lighting Service (LS)													
20	A. Energy	6,147	-	6,147	4,683	(86)	4,597	1,550	33.7%		800	17.4%	(g) 5,396 (2) 5,398	
21	B. Facilities	29,731	-	29,731	36,265	-	36,265	(6,534)	-18.0%		1,022	2.8%	(f) 37,287 - 37,287	
22	Total: V.	35,878	-	35,878	40,948	(86)	40,862	(4,984)	-12.2%		1,822	4.5%	42,683 (2) 42,685	
23														
24														
25														
26														
27	Total	942,120	7,117	935,003	837,851	(0)	837,851	97,152	11.6%		97,152	11.6%	935,003 (132) 935,135	

Notes:

Revenue Reconciliation Check

Present Operating Revenues		
Sales Revenue	\$ 837,851	Per Original Filing
Other Oper. Rev	\$ 27,508	Per Original Filing
Total Pres. Rev	\$ 865,359	
Plus		
Revenue Increase	\$ 104,269	FPSC Decision
Equals Final Revenues	\$ 969,628	
Summary of Final Revenue Development		
Sales Revenue	\$ 935,135	Col. (N), L. 27
Other Oper. Revenue	\$ 27,508	Per Original Filing
Plus Addnl. Serv. Chg. Rev	\$ 7,117	Col. (B), L. 27
Plus Addnl. Unbilled Rev	\$ (132)	Col. (M), L. 27
Equals Final Revenues	\$ 969,628	

(a) Additional revenue credits from increase in service charges allocated in proportion to present service charge revenue allocation in COS

(b) Under the approved IS Rate Restructuring, class revenues must be restated to reflect a revenue neutral implementation of IS as a DSM program with demand credits recoverable through the ECCR clause. The off-setting change in base revenues reflect payments of \$ 22,688,235 to interruptible customers and recovery from all rate classes on the basis of the 12 CP and 25% AD production capacity allocation method

(c) Revenues of rate classes I. and II. have been combined for increase determination since rate charges of each class are set effectively the same.

(d) Class Revenue Increases determined by: (1) assigning FPSC approved revenue changes to class V.B., Lighting Facilities, (2) limiting class V.A., Lighting Energy, to 1.5 times total average percentage increase per FPSC policy, (3) setting no change to class IV. revenues per FPSC policy, and (4) allocating remainder of revenue increase to combined classes I & II and class III. in proportion to these classes revenue deficiencies.

(e) Additional total unbilled revenue amount calculated as total base rate increase of 11.6% applied to total unbilled revenue amount valued at present rates and allocated to rate classes on basis of class MWH requirements. (11.6% x \$1,139) = (\$132)

(f) Reflects revenue effect of lighting facility and maintenance changes in accordance with Issue 93 as approved

(g) Set per Commission Policy. No class should receive an increase greater than 1.5 times the system average percentage increase in total, and no class should receive a decrease

Base rates, other charges, and credits for all rate schedules – effective May 7, 2009

Current Rate Schedule	Type of Charge	Current Rate	Proposed Rate Schedule	Proposed Rate
RS	Customer Facilities Charge:		RS	
	Standard	8.50 \$/Bill		10.50 \$/Bill
	Time-of-Day	11.50 \$/Bill		10.50 \$/Bill
	Energy and Demand Charge:			
	Standard	4.342 ¢/kWh		- ¢/kWh
	First 1,000 kWh	- ¢/kWh		4.287 ¢/kWh
	All additional kWh	- ¢/kWh		5.287 ¢/kWh
	Time-of-Day On-Peak	11.460 ¢/kWh		4.637 ¢/kWh ⁽¹⁾
	Time-of-Day Off-Peak	0.968 ¢/kWh		4.637 ¢/kWh ⁽¹⁾

(1) Assumes Time-of-Day customers transfer to Rate Rider RSVP-1

Current Rate Schedule	Type of Charge	Current Rate	Proposed Rate Schedule	Proposed Rate
GS	Customer Facilities Charge:		GS	
	Standard	8.50 \$/Bill		10.50 \$/Bill
	Standard - Unmetered	7.50 \$/Bill		9.00 \$/Bill
	Time-of-Day	11.50 \$/Bill		12.00 \$/Bill
	Energy and Demand Charge:			
	Standard	4.342 ¢/kWh		4.637 ¢/kWh
	Time-of-Day On-Peak	11.460 ¢/kWh		12.477 ¢/kWh
	Time-of-Day Off-Peak	0.968 ¢/kWh		1.010 ¢/kWh
	Emergency Relay Charge	0.190 ¢/kWh		0.145 ¢/kWh

Current Rate Schedule	Type of Charge	Current Rate	Proposed Rate Schedule	Proposed Rate
TS	Customer Facilities Charge:		TS	
	Standard	8.50 \$/Bill		10.50 \$/Bill
	Energy and Demand Charge:			
	Standard	4.342 ¢/kWh		4.637 ¢/kWh

Current Rate Schedule	Type of Charge	Current Rate	Proposed Rate Schedule	Proposed Rate
GSD	Customer Charge:		GSD	
	Standard Secondary	42 \$/Bill		57 \$/Bill
	Standard Primary	42 \$/Bill		130 \$/Bill
	Standard Subtransmission	42 \$/Bill		930 \$/Bill
	Optional Secondary	42 \$/Bill		57 \$/Bill
	Optional Primary	42 \$/Bill		130 \$/Bill
	Optional Subtransmission	42 \$/Bill		930 \$/Bill
	Time-of-Day Secondary	49 \$/Bill		57 \$/Bill
	Time-of-Day Primary	49 \$/Bill		130 \$/Bill
	Time-of-Day Subtransmission	49 \$/Bill		930 \$/Bill
	Energy Charge:			
	Standard	1.370 ¢/kWh		1.515 ¢/kWh
	Optional	5.210 ¢/kWh		5.564 ¢/kWh
	Time-of-Day On-Peak	2.198 ¢/kWh		2.751 ¢/kWh
	Time-of-Day Off-Peak	1.008 ¢/kWh		1.010 ¢/kWh
	Demand Charge:			
	Standard (all delivery voltages)	7.25 \$/kW		8.06 \$/kW
	Optional (all delivery voltages)	- \$/kW		- \$/kW
	Time-of-Day Billing (all delivery voltages)	2.36 \$/kW		2.72 \$/kW
	Time-of-Day Peak (all delivery voltages)	5.08 \$/kW		5.34 \$/kW
	Transformer Ownership Discount:			
	Standard Primary	(0.36) \$/kW		(0.70) \$/kW
	Standard Subtransmission	(0.59) \$/kW		(1.10) \$/kW
	Optional Primary	(0.36) \$/kW		(1.65) \$/MWh
	Optional Subtransmission	(0.59) \$/kW		(2.87) \$/MWh
	Time-of-Day Primary	(0.36) \$/kW		(0.70) \$/kW
	Time-of-Day Subtransmission	(0.59) \$/kW		(1.10) \$/kW
	Emergency Relay Power Supply Charge:			
	Standard (all delivery voltages)	0.60 \$/kW		0.57 \$/kW
	Optional (all delivery voltages)	0.60 \$/kW		1.45 \$/MWh
	Time-of-Day Billing (all delivery voltages)	0.60 \$/kW		0.57 \$/kW
	Meter Level Discount:			
	Standard Primary	(1.0) %		(1.0) %
	Standard Subtransmission	(2.0) %		(2.0) %
	Optional Primary	(1.0) %		(1.0) %
	Optional Subtransmission	(2.0) %		(2.0) %

Current Rate Schedule	Type of Charge	Current Rate	Proposed Rate Schedule	Proposed Rate
GSLD	Customer Charge:		GSD	
	Standard Secondary	255 \$/Bill		57 \$/Bill
	Standard Primary	255 \$/Bill		130 \$/Bill
	Standard Subtransmission	255 \$/Bill		930 \$/Bill
	Time-of-Day Secondary	255 \$/Bill		57 \$/Bill
	Time-of-Day Primary	255 \$/Bill		130 \$/Bill
	Time-of-Day Subtransmission	255 \$/Bill		930 \$/Bill
	Energy Charge:			
	Standard (All delivery voltages)	1.370 ¢/kWh		1.515 ¢/kWh
	Time-of-Day On-Peak (All delivery voltages)	2.198 ¢/kWh		2.751 ¢/kWh
	Time-of-Day Off-Peak (All delivery voltages)	1.008 ¢/kWh		1.010 ¢/kWh
	Demand Charge:			
	Standard (All delivery voltages)	7.25 \$/kW		8.06 \$/kW
	Time-of-Day Billing (All delivery voltages)	2.36 \$/kW		2.72 \$/kW
	Time-of-Day Peak (All delivery voltages)	5.08 \$/kW		5.34 \$/kW
	Power Factor Charge:			
	Standard (All Delivery voltages)	0.002 \$/kVARh		0.002 \$/kVARh
	Time-of-Day (All Delivery voltages)	0.002 \$/kVARh		0.002 \$/kVARh
	Power Factor Credit:			
	Standard (All Delivery voltages)	(0.001) \$/kVARh		(0.001) \$/kVARh
	Time-of-Day (All Delivery voltages)	(0.001) \$/kVARh		(0.001) \$/kVARh
	Emergency Relay Power Supply Charge:			
	Standard (All Delivery voltages)	0.60 \$/kW		0.57 \$/kW
	Time-of-Day (All Delivery voltages)	0.60 \$/kW		0.57 \$/kW
	Transformer Ownership Discount:			
	Standard Primary	(0.36) \$/kW		(0.70) \$/kW
	Standard Subtransmission	(0.59) \$/kW		(1.10) \$/kW
	Time-of-Day Primary	(0.36) \$/kW		(0.70) \$/kW
	Time-of-Day Subtransmission	(0.59) \$/kW		(1.10) \$/kW
	Meter Level Discount:			
	Standard Primary	(1.0) %		(1.0) %
	Standard Subtransmission	(2.0) %		(2.0) %
	Time-of-Day Primary	(1.0) %		(1.0) %
	Time-of-Day Subtransmission	(2.0) %		(2.0) %

Current Rate Schedule	Type of Charge	Current Rate	Proposed Rate Schedule	Proposed Rate
SBF	Customer Charge:		SBF	
	Standard Secondary	280 \$/Bill		82 \$/Bill
	Standard Primary	280 \$/Bill		155 \$/Bill
	Standard Subtransmission	280 \$/Bill		955 \$/Bill
	Time-of-Day Secondary	280 \$/Bill		82 \$/Bill
	Time-of-Day Primary	280 \$/Bill		155 \$/Bill
	Time-of-Day Subtransmission	280 \$/Bill		955 \$/Bill
	Supplemental Demand Charge:			
	Standard (All delivery voltages)	7.25 \$/kW		8.06 \$/kW
	Time-of-Day Billing (All delivery voltages)	2.36 \$/kW		2.72 \$/kW
	Time-of-Day Peak (All delivery voltages)	5.08 \$/kW		5.34 \$/kW
	Supplemental Energy Charge:			
	Standard (All delivery voltages)	1.370 ¢/kWh		1.515 ¢/kWh
	Time-of-Day On-Peak (All delivery voltages)	2.198 ¢/kWh		2.751 ¢/kWh
	Time-of-Day Off-Peak (All delivery voltages)	1.008 ¢/kWh		1.010 ¢/kWh
	Standby Demand Charge (All):			
	Local Facilities Reservation Plus the greater of	2.66 \$/kW		2.23 \$/kW
	Power Supply Reservation, or	0.87 \$/kW-Mo		1.20 \$/kW-Mo
	Power Supply Demand	0.34 \$/kW-Day		0.48 \$/kW-Day
	Standby Energy Charge:			
	Time-of-Day (All delivery voltages)	0.984 ¢/kWh		1.010 ¢/kWh
	Transformer Ownership Discount:			
	Supplemental			
	Standard Primary	(0.36) \$/kW		(0.70) \$/kW
	Standard Subtransmission	(0.59) \$/kW		(1.10) \$/kW
	Time-of-Day Primary	(0.36) \$/kW		(0.70) \$/kW
	Time-of-Day Subtransmission	(0.59) \$/kW		(1.10) \$/kW
	Standby			
	Time-of-Day Primary	(0.32) \$/kW		(0.58) \$/kW
	Time-of-Day Subtransmission	(0.52) \$/kW		(1.11) \$/kW
	Emergency Relay Power Supply Charge (all):			
	Supplemental	0.60 \$/kW		0.57 \$/kW
	Standby	0.60 \$/kW		0.57 \$/kW
	Power Factor Charge (all):	0.002 \$/kVARh		0.002 \$/kVARh
	Power Factor Credit (all):	(0.001) \$/kVARh		(0.001) \$/kVARh
	Meter Level Discount:			
	Supplemental			
	Standard Primary	(1.0) %		(1.0) %
	Standard Subtransmission	(2.0) %		(2.0) %
	Time-of-Day Primary	(1.0) %		(1.0) %
	Time-of-Day Subtransmission	(2.0) %		(2.0) %
	Standby			
	Time-of-Day Primary	(1.0) %		(1.0) %
	Time-of-Day Subtransmission	(2.0) %		(2.0) %

Current Rate Schedule	Type of Charge	Current Rate	Proposed Rate Schedule	Proposed Rate
IS-1	Customer Charge:		IS	
	Standard Primary	1,000 \$/Bill		622 \$/Bill
	Standard Subtransmission	1,000 \$/Bill		2,372 \$/Bill
	Time-of-Day Primary	1,000 \$/Bill		622 \$/Bill
	Time-of-Day Subtransmission	1,000 \$/Bill		2,372 \$/Bill
	Energy Charge:			
	Standard Primary	1.078 ¢/kWh		2.504 ¢/kWh
	Standard Subtransmission	1.078 ¢/kWh		2.504 ¢/kWh
	Time-of-Day On-peak - Primary	1.078 ¢/kWh		2.504 ¢/kWh
	Time-of-Day On-peak - Subtransmission	1.078 ¢/kWh		2.504 ¢/kWh
	Time-of-Day Off-peak - Primary	1.078 ¢/kWh		2.504 ¢/kWh
	Time-of-Day Off-peak - Subtransmission	1.078 ¢/kWh		2.504 ¢/kWh
	Demand Charge:			
	Standard (all delivery voltages)	1.45 \$/kW		1.45 \$/kW
	Time-of-Day Billing - (All delivery voltages)	- \$/kW		1.45 \$/kW
	Time-of-Day Peak - (All delivery voltages)	- \$/kW		- \$/kW
	Emergency Relay Power Supply Charge (all):	0.60 \$/kW		0.56 \$/kW
	Power Factor Charge (all):	0.002 \$/kVARh		0.002 \$/kVARh
	Power Factor Credit (all):	(0.001) \$/kVARh		(0.001) \$/kVARh
	Transformer Ownership Discount:			
	Standard Primary	- \$/kW		- \$/kW
	Standard Subtransmission	(0.23) \$/kW		(0.40) \$/kW
	Time-of-Day Primary	- \$/kW		- \$/kW
	Time-of-Day Subtransmission	(0.23) \$/kW		(0.40) \$/kW
	Meter Level Discount:			
	Standard Primary	0.0 %		0.0 %
	Standard Subtransmission	(1.0) %		(1.0) %
	Time-of-Day Primary	0.0 %		0.0 %
	Time-of-Day Subtransmission	(1.0) %		(1.0) %

Current Rate Schedule	Type of Charge	Current Rate	Proposed Rate Schedule	Proposed Rate
IS-3	Customer Charge:		IS	
	Standard Primary	1,000 \$/Bill		622 \$/Bill
	Standard Subtransmission	1,000 \$/Bill		2,372 \$/Bill
	Time-of-Day Primary	1,000 \$/Bill		622 \$/Bill
	Time-of-Day Subtransmission	1,000 \$/Bill		2,372 \$/Bill
	Energy Charge:			
	Standard Primary	1.327 ¢/kWh		2.504 ¢/kWh
	Standard Subtransmission	1.327 ¢/kWh		2.504 ¢/kWh
	Time-of-Day On-peak - Primary	1.327 ¢/kWh		2.504 ¢/kWh
	Time-of-Day On-peak - Subtransmission	1.327 ¢/kWh		2.504 ¢/kWh
	Time-of-Day Off-peak - Primary	1.327 ¢/kWh		2.504 ¢/kWh
	Time-of-Day Off-peak - Subtransmission	1.327 ¢/kWh		2.504 ¢/kWh
	Demand Charge:			
	Standard (all delivery voltages)	1.45 \$/kW		1.45 \$/kW
	Emergency Relay Power Supply Charge (all):	0.60 \$/kW		0.56 \$/kW
	Power Factor Charge (all):	0.002 \$/kVARh		0.002 \$/kVARh
	Power Factor Credit (all):	(0.001) \$/kVARh		(0.001) \$/kVARh
	Transformer Ownership Discount:			
	Standard Primary	- \$/kW		- \$/kW
	Standard Subtransmission	(0.23) \$/kW		(0.40) \$/kW
	Time-of-Day Primary	- \$/kW		- \$/kW
	Time-of-Day Subtransmission	(0.23) \$/kW		(0.40) \$/kW
	Meter Level Discount:			
	Standard Primary	0.0 %		0.0 %
	Standard Subtransmission	(1.0) %		(1.0) %
	Time-of-Day Primary	0.0 %		0.0 %
	Time-of-Day Subtransmission	(1.0) %		(1.0) %

Current Rate Schedule	Type of Charge	Current Rate	Proposed Rate Schedule	Proposed Rate
SBI-1	Customer Charge:		SBI	
	Standard Primary	1,025 \$/Bill		647 \$/Bill
	Standard Subtransmission	1,025 \$/Bill		2,397 \$/Bill
	Time-of-Day Primary	1,025 \$/Bill		647 \$/Bill
	Time-of-Day Subtransmission	1,025 \$/Bill		2,397 \$/Bill
	Supplemental Demand Charge:			
	Standard (all delivery voltages)	1.45 \$/kW		1.45 \$/kW
	Time-of-Day Billing - (All delivery voltages)	- \$/kW		1.45 \$/kW
	Time-of-Day Peak - (All delivery voltages)	- \$/kW		- \$/kW
	Supplemental Energy Charge:			
	Standard (all delivery voltages)	1.078 ¢/kWh		2.504 ¢/kWh
	Time-of-Day On-Peak - (All delivery voltages)	1.078 ¢/kWh		2.504 ¢/kWh
	Time-of-Day Off-Peak - (All delivery voltages)	1.078 ¢/kWh		2.504 ¢/kWh
	Standby Demand Charge (all delivery voltages):			
	Local Facilities Reservation	0.95 \$/kW		1.43 \$/kW
	Plus the greater of			
	Power Supply Reservation, or	0.09 \$/kW-Mo		1.19 \$/kW-Mo
	Power Supply Demand	0.03 \$/kW-Day		0.48 \$/kW-Day
	Standby Energy Charge:			
	Time-of-Day (All)	0.961 ¢/kWh		1.000 ¢/kWh
	Transformer Ownership Discount:			
	Supplemental			
	Standard Primary	- \$/kW		- \$/kW
	Standard Subtransmission	(0.23) \$/kW		(0.40) \$/kW
	Time-of-Day Primary	- \$/kW		- \$/kW
	Time-of-Day Subtransmission	(0.23) \$/kW		(0.40) \$/kW
	Standby			
	Time-of-Day Primary	- \$/kW		- \$/kW
	Time-of-Day Subtransmission	(0.21) \$/kW		(0.33) \$/kW
	Emergency Relay Power Supply Charge (all):			
	Supplemental	0.60 \$/kW		0.57 \$/kW
	Standby	0.60 \$/kW		0.57 \$/kW
	Power Factor Charge:	0.002 \$/kVARh		0.002 \$/kVARh
	Power Factor Credit:	(0.001) \$/kVARh		(0.001) \$/kVARh
	Meter Level Discount:			
	Supplemental			
	Standard Primary	0.0 %		0.0 %
	Standard Subtransmission	(1.0) %		(1.0) %
	Time-of-Day Primary	0.0 %		0.0 %
	Time-of-Day Subtransmission	(1.0) %		(1.0) %
	Standby			
	Time-of-Day Primary	0.0 %		0.0 %
	Time-of-Day Subtransmission	(1.0) %		(1.0) %

Current Rate Schedule	Type of Charge	Current Rate	Proposed Rate Schedule	Proposed Rate
SBI-3	Customer Charge:		SBI	
	Standard Primary	1,025 \$/Bill		647 \$/Bill
	Standard Subtransmission	1,025 \$/Bill		2,397 \$/Bill
	Time-of-Day Primary	1,025 \$/Bill		647 \$/Bill
	Time-of-Day Subtransmission	1,025 \$/Bill		2,397 \$/Bill
	Supplemental Demand Charge:			
	Standard (all delivery voltages)	1.45 \$/kW		1.45 \$/kW
	Time-of-Day Billing - (All delivery voltages)	- \$/kW		1.45 \$/kW
	Time-of-Day Peak - (All delivery voltages)	- \$/kW		- \$/kW
	Supplemental Energy Charge:			
	Standard (all delivery voltages)	1.327 ¢/kWh		2.504 ¢/kWh
	Time-of-Day On-Peak - (All delivery voltages)	1.327 ¢/kWh		2.504 ¢/kWh
	Time-of-Day Off-Peak - (All delivery voltages)	1.327 ¢/kWh		2.504 ¢/kWh
	Standby Demand Charge (all delivery voltages):			
	Local Facilities Reservation	0.95 \$/kW		1.43 \$/kW
	Plus the greater of			
	Power Supply Reservation, or	0.09 \$/kW-Mo		1.19 \$/kW-Mo
	Power Supply Demand	0.03 \$/kW-Day		0.48 \$/kW-Day
	Standby Energy Charge:			
	Time-of-Day (All)	0.961 ¢/kWh		1.000 ¢/kWh
	Transformer Ownership Discount:			
	Supplemental			
	Standard Primary	- \$/kW		- \$/kW
	Standard Subtransmission	(0.23) \$/kW		(0.40) \$/kW
	Time-of-Day Primary	- \$/kW		- \$/kW
	Time-of-Day Subtransmission	(0.23) \$/kW		(0.40) \$/kW
	Standby			
	Time-of-Day Primary	- \$/kW		- \$/kW
	Time-of-Day Subtransmission	(0.21) \$/kW		(0.33) \$/kW
	Emergency Relay Power Supply Charge (all):			
	Supplemental	0.60 \$/kW		0.57 \$/kW
	Standby	0.60 \$/kW		0.57 \$/kW
	Power Factor Charge:	0.002 \$/kVARh		0.002 \$/kVARh
	Power Factor Credit:	(0.001) \$/kVARh		(0.001) \$/kVARh
	Meter Level Discount:			
	Supplemental			
	Standard Primary	0.0 %		0.0 %
	Standard Subtransmission	(1.0) %		(1.0) %
	Time-of-Day Primary	0.0 %		0.0 %
	Time-of-Day Subtransmission	(1.0) %		(1.0) %
	Standby			
	Time-of-Day Primary	0.0 %		0.0 %
	Time-of-Day Subtransmission	(1.0) %		(1.0) %

Rates for LS-1 lighting rate schedule

Description	Charge per Unit	
	Fixture	Maintenance
LIGHTING FIXTURES		
COBRA 50 WATT HPS	2.85	2.24
PT 50 WATT HPS	3.59	2.24
COBRA_NEMA 70 WATT HPS	2.89	1.90
COACH PT 70 WATT HPS	4.25	1.90
COBRA_NEMA 100 WATT HPS	3.28	2.10
COBRA 150 WATT HPS	3.77	1.82
COBRA 250 WATT HPS	4.40	2.35
FLOOD 250 WATT HPS	4.85	2.35
COBRA 400 WATT HPS	4.59	2.70
FLOOD 400 WATT HPS	5.15	2.71
MONGOOSE 400 WATT HPS	5.87	2.73
YBOR ARCHWAY 80 x 10 WATT	15.26	16.44
CLASSIC PT 100 WATT HPS	10.70	1.71
CONTEMPORARY PT 100 WATT HPS	7.48	1.93
COLONIAL PT 100 WATT HPS	10.61	1.71
SALEM_STND_PT 100 WATT HPS	8.15	1.71
SHOEBOX 100 WATT HPS	7.23	1.71
SHOEBOX 250 WATT HPS	7.84	2.87
SHOEBOX 400 WATT HPS	8.59	2.20
<i>FLAT DECOR 400 WATT HPS</i>	eliminated	eliminated
SHOEBOX 175 WATT MH	7.18	3.34
SHOEBOX 400 WATT MH	9.04	3.58
SHOEBOX 1000 WATT MH	14.89	7.37
FLOOD 400 WATT MH	7.55	3.63
FLOOD 1000 WATT MH	9.48	7.37
<i>CUBE DECORATIVE 400 WATT MH</i>	eliminated	eliminated
GENERAL PT 175 WATT MH	9.83	3.37
SALEM PT 175 WATT MH	8.47	3.38
COBRA 400 WATT MH	5.44	3.62

LIGHTING POLES	Pole	Maintenance
WOOD 30 FT OH	2.36	0.15
WOOD 30 FT INACCESSIBLE OH	5.44	0.15
WOOD POLE 35 FT OH	2.66	0.15
CONC STD DB 35 FT OH	4.82	0.15
EXISTING POLE UG	4.47	0.31
CONC STD DB 35 FT UG FOR 70_100 WATT	10.23	0.31
CONC STD DB 35 FT UG FOR 150 WATT	13.88	0.31
CONC STD DB 35 FT UG FOR 250_400 WATT	20.98	0.31
ALUM DB 28 FT UG FOR 70_100 WATT	10.64	0.31
ALUM AB 27 FT UG FOR 150 WATT	25.15	0.31
ALUM AB 27 FT UG FOR 250_400 WATT	25.15	0.31
ALUM AB 37 FT UG	36.17	0.31
FIBER PT DB 16 FT UG	6.43	1.17
ALUM PT 10 FT UG	7.07	1.17
ALUM PT HERITAGE UG	17.72	0.99
ALUM PT CAPITOL UG	24.10	0.99
CONC PT WATERFORD UG	19.10	0.13
ALUM PT ALUMINUM UG	15.36	0.99
ALUM PT ARLINGTON UG	eliminated	eliminated
ALUM PT CHARLESTON UG	18.44	0.99
ALUM PT RIVIERA UG	18.56	0.99
COMP PT FRANKLIN DB 16 FT	21.58	0.99
FIBER PT WINSTON UG	12.38	0.99
CONC PT VICTORIAN UG	22.19	0.13
STEEL AB 30 FT UG	35.39	1.52
ALUM AB 30 FT UG	eliminated	eliminated
CONC TALL WATERFORD 35 FT UG	26.01	0.13
CONC STD DB 16 FT UG	14.47	0.13
CONC STD DB 25 OR 30 FT UG	19.44	0.13
CONC STD DB 35 FT UG	21.28	0.31
CONC STD DB 45 FT UG	25.01	0.13
CONC ROUND 23 FT UG	18.43	0.13
WOOD UP TO 45 FT OH	5.99	0.28
CONC UP TO 45 FT OH	9.03	0.28
CHARLESTON HD	20.96	0.99
CHARLESTON BANNER	23.93	0.99
MISCELLANEOUS EQUIPMENT	Bracket/Timer	Maintenance
DUAL PT BRACKET	3.85	0.05
TIMER DEVICE	6.81	1.29

BASE ENERGY CHARGE (¢/KWH)
 CUSTOMER CHARGE (only for metered street lights)

2.385 ¢/kWh
 10.50 \$/Bill

TAMPA ELECTRIC COMPANY
Cost Recovery Factors for the period May through December 2009

Rate Class	Environmental Cost Recovery Factor	Capacity Cost Recovery Factor		Energy Conservation Cost Recovery Factor	
	(c/kwh)	(c/kwh)	(\$/kw)	(c/kwh)	(\$/kw)
RS	0.223	0.541		0.221	
GS, TS	0.223	0.518		0.214	
GSD, SBF					
Secondary	0.223		1.73		0.73
Primary	0.221		1.72		0.73
Transmission	0.219		1.70		0.72
GSD-Optional					
Secondary	0.223	0.411		0.174	
Primary	0.221	0.407		0.172	
Transmission	0.219	0.403		0.171	
IS					
Primary	0.220		1.41		0.61
Transmission	0.218		1.39		0.61
LS 1	0.222	0.158		0.084	

TAMPA ELECTRIC COMPANY
Docket No. 080317-EI
Monthly 1,000 Kilowatt-Hour Residential Electric Bill

	Current	Recommended effective May 7, 2009*	Increase/ Decrease
Customer Charge	\$8.50	\$10.50	\$2.00
Energy Charge	\$43.42	\$42.87	(\$0.55)
Fuel and Purchased Power	\$64.16	\$47.99	(\$16.17)
Energy Conservation Cost Recovery	\$1.06	\$2.21	\$1.15
Environmental Cost Recovery	\$2.29	\$2.23	(\$0.06)
Capacity Cost Recovery	\$5.80	\$5.41	(\$0.39)
Gross Receipts Taxes	\$3.21	\$2.85	(\$0.36)
Total Monthly Bill	\$128.44	\$114.06	(\$14.38)

* The fuel charge reflects the staff-recommended charge in Docket No. 090001-EI, TECO's petition for a midcourse correction, to be decided at the April 7, 2009, Agenda Conference. Under TECO's proposed midcourse correction, the bill would be \$116.66.

Tampa Electric Company				
Total Residential Bill Comparisons by kWh Usage				
Usage	Current	Recommended effective May 7, 2009*	Difference From Current	
			\$	%
1,000 kWh	\$128.44	\$114.06	-\$14.38	-11.2%
1,250 kWh	\$160.93	\$145.02	-\$15.91	-9.9%
1,500 kWh	\$193.44	\$175.97	-\$17.47	-9.0%
2,000 kWh	\$258.42	\$237.87	-\$20.55	-8.0%
2,500 kWh	\$323.42	\$299.77	-\$23.65	-7.3%
3,000 kWh	\$388.40	\$361.67	-\$26.73	-6.9%

*Bills are calculated based on the staff-recommended fuel charge in Docket No. 090001-EI.