

Marguerite McLean

100000-07

From: Stright, Lisa [Lisa.Stright@pgnmail.com]
Sent: Friday, April 09, 2010 9:01 AM
To: Filings@psc.state.fl.us
Cc: Burnett, John
Subject: PEF Quarterly Bulk Power Report - Undocketed
Attachments: FINAL - Bulk Power '10 1st Qtr Rpt.pdf

This electronic filing is made by:

John T. Burnett
299 First Avenue North
St. Petersburg, FL 33733
(727) 820-5184
john.burnett@pgnmail.com

Undocketed

On behalf of Progress Energy Florida

Consisting of 2 pages.

**The attached document for filing is PEF's
Quarterly Bulk Power Report for the period
ending March 31, 2010.**

Lisa Stright
Regulatory Analyst - Legal Dept.
Progress Energy Svc Co.
106 E. College Ave., Suite 800
Tallahassee, FL 32301
direct line: (850) 521-1425
VN 230-5095
lisa.stright@pgnmail.com

DOCUMENT NUMBER-DATE

02665 APR -9 9

FPSC-COMMISSION CLERK

4/9/2010



JOHN T. BURNETT
ASSOCIATE GENERAL COUNSEL
PROGRESS ENERGY SERVICE COMPANY, LLC

April 9, 2010

VIA ELECTRONIC FILING

100000-07

Ms. Ann Cole, Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Re: Quarterly report of customer interruptions and curtailments.

Dear Ms. Cole:

Pursuant to Commission Rule 25-6.018(3), F.A.C., enclosed for filing on behalf of Progress Energy Florida, Inc., is the quarterly report of customer interruptions and curtailments for the quarter ending March 31, 2010.

Please acknowledge your receipt of this filing as provided in the Commission's electronic filing procedures. Thank you for your assistance in this matter.

Respectfully,

s/ John T. Burnett

JTB/lms

299 First Avenue North (33701) . Post Office Box 14042 (33733) . St. Petersburg, Florida
Phone: 727.820.5184 . Fax: 727.820.5249 . Email: john.burnett@pepmail.com

DOCUMENT NUMBER-DATE
02885 APR-9 9

FPSC-COMMISSION CLERK



Customer Interruption and Curtailment (Bulk Power) Quarterly Report (1st Quarter 2010)

Date: April 9, 2010

Reason for Interruption	Implemented IS/CS due to extreme cold weather conditions
Date	January 10, 2010
Time	8:30am
Duration of Interruption	30 minutes (08:30 – 09:00)
Amount of Load shed	100 MW

Reason for Interruption	Implemented IS/CS due to extreme cold weather conditions
Date	January 11, 2010
Time	5:38am
Duration of Interruption	3 hours 46 minutes (05:38 – 09:24)
Amount of Load shed	221 MW