



April 28, 2010

RECEIVED-FPSC

10 APR 28 PM 2:34

COMMISSION
CLERK

VIA HAND DELIVERY

Ms. Ann Cole, Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Re: *Petition for approval of amended standard offer contract, by Progress Energy Florida;
Docket No. 100168-EI*

Dear Ms. Cole:

On April 1, 2010, Progress Energy Florida, Inc.'s ("PEF") filed its Petition for approval of its Standard Offer Contract. On Tariff Sheet 9.415, PEF incorrectly designated its avoided unit as Suwannee P4 when it should have been an Undesignated CT Unit. As a matter of clarification, PEF hereby submits its REVISED Tariff Sheet 9.415 in both legislative and clean copy formats. The REVISED documents attached are to replace the originals filed on April 1, 2010.

Thank you for your assistance in this matter. Please feel free to call me at (727) 820-5184 should you have any questions.

- COM _____
 - APA _____
 - ECR _____
 - GCL 2
 - RAD** 5
 - SSC _____
 - ADM _____
 - OPC _____
 - CLK _____
- JTB/lms
— Attachments

Sincerely,

John T. Burnett cms
John T. Burnett

DOCUMENT NUMBER-DATE

03438 APR 28 09

FPSC-COMMISSION CLERK

REVISED Tariff Sheet 9.415
(Legislative version)

3. Term of Contract

Except as otherwise provided herein, this Contract shall become effective immediately upon its execution by the Parties and shall end at 12:01 a.m. on the Termination Date, (the "Term") unless terminated earlier in accordance with the provisions hereof. Notwithstanding the foregoing, if the Capacity Delivery Date of the Facility is not accomplished by the RF/QF before the Avoided Unit In-Service Date (or such later date as may be permitted by PEF pursuant to Section 7), this Contract shall be rendered null and void and PEF's shall have no obligations under this Contract.

4. Minimum Specifications and Milestones

As required by FPSC Rule 25-17.0832(4)(e), the minimum specifications pertaining to this Contract and milestone dates are as follows:

Avoided Unit	<u>Suwannee P4Undesignated CT</u>
Avoided Unit Capacity	178 MW
Avoided Unit In-Service Date	June 1, 2014 <u>2018</u>
Avoided Unit Heat Rate	10,760-648 BTU/kWh
Avoided Unit Variable O&M	0.9151.507¢ per kWh in mid- 2014 <u>2018</u> dollars escalating annually at 2.25 <u>00</u> %
Avoided Unit Life	25 years
Capacity Payments begin	Avoided Unit In-Service Date unless Option B, or D is selected <u>or amended in Appendix E</u>
Termination Date	May 31, 2024 <u>2028</u> (10 years) unless amended in Appendix E
Minimum Performance Standards – On Peak Availability Factor*	94%
Minimum Performance Standards – Off Peak Availability Factor	94%
Minimum Availability Factor Required to qualify for a Capacity payment	74%
Expiration Date	April 1, 2010 <u>2011</u>
Completed Permits Date	June 1, 2013 <u>2017</u>
Exemplary Early Capacity Payment Date	January 1, 2010 <u>2011</u>

* RF/QF performance shall be as measured and/or described in Appendix A.

REVISED Tariff Sheet 9.415
(Clean copy)

3. Term of Contract

Except as otherwise provided herein, this Contract shall become effective immediately upon its execution by the Parties and shall end at 12:01 a.m. on the Termination Date, (the "Term") unless terminated earlier in accordance with the provisions hereof. Notwithstanding the foregoing, if the Capacity Delivery Date of the Facility is not accomplished by the RF/QF before the Avoided Unit In-Service Date (or such later date as may be permitted by PEF pursuant to Section 7), this Contract shall be rendered null and void and PEF's shall have no obligations under this Contract.

4. Minimum Specifications and Milestones

As required by FPSC Rule 25-17.0832(4)(e), the minimum specifications pertaining to this Contract and milestone dates are as follows:

Avoided Unit	Undesignated CT
Avoided Unit Capacity	178 MW
Avoided Unit In-Service Date	June 1, 2018
Avoided Unit Heat Rate	10,648 BTU/kWh
Avoided Unit Variable O&M	1.507¢ per kWh in mid-2018 dollars escalating annually at 2.00%
Avoided Unit Life	25 years
Capacity Payments begin	Avoided Unit In-Service Date unless Option B, or D is selected or amended in Appendix E
Termination Date	May 31, 2028 (10 years) unless amended in Appendix E
Minimum Performance Standards – On Peak Availability Factor*	94%
Minimum Performance Standards – Off Peak Availability Factor	94%
Minimum Availability Factor Required to qualify for a Capacity payment	74%
Expiration Date	April 1, 2011
Completed Permits Date	June 1, 2017
Exemplary Early Capacity Payment Date	January 1, 2011

* RF/QF performance shall be as measured and/or described in Appendix A.