

GOLD COAST UTILITY CORP.

P.O. Box 9076 • Lakeshore, Florida 33854 • (863) 696-0504 • Fax (863) 696-0504 • e-mail: lwuco@msn.com

100000-07

DATE: June 21, 2010

PRECAUTIONARY BOIL WATER NOTICE

TO: ALL RESIDENTS OF THE NALCREST, LAKESHORE AREA
COMMUNITIES INCLUDING GRANADA CONDOS, WALDEN
SHORES MHP, AND VILLAGE GREEN APTS.

COMMISSIONER
CLERK

10 JUN 24 AM 8:59

RECEIVED-FPSC

A Low Chlorine residual was EXPERIENCED ON **June 21**. The cause of this problem was a malfunction in the Chlorination system at the water plant. We are working expeditiously to correct this problem.

AS A PRECAUTION, WE ADVISE THAT ALL WATER USED FOR DRINKING OR COOKING BE BOILED. A ROLLING BOIL OF ONE MINUTE IS SUFFICIENT. AS AN ALTERNATIVE BOTTLED WATER MAY BE USED.

THIS "PRECAUTIONARY BOIL WATER NOTICE" WILL REMAIN IN EFFECT UNTIL A BACTERIOLOGICAL SURVEY SHOWS THAT THE WATER IS SAFE TO DRINK.

RESIDENTS WILL BE NOTIFIED WHEN TESTING IS COMPLETE AND BOIL WATER NOTICE IS RESCINDED.

ANY QUESTIONS OR CONCERNS SHOULD BE DIRECTED TO ME AT 696-0504.

Nathan Eckstein
Facility Supervisor
GOLD COAST UTILITY CORP.

CC: FILE
POLK COUNTY HEALTH UNIT – ENVIRONMENTAL SECTION

DOCUMENT NUMBER-DATE

05246 JUN 24 2010

FPSC-001 P.001111.01