

State of Florida



Public Service Commission

CAPITAL CIRCLE OFFICE CENTER • 2540 SHUMARD OAK BOULEVARD
TALLAHASSEE, FLORIDA 32399-0850

RECEIVED-FPSC

11 JUN 16 PM 1:10

-M-E-M-O-R-A-N-D-U-M-

COMMISSION
CLERK

DATE: June 16, 2011
TO: Ann Cole, Office of Commission Clerk
FROM: Robert Simpson, Engineering Specialist II, Division of Economic Regulation *RS*
RE: Docket No. 100126-WU; Application for increase in water rates in Marion County by C.F.A.T. H2O, Inc.

Attached is email correspondence with Mr. Charles DeMenzes regarding the rated capacity of the two wells at CFAT's water treatment plant. Please add this copy of email documentation to the docket.

Should you have any questions regarding this matter, feel free to contact me.

Attachments

DOCUMENT NUMBER-DATE

04136 JUN 16 =

FPSC-COMMISSION CLERK

Robert Simpson

From: Charlie DeMenzes [charlie@altfo.com]

Sent: Friday, May 27, 2011 7:42 AM

To: Robert Simpson

Subject: RE: Docket No. 100126-CFAT

OK Robert I finally resolved the following.

1. In 2009 we had 6 general service water accounts which consisted of two (2) in Hilltop Manor which were laundry rooms and two (2) in Landfair which was a Church and a meter for irrigation. The Gas Station also had two (2) meters, one for the Store and one for fire hydrants.
2. The wells are both 10hp and the GPM is 250 per minute as it has very little TDH since it goes into a ground storage tank.

I hope this answers your questions. I will obtain the pump records from the well company that installed the latest well and forward it to you if you want.

Charles deMenzes

From: Robert Simpson [mailto:RSimpson@PSC.STATE.FL.US]

Sent: Thursday, May 26, 2011 3:02 PM

To: Charles DeMenzes

Subject: Docket No. 100126-CFAT

Mr. DeMenzes:

Staff is requesting that you provide information regarding the rated capacity of the two wells at your treatment plant. Please, add some documentation to support that information.

Sincerely,

Robert Simpson
Engineering Specialist
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399
Phone: (850) 413-7001
Fax: (850) 413-7002

6/14/2011

DOCUMENT NUMBER-DATE

04136 JUN 16 =

FPSC-COMMISSION CLERK