

**Dorothy Menasco**

110000-0T

**From:** Wells, Kathy [Kathy.Wells@fpl.com]  
**Sent:** Thursday, July 07, 2011 4:03 PM  
**To:** Filings@psc.state.fl.us  
**Cc:** Marshall Willis  
**Subject:** Florida Power & Light Company's 2011 Report on Storm Hardening/Preparedness and Distribution Reliability  
**Attachments:** 7.7.11 Transmittal to Cole (Reconciliation).pdf

Electronic Filing

a. Person responsible for this electronic filing:

Scott A. Goorland, Esq.  
 700 Universe Boulevard  
 Juno Beach, FL 33408  
 561-304-5639  
[scott.goorland@fpl.com](mailto:scott.goorland@fpl.com)

b. Florida Power &amp; Light Company's 2011 Status/Update report on Storm Hardening/Preparedness and Distribution Reliability

c. Documents are being filed on behalf of Florida Power &amp; Light Company.

d. There are a total of 2 pages in the attached document.

e. The document attached for electronic filing is Florida Power &amp; Light Company's Reconciliation of Adjusted with Exclusions page in connection with revisions to pages 107-112 of the 2010 Distribution Reliability Report.

Thank you for your attention and cooperation to this request.

Kathy J. Wells, CP  
 Certified Paralegal  
 Sr. Legal Assistant to  
 John T. Butler, Esq., Managing Attorney  
 Kenneth M. Rubin, Esq., Senior Attorney  
 Scott A. Goorland, Esq., Principal Attorney  
 Maria J. Moncada, Esq., Principal Attorney  
 Florida Power & Light Company  
 700 Universe Blvd.  
 Juno Beach, FL 33408  
 Direct: 561-304-5661  
 Fax: 561-691-7135  
 E-mail: [kathy.wells@fpl.com](mailto:kathy.wells@fpl.com)

The transmission is intended to be delivered only to the named addressee(s) and may contain information that is confidential and/or legally privileged. If this information is received by anyone other than the named addressee(s), the recipient should immediately notify the sender by E-MAIL and by telephone (561) 304-5661 and permanently delete the original and any copy, including printout of the information. In no event shall this material be read, used, copied, reproduced, stored or retained by anyone other than the named addressee(s), except with the express consent of the sender or the named addressee(s).

DOCUMENT NUMBER-DATE

04656 JUL -7 =

FPSC-COMMISSION CLERK

7/7/2011



Florida Power & Light Company, P. O. Box 14000, Juno Beach, FL 33408-0420  
Law Department

Scott A. Goorland  
Principal Attorney  
Florida Power & Light Company  
700 Universe Boulevard  
Juno Beach, FL 33408-0420  
(561) 304-5633  
(561) 691-7135 (Facsimile)  
E-mail: scott.goorland@fpl.com

July 7, 2011

**-VIA ELECTRONIC DELIVERY -**

110000-OT

Ms. Ann Cole  
Commission Clerk  
Florida Public Service Commission  
2540 Shumard Oak Blvd.  
Tallahassee, FL 32399-0850


**Re: Florida Power & Light Company's 2011 Status/Update report on Storm  
Hardening/Preparedness and Distribution Reliability**

Dear Ms. Cole:

On July 5, 2010, FPL filed revisions to its 2010 Distribution Reliability Report, originally filed on March 2, 2011. On July 6, 2011, Commission Staff requested a revised "Reconciliation of Adjusted with Exclusion to Actual Reliability Indices" page. On behalf of Florida Power & Light Company ("FPL"), enclosed for filing is FPL's revised "Reconciliation of Adjusted with Exclusion to Actual Reliability Indices" page in connection with revisions to pages 107-112 of the 2010 Distribution Reliability Report.

If there are any questions regarding this transmittal, please contact me at 561-304-5633.

Sincerely,

  
Scott A. Goorland

Enclosures

cc: Marshall Willis, Director, Division of Economic Regulation

DOCUMENT NUMBER-DATE

04656 JUL -7 =

an FPL Group company

FPSC-COMMISSION CLERK

**Reconciliation of Adjusted with Exclusions to Actual Reliability Indices**

FPL      March 1, 2011 Filing      Revised July 1, 2011

Index	CMI	CI	CME	CEMIS	Minutes	N	C	SAIDI	SAIFI	MAIFie	CEMIS	CAIDI
	(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	
								(1)/(7)	(2)/(7)	(3)/(7)	(4)/(7)	(1)/(2)
Filed Actual	366,723,074	4,354,064	42,306,178	35,559	22,338,488	105,037	4,491,878	81.6	0.97	9.4	0.8%	84.2
Filed Adjusted (a)	347,295,219	4,138,841	40,688,741	33,559	20,981,189	95,654	4,491,878	77.3	0.92	9.1	0.7%	83.9
Sum of Exclusions	19,427,855	215,223	0	0	1,407,299	9,383	4,491,878					
Calc Actual	366,723,074	4,354,064	40,688,741	33,559	22,388,488	105,037	4,491,878					

**Data Check against Filed Totals (Calc Total - Filed Actuals)**

Difference - see notes (a) & (b) below	OK	OK	-1,617,437 b	-2,000 b	OK	OK
---	----	----	-----------------	-------------	----	----

**Exclusions Details**

Generation						
Cust Req.	2,977,856	72,628	n/r	n/r	198,404	1,349
Planned	10,290,052	74,815	n/r	n/r	884,770	6,601
Transmission (a)	7,520,091	264,506				192
Other	n/r	n/r	n/r	n/r	n/r	n/r
Substation Events	n/r	n/r	n/r	n/r	n/r	n/r
Weather Total	6,159,947	67,780	0	0	324,125	1,433
List Events:						
Verified Tomadoes	2,525,920	26,063			102,628	430
Tropical Storm	3,634,027	41,717			221,497	1,003
			n/r	n/r		
			n/r	n/r		

a: Adjusted values exclusions do not include Transmission exclusions.

b: Our current reporting mechanisms do not allow us obtain detailed exclusions for this indicator.

DOCUMENT NUMBER-DATE

04656 JUL-7 =

FPSC-COMMISSION CLERK